

Equipment code : FAS

Machine Name : Fire Alarm testing weekly

Location : Control room

DESCRIPTION	Done	Result	Remark
Control module			
Test All Button operation and check lamp			
1 Test Reset, Alarm Silence, Panel Silence, Alarm, Sup, Trouble, Monitor, Detail, Command Menu, Numeric 0-9, Back, Enter, Previous and Next		☒ Normal ☐ Abnormal	
Check Lamp			
2 Check Power, Test, CPU Fail, Gnd fault, Disable,		☒ Normal ☐ Abnormal	
3 Check Display panel		☒ Normal ☐ Abnormal	
4 Check Present Time & Date		☒ Normal ☐ Abnormal	
Telephone module			
Test Button			
5 Test Connect, Disconnect		☒ Normal ☐ Abnormal	
6 Check Display panel		☒ Normal ☐ Abnormal	
7 Test Red Telephone condition		☒ Normal ☐ Abnormal	
8 Test Black Telephone no.1,2 condition		☒ Normal ☐ Abnormal	
9 Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Battery Cabinet			
# Check Voltage battery 24Vdc	24.0v	☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Graphic fire alarm at Front office room			
# Check LED lamp		☒ Normal ☐ Abnormal	
# Test Lamp test button		☒ Normal ☐ Abnormal	
# Test Off buzzer button		☒ Normal ☐ Abnormal	
# Test Buzzer speaker		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
# Check cable and connection		☒ Normal ☐ Abnormal	
Power Supply cabinet at Front office room			
# Check Voltage power supply 220Vac		☒ Normal ☐ Abnormal	220Vac
# Check Voltage battery 24Vdc		☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Test Sequence fire alarm			
# Test Smoke detector in guest room no. 516 Code at display		☐ Normal ☐ Abnormal	
# Test Smoke detector Zone Location Floor Code at display		☐ Normal ☐ Abnormal	
# Test Manual pull station ZoneLocation Floor Code at display		☐ Normal ☐ Abnormal	
# Test Fire Fighter Telephone ZoneLocation Floor Code at display		☐ Normal ☐ Abnormal	
# Trouble point code			
Remark		Check By : <u>Barc</u> Date : <u>4/12/23</u>	

W = Weekly

Equipment code : FAS

Machine Name : Fire Alarm testing weekly

Location : Control room

DESCRIPTION	Done	Result	Remark
Control module			
Test All Button operation and check lamp			
1 Test Reset, Alarm Silence, Panel Silence, Alarm, Sup, Trouble, Monitor, Detail, Command Menu, Numeric 0-9 , Back , Enter, Previous and Next		☒ Normal ☐ Abnormal	
Check Lamp			
2 Check Power, Test, CPU Fail, Gnd fault, Disable,		☒ Normal ☐ Abnormal	
3 Check Display panel		☒ Normal ☐ Abnormal	
4 Check Present Time & Date		☒ Normal ☐ Abnormal	
Telephone module			
Test Button			
5 Test Connect, Disconnect		☒ Normal ☐ Abnormal	
6 Check Display panel		☒ Normal ☐ Abnormal	
7 Test Red Telephone condition		☒ Normal ☐ Abnormal	
8 Test Black Telephone no.1,2 condition		☒ Normal ☐ Abnormal	
9 Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Battery Cabinet			
# Check Voltage battery 24Vdc	23.8	☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Graphic fire alarm at Front office room			
# Check LED lamp		☒ Normal ☐ Abnormal	
# Test Lamp test button		☒ Normal ☐ Abnormal	
# Test Off buzzer button		☒ Normal ☐ Abnormal	
# Test Buzzer speaker		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
# Check cable and connection		☒ Normal ☐ Abnormal	
Power Supply cabinet at Front office room			
# Check Voltage power supply 220Vac		☒ Normal ☐ Abnormal	220Vac
# Check Voltage battery 24Vdc		☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Test Sequence fire alarm			
# Test Smoke detector in guest room no. 325 Code at display _____		☒ Normal ☐ Abnormal	
# Test Smoke detector Zone Location _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Test Manual pull station ZoneLocation _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Test Fire Fighter Telephone ZoneLocation _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Trouble point code _____			
Remark	Check By : <u> </u> Date : <u>14-12-2023</u>		

W = Weekly

Equipment code : FAS

Location : Control room

Machine Name : Fire Alarm testing weekly

DESCRIPTION	Done	Result	Remark
Control module			
Test All Button operation and check lamp			
1 Test Reset, Alarm Silence, Panel Silence, Alarm, Sup, Trouble, Monitor, Detail, Command Menu, Numeric 0-9 , Back , Enter, Previous and Next		☒ Normal ☐ Abnormal	
Check Lamp			
2 Check Power, Test, CPU Fail, Gnd fault, Disable,		☒ Normal ☐ Abnormal	
3 Check Display panel		☒ Normal ☐ Abnormal	
4 Check Present Time & Date		☒ Normal ☐ Abnormal	
Telephone module			
Test Button			
5 Test Connect, Disconnect		☒ Normal ☐ Abnormal	
6 Check Display panel		☒ Normal ☐ Abnormal	
7 Test Red Telephone condition		☒ Normal ☐ Abnormal	
8 Test Black Telephone no.1,2 condition		☒ Normal ☐ Abnormal	
9 Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Battery Cabinet			
# Check Voltage battery 24Vdc	23.4	☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Graphic fire alarm at Front office room			
# Check LED lamp		☒ Normal ☐ Abnormal	
# Test Lamp test button		☒ Normal ☐ Abnormal	
# Test Off buzzer button		☒ Normal ☐ Abnormal	
# Test Buzzer speaker		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
# Check cable and connection		☒ Normal ☐ Abnormal	
Power Supply cabinet at Front office room			
# Check Voltage power supply 220Vac		☒ Normal ☐ Abnormal	220Vac
# Check Voltage battery 24Vdc		☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Test Sequence fire alarm			
# Test Smoke detector in guest room no. <u>210</u> Code at display _____		☒ Normal ☐ Abnormal	
# Test Smoke detector Zone Location _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Test Manual pull station ZoneLocation _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Test Fire Fighter Telephone ZoneLocation _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Trouble point code _____			
Remark	Check By : <u>EM</u> Date : <u>21-12-66</u>		

W = Weekly

Equipment code : FAS

Machine Name : Fire Alarm testing weekly

Location : Control room

DESCRIPTION	Done	Result	Remark
Control module			
Test All Button operation and check lamp			
1 Test Reset, Alarm Silence, Panel Silence, Alarm, Sup, Trouble, Monitor, Detail, Command Menu, Numeric 0-9, Back, Enter, Previous and Next		☒ Normal ☐ Abnormal	
Check Lamp			
2 Check Power, Test, CPU Fail, Gnd fault, Disable,		☒ Normal ☐ Abnormal	
3 Check Display panel		☒ Normal ☐ Abnormal	
4 Check Present Time & Date		☒ Normal ☐ Abnormal	
Telephone module			
Test Button			
5 Test Connect, Disconnect		☒ Normal ☐ Abnormal	
6 Check Display panel		☒ Normal ☐ Abnormal	
7 Test Red Telephone condition		☒ Normal ☐ Abnormal	
8 Test Black Telephone no.1,2 condition		☒ Normal ☐ Abnormal	
9 Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Battery Cabinet			
# Check Voltage battery 24Vdc	24	☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Graphic fire alarm at Front office room			
# Check LED lamp		☒ Normal ☐ Abnormal	
# Test Lamp test button		☒ Normal ☐ Abnormal	
# Test Off buzzer button		☒ Normal ☐ Abnormal	
# Test Buzzer speaker		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
# Check cable and connection		☒ Normal ☐ Abnormal	
Power Supply cabinet at Front office room			
# Check Voltage power supply 220Vac		☒ Normal ☐ Abnormal	220Vac
# Check Voltage battery 24Vdc		☒ Normal ☐ Abnormal	> 24Vdc
# Test Battery backup by turn off power supply 220Vac		☒ Normal ☐ Abnormal	
# Check cable and connection		☒ Normal ☐ Abnormal	
# Clean Cabinet		☒ Clean ☐ Not Clean	
Test Sequence fire alarm			
# Test Smoke detector in guest room no. <u>608</u> Code at display _____		☒ Normal ☐ Abnormal	
# Test Smoke detector Zone Location _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Test Manual pull station Zone Location _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Test Fire Fighter Telephone Zone Location _____ Floor _____ Code at display _____		☐ Normal ☐ Abnormal	
# Trouble point code _____			
Remark	Check By : <u>Gane</u> Date : <u>28/12/23</u>		

W = Weekly