



บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6607-WW2338
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: July 13, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: July 14, 2023
Sampling Method	: Grab Sampling	Analytical Date	: July 14-21, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: July 24, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 01.10 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.2	-
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	19.2	-
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	42.8	-
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF, Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน 2-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT

Customer Name : Juristic person Life @ Sukhumvit
Project Name : Life @ Sukhumvit
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.
Sampling Point : Waste water collect.
GPS. Coordinate : 47P 0671854 E 1517007 N
Sampling Method : Grab Sampling
Sampling By : TNP ENVIRONMENT CO., LTD
Sampling Name : Mr. Pakin Srisawat
Registered No. : -


Customer Code : W66019
Sample No : 6607-WW2338
Sample Type : Waste Water
Sampling Date : July 13, 2023
Received Date : July 14, 2023
Analytical Date : July 17-19, 2023
Report Date : July 24, 2023
Sampling Time : 01.10 p.m.

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	APHA : 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-๓๑๘
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6607-WW2339
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: July 13, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: July 14, 2023
Sampling Method	: Grab Sampling	Analytical Date	: July 14-21, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: July 24, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 01.19 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.0	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	31.0	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	44.5	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rd ed. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน 2-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6607-WW2339
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: July 13, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: July 14, 2023
Sampling Method	: Grab Sampling	Analytical Date	: July 17-19, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: July 24, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 01.19 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	APHA : 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rd ed. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6607-WW2340
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: July 13, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: July 14, 2023
Sampling Method	: Grab Sampling	Analytical Date	: July 14-21, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: July 24, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 01.25 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.3	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	<5.0	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	4.0	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Clear and Setiment.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน 2-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6607-WW2340
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: July 13, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: July 14, 2023
Sampling Method	: Grab Sampling	Analytical Date	: July 17-19, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: July 24, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 01.25 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	APHA : 9221 E	540	-
Sample Condition		Clear and Setiment.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6608-WW2755
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: August 25, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: August 28, 2023
Sampling Method	: Grab Sampling	Analytical Date	: August 28-September 05, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: September 15, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.36 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH@25°C ⁽¹⁾	-	Electrometric Method	7.3	-
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	27.9	-
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	36.4	-
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.






ANALYSIS REPORT

Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6608-WW2755
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: August 25, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: August 28, 2023
Sampling Method	: Grab Sampling	Analytical Date	: August 29-31, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: September 15, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.36 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	APHA : 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark (1) : Analysis by Environment & Laboratory Co.,Ltd Registered Laboratory No. ๖-029
(2) : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ว-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6608-WW2756
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: August 25, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: August 28, 2023
Sampling Method	: Grab Sampling	Analytical Date	: August 28-September 05, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: September 15, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.38 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.0	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	20.5	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	31.4	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT

Customer Name : Juristic person Life @ Sukhumvit
Project Name : Life @ Sukhumvit
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.
Sampling Point : Wastewater treatment system. (effluent)
GPS. Coordinate : 47P 0671854 E 1517007 N
Sampling Method : Grab Sampling
Sampling By : TNP ENVIRONMENT CO., LTD
Sampling Name : Mr. Pakin Srisawat
Registered No. : -

Customer Code : W66019
Sample No : 6608-WW2756
Sample Type : Waste Water
Sampling Date : August 25, 2023
Received Date : August 28, 2023
Analytical Date : August 29-31, 2023
Report Date : September 15, 2023
Sampling Time : 02.38 p.m.

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	APHA : 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark (1) : Analysis by Environment & Laboratory Co.,Ltd Registered Laboratory No. ๖-029
(2) : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.



ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6608-WW2757
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: August 25, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: August 28, 2023
Sampling Method	: Grab Sampling	Analytical Date	: August 28–September 05, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: September 15, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.45 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.8	5–9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103–105 °C	10.0	≤20
Biochemical Oxygen Demand	mg/L	5–Day BOD Test, Membrane Electrode Method	<2.0	≤30
Fat, Oil and Grease	mg/L	Liquid–Liquid, Partition–Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Clear and Setiment.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.






ANALYSIS REPORT

Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6608-WW2757
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: August 25, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: August 28, 2023
Sampling Method	: Grab Sampling	Analytical Date	: August 29-31, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: September 15, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.45 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	APHA : 9221 E	490	-
Sample Condition		Turbid Clear and Setiment		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Environment & Laboratory Co.,Ltd Registered Laboratory No. ๖-029
⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6609-WW3031
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: September 14, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: September 15, 2023
Sampling Method	: Grab Sampling	Analytical Date	: September 15-26, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: October 10, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.37 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH@25°C ⁽¹⁾	-	Electrometric Method	7.3	-
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	50.3	-
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	45.2	-
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6609-WW3031
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: September 14, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: September 15, 2023
Sampling Method	: Grab Sampling	Analytical Date	: September 16-October 05, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: October 10, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.37 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT

Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6609-WW3032
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: September 14, 2023
GPS. Coordinate	: 47P 0671886 E 1517035 N	Received Date	: September 15, 2023
Sampling Method	: Grab Sampling	Analytical Date	: September 15-26, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: October 10, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.41 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.4	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	18.4	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	43.7	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.



ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6609-WW3032
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: September 14, 2023
GPS. Coordinate	: 47P 0671886 E 1517035 N	Received Date	: September 15, 2023
Sampling Method	: Grab Sampling	Analytical Date	: September 16-October 05, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: October 10, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.41 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.






ANALYSIS REPORT

Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6609-WW3033
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: September 14, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: September 15, 2023
Sampling Method	: Grab Sampling	Analytical Date	: September 15-26, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: October 10, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.49 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH@25°C ⁽¹⁾	-	Electrometric Method	7.4	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	27.3	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	39.5	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679
⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6609-WW3033
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: September 14, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: September 15, 2023
Sampling Method	: Grab Sampling	Analytical Date	: September 16-October 05, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: October 10, 2023
Sampling Name	: Mr. Pakin Srisawat	Sampling Time	: 02.49 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. 2-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6610-WW3557
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: October 27, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: October 29, 2023
Sampling Method	: Grab Sampling	Analytical Date	: October 29–November 13, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: November 15, 2023
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 04.40 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.5	-
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103–105 °C	9.0	-
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	30.7	-
Fat, Oil and Grease	mg/L	Liquid–Liquid, Partition–Gravimetric Method	<5.0	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rd ed. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เลขชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT

Customer Name : Juristic person Life @ Sukhumvit
Project Name : Life @ Sukhumvit
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.
Sampling Point : Waste water collect.
GPS. Coordinate : 47P 0671854 E 1517007 N
Sampling Method : Grab Sampling
Sampling By : TNP ENVIRONMENT CO., LTD
Sampling Name : Mr.Nathapon Saelee
Registered No. : -

Customer Code : W66019
Sample No : 6610-WW3557
Sample Type : Waste Water
Sampling Date : October 27, 2023
Received Date : October 30, 2023
Analytical Date : October 30-November 07, 2023
Report Date : November 15, 2023
Sampling Time : 04.40 p.m.

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.



บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ว-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6610-WW3558
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: October 27, 2023
GPS. Coordinate	: 47P 0671886 E 1517035 N	Received Date	: October 29, 2023
Sampling Method	: Grab Sampling	Analytical Date	: October 29–November 13, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: November 15, 2023
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 04.35 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.5	5–9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103–105 °C	10.0	≤20
Biochemical Oxygen Demand	mg/L	5–Day BOD Test, Membrane Electrode Method	25.4	≤30
Fat, Oil and Grease	mg/L	Liquid–Liquid, Partition–Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT

Customer Name : Juristic person Life @ Sukhumvit
Project Name : Life @ Sukhumvit
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.
Sampling Point : Wastewater treatment system. (effluent)
GPS. Coordinate : 47P 0671886 E 1517035 N
Sampling Method : Grab Sampling
Sampling By : TNP ENVIRONMENT CO., LTD
Sampling Name : Mr.Nathapon Saelee
Registered No. : -


Customer Code : W66019
Sample No : 6610-WW3558
Sample Type : Waste Water
Sampling Date : October 27, 2023
Received Date : October 30, 2023
Analytical Date : October 30-November 07, 2023
Report Date : November 15, 2023
Sampling Time : 04.35 p.m.

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6610-WW3559
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: October 27, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: October 29, 2023
Sampling Method	: Grab Sampling	Analytical Date	: October 29-November 13, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: November 15, 2023
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 04.46 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.6	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	<5.0	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	2.1	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Clear and Sediment.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เลขชน 2-318

ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110

เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com

เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6610-WW3559
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: October 27, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: October 30, 2023
Sampling Method	: Grab Sampling	Analytical Date	: October 30-November 07, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: November 15, 2023
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 04.46 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23rd Edition, 2017, Part 9221 E	490	-
Sample Condition		Clear and Sediment.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. 2-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเมนต์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6611-WW3756
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: November 16, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: November 17, 2023
Sampling Method	: Grab Sampling	Analytical Date	: November 17-24, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: December 01, 2023
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 11.32 a.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.0	-
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	19.5	-
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	38.6	-
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rd ed. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT

Customer Name : Juristic person Life @ Sukhumvit
Project Name : Life @ Sukhumvit
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.
Sampling Point : Waste water collect.
GPS. Coordinate : 47P 0671854 E 1517007 N
Sampling Method : Grab Sampling
Sampling By : TNP ENVIRONMENT CO., LTD
Sampling Name : Mr.Nathapon Saelee
Registered No. : -


Customer Code : W66019
Sample No : 6611-WW3756
Sample Type : Waste Water
Sampling Date : November 16, 2023
Received Date : November 17, 2023
Analytical Date : November 17-29, 2023
Report Date : December 01, 2023
Sampling Time : 11.32 a.m.

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23 rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment



TIS17025-2561
TESTING No. 1679

ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6611-WW3757
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: November 16, 2023
GPS. Coordinate	: 47P 0671886 E 1517035 N	Received Date	: November 17, 2023
Sampling Method	: Grab Sampling	Analytical Date	: November 17-24, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: December 01, 2023
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 11.36 a.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.0	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	22.7	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	34.0	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rd ed. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ๖-๓18
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT

Customer Name : Juristic person Life @ Sukhumvit
Project Name : Life @ Sukhumvit
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.
Sampling Point : Wastewater treatment system. (effluent)
GPS. Coordinate : 47P 0671886 E 1517035 N
Sampling Method : Grab Sampling
Sampling By : TNP ENVIRONMENT CO., LTD
Sampling Name : Mr.Nathapon Saelee
Registered No. : -


Customer Code : W66019
Sample No : 6611-WW3757
Sample Type : Waste Water
Sampling Date : November 16, 2023
Received Date : November 17, 2023
Analytical Date : November 17-29, 2023
Report Date : December 01, 2023
Sampling Time : 11.36 a.m.

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23 rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name : Juristic person Life @ Sukhumvit **Customer Code** : W66019
Project Name : Life @ Sukhumvit **Sample No** : 6611-WW3758
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok. **Sample Type** : Waste Water
Sampling Point : Before discharging into public sewers. **Sampling Date** : November 16, 2023
GPS. Coordinate : 47P 0671810 E 1516993 N **Received Date** : November 17, 2023
Sampling Method : Grab Sampling **Analytical Date** : November 17-29, 2023
Sampling By : TNP ENVIRONMENT CO., LTD **Report Date** : December 01, 2023
Sampling Name : Mr.Nathapon Saelee **Sampling Time** : 11.42 a.m.
Registered No. : -

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.1	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	16.8	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	5.7	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Clear Yollow and Sediment.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





บริษัท ทีเอ็นพี เอ็นไวรอนเม้นท์ จำกัด (สำนักงานใหญ่) เลขทะเบียนห้องปฏิบัติการวิเคราะห์เลขชน ๓-318
ตั้งอยู่ที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110
เบอร์ติดต่อ 02-156-8273 / 088-2968628 อีเมล tnp.envi@gmail.com
เว็บไซต์ www.tnpenvironment.co.th , Line @ : @tnplab318 , Facebook.com/Tnp.environment

ANALYSIS REPORT

Customer Name : Juristic person Life @ Sukhumvit
Project Name : Life @ Sukhumvit
Address : 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.
Sampling Point : Before discharging into public sewers.
GPS. Coordinate : 47P 0671810 E 1516993 N
Sampling Method : Grab Sampling
Sampling By : TNP ENVIRONMENT CO., LTD
Sampling Name : Mr.Nathapon Saelee
Registered No. : -


Customer Code : W66019
Sample No : 6611-WW3758
Sample Type : Waste Water
Sampling Date : November 16, 2023
Received Date : November 17, 2023
Analytical Date : November 17-29, 2023
Report Date : December 01, 2023
Sampling Time : 11.42 a.m.

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23 rd Edition, 2017, Part 9221 E	3,300	-
Sample Condition		Clear Yollow and Sediment.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๓-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6612-WW4236
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: December 15, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: December 16, 2023
Sampling Method	: Grab Sampling	Analytical Date	: December 16-25, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: January 09, 2024
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 03.14 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.4	-
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	47.0	-
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	27.7	-
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rd ed. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6612-WW4236
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Waste water collect.	Sampling Date	: December 15, 2023
GPS. Coordinate	: 47P 0671854 E 1517007 N	Received Date	: December 18, 2023
Sampling Method	: Grab Sampling	Analytical Date	: December 18-26, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: January 09, 2024
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 03.14 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23 rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6612-WW4237
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: December 15, 2023
GPS. Coordinate	: 47P 0671886 E 1517035 N	Received Date	: December 16, 2023
Sampling Method	: Grab Sampling	Analytical Date	: December 16-25, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: January 09, 2024
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 03.18 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH @25°C ⁽¹⁾	-	Electrometric Method	7.4	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	37.2	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	35.9	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT


Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6612-WW4237
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Wastewater treatment system. (effluent)	Sampling Date	: December 15, 2023
GPS. Coordinate	: 47P 0671886 E 1517035 N	Received Date	: December 18, 2023
Sampling Method	: Grab Sampling	Analytical Date	: December 18-26, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: January 09, 2024
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 03.18 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23 rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๓-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rd ed. Washington, DC: APHA, 2017.






ANALYSIS REPORT

Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6612-WW4238
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: December 15, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: December 16, 2023
Sampling Method	: Grab Sampling	Analytical Date	: December 16-25, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: January 09, 2024
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 03.23 p.m.
Registered No.	: -		

Parameter	Unit	Analytical Method ⁽²⁾	Result	Standard
pH@25°C ⁽¹⁾	-	Electrometric Method	7.3	5-9
Total Suspended Solids ⁽¹⁾	mg/L	Dried at 103-105 °C	25.7	≤20
Biochemical Oxygen Demand	mg/L	5-Day BOD Test, Membrane Electrode Method	41.4	≤30
Fat, Oil and Grease	mg/L	Liquid-Liquid, Partition-Gravimetric Method	<5.0	≤20
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size
B.E. 2548 (Building Type n)

Remark ⁽¹⁾ : Specific test accredited certification ISO/IEC 17025:2017 Accreditation No. Testing 1679
⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.





ANALYSIS REPORT

Customer Name	: Juristic person Life @ Sukhumvit	Customer Code	: W66019
Project Name	: Life @ Sukhumvit	Sample No	: 6612-WW4238
Address	: 1451 Sukhumvit Road, Phra Khanong Nuea, Watthana, Bangkok.	Sample Type	: Waste Water
Sampling Point	: Before discharging into public sewers.	Sampling Date	: December 15, 2023
GPS. Coordinate	: 47P 0671810 E 1516993 N	Received Date	: December 18, 2023
Sampling Method	: Grab Sampling	Analytical Date	: December 18-26, 2023
Sampling By	: TNP ENVIRONMENT CO., LTD	Report Date	: January 09, 2024
Sampling Name	: Mr.Nathapon Saelee	Sampling Time	: 03.23 p.m.
Registered No.	: -		

Parameter ⁽¹⁾	Unit	Analytical Method ⁽²⁾	Result	Standard
Fecal Coliform Bacteria	MPN/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 23 rd Edition, 2017, Part 9221 E	>160,000	-
Sample Condition		Turbid Yellow, Sediment and Odorous.		

Standard : The Ministry of Natural Resources and the Environment on the standard control standards matters from certain types of building, and some size B.E. 2548 (Building Type ก)

Remark ⁽¹⁾ : Analysis by Bureau Veritas AQ Lab Thailand Ltd. No. ๖-313

⁽²⁾ : APHA, AWWA, WEF. Standard Methods for the Examination of Water and Wastewater. 23rded. Washington, DC: APHA, 2017.

