


ภาคผนวกที่ 7

เอกสารรายงานการตรวจสอบคุณภาพสระว่ายน้ำ


ประจำเดือน มกราคม 2567 - มิถุนายน 2567

เอกสารตรวจสอบคุณภาพสระว่ายน้ำประจำเดือน



My Story Ladprao 71

Check Chlorine Swimming Pool



เดือน มกราคม 2567
อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	✓	
2	3.0	6.8	3.0	6.8	✓	
3	1.5	6.8	1.5	6.8	✓	
4	1.5	6.8	1.5	6.8	✓	
5	3.0	6.8	3.0	6.8	✓	
6	3.0	6.8	3.0	6.8	✓	
7	3.0	6.8	3.0	6.8	✓	
8	3.0	6.8	3.0	6.8	✓	
9	1.5	6.8	1.5	6.8	✓	
10	1.5	6.8	1.5	6.8	✓	
11	1.5	6.8	1.5	6.8	✓	
12	1.5	6.8	1.5	6.8	✓	
13	1.5	6.8	1.5	6.8	✓	
14	1.5	6.8	1.5	6.8	✓	
15	1.5	6.8	1.5	6.8	✓	
16	3.0	6.8	3.0	6.8	✓	
17	3.0	6.8	3.0	6.8	✓	
18	3.0	6.8	3.0	6.8	✓	
19	3.0	6.8	3.0	6.8	✓	
20	1.5	6.8	1.5	6.8	✓	
21	1.5	6.8	1.5	6.8	✓	
22	1.5	6.8	1.5	6.8	✓	
23	1.5	6.8	1.5	6.8	✓	
24	1.0	6.8	3.0	6.8	✓	
25	3.0	6.8	3.0	6.8	✓	
26	3.0	6.8	3.0	6.8	✓	
27	3.0	6.8	3.0	6.8	✓	
28	3.0	6.8	3.0	6.8	✓	
29	3.0	6.8	3.0	6.8	✓	
30	3.0	6.8	3.0	6.8	✓	
31	3.0	6.8	3.0	6.8	✓	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- a. pH of 7.2 to 7.5
- b. Total alkalinity of 90 to 110ppm
- c. Calcium hardness of 200 to 275ppm
- d. Free residue chlorine of 1.0 to 1.5ppm
- e. Free of Bacteria.
- f. For indoor pool the water temperature shall be 29°C.



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน มกราคม 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	อ	
2	1.5	6.8	1.5	6.8	อ	
3	3.0	6.8	3.0	6.8	อ	
4	1.5	6.8	1.5	6.8	อ	
5	1.5	6.8	1.5	6.8	อ	
6	1.5	6.8	1.5	6.8	อ	
7	1.5	6.8	1.5	6.8	อ	
8	1.5	6.8	1.5	6.8	อ	
9	1.5	6.8	1.5	6.8	อ	
10	3.0	6.8	3.0	6.8	อ	
11	3.0	6.8	3.0	6.8	อ	
12	3.0	6.8	3.0	6.8	อ	
13	1.5	6.8	1.5	6.8	อ	
14	1.5	6.8	1.5	6.8	อ	
15	1.5	6.8	1.5	6.8	อ	
16	3.0	6.8	3.0	6.8	อ	
17	3.0	6.8	3.0	6.8	อ	
18	3.0	6.8	3.0	6.8	อ	
19	1.5	6.8	1.5	6.8	อ	
20	1.5	6.8	1.5	6.8	อ	
21	1.5	6.8	1.5	6.8	อ	
22	1.0	6.8	3.0	6.8	อ	
23	3.0	6.8	3.0	6.8	อ	
24	3.0	6.8	3.0	6.8	อ	
25	3.0	6.8	3.0	6.8	อ	
26	1.5	6.8	1.5	6.8	อ	
27	1.5	6.8	1.5	6.8	อ	
28	1.5	6.8	1.5	6.8	อ	
29	1.5	6.8	1.5	6.8	อ	
30	1.5	6.8	1.5	6.8	อ	
31	1.5	6.8	1.5	6.8	อ	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน กุมภาพันธ์ 2567

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	วิมล	
2	3.0	6.8	3.0	6.8	วิมล	
3	3.0	6.8	3.0	6.8	วิมล	
4	3.0	6.8	3.0	6.8	วิมล	
5	3.0	6.8	3.0	6.8	วิมล	
6	3.0	6.8	3.0	6.8	วิมล	
7	3.0	6.8	3.0	6.8	วิมล	
8	3.0	6.8	3.0	6.8	วิมล	
9	3.0	6.8	3.0	6.8	วิมล	
10	3.0	6.8	3.0	6.8	วิมล	
11	3.0	6.8	3.0	6.8	วิมล	
12	3.0	6.8	3.0	6.8	วิมล	
13	3.0	6.8	3.0	6.8	วิมล	
14	3.0	6.8	3.0	6.8	วิมล	
15	3.0	6.8	3.0	6.8	วิมล	
16	3.0	6.8	3.0	6.8	วิมล	
17	3.0	6.8	3.0	6.8	วิมล	
18	3.0	6.8	3.0	6.8	วิมล	
19	3.0	6.8	3.0	6.8	วิมล	
20	3.0	6.8	3.0	6.8	วิมล	
21	3.0	6.8	3.0	6.8	วิมล	
22	3.0	6.8	3.0	6.8	วิมล	
23	3.0	6.8	3.0	6.8	วิมล	
24	3.0	6.8	3.0	6.8	วิมล	
25	3.0	6.8	3.0	6.8	วิมล	
26	3.0	6.8	3.0	6.8	วิมล	
27	3.0	6.8	3.0	6.8	วิมล	
28	3.0	6.8	3.0	6.8	วิมล	
29	3.0	6.8	3.0	6.8	วิมล	
30						
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน กุมภาพันธ์ 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	วิเศษ	
2	3.0	6.8	3.0	6.8	วิเศษ	
3	3.0	6.8	3.0	6.8	วิเศษ	
4	3.0	6.8	3.0	6.8	วิเศษ	
5	3.0	6.8	3.0	6.8	วิเศษ	
6	3.0	6.8	3.0	6.8	วิเศษ	
7	3.0	6.8	3.0	6.8	วิเศษ	
8	3.0	6.8	3.0	6.8	วิเศษ	
9	3.0	6.8	3.0	6.8	วิเศษ	
10	3.0	6.8	3.0	6.8	วิเศษ	
11	3.0	6.8	3.0	6.8	วิเศษ	
12	3.0	6.8	3.0	6.8	วิเศษ	
13	3.0	6.8	3.0	6.8	วิเศษ	
14	3.0	6.8	3.0	6.7	วิเศษ	
15	3.0	6.8	3.0	6.7	วิเศษ	
16	3.0	6.8	3.0	6.8	วิเศษ	
17	3.0	6.8	3.0	6.8	วิเศษ	
18	3.0	6.8	3.0	6.8	วิเศษ	
19	3.0	6.8	3.0	6.8	วิเศษ	
20	3.0	6.8	3.0	6.8	วิเศษ	
21	3.0	6.8	3.0	6.8	วิเศษ	
22	3.0	6.8	3.0	6.8	วิเศษ	
23	3.0	6.8	3.0	6.8	วิเศษ	
24	3.0	6.8	3.0	6.8	วิเศษ	
25	3.0	6.8	3.0	6.8	วิเศษ	
26	3.0	6.8	3.0	6.8	วิเศษ	
27	3.0	6.8	3.0	6.8	วิเศษ	
28	3.0	6.8	3.0	6.8	วิเศษ	
29	3.0	6.8	3.0	6.8	วิเศษ	
30						
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน มีนาคม 2567

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	NS	
2	3.0	6.8	3.0	6.8	NS	
3	3.0	6.8	3.0	6.8	NS	
4	3.0	6.8	3.0	6.8	NS	
5	3.0	6.8	3.0	6.8	NS	
6	3.0	6.8	3.0	6.8	NS	
7	3.0	6.8	3.0	6.8	NS	
8	3.0	6.8	3.0	6.8	NS	
9	3.0	6.8	3.0	6.8	NS	
10	3.0	6.8	3.0	6.8	NS	
11	3.0	6.8	3.0	6.8	NS	
12	3.0	6.8	3.0	6.8	NS	
13	3.0	6.8	3.0	6.8	NS	
14	3.0	6.8	3.0	6.8	NS	
15	3.0	6.8	3.0	6.8	NS	
16	1.5	6.8	1.5	6.8	NS	
17	1.5	6.8	1.5	6.8	NS	
18	3.0	6.8	3.0	6.8	NS	
19	3.0	6.8	3.0	6.8	NS	
20	3.0	6.8	3.0	6.8	NS	
21	3.0	6.8	3.0	6.8	NS	
22	1.5	6.8	1.5	6.8	NS	
23	1.5	6.8	1.5	6.8	NS	
24	1.5	6.8	1.5	6.8	NS	
25	1.0	6.8	1.0	6.8	NS	
26	3.0	6.8	3.0	6.8	NS	
27	3.0	6.8	3.0	6.8	NS	
28	3.0	6.8	3.0	6.8	NS	
29	3.0	6.8	3.0	6.8	NS	
30	3.0	6.8	3.0	6.8	NS	
31	3.0	6.8	3.0	6.8	NS	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน มีนาคม 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	RS	
2	3.0	6.8	3.0	6.8	ว	
3	3.0	6.8	3.0	6.8	อ	
4	3.0	6.8	3.0	6.8	ร	
5	3.0	6.8	3.0	6.8	ร	
6	3.0	6.8	3.0	6.8	ร	
7	3.0	6.8	3.0	6.8	ร	
8	3.0	6.8	3.0	6.8	ร	
9	3.0	6.8	3.0	6.8	ร	
10	3.0	6.8	3.0	6.8	ร	
11	3.0	6.8	3.0	6.8	ร	
12	3.0	6.8	3.0	6.8	ร	
13	3.0	6.8	3.0	6.8	ร	
14	3.0	6.8	3.0	6.8	ร	
15	3.0	6.8	3.0	6.8	ร	
16	1.5	6.8	1.5	6.8	ร	
17	1.5	6.8	1.5	6.8	ร	
18	3.0	6.8	3.0	6.8	ร	
19	3.0	6.8	3.0	6.8	ร	
20	3.0	6.8	3.0	6.8	ร	
21	3.0	6.8	3.0	6.8	ร	
22	1.5	6.8	1.5	6.8	ร	
23	1.5	6.8	1.5	6.8	ร	
24	1.5	6.8	1.5	6.8	ร	
25	1.0	6.8	1.0	6.8	ร	
26	3.0	6.8	3.0	6.8	ร	
27	3.0	6.8	3.0	6.8	ร	
28	3.0	6.8	3.0	6.8	ร	
29	3.0	6.8	3.0	6.8	ร	
30	3.0	6.8	3.0	6.8	ร	
31	3.0	6.8	3.0	6.8	ร	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For Indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน 6/2564 25/7

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	✓	
2	1.5	6.8	1.5	6.8	✓	
3	1.5	6.8	1.5	6.8	✓	
4	1.5	6.8	1.5	6.8	✓	
5	1.5	6.8	1.5	6.8	✓	
6	3.0	6.8	3.0	6.8	✓	
7	3.0	6.8	3.0	6.8	✓	
8	3.0	6.8	3.0	6.8	✓	
9	1.5	6.8	1.5	6.8	✓	
10	1.5	6.8	1.5	6.8	✓	
11	1.5	6.8	1.5	6.8	✓	
12	1.5	6.8	1.5	6.8	✓	
13	3.0	6.8	3.0	6.8	✓	
14	3.0	6.8	3.0	6.8	✓	
15	3.0	6.8	3.0	6.8	✓	
16	1.5	6.8	1.5	6.8	✓	
17	1.5	6.8	1.5	6.8	✓	
18	1.5	6.8	1.5	6.8	✓	
19	1.5	6.8	1.5	6.8	✓	
20	1.5	6.8	1.5	6.8	✓	
21	1.5	6.8	1.5	6.8	✓	
22	3.0	6.8	3.0	6.8	✓	
23	3.0	6.8	3.0	6.8	✓	
24	3.0	6.8	3.0	6.8	✓	
25	3.0	6.8	3.0	6.8	✓	
26	1.5	6.8	1.5	6.8	✓	
27	1.5	6.8	1.5	6.8	✓	
28	1.5	6.8	1.5	6.8	✓	
29	1.5	6.8	1.5	6.8	✓	
30	1.5	6.8	1.5	6.8	✓	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน : มิถุนายน 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	✓	
2	1.5	6.8	1.5	6.8	✓	
3	1.6	6.8	1.5	6.8	✓	
4	1.0	6.8	1.0	6.8	✓	
5	3.0	6.8	3.0	6.8	✓	
6	3.0	6.8	3.0	6.8	✓	
7	3.0	6.8	3.0	6.8	✓	
8	3.0	6.8	3.0	6.8	✓	
9	1.5	6.8	1.5	6.8	✓	
10	1.5	6.8	1.5	6.8	✓	
11	1.5	6.8	1.5	6.8	✓	
12	1.5	6.8	1.5	6.8	✓	
13	3.0	6.8	3.0	6.8	✓	
14	3.0	6.8	3.0	6.8	✓	
15	3.0	6.8	3.0	6.8	✓	
16	3.0	6.8	3.0	6.8	✓	
17	1.5	6.8	1.5	6.8	✓	
18	1.5	6.8	1.5	6.8	✓	
19	1.5	6.8	1.5	6.8	✓	
20	1.5	6.8	1.5	6.8	✓	
21	3.0	6.8	3.0	6.8	✓	
22	3.0	6.8	3.0	6.8	✓	
23	3.0	6.8	3.0	6.8	✓	
24	1.5	6.8	1.5	6.8	✓	
25	1.5	6.8	1.5	6.8	✓	
26	1.5	6.8	1.5	6.8	✓	
27	3.0	6.8	3.0	6.8	✓	
28	3.0	6.8	3.0	6.8	✓	
29	3.0	6.8	3.0	6.8	✓	
30	3.0	6.8	3.0	6.8	✓	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

a. pH of 7.2 to 7.5

b. Total alkalinity of 90 to 110ppm

c. Calcium hardness of 200 to 275ppm

d. Free residue chlorine of 1.0 to 1.5ppm

e. Free of Bacteria.

f. For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน พฤษภาคม 2567

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	AS	
2	3.0	6.8	3.0	6.8	AS	
3	3.0	6.8	3.0	6.8	AS	
4	3.0	6.8	3.0	6.8	AS	
5	1.5	6.8	1.5	6.8	AS	
6	1.5	6.8	1.5	6.8	AS	
7	1.5	6.8	1.5	6.8	AS	
8	1.5	6.8	1.5	6.8	AS	
9	1.5	6.8	1.5	6.8	AS	
10	1.0	6.8	1.0	6.8	AS	
11	1.0	6.8	1.0	6.8	AS	
12	3.0	6.8	3.0	6.8	AS	
13	3.0	6.8	3.0	6.8	AS	
14	3.0	6.8	3.0	6.8	AS	
15	3.0	6.8	3.0	6.8	AS	
16	3.0	6.8	3.0	6.8	AS	
17	1.5	6.8	1.5	6.8	AS	
18	1.5	6.8	1.5	6.8	AS	
19	1.5	6.8	1.5	6.8	AS	
20	1.5	6.8	1.5	6.8	AS	
21	1.5	6.8	1.5	6.8	AS	
22	1.5	6.8	1.5	6.8	AS	
23	1.5	6.8	1.5	6.8	AS	
24	3.0	6.8	3.0	6.8	AS	
25	3.0	6.8	3.0	6.8	AS	
26	3.0	6.8	3.0	6.8	AS	
27	1.5	6.8	1.5	6.8	AS	
28	1.5	6.8	1.5	6.8	AS	
29	1.5	6.8	1.5	6.8	AS	
30	1.5	6.8	1.5	6.8	AS	
31	1.5	6.8	1.5	6.8	AS	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน : พฤษภาคม 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.6	6.8	1.6	6.8	OK	
2	1.6	6.8	1.6	6.8	OK	
3	1.6	6.8	1.6	6.8	OK	
4	1.0	6.8	1.0	6.8	OK	
5	3.0	6.8	3.0	6.8	OK	
6	3.0	6.8	3.0	6.8	OK	
7	3.0	6.8	3.0	6.8	OK	
8	3.0	6.8	3.0	6.8	OK	
9	3.0	6.8	3.0	6.8	OK	
10	1.6	6.8	1.6	6.8	OK	
11	1.6	6.8	1.6	6.8	OK	
12	1.6	6.8	1.6	6.8	OK	
13	3.0	6.8	3.0	6.8	OK	
14	3.0	6.8	3.0	6.8	OK	
15	3.0	6.8	3.0	6.8	OK	
16	3.0	6.8	3.0	6.8	OK	
17	1.6	6.8	1.6	6.8	OK	
18	1.6	6.8	1.6	6.8	OK	
19	1.6	6.8	1.6	6.8	OK	
20	1.6	6.8	1.6	6.8	OK	
21	3.0	6.8	3.0	6.8	OK	
22	3.0	6.8	3.0	6.8	OK	
23	3.0	6.8	3.0	6.8	OK	
24	3.0	6.8	3.0	6.8	OK	
25	3.0	6.8	3.0	6.8	OK	
26	3.0	6.8	3.0	6.8	OK	
27	3.0	6.8	3.0	6.8	OK	
28	3.0	6.8	3.0	6.8	OK	
29	1.6	6.8	1.6	6.8	OK	
30	1.6	6.8	1.6	6.8	OK	
31	1.6	6.8	1.6	6.8	OK	

Remark : Spa and Swimming Pool Water Quality
 The pool water quality should have the following range of values:
 a. pH of 7.2 to 7.5
 b. Total alkalinity of 90 to 110ppm
 c. Calcium hardness of 200 to 275ppm
 d. Free residue chlorine of 1.0 to 1.5ppm
 e. Free of Bacteria.
 f. For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน 2061/2567

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	✓	
2	1.5	6.8	1.5	6.8	✓	
3	1.0	6.8	1.0	6.8	✓	
4	3.0	6.8	3.0	6.8	✓	
5	3.0	6.8	3.0	6.8	✓	
6	3.0	6.8	3.0	6.8	✓	
7	1.5	6.8	3.0	6.8	✓	
8	1.5	6.8	1.5	6.8	✓	
9	1.5	6.8	1.5	6.8	✓	
10	3.0	6.8	3.0	6.8	✓	
11	3.0	6.8	3.0	6.8	✓	
12	3.0	6.8	3.0	6.8	✓	
13	1.5	6.8	1.5	6.8	✓	
14	1.5	6.8	1.5	6.8	✓	
15	1.5	6.8	1.5	6.8	✓	
16	1.5	6.8	1.5	6.8	✓	
17	3.0	6.8	3.0	6.8	✓	
18	3.0	6.8	3.0	6.8	✓	
19	3.0	6.8	3.0	6.8	✓	
20	3.0	6.8	3.0	6.8	✓	
21	1.5	6.8	1.5	6.8	✓	
22	1.5	6.8	1.5	6.8	✓	
23	1.5	6.8	1.5	6.8	✓	
24	1.5	6.8	1.5	6.8	✓	
25	1.5	6.8	1.5	6.8	✓	
26	3.0	6.8	3.0	6.8	✓	
27	3.0	6.8	3.0	6.8	✓	
28	3.0	6.8	3.0	6.8	✓	
29	3.0	6.8	3.0	6.8	✓	
30	3.0	6.8	3.0	6.8	✓	
31					✓	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน : สิงหาคม 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.6	6.8	1.6	6.7	AS	
2	1.6	6.8	1.5	6.7	AS	
3	1.6	6.8	1.6	6.7	AS	
4	3.0	6.8	3.0	6.7	AS	
5	3.0	6.8	3.0	6.7	AS	
6	1.0	6.8	1.0	6.7	AS	
7	1.6	6.8	1.6	6.7	AS	
8	1.6	6.8	1.6	6.7	AS	
9	3.0	6.7	3.0	6.7	AS	
10	1.6	6.8	1.6	6.7	AS	
11	1.6	6.8	1.6	6.7	AS	
12	1.6	6.8	1.6	6.7	AS	
13	3.0	6.7	3.0	6.7	AS	
14	3.0	6.8	3.0	6.7	AS	
15	3.0	6.8	3.0	6.7	AS	
16	3.0	6.8	3.0	6.8	AS	
17	3.0	6.8	3.0	6.8	AS	
18	3.0	6.8	3.0	6.7	AS	
19	1.6	6.7	1.6	6.8	AS	
20	1.6	6.8	1.6	6.8	AS	
21	1.6	6.8	1.6	6.7	AS	
22	1.6	6.8	1.6	6.7	AS	
23	1.6	6.8	1.6	6.8	AS	
24	1.6	6.8	1.6	6.8	AS	
25	1.6	6.8	1.6	6.8	AS	
26	1.6	6.8	1.6	6.7	AS	
27	1.6	6.8	1.6	6.7	AS	
28	1.6	6.7	1.6	6.8	AS	
29	3.0	6.7	3.0	6.8	AS	
30	3.0	6.8	3.0	6.7	AS	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C