

# ผลวิเคราะห์คุณภาพน้ำทิ้ง โครงการ CAPE RACHA HOTEL



**United Analyst and Engineering Consultant Co., Ltd.**  
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260  
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com



NSC-TISI-TIS 17025  
TESTING 0207

## ANALYSIS REPORT

**CUSTOMER NAME** : KALEIDESCOPE PROPERTIES CO., LTD. (CAPE RACHA HOTEL)  
**ADDRESS** : 35,35/1 JIRM JOMPOL ROAD SI RACHA SI RACHA CHON BURI  
**CONTACT INFORMATION** : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com  
**SAMPLING SOURCE** : WASTEWATER TREATMENT PLANT OF CAPE RACHA HOTEL  
**SAMPLE TYPE** : WASTEWATER  
**SAMPLING DATE** : APRIL 3, 2024  
**SAMPLING TIME** : -  
**SAMPLING METHOD** : -  
**SAMPLING BY** : CUSTOMER  
**ANALYZED BY** : MISS NAPAPORN KHUNNOKKHUM  
**RECEIVED DATE** : APRIL 4, 2024  
**ANALYTICAL DATE** : APRIL 4-11, 2024  
**ISSUE DATE** : APRIL 19, 2024  
**REPORT NO.** : 2024-U032153  
**WORK NO.** : 2024-002931  
**ANALYSIS NO.** : T24AH207-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			อ้างอิง CHA1 (ขาดอก) T24AH207-0001		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD (SM: PART 4500-H <sup>+</sup> B)	6.7 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: PART 5210 B AND PART 4500-O C)	3.1	≤ 30	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	9.4	≤ 40	5.0
FAT, OIL AND GREASE <sup>c</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	ND	≤ 20	3
<b>SAMPLE CONDITION</b> WATER'S COLOUR/TURBID SEDIMENT			BROWN/TURBID BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>RD</sup> EDITION, 2017.


REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122, PART 125 D, DATED DECEMBER 29, 2005.

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

APRIL 22, 2024



• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.  
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1

- End of Analysis Report -

