

CHANDLER DEPARTMENT
FIRE & RESCUE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF *January 2020*

Location	Emergency Light			Control Unit	Remarks	Check By
	Guest's Lift Area	Staff's Lift Area	Exit Sign			
14 th floor	/	/	/	/	} done	} MYSB 2/1/62
12 th floor	/	/	/	/		
11 th floor	/	/	/	/		
10 th floor	/	/	/	/		
9 th floor	/	/	/	/		
8 th floor	/	/	/	/		
7 th floor	/	/	/	/		
6 th floor	/	/	/	/		
5 th floor	/	/	/	/		
4 th floor	/	/	/	/		
3 rd floor	/	/	/	/		
2 nd floor	/	/	/	/		
Ground floor	/	/	/	/		
Basement floor	/	/	/	/		
Carpark	/	/	/	/		
Public Area						
Administration office				/	} done	} MYSB 2/1/62
Housekeeping office				/		
Engineering office				/		
Laundry room	/					
Canteen	/					
Male locker room	/					
Female locker room	/					
Fitness Center	/					
In front of guest's lift 14 th floor	/					

GRAND ATTRACTION
HOTEL AND CASINO

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF February 2022

NOTIFY EMERGENCY LIGHT TEST FOR DETAIL OF February 2022						
Location	Emergency Light			Control Unit	Remark	Check By
	Guest's lift zone	Staff's lift zone	Exit zone			
14 th floor	/	/		/	JNM	MM8/20 2/2/68
12 th floor	/	/		/		
11 th floor	/	/		/		
10 th floor	/	/		/		
9 th floor	/	/		/		
8 th floor	/	/		/		
7 th floor	/	/		/		
6 th floor	/	/		/		
5 th floor	/	/	/	/		
4 th floor	/	/	/	/		
3 rd floor	/	/	/	/		
2 nd floor	/	/		/		
Ground floor	/	/		/		
Basement floor	/	/		/		
Carpark	/	/		/		
Public Area						
Location	Emergency Light		Control Unit	Remark	Check By	
Administration office			/		JNM	MM8/20 2/2/68
Housekeeping office			/			
Engineering office			/			
Laundry room	/					
Canteen	/					
Male locker room	/					
Female locker room	/					
Fitness Center	/					
In front of guest's lift 14 th floor	/					



MINISTRY OF HEALTH AND FAMILY WELFARE
GOVERNMENT OF INDIA

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF March /2020

Location	Emergency Light			Control Unit	Remarks	Check by
	Guest's lift Area	Staff's lift Area	Lift Area			
14 th floor	/	/				
12 th floor	/	/				
11 th floor	/	/		/		
10 th floor	/	/		/		
9 th floor	/	/		/		
8 th floor	/	/		/		
7 th floor	/	/		/		
6 th floor	/	/		/		
5 th floor	/	/	/	/	↓	
4 th floor	/	/	/	/		
3 rd floor	/	/	/	/		
2 nd floor	/	/		/		
Ground floor	/	/				
Basement floor	/	/				
Carpark	/	/				
Public Area						
Location	Emergency Light		Control Unit		Remarks	Check by
Administration office			/			
Housekeeping office			/			
Engineering office			/			
Laundry room	/					
Canteen	/					
Male locker room	/					
Female locker room	/					
Fitness Center	X					
Front of guest's lift 14 th floor	X					



GRAND MERCURE
LUXURY HOTELS & RESORTS

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF April /2024

Location	Emergency Light			Control Unit	Remark	Check By
	Guest's lift zone	Staff's lift zone	Lift zone			
14 th floor	/	/			✓ 10/05/24 7/10/24	
12 th floor	/	/		/		
11 th floor	/	/		/		
10 th floor	/	/		/		
9 th floor	/	/		/		
8 th floor	/	/		/		
7 th floor	/	/		/		
6 th floor	/	/		/		
5 th floor	/	/	/	/		
4 th floor	/	/	/	/		
3 rd floor	/	/	/	/		
2 nd floor	/	/		/		
Ground floor	/	/		/		
Basement floor	/	/		/		
Carpark	/	/				
Public Area						
Administration office				/	✓ 10/05/24 7/10/24	
Housekeeping office				/		
Engineering office				/		
Laundry room	/					
Canteen	/					
Male locker room	/					
Female locker room	/					
Gym Center	X			1/15 7/15		
In front of guest's lift 14 th floor	X					

GRAND MERIDIAN
HOTEL & RESORTS

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF *May* 2024

Location	Emergency Exit			Control Unit	Remark	Check By
	Guest's lift door	Staff's lift door	Exit door			
14 th floor	/	/				
12 th floor	/	/		/		
11 th floor	/	/		/		
10 th floor	/	/		/		
9 th floor	/	/		/		
8 th floor	/	/		/		
7 th floor	/	/		/		
6 th floor	/	/		/	} <i>done</i>	} <i>done</i> 7/5/2024
5 th floor	/	/	/	/		
4 th floor	/	/	/	/		
3 rd floor	/	/	/	/		
2 nd floor	/	/		/		
Ground floor	/	/				
Basement floor	/	/				
Carpark	/	/				
Location	Emergency Exit			Control Unit	Remark	Check By
	Guest's lift door	Staff's lift door	Exit door			
Administration office				/		
Housekeeping office				/		
Engineering office				/		
Laundry room	/					
Canteen	/				} <i>done</i>	} <i>done</i> 7/5/2024
Male locker room	/					
Female locker room	/					
Gym Center	X					
front of guest's lift 14 th floor	X					

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF June 2024

Location	Emergency light			Central Batt	Remark	Check By
	Guest's life Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	ธวัชชัย
12 th floor	/	/		/	ปกติ	ธวัชชัย
11 th floor	/	/		/	ปกติ	ธวัชชัย
10 th floor	/	/		/	ปกติ	ธวัชชัย
9 th floor	/	/		/	ปกติ	ธวัชชัย
8 th floor	/	/		/	ปกติ	ธวัชชัย
7 th floor	/	/		/	ปกติ	ธวัชชัย
6 th floor	/	/		/	ปกติ	ธวัชชัย
5 th floor	/	/	/	/	ปกติ	ธวัชชัย
4 th floor	/	/	/	/	ปกติ	ธวัชชัย
3 rd floor	/	/	/	/	ปกติ	ธวัชชัย
2 nd floor	/	/		/	ปกติ	ธวัชชัย
Ground floor	/	/		/	ปกติ	ธวัชชัย
Basement floor	/	/			ปกติ	ธวัชชัย
Carpark	/	/			ปกติ	ธวัชชัย

Public Area

Location	Emergency light		Central Batt	Remark	Check By
Administration office			/		ธวัชชัย
Housekeeping office			/		ธวัชชัย
Engineering office			/		ธวัชชัย
Laundry room	/				ธวัชชัย
Canteen	/				ธวัชชัย
Male locker room	/				ธวัชชัย
Female locker room	/				ธวัชชัย
Fitness Center	X			ไม่มี	ธวัชชัย
In front of guest's lift 14 th floor	X			ไม่มี	ธวัชชัย

GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG TEST FIRE ALARM CONTROL SYSTEM 2024

SYSTEM: FIRE PROTECTION

FREQUENCY : WEEKLY

PROJECT: Asoke Residence Bangkok Grand Mercue

Date: 2 / 1 / 2024

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR <input checked="" type="checkbox"/> 806		HEAT DETECTOR <input type="checkbox"/>		PULL STATION <input type="checkbox"/>		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		
<u>1</u>							

Suggestion / Remark: tes Alarm Smoke Detector Bed Room 806 R.8
Bell Working Normal

Checked By: M/S/N

Approve By:

(.....)

(.....)

DATE: 2 / 1 / 2024

DATE: / /

GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG TEST FIRE ALARM CONTROL SYSTEM 2024

SYSTEM: FIRE PROTECTION

FREQUENCY : WEEKLY

PROJECT: Asoke Residence Bangkok Grand Mercue

Date: 9 / 2 / 2024

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR <input checked="" type="checkbox"/> 1206		HEAT DETECTOR <input type="checkbox"/>		PULL STATION <input type="checkbox"/>		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Suggestion / Remark: test Alarm Smoke Detector Bed Room 1206 Fl. 12
Bell Working Normal

Checked By:

Approve By:

(.....)

(.....)

DATE: 9 / 2 / 2024

DATE: / /

GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG TEST FIRE ALARM CONTROL SYSTEM 2024

SYSTEM: FIRE PROTECTION

FREQUENCY : WEEKLY

PROJECT: Asoke Residence Bangkok Grand Mercue

Date: 5 / 4 / 2024

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR <input checked="" type="checkbox"/> 602 IV		HEAT DETECTOR <input type="checkbox"/>		PULL STATION <input type="checkbox"/>		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		
✓							

Suggestion / Remark: Test Alarm Smoke Detector living Room 602 FL6
Bell working Normal

Checked By: *[Signature]*

Approve By:

(.....)

(.....)

DATE: 5 / 4 / 2024

DATE: / /

GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG TEST FIRE ALAM CONTROL SYSTEM 2024

SYSTEM: FIRE PROTECTION

FREQUENCY : WEEKLY

PROJECT: Asoke Residence Bangkok Grand Mercue

Date: 5 / 5 / 2024

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR <input checked="" type="checkbox"/> 1105 LL		HEAT DETECTOR <input type="checkbox"/>		PULL STATION <input type="checkbox"/>		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		
/							

Suggestion / Remark: Test Alarm Smoke Detector Working from 1105 PM 11
Bell working normal

Checked By: [Signature]

(.....)

DATE: 3 / 5 / 2024

Approve By:

(.....)

DATE:/...../.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2024

SYSTEM: FIRE PROTECTION				FREQUENCY : WEEKLY			
PROJECT: Grand Mercure Bangkok Asoke Residence				Date: 7/6/67			
LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM							
SMOKE DETECTOR706..... <input type="checkbox"/>		HEAT DETECTOR <input type="checkbox"/>		PULL STATION <input type="checkbox"/>		INSPECTE R	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		
Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 706 PL.7 Bell working Normal 							
Checked By:สายชล..... (.....)				Approve By:ธวัชชัย..... (.....)			
DATE:7.... /6..... /67.....				DATE:7.... /6..... /67.....			

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT : Grand Mercure Bangkok Asoke Residence

DATE: 5 / 1 / 2024

SYSTEM : FIRE PROTECTION

FREQUENCY: WEEKLY

EQUIPMENT : FIRE PUMP

LOCATION: PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL : 488 LITE

2 EXAMINE LEVEL OF LUBRICANT OIL : [] L [] M [] H

3 EXAMINE LEVEL OF WATER IN BOILER: [] L [] M [] H

4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY: [] L [] M [] H

5 RECORDED VOLTAGE OF BATTERY : B1. 14.6 V B2. 15.1 V

6 RECORDED ENGINE WATER TEMPERATURE : 80 C

7 RECORDED PRESSURE OF LUBRICATING OIL : 60 PSI

8 RECORDED SPEED OF FIRE PUMP : 1800 RPM

9 RECORDED WORK HOUR OF FIRE PUMP : 000915 HOUR

EXAMINE AIR FILTER OF FIREPUMP: [] NORMAL [] CLEAN [] CHANGE

11 EXAMINE LEAKAGE OF OIL PIPE: [] NORMAL [] CLEAN [] CHANGE

12 TEST THE OPERATION OF CONTROL CABINET: [] NORMAL [] ABNORMAL [] CORRECT

13 TEST THE OPERATION OF RELASE VALVE: [] NORMAL [] ABNORMAL [] CORRECT

14 TEST THE OPERATION OF CHECK VALVE : [] NORMAL [] ABNORMAL [] CORRECT

15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP: [] NORMAL [] ABNORMAL [] CORRECT

16 CLEAN FIRE PUMP ,BATTERY AND FUEL TANK : [] CLEAN [] NO CLEAN

17 RECORDED PRESSURE OF WATER PIPE:

17.1 OUTPUT FIRE PUMP PRESSURE : 250 PSI

17.2 OUTPUT JOCKEY PUMP PRESSURE : 200 PSI

18 RELEASE WATER FOR AUTOMATIC TESTED:

18.1 FIRE PUMP:

START : 220 PSI

18.2 JOCKEY PUMP:

START : 210 PSI STOP : 200 PSI
TIME : START 15.10 TIME : STOP 15.20

19

SECTION / REMARKS:

Manual test Running

CHECKED BY : MEON

APPROVED BY :

DATE : 5 / 1 / 2024

DATE :

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT : Grand Mercure Bangkok Asoke Residence	DATE : 9 / 2 / 2024
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL : 488 LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M <input checked="" type="checkbox"/> H
3 EXAMINE LEVEL OF WATER IN BOILER :	[] L [] M <input checked="" type="checkbox"/> H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY :	[] L [] M <input checked="" type="checkbox"/> H
5 RECORDED VOLTAGE OF BATTERY : B1. 14.6 V B2. 13.1 V	
6 RECORDED ENGINE WATER TEMPERATURE : 80 C	
7 RECORDED PRESSURE OF LUBRICATING OIL : 60 PSI	
8 RECORDED SPEED OF FIRE PUMP : 1700 RPM	
9 RECORDED WORK HOUR OF FIRE PUMP : 000315 HOUR	
10 EXAMINE AIR FILTER OF FIREPUMP :	<input checked="" type="checkbox"/> NORMAL [] CLEAN [] CHANGE
11 EXAMINE LEAKAGE OF OIL PIPE :	<input checked="" type="checkbox"/> NORMAL [] CLEAN [] CHANGE
12 TEST THE OPERATION OF CONTROL CABINET :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
13 TEST THE OPERATION OF RELEASE VALVE :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
14 TEST THE OPERATION OF CHECK VALVE :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
16 CLEAN FIRE PUMP, BATTERY AND FUEL TANK :	<input checked="" type="checkbox"/> CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE : 250 PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE : 240 PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED :	
18.1 FIRE PUMP :	START : 220 PSI
18.2 JOCKEY PUMP :	START : 240 PSI STOP : 240 PSI
19	TIME : START 15.00 TIME : STOP 15.10

SUGGESTION / REMARKS : Normal test Running


CHECKED BY : <u>MUSON</u> DATE : 9 / 2 / 2024	APPROVED BY : _____ DATE : _____
--	-------------------------------------

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT : Grand Mercure Bangkok Asoke Residence	DATE : 7 / 3 / 2024
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL : 480 LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [] H
3 EXAMINE LEVEL OF WATER IN BOILER :	[] L [] M [] H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY :	[] L [] M [] H
5 RECORDED VOLTAGE OF BATTERY : B1. 12.5 V B2. 12.6 V	
6 RECORDED ENGINE WATER TEMPERATURE : 80 C	
7 RECORDED PRESSURE OF LUBRICATING OIL : 60 PSI	
8 RECORDED SPEED OF FIRE PUMP : RPM	
9 RECORDED WORK HOUR OF FIRE PUMP : 000316 HOUR	
EXAMINE AIR FILTER OF FIREPUMP :	<input checked="" type="checkbox"/> NORMAL [] CLEAN [] CHANGE
11 EXAMINE LEAKAGE OF OIL PIPE :	<input checked="" type="checkbox"/> NORMAL [] CLEAN [] CHANGE
12 TEST THE OPERATION OF CONTROL CABINET :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
13 TEST THE OPERATION OF RELEASE VALVE :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
14 TEST THE OPERATION OF CHECK VALVE :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
16 CLEAN FIRE PUMP BATTERY AND FUEL TANK :	<input checked="" type="checkbox"/> CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE : 250 PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE : 240 PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED :	
18.1 FIRE PUMP :	START : 220 PSI
18.2 JOCKEY PUMP :	START : 210 PSI STOP : 240 PSI
19	TIME : START 15:00 TIME : STOP 15:10

SUGGESTION / REMARKS : Manual test Running

CHECKED BY :  APPROVED BY :
 DATE : 7 / 3 / 24 DATE :

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT : Grand Mercure Bangkok Asoke Residence	DATE : 7 A 2021
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

- 1 RECORDED LEVEL OF DIESEL OIL : 175 LITE
- 2 EXAMINE LEVEL OF LUBRICANT OIL : [] L [] M [] H
- 3 EXAMINE LEVEL OF WATER IN BOILER : [] L [] M [] H
- 4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY : [] L [] M [] H
- 5 RECORDED VOLTAGE OF BATTERY : B1. 14.6 V B2. 12.6 V
- 6 RECORDED ENGINE WATER TEMPERATURE : 80 C
- 7 RECORDED PRESSURE OF LUBRICATING OIL : 60 PSI
- 8 RECORDED SPEED OF FIRE PUMP : 1700 RPM
- 9 RECORDED WORK HOUR OF FIRE PUMP : 000321 HOUR

- 10 EXAMINE AIR FILTER OF FIREPUMP : [] NORMAL [] CLEAN [] CHANGE
- 11 EXAMINE LEAKAGE OF OIL PIPE : [] NORMAL [] CLEAN [] CHANGE
- 12 TEST THE OPERATION OF CONTROL CABINET : [] NORMAL [] ABNORMAL [] CORRECT
- 13 TEST THE OPERATION OF RELEASE VALVE : [] NORMAL [] ABNORMAL [] CORRECT
- 14 TEST THE OPERATION OF CHECK VALVE : [] NORMAL [] ABNORMAL [] CORRECT
- 15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP : [] NORMAL [] ABNORMAL [] CORRECT
- 16 CLEAN FIRE PUMP, BATTERY AND FUEL TANK : [] CLEAN [] NO CLEAN
- 17 RECORDED PRESSURE OF WATER PIPE :
- 17.1 OUTPUT FIRE PUMP PRESSURE : 250 PSI
- 17.2 OUTPUT JOCKEY PUMP PRESSURE : 240 PSI
- 18 RELEASE WATER FOR AUTOMATIC TESTED:
- 18.1 FIRE PUMP: START : 220 PSI
- 18.2 JOCKEY PUMP: START : 210 PSI STOP : 240 PSI
- 19 TIME : START : 15.30 TIME : STOP : 15.40

TESTION / REMARKS

Manual test Running

CHECKED BY : [Signature] APPROVED BY :

DATE : 7 A 2021


DATE :

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT : Grand Mercure Bangkok Asoke Residence	DATE : 7 5 2024
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL : 460 LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M <input checked="" type="checkbox"/> H
3 EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M <input checked="" type="checkbox"/> H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M <input checked="" type="checkbox"/> H
5 RECORDED VOLTAGE OF BATTERY : B1 14.1 V B2 12.6 V	
6 RECORDED ENGINE WATER TEMPERATURE : 80 C	
7 RECORDED PRESSURE OF LUBRICATING OIL : 60 PSI	
8 RECORDED SPEED OF FIRE PUMP : 1700 RPM	
9 RECORDED WORK HOUR OF FIRE PUMP : 000328 HOUR	
EXAMINE AIR FILTER OF FIREPUMP :	<input checked="" type="checkbox"/> NORMAL [] CLEAN [] CHANGE
11 EXAMINE LEAKAGE OF OIL PIPE :	<input checked="" type="checkbox"/> NORMAL [] CLEAN [] CHANGE
12 TEST THE OPERATION OF CONTROL CABINET:	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
13 TEST THE OPERATION OF RELASE VALVE:	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
14 TEST THE OPERATION OF CHECK VALVE :	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	<input checked="" type="checkbox"/> NORMAL [] ABNORMAL [] CORRECT
16 CLEAN FIRE PUMP ,BATTERY AND FUEL TANK :	<input checked="" type="checkbox"/> CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE : 250 PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE : 240 PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED:	
18.1 FIRE PUMP:	START 220 PSI
18.2 JOCKEY PUMP:	START 210 PSI STOP 240 PSI
19	TIME : START 15.00 TIME : STOP 15.10

GESTION / REMARKS : Manual Test Running

CHECKED BY : 	APPROVED BY :
DATE : 7 5 24	DATE :



GRAND MERCURE
BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure

DATE :7...../.....6...../.....67.....

SYSTEM : FIRE PROTECTION

FREQUENCY : WEEKLY

EQUIPMENT : FIRE PUMP

LOCATION : PUMP ROOM TOWER B.

- 1 RECORDED LEVEL OF DIESEL OIL :458.....LITE
- 2 EXAMINE LEVEL OF LUBRICANT OIL : ☐ L ☐ M ☐ H
- 3 EXAMINE LEVEL OF WATER IN BOILER: ☐ L ☐ M ☐ H
- 4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY: ☐ L ☐ M ☐ H
- 5 RECORDED VOLTAGE OF BATTERY : B1.....14.7.....V B2.....12.5.....V
- 6 RECORDED ENGINE WATER TEMPERATURE :80.....C
- 7 RECORDED PRESSURE OF LUBRICATING OIL :60.....PSI
- 8 RECORDED SPEED OF FIRE PUMP :1700.....RPM
- 9 RECORDED WORK HOUR OF FIRE PUMP :000329.....HOUR
- 10 EXAMINE AIR FILTER OF FIREPUMP : ☐ NORMAL ☐ CLEAN ☐ CHANGE
- 11 EXAMINE LEAKAGE OF OIL PIPE : ☐ NORMAL ☐ CLEAN ☐ CHANGE
- 12 TEST THE OPERATION OF CONTROL CABINET: ☐ NORMAL ☐ ABNORMAL ☐ CORRECT
- 13 TEST THE OPERATION OF RELASE VALVE: ☐ NORMAL ☐ ABNORMAL ☐ CORRECT
- 14 TEST THE OPERATION OF CHECK VALVE : ☐ NORMAL ☐ ABNORMAL ☐ CORRECT
- 15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP: ☐ NORMAL ☐ ABNORMAL ☐ CORRECT
- 16 CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK : ☐ CLEAN ☐ NO CLEAN
- 17 RECORDED PRESSURE OF WATER PIPE :
- 17.1 OUTPUT FIRE PUMP PRESSURE :250.....PSI
- 17.2 OUTPUT JOCKEY PUMP PRESSURE :240.....PSI
- 18 RELEASE WATER FOR AUTOMATIC TESTED:
- 18.1 FIRE PUMP: START :220.....PSI
- 18.2 JOCKEY PUMP: START :210.....PSI STOP :240.....PS
- 19 TIME :START.....15.00..... TIME :STOP.....15.10.
- 20

SUGGESTION / REMARKS.....Manual test Running.....

CHECKED BY :.....

APPROVED BY :.....

DATE :7...../.....6...../.....67.....

DATE :7...../.....6...../.....67.....

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF January 2024

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: ธีรชัย
	Guest's life Zone		Staff's lift Zone		DATE : 7/1/67
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF February 2024

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: ธีรชัย
	Guest's life Zone		Staff's lift Zone		DATE : 7/2/67
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....



GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF March 2024

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: ธีรชัย
	Guest's life Zone		Staff's lift Zone		DATE : 7/3/67
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

.....



GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF April 2024

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: ธีรชัย
	Guest's life Zone		Staff's lift Zone		DATE : 7/4/67
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....
.....
.....
.....



GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF May 2024

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: ธีรชัย
	Guest's life Zone		Staff's lift Zone		DATE : 7/5/67
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....



GRAND MERCURE
BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF June 2024

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: ฐวัชชัย
	Guest's life Zone		Staff's lift Zone		DATE : 7/6/67
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF January 2024

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7 / 1 / 2024	Remark
	Guest's life Zone		Staff's lift Zone		CHECK BY 10/08/24	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/		10/08/24 7/1/24	JMS
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/		/			
Laundry room	/		/			
Administration office	/		/			
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF February 2024

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7 / 2 / 2024	Remark
	Guest's life Zone		Staff's lift Zone		CHECK BY: 10/08/24	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor	/	/	/			
12 th floor	/	/	/			
11 th floor	/	/	/			
10 th floor	/	/	/			
9 th floor	/	/	/			
8 th floor	/	/	/			
7 th floor	/	/	/			
6 th floor	/	/	/			
5 th floor	/	/	/			Normal
4 th floor	/	/	/		10/08/24	
3 rd floor	/	/	/		7/2/24	
2 nd floor	/	/	/			
Ground floor		/	/			
Basement floor	/	/	/			
Laundry room	/	/	/			
Administration office	/	/	/			
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF March 2024

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/3/2024	Remark
	Guest's life Zone		Staff's lift Zone			
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE	CHECK BY	
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/		10/08/24	Normal
3 rd floor		/	/		7/3/24	
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/		/			
Laundry room	/		/			
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF April 2024

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7 / 1 / 2024	Remark
	Guest's life Zone		Staff's lift Zone		CHECK BY: [Signature]	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/		[Signature] 7/1/2024	Normal
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF May 2024

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/5/67	Remark
	Guest's life Zone		Staff's lift Zone			
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE	CHECK BY ๓๖๗๗๗	
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF June2024

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/6/67	Remark
	Guest's life Zone		Staff's lift Zone			
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE	CHECK BY รัชชัย	
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....