

ภาคผนวก ข

เอกสารประกอบการปฏิบัติตามมาตรการด้านสิ่งแวดล้อม

ภาคผนวก ข

เอกสารประกอบการปฏิบัติตามมาตรการด้านสิ่งแวดล้อม

- ข1 เอกสารการตรวจสอบระบบบำบัดแบบตะกอนเร่ง (Activated Sludge)
- ข2 เอกสารการดูแลรักษาและควบคุมระบบบำบัดน้ำเสีย
- ข3 เอกสารการสูบน้ำส่วนเกินจากระบบบำบัดน้ำเสีย
- ข4 เอกสารรับรองการขอเข้ารับบริการระบบบำบัดน้ำเสีย
ของโรงควบคุมคุณภาพน้ำดินแดง กรุงเทพมหานคร
- ข5 เอกสารการประสานงานร้านซื้อของเก่าใกล้เคียงให้เข้ามารับซื้อมูลฝอย
- ข6 เอกสารระบบป้องกันและเตือนอัคคีภัย
- ข7 เอกสารการตรวจสอบระบบป้องกันและเตือนอัคคีภัย
- ข8 เอกสารการจัดอบรมและซ้อมการอพยพคนกรณีเพลิงไหม้
- ข9 เอกสารการปฏิบัติตามข้อกำหนดในประกาศกรมอนามัย
ข้อปฏิบัติการควบคุมเชื้อลิจิโอเนลลาในหอผึ่งเย็นของอาคาร
- ข10 เอกสารการตรวจสอบอุปกรณ์ที่ใช้ระบายอากาศ
- ข11 เอกสารการรณรงค์ให้ผู้มาใช้บริการใช้บริการรถไฟฟ้าขนส่งมวลชน
- ข12 เอกสารการปฏิบัติตาม พ.ร.บ. การส่งเสริมการอนุรักษ์พลังงาน พ.ศ.2535
- ข13 เอกสารประชาสัมพันธ์วิธีการประหยัดพลังงาน
- ข14 รูปประกอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม

ภาคผนวก ข1

เอกสารการตรวจสอบระบบบำบัดแบบตะกอนเร่ง
(Activated Sludge)

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/67

EJECTOR PUMP NO ...1.....

TIME 14.00

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month <small>Mar,Jun,Sep,Dec</small>	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY .. 

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH1/67.....

EJECTOR PUMP NO ...2.....

TIME14.00.....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/67

EJECTOR PUMP NO ...3.....

TIME 12.00

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY RECHECK BY ... 

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/67

EJECTOR PUMP NO ...4.....

TIME 14.00

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<u>✓</u>	
	2	Cleanning Overall Inside Panel Control	<u>✓</u>					
	3	Fitting All Inside Panel Control					<u>✓</u>	
	4	Testing Overload					<u>✓</u>	
	5	Testing Timer Operate					<u>✓</u>	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... 

RECHECK BY ... 

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/67

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY .. [REDACTED]

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/67

EJECTOR PUMP NO ...6.....

TIME 14.00

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<u>/</u>	
	2	Cleanning Overall Inside Panel Control	<u>/</u>					
	3	Fitting All Inside Panel Control					<u>/</u>	
	4	Testing Overload					<u>/</u>	
	5	Testing Timer Operate					<u>/</u>	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY ... 

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/69

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... 

RECHECK BY .. 

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/67

EJECTOR PUMP NO ...8.....

TIME 12.00

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<u>/</u>	
	2	Cleanning Overall Inside Panel Control	<u>/</u>					
	3	Fitting All Inside Panel Control					<u>/</u>	
	4	Testing Overload					<u>/</u>	
	5	Testing Timer Operate					<u>/</u>	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH ..04/02/07.....

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY .. [REDACTED]

RECHECK BY ... [REDACTED]

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 04/02/19

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 04/02/19

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... RECHECK BY ... 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 04/02/67

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY . [REDACTED]

RECHECK BY ... [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 04/02/67

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY RECHECK BY 

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH ..04/02/57.....

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

.....

RECORD BY . [REDACTED]

RECHECK BY ... [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 04/02/17

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 04/02/67.....

EJECTOR PUMP NO ...8.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY .. 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 15/8/67

EJECTOR PUMP NO ...8.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE for Mr.

COMMENT

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 16/3/67

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY . [REDACTED]

RECHECK BY ... [REDACTED]

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 16/3/67.....

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... [REDACTED]

RECHECK BY ... [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 16/3/67.....

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY .. RECHECK BY .. 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 16/3/67

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH ...16/3/67...

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... [REDACTED]

RECHECK BY ... [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH16/3/67.....

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 16/3/67.....

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... 

RECHECK BY ... 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 21/4/67

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ...

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 7/4/67

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY ...

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 14/67

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY . [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 7/4/67.....

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 7/4/67

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					✓	
	7	Check Chain					✓	
	8	Check Piping And Valves					✓	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 7/4/67

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY 

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/11/67

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

EJECTOR PUMP

MAINTENANCE REPORT

MONTH 7/14/67.....

TIME

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE ชุดความรู้ ๑๓๐/๒๕๖๓

COMMENT

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/9/67

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/5/67

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/5/67

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY ...

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/5/67.....

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ... [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/5/67

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED] ..

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH5/9/67.....

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/5/67.....

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/5/67

EJECTOR PUMP NO ...8.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE ฝึกลูก (ยกเล็กใช้งาน)

COMMENT

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/67

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/67

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

[REDACTED]

RECHECK BY

[REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH6/07.....

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/67

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY



EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH ๕/๐๗

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload						/
	5	Testing Timer Operate						/
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE ปล่อยเสียงนกหวีด (๓๐ วินาที)

COMMENT

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/07

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/07

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/67

EJECTOR PUMP NO ...8.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	/
	5	Testing Timer Operate						/
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain	/					
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE 2/2/67 (20602)

COMMENT

RECORD BY

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 1/67
TIME 14.00

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....
.....
.....

COMMENT

.....
.....
.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 1 / 67
TIME 14.00

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....
.....
.....

COMMENT

.....
.....
.....

RECORD BY [REDACTED]

RECHECK BY ... [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 16/2/67
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operation					✓	
	6	Check Sludge Level In The Tank					✓	
3 Month <small>Mar,Jun,Sep,Dec</small>	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY .. [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 16/2/67
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operation					✓	
	6	Check Sludge Level In The Tank					✓	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY .. [REDACTED] RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 16/03/67.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation		/				
	6	Check Sludge Level In The Tank		/				
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 16/03/67.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 4/4/67
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	


N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED


NOTE

.....
.....
.....

COMMENT

.....
.....
.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 4/4/07

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 5/5/67.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 5/5/17

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<u>/</u>	
	2	Cleanning Overall Inside Panel Control	<u>/</u>					
	3	Fitting All Inside Panel Control					<u>/</u>	
	4	Testing Overload					<u>/</u>	
	5	Testing Timer Operation					<u>/</u>	
	6	Check Sludge Level In The Tank					<u>/</u>	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve					<u>/</u>	
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 6/67
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/				/	
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/				/	
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY ... [REDACTED]

RECHECK BY . [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 6/67
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/				/	
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/				/	
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....
.....
.....

COMMENT

.....
.....
.....

RECORD BY



RECHECK BY



GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 1

MONTH1/67.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 2

MONTH9/67.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 21/2/67

SLUDGE RETURN PUMP 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operation					✓	
	6	Check Sludge Level In The Tank					✓	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ... [REDACTED]

RECHECK BY ... [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 21/2/67

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY ... 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 1

MONTH 16/03/67.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operation					✓	
	6	Check Sludge Level In The Tank					✓	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	✓					
	8	Check Guide Well					✓	
	9	Check Piping And Valve					✓	

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 16/03/67.....

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation		/				
	6	Check Sludge Level In The Tank		/				
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY . [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 1

MONTH 11/11/16.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control					✓	
	4	Testing Overload					✓	
	5	Testing Timer Operation					✓	
	6	Check Sludge Level In The Tank					✓	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	✓					
	8	Check Guide Well					✓	
	9	Check Piping And Valve					✓	

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 2

MONTH 5/4/67.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 1

MONTH 5/6/67

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<input checked="" type="checkbox"/>	
	2	Cleanning Overall Inside Panel Control	<input checked="" type="checkbox"/>					
	3	Fitting All Inside Panel Control					<input checked="" type="checkbox"/>	
	4	Testing Overload					<input checked="" type="checkbox"/>	
	5	Testing Timer Operation					<input checked="" type="checkbox"/>	
	6	Check Sludge Level In The Tank					<input checked="" type="checkbox"/>	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 2

MONTH 5/5/67
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month <small>Mar,Jun,Sep,Dec</small>	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE
.....
.....
.....

COMMENT
.....
.....
.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
SLUDGE RETURN PUMP 1

MONTH 6/67
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/				/	
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve					/	
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/67

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control					/	
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month	7	Cleanning & Check Shake Valve					/	
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY