

ภาคผนวก ข2

เอกสารการดูแลรักษาและควบคุมระบบบำบัดน้ำเสีย

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 1/2564

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.3	11.2	11.3	11.3	11.3	11.3	11.3
		S	11.8	11.2	11.2	11.4	11.4	11.4	11.4
		T	11.6	11.2	11.3	11.4	11.3	11.3	11.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	10.9	10.9	10.9	10.9
		S	11.3	11.0	11.1	11.3	11.3	11.3	11.2
		T	11.2	11.0	11.0	10.9	10.9	10.9	10.8
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		UN	UN	UN	UN	UN	UN	UN
SLP2	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		UN	UN	UN	UN	UN	UN	UN
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.9	7.2	6.9	6.9	6.9	6.9	6.9
		S	7.1	7.2	7.0	7.0	7.0	7.0	7.0
		T	7.0	7.2	7.2	7.2	7.1	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.9	7.6	7.6	7.6	7.6	7.6	7.6
		S	7.6	7.6	7.6	7.6	7.6	7.6	7.6
		T	7.6	7.6	7.5	7.5	7.5	7.5	7.5
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.2	3.1	3.1	3.1	3.1	3.1	3.1
		S	3.1	3.1	3.1	3.1	3.1	3.1	3.1
		T	3.2	3.2	3.1	3.1	3.1	3.1	3.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	2.3	2.3	2.1	2.1	2.1	2.1	2.1
		S	1.9	2.3	1.9	2.0	2.0	2.1	2.1
		T	1.8	1.9	1.9	2.0	2.0	2.0	2.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	3.3	3.5	3.2	3.6	3.6	3.6	3.6
		S	3.5	3.3	3.3	3.6	3.6	3.4	3.4
		T	3.3	3.2	3.5	3.7	3.7	3.4	3.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.9	4.0	7.1	4.0	7.0	7.0	7.0
		S	7.2	7.2	7.2	6.3	6.3	6.8	6.8
		T	7.0	7.0	7.0	6.9	6.9	6.9	6.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.2	6.2	6.3	6.1	6.1	6.1	6.1
		S	6.3	6.3	6.3	6.3	6.3	6.3	6.3
		T	6.5	6.4	6.2	6.2	6.2	6.2	6.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	5.9	5.9	5.9	5.5	5.6	5.6	5.6
		S	5.9	5.9	6.0	5.6	5.6	5.6	5.6
		T	5.9	5.9	5.9	5.9	5.8	5.7	5.7
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.6	4.9	4.5	4.6	4.6	4.6	4.6
		S	4.9	4.8	4.6	4.6	4.6	4.6	4.6
		T	4.2	4.9	4.8	4.6	4.6	4.6	4.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE6	Auto/Off/Manual		A	M	M	A	A	A	A
	Current(A)	R	6.7	6.7	6.8	6.8	6.8	6.8	6.8
		S	8.0	6.8	6.7	6.8	6.4	6.4	6.4
		T	6.9	6.7	6.8	6.9	6.8	6.8	6.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE7	Auto/Off/Manual		M	A	A	M	M	M	M
	Current(A)	R	7.9	7.9	7.9	7.6	7.6	7.6	7.6
		S	7.8	7.8	7.8	7.4	7.4	7.4	7.4
		T	7.8	7.9	7.9	7.5	7.8	7.8	7.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE8	Auto/Off/Manual		A	A	A	M	M	M	M
	Current(A)	R	7.3	7.2	7.3	7.3	7.3	7.3	7.3
		S	7.2	7.3	7.3	7.2	7.2	7.2	7.2
		T	7.5	7.2	7.5	7.1	7.1	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
Date Check >>			1 / 1 / 14	2 / 1 / 14	3 / 1 / 14	4 / 1 / 14	5 / 1 / 14	6 / 1 / 14	7 / 1 / 14
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 8-14/1/67

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	n	M	M
	Current(A)	R	11.3	11.3	11.6	11.3	11.2	11.2	11.2
		S	11.8	11.8	12.1	11.9	11.8	11.8	11.3
		T	11.6	11.6	11.9	11.8	11.4	11.4	11.3
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.6	11.5	11.6	11.6
		S	11.2	11.1	12.0	11.9	11.6	11.5	11.5
		T	11.1	11.2	11.6	11.5	11.4	11.4	11.6
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.3	1.2	1.2	1.3	1.2	1.2	1.2
		S	1.4	1.3	1.4	1.4	1.3	1.3	1.3
		T	1.4	1.6	1.6	1.6	1.5	1.5	1.5
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.3	1.3	1.1	1.9	1.8	1.8	1.8
		S	1.3	1.4	1.2	1.3	1.7	1.4	1.4
		T	1.6	1.5	1.9	2.0	1.9	1.9	1.4
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.9	6.9	7.0	6.8	6.9	6.6	6.6
		S	7.0	7.0	7.0	7.1	7.0	7.0	6.9
		T	7.1	7.1	7.1	6.9	6.9	6.9	6.9
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.6	7.6	7.5	7.4	7.3	7.3	7.3
		S	7.6	7.4	7.4	7.6	7.5	7.5	7.9
		T	7.5	7.6	7.6	7.5	7.4	7.4	7.4
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.1	3.1	1.1	2.9	2.3	2.4	2.3
		S	3.1	3.0	1.1	1.7	1.9	1.9	2.4
		T	3.1	3.1	1.2	1.8	1.8	2.0	2.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	2.2	2.1	1.6	2.4	2.3	2.4	2.4
		S	2.0	2.1	1.6	1.8	2.5	2.5	2.5
		T	2.0	2.0	1.6	1.9	2.6	2.5	2.5
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

DS-115

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	3.6	3.6	3.4	3.5	3.6	3.6	3.6
		S	3.6	2.4	3.7	3.4	3.3	3.3	3.4
		T	3.7	3.6	3.9	3.4	3.6	3.6	3.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	4.0	4.1	4.2	4.1	4.2	4.2	4.2
		S	6.3	6.5	4.1	4.3	4.2	4.3	4.3
		T	6.4	6.6	6.9	4.0	4.2	4.1	4.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.4	6.8	6.5	6.5	6.5
		S	6.3	6.1	6.8	6.3	6.4	6.4	6.6
		T	6.2	6.3	6.8	6.2	6.6	6.5	6.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE4	Auto/Off/Manual		M	M	A	M	A	A	A
	Current(A)	R	5.5	5.6	5.5	6.0	5.9	6.0	6.0
		S	5.6	5.3	6.0	5.9	5.8	5.9	5.9
		T	5.9	5.8	5.9	5.5	5.5	5.6	5.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.6	4.6	4.7	4.9	4.8	4.8	4.8
		S	4.7	4.7	4.9	4.7	4.8	4.9	4.9
		T	4.6	4.6	4.8	4.7	4.8	4.9	4.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE6	Auto/Off/Manual		A	A	M	M	M	M	M
	Current(A)	R	4.8	4.8	4.1	4.4	4.3	4.3	4.3
		S	4.9	4.9	4.5	4.8	4.4	4.4	4.4
		T	4.9	4.8	4.4	4.4	4.3	4.4	4.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE7	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.6	4.6	4.9	4.9	4.8	4.8	4.8
		S	4.7	4.7	4.8	4.8	4.7	4.7	4.7
		T	4.8	4.8	4.2	4.0	4.9	4.8	4.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE8	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	4.3	4.3	4.4	4.7	4.6	4.6	4.6
		S	4.2	4.2	4.6	4.5	4.4	4.4	4.4
		T	4.1	4.2	4.7	4.6	4.5	4.5	4.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
Date Check >>			8 / 1 / 14	9 / 1 / 14	10 / 1 / 14	11 / 1 / 14	12 / 1 / 14	13 / 1 / 14	14 / 1 / 14
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 15-22/1/67

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.3	11.3	11.3	11.2	11.2	11.2	11.3
		S	11.8	11.8	11.9	11.8	11.8	11.6	11.9
		T	11.6	11.6	11.8	11.4	11.6	11.5	11.8
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.6	11.5	11.6	11.6	11.6
		S	11.9	11.2	11.9	11.8	11.4	11.7	11.9
		T	11.2	11.1	11.5	11.4	11.8	11.8	11.9
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.3	1.3	1.3	1.2	1.2	1.2	1.3
		S	1.6	1.4	1.4	1.3	1.3	1.3	1.4
		T	1.4	1.6	1.6	1.5	1.6	1.4	1.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.5	1.3	1.9	1.8	1.8	1.8	1.9
		S	2.5	1.4	1.9	1.7	1.4	1.4	1.9
		T	1.8	1.6	2.0	1.9	1.9	1.9	2.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.9	6.9	6.8	6.7	6.4	6.4	6.8
		S	7.0	7.0	7.1	7.0	7.0	7.0	7.1
		T	7.1	7.1	6.9	6.8	6.5	6.9	6.9
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	2.6	2.6	2.4	2.3	2.3	2.3	2.4
		S	2.6	2.6	2.6	2.5	2.5	2.5	2.6
		T	2.4	2.5	2.5	2.4	2.4	2.4	2.5
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.9	3.1	2.9	3.0	3.0	3.0	2.9
		S	3.1	3.2	3.3	3.1	3.1	3.1	3.3
		T	3.2	3.1	3.3	3.0	3.0	3.0	3.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	2.2	2.3	2.4	2.4	2.4	2.4	2.4
		S	2.0	2.1	2.3	2.0	2.2	2.2	2.3
		T	2.1	2.2	2.3	2.1	2.1	2.1	2.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

← 15-22/1/67

← 15-22/1/67
15-22/1/67
15-22/1/67

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	3.6	3.6	3.5	3.6	3.6	3.6	3.5
		S	3.6	3.5	3.4	3.8	3.4	3.4	3.4
		T	3.7	3.7	3.7	3.7	3.6	3.6	3.7
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	4.0	4.0	4.1	4.0	4.0	4.0	4.1
		S	6.6	6.9	7.3	6.9	6.9	6.9	7.3
		T	6.7	6.9	7.0	6.8	6.9	6.8	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.5	6.4	6.4	6.4	6.5
		S	6.3	6.3	6.3	6.3	6.4	6.4	6.3
		T	6.2	6.3	6.2	6.3	6.4	6.4	6.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	A	M	M	M	A
	Current(A)	R	5.5	5.4	6.0	5.9	5.8	5.9	6.0
		S	5.6	5.5	5.9	5.7	5.8	5.8	5.9
		T	5.8	5.6	5.5	5.5	5.6	5.8	5.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.6	4.6	4.9	4.6	4.6	4.6	4.9
		S	4.7	4.7	4.7	4.7	4.3	4.7	4.7
		T	4.6	4.7	4.7	4.6	4.6	4.6	4.7
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	M	A	A	A	M
	Current(A)	R	6.8	6.8	4.4	4.2	4.9	4.2	4.4
		S	6.4	6.9	4.5	4.2	4.3	4.3	4.5
		T	6.9	6.8	4.4	4.2	4.2	4.3	4.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		A	A	A	M	M	M	A
	Current(A)	R	4.6	4.6	4.9	4.8	4.8	4.8	4.9
		S	4.7	4.7	4.8	4.9	4.9	4.9	4.8
		T	4.8	4.7	8.0	4.8	4.8	4.8	8.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		M	M	A	M	M	M	A
	Current(A)	R	4.3	4.3	4.7	4.3	4.3	4.3	4.7
		S	4.2	4.2	4.5	4.6	4.6	4.6	4.5
		T	4.2	4.2	4.6	4.5	4.5	4.5	4.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			15/1/17	16/1/17	17/1/17	18/1/17	19/1/17	20/1/17	21/1/17
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH

2/67

WASTE WATERTREATMENT PLANT

TIME

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	A	M	A	M			
	Current(A)	R	10.7	11.1	10.9	11.8		
		S	11.4	11.6	11.7	11.9		
		T	11.2	11.3	11.4	11.4		
	Overload -Alarm	N	N	N	N			
	Latching relay control	N	N	N	N			
WWP2	Auto/Off/Manual	M	M	M	M			
	Current(A)	R	9.6	10.3	10.9	11.2		
		S	11.5	11.5	11.6	11.9		
		T	11.4	11.4	11.6	11.8		
	Overload -Alarm	N	N	N	N			
	Latching relay control	N	N	N	N			
SLP1	Auto/Off/Manual	A	A	A	A			
	Current(A)	R	0.9	0.9	0.9	1.0		
		S	1.0	1.0	1.0	1.1		
		T	1.1	1.0	1.1	1.1		
	Timer	N	N	N	N			
	Overload -Alarm	N	N	N	N			
SLP2	Auto/Off/Manual	A	A	A	A			
	Current(A)	R	1.7	1.6	1.7	1.6		
		S	1.5	1.5	1.6	1.7		
		T	1.7	1.6	1.9	1.6		
	Timer	N	N	N	N			
	Overload -Alarm	N	N	N	N			
DP1	Auto/Off/Manual	M	M	M	M			
	Current(A)	R	6.4	6.7	6.7	6.9		
		S	7.4	7.5	7.3	7.8		
		T	7.1	7.2	7.1	7.8		
	Overload -Alarm	N	N	N	N			
	Latching relay control	N	N	N	N			
DP2	Auto/Off/Manual	M	M	M	M			
	Current(A)	R	7.5	7.6	7.6	7.7		
		S	7.6	7.7	7.5	7.7		
		T	7.7	7.9	7.8	7.6		
	Overload -Alarm	N	N	N	N			
	Latching relay control	N	N	N	N			
SP1	Auto/Off/Manual	M	M	M	M			
	Current(A)	R	3.3	3.3	3.3	3.3		
		S	3.4	3.3	2.0	3.0		
		T	3.1	1.6	2.0	3.6		
	Overload -Alarm	N	N	N	N			
	Latching relay control	N	N	N	N			
SP2	Auto/Off/Manual	M	M	M	M			
	Current(A)	R	2.3	2.2	2.4	2.3		
		S	2.3	2.2	2.3	2.6		
		T	2.1	2.2	2.2	2.6		
	Overload -Alarm	N	N	N	N			
	Latching relay control	N	N	N	N			
Pilot Lamp		N	N	N	N			

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	3.1	3.2	3.4	3.1			
		S	3.8	3.7	3.8	3.8			
		T	3.9	3.8	4.0	3.9			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
SE2	Auto/Off/Manual		M	M	M	A			
	Current(A)	R	6.1	6.7	6.8	6.0			
		S	7.2	7.0	6.9	6.1			
		T	6.8	6.9	6.7	6.0			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
SE3	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	6.8	6.0	6.0	6.1			
		S	6.9	6.7	6.7	6.8			
		T	6.7	6.7	6.8	6.6			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
SE4 (CAT)	Auto/Off/Manual		M	M	M	A			
	Current(A)	R	6.8	6.9	5.6	6.1			
		S	6.8	6.2	6.4	6.1			
		T	6.9	6.8	5.8	6.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
SE5 (CAT)	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	4.5	4.5	4.5	4.7			
		S	4.3	3.8	4.8	4.8			
		T	5.0	4.4	4.8	4.8			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
SE6	Auto/Off/Manual		A	M	M	A			
	Current(A)	R	6.8	7.1	7.2	6.8			
		S	7.6	7.3	7.4	6.8			
		T	6.7	6.9	7.0	6.7			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
SE7	Auto/Off/Manual		M	M	A	A			
	Current(A)	R	8.6	8.2	8.1	8.8			
		S	8.8	8.4	8.3	8.8			
		T	8.4	8.1	8.1	8.7			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
SE8	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	7.0	6.9	7.0	7.3			
		S	7.5	7.4	7.5	7.3			
		T	7.3	7.3	7.4	7.6			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp			N	N	N	N			
Date Check >>			26/2/07	27/2/07	28/2/07	29/2/07			
Record By >>									
Recheck By >>									

Remark: SE7, SE8 N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 1-4/2/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual					M	M	M	M
	Current(A)	R				10.1	9.8	10.1	10.6
		S				11.2	11.5	11.3	11.4
		T				11.0	11.5	11.0	11.1
	Overload -Alarm					N	N	N	N
	Latching relay control					N	N	N	N
WWP2	Auto/Off/Manual					M	M	M	M
	Current(A)	R				10.1	11.0	10.9	11.0
		S				11.5	11.6	11.6	11.7
		T				11.4	11.7	11.4	11.4
	Overload -Alarm					N	N	N	N
	Latching relay control					N	N	N	N
SLP1	Auto/Off/Manual					Off	Off	A	A
	Current(A)	R				-	-	1.0	1.0
		S				-	-	1.0	1.0
		T				-	-	1.0	1.0
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
SLP2	Auto/Off/Manual					A	A	A	M
	Current(A)	R				1.6	1.6	1.6	1.6
		S				1.6	1.6	1.6	1.5
		T				1.5	1.5	1.6	1.6
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
DP1	Auto/Off/Manual					M	M	M	M
	Current(A)	R				6.3	6.5	6.3	6.4
		S				7.4	7.0	7.2	7.3
		T				7.2	6.7	7.0	7.1
	Overload -Alarm					N	N	N	N
	Latching relay control					N	N	N	N
DP2	Auto/Off/Manual					M	M	M	M
	Current(A)	R				7.6	7.3	7.2	7.5
		S				7.6	7.3	7.3	7.5
		T				7.7	7.4	7.5	7.7
	Overload -Alarm					N	N	N	N
	Latching relay control					N	N	N	N
SP1	Auto/Off/Manual					M	M	M	M
	Current(A)	R				3.2	3.3	1.2	3.1
		S				2.1	2.2	1.3	3.2
		T				2.0	2.1	1.3	2.0
	Overload -Alarm					N	N	N	N
	Latching relay control					N	N	N	N
SP2	Auto/Off/Manual					M	M	M	M
	Current(A)	R				2.3	2.2	3.6	2.4
		S				2.4	2.2	3.5	2.1
		T				2.3	2.2	3.4	2.1
	Overload -Alarm					N	N	N	N
	Latching relay control					N	N	N	N

* บันทึกค่าการไหลของน้ำในระบบ SP2 1/2/67. ค่าการไหลของน้ำในระบบ. 3/2/67. *

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual					A	A	A	A
	Current(A)	R				3.5	3.5	3.5	3.4
		S				3.9	3.8	3.2	3.5
		T				4.0	3.9	3.9	3.8
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
SE2	Auto/Off/Manual					M	M	M	M
	Current(A)	R				6.5	6.6	6.5	6.6
		S				7.0	6.4	6.8	7.1
		T				6.9	6.7	6.9	6.6
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
SE3	Auto/Off/Manual					A	A	A	A
	Current(A)	R				6.3	6.3	6.3	6.2
		S				6.9	6.8	6.9	6.8
		T				6.8	6.8	6.8	6.8
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
SE4	Auto/Off/Manual					A	A	A	A
	Current(A)	R				5.8	5.6	5.6	6.0
		S				5.9	5.3	5.4	6.2
		T				5.8	5.5	5.5	5.8
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
SE5	Auto/Off/Manual					A	A	A	A
	Current(A)	R				4.6	4.7	4.6	4.6
		S				3.6	3.3	3.5	3.0
		T				4.8	4.4	4.8	4.7
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
SE6	Auto/Off/Manual					M	M	M	M
	Current(A)	R				7.3	7.1	7.0	7.1
		S				7.9	7.7	7.7	7.3
		T				6.8	7.0	7.1	6.9
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
SE7	Auto/Off/Manual					A	A	A	A
	Current(A)	R				8.1	8.3	8.2	8.2
		S				8.4	8.4	8.4	8.4
		T				8.1	8.2	8.2	8.1
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
SE8	Auto/Off/Manual					A	A	A	A
	Current(A)	R				6.9	7.0	7.0	7.0
		S				7.3	7.5	7.3	7.4
		T				7.4	7.4	7.4	7.4
	Timer					N	N	N	N
	Overload -Alarm					N	N	N	N
Pilot Lamp					N	N	N	N	
Date Check >>			/ /	/ /	/ /	1 / 2 / 67	2 / 2 / 67	3 / 2 / 67	4 / 2 / 67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 2/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	M	M	A	A	A	M
	Current(A)	R	12.3	10.4	11.1	11.9	11.7	10.5
		S	12.4	10.9	11.7	11.8	11.6	11.5
		T	11.9	10.7	11.7	11.9	11.7	11.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
WWP2	Auto/Off/Manual	M	A	M	M	M	M	M
	Current(A)	R	12.5	10.4	11.1	11.9	11.7	10.2
		S	12.6	10.9	11.9	11.8	11.9	9.8
		T	11.8	10.7	11.9	11.9	11.6	11.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP1	Auto/Off/Manual	M	M	M	M	M	A	A
	Current(A)	R	1.2	1.0	1.0	1.3	1.0	2.0
		S	1.3	1.1	1.0	1.8	1.0	2.1
		T	1.2	1.1	1.6	1.3	1.7	1.1
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP2	Auto/Off/Manual	M	M	M	A	A	M	A
	Current(A)	R	1.7	1.5	1.6	1.6	1.7	1.9
		S	1.8	1.5	1.6	1.8	1.7	1.8
		T	1.9	1.6	1.6	1.6	1.6	2.1
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DPI	Auto/Off/Manual	M	M	M	M	M	M	A
	Current(A)	R	6.9	7.0	6.9	6.9	7.1	6.6
		S	7.0	7.0	6.9	6.8	7.1	7.2
		T	7.2	6.9	6.6	6.1	7.3	7.0
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.7	7.6	7.8	7.7	7.8	7.4
		S	7.8	7.7	7.8	7.6	7.8	7.6
		T	7.6	7.7	7.8	7.6	7.8	7.5
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.5	3.4	3.6	3.9	3.6	3.2
		S	3.5	3.5	3.6	3.7	3.9	3.3
		T	3.6	3.5	3.7	3.6	3.8	2.0
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.6	3.5	3.6	3.8	3.9	2.3
		S	3.6	3.5	3.6	3.7	3.8	2.2
		T	3.7	3.6	3.6	3.7	3.8	2.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	3.4	3.2	3.1	3.0	3.1	3.0	3.4
		S	3.5	3.5	3.4	3.1	3.0	3.9	3.8
		T	4.0	3.6	3.9	3.6	3.9	3.8	4.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	A	M	M	M	A	M
	Current(A)	R	7.3	6.5	7.0	7.2	7.0	6.6	6.5
		S	7.8	6.5	7.1	7.8	7.4	7.1	7.3
		T	7.5	6.1	7.1	7.0	7.8	6.9	6.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.4	6.3	6.0	6.1	6.0	6.3	6.4
		S	6.3	6.2	6.9	6.6	6.6	6.6	6.2
		T	6.8	6.3	6.0	6.9	6.8	6.0	6.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	A	M	M	M	A	A
	Current(A)	R	5.8	5.0	6.0	6.5	6.6	6.0	6.1
		S	5.9	5.5	6.0	6.8	6.8	6.3	6.2
		T	6.0	5.3	6.1	6.0	6.2	6.6	5.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.9	4.3	4.7	4.7	4.6	4.6	4.4
		S	5.3	4.7	4.9	4.9	4.9	4.9	4.2
		T	5.1	4.5	4.6	4.6	4.6	4.9	4.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	M	A	A	A	M	M
	Current(A)	R	7.4	6.5	7.1	7.2	7.9	7.0	7.5
		S	7.2		6.3	7.6	7.0	7.1	7.9
		T	7.3	6.8	7.0	7.9	7.1	6.9	7.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		N	A	M	M	M	A	A
	Current(A)	R	9.1	7.5	8.1	8.1	8.1	8.4	8.2
		S	9.4	7.6	7.6	8.0	8.0	8.4	8.3
		T	8.9	7.5	7.1	8.0	8.1	8.0	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		M	A	M	A	A	A	A
	Current(A)	R	7.7	6.5	7.8	7.2	7.0	7.1	7.0
		S	7.5	6.6	7.1	7.2	6.8	7.0	7.3
		T	7.8	6.8	7.9	7.2	7.1	7.0	7.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			5/2/67	6/2/67	7/2/67	8/2/67	9/2/67	10/2/67	11/2/67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 2/67

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	10.7	10.9	10.6	10.3	11.2	10.0	10.4
		S	11.2	11.5	11.5	11.2	11.6	11.0	11.2
		T	11.2	11.3	11.2	10.9	11.2	11.2	11.1
	Overload -Alarm		N	N	N	N	2	2	N
	Latching relay control		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N
WWP2	Auto/Off/Manual		M	M	M	M	A	M	M
	Current(A)	R	10.5	10.9	10.7	10.1	11.0	11.1	10.4
		S	11.7	11.1	11.5	11.1	11.4	11.0	11.3
		T	11.5	11.5	11.6	11.3	11.6	10.9	11.5
	Overload -Alarm		N	N	N	N	2	2	N
	Latching relay control		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N
SLP1	Auto/Off/Manual		A	A	A	A	2	2	
	Current(A)	R	1.0	1.0	1.0	0.9	1.0	1.0	1.0
		S	1.1	1.0	1.0	1.0	1.6	1.9	1.1
		T	1.0	1.0	1.1	1.0	1.8	1.0	1.1
	Timer		N	N	N	N	2	2	N
	Overload -Alarm		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N
SLP2	Auto/Off/Manual		A	A	M	A	2	2	
	Current(A)	R	1.6	1.7	1.7	1.6	1.7	1.7	1.7
		S	1.6	1.6	1.6	1.6	1.6	1.6	1.6
		T	2.1	1.9	2.0	1.6	1.8	1.6	1.9
	Timer		N	N	N	N	2	2	N
	Overload -Alarm		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N
DP1	Auto/Off/Manual		M	M	M	M	2	2	M
	Current(A)	R	6.1	6.1	6.9	6.5	6.4	6.9	6.3
		S	6.8	6.8	7.3	7.5	6.4	6.8	7.5
		T	6.9	6.9	7.2	7.2	6.1	6.8	7.4
	Overload -Alarm		N	N	N	N	2	2	N
	Latching relay control		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N
DP2	Auto/Off/Manual		M	M	M	M	2	2	M
	Current(A)	R	7.5	7.5	7.6	7.6	7.0	7.4	7.6
		S	7.4	7.4	7.6	7.6	7.0	7.0	7.6
		T	7.6	7.6	7.8	7.8	7.0	7.0	7.8
	Overload -Alarm		N	N	N	N	2	2	N
	Latching relay control		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N
SP1	Auto/Off/Manual		M	M	M	M	2	2	M
	Current(A)	R	3.2	3.3	3.3	3.2	3.6	3.0	3.3
		S	2.3	2.0	2.1	2.0	3.0	3.6	3.4
		T	2.1	2.0	2.0	2.0	3.6	3.6	3.3
	Overload -Alarm		N	N	N	N	2	2	N
	Latching relay control		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N
SP2	Auto/Off/Manual		M	M	M	M	2	2	M
	Current(A)	R	2.2	2.3	2.4	2.3	3.3	3.1	2.2
		S	2.3	2.2	2.3	2.3	3.6	3.0	2.6
		T	2.2	2.2	2.2	2.2	3.0	3.0	2.3
	Overload -Alarm		N	N	N	N	2	2	N
	Latching relay control		N	N	N	N	2	2	N
	Pilot Lamp		N	N	N	N	2	2	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	3.5	3.4	3.5	3.3	3.4	3.4	3.4
		S	3.7	3.7	3.9	3.7	3.6	3.6	3.8
		T	3.9	3.9	3.9	3.7	3.5	3.6	3.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	N	N	M
	Current(A)	R	7.0	6.8	6.7	6.5	6.0	6.9	6.8
		S	7.2	7.0	7.0	7.0	6.8	6.9	7.0
		T	7.9	7.0	7.1	6.7	6.3	7.1	7.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.3	6.4	6.4	6.2	6.4	6.4	6.5
		S	6.9	6.8	6.8	6.7	6.6	6.6	6.8
		T	6.8	6.8	6.8	6.7	6.5	6.6	6.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	A	M	N	N	M
	Current(A)	R	6.0	5.1	5.8	5.7	5.7	5.6	5.8
		S	6.4	6.6	5.9	6.7	6.6	6.6	6.2
		T	5.8	6.0	5.6	5.5	6.4	6.9	5.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.7	4.7	4.6	4.5	4.6	4.6	4.7
		S	5.0	4.2	3.6	4.7	4.9	4.6	4.9
		T	4.7	4.9	4.7	4.7	4.9	4.6	4.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		M	A	M	M	N	N	M
	Current(A)	R	7.5	7.1	7.4	6.9	6.0	6.9	7.3
		S	7.6	7.2	7.4	7.4	6.8	6.8	7.6
		T	7.1	6.9	7.0	7.2	6.8	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		A	M	A	A	A	A	A
	Current(A)	R	8.3	8.7	8.2	8.2	8.1	8.6	8.3
		S	8.4	8.8	8.4	8.2	8.1	8.1	8.4
		T	8.2	8.5	8.1	8.0	8.3	8.2	8.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.0	7.1	7.0	6.9	7.0	7.4	7.1
		S	7.5	7.5	7.4	7.3	7.3	7.4	7.5
		T	7.4	7.4	7.4	7.3	7.6	7.6	7.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			12/2/67	13/2/67	14/2/67	15/2/67	16/2/67	17/2/67	18/2/67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 2/67

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		A	A	M	A	M	M	M
	Current(A)	R	10.9	10.4	10.0	10.4	11.0	10.2	11.0
		S	11.4	11.0	10.5	10.9	11.6	11.0	11.7
		T	11.0	10.7	10.6	11.0	11.3	10.6	11.3
	Overload -Alarm		N	N	N	22	N	N	N
	Latching relay control		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N
WWP2	Auto/Off/Manual		M	M	M	3	M	M	M
	Current(A)	R	10.6	10.4	10.0	10.4	10.6	9.7	9.8
		S	11.5	10.0	10.6	11.0	11.2	10.9	11.1
		T	11.5	11.0	11.0	10.9	11.3	11.1	11.5
	Overload -Alarm		N	N	N	22	N	N	N
	Latching relay control		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N
SLP1	Auto/Off/Manual		A	A	A	3	A	A	A
	Current(A)	R	1.0	0.9	0.9	1.0	0.9	0.9	1.0
		S	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		T	1.0	1.0	1.0	1.0	1.0	1.0	1.0
	Timer		N	N	N	22	N	N	N
	Overload -Alarm		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N
SLP2	Auto/Off/Manual		A	A	A	3	A	A	A
	Current(A)	R	1.7	1.7	1.4	1.6	1.6	1.5	1.4
		S	1.6	1.6	1.3	1.6	1.6	1.6	1.6
		T	1.9	1.8	1.4	1.6	1.9	1.8	1.7
	Timer		N	N	N	22	N	N	N
	Overload -Alarm		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N
DPI	Auto/Off/Manual		M	M	M	3	M	M	M
	Current(A)	R	6.7	6.6	6.9	6.4	6.8	6.9	6.8
		S	7.4	7.1	7.3	6.9	7.4	7.4	7.4
		T	7.2	7.1	7.2	7.0	7.1	7.2	7.2
	Overload -Alarm		N	N	N	22	N	N	N
	Latching relay control		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N
DP2	Auto/Off/Manual		M	M	M	3	M	M	M
	Current(A)	R	7.5	7.2	7.6	7.2	7.5	7.6	7.5
		S	7.5	7.5	7.6	7.3	7.6	7.6	7.6
		T	7.7	7.6	7.9	7.0	7.7	7.9	7.9
	Overload -Alarm		N	N	N	22	N	N	N
	Latching relay control		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N
SP1	Auto/Off/Manual		M	M	M	3	M	M	M
	Current(A)	R	3.3	3.3	3.2	3.0	3.4	3.2	3.3
		S	3.4	2.1	2.1	3.1	3.4	3.4	3.4
		T	3.2	2.1	1.9	3.4	3.3	3.2	1.9
	Overload -Alarm		N	N	N	22	N	N	N
	Latching relay control		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N
SP2	Auto/Off/Manual		M	M	M	3	M	M	M
	Current(A)	R	2.5	2.1	2.2	2.8	2.3	2.4	2.0
		S	2.2	2.3	2.2	2.2	2.2	2.2	2.4
		T	2.2	2.2	2.2	2.1	2.1	2.2	2.1
	Overload -Alarm		N	N	N	22	N	N	N
	Latching relay control		N	N	N	22	N	N	N
	Pilot Lamp		N	N	N	22	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	0.4	0.4	0.3	0.1	0.4	0.5	0.4
		S	0.9	0.9	0.6	0.6	0.8	0.9	0.8
		T	0.9	0.9	0.7	0.0	0.9	0.9	0.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.6	6.6	6.3	6.8	6.8	6.7	6.9
		S	7.3	7.4	6.8	6.1	7.3	7.3	7.4
		T	7.0	7.0	6.6	6.6	7.0	6.7	7.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.3	6.3	6.0	6.1	6.4	6.3	6.3
		S	6.8	6.8	6.4	6.0	6.9	6.9	7.0
		T	6.8	6.7	6.4	6.1	6.8	6.8	6.7
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	5.8	5.8	5.5	5.1	6.7	6.1	6.0
		S	6.3	6.3	5.9	6.6	6.1	6.2	6.3
		T	5.8	5.9	5.4	6.6	5.7	6.7	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.6	4.6	4.0	4.6	4.7	4.8	4.5
		S	3.9	4.9	4.6	4.6	4.5	4.9	5.0
		T	4.7	4.7	4.4	4.0	4.8	4.7	4.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.4	7.1	6.7	7.2	7.3	7.4	7.4
		S	7.5	7.4	7.0	7.1	7.8	7.5	7.5
		T	6.9	7.2	7.0	6.9	7.4	7.2	7.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.3	8.2	7.7	8.1	8.3	7.9	8.3
		S	8.4	8.3	7.9	7.9	8.5	8.1	8.5
		T	8.2	8.2	7.7	7.8	8.1	7.8	8.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.1	6.9	6.6	7.1	7.1	6.7	7.0
		S	7.6	7.3	7.1	7.0	7.5	7.2	7.6
		T	7.4	7.4	7.1	7.8	7.5	7.1	7.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			19/2/67	20/2/67	21/2/67	22/2/67	23/2/67	24/2/67	25/2/67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH

20-81-8-17

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	A	A	M	M
	Current(A)	R	11.0	11.6	11.6	10.9	11.8	10.5	11.1
		S	11.1	11.2	11.1	11.0	11.3	10.9	11.5
		T	10.9	11.1	11.1	11.1	11.1	10.7	11.3
	Overload -Alarm		22	22	22	22	22	N	N
	Latching relay control		22	22	22	22	22	N	N
WWP2	Auto/Off/Manual		22	22	22	22	22	M	M
	Current(A)	R	11.1	11.0	11.6	11.1	11.0	11.3	11.9
		S	11.1	11.1	11.6	11.1	11.4	11.8	12.0
		T	11.1	11.1	11.6	11.3	11.4	11.4	11.6
	Overload -Alarm		22	22	22	22	22	N	N
	Latching relay control		22	22	22	22	22	N	N
SLP1	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
SLP2	Auto/Off/Manual		22	22	22	22	22	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.7	1.6
		S	1.1	1.1	1.1	1.1	1.1	1.5	1.5
		T	1.1	1.1	1.1	1.1	1.1	1.8	1.8
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
DP1	Auto/Off/Manual		22	22	22	22	22	M	M
	Current(A)	R	4.4	4.4	4.4	4.4	4.4	4.2	7.0
		S	4.4	4.4	4.4	4.4	4.4	4.2	7.1
		T	4.4	4.4	4.4	4.4	4.4	4.3	7.3
	Overload -Alarm		22	22	22	22	22	N	N
	Latching relay control		22	22	22	22	22	N	N
DP2	Auto/Off/Manual		22	22	22	22	22	M	M
	Current(A)	R	4.4	4.4	4.4	4.4	4.4	4.3	7.8
		S	4.4	4.4	4.4	4.4	4.4	4.3	7.8
		T	4.4	4.4	4.4	4.4	4.4	4.3	7.8
	Overload -Alarm		22	22	22	22	22	N	N
	Latching relay control		22	22	22	22	22	N	N
SP1	Auto/Off/Manual		22	22	22	22	22	M	A
	Current(A)	R	3.3	3.3	3.3	3.3	3.3	3.5	3.5
		S	3.3	3.3	3.3	3.3	3.3	3.6	3.5
		T	3.3	3.3	3.3	3.3	3.3	3.6	3.6
	Overload -Alarm		22	22	22	22	22	N	N
	Latching relay control		22	22	22	22	22	N	N
SP2	Auto/Off/Manual		22	22	22	22	22	N	N
	Current(A)	R	4.4	4.4	4.4	4.4	4.4	4.2	3.3
		S	4.4	4.4	4.4	4.4	4.4	4.3	3.2
		T	4.4	4.4	4.4	4.4	4.4	4.3	3.3
	Overload -Alarm		22	22	22	22	22	N	N
	Latching relay control		22	22	22	22	22	N	N

SP2 - 20/81/8-17 (1/2/2/2/2/2/2/2/2/2)

3/4/67

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual	A	A	M	A	A	A	A
	Current(A)	R	9.9	9.9	9.6	9.6	3.3	3.4
		S	1.0	1.1	1.1	1.0	3.6	3.3
		T	1.1	1.4	1.0	1.1	3.8	3.9
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	N	N
	Pilot Lamp	22	22	22	22	22	N	N
SE2	Auto/Off/Manual	M	22	22	A	A	M	M
	Current(A)	R	4.4	4.3	4.1	4.4	6.2	6.8
		S	4.2	4.6	4.6	4.9	6.9	6.9
		T	4.8	4.6	4.6	4.0	6.8	7.1
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	N	N
	Pilot Lamp	22	22	22	22	22	N	N
SE3	Auto/Off/Manual	A	A	M	M	22	A	A
	Current(A)	R	6.6	6.4	6.1	6.6	6.4	6.4
		S	6.1	6.1	6.1	6.1	6.7	6.8
		T	6.6	6.6	6.6	6.2	6.6	6.9
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	N	N
	Pilot Lamp	22	22	22	22	22	N	N
SE4	Auto/Off/Manual	A	A	M	A	A	A	A
	Current(A)	R	6.8	6.1	6.3	6.0	5.9	6.0
		S	6.1	6.4	6.4	6.1	6.0	6.1
		T	6.0	6.4	6.9	6.1	5.8	5.9
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	N	N
	Pilot Lamp	22	22	22	22	22	N	N
SE5	Auto/Off/Manual	M	22	A	A	A	M	M
	Current(A)	R	1.8	1.9	1.8	1.8	4.7	4.8
		S	1.2	1.6	1.9	1.0	4.5	4.9
		T	1.9	1.9	1.6	1.9	4.1	4.6
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	N	N
	Pilot Lamp	22	22	22	22	22	N	N
SE6	Auto/Off/Manual	A	A	A	M	M	A	A
	Current(A)	R	4.0	4.1	4.9	4.1	6.9	7.2
		S	4.1	4.1	4.1	4.4	2.4	2.4
		T	4.2	4.6	4.6	4.8	2.2	2.0
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	N	N
	Pilot Lamp	22	22	22	22	22	N	N
SE7	Auto/Off/Manual	22	22	22	22	22	A	M
	Current(A)	R	8.7	8.4	8.6	8.8	8.2	8.5
		S	8.1	8.2	8.7	8.6	8.2	8.6
		T	8.6	8.4	8.4	8.6	8.1	8.5
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	N	N
	Pilot Lamp	22	22	22	22	22	N	N
SE8	Auto/Off/Manual	22	22	22	22	22	OFF	OFF
	Current(A)	R	1.1	1.1	1.1	1.1	1	1
		S	1.1	1.1	1.1	1.1	1	1
		T	1.1	1.1	1.1	1.1	1	1
	Timer	22	22	22	22	22	N	N
	Overload -Alarm	22	22	22	22	22	UN	UN
	Pilot Lamp	22	22	22	22	22	N	N
Date Check >>		20/3/17	21/3/17	22/3/17	23/3/17	24/3/17	25/3/17	26/3/17
Record By >>								
Recheck By >>								

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

.....

DAILY REPORT

MONTH.

18-71-3-64

TIME.

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		A	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.0	11.1	11.0	11.0	11.8
		S	11.0	11.1	11.1	11.1	11.0	11.5	11.4
		T	11.0	11.1	11.1	11.1	11.0	11.2	11.6
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp							N	N	
WWP2	Auto/Off/Manual		A	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.0	11.0	11.3	11.4
		S	11.0	11.1	11.1	11.1	11.0	11.5	11.6
		T	11.0	11.1	11.1	11.1	11.0	11.9	11.1
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp							N	N	
SLP1	Auto/Off/Manual		A	M	A	M	M	OFF	OFF
	Current(A)	R	11.0	11.0	11.1	11.1	11.0	11.0	11.0
		S	11.0	11.1	11.1	11.1	11.0	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.0
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
SLP2	Auto/Off/Manual		A	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.1	11.0	11.0	11.0
		S	11.0	11.1	11.1	11.1	11.0	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.0
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
DP1	Auto/Off/Manual		A	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.1	11.0	11.0	11.0
		S	11.0	11.1	11.1	11.1	11.0	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.0
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp							N	N	
DP2	Auto/Off/Manual		A	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.1	11.0	11.0	11.0
		S	11.0	11.1	11.1	11.1	11.0	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.0
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp							N	N	
SP1	Auto/Off/Manual		A	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.1	11.0	11.0	11.0
		S	11.0	11.1	11.1	11.1	11.0	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.0
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp							N	N	
SP2	Auto/Off/Manual		A	M	A	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.1	11.0	11.0	11.0
		S	11.0	11.1	11.1	11.1	11.0	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.0
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp							N	N	

SP_2 အိုင်အိုနိုက်ဇင်းကွန်စင်ထရိန်းရှင်း (SP₁ ရှုတ်ခံယူမှု)

20-3-64 ~~Handwritten signature~~ Rum sel-8 u.a. GLP 1-2 Rus

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	M	M	A	A
	Current(A)	R	9.9	9.9	9.9	9.8	9.9	13.6	3.5
		S	1.1	1.4	1.1	1.2	1.4	3.9	3.8
		T	1.1	1.4	1.4	1.8	1.4	4.0	4.1
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
Pilot Lamp		22	22	22	22	22	N	N	
SE2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.6	6.6	6.6	6.8	6.8	6.8	6.8
		S	6.6	6.6	6.6	6.9	6.9	6.9	6.9
		T	6.6	6.6	6.6	6.8	6.8	7.0	6.8
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
Pilot Lamp		22	22	22	22	22	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	M	M
	Current(A)	R	6.6	6.6	6.6	6.8	6.6	6.5	6.6
		S	6.6	6.6	6.6	6.8	6.6	7.0	6.5
		T	6.6	6.6	6.6	6.8	6.6	7.1	7.0
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
Pilot Lamp		22	22	22	22	22	N	N	
SE4	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.2	6.1	6.1	6.4	5.8	5.8
		S	6.1	6.3	6.0	6.2	6.6	6.2	6.2
		T	6.3	6.3	6.2	6.1	6.4	5.7	5.7
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
Pilot Lamp		22	22	22	22	22	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.9	1.9	1.8	1.8	1.8	4.8	4.8
		S	0.9	0.9	0.9	0.9	0.9	4.1	4.9
		T	1.9	1.6	0.1	1.9	1.9	4.4	4.9
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
Pilot Lamp		22	22	22	22	22	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	M	M
	Current(A)	R	4.0	4.4	4.0	4.1	4.0	7.1	7.1
		S	4.0	4.4	4.0	4.1	4.0	7.8	7.8
		T	4.0	4.4	4.0	4.1	4.0	7.0	7.1
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
Pilot Lamp		22	22	22	22	22	N	N	
SE7	Auto/Off/Manual		A	A	A	M	M	A	A
	Current(A)	R	8.4	8.4	8.4	8.1	8.4	8.4	8.3
		S	8.6	8.6	8.6	8.6	8.6	8.3	8.4
		T	8.6	8.4	8.1	8.6	8.6	8.3	8.3
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	N	N
Pilot Lamp		22	22	22	22	22	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	1	1	1	1	1	1	1
		S	1	1	1	1	1	1	1
		T	1	1	1	1	1	1	1
	Timer		22	22	22	22	22	N	N
	Overload -Alarm		22	22	22	22	22	UN	UN
Pilot Lamp		22	22	22	22	22	N	N	
Date Check >>			14/3/62	19/3/62	20/3/62	21/3/62	22/3/62	23/3/62	24/3/62
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

SP2 = วิศวกรไฟฟ้า (เครื่องวัด)

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH. 11-11-8-64

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	M	A	A	M	M	M
	Current(A)	R	11.0	11.2	11.6	11.4	11.2	11.0
		S	11.1	11.0	11.4	11.5	11.3	11.9
		T	11.0	10.9	11.6	11.6	11.2	11.9
	Overload -Alarm	22	22	22	22	N	N	22
	Latching relay control	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22
WWP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.2	11.3	11.2	11.0
		S	10.0	11.0	11.6	11.3	12.0	11.0
		T	10.0	10.9	11.2	11.4	11.4	11.0
	Overload -Alarm	22	22	22	22	N	N	22
	Latching relay control	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22
SLP1	Auto/Off/Manual	A	A	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	1.0	1.0	1.0	-	-	-
		S	1.0	1.0	1.0	-	-	-
		T	1.0	1.0	1.0	-	-	-
	Timer	22	22	22	22	N	N	22
	Overload -Alarm	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22
SLP2	Auto/Off/Manual	M	M	A	A	A	M	A
	Current(A)	R	1.2	1.2	1.2	1.8	1.6	1.7
		S	1.2	1.2	1.2	1.7	1.7	1.7
		T	1.2	1.2	1.2	1.7	1.6	1.7
	Timer	22	22	22	22	N	N	22
	Overload -Alarm	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22
DP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	4.6	4.6	4.6	7.1	6.2	4.6
		S	4.6	4.6	4.6	7.2	6.2	4.6
		T	4.6	4.6	4.6	7.2	7.1	4.6
	Overload -Alarm	22	22	22	22	N	N	22
	Latching relay control	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22
DP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	4.6	4.6	4.6	7.7	7.5	4.6
		S	4.6	4.6	4.6	7.5	7.9	4.6
		T	4.6	4.6	4.6	7.7	7.7	4.6
	Overload -Alarm	22	22	22	22	N	N	22
	Latching relay control	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22
SP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.2	3.0	3.3	3.3	3.1	3.2
		S	3.3	3.0	3.2	3.4	3.3	3.3
		T	3.2	3.0	3.2	3.3	3.2	3.3
	Overload -Alarm	22	22	22	22	N	N	22
	Latching relay control	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22
SP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	4.0	4.0	4.0	3.4	3.5	4.0
		S	4.0	4.0	4.0	3.5	3.3	4.0
		T	4.0	4.0	4.0	3.4	3.5	4.0
	Overload -Alarm	22	22	22	22	N	N	22
	Latching relay control	22	22	22	22	N	N	22
	Pilot Lamp	22	22	22	22	N	N	22

အမှတ် ၇ Pump = SP1, SP2 Pump မှတ်တမ်း (A) နှင့်
 အမှတ် ၈ နှင့် ၉ ၈.၁-၈.၆ မှတ်

၁၈-၈-၆၄ Pump SLP1 စက်: ၁၈ မှတ် OFF ဖြစ်၊ စက်
 အမှတ် ၈

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.3	8.2	8.6	8.6	3.6	2.9	8.0
		S	8.9	8.0	8.9	8.9	3.9	3.4	1.0
		T	8.9	8.6	8.9	8.9	4.0	3.7	1.0
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
SE2	Auto/Off/Manual		A	A	A	A	M	M	22
	Current(A)	R	6.8	6.8	6.0	4.9	6.7	6.5	6.6
		S	6.1	6.9	6.9	6.9	7.3	6.7	4.8
		T	6.1	6.9	6.9	6.9	6.9	6.1	4.1
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.9	6.9	6.1	6.9	6.9	6.8	6.1
		S	6.9	6.9	6.8	6.6	6.9	6.2	6.4
		T	6.9	6.9	6.8	6.6	6.8	6.1	6.4
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
SE4	Auto/Off/Manual		A	A	A	3	A	A	A
	Current(A)	R	6.0	6.1	6.1	6.9	5.5	4.9	6.9
		S	6.0	6.0	6.1	6.9	5.9	5.0	6.1
		T	6.0	6.0	6.1	6.9	5.6	5.2	6.1
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.6	4.6	4.7	4.8	4.3	4.3	4.6
		S	4.6	4.6	4.7	4.8	4.8	4.2	4.1
		T	4.6	4.6	4.7	4.9	4.1	4.4	4.6
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
SE6	Auto/Off/Manual		3	3	2	A	M	M	3
	Current(A)	R	6.0	6.1	6.6	6.6	7.2	6.9	4.0
		S	6.0	6.1	6.6	6.6	7.6	7.2	4.1
		T	6.0	6.1	6.6	6.6	7.3	6.2	6.8
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
SE7	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.0	8.0	8.1	8.9	8.1	8.0	8.1
		S	8.9	8.0	8.9	8.1	8.2	8.1	8.4
		T	8.6	8.1	8.8	8.4	8.0	8.0	8.3
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
SE8	Auto/Off/Manual		3	3	A	A	OFF	OFF	OFF
	Current(A)	R	4.6	4.6	4.6	4.6	0	0	0
		S	4.6	4.6	4.6	4.6	0	0	0
		T	4.6	4.6	4.6	4.6	0	0	0
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp		22	22	22	22	N	N	22	
Date Check >>			11/3/14	12/3/14	13/3/14	14/3/14	15/3/14	16/3/14	17/3/14
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 1-10-8-67

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	A	A	M	M	M
	Current(A)	R	11.8	10.1	11.1	11.0	11.4	11.0	11.2
		S	11.0	10.9	11.9	11.0	11.8	11.6	11.0
		T	11.2	11.6	11.0	11.9	11.6	11.8	10.9
	Overload -Alarm		22	22	22	22	N	N	22
	Latching relay control		22	22	22	22	N	N	22
WWP2	Auto/Off/Manual		M	M	A	A	M	M	M
	Current(A)	R	11.4	11.3	11.1	11.2	11.3	11.2	11.4
		S	11.4	11.0	11.0	11.9	11.9	11.8	11.9
		T	11.6	11.0	11.6	11.6	11.6	11.7	11.0
	Overload -Alarm		22	22	22	22	N	N	22
	Latching relay control		22	22	22	22	N	N	22
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.00	1.03	1.03	1.03	1.0	1.1	1.0
		S	1.00	1.03	1.03	1.03	1.1	1.0	1.0
		T	1.00	1.03	1.03	1.03	1.1	1.1	1.0
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
SLP2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.6	1.6	1.6	1.6	1.4	1.5	1.6
		S	1.6	1.6	1.6	1.6	1.5	1.5	1.6
		T	1.6	1.6	1.6	1.6	1.7	1.6	1.6
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
DP1	Auto/Off/Manual		M	M	A	A	M	M	M
	Current(A)	R	7.6	7.6	7.6	7.6	7.1	7.0	7.6
		S	7.6	7.6	7.6	7.6	7.3	7.1	7.6
		T	7.6	7.6	7.6	7.6	7.4	7.3	7.6
	Overload -Alarm		22	22	22	22	N	N	22
	Latching relay control		22	22	22	22	N	N	22
DP2	Auto/Off/Manual		M	M	A	A	M	M	M
	Current(A)	R	7.6	7.6	7.6	7.6	7.8	7.8	7.6
		S	7.6	7.6	7.6	7.6	7.7	7.6	7.6
		T	7.6	7.6	7.6	7.6	7.8	7.7	7.6
	Overload -Alarm		22	22	22	22	N	N	22
	Latching relay control		22	22	22	22	N	N	22
SP1	Auto/Off/Manual		M	M	A	A	M	M	M
	Current(A)	R	3.1	3.1	3.1	3.1	3.4	3.5	3.5
		S	3.1	3.1	3.1	3.1	3.4	3.4	3.1
		T	3.1	3.1	3.1	3.1	3.4	3.5	3.1
	Overload -Alarm		22	22	22	22	N	N	22
	Latching relay control		22	22	22	22	N	N	22
SP2	Auto/Off/Manual		M	M	A	A	M	M	M
	Current(A)	R	3.1	3.1	3.1	3.1	3.5	3.4	3.5
		S	3.1	3.1	3.1	3.1	3.4	3.5	3.1
		T	3.1	3.1	3.1	3.1	3.4	3.4	3.1
	Overload -Alarm		22	22	22	22	N	N	22
	Latching relay control		22	22	22	22	N	N	22

SP1, SP2 Run manual (CA) (1st stage)
 2nd stage (2nd stage) 3.0 - 3.6

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	M	A	A	A	A	A
	Current(A)	R	3.3	3.1	3.3	3.1	3.5	3.6	3.1
		S	3.9	3.6	3.6	3.4	3.9	3.8	3.9
		T	3.9	3.6	3.7	3.6	4.0	4.0	3.9
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
SE2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.6	4.6	4.6	4.6	6.5	6.6	4.3
		S	4.6	4.6	4.6	4.6	6.9	6.8	4.2
		T	4.6	4.6	4.6	4.6	7.0	7.0	4.2
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.4	6.5	6.1
		S	6.1	6.1	6.1	6.1	6.9	6.9	6.1
		T	6.1	6.1	6.1	6.1	6.8	6.7	6.1
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
SE4	Auto/Off/Manual		A	A	A	A	M	M	A
	Current(A)	R	6.1	6.1	6.1	6.1	4.7	4.8	6.1
		S	6.1	6.1	6.1	6.1	4.5	4.6	6.1
		T	6.1	6.1	6.1	6.1	4.8	4.7	6.1
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.8	4.6	4.8	4.8	4.6	6.1	4.6
		S	4.8	4.6	4.8	4.8	5.1	5.5	4.7
		T	4.8	4.6	4.8	4.8	5.6	5.8	4.7
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.1	4.1	4.1	4.1	7.1	7.0	4.1
		S	4.1	4.1	4.1	4.1	7.3	7.5	4.1
		T	4.1	4.1	4.1	4.1	7.0	7.2	4.1
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
SE7	Auto/Off/Manual		A	A	A	A	M	M	A
	Current(A)	R	8.3	8.3	8.3	8.3	8.3	8.4	8.3
		S	8.3	8.3	8.3	8.3	7.9	8.0	8.3
		T	8.3	8.3	8.3	8.3	8.1	8.0	8.3
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
SE8	Auto/Off/Manual		A	A	A	A	M	M	A
	Current(A)	R	7.3	7.3	7.3	7.3	7.3	7.3	7.3
		S	7.3	7.3	7.3	7.3	7.4	7.5	7.3
		T	7.3	7.3	7.3	7.3	7.3	7.2	7.3
	Timer		22	22	22	22	N	N	22
	Overload -Alarm		22	22	22	22	N	N	22
Pilot Lamp			22	22	22	22	N	N	22
Date Check >>			4/3/17	4/3/17	4/3/17	4/3/17	8/3/17	9/3/17	10/3/17
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 1-8-67

WASTE WATERTREATMENT PLANT

TIME

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual					M	M	M
	Current(A)					11.4	11.0	11.0
						11.1	10.9	11.5
						11.3	10.2	11.2
	Overload -Alarm					222	222	N
	Latching relay control					222	222	N
	Pilot Lamp					222	222	N
WWP2	Auto/Off/Manual					11.3	11.3	M
	Current(A)					11.4	11.1	10.1
						10.9	10.0	11.8
						11.1	10.6	11.6
	Overload -Alarm					222	222	N
	Latching relay control					222	222	N
	Pilot Lamp					222	222	N
SLP1	Auto/Off/Manual					11.3	11.3	A
	Current(A)					11.4	11.0	1.0
						11.1	11.2	1.0
						11.3	11.2	1.1
	Timer					222	222	N
	Overload -Alarm					222	222	N
	Pilot Lamp					222	222	N
SLP2	Auto/Off/Manual					11.3	11.3	M
	Current(A)					11.4	11.0	1.6
						11.1	11.2	1.4
						11.3	11.2	1.9
	Timer					222	222	N
	Overload -Alarm					222	222	N
	Pilot Lamp					222	222	N
DP1	Auto/Off/Manual					11.3	11.3	M
	Current(A)					11.4	11.0	6.3
						11.1	11.2	6.6
						11.3	11.2	6.7
	Overload -Alarm					222	222	N
	Latching relay control					222	222	N
	Pilot Lamp					222	222	N
DP2	Auto/Off/Manual					11.3	11.3	M
	Current(A)					11.4	11.0	7.3
						11.1	11.2	7.4
						11.3	11.2	7.4
	Overload -Alarm					222	222	N
	Latching relay control					222	222	N
	Pilot Lamp					222	222	N
SP1	Auto/Off/Manual					8.3	8.3	M
	Current(A)					8.4	8.1	3.3
						8.0	8.6	3.4
						8.0	8.3	3.3
	Overload -Alarm					222	222	N
	Latching relay control					222	222	N
	Pilot Lamp					222	222	N
SP2	Auto/Off/Manual					8.3	8.3	M
	Current(A)					8.4	8.1	3.3
						8.0	8.6	3.4
						8.0	8.3	3.4
	Overload -Alarm					222	222	N
	Latching relay control					222	222	N
	Pilot Lamp					222	222	N

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual					A	A	A
	Current(A)	R				3.3	3.1	3.4
		S				3.4	3.3	3.8
		T				3.9	3.0	4.0
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
SE2	Auto/Off/Manual					A	A	M
	Current(A)	R				4.0	4.3	7.0
		S				4.0	4.0	7.1
		T				4.0	4.0	7.0
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
SE3	Auto/Off/Manual					A	A	A
	Current(A)	R				6.6	6.8	6.2
		S				6.6	6.1	6.9
		T				6.6	6.0	6.8
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
SE4	Auto/Off/Manual					A	A	A
	Current(A)	R				8.1	8.6	5.4
		S				8.4	8.0	7.1
		T				8.4	8.4	5.6
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
SE5	Auto/Off/Manual					A	A	A
	Current(A)	R				1.4	1.8	4.4
		S				1.6	1.5	4.1
		T				1.4	1.3	4.6
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
SE6	Auto/Off/Manual					A	A	M
	Current(A)	R				4.4	4.1	7.2
		S				4.0	4.4	7.3
		T				4.2	4.6	7.0
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
SE7	Auto/Off/Manual					A	A	A
	Current(A)	R				8.1	8.1	8.2
		S				8.4	8.0	8.3
		T				8.6	8.0	8.1
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
SE8	Auto/Off/Manual					A	A	A
	Current(A)	R				4.4	4.7	7.3
		S				4.4	4.1	7.8
		T				4.0	4.6	7.7
	Timer					2	2	N
	Overload -Alarm					2	2	N
	Pilot Lamp					2	2	N
Date Check >>		/ /	/ /	/ /	/ /	1/3/62	2/3/62	3/3/62
Record By >>								
Recheck By >>								

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....4/167

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	m	m					
	Current(A)	R	11.8	11.1				
		S	11.8	11.7				
		T	11.5	11.8				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
WWP2	Auto/Off/Manual	m	m					
	Current(A)	R	11.6	11.6				
		S	11.9	11.6				
		T	11.9	11.9				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SLP1	Auto/Off/Manual	A	A					
	Current(A)	R	1.7	1.7				
		S	1.8	1.8				
		T	1.8	1.8				
	Timer	N	N					
	Overload -Alarm	N	N					
SLP2	Auto/Off/Manual	A	A					
	Current(A)	R	1.8	1.4				
		S	1.6	1.6				
		T	1.8	1.8				
	Timer	N	N					
	Overload -Alarm	N	N					
DP1	Auto/Off/Manual	m	m					
	Current(A)	R	6.5	6.3				
		S	7.0	7.1				
		T	7.0	7.4				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
DP2	Auto/Off/Manual	m	m					
	Current(A)	R	7.8	7.8				
		S	7.7	7.9				
		T	7.8	7.7				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SP1	Auto/Off/Manual	m	m					
	Current(A)	R	8.8	8.6				
		S	8.8	8.8				
		T	8.8	8.8				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SP2	Auto/Off/Manual	m	m					
	Current(A)	R	8.8	8.4				
		S	8.8	8.9				
		T	8.8	8.6				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SP2	Auto/Off/Manual	m	m					
	Current(A)	R	8.8	8.4				
		S	8.8	8.9				
		T	8.8	8.6				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SP2	Auto/Off/Manual	m	m					
	Current(A)	R	8.8	8.4				
		S	8.8	8.9				
		T	8.8	8.6				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SP2	Auto/Off/Manual	m	m					
	Current(A)	R	8.8	8.4				
		S	8.8	8.9				
		T	8.8	8.6				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SP2	Auto/Off/Manual	m	m					
	Current(A)	R	8.8	8.4				
		S	8.8	8.9				
		T	8.8	8.6				
	Overload -Alarm	N	N					
	Latching relay control	N	N					
SP2	Auto/Off/Manual	m	m					
	Current(A)	R	8.8	8.4				
		S	8.8	8.9				
		T	8.8	8.6				
	Overload -Alarm	N	N					
	Latching relay control	N	N					

2/3/67

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A					
	Current(A)	R	3.9	3.9					
		S	4.8	4.9					
		T	4.9	4.8					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE2	Auto/Off/Manual		M	M					
	Current(A)	R	2.6	2.6					
		S	2.6	2.6					
		T	2.8	2.8					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE3	Auto/Off/Manual		A	A					
	Current(A)	R	6.4	6.4					
		S	6.6	6.8					
		T	6.7	6.8					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE4	Auto/Off/Manual		A	A					
	Current(A)	R	5.9	5.9					
		S	6.1	6.1					
		T	6.1	6.8					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE5	Auto/Off/Manual		M	M					
	Current(A)	R	4.7	4.7					
		S	5.1	4.9					
		T	4.9	4.8					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE6	Auto/Off/Manual		A	A					
	Current(A)	R	2.0	2.0					
		S	2.2	2.3					
		T	2.1	2.1					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE7	Auto/Off/Manual		M	M					
	Current(A)	R	8.4	8.4					
		S	8.4	8.4					
		T	8.9	8.9					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE8	Auto/Off/Manual		OFF	OFF					
	Current(A)	R	-	-					
		S	-	-					
		T	-	-					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
Date Check >>			19/4/67	20/4/67	/ /	/ /	/ /	/ /	/ /
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....4/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.2	11.1	11.1	10.3	11.2	11.2	10.7
		S	11.7	11.6	11.4	10.4	11.8	11.7	11.4
		T	11.1	11.1	11.6	10.5	11.5	11.5	10.9
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
WWP2	Auto/Off/Manual		M	M	M	M	M	A	A
	Current(A)	R	11.9	12.0	11.5	11.3	11.4	11.3	10.9
		S	11.5	11.7	11.8	11.8	11.9	11.8	11.4
		T	11.8	11.9	11.6	11.7	11.5	11.6	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.9	1.9	1.8	1.9	1.8	1.9	1.9
		S	1.9	1.9	1.9	2.0	1.8	1.9	2.0
		T	1.9	1.9	1.9	2.0	1.8	1.9	1.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SLP2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.3	1.3	1.4	1.4	1.3	1.5	1.2
		S	1.6	1.3	1.3	1.2	1.4	1.4	1.3
		T	1.3	1.3	1.6	1.6	1.3	1.3	1.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.5	7.2	7.2	6.9	6.8	6.9	6.6
		S	7.3	7.3	7.5	7.2	7.0	7.1	7.0
		T	7.4	7.6	7.4	7.3	7.1	7.4	7.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.4	7.6	7.6	7.8	7.8	7.7	7.6
		S	7.2	7.3	7.5	7.9	7.7	7.9	7.8
		T	7.3	7.4	7.5	7.8	7.8	7.7	7.8
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.3	3.3	3.3	3.2	3.3	3.1	3.2
		S	3.4	3.3	3.2	3.3	3.3	3.3	3.3
		T	3.3	3.3	3.1	3.3	3.2	3.2	3.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.2	3.2	3.3	3.4	3.3	3.4	3.1
		S	3.2	3.2	3.4	3.2	3.3	3.4	3.2
		T	3.4	3.3	3.4	3.2	3.3	3.2	3.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	M	A	M
	Current(A)	R	3.0	3.2	3.9	3.8	3.9	4.1	3.8
		S	3.4	3.4	4.2	4.2	4.3	4.4	4.1
		T	3.2	3.4	4.3	4.3	4.5	4.5	4.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		A	M	M	M	A	M	A
	Current(A)	R	6.8	6.3	7.1	7.0	7.1	6.8	6.5
		S	7.2	6.9	7.6	7.2	7.3	6.9	7.0
		T	6.9	6.9	7.2	7.2	7.3	7.0	7.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	M	A
	Current(A)	R	6.4	6.3	6.4	6.5	6.4	6.3	6.0
		S	6.2	6.1	6.8	6.8	6.8	7.0	6.6
		T	6.3	6.3	6.7	6.8	6.7	6.9	6.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		A	A	A	A	A	A	M
	Current(A)	R	5.8	6.0	5.9	6.0	5.8	6.0	6.1
		S	5.9	6.2	6.1	6.4	6.2	6.3	6.4
		T	6.0	6.0	6.1	6.0	5.6	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	M	M	M	M	A	A
	Current(A)	R	4.7	4.9	4.2	4.9	4.9	4.7	4.9
		S	4.3	4.6	5.1	5.1	5.0	4.5	5.0
		T	4.4	4.3	4.9	5.1	5.0	4.9	5.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		M	A	A	A	A	M	A
	Current(A)	R	6.5	7.0	7.1	7.3	7.1	7.0	7.4
		S	7.2	7.2	6.9	7.0	7.2	7.6	7.2
		T	6.3	7.2	7.0	7.1	7.3	7.5	7.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.5	8.4	8.4	8.6	8.4	8.5	8.3
		S	8.5	8.4	8.6	8.6	8.5	8.6	8.3
		T	8.3	8.3	8.3	8.5	8.4	8.5	8.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		UN	UN	UN	UN	UN	UN	UN
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			22/4/17	23/4/17	24/4/17	25/4/17	26/4/17	27/4/17	28/4/17
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 4. 67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	M	M	A	M	M	M
	Current(A)	R	11.4	11.2	10.8	11.1	10.9	11.8
		S	11.2	11.7	11.5	11.6	11.6	11.6
		T	11.2	11.3	11.1	11.4	11.3	11.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
WWP2	Auto/Off/Manual	M	M	M	M	A	M	M
	Current(A)	R	11.3	11.6	11.0	11.3	11.3	11.3
		S	12.1	11.9	11.7	11.9	11.8	11.9
		T	11.7	11.4	11.3	11.5	11.5	11.8
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP1	Auto/Off/Manual	A	A	M	A	A	A	A
	Current(A)	R	1.7	1.8	2.2	1.9	1.8	1.9
		S	1.6	2.0	2.0	1.9	1.9	1.9
		T	1.6	1.9	2.1	1.9	1.9	1.9
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP2	Auto/Off/Manual	M	M	A	A	A	A	A
	Current(A)	R	1.7	1.6	1.5	1.5	1.4	1.4
		S	1.4	1.4	1.6	1.5	1.4	1.4
		T	1.3	1.7	1.5	1.5	1.4	1.4
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.3	7.5	7.0	7.4	7.2	7.3
		S	8.4	7.2	7.5	7.2	7.4	7.2
		T	7.3	7.3	7.4	7.2	7.5	7.1
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	8.4	7.9	8.3	7.2	7.3	7.9
		S	8.5	7.9	8.0	7.8	8.0	7.9
		T	8.2	7.8	7.9	7.8	8.0	7.9
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP1	Auto/Off/Manual	M	M	M	A	M	M	M
	Current(A)	R	3.3	3.3	3.1	3.1	3.2	3.3
		S	3.3	3.4	3.3	3.3	3.2	3.3
		T	3.2	3.3	3.3	3.2	3.3	3.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.4	3.4	3.2	3.3	3.4	3.7
		S	3.5	3.4	3.3	3.4	3.4	3.4
		T	3.4	3.2	3.2	3.4	3.4	3.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	A	A	A	A	A	A
	Current(A)	R	3.7	3.6	3.0	3.3	3.6	3.5	3.3
		S	3.8	3.9	3.4	3.9	3.8	3.9	3.9
		T	3.9	4.0	3.5	4.0	3.9	4.0	3.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		A	M	M	M	A	A	A
	Current(A)	R	6.8	6.9	6.8	7.0	6.9	6.8	6.9
		S	7.2	7.2	7.3	7.3	7.1	7.4	7.0
		T	6.9	6.9	7.1	7.1	7.3	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	M	M	A
	Current(A)	R	7.2	6.4	6.3	6.5	6.6	6.6	6.4
		S	7.1	6.9	6.8	6.2	7.0	6.9	6.4
		T	7.3	6.8	6.7	6.7	7.0	7.0	6.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	A	A	A	A	A	A
	Current(A)	R	6.3	5.8	5.6	5.7	5.9	5.9	4.0
		S	6.4	6.0	6.0	6.0	6.3	6.2	5.1
		T	6.2	5.9	5.8	5.8	6.0	6.0	5.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	M	M	M	A	A	A
	Current(A)	R	4.8	4.9	4.7	4.8	4.8	4.7	5.0
		S	4.7	5.2	5.0	5.2	5.0	5.0	4.4
		T	4.9	5.0	4.6	4.8	4.9	4.9	4.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	M	M	M
	Current(A)	R	6.7	6.5	7.0	7.2	7.9	7.7	7.7
		S	6.9	7.2	7.1	7.3	7.6	8.0	7.7
		T	7.1	7.1	6.9	7.1	7.4	7.5	7.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	A	M	M
	Current(A)	R	8.3	8.5	8.6	8.5	7.4	8.6	8.3
		S	8.3	8.7	8.7	8.7	8.4	8.5	8.3
		T	8.3	8.2	8.5	8.4	8.2	8.5	8.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		UN	UN	UN	UN	UN	UN	UN
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			13/4/67	16/4/67	17/4/67	18/4/67	19/4/67	20/4/67	21/4/67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

DAILY REPORT

MONTH. 8/14/69

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	12.1	11.2	11.1	11.1	11.2	11.1	11.3
		S	11.0	11.5	11.5	11.4	11.6	11.6	11.2
		T	11.1	11.3	11.7	11.3	11.3	11.2	11.4
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
WWP2	Auto/Off/Manual		M	A	M	M	M	M	M
	Current(A)	R	11.3	11.8	11.2	11.4	11.5	11.3	11.6
		S	12.0	11.9	12.0	11.9	12.1	11.7	11.7
		T	11.9	11.6	11.7	11.6	11.6	11.9	11.9
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SLP1	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		UN	UN	UN	UN	UN	UN	N
Pilot Lamp		N	N	N	N	N	N	N	
SLP2	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	A
	Current(A)	R	-	-	-	-	-	-	1.3
		S	-	-	-	-	-	-	1.4
		T	-	-	-	-	-	-	1.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.2	7.3	7.1	7.2	7.1	7.3
		S	7.4	7.3	7.2	7.5	7.5	7.2	8.0
		T	7.3	7.3	7.3	7.3	7.3	7.5	7.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.6	7.7	7.8	7.9	7.7	7.9	7.7
		S	7.8	7.7	7.7	7.8	7.4	7.7	8.3
		T	7.9	7.8	7.2	7.8	7.9	7.8	7.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SPI	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.2	3.3	3.2	3.2	3.3	3.2	3.3
		S	3.3	3.4	3.4	3.3	3.3	3.3	3.2
		T	3.2	3.3	3.4	3.2	3.1	3.2	3.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.4	3.4	3.3	3.4	3.4	3.3	3.4
		S	3.3	3.4	3.4	3.5	3.5	3.3	3.4
		T	3.4	3.3	3.5	3.4	3.5	3.5	3.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	

13/4/67 SE7 = Manual การเข้าถึง ตอน ที่ ๑-๒ ได้จัดทำเสร็จแล้ว
14/4/67 SLP1 = ผอ.ศูนย์ฯ รับทราบ

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	M	A	M
	Current(A)	R	3.9	3.4	3.5	3.6	3.2	3.6	3.9
		S	4.0	3.7	4.0	3.7	3.7	4.1	4.0
		T	4.1	3.8	3.9	3.9	3.7	4.1	4.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	A	A	A	M	A
	Current(A)	R	6.9	6.9	6.7	6.6	6.7	6.5	7.0
		S	7.3	7.0	7.1	6.6	7.0	7.4	6.9
		T	6.9	7.2	6.7	6.9	6.8	7.0	6.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	M	M	A	A	A
	Current(A)	R	7.2	6.4	6.6	6.7	6.3	6.5	7.1
		S	7.3	6.9	7.2	6.9	6.8	6.8	7.0
		T	7.1	6.8	7.2	6.6	6.6	6.8	7.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		A	A	M	A	M	A	M
	Current(A)	R	6.3	6.0	5.7	6.3	5.9	5.7	6.2
		S	6.3	6.2	6.5	6.2	6.2	6.1	6.3
		T	6.1	5.9	6.0	6.0	6.1	5.9	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		M	M	A	A	A	M	A
	Current(A)	R	4.9	4.8	4.6	3.9	4.7	4.8	4.9
		S	5.1	4.7	4.9	4.8	5.0	5.0	5.0
		T	4.6	4.5	4.2	4.1	4.9	4.8	4.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	M	A	A	A
	Current(A)	R	7.1	6.8	6.6	6.9	7.0	7.0	7.1
		S	7.0	7.3	7.6	7.2	7.1	7.1	7.0
		T	7.2	7.1	6.7	6.8	7.1	7.3	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		A	M	M	M	M	M	M
	Current(A)	R	8.4	8.7	8.4	8.6	8.6	8.5	8.4
		S	8.7	8.6	8.7	8.8	8.5	8.8	8.3
		T	8.6	8.4	8.6	8.4	8.6	8.4	8.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		UN	UN	UN	UN	UN	UN	UN
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			8 / 4 / 67	9 / 4 / 67	10 / 4 / 67	11 / 4 / 67	12 / 4 / 67	13 / 4 / 67	14 / 4 / 67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....1/4/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	11.3	11.4	11.0	11.0	12.1	12.1
		S	11.4	11.4	11.4	11.5	11.0	11.6
		T	11.1	11.5	11.2	11.3	11.4	11.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
WWP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	11.3	11.8	11.5	11.3	12.5	12.3
		S	11.9	11.9	12.0	11.9	12.7	12.7
		T	11.6	11.6	11.6	11.6	12.6	12.2
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP1	Auto/Off/Manual	OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-
		S	-	-	-	-	-	-
		T	-	-	-	-	-	-
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	UN	UN	UN	UN	UN	UN	UN
	Pilot Lamp	N	N	N	N	N	N	N
SLP2	Auto/Off/Manual	M	M	A	M	M	M	OFF
	Current(A)	R	1.5	1.4	1.6	1.7	1.7	1.7
		S	1.6	1.7	1.5	2.1	1.5	1.7
		T	1.6	1.7	1.7	1.6	1.7	1.5
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.6	7.6	7.1	6.6	7.1	7.5
		S	7.5	7.5	7.4	7.0	7.4	7.8
		T	7.6	7.1	7.3	7.1	7.3	7.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.8	7.8	7.8	7.6	7.8	7.8
		S	7.4	7.4	7.5	7.9	7.5	7.6
		T	7.7	7.6	7.0	7.8	7.6	7.9
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.3	3.3	3.3	3.2	3.5	3.5
		S	3.4	3.4	3.3	3.3	3.5	3.4
		T	3.3	3.4	3.4	3.2	3.4	3.2
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.4	3.4	3.0	3.4	2.3	3.4
		S	3.5	3.5	3.4	3.4	2.9	3.6
		T	3.4	3.4	3.4	3.4	2.5	3.6
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N

dp2 = 2000.115 + 1000.000 pump.

SLP2 = 1000.000 700 370 v

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	M	M	M
	Current(A)	R	3.5	3.5	3.5	3.6	4.0	3.7
		S	3.8	3.8	3.8	4.0	4.0	4.0
		T	4.0	4.0	3.9	4.0	4.0	4.3
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	A	A	A
	Current(A)	R	6.7	6.7	7.2	6.9	6.7	7.0
		S	7.3	7.4	7.4	7.6	6.7	7.6
		T	6.9	6.9	6.9	6.9	6.8	6.9
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SE3	Auto/Off/Manual		A	A	A	M	A	A
	Current(A)	R	6.5	6.6	6.4	6.7	7.1	7.2
		S	6.8	6.6	6.7	7.1	6.3	7.3
		T	6.8	6.7	6.8	7.0	6.7	7.0
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SE4	Auto/Off/Manual		A	A	A	M	M	M
	Current(A)	R	5.7	6.9	6.0	5.9	6.1	5.9
		S	6.1	6.1	6.1	5.5	6.0	5.9
		T	6.0	6.4	5.9	6.1	5.9	5.9
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SE5	Auto/Off/Manual		M	M	M	A	A	A
	Current(A)	R	4.8	4.8	4.8	4.8	5.1	5.3
		S	4.8	4.7	4.1	5.0	5.5	5.0
		T	4.2	4.6	4.9	4.9	5.3	4.9
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SE6	Auto/Off/Manual		A	A	A	A	A	A
	Current(A)	R	7.2	7.1	7.0	7.1	7.4	7.1
		S	7.2	7.1	7.2	7.7	7.5	6.9
		T	7.4	7.9	7.1	6.9	7.3	7.0
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SE7	Auto/Off/Manual		A	A	M	M	M	M
	Current(A)	R	8.1	8.1	8.4	8.5	8.4	8.4
		S	8.1	8.1	8.6	8.5	8.8	8.9
		T	8.1	8.1	8.4	8.5	8.6	8.6
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-
		S	-	-	-	-	-	-
		T	-	-	-	-	-	-
	Timer		N	N	N	N	N	N
	Overload -Alarm		UN	UN	UN	UN	UN	UN
	Pilot Lamp		N	N	N	N	N	N
Date Check >>		1/4/67	2/4/67	3/4/67	4/4/67	5/4/67	6/4/67	7/4/67
Record By >>								
Recheck By >>								

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... ๖.๙. ๒๕

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	11.3	11.4	11.4	11.1	11.3		
		S	11.6	11.6	11.6	11.6	11.6		
		T	11.4	11.3	11.3	11.3	11.3		
	Overload -Alarm		N	N	N	N	N		
	Latching relay control		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		
WWP2	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	11.4	11.3	11.3	11.3	11.4		
		S	11.6	11.4	11.4	11.4	11.3		
		T	11.2	11.1	11.1	11.1	11.1		
	Overload -Alarm		N	N	N	N	N		
	Latching relay control		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		
SLP1	Auto/Off/Manual		A	A	A	A	A		
	Current(A)	R	1.6	1.5	1.5	1.5	1.6		
		S	1.5	1.6	1.6	1.6	1.6		
		T	1.6	1.5	1.5	1.5	1.5		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		
SLP2	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	1.4	1.5	1.5	1.5	1.6		
		S	1.6	1.6	1.6	1.6	1.6		
		T	1.5	1.4	1.6	1.6	1.6		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		
DP1	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	7.4	7.5	7.5	7.5	7.5		
		S	7.4	7.4	7.6	7.4	7.5		
		T	7.6	7.6	7.6	7.6	7.6		
	Overload -Alarm		N	N	N	N	N		
	Latching relay control		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		
DP2	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	7.7	7.5	7.5	7.5	7.5		
		S	7.6	7.7	7.7	7.7	7.7		
		T	7.8	7.6	7.3	7.3	7.5		
	Overload -Alarm		N	N	N	N	N		
	Latching relay control		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		
SP1	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	3.3	3.7	3.7	3.7	3.7		
		S	3.6	3.5	3.9	3.6	3.6		
		T	3.7	3.4	3.4	3.4	3.6		
	Overload -Alarm		N	N	N	N	N		
	Latching relay control		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		
SP2	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	3.3	3.4	3.4	3.4	3.4		
		S	3.4	3.5	3.5	3.5	3.5		
		T	3.2	3.3	3.3	3.5	3.5		
	Overload -Alarm		N	N	N	N	N		
	Latching relay control		N	N	N	N	N		
	Pilot Lamp		N	N	N	N	N		

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A		
	Current(A)	R	4.5	4.6	4.6	4.5	4.5		
		S	4.4	4.4	4.6	4.4	4.4		
		T	4.7	4.2	4.8	4.7	4.7		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
SE2	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	6.4	6.5	6.5	6.5	6.5		
		S	6.6	6.7	6.7	6.7	6.6		
		T	6.7	6.4	6.6	6.4	6.6		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
SE3	Auto/Off/Manual		A	A	A	A	A		
	Current(A)	R	6.7	6.8	6.8	6.8	6.8		
		S	6.4	6.7	6.7	6.7	6.7		
		T	6.6	6.4	6.4	6.4	6.4		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
SE4	Auto/Off/Manual		A	A	A	A	A		
	Current(A)	R	5.3	5.6	5.6	5.6	5.6		
		S	5.5	5.2	5.9	5.2	5.9		
		T	5.7	5.3	5.3	5.3	5.9		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
SE5	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF		
	Current(A)	R	-	-	-	-	-		
		S	-	-	-	-	-		
		T	-	-	-	-	-		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
SE6	Auto/Off/Manual		A	A	A	A	A		
	Current(A)	R	7.8	7.6	7.6	7.6	7.6		
		S	7.7	7.5	7.5	7.5	7.5		
		T	7.6	7.7	7.7	7.7	7.7		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
SE7	Auto/Off/Manual		M	M	M	M	M		
	Current(A)	R	8.7	8.3	8.5	8.5	8.5		
		S	8.4	8.8	8.8	8.8	8.4		
		T	8.5	8.4	8.4	8.4	8.6		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
SE8	Auto/Off/Manual		off	off	OFF	OFF	OFF		
	Current(A)	R	-	-	-	-	-		
		S	-	-	-	-	-		
		T	-	-	-	-	-		
	Timer		N	N	N	N	N		
	Overload -Alarm		N	N	N	N	N		
Pilot Lamp			N	N	N	N	N		
Date Check >>			27/5/67	28/5/67	29/5/67	30/5/67	31/5/67	/ /	/ /
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....9/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.1	11.1	11.2	11.3	11.1
		S	11.3	11.4	11.4	11.4	11.3	11.6	11.3
		T	11.1	11.2	11.2	11.2	11.6	11.8	11.6
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.3	11.1	11.1	11.1	11.2	11.2	11.3
		S	11.3	11.6	11.6	11.6	11.3	11.4	11.4
		T	11.7	11.3	11.4	11.4	11.8	11.1	11.4
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.6	1.6	1.6	1.6	1.6	1.3	1.6
		S	1.3	1.4	1.4	1.4	1.5	1.7	1.3
		T	1.6	1.7	1.7	1.7	1.7	1.6	1.7
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.3	1.3	1.6	1.4	1.3	1.4	1.4
		S	1.4	1.1	1.6	1.6	1.3	1.3	1.6
		T	1.2	1.4	1.6	1.6	1.4	1.4	1.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.4	7.7	7.8	7.8	7.6	7.4	7.6
		S	7.6	7.4	7.5	7.5	7.7	7.6	7.5
		T	7.3	7.3	7.4	7.4	7.5	7.4	7.8
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.2	7.8	7.8	7.8	7.8	7.6	7.7
		S	7.3	7.6	7.6	7.6	7.6	7.3	7.6
		T	7.3	7.4	7.5	7.6	7.3	7.1	7.5
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.8	3.3	3.4	3.4	3.3	3.1	3.3
		S	3.4	3.7	3.6	3.6	3.8	3.3	3.6
		T	3.3	3.4	3.7	3.7	3.6	3.3	3.4
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.0	3.4	3.4	3.4	3.2	3.3	3.2
		S	3.1	3.3	3.5	3.5	3.6	3.3	3.5
		T	3.2	3.1	3.1	3.1	3.4	3.3	3.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.4	4.5	4.6	4.6	4.5	4.2	4.3
		S	4.3	4.7	4.6	4.6	4.6	4.3	4.3
		T	4.8	4.7	4.6	4.9	4.9	4.9	4.7
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.6	6.3	6.8	6.3	6.6	6.2	6.6
		S	6.4	6.3	6.8	6.4	6.4	6.7	6.8
		T	6.7	6.7	6.6	6.4	6.7	6.4	6.5
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.4	6.7	6.7	6.7	6.5	6.5	6.5
		S	6.3	6.3	6.6	6.6	6.6	6.6	6.6
		T	6.6	6.5	6.5	6.5	6.6	6.5	6.7
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE4	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	5.3	5.3	5.3	5.3	5.3	5.5	5.5
		S	5.7	5.7	5.7	5.7	5.1	5.7	5.6
		T	5.9	5.9	5.9	5.9	5.9	5.9	5.8
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE5	Auto/Off/Manual		off	off	off	off	off	off	off
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.7	7.6	7.6	7.8	7.6	7.8	7.6
		S	7.3	7.5	7.8	7.8	7.5	7.9	7.4
		T	7.6	7.4	7.4	7.4	7.4	7.3	7.4
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.8	8.6	8.6	8.7	8.8	8.5	8.6
		S	8.5	8.4	8.4	8.6	8.4	8.5	8.4
		T	8.5	8.5	8.5	8.4	8.5	8.2	8.4
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE8	Auto/Off/Manual		off	off	off	off	off	off	off
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
Date Check >>			20/05/17	21/05/17	22/05/17	23/05/17	24/05/17	25/05/17	26/05/17
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....5167

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.3	11.2	11.1	11.2	11.1
		S	11.8	11.8	11.7	11.4	11.8	11.9	11.3
		T	11.9	11.8	11.1	11.6	11.2	11.9	11.6
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.6	11.4	11.4	11.3	11.3	11.8	11.2
		S	11.3	11.6	11.2	11.1	11.3	11.8	11.4
		T	11.9	11.5	11.6	11.3	11.4	11.50	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.7	1.7	1.7	1.3	1.6	1.6	1.3
		S	1.8	1.8	1.6	1.6	1.6	1.6	1.6
		T	1.8	1.8	1.7	1.7	1.7	1.7	1.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		A	A	M	M	M	M	M
	Current(A)	R	1.6	1.6	1.3	1.4	1.4	1.6	1.4
		S	1.3	1.3	1.3	1.3	1.3	1.3	1.4
		T	1.3	1.3	1.4	1.4	1.3	1.5	1.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.5	6.5	6.5	6.8	6.7	7.0	6.4
		S	7.1	7.5	7.4	7.2	7.0	7.1	6.9
		T	7.2	7.4	7.0	7.1	7.1	7.1	6.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.2	7.1	7.1	7.2
		S	7.1	7.4	7.2	7.2	7.3	7.3	7.4
		T	7.2	7.2	7.2	7.4	7.2	7.4	7.5
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.6	3.6	3.6	3.6	3.7	3.8	3.2
		S	3.6	3.4	3.4	3.3	3.6	3.6	3.3
		T	3.6	3.6	3.4	3.5	3.9	3.1	3.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.1	3.1	3.2	3.1	3.2	3.2	3.0
		S	3.1	3.4	3.0	3.0	3.1	3.1	3.1
		T	3.0	3.0	3.1	3.1	3.3	3.3	2.9
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.0	4.1	4.3	4.4	4.0	4.0	4.0
		S	4.9	4.9	4.2	4.2	4.2	4.1	4.1
		T	4.9	4.1	4.5	4.1	4.4	4.2	4.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.2	7.1	6.9	7.0	7.8	7.9	7.0
		S	7.4	7.6	6.8	7.4	7.5	7.5	7.4
		T	7.3	7.6	7.0	7.6	7.4	7.4	7.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.6	6.6	6.4	6.4	6.4	6.6	6.3
		S	6.8	6.6	6.3	6.3	6.5	6.5	6.4
		T	6.6	6.9	6.4	6.4	6.3	6.3	6.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	5.2	5.9	5.2	5.2	5.2	5.9	5.1
		S	5.6	5.6	5.6	5.6	5.6	5.8	5.0
		T	5.7	5.7	5.7	5.8	5.7	5.7	5.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	4.8	4.8	4.8	4.8	4.4	4.6	4.9
		S	4.8	4.6	4.6	4.6	4.6	4.7	4.8
		T	4.6	4.6	4.6	4.6	4.8	4.9	4.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.2	7.2	7.2	7.4	7.2	7.2	7.4
		S	7.1	7.1	7.1	7.1	7.3	7.3	7.6
		T	7.9	7.4	7.2	7.6	7.4	7.4	7.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.6	8.6	8.6	8.8	8.5	8.8	8.3
		S	8.6	8.4	8.6	8.7	8.6	8.6	8.5
		T	8.7	8.7	8.6	8.6	8.7	8.7	8.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		off	off	off	off	off	off	off
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			6/9/67	7/5/67	8/3/67	9/5/67	10/5/67	11/5/67	12/5/67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark..... SE7 05/06/67 11:00 AM 11:00 AM 11:00 AM 11:00 AM 11:00 AM 11:00 AM 11:00 AM

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....5/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			11.1	11.0	11.1	11.1	11.1
		S			11.8	11.6	11.6	11.6	11.6
		T			11.2	11.3	11.3	11.3	11.3
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
WWP2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			11.4	11.4	11.6	11.6	11.4
		S			11.3	11.3	11.6	11.6	11.3
		T			11.9	11.7	11.7	11.6	11.8
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
SLP1	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			1.7	1.7	1.7	1.7	1.7
		S			1.8	1.7	1.7	1.7	1.7
		T			1.8	1.8	1.8	1.8	1.8
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
SLP2	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			1.9	1.3	1.8	1.3	1.4
		S			1.3	1.2	1.3	1.3	1.3
		T			1.3	1.2	1.4	1.4	1.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
DP1	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			6.5	6.8	6.8	6.7	6.8
		S			7.0	6.9	6.9	6.7	6.7
		T			7.1	7.0	7.1	6.8	6.7
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
DP2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			7.2	7.2	7.2	7.2	7.4
		S			7.7	7.7	7.8	7.9	7.2
		T			7.6	8.1	8.1	7.9	7.8
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
SP1	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			3.4	3.6	3.6	3.4	3.4
		S			3.3	3.4	3.4	3.3	3.4
		T			3.3	3.4	3.4	3.4	2.9
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
SP2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			3.4	3.5	3.5	3.2	3.1
		S			3.2	3.2	3.2	3.2	3.2
		T			3.6	3.5	3.5	3.5	3.0
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			3.9	4.0	4.0	4.0	4.0
		S			4.2	4.1	4.1	4.1	4.2
		T			4.2	4.1	4.1	4.1	4.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	
SE2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			7.6	7.7	7.1	7.1	7.7
		S			7.6	7.5	7.5	7.5	7.4
		T			7.2	7.4	7.4	7.4	7.3
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	
SE3	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			6.4	6.2	6.2	6.9	6.4
		S			6.8	6.6	6.1	6.1	6.9
		T			6.3	6.0	6.0	6.2	6.6
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	
SE4	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			5.9	5.7	6.7	6.7	5.9
		S			5.8	5.8	6.8	6.8	6.4
		T			6.1	6.0	6.0	6.0	6.3
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	
SE5	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			4.7	4.7	4.7	4.7	4.8
		S			4.8	4.7	4.8	4.7	4.3
		T			4.6	4.8	4.9	4.8	4.6
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	
SE6	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			7.1	7.3	7.3	7.3	7.2
		S			7.3	7.2	7.3	7.3	7.1
		T			7.0	7.1	7.4	7.4	7.3
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	
SE7	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			8.4	8.5	8.5	8.6	8.2
		S			8.4	8.5	8.5	8.5	8.4
		T			8.9	9.0	9.0	8.0	8.5
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	
SE8	Auto/Off/Manual				OFF	OFF	OFF	OFF	OFF
	Current(A)	R			-	-	-	-	-
		S			-	-	-	-	-
		T			-	-	-	-	-
	Timer				N	N	N	N	N
	Overload -Alarm				UN	UN	UN	UN	UN
Pilot Lamp					N	N	N	N	
Date Check >>			1 / 1	1 / 1	1 / 5 / 67	2 / 5 / 67	8 / 5 / 67	14 / 6 / 67	8 / 3 / 67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark: SE7 ตัวกด Magnetic คือตัวกด

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 5/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.2	11.4	11.2	11.1	11.1	11.3	11.1
		S	11.5	11.7	11.3	11.6	11.6	11.6	11.4
		T	11.3	11.5	11.3	11.3	11.3	11.5	11.6
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.3	11.4	11.2	11.2	11.4	11.0	11.2
		S	11.3	11.6	11.6	11.6	11.6	11.4	11.7
		T	11.1	11.2	11.1	11.1	11.2	11.1	11.3
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.7	1.6	1.4	1.4	1.4	1.3	1.4
		S	1.5	1.5	1.3	1.3	1.3	1.3	1.3
		T	1.8	1.6	1.3	1.3	1.3	1.6	1.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.5	1.4	1.7	1.7	1.7	1.8	1.7
		S	1.6	1.6	1.6	1.6	1.6	1.7	1.6
		T	1.5	1.3	1.4	1.4	1.4	1.7	1.7
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.2	7.3	7.5	7.5	7.5	7.6	7.6
		S	7.1	7.3	7.4	7.4	7.4	7.7	7.5
		T	7.3	7.6	7.6	7.6	7.6	7.4	7.6
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.3	7.3	7.8	7.7	7.7	7.8	7.9
		S	7.2	7.6	7.7	7.3	7.3	7.3	7.7
		T	7.4	7.3	7.7	7.3	7.3	7.5	7.7
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.7	3.6	3.3	3.3	3.3	3.3	3.3
		S	3.6	3.1	3.2	3.1	3.1	3.3	3.2
		T	3.4	3.3	3.3	3.3	3.3	3.1	3.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.3	3.6	3.1	3.1	3.1	3.2	3.1
		S	3.1	3.8	3.0	3.1	3.4	3.6	3.1
		T	3.7	3.2	3.1	3.1	3.1	3.3	3.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	4.3	4.7	4.3	10.9	10.9	4.4	4.7
		S	4.3	4.6	4.4	10.6	10.6	4.7	4.3
		T	4.6	4.7	4.6	10.6	10.6	4.3	4.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.9	6.8	6.8	6.8	6.8	6.8	6.9
		S	7.2	6.9	6.9	6.3	6.3	6.9	6.8
		T	7.0	7.1	6.9	6.9	6.9	6.6	6.7
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.2	6.3	6.4	6.6	6.4	6.3	6.6
		S	6.7	6.8	6.6	6.3	6.3	6.2	6.4
		T	6.6	6.4	6.3	6.6	6.4	6.7	6.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	5.5	5.4	5.3	5.5	5.5	5.3	5.4
		S	5.8	5.9	5.5	5.4	5.4	5.4	5.7
		T	5.4	5.3	5.2	5.2	5.3	5.3	5.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		M	M	M	M	OFF	OFF	OFF
	Current(A)	R	4.9	4.7	4.6	10.6	-	-	-
		S	4.4	4.3	4.2	10.2	-	-	-
		T	4.7	4.3	4.3	10.5	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.3	7.7	7.4	7.8	7.6	7.4	7.7
		S	7.7	7.8	7.6	7.9	7.6	7.6	7.8
		T	7.1	7.3	7.7	7.6	7.6	7.7	7.3
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.6	8.8	8.6	8.6	8.7	8.8	8.4
		S	8.5	8.4	8.7	8.5	8.6	8.4	8.7
		T	8.8	8.5	8.8	8.4	8.6	8.6	8.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			13/5/17	14/5/17	15/5/17	16/5/17	17/5/17	18/5/17	19/5/17
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 23/6/67

WASTE WATERTREATMENT PLANT

TIME

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.2
		S	11.2	11.2	11.2	11.2	11.2	11.3
		T	11.4	11.4	11.4	11.3	11.4	11.2
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
WWP2	Auto/Off/Manual	A	A	A	A	A	A	A
	Current(A)	R	11.2	11.2	11.3	11.2	11.2	11.3
		S	11.4	11.4	11.4	11.4	11.4	11.4
		T	11.4	11.4	11.4	11.4	11.4	11.2
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP1	Auto/Off/Manual	A	A	A	A	A	A	A
	Current(A)	R	1.9	1.8	1.8	1.8	1.8	2.0
		S	1.8	1.8	1.8	1.9	1.9	2.1
		T	1.9	1.9	1.9	1.9	1.9	2.0
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP2	Auto/Off/Manual	A	A	A	A	A	A	A
	Current(A)	R	1.3	1.3	1.3	1.3	1.3	1.3
		S	1.4	1.4	1.4	1.4	1.4	1.4
		T	1.3	1.3	1.3	1.3	1.3	1.3
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DPI	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.8	7.8	7.8	7.8	7.9	8.0
		S	7.8	7.6	7.8	7.9	7.9	8.0
		T	7.9	7.9	7.9	7.6	7.8	8.0
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.5	7.5	7.5	7.5	7.5	7.6
		S	7.6	7.6	7.6	7.6	7.6	7.7
		T	7.6	7.6	7.6	7.9	7.5	7.5
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SPI	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.4	3.4	3.4	3.4	3.3	3.2
		S	3.3	3.3	3.3	3.3	3.4	3.4
		T	3.4	3.4	3.4	3.3	3.3	3.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.6	3.4	3.4	3.4	3.3	3.3
		S	3.5	3.5	3.5	3.5	3.5	3.5
		T	3.5	3.5	3.5	3.3	3.3	3.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		S	6.4	6.4	6.3	6.3	6.4	6.4	6.2
		T	6.3	6.3	6.3	6.3	6.3	6.3	6.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.0	6.0	6.0	6.0	6.0	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.2
		T	6.0	6.0	6.0	6.1	6.0	6.0	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.7	6.7	6.7	6.7	6.7	6.7	6.6
		S	7.6	6.8	6.8	6.8	7.1	7.1	6.9
		T	7.0	7.0	7.0	7.0	7.0	7.0	6.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.9	6.4	6.5	6.5	6.2	6.2	6.3
		S	6.5	6.5	6.5	6.5	6.5	6.5	6.4
		T	6.4	6.4	6.4	6.4	6.4	6.4	6.4
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp			-	-	-	-	-	-	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.2	7.2	7.2	7.2	7.0	7.0	7.0
		S	7.3	7.3	7.3	7.3	7.0	7.0	7.1
		T	7.4	7.4	7.4	7.4	7.2	7.2	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.7	8.9	8.9	8.9	8.7	8.7	8.6
		S	8.6	8.6	8.6	8.6	8.7	8.7	8.7
		T	8.6	8.6	8.6	8.6	8.6	8.6	8.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp			-	-	-	-	-	-	
Date Check >>			24/6/67	25/6/67	25/6/67	26/6/67	28/6/67	29/6/67	30/6/67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH...16/6/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.2	11.1	11.1
		S	11.2	11.2	11.2	11.3	11.4	11.4
		T	11.6	11.4	11.6	11.2	11.3	11.6
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
WWP2	Auto/Off/Manual	A	A	A	A	A	A	A
	Current(A)	R	11.8	11.3	11.9	11.3	11.2	11.2
		S	11.6	11.6	11.6	11.6	11.6	11.4
		T	11.9	11.3	11.3	11.4	11.6	11.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP1	Auto/Off/Manual	M	M	M	M	A	A	A
	Current(A)	R	2.0	2.0	2.0	1.8	1.8	1.5
		S	2.1	2.1	2.1	1.9	1.9	1.9
		T	2.0	2.0	2.0	1.9	1.9	1.9
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP2	Auto/Off/Manual	M	M	M	M	A	A	A
	Current(A)	R	1.4	1.4	1.4	1.4	1.3	1.3
		S	1.3	1.3	1.3	1.3	1.4	1.4
		T	1.4	1.4	1.4	1.4	1.3	1.3
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.8	7.8	7.8	7.8	7.8	7.8
		S	7.5	7.5	7.5	7.8	7.9	7.9
		T	7.8	7.8	7.8	7.8	7.8	7.8
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.4	7.4	7.4	7.4	7.5	7.5
		S	7.5	7.5	7.5	7.4	7.6	7.6
		T	7.4	7.4	7.4	7.6	7.5	7.6
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.4	3.2	3.2	3.2	3.3	3.3
		S	3.4	3.4	3.4	3.4	3.4	3.4
		T	3.2	3.2	3.2	3.3	3.3	3.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.3	3.3	3.3	3.3	3.4	3.4
		S	3.5	3.4	3.4	3.4	3.5	3.4
		T	3.4	3.4	3.4	3.3	3.3	3.5
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	6.9	6.3	6.8	6.0	6.1	6.1
		S	6.5	6.5	6.8	6.4	6.4	6.4
		T	6.5	6.5	6.5	6.2	6.3	6.3
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SE2	Auto/Off/Manual	A	A	A	A	A	A	A
	Current(A)	R	6.0	6.0	6.0	5.9	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.1
		T	6.0	6.0	6.1	5.8	6.0	6.0
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SE3	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	6.6	6.6	6.6	6.6	6.7	6.7
		S	6.8	6.8	6.6	7.0	7.1	7.2
		T	6.9	6.9	6.9	7.0	7.0	7.0
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SE4	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	6.0	6.0	6.0	6.1	6.2	6.2
		S	6.1	6.1	6.1	6.4	6.5	6.5
		T	6.1	6.1	6.1	6.3	6.4	6.4
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SE5	Auto/Off/Manual	OPF	OPF	OPF	OPF	OPF	OPF	OPF
	Current(A)	R	1	1	1	1	1	1
		S	1	1	1	1	1	1
		T	1	1	1	1	1	1
	Timer	1	1	1	1	1	1	1
	Overload -Alarm	1	1	1	1	1	1	1
	Pilot Lamp	1	1	1	1	1	1	1
SE6	Auto/Off/Manual	A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	7.0	7.0	7.0
		S	6.6	6.5	6.5	6.9	7.0	7.0
		T	6.8	6.8	6.8	7.0	7.0	7.1
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SE7	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	8.5	8.5	8.5	8.5	9.7	8.7
		S	8.7	8.7	8.7	8.6	8.7	8.6
		T	8.6	8.6	8.6	8.6	8.6	8.6
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SE8	Auto/Off/Manual	OPF	OPF	OPF	OPF	OPF	OPF	OPF
	Current(A)	R	1	1	1	1	1	1
		S	1	1	1	1	1	1
		T	1	1	1	1	1	1
	Timer	1	1	1	1	1	1	1
	Overload -Alarm	1	1	1	1	1	1	1
	Pilot Lamp	1	1	1	1	1	1	1
Date Check >>		17/6/17	18/6/17	19/6/17	20/6/17	21/6/17	22/6/17	23/6/17
Record By >>								
Recheck By >>								

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 6 / 67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	11.1	11.4	11.1	11.2	11.2	11.2
		S	11.1	11.1	11.1	11.3	11.3	11.1
		T	11.5	11.5	11.6	11.4	11.4	11.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
WWP2	Auto/Off/Manual	M	M	M	M	A	A	A
	Current(A)	R	11.1	11.3	11.3	11.3	11.3	11.3
		S	11.4	11.4	11.4	11.6	11.6	11.6
		T	11.5	11.5	11.5	11.4	11.5	11.3
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP1	Auto/Off/Manual	A	A	A	A	M	M	M
	Current(A)	R	2.1	2.1	2.1	2.0	2.0	2.0
		S	2.4	2.4	2.1	2.1	2.1	2.1
		T	2.4	2.4	2.3	2.0	2.0	2.0
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	1.3	1.3	1.3	1.3	1.4	1.6
		S	1.4	1.4	1.4	1.3	1.4	1.3
		T	1.4	1.4	1.6	1.4	1.4	1.6
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.8	7.8	7.8	7.8	7.8	7.8
		S	7.4	7.4	7.4	7.5	7.5	7.5
		T	7.6	7.6	7.4	7.7	7.7	7.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	7.4	7.4	7.4	7.4	7.4	7.4
		S	7.6	7.6	7.6	7.5	7.5	7.5
		T	7.5	7.5	7.5	7.5	7.4	7.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP1	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.4	3.4	3.4	3.2	3.2	3.2
		S	3.4	3.4	3.4	3.4	3.4	3.4
		T	3.6	3.6	3.6	3.3	3.2	3.2
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP2	Auto/Off/Manual	M	M	M	M	M	M	M
	Current(A)	R	3.1	3.1	3.1	3.3	3.3	3.3
		S	3.4	3.4	3.4	3.4	3.4	3.4
		T	3.3	3.3	3.4	3.4	3.4	3.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	M	M	M
	Current(A)	R	6.4	6.4	6.6	6.4	6.2	6.3	6.3
		S	6.8	6.8	6.9	6.6	6.5	6.5	6.5
		T	6.8	6.8	6.8	6.8	6.5	6.5	6.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.8	6.8	6.3	6.3	6.9	6.0	6.0
		S	6.9	6.9	6.9	6.9	6.1	6.1	6.1
		T	6.4	6.4	6.4	6.4	6.0	6.0	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.7	6.7	6.7	6.7	6.7	6.6	6.6
		S	6.6	6.6	6.7	6.7	6.9	6.8	6.8
		T	6.6	6.6	6.9	6.5	6.9	6.9	6.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	5.9	5.9	5.9	5.9	5.9	6.0	6.0
		S	5.6	5.6	5.6	5.6	6.1	6.1	6.1
		T	5.7	5.7	5.6	5.5	6.0	6.0	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.3	6.3	6.3	6.3	6.8	6.7	6.7
		S	6.9	6.9	6.9	6.9	8.0	6.9	6.9
		T	6.9	6.9	6.9	6.9	6.8	6.8	6.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.4	8.4	8.4	8.6	8.5	8.4	8.5
		S	8.6	8.6	8.5	8.5	8.8	8.7	8.7
		T	8.5	8.5	8.4	8.4	8.5	8.5	8.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
Date Check >>			10/6/17	11/6/17	12/6/17	13/6/17	14/6/17	15/6/17	16/6/17
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....6/67.....

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M	m	m	m	m	m	m
	Current(A)	R	11.2	11.1	11.1	11.1	11.1	11.1
		S	11.7	11.7	11.7	11.1	11.1	11.1
		T	11.5	11.5	11.5	11.5	11.5	11.5
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
WWP2	Auto/Off/Manual	M	m	m	m	m	m	m
	Current(A)	R	11.3	11.1	11.1	11.3	11.4	11.1
		S	12.0	11.9	11.9	11.4	11.9	11.4
		T	11.5	11.5	11.5	11.5	11.5	11.5
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP1	Auto/Off/Manual	A	A	A	A	A	A	A
	Current(A)	R	2.0	2.1	2.1	2.1	2.1	2.1
		S	2.0	2.9	2.1	2.4	2.4	2.4
		T	2.0	2.1	2.6	2.4	2.6	2.4
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SLP2	Auto/Off/Manual	M	m	m	m	m	m	m
	Current(A)	R	1.2	1.4	1.2	1.3	1.3	1.3
		S	1.4	1.6	1.6	1.4	1.4	1.6
		T	1.3	1.6	1.6	1.4	1.4	1.4
	Timer	N	N	N	N	N	N	N
	Overload -Alarm	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP1	Auto/Off/Manual	M	m	m	m	m	m	m
	Current(A)	R	7.5	7.9	7.8	7.9	7.6	7.8
		S	7.3	7.6	7.6	7.4	7.4	7.4
		T	7.5	7.5	7.6	7.6	7.6	7.6
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
DP2	Auto/Off/Manual	M	m	m	m	m	m	m
	Current(A)	R	7.4	7.4	7.6	7.4	7.4	7.4
		S	7.5	7.5	7.6	7.6	7.6	7.6
		T	7.5	7.4	7.5	7.4	7.5	7.5
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP1	Auto/Off/Manual	M	m	m	m	m	m	m
	Current(A)	R	3.2	3.2	3.2	3.4	3.2	3.2
		S	3.3	3.4	3.1	3.1	3.4	3.4
		T	3.3	3.3	3.3	3.3	3.7	3.5
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N
SP2	Auto/Off/Manual	M	m	m	m	m	m	m
	Current(A)	R	3.3	3.3	3.3	3.3	3.2	3.2
		S	3.3	3.6	3.4	3.4	3.4	3.2
		T	3.3	3.6	3.6	3.4	3.4	3.4
	Overload -Alarm	N	N	N	N	N	N	N
	Latching relay control	N	N	N	N	N	N	N
	Pilot Lamp	N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.2	6.2	6.4	6.4	6.6	6.4	6.4
		S	6.7	6.7	6.9	6.9	6.9	6.9	6.9
		T	6.6	6.8	6.7	6.7	6.7	6.7	6.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.7	6.7	6.7	6.7	6.7	6.7	6.3
		S	6.9	6.9	6.9	6.9	6.9	6.9	6.9
		T	6.6	6.6	6.6	6.6	6.8	6.6	6.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		N	M	M	M	M	M	M
	Current(A)	R	6.7	6.7	6.7	6.7	6.5	6.7	6.7
		S	7.1	7.1	7.1	7.1	6.9	6.9	6.6
		T	7.0	7.0	7.0	7.0	6.6	6.6	6.6
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	5.4	5.9	5.9	5.9	5.9	5.9	5.9
		S	5.7	5.9	5.8	5.8	5.8	5.8	5.8
		T	5.8	5.8	5.8	5.8	5.8	5.8	5.8
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.3	6.3	6.3	6.4	6.4	6.3	6.3
		S	7.0	7.0	7.0	6.9	6.6	6.9	6.9
		T	6.4	6.6	7.0	6.9	6.9	6.9	6.9
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.4	8.4	8.4	8.4	8.5	8.4	8.4
		S	8.6	8.5	8.5	8.6	8.6	8.5	8.6
		T	8.5	8.6	8.5	8.0	8.4	8.5	8.5
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE8	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
Date Check >>			3/6/67	4/6/67	5/6/67	6/6/67	7/6/67	8/6/67	9/6/67
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....6/67

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual						M	M
	Current(A)	R					11.4	11.4
		S					11.6	11.5
		T					11.3	11.4
	Overload -Alarm						N	N
	Latching relay control						N	N
	Pilot Lamp						N	N
WWP2	Auto/Off/Manual						M	M
	Current(A)	R					11.3	11.3
		S					11.4	11.4
		T					11.1	11.2
	Overload -Alarm						N	N
	Latching relay control						N	N
	Pilot Lamp						N	N
SLP1	Auto/Off/Manual						A	A
	Current(A)	R					1.5	1.6
		S					1.6	1.6
		T					1.5	1.5
	Timer						N	N
	Overload -Alarm						N	N
	Pilot Lamp						N	N
SLP2	Auto/Off/Manual						M	M
	Current(A)	R					1.5	1.5
		S					1.6	1.6
		T					1.4	1.5
	Timer						N	N
	Overload -Alarm						N	N
	Pilot Lamp						N	N
DP1	Auto/Off/Manual						M	M
	Current(A)	R					7.5	7.4
		S					7.4	7.4
		T					7.6	7.5
	Overload -Alarm						N	N
	Latching relay control						N	N
	Pilot Lamp						N	N
DP2	Auto/Off/Manual						M	M
	Current(A)	R					7.5	7.5
		S					7.7	7.6
		T					7.3	7.4
	Overload -Alarm						N	N
	Latching relay control						N	N
	Pilot Lamp						N	N
SP1	Auto/Off/Manual						M	M
	Current(A)	R					3.7	3.6
		S					3.3	3.3
		T					3.4	3.4
	Overload -Alarm						N	N
	Latching relay control						N	N
	Pilot Lamp						N	N
SP2	Auto/Off/Manual						M	M
	Current(A)	R					3.4	3.4
		S					3.5	3.5
		T					3.5	3.4
	Overload -Alarm						N	N
	Latching relay control						N	N
	Pilot Lamp						N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual							A	A
	Current(A)	R						4.6	4.6
		S						4.4	4.4
		T						4.2	4.3
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SE2	Auto/Off/Manual							M	M
	Current(A)	R						6.5	6.5
		S						6.6	6.6
		T						6.4	6.4
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SE3	Auto/Off/Manual							A	A
	Current(A)	R						6.8	6.7
		S						6.7	6.7
		T						6.4	6.4
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SE4	Auto/Off/Manual							A	A
	Current(A)	R						5.6	5.6
		S						5.2	5.2
		T						5.3	5.3
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SE5	Auto/Off/Manual							OFF	OFF
	Current(A)	R						-	-
		S						-	-
		T						-	-
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SE6	Auto/Off/Manual							A	A
	Current(A)	R						7.6	7.4
		S						7.5	7.6
		T						7.7	7.6
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SE7	Auto/Off/Manual							M	M
	Current(A)	R						8.5	8.4
		S						8.6	8.5
		T						8.4	8.4
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SE8	Auto/Off/Manual							OFF	OFF
	Current(A)	R						-	-
		S						-	-
		T						-	-
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
Date Check >>			/ /	/ /	/ /	/ /	/ /	1 / 6 / 07	2 / 6 / 07
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

.....