

ภาคผนวก ข8

เอกสารการจัดอบรมและข้อมูลการอพยพคนกรณีเพลิงไหม้

---

ที่ กท ๑๘๐๘/๑๐๓๒



สำนักป้องกันและบรรเทาสาธารณภัย

๗๗/๑ ถนนพระรามที่๖ กรุงเทพฯ ๑๐๕๐๐

๖ ตุลาคม ๒๕๖๖

เรื่อง การฝึกอบรมดับเพลิงขั้นต้นและการฝึกซ้อมดับเพลิงและซ้อมหนีไฟประจำปี

เรียน ผู้บริหารโรงแรมแกรนด์ เซนเตอร์พอยต์ ราชดำริ

อ้างถึง หนังสือโรงแรมแกรนด์ เซนเตอร์พอยต์ ราชดำริ ลงวันที่ ๑๒ กันยายน ๒๕๖๖

สิ่งที่ส่งมาด้วย หนังสือรับรองผลการอบรมดับเพลิงขั้นต้นและฝึกซ้อมดับเพลิงและหนีไฟประจำปี

รายชื่อพนักงานที่เข้ารับการอบรมดับเพลิงขั้นต้นและฝึกซ้อมดับเพลิงและหนีไฟประจำปี

ตามหนังสือที่อ้างถึงดังกล่าวโรงแรมแกรนด์ เซนเตอร์พอยต์ ราชดำริ ขอรับการสนับสนุนเจ้าหน้าที่สำนักป้องกันและบรรเทาสาธารณภัยเพื่อทำการอบรมดับเพลิงขั้นต้นและการฝึกซ้อมดับเพลิงและซ้อมหนีไฟประจำปี ๒๕๖๖ ความละเอียดแจ้งแล้วนั้น

สำนักป้องกันและบรรเทาสาธารณภัย กรุงเทพมหานคร ได้จัดเจ้าหน้าที่ไปดำเนินการอบรมที่โรงแรม ในวันที่ ๕ ตุลาคม ๒๕๖๖ โดยมีผู้เข้ารับการอบรมดับเพลิงขั้นต้น จำนวน ๔๔ คน และมีผู้เข้าร่วมฝึกซ้อมดับเพลิงและซ้อมหนีไฟประจำปี จำนวน ๕๘ คน เป็นไปตามกฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานที่เกี่ยวกับการป้องกันและระงับอัคคีภัย พ.ศ.๒๕๕๕ เรียบร้อยแล้ว

จึงเรียนมาเพื่อโปรดทราบ

ขอแสดงความนับถือ



(นายธีรยุทธ ภูมิภักดิ์)

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย

กองปฏิบัติการดับเพลิงและกู้ภัย ๕

โทรศัพท์ ๐ ๒๓๕๔ ๖๘๗๕

โทรสาร ๐ ๒๓๕๔ ๖๘๗๕

ที่ กท ๑๘๐๘/๑๐๓๓



สำนักป้องกันและบรรเทาสาธารณภัย  
๗๓/๑ ถนนพระรามที่๖ กทม.๑๐๕๐๐

หนังสือฉบับนี้ให้ไว้เพื่อรับรองว่าพนักงานของโรงแรมแกรนด์ เซนเตอร์พอยต์ ราชดำริ ตั้งอยู่เลขที่ ๑๕๓ ซอยมหาดเล็กหลวง ๑ ถนนราชดำริ แขวงลุมพินี เขตปทุมวัน กรุงเทพฯ ๑๐๓๓๐ โดยมี คุณอนนทร์ คงศิริพันธ์ พร้อมด้วยพนักงานจำนวนทั้งสิ้น ๔๔ คน (ตามบัญชีแนบท้ายหนังสือรับรองนี้) ได้ผ่านการอบรมดับเพลิงขั้นต้น เป็นไปตามกฎกระทรวงกำหนดมาตรฐานในการบริหารจัดการ และดำเนินการ ด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานที่เกี่ยวกับการป้องกันและระงับอัคคีภัย พ.ศ.๒๕๕๕ เรียบร้อยแล้ว โดยดำเนินการฝึกอบรมในวันที่ ๕ ตุลาคม พุทธศักราช ๒๕๖๖ โดยวิทยากรจาก สำนักป้องกันและบรรเทาสาธารณภัย กรุงเทพมหานคร ใบอนุญาตเลขที่ ดพต.-ร ๒๐๒

ให้ไว้ ณ วันที่ ๑๖ / ตุลาคม พุทธศักราช ๒๕๖๖



(นายธีรยุทธ ภูมิภักดิ์)

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย

ที่ กท ๑๘๐๘/๐๐๓๔



สำนักป้องกันและบรรเทาสาธารณภัย  
๗๗/๑ ถนนพระรามที่๖ กทม.๑๐๔๐๐

หนังสือฉบับนี้ให้ไว้เพื่อรับรองว่าพนักงานของโรงแรมแกรนด์ เซนเตอร์พอยต์ ราชดำริ ตั้งอยู่เลขที่ ๑๕๓ ซอยมหาดเล็กหลวง ๑ ถนนราชดำริ แขวงลุมพินี เขตปทุมวัน กรุงเทพฯ ๑๐๓๓๐ โดยมี คุณอนนทร์ คงศิริพันธ์ พร้อมด้วยพนักงานจำนวนทั้งสิ้น ๕๘ คน (ตามบัญชีแนบท้ายหนังสือรับรองนี้) ได้ผ่านการฝึกซ้อมดับเพลิงและซ้อมหนีไฟประจำปี เป็นไปตามกฎกระทรวงกำหนดมาตรฐานในการบริหารจัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานที่เกี่ยวกับการป้องกัน และระงับอัคคีภัย พ.ศ.๒๕๕๕ เรียบร้อยแล้ว โดยดำเนินการฝึกซ้อมวันที่ ๕ ตุลาคม พุทธศักราช ๒๕๖๖ โดยวิทยากรจากสำนักป้องกันและบรรเทาสาธารณภัย กรุงเทพมหานคร ใบอนุญาตเลขที่ ดพผ.-ร ๒๐๒ ผล การดำเนินการอยู่ในเกณฑ์ดี

ให้ไว้ ณ วันที่ ๖ ตุลาคม พุทธศักราช ๒๕๖๖



(นายธีรยุทธ ภูมิภักดิ์)

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย



## รายงานการฝึกอบรมการดับเพลิงขั้นต้น

( สำหรับหน่วยงานที่ได้รับใบอนุญาตเท่านั้น )

ชื่อหน่วยงานที่ได้รับใบอนุญาต.....สำนักงานป้องกันและบรรเทาสาธารณภัย กรุงเทพมหานคร.....  
หมายเลขใบอนุญาต.....ดพด.-ร ๒๐๒.....หมดอายุ.....๑๐ พฤษภาคม ๒๕๖๗.....

### ส่วนที่ ๑ รายงานการฝึกอบรม

๑. ข้อมูลสถานประกอบกิจการที่เข้ารับการฝึกอบรม  
ชื่อสถานประกอบกิจการ.....โรงแรมแกรนด์เซนต์เอเธอร์เพลส ราชดำริ.....  
ประเภทกิจการ.....โรงแรม.....  
ที่ตั้ง.....๑๕๓.....ซอย.....มหาดเล็กหลวง ๑.....ถนน.....ราชดำริ.....แขวง.....ลุมพินี.....  
เขต.....ปทุมวัน.....จังหวัด.....กรุงเทพมหานคร.....รหัสไปรษณีย์.....๑๐๓๓๐.....  
โทรศัพท์.....๐๒ - ๖๗๐ ๕๐๐๐.....โทรสาร.....๐๒ - ๖๗๐ ๕๑๐๐.....
๒. วัน เดือน ปี ที่ฝึกอบรม.....๕ ตุลาคม ๒๕๖๖.....
๓. จำนวนผู้เข้ารับการฝึกอบรม.....๔๔.....คน ( แนบรายชื่อผู้ผ่านการฝึกอบรม )  
หญิง.....๑๗.....คน ชาย.....๒๗.....คน
๔. ชื่อวิทยากรผู้ทำการอบรมภาคทฤษฎี  
๔.๑.....ส.อ.ณัฏฐ์ พรหมเกสร.....๔.๒.....
๕. ชื่อวิทยากรผู้ทำการอบรมภาคปฏิบัติ  
๕.๑.....ส.อ.ณัฏฐ์ พรหมเกสร.....๕.๒.....นายศุภวิทย์ วัจระอม.....  
๕.๓.....นายพรพล บุตติวงศ์.....๕.๔.....
๖. ชื่อผู้ดูแลการฝึกอบรม.....ส.อ.ณัฏฐ์ พรหมเกสร.....
๗. สถานที่ฝึกภาคปฏิบัติ.....โรงแรมแกรนด์ เซนต์เอเธอร์เพลส ราชดำริ.....  
ลงชื่อ.....  
( ส.อ.ณัฏฐ์ พรหมเกสร )  
พนักงานป้องกันและบรรเทาสาธารณภัยชำนาญงาน.....  
ผู้จัดทำรายงาน.....  
วัน / เดือน / ปี ที่รายงาน.....๖ ตุลาคม ๒๕๖๖.....

### ส่วนที่ ๒ การรับรอง

ข้าพเจ้าขอรับรองว่าได้มีการฝึกซ้อมดับเพลิงและหนีไฟตามรายละเอียดข้างต้นจริง

- ลงชื่อ.....  
( ส.อ.ณัฏฐ์ พรหมเกสร )  
วิทยากร.....
- ลงชื่อ.....  
( นายศุภวิทย์ วัจระอม )  
วิทยากร.....
- ลงชื่อ.....  
( นายพรพล บุตติวงศ์ )  
วิทยากร.....
- ลงชื่อ.....  
( ..... )  
วิทยากร.....
- ลงชื่อ..... นายจ้ำ / เจ้าของสถานประกอบกิจการที่ได้รับการฝึกซ้อมดับเพลิงและฝึกซ้อมหนีไฟ.....  
( ..... ) หรือผู้มีอำนาจกระทำการแทน

## รายงานผลการฝึกอบรมการดับเพลิงและฝึกซ้อมอพยพหนีไฟ

( สำหรับหน่วยงานที่ได้รับใบอนุญาตเท่านั้น )

ชื่อหน่วยงานที่ได้รับใบอนุญาต..... สำนักป้องกันและบรรเทาสาธารณภัย กรุงเทพมหานคร.....  
หมายเลขใบอนุญาต..... ดพฝ.-ร. ๒๐๒..... หมดยุ..... ๑๐ พฤษภาคม ๒๕๖๗.....

### ส่วนที่ ๑ การรายงานการฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

๑. ข้อมูลสถานประกอบกิจการที่เข้ารับการฝึกอบรม  
ชื่อสถานประกอบกิจการ..... โรงแรมแกรนด์ไฮแอทเอราวัณ.....  
ประเภทกิจการ..... โรงแรม.....  
ที่ตั้ง..... ๑๕๓..... ซอย..... มหาดเล็กหลวง๑..... ถนน..... ราชดำริ..... แขวง..... ลุมพินี.....  
เขต..... ปทุมวัน..... จังหวัด..... กรุงเทพมหานคร..... รหัสไปรษณีย์..... ๑๐๓๓๐.....  
โทรศัพท์..... ๐๒ - ๖๗๐ ๕๐๐๐..... โทรสาร..... ๐๒ - ๖๗๐ ๕๑๐๐.....
๒. วัน เดือน ปี ที่ฝึกอบรม..... ๕ ตุลาคม ๒๕๖๖.....
๓. จำนวนผู้เข้ารับการฝึกซ้อมดับเพลิง..... ๕๘..... คน หญิง..... ๒๖..... คน ชาย..... ๓๒..... คน
๔. จำนวนผู้เข้ารับการฝึกซ้อมอพยพหนีไฟ..... ๕๘..... คน หญิง..... ๒๖..... คน ชาย..... ๓๒..... คน
๕. ระยะเวลาในการฝึกซ้อมอพยพหนีไฟ..... ๗.๕๕..... นาที  
( เริ่มตั้งแต่สัญญาณอพยพหนีไฟดังขึ้น จนถึงคนสุดท้ายมาถึงจุด รวมพล )
๖. ชื่อวิทยากรผู้ดำเนินการฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ  
๖.๑..... สอ.ณัฏฐ์ พรหมเกสร..... ๖.๒..... นายศุภวิทย์ วังคะอ้อม.....  
๖.๓..... นายพรพล บุตติวงศ์..... ๖.๔..... -.....
๗. ชื่อผู้ดูแลการฝึกซ้อม  
๗.๑..... สอ.ณัฏฐ์ พรหมเกสร..... ๗.๒..... -.....  
๗.๓..... -..... ๗.๔..... -.....
- ลงชื่อ..... ( สอ.ณัฏฐ์ พรหมเกสร )..... ลงชื่อ..... ( นายประกอบ โพธิ์คาย ).....  
( สอ.ณัฏฐ์ พรหมเกสร )..... ( นายประกอบ โพธิ์คาย ).....
- พนักงานป้องกันและบรรเทาสาธารณภัยชำนาญงาน..... เจ้าพนักงานป้องกันและบรรเทาสาธารณภัยชำนาญงาน.....  
ผู้จัดทำรายงาน..... ( ได้รับมอบหมายจากผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย ).....  
วัน / เดือน / ปี ที่รายงาน..... ๖ ตุลาคม ๒๕๖๖.....  
รักษาการในตำแหน่งผู้อำนวยการกองปฏิบัติการดับเพลิงและกู้ภัย ๕.....  
สำนักป้องกันและบรรเทาสาธารณภัย.....

### ส่วนที่ ๒ การรับรอง

ข้าพเจ้าขอรับรองว่าได้มีการฝึกซ้อมดับเพลิงและหนีไฟตามรายละเอียดข้างต้นจริง

- ลงชื่อ..... วิทยาการ.....  
( สอ.ณัฏฐ์ พรหมเกสร )..... ( นายศุภวิทย์ วังคะอ้อม ).....
- ลงชื่อ..... วิทยาการ.....  
( นายพรพล บุตติวงศ์ )..... ( ).....
- ลงชื่อ..... นายจ้าง / เจ้าของสถานประกอบกิจการที่ได้รับการฝึกซ้อมดับเพลิงและฝึกซ้อมหนีไฟ.....  
( ..... ) หรือผู้มีอำนาจกระทำการแทน.....

บัญชีรายชื่อผู้เข้ารับการอบรมดับเพลิงขั้นต้น

โรงแรมแกรนด์ เซนเตอร์ พอยต์ ราชดำริ

วันที่ 5 ตุลาคม 2566

รายชื่อผู้เข้ารับการอบรม

ลำดับ	รายชื่อ	ตำแหน่ง	เจ้าภาพเทศบาล กิ่งอำเภอ	หมายเหตุ
1	นายอนนทร์ คงศิริพันธ์	General Manager		
2	นางสาวพรพิมล เจริญเสรีชัย	Executive Assistant Manager		
3	นางสาวปิยนดา วงศ์นคร	Inventory Supervisor		
4	นางสาว วิภาดา เปลี่ยนสมุทร	Sales Coordinator		
5	นาย อรรถนัย ไทยยืนวงษ์	Sales Coordinator		
6	นายอภิสิทธิ์ การเพียร	Duty Manager		
7	นางสาวจุฑาทิพย์ รักวิเศษ	Guest Service Supervisor		
8	นางสาวศิริลักษณ์ แสงประกายโชติ	Guest Service Executive		
9	นางสาวรณภา ปิ่นชัย	Guest Service Executive		
10	นายจิตติคุณ เสี่ยงบุญ	Bell Boy		
11	นายพรชัย ธรรมสาร	Bell Boy		
12	นางสาวอิสริยา เปรมสุวรรณ	Telephone Operator		
13	นางสาวสุพัตรา ขจรกลาง	Finance Officer		
14	นางพูนทรัพย์ ไชยอนันต์สวัสดิ์	Housekeeping Manager		
15	นางสาวสุนันท์ รัตนพันธ์	Assistant Housekeeper		
16	นางจิตติพร ทองมี	Assistant Housekeeper		
17	นายปิยะรัฐ ไชยโคตร	PCS		
18	นายณรงค์ สุวรรณกิจการ	Security Officer		
19	นายวันทา มีศรี	Security Officer		
20	นายธีระวัฒน์ เกษมจันศิริพันธ์	Security Officer		
21	นายโสภณ ยิ้มสวัสดิ์	Assistant Engineer Manager		
22	นายภิรมย์ ใจพรหม	Assistant Engineer Manager		
23	นายกังวาล ศรีอันเจน	Engineering Supervisor		
24	นายพนรัตน์ สัตตพลฤกษ์	Technician		
25	นายจตุพล พานุนทด	Technician		
26	นายจักรินทร สอนสัง	Technician		
27	นายกฤตชัย คุณรูป	Technician		
28	นายจีระพงษ์ สุขจิต	Carpenter		
29	นายอนัญพัทธ์ หักฉันทพิพย์	Recreation officer		
30	นายภาณุพงศ์ อินนาก	Recreation officer		
31	นางสาวกัณณา สุขอ่อน	ห้องอาหาร Bluespice		
32	นางสาววิลาสินี วรรณไวยาร	ห้องอาหาร Bluespice		
33	นางสาวจิตรลดาพร บุตรจิกร์	ห้องอาหาร Bluespice		
34	นายสราวุฒ ห้วยลึก	ห้องอาหาร Bluespice		
35	นายธนัฐ พันธุ์สุตร	ห้องอาหาร Bluespice		

ตั้งอยู่เลขที่ ๑๕๓ ซอยมหาดเล็กหลวง ๑ ถนนราชดำริ แขวงลุมพินี เขตปทุมวัน กรุงเทพฯ ๑๐๓๓๐



บัญชีรายชื่อผู้เข้ารับการอบรมดับเพลิงขั้นต้น  
โรงแรมแกรนด์ เซนเตอร์ พอยต์ ราชดำริ  
วันที่ 5 ตุลาคม 2566

37	นางสาวเจษฎาภรณ์ มุสิกมาตย์	ระรินจินดา		
38	นายพร เสือใหญ่	Security Officer		
39	นายพงษ์พัฒน์ บุคดา	IT Officer		
40	นางสาวจุฬาลักษณ์ ศักดิ์เพชร	ห้องอาหาร Bluespice		
41	นายสงกรานต์ มานะศรี	Banquet Officer		
42	นายอนุพาน ภูเก้าแก้ว	Banquet Officer		
43	นายพิรพล เจริญภักดิ์	ห้องอาหาร Bluespice		
44	นางสาวกิตติวลัย เสาร์ไชย	ห้องอาหาร Bluespice		

ผู้ชาย 27 คน ผู้หญิง 17 คน รวม 44 คน

ตรวจแล้วถูกต้อง



( ณิชภัทร พรหมเกสร )

พนักงานป้องกันและบรรเทาสาธารณภัยชำนาญงาน

บัญชีรายชื่อผู้เข้ารับการฝึกซ้อมดับเพลิงและซ้อมหนีไฟประจำปี 2566

โรงแรมแกรนด์ เซนเตอร์ พอยต์ ราชดำริ

วันที่ 5 ตุลาคม 2566

รายชื่อผู้เข้ารับการอบรม

ลำดับ	รายชื่อ	ตำแหน่ง	หมายเหตุ	
1	นายอนนทร์ คงศิริพันธ์	General Manager		
2	นางสาวพรพิมล เจริญเสรีชัย	Executive Assistant Manager		
3	นางสาวปิยนดา วงศ์นคร	Inventory Supervisor		
4	นางสาว วิภาดา เปลี่ยนสมุทร	Sales Coordinator		
5	นาย อรรถนัย ไทยอินวงษ์	Sales Coordinator		
6	นายอภิสิทธิ์ การเพียร	Duty Manager		
7	นางสาวจุฑาทิพย์ รักวิเศษ	Guest Service Supervisor		
8	นางสาวศิริรักษ์ แสงประกายโชติ	Guest Service Executive		
9	นางสาวรณภา ปิ่นชัย	Guest Service Executive		
10	นายจิตติคุณ เสี่ยงบุญ	Bell Boy		
11	นายพรชัย ธรรมสาร	Bell Boy		
12	นางสาวรมย์วี คำพรรณ	Telephone Operator		
13	นางสาวสุพัตรา ขจรกลาง	Finance Officer		
14	นางสาวแกงป้อ แสนสากัน	Finance Officer		
15	นางสาวศิวารรณ นาคะ	Finance Officer		
16	นางพูนทรัพย์ ไชยอนันต์สวัสดิ์	Housekeeping Manager		
17	นางจิตติพร ทองมี	Assistant Housekeeper		
18	นางวีณา พรหมประสิทธิ์	Assistant Housekeeper		
19	นางสาวกุสุมา จากผา	Assistant Housekeeping Manager		
20	นางทุเรียน เจริญถัมภ์	Assistant Housekeeper		
21	นางสาวกฤษรา นันทา	Assistant Housekeeping Manager		
22	นายอิสระ ประทุมรัตน์	Assistant Housekeeper		
23	นางสาวมะลิ สุขสวรรค์	Assistant Housekeeper		
24	นางสาวเบญจรัตน์ ภูระวรรณ	Assistant Housekeeper		
25	นางสาวชลมาศ หับทิมโต	Assistant Housekeeper		
26	นางสาวก่องทรัพย์ สมศรี	Assistant Housekeeper		
27	นางสาวสุนันท์ รัตนพันธ์	Assistant Housekeeper		
28	นายณวัฒน์ สุวรรณกิจการ	Security Officer		
29	นายชัยรัตน์ อนันตะสุข	Security Officer		
30	นายวันทา มีศรี	Security Officer		
31	นายธีระวัฒน์ เกยมจินศิรินนท์	Security Officer		
32	นายพัศกร ไชระเวก	Cluster Engineer Manager		
33	นายโสภณ ชัยสวัสดิ์	Assistant Engineer Manager		
34	นายภิรมย์ ใจพรหม	Assistant Engineer Manager		
35	นายกังวาล ศรีอันเจน	Engineering Supervisor		

7763-

บัญชีรายชื่อผู้เข้ารับการฝึกซ้อมดับเพลิงและซ้อมหนีไฟประจำปี 2566

โรงแรมแกรนด์ เซนเตอร์ พอยต์ ราชดำริ

วันที่ 5 ตุลาคม 2566

รายชื่อผู้เข้ารับการอบรม

36	นายสิทธิชัย ถนอมศักดิ์	Senior Technician		
37	นายสุวิทย์ พิมพ์	Senior Technician		
38	นายเอนก หัสบุตร	Technician		
39	นายทวีศักดิ์ โตทา	Technician		
40	นายวันเฉลิม วุฒิเจลา	Technician		
41	นายพูนศักดิ์ ชนะแสง	Technician		
42	นายภาสกร เชี่ยวเวช	Technician		
43	นายพนรัตน์ สิตลพฤกษ์	Technician		
44	นายจตุพล พาชุนทด	Technician		
45	นายจักรินทร์ สอนสัง	Technician		
46	นายกฤตชัย คุณรูป	Technician		
47	นายพยมพัฒน์ นุดดา	IT Officer		
48	นายอนันต์พัทธ์ ทักษิณาทิพย์	Recreation officer		
49	นายภาณุพงศ์ อินนาก	Recreation officer		
50	นางสาวมินตรา มงคลสุภา	ห้องอาหาร Bluespice		
51	นางสาววิลาสินี วรรณโวหาร	ห้องอาหาร Bluespice		
52	นางสาวจิตรลดาพร บุตรจิจักร์	ห้องอาหาร Bluespice		
53	นายสราวุฒิ ห้วยลึก	ห้องอาหาร Bluespice		
54	นางสาวจุฑาทิพย์ หนูไพล	ห้องอาหาร Bluespice		
55	นายธวัช พันธ์สุตร	ห้องอาหาร Bluespice		
56	นายจารุพงษ์ กลั่นสุวรรณ	ห้องอาหาร Bluespice		
57	นายสุภัค ทองยา	ห้องอาหาร Bluespice		
58	นางสาวเจนุภากรณ์ มูลมาตร	ระรินจินดา		

ผู้ชาย 32 คน ผู้หญิง 26 คน รวม 58 คน

ตรวจแล้วถูกต้อง



( ณิชภัทร พรหมเกสร )

พนักงานป้องกันและบรรเทาสาธารณภัยชำนาญงาน



## การรายงานสรุปผลการจัดฝึกอบรมการดับเพลิงขั้นต้น

เขียนที่ สถานีดับเพลิงและกู้ภัยปากคลองสาน

วันที่ ๖ เดือน ตุลาคม พ.ศ. ๒๕๖๖

## ส่วนที่ ๑ ข้อมูลผู้รับใบอนุญาต

ชื่อผู้รับใบอนุญาต กรุงเทพมหานคร (สำนักป้องกันและบรรเทาสาธารณภัย)

เลขทะเบียนนิติบุคคล ๐-๙๙๙๙๐-๐๐๐๑๖๐-๑๕-๑

ใบอนุญาตเลขที่ ดพต.ร๒๐๒ วันอนุญาต ๑๑ พฤษภาคม ๒๕๖๔ วันหมดอายุ ๑๐ พฤษภาคม ๒๕๖๗

ตั้งอยู่ เลขที่ ๑๓๓ หมู่ที่ ๑ ตรอก/ซอย - ถนน ดินสอ แขวง/ตำบล เสาชิงช้า เขต/อำเภอ พระนคร

จังหวัด กรุงเทพมหานคร รหัสไปรษณีย์ ๑๐๒๐๐ โทรศัพท์ ๐-๒๒๗๙ ๗๓๐๓ โทรสาร ๐-๒๒๗๙ ๗๓๐๔

E-mail fireinspectionbma@gmail.com

## ส่วนที่ ๒ การดำเนินการจัดฝึกอบรมการดับเพลิงขั้นต้น

สถานที่จัดฝึกอบรม (ภาคทฤษฎี) โรงแรมแกรนด์ เซนเตอร์ พอยต์ ราชดำริ

ตั้งอยู่ เลขที่ ๑๕๓ หมู่ที่ ๑ - ตรอก/ซอย มหาตมเล็กหลวง ๑ ถนน ราชดำริ

แขวง/ตำบล ลุมพินี เขต/อำเภอ ปทุมวัน จังหวัด กรุงเทพฯ

รหัสไปรษณีย์ ๑๐๓๓๐ โทรศัพท์ - โทรสาร -

สถานที่จัดฝึกอบรม (ภาคปฏิบัติ) โรงแรมแกรนด์ เซนเตอร์ พอยต์ ราชดำริ

ตั้งอยู่ เลขที่ ๑๕๓ หมู่ที่ ๑ - ตรอก/ซอย มหาตมเล็กหลวง ๑ ถนน ราชดำริ

แขวง/ตำบล ลุมพินี เขต/อำเภอ ปทุมวัน จังหวัด กรุงเทพฯ

รหัสไปรษณีย์ ๑๐๓๓๐ โทรศัพท์ - โทรสาร -

## ส่วนที่ ๓ เอกสารหรือหลักฐานที่ต้องแนบ ดังนี้

๑. สำเนาแบบแจ้งกำหนดการจัดฝึกอบรมการดับเพลิงขั้นต้น (แบบ ภก.จ.๑)

๒. รายชื่อผู้ผ่านการฝึกอบรม

๓. รายชื่อวิทยากร (ภาคทฤษฎีและภาคปฏิบัติ)



(ถ้ามี)

ลงชื่อ (นายธีรยุทธ ภูมิภักดิ์) ผู้รับใบอนุญาต

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย

วันที่ ๖ เดือน ๑๐ พ.ศ. ๒๕๖๖

หมายเหตุ ๑. กรณีเป็นนิติบุคคลที่มีหนังสือรับรองนิติบุคคลให้ประทับตรา จะต้องมีการประทับพร้อมลงนาม

๒. ให้รายงานสรุปผลการให้บริการจัดฝึกอบรมการดับเพลิงขั้นต้น ให้แจ้งตามแบบ ภก.รง.๑ ต่อการให้บริการ ๑ ครั้ง ทั้งนี้ ภายใน ๓๐ วันนับแต่วันที่เสร็จสิ้นการให้บริการ



## รายงานสรุปผลการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

เขียนที่ สถานีดับเพลิงและกู้ภัยปากคลองสาน

วันที่ ๖ เดือน ตุลาคม พ.ศ. ๒๕๖๖

## ส่วนที่ ๑ ข้อมูลผู้รับใบอนุญาต

ชื่อผู้รับใบอนุญาต กรุงเทพมหานคร (สำนักป้องกันและบรรเทาสาธารณภัย)

เลขทะเบียนนิติบุคคล ๐-๙๙๙๐-๐๐๑๖๐-๑๕-๑

ใบอนุญาตเลขที่ ดพฝ-ร๒๐๒ วันอนุญาต ๑๑ พฤษภาคม ๒๕๖๕ วันหมดอายุ ๑๐ พฤษภาคม ๒๕๖๗

ตั้งอยู่ เลขที่ ๑๗๓ หมู่ที่ ๑ ตรอก/ซอย - ถนน ดินสอ แขวง/ตำบล เสาชิงช้า เขต/อำเภอ พระนคร

จังหวัด กรุงเทพมหานคร รหัสไปรษณีย์ ๑๐๒๐๐ โทรศัพท์ ๐-๒๒๗๙ ๗๓๐๓ โทรสาร ๐-๒๒๗๙ ๗๓๐๔

E-mail fireinspectionbma@gmail.com

ส่วนที่ ๒ การดำเนินการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ (ทำเครื่องหมาย ✓ ในช่อง ☐)☒ กรณีสถานประกอบกิจการเดียว ชื่อสถานประกอบกิจการ โรงแรมแกรนด์ เซนเตอร์ พอยต์ ราชดำริ

ประเภทกิจการ โรงแรม

ตั้งอยู่เลขที่ ๑๕๓ หมู่ที่ ๑ ตรอก/ซอย มหาตมเล็กหลวง ๑ ถนน ราชดำริ

แขวง/ตำบล ลุมพินี เขต/อำเภอ ปทุมวัน จังหวัด กรุงเทพฯ

รหัสไปรษณีย์ ๑๐๓๓๐ โทรศัพท์ - โทรสาร - E-mail -

ลูกจ้างทั้งหมด จำนวน ๗๒ คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน ๕๘ คน

☐ กรณีสถานที่ที่มีหลายสถานประกอบกิจการตั้งอยู่รวมกัน

ระบุชื่ออาคาร/สถานที่

ตั้งอยู่เลขที่ ๑๕๓ หมู่ที่ ๑ ตรอก/ซอย ถนน

แขวง/ตำบล เขต/อำเภอ จังหวัด

รหัสไปรษณีย์ โทรศัพท์ โทรสาร E-mail

สถานประกอบกิจการที่เข้าร่วมทั้งหมด จำนวน แห่ง ประกอบด้วย

๑. ชื่อสถานประกอบกิจการ

ลูกจ้างทั้งหมด จำนวน คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน คน

๒. ชื่อสถานประกอบกิจการ

ลูกจ้างทั้งหมด จำนวน คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน คน

๓. ชื่อสถานประกอบกิจการ

ลูกจ้างทั้งหมด จำนวน คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน คน

(กรณีมีสถานประกอบกิจการเข้าร่วมฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟหลายแห่ง สามารถเพิ่มข้อมูลหรือจัดทำเอกสารแนบเพิ่มเติมได้)

ดำเนินการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ เมื่อวันที่ ๕ เดือน ตุลาคม พ.ศ. ๒๕๖๖

ส่วนที่ ๓ เอกสารหรือหลักฐานที่ต้องแนบ ดังนี้

๔. สำเนาแบบแจ้งกำหนดการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ (แบบ กภ.จ.๒)
๕. รายชื่อวิทยากร
๖. รายละเอียดและผลการประเมินการฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ



(ถ้ามี)

ลงชื่อ..... (นายธีรยุทธ ภูมิภักดิ์) ..... ผู้รับใบอนุญาต  
ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย  
วันที่ ๑๖ เดือน ..... ค.ศ. ..... พ.ศ. ๒๕๖๖

หมายเหตุ ๑. กรณีเป็นนิติบุคคลที่มีหนังสือรับรองนิติบุคคลให้ประทับตรา จะต้องมีการประทับพร้อมลงนาม  
๒. ให้รายงานสรุปผลการให้บริการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ ตามแบบ แบบ กภ.  
รง.๒ ต่อการให้บริการ ๑ ครั้ง ทั้งนี้ ภายใน ๓๐ วันนับแต่วันที่เสร็จสิ้นการให้บริการ

กำหนดการอบรมดับเพลิงขั้นต้น  
 โรงแรมแกรนด์ เซนเตอร์ พอยท์ ราชดำริ  
 เลขที่ ๑๕๓ ซอยมหาดเล็กหลวง ๑ ถนนราชดำริ แขวงลุมพินี เขตปทุมวัน กรุงเทพฯ ๑๐๓๓๐  
 วันที่ ๕ ตุลาคม ๒๕๖๖

เวลา	รายการฝึกอบรม	วิทยากร
๐๙.๐๐ - ๑๒.๐๐ น.	อบรมหลักการดับเพลิงขั้นต้น ภาคทฤษฎี ๑. ความรู้ด้านอัคคีภัยและสาเหตุเพลิงไหม้ ๒. ความรู้ด้านอุปกรณ์ดับเพลิงขั้นต้น และหลักการดับเพลิง ๓. ความรู้ด้านแผนและการวางแผนปฏิบัติการ ๔. หลักการปฐมพยาบาลเบื้องต้น	สอ.ณัฏภัทร พรหมเกศร (ผู้ควบคุมการฝึก)  นายพรพล บุตติวงศ์
๑๖.๐๐ - ๑๖.๓๐ น.	สาธิตการใช้อุปกรณ์ดับเพลิงขั้นต้น และการใช้สายฉีดน้ำดับเพลิง ภาคปฏิบัติ	สอ.ณัฏภัทร พรหมเกศร นายพรพล บุตติวงศ์

รายชื่อวิทยากร

หน่วยงานอบรม : กรุงเทพมหานคร ใบอนุญาต ดพต.-ร๒๐๒

ลำดับ	ชื่อ - สกุล	หัวข้ออบรม	สังกัด	หมายเลขบัตรประชาชน
๓๖๕	สอ.ณัฏภัทร พรหมเกศร	ภาคทฤษฎี/ปฏิบัติ	ปากคลองสาน	๑ ๑๐๑๔ ๙๙๑๐๕ ๑๐๗
๖	นายพรพล บุตติวงศ์	ภาคปฏิบัติ	สนง.ยุทธศาสตร์	๑ ๑๐๑๔ ๙๙๑๐๕ ๑๐๗

แผนที่สถานที่ฝึกอบรมบริษัท

เลขที่ ๑๕๓ ซอยมหาดเล็กหลวง ๑ ถนนราชดำริ แขวงลุมพินี เขตปทุมวัน กรุงเทพฯ ๑๐๓๓๐





กำหนดการฝึกซ้อมดับเพลิงและซ้อมหนีไฟประจำปี  
โรงแรมแกรนด์ เซนเตอร์ พอยท์ ราชดำริ  
เลขที่ ๑๕๓ ซอยมหาดเล็กหลวง ๑ ถนนราชดำริ แขวงลุมพินี เขตปทุมวัน กรุงเทพฯ ๑๐๓๓๐  
วันที่ ๕ ตุลาคม ๒๕๖๖

เวลา	รายการฝึกอบรม	วิทยากร
๑๓.๐๐ – ๑๕.๓๐ น.	อบรมทบทวนด้านการฝึกซ้อมดับเพลิงและซ้อมหนีไฟ ๕. แผนการดับเพลิงขั้นต้นและขั้นรุนแรง ๖. แผนการอพยพหนีไฟ และหลักการอพยพหนีไฟที่ปลอดภัย ๗. แผนการช่วยเหลือผู้ประสบเหตุ ๘. หลักการปฐมพยาบาลเบื้องต้น	สอ.ณัฏภัทร พรหมเกศร (ผู้ควบคุมการฝึก)  นายพรพล บุตติวงศ์
๑๕.๓๐ – ๑๖.๐๐ น.	จำลองสถานการณ์การฝึกซ้อมดับเพลิงและซ้อมหนีไฟในสถานที่จริง	สอ.ณัฏภัทร พรหมเกศร นายพรพล บุตติวงศ์

**รายชื่อวิทยากร**

หน่วยงานอบรม : กรุงเทพมหานคร ใบอนุญาต ดพฝ.-ร๒๐๒

ลำดับ	ชื่อ – สกุล	หัวข้ออบรม	สังกัด	หมายเลขบัตรประชาชน
๓๖๕	สอ.ณัฏภัทร พรหมเกศร	ภาคทฤษฎี/ปฏิบัติ	ปากคลองสาน	๑ ๑๐๑๔ ๙๙๑๐๕ ๑๐๗
๖	นายพรพล บุตติวงศ์	ภาคปฏิบัติ	สนง.ยุทธศาสตร์	๑ ๑๐๑๔ ๙๙๑๐๕ ๑๐๗

**แผนที่สถานที่ฝึกอบรมบริษัท**

เลขที่ ๑๕๓ ซอยมหาดเล็กหลวง ๑ ถนนราชดำริ แขวงลุมพินี เขตปทุมวัน กรุงเทพฯ ๑๐๓๓๐



ภาคผนวก ข9

เอกสารการปฏิบัติตามข้อกำหนดในประกาศกรมอนามัย  
ข้อปฏิบัติการควบคุมเชื้อลิจิโอเนลลาในหอฝึ่งเย็นของอาคาร

---

## Analysis/Test Report

**Customer Name :** CENTERLISE CO.,LTD.

**Address :** 45 Soi Sukhumvit 23 (Prasarnmit), Sukhumvit Road, Khlong Toei Nuay, Wattana, Bangkok. 10110

**Sampling Site :** Grande Centre Point Hotel (Ratchadamri)

**Sample Type :** Cooling Water

**Sampling by :** Customer

**Sampling Method :** Grab

**Sampling Date :** 05/03/2024

**Sampling Time :** -

**Received Date :** 07/03/2024

**Analytical Date :** 07 - 18/03/2024

**Report Date :** 19/03/2024

**Report No. :** RS05479/67

Parameters	Unit	Method	TS05069 /67
			Cooling Water
Legionella spp.	CFU/L	ISO 11731 : 2017	not detected
Sample Condition		Observation	Light Yellow, Clear

Miss NISACHOL EUNGKLIENG

Analyst

19/03/2024



Miss ORASA YUBUA

Technical Manager

19/03/2024

Reported results refer to the sample as received only.

Test report shall not be reproduced except in full, without written approved of the laboratory.

The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025

ภาคผนวก ข10

เอกสารการตรวจสอบอุปกรณ์ที่ใช้ระบายอากาศ

---



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 19/1/67

AHU NO....L1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

AHU NO....F2...

MONTH 29/1/67

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun, Sep, Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

COMMENT .....

RECORD BY ..... 

RECHECK BY ..... 

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 29/1/67

AHU NO....L3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 29/1/67

AHU NO....M1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANING      A = ADJUST&ADDED  
 R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 29/1/67

AHU NO....M2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Belt					✓	
	5	Check Bearing					✓	
	6	Check&Cleaned Frame					✓	
	7	Check & Fitting Support					✓	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANING      A = ADJUST&ADDED  
 R = REPAIR      P = REPLACED

NOTE .....

.....


.....

.....

COMMENT .....

.....

.....

RECORD BY RECHECK BY 

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 29/1/67

AHU NO....M3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Belt					✓	
	5	Check Bearing					✓	
	6	Check&Cleaned Frame					✓	
	7	Check & Fitting Support					✓	
3 Month Mar,Jun,Sep,Dce	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ...

RECHECK BY



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 99/11/67

AHU NO....L2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 29/1/67

AHU NO....F1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY ... RECHECK BY ... 

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 8/11/67.....

AHU NO....4-1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....



.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 8/1/07.....

AHU NO....4-2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ...

RECHECK BY ...

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/2/67

AHU NO....L1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/2/67

AHU NO....L2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun, Sep, Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/2/67

AHU NO....L3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/9/67

AHU NO....M1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/2/67

AHU NO....M2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/02/07

AHU NO....4-1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/02/07.....

AHU NO....4-2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 23/2/67

AHU NO....F1...

TIME .....

TIME	ITEM	ION MAIN	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control						
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Belt					✓	
	5	Check Bearing					✓	
	6	Check&Cleaned Frame					✓	
	7	Check & Fitting Support					✓	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING


A = ADJUST&ADDED

R = REPAIR

P = REPLACED

RE .....

MENT .....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 2/67

AHU NO....F2...

TIME .....

TIME	ITEM	ION MAIN	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control						
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Belt					✓	
	5	Check Bearing					✓	
	6	Check&Cleaned Frame					✓	
	7	Check & Fitting Support					✓	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

TE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 20/3/67

AHU NO....L1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY .....

RECHECK BY .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 8/18/16

AHU NO....L2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Belt					✓	
	5	Check Bearing					✓	
	6	Check&Cleaned Frame					✓	
	7	Check & Fitting Support					✓	
3 Month Mar,Jun, Sep, Dec	8	Cleanning Air Grill Return & Supply	✓					
	9	Tighting All Bolt/Nut Motor & Blower					✓	
	10	Cleanning Motor & Blower	✓				✓	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 21/8/67

AHU NO....L3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/				/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 19/8/67.....

AHU NO....M1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun, Sep, Dec	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/				/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY XXXXXXXXXX.....RECHECK BY XXXXXXXXXX.....



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 13/8/17.....

AHU NO....M2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/				/	
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED].....

RECHECK BY [REDACTED].....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 25/8/67.....

AHU NO....F1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 9/8/62

AHU NO....F2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH ..... 4/67 .....

AHU NO....L1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY ..... [REDACTED] .....

RECHECK BY ..... [REDACTED] .....




# GRANDE CENTRE POINT RATCHADAMRI MONTHLY REPORT

SYSTEM & SAFETY

AHU NO. L-1 Model: CLCP012 Serial: 310403-725921

DATE 24/4/67

ตรวจเช็คผลวัดลมก่อนล้างคอยล์แอร์ AHU



Remark

$$559 \div 8 = 69.88 \text{ ft/min} \times 10$$


$$278 \times 4.42 = 12.29 \text{ ft}^2$$

$$12.29 \times 69.88 = 858.82 \text{ ft}^3/\text{min} \times 10$$

$$858.82 \times 10 = 8,588.2 \text{ ft}^3/\text{min}$$

$$\text{CFM} = 8,588.2 \text{ ft}^3/\text{min}$$

ตรวจเช็คผลวัดลมหลังล้างคอยล์แอร์ AHU



Remark

$$691 \div 8 = 86.37 \text{ ft/min} \times 10$$

$$278 \times 4.42 = 12.29 \text{ ft}^2$$

$$12.29 \times 86.37 = 1,061.48 \text{ ft}^3/\text{min} \times 10$$

$$1,061.48 \times 10 = 10,614.8 \text{ ft}^3/\text{min}$$

$$\text{CFM} = 10,614.8 \text{ ft}^3/\text{min}$$

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 4/67

AHU NO....L2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY : RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/67

AHU NO....L3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
3 Month Mar,Jun,Sep,Dec	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....


.....


.....

COMMENT .....

.....

.....

RECORD BY  .....

RECHECK BY  .....



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 4/67

AHU NO....M1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&amp;ADDED

R = REPAIR P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY ..... RECHECK BY ..... 



# GRANDE CENTRE POINT RATCHADAMRI MONTHLY REPORT

## SYSTEM & SAFETY

AHU NO M-1 Model : GLCP016 Serial : JT1106-716570

DATE 25/4/67

ตรวจเช็คผลวัดลมก่อนล้างคอยล์แอร์ AHU



Remark


$$492 \div 8 = 61.50 \text{ ft/min} \times 10 \text{ CFM} = 10,461.1 \text{ ft}^3/\text{min}$$

$$4.43 \times 3.84 = 17.01 \text{ ft}^2$$

$$17.01 \times 61.50 = 1,046.11 \text{ ft}^3/\text{min} \times 10$$

$$1,046.11 \times 10 = 10,461.1 \text{ ft}^3/\text{min} \text{ (CFM)}$$

ตรวจเช็คผลวัดลมหลังล้างคอยล์แอร์ AHU



Remark

$$528 \div 8 = 66 \text{ ft/min} \times 10 \text{ CFM} = 11,226.6 \text{ ft}^3/\text{min}$$

$$4.43 \times 3.84 = 17.01 \text{ ft}^2$$

$$17.01 \times 66 = 1,122.66 \text{ ft}^3/\text{min} \times 10$$

$$1,122.66 \times 10 = 11,226.6 \text{ ft}^3/\text{min} \text{ (CFM)}$$

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH ....4/67.....

AHU NO....M2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY .....

RECHECK BY .....

# GRANDE CENTRE POINT RATCHADAMRI

## MONTHLY REPORT

### SYSTEM & SAFETY

AHU NO ... ๓๖ Model : LCP016 Serial : 571102-71571

DATE ๒๕/๔/๖๗

ตรวจเช็คผลวัดลมก่อนล้างคอยล์แอร์ AHU

58	69	70	65	ft/min
53	58	59	59	ft/min

### Remark

$491 \div 9 = 54.57 \text{ ft/min} \times 10$   
 $4.43 \times 3.84 = 17.01 \text{ ft}^2$   
 $17.01 \times 1.57 = 1043.90 \text{ ft}^3/\text{min} \times 10$   
 $1043.90 \times 10 = 10439 \text{ ft}^3/\text{min (CFM)}$   
 $\text{CFM} = 10439 \text{ ft}^3/\text{min}$

ตรวจเช็คผลวัดลมหลังล้างคอยล์แอร์ AHU

63	73	73	68	ft/min
60	65	65	60	ft/min

### Remark

$527 \div 9 = 58.57 \text{ ft/min} \times 10$   
 $4.43 \times 3.84 = 17.01 \text{ ft}^2$   
 $17.01 \times 1.57 = 1043.90 \text{ ft}^3/\text{min} \times 10$   
 $1043.90 \times 10 = 10439 \text{ ft}^3/\text{min (CFM)}$   
 $\text{CFM} = 10439 \text{ ft}^3/\text{min}$



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/67

AHU NO....M3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<input checked="" type="checkbox"/>	
		Cleanning Overall Inside Panel Control	<input checked="" type="checkbox"/>					
		Fitting All Inside Panel Control					<input checked="" type="checkbox"/>	
		Testing Overload					<input checked="" type="checkbox"/>	
	2	Check Operation					<input checked="" type="checkbox"/>	
	3	Check Motor& Blower					<input checked="" type="checkbox"/>	
	4	Check Belt					<input checked="" type="checkbox"/>	
	5	Check Bearing					<input checked="" type="checkbox"/>	
	6	Check&Cleaned Frame	<input checked="" type="checkbox"/>					
	7	Check & Fitting Support					<input checked="" type="checkbox"/>	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....


COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH .....4/.....

AHU NO....4-1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/67 .....

AHU NO....4-2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED

R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 4/67

AHU NO....F2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control					/	
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY .....

RECHECK BY .....

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/62

AHU NO....F1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control					/	
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED

R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH .....5/67.....

AHU NO....L1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/67

AHU NO....L2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 5/67.....

AHU NO....L3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 5/67.....

AHU NO....M1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
3 Month Mar,Jun,Sep,Dec	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY .  .....RECHECK BY  .....



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 5/67

AHU NO....M2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/67

AHU NO....M3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/67.....

AHU NO....4-1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....


.....


COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/67

AHU NO....4-2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....


.....


.....

COMMENT .....

.....

.....

RECORD BY 

RECHECK BY 



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/67

AHU NO....F1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH .. 5/6/7 .....

AHU NO....F2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY .. [REDACTED] .....

RECHECK BY [REDACTED]

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/5/6/67

AHU NO....L1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/				/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE หม้อลม 1 ใบ

COMMENT .....

RECORD BY

RECHECK BY

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 18/6/67.....

AHU NO....L2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH ..... 6/67

AHU NO....L3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Belt					✓	
	5	Check Bearing					✓	
	6	Check&Cleaned Frame	✓					
3 Month Mar,Jun,Sep,Dec	7	Check & Fitting Support					✓	
	8	Cleanning Air Grill Return & Supply	✓					
	9	Tighting All Bolt/Nut Motor & Blower					✓	
	10	Cleanning Motor & Blower					✓	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ..... [REDACTED]

RECHECK BY ..... [REDACTED]

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 8/6/67

AHU NO....M1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/				/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 8/6/67

AHU NO....M2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt						/
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sept,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE

การทำความสะอาดคอยล์และพัดลม

COMMENT

RECORD BY

RECHECK BY



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH ...6/67.....

AHU NO....M3...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED]



GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH ...6/67.....

AHU NO....4-1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower	/					

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/67

AHU NO....4-2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<input checked="" type="checkbox"/>	
		Cleanning Overall Inside Panel Control	<input checked="" type="checkbox"/>					
		Fitting All Inside Panel Control					<input checked="" type="checkbox"/>	
		Testing Overload					<input checked="" type="checkbox"/>	
	2	Check Operation					<input checked="" type="checkbox"/>	
	3	Check Motor& Blower					<input checked="" type="checkbox"/>	
	4	Check Belt					<input checked="" type="checkbox"/>	
	5	Check Bearing					<input checked="" type="checkbox"/>	
	6	Check&Cleaned Frame	<input checked="" type="checkbox"/>					
	7	Check & Fitting Support					<input checked="" type="checkbox"/>	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	<input checked="" type="checkbox"/>					
	9	Tighting All Bolt/Nut Motor & Blower					<input checked="" type="checkbox"/>	
	10	Cleanning Motor & Blower	<input checked="" type="checkbox"/>					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY .....

RECHECK BY .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 10/6/67

AHU NO....F1...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

COMMENT .....

RECORD BY

RECHECK BY



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 12/6/67

AHU NO....F2...

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame	/					
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower					/	
	10	Cleanning Motor & Blower					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

RECORD BY ..

RECHECK BY ..



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....L....

MONTH .....1/67.....  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ...

RECHECK BY ..

## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST MOTOR FAN(KITCHEN)MONTH 29/01/2024

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame	/				/	
3 Month Mar,Jun,Sep,Dec	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

COMMENT .....

RECORD BY ..

RECHECK BY ..

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....7....

MONTH .....1/67.....  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
Mar,Jun, Sep,Dec	8	Cleanning Air Grill Return & Supply						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....  
.....  
.....

COMMENT .....

.....  
.....  
.....

RECORD BY ....

RECHECK BY ....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....L....

MONTH 23/8/67  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....


.....

.....

COMMENT .....

.....

.....

RECORD BY 

RECHECK BY 



## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 23/2/67

SMOKE EXHAUST FAN ...M1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Timer Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Bearing					✓	
	5	Check&Cleaned Frame					✓	
	6	Check & Fitting Support					✓	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

EXHAUST MOTOR FAN(KITCHEN)

MONTH 23/9/67.....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun, Sep, Dec	5	Check&Cleared Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....


.....

.....

COMMENT .....

.....

.....

RECORD BY RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....7....

MONTH 4/67  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<u>/</u>	
		Cleanning Overall Inside Panel Control	<u>/</u>					
		Fitting All Inside Panel Control					<u>/</u>	
		Testing Overload					<u>/</u>	
	2	Check Motor& Blower					<u>/</u>	
	3	Check Belt					<u>/</u>	
	4	Check Bearing					<u>/</u>	
3 Month <small>Mar,Jun,Sep,Dec</small>	5	Check&Cleaned Frame	<u>/</u>					
	6	Tighting All Bolt/Nut Motor & Blower					<u>/</u>	
	7	Check & Fitting Support					<u>/</u>	
	8	Cleanning Air Grill Return & Supply	<u>/</u>					

N = NORMAL      AB = ABNORMAL      C = CLEANING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

COMMENT .....

.....

.....

RECORD BY                     

RECHECK BY

## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

EXHAUST MOTOR FAN(KITCHEN)

MONTH 3/67

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					<input checked="" type="checkbox"/>	
		Cleanning Overall Inside Panel Control	<input checked="" type="checkbox"/>					
		Fitting All Inside Panel Control					<input checked="" type="checkbox"/>	
		Testing Overload					<input checked="" type="checkbox"/>	
	2	Check Motor& Blower					<input checked="" type="checkbox"/>	
	3	Check Belt					<input checked="" type="checkbox"/>	
	4	Check Bearing					<input checked="" type="checkbox"/>	
3 Month Mar,Jun,Sept,Dec	5	Check&Cleaned Frame	<input checked="" type="checkbox"/>					
	6	Tighting All Bolt/Nut Motor & Blower					<input checked="" type="checkbox"/>	
	7	Check & Fitting Support					<input checked="" type="checkbox"/>	
	8	Cleanning Air Grill Return & Supply	<input checked="" type="checkbox"/>					

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....


.....

.....

COMMENT .....

.....

.....

RECORD BY RECHECK BY 



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....L....

MONTH 9/67  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Motor& Blower					✓	
	3	Check Belt					✓	
	4	Check Bearing					✓	
	5	Check&Cleared Frame	✓					
3 Month <small>Mar,Jun,Sep,Dec</small>	6	Tighting All Bolt/Nut Motor & Blower					✓	
	7	Check & Fitting Support					✓	
	8	Cleanning Air Grill Return & Supply	✓					

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....L....

MONTH 18.04.07.....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month <small>Mar,Jun,Sep,Dec</small>	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower					/	
	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

EXHAUST MOTOR FAN(KITCHEN)

MONTH 16.09.07

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower					/	
	7	Check & Fitting Support					/	
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

COMMENT .....

RECORD BY .....

RECHECK BY .....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....7....

MONTH ..18.04.07.....  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower					/	
	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply	/					

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ...

RECHECK BY



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....L....

MONTH 19/5/67  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month <small>Mar,Jun,Sep,Dec</small>	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ...  ...

RECHECK BY  .....

## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

EXHAUST MOTOR FAN(KITCHEN)

MONTH 5/67

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control						
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun, Sep,Dec	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....7....

MONTH 5/67.....  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<u>/</u>	
		Cleanning Overall Inside Panel Control	<u>/</u>					
		Fitting All Inside Panel Control					<u>/</u>	
		Testing Overload					<u>/</u>	
	2	Check Motor& Blower					<u>/</u>	
	3	Check Belt					<u>/</u>	
	4	Check Bearing					<u>/</u>	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					<u>/</u>	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						


N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....  
.....  
.....

COMMENT .....

.....  
.....  
.....

RECORD BY  .....

RECHECK BY  .....

GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN....L....

MONTH ..... 6/07 .....  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sept,Dec	5	Check&Cleaned Frame	/					
	6	Tighting All Bolt/Nut Motor & Blower					/	
	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY

RECHECK BY



## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

EXHAUST MOTOR FAN(KITCHEN)

MONTH 6/67

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

COMMENT .....

.....

RECORD BY



RECHECK BY



GRANDE CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY  
EXHAUST FAN.7....

MONTH ..... 6/87 .....  
TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun, Sep,Dec	5	Check&Cleaned Frame	/					
	6	Tighting All Bolt/Nut Motor & Blower					/	
	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply	/				/	

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED]

RECHECK BY [REDACTED]

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 1/67 .....

PRESSURIZE FAN 1

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame	/					
	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY ..... [REDACTED] .....

RECHECK BY ..... [REDACTED] .....

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 1/67

PRESSURIZE FAN 2

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame	/					
	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY ...  .....

RECHECK BY ....  .....



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 10/02/67

PRESSURIZE FAN 1

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame	/				/	
	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Dampers						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY .....

RECHECK BY .....

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 10/02/01

PRESSURIZE FAN 2

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame	/				/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 17/8/68

PRESSURIZE FAN 2

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return					/	
	8	Cleanning Relief Damper	/					
	9	Cleanning Supply Damperes	/					
	10	Added Grease The Damper Motordrive					/	

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 12/3/67

PRESSURIZE FAN 1

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return					/	
	8	Cleanning Relief Damper	/					
	9	Cleanning Supply Damperes	/					
	10	Added Grease The Damper Motordrive					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....



# GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 06.04.07.....

PRESSURIZE FAN 1

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame	/					
3 Month Mar,Jun, Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	8	Cleanning Relief Damper	/					
	9	Cleanning Supply Damperes	/					
	10	Added Grease The Damper Motordrive					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 21.04.07

PRESSURIZE FAN 2

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame	/					
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	8	Cleanning Relief Damper	/					
	9	Cleanning Supply Damperes	/					
	10	Added Grease The Damper Motordrive					/	

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 6/5/67.....

PRESSURIZE FAN 1

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<input checked="" type="checkbox"/>	
		Cleanning Overall Inside Panel Control	<input checked="" type="checkbox"/>					
		Fitting All Inside Panel Control					<input checked="" type="checkbox"/>	
		Testing Overload					<input checked="" type="checkbox"/>	
	2	Check Timer Operation					<input checked="" type="checkbox"/>	
	3	Check Motor& Blower					<input checked="" type="checkbox"/>	
	4	Check Bearing					<input checked="" type="checkbox"/>	
	5	Check&Cleaned Frame					<input checked="" type="checkbox"/>	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					<input checked="" type="checkbox"/>	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 6/5/67

PRESSURIZE FAN 2

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE .....

.....


.....

.....

COMMENT .....

.....

.....

RECORD BY 

RECHECK BY 



## GRANDE CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 29/6/67

PRESSURIZE FAN 1

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun, Sep, Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	8	Cleanning Relief Damper	/					
	9	Cleanning Supply Damperes	/					
	10	Added Grease The Damper Motordrive					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ..

RECHECK BY ..

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 29/6/67.....

PRESSURIZE FAN 2

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	8	Cleanning Relief Damper	/					
	9	Cleanning Supply Damperes	/					
	10	Added Grease The Damper Motordrive					/	

N = NORMAL      AB = ABNORMAL      C = CLEANNING      A = ADJUST&ADDED

R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY

RECHECK BY

## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH ..... 1/67 .....

SMOKE EXHAUST FAN ...M1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY ....

RECHECK BY .....

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH ..... 1 / 6x .....

SMOKE EXHAUST FAN ...M2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Timer Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Bearing					✓	
	5	Check&Cleaned Frame					✓	
	6	Check & Fitting Support					✓	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....



RECHECK BY .....





CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH ..... 1/67 .....

SMOKE EXHAUST FAN ...2-1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Timer Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Bearing					✓	
	5	Check&Cleaned Frame					✓	
	6	Check & Fitting Support					✓	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ....

RECHECK BY ....

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 23/2/67

SMOKE EXHAUST FAN ...2-1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control					✓	
		Testing Overload					✓	
	2	Check Timer Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Bearing					✓	
	5	Check&Cleaned Frame					✓	
	6	Check & Fitting Support					✓	
3 Month	7	Cleanning Air Grill Return						
Mar.,Jun, Sep, Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL      UN = UNORMAL      C = CLEANING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY [REDACTED] .....      RECHECK BY [REDACTED] .....

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/67

SMOKE EXHAUST FAN ...M1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL      UN = UNORMAL      C = CLEANNING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....


.....


.....

COMMENT .....

.....

.....

RECORD BY 

RECHECK BY 

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/67.....

SMOKE EXHAUST FAN ...M2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					<input checked="" type="checkbox"/>	
		Cleanning Overall Inside Panel Control	<input checked="" type="checkbox"/>					
		Fitting All Inside Panel Control					<input checked="" type="checkbox"/>	
		Testing Overload					<input checked="" type="checkbox"/>	
	2	Check Timer Operation					<input checked="" type="checkbox"/>	
	3	Check Motor& Blower					<input checked="" type="checkbox"/>	
	4	Check Bearing					<input checked="" type="checkbox"/>	
	5	Check&Cleaned Frame					<input checked="" type="checkbox"/>	
	6	Check & Fitting Support					<input checked="" type="checkbox"/>	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....


.....

COMMENT .....

.....

.....

RECORD BY 

RECHECK BY 



CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 31.03.17

SMOKE EXHAUST FAN ...2-1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return	/					
Mar.,Jun, Sep.,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....


COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9. 03. 67

SMOKE EXHAUST FAN ...M1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
Mar.,Jun.,Sep.,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY [REDACTED] .....

RECHECK BY [REDACTED] .....

## CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 31.09.17

SMOKE EXHAUST FAN ...M2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....



.....

.....

COMMENT .....

.....

.....

RECORD BY RECHECK BY 

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 18.09.67

SMOKE EXHAUST FAN ...M1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return	/					
Mar.,Jun.,Sep.,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY 

RECHECK BY 



## CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH ...13.07.07.....

SMOKE EXHAUST FAN ...M2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return	/					
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 19.04.07.....

SMOKE EXHAUST FAN ...2-1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
Mar,Jun,Sept,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

.....

RECORD BY 

RECHECK BY 

## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 19/5/67

SMOKE EXHAUST FAN ...M1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

## CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 19/5/67

SMOKE EXHAUST FAN ...M2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....



## CENTRE POINT RATCHADAMRI

## MAINTENANCE REPORT

SYSTEM &amp; SAFETY

MONTH 19/5/67

SMOKE EXHAUST FAN ...2-1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....


.....

.....

COMMENT .....

.....

.....

RECORD BY RECHECK BY 

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH ...29/6/67...

SMOKE EXHAUST FAN ...M1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control		✓				
		Testing Overload					✓	
	2	Check Timer Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Bearing					✓	
	5	Check&Cleaned Frame	✓				✓	
	6	Check & Fitting Support					✓	
3 Month	7	Cleanning Air Grill Return	✓					
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower		✓				

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY ...

RECHECK BY ...

## CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH: 29/6/67

SMOKE EXHAUST FAN...M2....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control		✓				
		Testing Overload					✓	
	2	Check Timer Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Bearing					✓	
	5	Check&Cleaned Frame	✓				✓	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					✓	
	7	Cleanning Air Grill Return	✓					
	11	Tighting All Bolt/Nut Motor & Blower		✓				

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&amp;ADDED

R = REPAIR

P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY .....

RECHECK BY .....

CENTRE POINT RATCHADAMRI  
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 29/6/67

SMOKE EXHAUST FAN ...2-1....

TIME .....

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control		✓				
		Testing Overload					✓	
	2	Check Timer Operation					✓	
	3	Check Motor& Blower					✓	
	4	Check Bearing					✓	
	5	Check&Cleaned Frame	✓				✓	
	6	Check & Fitting Support					✓	
3 Month	7	Cleanning Air Grill Return	✓					
Mar.,Jun.,Sep.,Dec	11	Tighting All Bolt/Nut Motor & Blower		✓				

N = NORMAL      UN = UNORMAL      C = CLEANING      A = ADJUST&ADDED  
R = REPAIR      P = REPLACED

NOTE .....

.....

.....

.....

COMMENT .....

.....

.....

RECORD BY

RECHECK BY