

แผนกิจกรรมฝึกซ้อมอพยพออกจากอาคารในกรณีเหตุเพลิงไหม้



กรุงเทพมหานคร



วุฒิบัตรเลขที่ สปภ.(กบก.๒) ๔๐๗/๒๕๖๖

ได้รับใบอนุญาตจากกรมสวัสดิการและคุ้มครองแรงงาน ใบอนุญาตเลขที่ ดพฝ.-ร ๒๐๒

ขอรับรองว่า

โรงแรม ไฮแอท รีเจนซี่ กรุงเทพฯ สุขุมวิท

ตั้งอยู่ที่ ๑ ซอยสุขุมวิท ๑๓ ถนนสุขุมวิท แขวงคลองเตยเหนือ เขตวัฒนา กรุงเทพมหานคร ๑๐๑๑๐

ได้ดำเนินการฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

ตามกฎหมายกำหนดมาตรฐานในการบริหาร จัดการ และดำเนินการด้านความปลอดภัยอาชีวอนามัย
และสภาพแวดล้อมในการทำงานเกี่ยวกับการป้องกันและระงับอัคคีภัย พ.ศ. ๒๕๕๕ ลงวันที่ ๗ ธันวาคม พ.ศ. ๒๕๕๕

มีผู้เข้ารับการฝึกอบรม จำนวน ๑๑๘ คน

เมื่อวันที่ ๒๗ กันยายน ๒๕๖๖

ให้ไว้ ณ วันที่ ๒๐ ตุลาคม ๒๕๖๖

(นายธีรยุทธ ภูมิภักดี)

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย
ปฏิบัติราชการแทนผู้ว่าราชการกรุงเทพมหานคร

Minutes of Annual Fire Drill

Date: Wednesday 27 September 2023.

Time: 17.05 – 17.25 hrs.

Simulation Scene: Room 1604.

Roles and Responsibility

Chief Warden: Khun Sammy Carolus/General Manager

Deputy Chief Warden: Khun Narinthorn Jaiyen/Director of Operations

Investigation Team

1. Khun Saran Chatchane/Team Leader Security
2. Khun Monthon Pratumchat/Assistant Manager FO

Fire Fighting Team

1. Khun Rungrot Phomsamlee/Technician
2. Khun Satjaphong Thaweesang/Technician
3. Khun Warut Binlateh/Bellman
4. Khun Surawut Lekjula/Commis Market Cafe

Assembly Point: Khun Napakwan Pongchawalit/Human Resources Manager

Observer/Minutes Taker: Khun Thanakorn Anurak/Security Manager

Sequence of Events Sequence	Description	Start Time	End Time	Period
1	Heat detector was activated at Room number 1604	17.05	-	0 Min
2	Control Room notified sent the message "Unconfirmed fire" to Line Group	17.06	-	0 Min
3	Investigation team went to the scene, found the real Fire. (AMFO and Security)	17.07	-	0 Min
4	Investigation Team (AMFO) reported to Khun Sammy for the situation.	17.08	17.09	1 Min

5	Investigation Team (Security) sent the message "Confirmed Fire" to Line Group.	17.08	-	0 Min
6	Investigation Team (AMFO) reported to Khun Sammy for the situation.	17.08	17.09	1 Min
7	GSC alerted the Support Team via phone.	17.08	17.10	2 Min
6	Investigation Team tried to put off the fire by fire extinguishers	17.09	17.12	3 Min
7	Hotel Fire Fighting team arrived to the scene then try to put off the fire.	17.12	17.14	2 Min
8	Investigation team (AM/FO) reported to Khun Sammy that the fire cannot control, ask for the permission to turn on General alarm.	17.14	17.15	1 Min
9	Investigation team (Security) send the message "Uncontrolled fire" to Line Emergency group.	17.15	17.15	0 Min
10	GSC call to Fire Station. (Pretended)	17.15	17.16	1 Min
11	Security turned on the General Alarm.	17.16	17.19	3 Min
12	Fire Brigade arrived to the scene. AM/FO briefed the situation then evacuated to the Assembly point	17.21	17.22	2 Min
13	First colleague came to the Assembly point.	17.18	17.18	0 Min
14	Last colleague came to the Assembly Point (nurse).	17.25	17.25	0 Min

Comments**Public announcement**

1. All guest floors working as normal, 2 languages (English and Thai) were cleared. Strobe lights as well.
2. Basement at training room did not have any emergency signal (alarm, PA and strobe light).
3. All public area working as normal.
4. Inside Market café kitchen need to improve the sound system as only one speaker installed in the steward room. Watching machine area the sound is very low.