

ภาคผนวก ข

เอกสารประกอบการปฏิบัติตาม  
มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม

## ภาคผนวก ข.1

---

ตำแนห่งสื่อนำส่งรายงานผลการปฏิบัติตาม  
มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม  
และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม


## UBE Chemicals (Asia) Public Company Limited

Office : 98 Sathorn Square Office Tower, 18<sup>th</sup> Floor,  
North Sathorn Road, Silom, Bangrak, Bangkok 10500, Thailand  
Tel. 66-2-206-9300 Fax. 66-2-206-9310

Factory : 140/6 Moo 4, Sukhumvit Road, Tapong Subdistrict,  
Muang Rayong District, Rayong Province 21000, Thailand  
Tel. 66-38-928-700 Fax. 66-38-928-865

<http://www.ube.co.th>

**UBE**  
UBE GROUP (THAILAND)



เลขที่ รง.UCHA/0006/67

24 มกราคม 2567

เรื่อง รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาโปรแลคตัม

เรียน อธิบดีกรมโรงงานอุตสาหกรรม

สิ่งที่ส่งมาด้วย รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาโปรแลคตัม  
ครั้งที่ 2/2566 ระหว่างเดือนกรกฎาคม ถึงธันวาคม พ.ศ. 2566 จำนวน 3 ฉบับ

ตามที่สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม มีมติเห็นชอบรายงาน  
การเปลี่ยนแปลงรายละเอียดโครงการโรงงานผลิตคาโปรแลคตัม ของบริษัท อูเบ เคมิคอลส์ (เอเชีย) จำกัด  
(มหาชน) ตามหนังสือแจ้งผลการพิจารณา ที่ ทส 1009.8/5240 ลงวันที่ 1 พฤษภาคม พ.ศ.2560  
โดยให้บริษัทฯ เสร็จรายงานผลการปฏิบัติตามมาตรการฯ จัดส่งให้สำนักงานนโยบายและ  
แผนทรัพยากรธรรมชาติและสิ่งแวดล้อม กรมโรงงานอุตสาหกรรม และสำนักงานทรัพยากรธรรมชาติและ  
สิ่งแวดล้อมจังหวัดระยอง ทราบทุก 6 เดือน

บริษัทฯ ใ้ขอส่งรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม  
และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ครั้งที่ 2/2566 ระหว่างเดือนกรกฎาคม ถึงธันวาคม  
พ.ศ. 2566 รายละเอียดดังสิ่งที่ส่งมาด้วย

จึงเรียนมาเพื่อโปรดพิจารณา

ขอแสดงความนับถือ

(นายมงกฏ ชินพาสานนท์)

ผู้รับมอบอำนาจประกอบกิจการโรงงาน

**UBE Chemicals (Asia) Public Company Limited**

Office : 98 Sathorn Square Office Tower, 18<sup>th</sup> Floor,  
North Sathorn Road, Silom, Bangrak, Bangkok 10500, Thailand  
Tel. 66-2-206-9300 Fax. 66-2-206-9310

Factory : 140/6 Moo 4, Sukhumvit Road, Tapong Subdistrict,  
Muang Rayong District, Rayong Province 21000, Thailand  
Tel. 66-38-928-700 Fax. 66-38-928-865

<http://www.ube.co.th>

เลขที่ รง.UCHA/0008/67

24 มกราคม 2567

เรื่อง รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตาม  
ตรวจสอบผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาโพรแลกตาม์

เรียน นายกองค้การบริหารส่วนตำบลตะพง


สิ่งที่ส่งมาด้วย รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาโพรแลกตาม์  
ครั้งที่ 2/2566 ระหว่างเดือนกรกฎาคม ถึงธันวาคม พ.ศ. 2566 จำนวน 1 ฉบับ

ตามที่ สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม มีมติเห็นชอบรายงาน  
การเปลี่ยนแปลงรายละเอียดโครงการโรงงานผลิตคาโพรแลกตาม์ ของบริษัท อูเบ เคมิคอลส์ (เอเชีย) จำกัด  
(มหาชน) ตามหนังสือแจ้งผลการพิจารณา ที่ ทส 1009.8/5240 ลงวันที่ 1 พฤษภาคม พ.ศ.2560 โดยให้  
บริษัทฯ เสร็จรายงานผลการปฏิบัติตามมาตรการฯ จัดส่งให้สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและ  
สิ่งแวดล้อม กรมโรงงานอุตสาหกรรม และสำนักงานทรัพยากรธรรมชาติและสิ่งแวดล้อมจังหวัดระยอง  
ทราบทุก 6 เดือน

บริษัทฯ ใ้รخواستรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ครั้งที่ 2/2566 ระหว่างเดือนกรกฎาคม ถึงธันวาคม  
พ.ศ. 2566 รายละเอียดดังสิ่งที่ส่งมาด้วย

จึงเรียนมาเพื่อโปรดพิจารณา

ขอแสดงความนับถือ



(นายมงกฏ ชินพวงสานนท์)

ผู้รับมอบอำนาจประกอบกิจการโรงงาน

กิตติ์  
30/1/67




## UBE Chemicals (Asia) Public Company Limited

Office : 98 Sathorn Square Office Tower, 18<sup>th</sup> Floor,  
North Sathorn Road, Silom, Bangrak, Bangkok 10500, Thailand  
Tel. 66-2-206-9300 Fax. 66-2-206-9310

Factory : 140/6 Moo 4, Sukhumvit Road, Tapong Subdistrict,  
Muang Rayong District, Rayong Province 21000, Thailand  
Tel. 66-38-928-700 Fax. 66-38-928-865

<http://www.ube.co.th>

**UBE**  
UBE GROUP (THAILAND)



เลขที่ รง.UCHA/0006/67

24 มกราคม 2567

เรื่อง รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาโปรแลคตัม

เรียน อธิบดีกรมโรงงานอุตสาหกรรม

สิ่งที่ส่งมาด้วย รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาโปรแลคตัม  
ครั้งที่ 2/2566 ระหว่างเดือนกรกฎาคม ถึงธันวาคม พ.ศ. 2566 จำนวน 3 ฉบับ

ตามที่สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม มีมติเห็นชอบรายงาน  
การเปลี่ยนแปลงรายละเอียดโครงการโรงงานผลิตคาโปรแลคตัม ของบริษัท อูเบ เคมิคอลส์ (เอเชีย) จำกัด  
(มหาชน) ตามหนังสือแจ้งผลการพิจารณา ที่ ทส 1009.8/5240 ลงวันที่ 1 พฤษภาคม พ.ศ.2560  
โดยให้บริษัทฯ เสร็จรายงานผลการปฏิบัติตามมาตรการฯ จัดส่งให้สำนักงานนโยบายและ  
แผนทรัพยากรธรรมชาติและสิ่งแวดล้อม กรมโรงงานอุตสาหกรรม และสำนักงานทรัพยากรธรรมชาติและ  
สิ่งแวดล้อมจังหวัดระยอง ทราบทุก 6 เดือน

บริษัทฯ ได้จัดส่งรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม  
และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ครั้งที่ 2/2566 ระหว่างเดือนกรกฎาคม ถึงธันวาคม  
พ.ศ. 2566 รายละเอียดดังสิ่งที่ส่งมาด้วย

จึงเรียนมาเพื่อโปรดพิจารณา


ขอแสดงความนับถือ

(นายมงกฏ ชินพงसानนท์)

ผู้รับมอบอำนาจประกอบกิจการโรงงาน

## ยืนยันการรับข้อมูลเข้าสู่ระบบอิเล็กทรอนิกส์

เลขที่ Monitor : 256701-770  
ชื่อโครงการ : การเปลี่ยนแปลงรายละเอียดในรายงานการวิเคราะห์ผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาปโรแลคตัม (ครั้งที่ 4)  
รอบรายงาน : ก.ค. 66 - ธ.ค. 66  
วันที่ยื่นรายงาน : 30/01/2567  
เลขที่ IEE/EIA/EHIA : 10899  
ผู้ยื่นรายงาน : กอบัว เกศเทศ  
อีเมล : korbua@ube.co.th  
โทรศัพท์ : 0924629156



QR Code สำหรับเรียกดูข้อมูลรายงานรายงาน Monitor นี้  
โดยท่านสามารถเรียกดูข้อมูลรายงานต่างๆ  
ที่เกี่ยวข้องกับโครงการได้ผ่านโมบายแอปพลิเคชัน Smart EIA  
อีกหนึ่งช่องทาง

สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม



กองพัฒนาระบบการประเมินผลกระทบสิ่งแวดล้อม  
Division of Environmental Impact Assessment Development

## ภาคผนวก ข.2

---

### การวิเคราะห์งานโดยวิธีการ HAZOP Study

ที่ อก ๐๓๑๒/ ๕ ๕๑ ๓



กรมโรงงานอุตสาหกรรม  
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท  
เขตราชเทวี กรุงเทพฯ ๑๐๕๐๐

๑๗ มิถุนายน ๒๕๖๗

เรื่อง แจ้งผลการพิจารณารายงานการวิเคราะห์ความเสี่ยงจากอันตรายที่อาจเกิดจากการประกอบกิจการโรงงาน  
เรียน กรรมการผู้จัดการ บริษัท อุเบ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)

อ้างถึง หนังสือบริษัท อุเบ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน) ที่ รง.UCHA/๐๐๔๐/๖๗ ลงวันที่ ๒๙ พฤษภาคม ๒๕๖๗

ตามหนังสือที่อ้างถึง ท่านได้ส่งรายงานการวิเคราะห์ความเสี่ยงจากอันตรายที่อาจเกิดจากการประกอบกิจการโรงงานของ บริษัท อุเบ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน) ประกอบกิจการผลิตสารคาโปรแลคตัม และผลิตปุ๋ยแอมโมเนียซัลเฟต EIA ทะเบียนโรงงานเลขที่ ๙๑๐๙๐๑๐๐๑๒๕๓๙๓ (ข๓-๔๔-๑/๓๙รย) ตั้งอยู่เลขที่ ๑๔๐/๖ หมู่ที่ ๔ ซอยเขตประกอบการฯ ที่พีไอ ถนนสุขุมวิท ตำบลตะพง อำเภอเมืองระยอง จังหวัดระยอง นั้น

กรมโรงงานอุตสาหกรรม ได้พิจารณารายงานการวิเคราะห์ความเสี่ยงจากอันตรายที่อาจเกิดจากการประกอบกิจการโรงงานแล้ว ขอแจ้งให้ทราบว่ารายงานดังกล่าวผ่านเกณฑ์การพิจารณา จึงเห็นชอบในรายงานดังกล่าว ซึ่งท่านต้องปฏิบัติตามแผนงานบริหารจัดการความเสี่ยงอย่างเคร่งครัด และดำเนินการปรับปรุงรายงานครั้งต่อไปตามที่กำหนดในประกาศกระทรวงอุตสาหกรรมในส่วนที่เกี่ยวกับการทบทวนการทบทวนแผนงานบริหารจัดการความเสี่ยง ให้สอดคล้องกับผลการศึกษา วิเคราะห์ และทบทวนการดำเนินงานในโรงงานเพื่อการชั่งอันตรายและการประเมินความเสี่ยงที่ได้จัดทำขึ้น

ทั้งนี้ ตามประกาศกระทรวงอุตสาหกรรม (ฉบับที่ ๕) พ.ศ.๒๕๖๖ เรื่อง มาตรการคุ้มครองความปลอดภัยในการดำเนินงาน กำหนดให้ท่านจัดส่งรายงานการวิเคราะห์ความเสี่ยงจากอันตรายที่อาจเกิดจากการประกอบกิจการโรงงานระหว่างวันที่ ๑ มกราคม ๒๕๖๙ ถึงวันที่ ๓๑ สิงหาคม ๒๕๖๙

จึงเรียนมาเพื่อทราบ และขอให้ท่านจัดส่งรายงานการวิเคราะห์ความเสี่ยงฯ ครั้งต่อไป ผ่านระบบรายงานการวิเคราะห์ความเสี่ยงฯ ของกรมโรงงานอุตสาหกรรมหรือจัดส่งรายงานการวิเคราะห์ความเสี่ยงฯ พร้อมอุปกรณ์จัดเก็บข้อมูล (Thumb Drive หรือ CD) ให้กองส่งเสริมเทคโนโลยีความปลอดภัยโรงงาน กรมโรงงานอุตสาหกรรม ตามวันที่ระบุข้างต้น ทั้งนี้ หากมีข้อสงสัยสอบถามรายละเอียดเพิ่มเติมได้ที่ นางสาวขวัญจิรา สุวรรณรัตน์ และท่านสามารถดูรายละเอียดคู่มือเพิ่มเติมได้ที่ <http://reg3.diw.go.th/safety/คู่มือ/ประเมินความเสี่ยง>

ขอแสดงความนับถือ

(นายบวร สัตยาคุณพิพงศ์)

ผู้อำนวยการกองส่งเสริมเทคโนโลยีความปลอดภัยโรงงาน

ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

กองส่งเสริมเทคโนโลยีความปลอดภัยโรงงาน

โทร. ๐ ๒๔๓๐ ๖๓๑๔ ต่อ ๒๓๐๙

โทรสาร ๐ ๒๔๓๐ ๖๓๑๔ ต่อ ๒๓๙๙

ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

ที่ อก ๐๓๑๒/ - ๑ ๗ ๕ ๖



กองส่งเสริมเทคโนโลยีความปลอดภัยโรงงาน  
กรมโรงงานอุตสาหกรรม  
ถนนพระรามที่ ๖ เขตราชเทวี  
กรุงเทพมหานคร ๑๐๕๐๐

๕ กันยายน ๒๕๖๑

เรื่อง รายงานการวิเคราะห์ความเสี่ยงจากอันตรายที่อาจเกิดจากการประกอบกิจการโรงงาน

เรียน กรรมการผู้จัดการ บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)

สิ่งที่ส่งมาด้วย แบบรายงานการปฏิบัติตามแนวทาง/มาตรการที่เสนอในรายงานการวิเคราะห์ความเสี่ยง  
ประจำปี พ.ศ. ....

ตามที่ท่านได้ยื่นรายงานการวิเคราะห์ความเสี่ยงจากอันตรายที่อาจเกิดจากการประกอบกิจการ-  
โรงงาน ประกอบกิจการผลิตคาโปรแลคตัมและปุ๋ยแอมโมเนียมซัลเฟต ทะเบียนโรงงานเลขที่ ข ๓-๔๔-๑/๓๙ อย  
ตั้งอยู่เลขที่ ๑๔๐/๖ หมู่ที่ ๔ ตำบลตะพง อำเภอเมืองระยอง จังหวัดระยอง นั้น

กองส่งเสริมเทคโนโลยีความปลอดภัยโรงงาน กรมโรงงานอุตสาหกรรม ได้รับรายงานดังกล่าวแล้ว  
จึงขอให้ท่านปฏิบัติตามมาตรการป้องกันและควบคุมอันตราย แผนงานบริหารจัดการความเสี่ยง และกฎหมาย  
ความปลอดภัยที่เกี่ยวข้องอย่างเคร่งครัด ทั้งนี้ ให้ท่านจัดทำรายงานการปฏิบัติเป็นประจำทุกปี ตามสิ่งที่ส่งมาด้วย  
หรือแบบอื่นที่ท่านเห็นว่าเหมาะสม โดยเก็บไว้ที่โรงงานพร้อมให้เจ้าหน้าที่ตรวจสอบได้เสมอ

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายสุภกิจ บุญศิริ)

ผู้อำนวยการกองส่งเสริมเทคโนโลยีความปลอดภัยโรงงาน

ฝ่ายบริหารทั่วไป


โทร. ๐ ๒๒๐๒ ๔๒๑๖

โทรสาร ๐ ๒๓๕๔ ๓๓๙๒

PROCEDURE	การวิเคราะห์งานโดยวิธีการ HAZOP Study (Hazard and Operability Study)	Date : 18 Jan. 2021
		Page : 1 of 3
Doc. No. : UP-PRM-00-003		Rev. No : 01



PROCEDURE	การวิเคราะห์งานโดยวิธีการ HAZOP Study (Hazard and Operability Study)	Date : 18 Jan. 2021
		Page : 2 of 3
Doc. No. : UP-PRM-00-003		Rev. No : 01



PROCEDURE	การวิเคราะห์งานโดยวิธีการ HAZOP Study (Hazard and Operability Study)	Date : 18 Jan. 2021
		Page : 3 of 3
Doc. No. : UP-PRM-00-003		Rev. No : 01



ภาคผนวก ข.3

เอกสารแจ้งกำหนดการตรวจสอบผลการปฏิบัติตามมาตรการฯ



## UBE Chemicals (Asia) Public Company Limited

Office : 98 Sathorn Square Office Tower, 18<sup>th</sup> Floor,  
North Sathorn Road, Silom, Bangrak, Bangkok 10500, Thailand  
Tel. 66-2-206-9300 Fax. 66-2-206-9310

Factory : 140/6 Moo 4, Sukhumvit Road, Tapong Subdistrict,  
Muang Rayong District, Rayong Province 21000, Thailand  
Tel. 66-38-928-700 Fax. 66-38-928-865

<http://www.ube.co.th>

**UBE**  
UBE GROUP (THAILAND)

สำนักงาน
อุตสาหกรรมจังหวัดระยอง
เลขที่รับ..... 4097
วันที่ 3.1 พ.ค. 2567
เวลา.....

เลขที่ รง.UCHA/0039/67

29 พฤษภาคม 2567

เรื่อง แจ้งกำหนดการตรวจสอบผลการปฏิบัติตามมาตรการป้องกัน และแก้ไขผลกระทบสิ่งแวดล้อม และ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการฯ บริษัท อุเบ เคมิคอลส์ (เอเชีย)  
จำกัด (มหาชน) โดยบริษัท ซีคอต จำกัด

เรียน อุตสาหกรรมจังหวัดระยอง

สิ่งที่ส่งมาด้วย รายการตรวจสอบผลการปฏิบัติตามมาตรการป้องกัน และแก้ไขผลกระทบสิ่งแวดล้อม และ  
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการ

เนื่องด้วยตามมาตรการป้องกัน และแก้ไขผลกระทบสิ่งแวดล้อม (ระยะดำเนินการ) โครงการ  
โรงงานผลิตคาโพรแลกตาม์ (ภายหลังการเปลี่ยนแปลงรายละเอียด โครงการในรายงานการวิเคราะห์  
ผลกระทบสิ่งแวดล้อม โครงการโรงงานผลิตคาโพรแลกตาม์ (ครั้งที่ 4)) ของบริษัท อุเบ เคมิคอลส์ (เอเชีย)  
จำกัด (มหาชน) ในหัวข้อเรื่องมาตรการทั่วไป กำหนดให้ทางบริษัทฯ ดำเนินการว่าจ้างหน่วยงานกลาง  
(Third Party) เพื่อดำเนินการตรวจสอบผลการปฏิบัติตามมาตรการป้องกัน และแก้ไขผลกระทบสิ่งแวดล้อม  
และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการ ให้หน่วยงานอนุญาตรับทราบนั้น

ในการนี้ทางบริษัท อุเบ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน) ทะเบียนโรงงานเลขที่ ข 3-44-1/39 รย  
ประกอบกิจการผลิตคาโพรแลกตาม์และปุ๋ยแอมโมเนียมซัลเฟต ตั้งอยู่เลขที่ 140/6 หมู่ที่ 4 ต.ตะพง อ.เมือง  
จ.ระยอง จึงขอเรียนแจ้งกำหนดการในการดำเนินการติดตามตรวจสอบผลการปฏิบัติตามมาตรการฯ โดย  
บริษัท ซีคอต จำกัด ในวันที่ 17 มิถุนายน 2567 ให้ทางอุตสาหกรรมจังหวัดรับทราบ โดยมีรายละเอียดตาม  
สิ่งที่ส่งมาด้วย

จึงเรียนมาเพื่อโปรดทราบ

ได้รับเอกสารต้นฉบับแล้ว
ผู้รับ
วันที่ 31/05/2567
กรุณาส่งกลับ

ขอแสดงความนับถือ

(นายมงคล ชินพาสานนท์)

ผู้รับมอบอำนาจประกอบกิจการโรงงาน

ผู้ประสานงาน : นางสาวกอบัว เกศเทศ โทร.092-462-9156

#### ภาคผนวก ข.4

---

### เอกสารการแจ้งซ่อมบำรุงเครื่องจักรและอุปกรณ์ประจำปี

## แบบแจ้งการหยุดเดินเครื่องจักรและรายละเอียดในการป้องกัน

### แก้ไขปัญหาสิ่งแวดล้อม

1. ชื่อผู้ประกอบการโรงงาน..... บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน).....
2. สถานที่ตั้งโรงงาน..... 140/6 หมู่ 4 ต.ตะพง อ.เมืองระยอง จ.ระยอง 21000.....
3. ประกอบกิจการ..... ผลิตภัณฑ์โพรแพนคัมและแอมโมเนียมซัลเฟต.....  
ทะเบียนโรงงานเลขที่..... ข 3-44-1/39 รย.....
4. หยุดเดินเครื่องจักรเนื่องจาก..... ช่อมบำรุงเครื่องจักร (นางสาว).....  
หยุดเดินเครื่องจักร ระหว่างวันที่..... 12 กรกฎาคม 2566..... ถึงวันที่..... 23 สิงหาคม 2566.....

#### หมายเหตุ :

เนื่องด้วยเหตุผลทางด้านการตลาด จึงมีความจำเป็นที่จะต้องเลื่อนกำหนดการหยุดซ่อมบำรุง  
จากวันที่ 12 - 31 กรกฎาคม 2566 เป็นวันที่ 12 กรกฎาคม - 23 สิงหาคม 2566

5. มาตรการป้องกันและแก้ไขปัญหาด้านสิ่งแวดล้อม และความปลอดภัย  
บริษัทฯ ปฏิบัติตามมาตรการป้องกันผลกระทบสิ่งแวดล้อมที่กำหนดไว้ใน EIA ดังนี้
  - 5.1) กระบวนการนำวัตถุดิบ ผลิตภัณฑ์ หรือวัสดุอื่นๆ ออกจากระบบ  
..... - จัดเก็บวัตถุดิบไว้ในระบบทั้งหมด รวมทั้งวัตถุดิบที่อยู่ในระหว่างผลิต.....
  - 5.2) มาตรการป้องกันปัญหาสิ่งแวดล้อมด้านมลพิษทางอากาศ เช่น วิธีการไล่แก๊สเสียออกจากระบบ,  
การใช้เชื้อเพลิง/อัตราส่วนในการเผาทั้งที่ปล่อย  
..... - มีการตัดแยกอุปกรณ์ (Isolation) และดำเนินการไล่อากาศหรือของเหลว ไปยังระบบรองรับ หรือ  
ระบบควบคุมที่จัดเตรียมไว้.....
  - 5.3) มาตรการป้องกันปัญหาสิ่งแวดล้อมด้านน้ำเสีย  
..... - มีการเดินระบบบำบัดน้ำเสีย และควบคุมคุณภาพน้ำที่ปล่อยออกจากโรงงานอย่างให้เป็นไปตาม  
มาตรฐานที่กำหนด.....
  - 5.4) มาตรการป้องกันปัญหาสิ่งแวดล้อมด้านกากอุตสาหกรรม  
..... - มีระบบการจัดเก็บกากอุตสาหกรรมลงภาชนะแบบปิด และจัดส่งให้กับบริษัทผู้ได้รับอนุญาตไป  
ดำเนินการกำจัด/ บำบัดตามมาตรฐานการจัดการกากอุตสาหกรรม.....
6. ชื่อผู้รับผิดชอบและประสานงาน..... นายปรกรณ์ ชรรณเวชวิทย์ โทร..... 081-559-1329.....

ผู้รายงาน.....

(.....)

ตำแหน่ง..... ผู้จัดการโรงงาน.....

**แบบแจ้งการหยุดเดินเครื่องจักรและรายละเอียดในการป้องกัน**  
**แก้ไขปัญหาลิ่งแวดล้อม**

1. ชื่อผู้ประกอบการโรงงาน..... บริษัท อูเมะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน).....
2. สถานที่ตั้งโรงงาน..... 140/6 หมู่ 4 ต.ตะพง อ.เมืองระยอง จ.ระยอง 21000.....
3. ประเภทกิจการ..... ผลิตภัณฑ์โพรเพลคแคมและแอมโมเนียมซัลเฟต.....  
ทะเบียนโรงงานเลขที่..... ข 3-44-1/39 รย.....
4. หยุดเดินเครื่องจักรเนื่องจาก..... ซ่อมบำรุงเครื่องจักร (บางส่วน).....  
.....  
หยุดเดินเครื่องจักร ระหว่างวันที่..... 15 ธันวาคม 2566..... ถึงวันที่..... 25 ธันวาคม 2566.....
5. มาตรการป้องกันและแก้ไขปัญหาด้านสิ่งแวดล้อม และความปลอดภัย  
บริษัทฯ ปฏิบัติตามมาตรการป้องกันผลกระทบสิ่งแวดล้อมที่กำหนดไว้ใน EIA ดังนี้  
5.1) กระบวนการนำวัตถุดิบ ผลิตภัณฑ์ หรือวัสดุอื่นๆ ออกจากระบบ  
..... - จัดเก็บวัตถุดิบไว้ในระบบทั้งหมด รวมทั้งวัตถุดิบที่อยู่ในระหว่างผลิต.....  
.....  
5.2) มาตรการป้องกันปัญหาลิ่งแวดล้อมด้านมลพิษทางอากาศ เช่น วิธีการไล่แก๊สเสียออกจากระบบ,  
การใช้เชื้อเพลิง/อัตราส่วนในการเผาไหม้ที่ปลอดภัย  
..... - มีการรวบรวมไปยังระบบบำบัดมลพิษทางอากาศที่กำหนดไว้ และควบคุมคุณภาพอากาศจาก  
ปล่องระบายให้เป็นไปตามมาตรฐานที่กำหนด.....  
5.3) มาตรการป้องกันปัญหาลิ่งแวดล้อมด้านน้ำเสีย  
..... - มีการเดินระบบบำบัดน้ำเสีย และควบคุมคุณภาพน้ำที่ปล่อยออกจากโรงงาน ให้เป็นไปตาม  
มาตรฐานที่กำหนด.....  
5.4) มาตรการป้องกันปัญหาลิ่งแวดล้อมด้านกากอุตสาหกรรม  
..... - มีระบบการจัดเก็บกากอุตสาหกรรมลงภาชนะแบบปิด และจัดส่งให้บริษัทผู้ได้รับอนุญาตไป  
ดำเนินการกำจัด/ บำบัดตามมาตรฐานการจัดการกากอุตสาหกรรม.....
6. ชื่อผู้รับผิดชอบและประสานงาน..... นายปรกรณ์ ธรรมเวทิตี โทร..... 081-559-1329.....

ผู้รายงาน.....

(.....)

ตำแหน่ง.....

ผู้จัดการโรงงาน.....


## ภาคผนวก ข.5

---

เอกสารการทบทวนเหตุการณ์อุบัติภัย/อุบัติเหตุที่เกิดจาก  
การประกอบกิจการอุตสาหกรรมที่มีการผลิตลักษณะเดียวกัน  
ทั้งในประเทศและต่างประเทศ

UBE Chemicals (Asia) Public Company Limited			
MINUTES OF MEETING	LOCATION : VC-UGT007-UCHA-RYG-CPL1-I-W	REPORTED BY :	
	MEETING DATE : 3 เมษายน 2567 (13:30-14:30 น.)	TOTAL : 4 PAGE (Include this page)	
SUBJECT : การประชุมขอความปลอดภัยอาชีวอนามัยและสภาพแวดล้อมในการทำงาน กะ " A " ครั้งที่ 3/2567			
MEETING PURPOSE : เพื่อประสานงานและดำเนินกิจกรรมด้านความปลอดภัยอาชีวอนามัยและสิ่งแวดลอม			
ATTENDANT : <span style="background-color: #cccccc; display: inline-block; width: 150px; height: 1.2em; vertical-align: middle;"></span>		COPY CONCERN	
<span style="background-color: #cccccc; display: inline-block; width: 150px; height: 1.2em; vertical-align: middle;"></span> ,		คุณเสก	
ITEM	DISCUSSION	ACTION BY	TIME LIMIT
	<p><u>วาระที่ 1 ประธานแจ้งให้ที่ประชุมทราบ</u></p> <p>คุณสุรพงษ์ กล่าวเปิดประชุม Sub. OSHE และรายงานสถานการณ์เกี่ยวกับระบบบำบัดน้ำเสีย ซึ่งขณะนี้เมเนจเม้นท์ที่ดียังไม่ได้เข้าสู่ภาวะปกติ จึงขอความร่วมมือกับทุกคนให้ช่วยกันดูแลและเฝ้าระวัง กรณีที่เกิดเหตุการณ์สารเคมีรั่วไหลหรือมีกิจกรรมที่อาจเกิดผลกระทบต่อระบบบำบัดน้ำเสีย ขอให้รีบแจ้งต่อหัวหน้างานหรือผู้เกี่ยวข้องทันที เพื่อจะได้หาวิธีแก้ไขและลดผลกระทบที่อาจเกิดขึ้น</p> <p><u>วาระที่ 2 พิจารณารายงานการประชุม</u></p> <p>ในที่ประชุมไม่มีมติรับรองรายงานการประชุม</p> <p><u>วาระที่ 3</u></p> <p><u>3.1 Safety and environment sharing</u></p> <p>คุณสุรพงษ์ Share เหตุการณ์สารเคมีรั่วไหลจากท่อที่ถูกยกเลิกการใช้งานไปแล้ว แต่ไม่ได้มีการตัดแยกออกจากระบบอย่างถูกวิธี ซึ่งเหตุการณ์ในครั้งนี้ทำให้เกิดผลกระทบต่อสิ่งแวดล้อมและชุมชนใกล้เคียง (รายละเอียดตามเอกสาร)</p>		

[illegible]

ITEM	DESCRIPTION	ACTION BY	TIME LIMIT
	<p><b>3.3 Hiyari hatt และ SOR</b>  SOR ได้ตามเป้าหมายที่วางไว้เกือบทุกหน่วยงาน (รายละเอียดตามเอกสาร)</p>  <p>ในส่วนของ Hiyari hatt ปัจจุบันยังไม่ได้มีการ Update Dashboard ในระบบ</p> <p><b>3.4 ประเด็นด้านความปลอดภัยและสิ่งแวดล้อมจาก Plant Partrol (NC)</b>  - ไม่มีประเด็น</p> <p><b>3.5 นำทิ้งและกากของเสีย</b>  - ไม่มีประเด็น</p> <p><b>3.6 กฎหมายใหม่</b>  - เพิ่มเติมมาตรฐานการตรวจวัดเสียงรบกวน จะมีการตรวจวัดเพิ่มเติมในขณะที่ Plant shutdown เพื่อเปรียบเทียบความดังของเสียงเทียบกับช่วงเวลา Plant run ปกติ (รายละเอียดจะแจ้งเพิ่มเติมอีกครั้ง)</p>		

ITEM	DESCRIPTION	ACTION BY	TIME
	<p><b>3.7 ประเด็นจากการประชุมในกรณีอื่น</b>  - ไม่มีประเด็นให้ต้องติดตาม</p> <p><b>4 ติดตามงานค้างจากการประชุมครั้งก่อน</b>  - ไม่มีประเด็นตกค้าง</p> <p><b>5 ข้อเสนอแนะด้านความปลอดภัยและชีวอนามัย</b>  <b>คุณ จักรัต</b>  มีต้นไม้เริ่มตายบริเวณริมรั้วฝั่งทิศใต้ ตั้งแต่ Unit 2100 - CW 2030 หวันว่าจะทำให้เกิดอุบัติเหตุขึ้นได้  <b>คุณ กอบัว</b> แจ้งว่าทาง CSR มีแผนในการตัดและนำต้นไม้ใหม่ไปปลูกทดแทน</p> <p><b>คุณ ชัยวุธ</b>  รถที่เข้ามารับของเสียหรือโหลดสารเคมีไม่มีป้ายติดหน้ารถ ว่าต้องเข้ามาที่หน่วยงานไหน  <b>คุณ กอบัว</b> แจ้งว่าเบื้องต้นจะแจ้งไปยังต้นสังกัดให้ทำป้ายติดหน้ารถ</p> <p><b>วาระที่ 6 สรุปและปิดการประชุม</b>  <b>คุณสุรพงษ์</b> กล่าวปิดประชุมและนัดประชุมครั้งต่อไป วันที่ 26 เมษายน 2567</p>		

## ภาคผนวก ข.6

### เอกสารการจัดทำฐานข้อมูลสุขภาพของพนักงาน



**B BANGKOK  
HOSPITAL**  
RAYONG



บริษัท อุเบ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)(UCHA)

ชื่อ :

Order No.: 305

เลขประจำตัวพนักงาน :

อายุ : 33 ปี เพศ : ชาย(Male)

ตำแหน่ง : Community Officer

แผนก :



ฝ่าย : UCHA Government Affair & Community

วันที่ตรวจ : 2 สิงหาคม 2565

**MEDICAL CHECK-UP REPORT  
HEALTH PROMOTION**

**รายงานผลการตรวจสุขภาพ**

## ภาคผนวก ข.7

### เอกสารบันทึกข้อมูลสุขภาพของพนักงานและผู้รับเหมา

UBE GROUP (THAILAND)											
TABLE OF PATIENT TREATED AT F/A on January 2024											
TYPE OF SICKNESS											
GROUP	ระบบทางเดินหายใจ	ระบบทางเดินอาหาร	ระบบผิวหนัง	ระบบกล้ามเนื้อ	ระบบ หู ตา จมูก	ระบบประสาท	ระบบหัวใจและหลอดเลือด	ระบบทางเดินปัสสาวะ	อุบัติเหตุในงาน	ท่านผล	TOTAL (CASE) ราย
UCHA	196	69	12	51	5	15	0	0	0	6	368
TSL	6	6	1	3	0	0	0	1	0	0	20
UFA	26	9	1	7	0	2	0	0	0	0	47
UTCA	1	0	0	0	0	0	0	0	0	0	2
UTH	0	0	0	0	0	0	0	0	0	0	0
RFT	0	0	0	0	0	0	0	0	0	0	0
Contractor	76	45	4	15	4	6	2	3	0	0	160
TOTAL	305	129	18	76	9	23	2	4	0	6	597

UBE GROUP (THAILAND)											
TABLE OF PATIENT TREATED AT F/A on February 2024											
TYPE OF SICKNESS											
GROUP	ระบบทางเดินหายใจ	ระบบทางเดินอาหาร	ระบบผิวหนัง	ระบบกล้ามเนื้อ	ระบบ หู ตา จมูก	ระบบประสาท	ระบบหัวใจและหลอดเลือด	ระบบทางเดินปัสสาวะ	อุบัติเหตุในงาน	ท่านผล	TOTAL (CASE) ราย
UCHA	150	51	16	49	7	8	1	2	0	2	293
TSL	4	3	0	3	0	0	0	0	0	2	15
UFA	14	5	1	4	0	1	0	0	0	0	26
UTCA	1	0	1	2	0	0	0	1	0	0	6
UTH	0	0	0	0	0	0	0	0	0	0	0
RFT	0	0	0	0	0	0	0	0	0	0	0
Contractor	17	41	17	45	6	8	0	0	0	6	146
TOTAL	186	100	35	103	13	17	1	3	0	10	486

UBE GROUP (THAILAND)											
TABLE OF PATIENT TREATED AT F/A on March 2024											
TYPE OF SICKNESS											
GROUP	ระบบทางเดินหายใจ	ระบบทางเดินอาหาร	ระบบผิวหนัง	ระบบกล้ามเนื้อ	ระบบ หู ตา จมูก	ระบบประสาท	ระบบหัวใจและหลอดเลือด	ระบบทางเดินปัสสาวะ	อุบัติเหตุในงาน	ท่าแผล	TOTAL (CASE) ราย
UCHA	158	48	18	60	2	21	1	1	0	14	337
TSL	7	2	1	3	0	1	0	0	0	0	15
UFA	7	8	1	6	2	1	0	0	0	1	27
UTCA	0	1	0	0	0	0	0	0	0	0	1
UTH	0	0	0	0	0	0	0	0	0	0	0
RFT	0	0	0	0	0	0	0	0	0	0	0
Contractor	11	46	14	11	6	4	0	2	1	3	104
TOTAL	183	105	34	80	10	27	1	3	1	18	484

UBE GROUP (THAILAND)											
TABLE OF PATIENT TREATED AT F/A on April 2024											
TYPE OF SICKNESS											
GROUP	ระบบทางเดินหายใจ	ระบบทางเดินอาหาร	ระบบผิวหนัง	ระบบกล้ามเนื้อ	ระบบ หู ตา จมูก	ระบบประสาท	ระบบหัวใจและหลอดเลือด	ระบบทางเดินปัสสาวะ	อุบัติเหตุในงาน	ท่าแผล	TOTAL (CASE) ราย
UCHA	136	65	26	59	9	14	0	0	0	5	327
TSL	8	12	2	3	0	1	0	1	0	0	30
UFA	13	1	3	2	4	0	0	0	0	0	26
UTCA	0	0	0	0	0	0	0	0	0	0	2
UTH	0	0	0	0	0	0	0	0	0	0	0
RFT	0	0	0	0	0	0	0	0	0	0	0
Contractor	74	14	26	49	4	8	1	3	1	8	191
TOTAL	231	92	57	113	17	23	1	4	1	13	576


UBE GROUP (THAILAND)											
TABLE OF PATIENT TREATED AT F/A on May 2024											
TYPE OF SICKNESS											
GROUP	ระบบทางเดินหายใจ	ระบบทางเดินอาหาร	ระบบผิวหนัง	ระบบกล้ามเนื้อ	ระบบ หู ตา จมูก	ระบบประสาท	ระบบหัวใจและหลอดเลือด	ระบบทางเดินปัสสาวะ	อุบัติเหตุในงาน	ทำแผล	TOTAL (CASE) ราย
UCHA	121	62	21	49	4	21	0	0	0	2	293
TSL	0	5	1	3	0	1	0	0	0	0	12
UFA	10	2	1	4	0	0	0	0	0	0	22
UTCA	0	0	0	0	0	0	0	0	0	0	1
UTH	0	0	0	0	0	0	0	0	0	0	0
RFT	0	0	0	0	0	0	0	0	0	0	0
Contractor	23	35	21	13	4	28	0	3	0	2	131
TOTAL	154	104	44	69	8	50	0	3	0	4	459

UBE GROUP (THAILAND)											
TABLE OF PATIENT TREATED AT F/A on June 2024											
TYPE OF SICKNESS											
GROUP	ระบบทางเดินหายใจ	ระบบทางเดินอาหาร	ระบบผิวหนัง	ระบบกล้ามเนื้อ	ระบบ หู ตา จมูก	ระบบประสาท	ระบบหัวใจและหลอดเลือด	ระบบทางเดินปัสสาวะ	อุบัติเหตุในงาน	ทำแผล	TOTAL (CASE) ราย
UCHA	100	45	11	47	4	21	0	1	0	7	242
TSL	3	2	3	2	0	0	0	1	0	0	13
UFA	2	2	0	4	3	0	0	1	0	5	18
UTCA	0	0	0	0	0	0	0	0	0	0	2
UTH	0	0	0	0	0	0	0	0	0	0	0
RFT	0	0	0	0	0	0	0	0	0	0	0
Contractor	54	35	14	12	5	11	0	5	0	5	143
TOTAL	159	84	28	65	12	32	0	8	0	17	418

ภาคผนวก ข.8

---

เอกสารคัดเลือกและประเมินคุณภาพห้องปฏิบัติการวิเคราะห์  
ของหน่วยงานกลาง (Third Party)



Dear N'Smart

ขอจัดส่งสรุปข้อมูล Environmental Monitoring จาก Third Party จำนวน 5 ราย ดังนี้ (รายละเอียดดังเอกสารแนบ)






- งานตรวจวัดคุณภาพอากาศ : SECOT (เจ้าเดิม)
- งานตรวจวัดคุณภาพน้ำ : ALS (เจ้าเดิม)

ทั้งนี้เพื่อดำเนินการในส่วนที่เกี่ยวข้องตามขั้นตอนต่อไปค่ะ

หมายเหตุ : หากไม่มีประเด็นอะไรเพิ่มเติม ทาง OSHE ขออนุญาตประสานงานเรื่องแผนตรวจวัดของเดือนเมษายน 2566 กับ third party ทั้ง 2 ราย เพื่อความต่อเนื่องในการปฏิบัติงานฯ นะคะ ... ขอขอบคุณค่ะ



 You forwarded this message on 26/05/2023 09:37.

 ราคาเสนอซื้อเศษวัสดุเหลือใช้ประจำปี 2566_Award.pdf 711 KB	 รายการวัสดุเหลือใช้ 2565-2566_Update Price.xlsx 18 KB	 3K_2023.pdf 644 KB
 PTSL_2023_2.pdf 2 MB	 CKC_2023.pdf 719 KB	

Dear All,

Greeting from procurement team,  
Refer the official bidding and awarding process of Scrap FY 2023 – 2024

On behalf of the committee of UBE Group, we are pleased to informed you upon the new price list as attachment.  
Validity Period: 1 June 2023 – 31 May 2024

Best Regards,





<b>UBE</b>		ใบประเมินผู้ให้บริการ		SECTION : _____
UBE Technical Center (Asia) Ltd.		(Suppliers services annual evaluation form)		No. : _____
ผลิตภัณฑ์ / การบริการ		บริษัท / องค์กร		ประจำปี
รายละเอียดของการประเมินผู้ให้บริการ				
ลำดับ	หัวข้อการประเมิน	เกณฑ์การประเมิน	คะแนน	
1	ความถูกต้องและความน่าเชื่อถือของข้อมูล	(20) เป็นที่พอใจ - ไม่พบการรายงานผลผิดพลาด (10) ขอมรับได้ - พบการรายงานผลผิดพลาดน้อย (0) ไม่เป็นที่พอใจ - พบการรายงานผลผิดพลาดมาก		
2	การให้บริการ	(20) เป็นที่พอใจ - ให้บริการและตอบสนองความต้องการ ได้สม่ำเสมอ (10) ขอมรับได้ - ให้บริการและตอบสนองความต้องการ ได้บ้าง (0) ไม่เป็นที่พอใจ - ให้บริการและตอบสนองความต้องการ ได้ไม่ดี/ต้องคอยติดตาม		
3	ราคาค่าบริการ	(20) เป็นที่พอใจ - ราคาค่ากว่าผู้ให้บริการอื่น (10) ขอมรับได้ - ราคาค่ากว่าผู้ให้บริการอื่นเป็นจนวนใหญ่ (0) ไม่เป็นที่พอใจ - ราคาส่งกว่าผู้ให้บริการรายอื่นๆ		
4	กำหนดการส่งมอบผลการทดสอบ/บริการ	(20) เป็นที่พอใจ - ทันตามเวลาที่กำหนด (+/- 13 วัน) (10) ขอมรับได้ - ทันตามเวลาที่กำหนด (+/- 15 วัน) แต่ไม่เกิน (+/- 30 วัน) (0) ไม่เป็นที่พอใจ - ไม่ทันตามเวลาที่กำหนด		
5	ระบบคุณภาพของห้องปฏิบัติการทดสอบ	(20) เป็นที่พอใจ - ได้รับรองรับรองความสามารถของห้องปฏิบัติการทดสอบตามมาตรฐาน ISO/IEC 17025 (10) ขอมรับได้ - ได้รับรองรับรองความสามารถของห้องปฏิบัติการทดสอบตามมาตรฐาน ISO 9000 (0) ไม่เป็นที่พอใจ - มีระบบคุณภาพแต่อยู่ระหว่างการดำเนินการ		
เกณฑ์การประเมิน			คะแนนรวม	
<ul style="list-style-type: none"> <li>- 80 คะแนนขึ้นไป จาก 100 คะแนน จะผ่านเกณฑ์และให้คงไว้ใน Approved Suppliers list</li> <li>- ต่ำกว่า 80 คะแนน ไม่เป็นที่น่าพอใจ และสมควรให้ถอนรายชื่อออกจาก Approved Suppliers list</li> </ul>			ผลการประเมิน	
ข้อคิดเห็นจากผู้คัดเลือก / สรุปผลการประเมิน <input type="checkbox"/> เป็นที่พอใจและสมควรให้ใช้บริการต่อไป <input type="checkbox"/> สมควรให้ถอนรายชื่อออกจาก ASL <input type="checkbox"/> อื่นๆ _____		ความคิดเห็นของผู้จัดการห้องปฏิบัติการทดสอบ _____ _____ _____		
ลงชื่อ _____ ( _____ ) Date ____ / ____ / ____		ลงชื่อ _____ ( _____ ) Date ____ / ____ / ____		

ภาคผนวก ข.9

---

**เอกสารการจัดทำ VOCs Emission Inventory**

## แบบรายงานผลการตรวจวัดการรั่วซึมของสารอินทรีย์ระเหยจากอุปกรณ์

และการซ่อมแซมอุปกรณ์ในโรงงานอุตสาหกรรม

(๑ แบบรายงานต่อ ๑ โรงงาน)

ประจำปี พ.ศ. 2567..... ครั้งที่ 1.....

( Complete )

ประจำช่วงเดือน มกราคม..... พ.ศ. 2567..... ถึง มิถุนายน..... พ.ศ. 2567.....

## รายละเอียดเกี่ยวกับโรงงาน

ชื่อโรงงาน..... บริษัท อูเมะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน).....ทะเบียนโรงงานเลขที่..... ข3-44-1/39รย

สถานที่ตั้งโรงงาน 140/6 หมู่ 4 ต.ตะพง อ.เมือง จ.ระยอง 21000.....

ปริมาณสารอินทรีย์ระเหยรวมที่มีหรือใช้ในกระบวนการผลิต..... 60,906.....ตันต่อปี

ประเภทอุปกรณ์	สถานะสารอินทรีย์ระเหย	จำนวนอุปกรณ์ทั้งหมดของโรงงาน		จำนวนอุปกรณ์ที่ต้องตรวจวัดการรั่วซึมในรอบการรายงานครั้งนี้			ปริมาณสารอินทรีย์ระเหยรวมในรูปมีเทนที่รั่วซึมจากอุปกรณ์ที่ตรวจวัดการรั่วซึมทั้งหมดในรอบการรายงานครั้งนี้ (กิโลกรัม)
		จำนวนอุปกรณ์ที่ต้องตรวจวัดการรั่วซึม	จำนวนอุปกรณ์ที่ได้รับการยกเว้นไม่ต้องตรวจวัดการรั่วซึม	จำนวนอุปกรณ์ที่ตรวจวัดการรั่วซึมทั้งหมด	จำนวนอุปกรณ์ที่มีผลการตรวจวัดเกินจากเกณฑ์การควบคุมการรั่วซึม	จำนวนอุปกรณ์ที่ได้รับการซ่อมแซมให้อยู่ในเกณฑ์การควบคุมการรั่วซึม	
		(จุด)	(จุด)	(จุด)	(จุด)	(จุด)	
วาล์ว (Valves)	แก๊ส	34	95	34	0	0	12.29
	ของเหลว	830	1,340	830	0	0	
ปั๊ม (Pumps)	ของเหลว	18	19	18	0	0	
อุปกรณ์ลดความดัน (Pressure Relief Devices)	แก๊ส	3	20	3	0	0	
	ของเหลว	4	17	4	0	0	
เครื่องอัดอากาศ (Compressors)	ทั้งหมด	0	0	0	0	0	
ข้อต่อหรือหน้าแปลน (Connectors or Flanges)	ทั้งหมด	1,658	2,205	1,658	0	0	
ท่อส่งปลายเปิด (Open-Ended Lines)	ทั้งหมด	30	37	30	0	0	
จุดเก็บตัวอย่างสารเคมี (Sampling Connections)	ทั้งหมด	2	0	2	0	0	
อุปกรณ์ที่ใช้กวนหรือผสมของเหลว (Agitators or Mixers)	ทั้งหมด	3	2	3	0	0	

(ลงชื่อ) .....  
(.....)

ผู้จัดการสิ่งแวดล้อมหรือผู้ได้รับอนุญาตประกอบกิจการโรงงาน

ภาคผนวก ข.10

---

เอกสารสอบเทียบอุปกรณ์  
ของระบบตรวจวัดคุณภาพอากาศจากปล่องแบบต่อเนื่อง (CEMS)

Work Report		UBE	
Work Order NO.	Plant	Work Team	Date
	CPL	INST-04	29/02/67
Work Order Description			
<h1>PM 1M Inspection and Calibration</h1> <p>AT-45-202      AT-12-301      AT-12-302 A&amp;B</p>			
List	Report by	Approve by	
Signature			
Name			
Date	29/02/2567	29/02/2024	

Save to IPAD

Send Update

Close Work

# PM 1M Inspection and Calibration

**UBE**  
UBE GROUP (THAILAND)

Tag No.	AT-1000 (NO)	Reading	New Gas Value	Adjustment	Hard Point Reading (NO)
Measurement	As Is	Units	AS-1000	Range	0.00 ppm
Exp. No.	Date: 2022-11-11 11:00:00 AM / 11:00:00 AM / 11:00:00 AM			Inspector: T. J. J.	100%

Standard Gas (ppm)	Serial No.	Certificate No.	Expired Date
Zero Gas, Nitrogen :	0	-	-
Span Gas NO2 :	255.00	3696/22	D878128
			2567/11/22

As Found

Allowable Error: 10.00 ppm

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
Zero Gas :	0.00	-1.00	-10.00	Pass
Span Gas :	255.00	235.00	-200.00	Fault

35.00

As Left

Allowable Error: 10.00 ppm

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
Zero Gas :	0.00	0.00	0.00	Pass
Span Gas :	255.00	255.00	0.00	Pass

43.00

Remarks:

Tag No.	AT-1000 (NO)	Reading	New Gas Value	Adjustment	Hard Point Reading (NO)
Measurement	As Is	Units	AS-1000	Range	0.00 ppm
Exp. No.	Date: 2022-11-11 11:00:00 AM / 11:00:00 AM / 11:00:00 AM			Inspector: T. J. J.	100%

Standard Gas (ppm)	Serial No.	Certificate No.	Expired Date
Zero Gas, Nitrogen :	0	-	-
Span Gas NO2 :	76.00	3693/22	A00560VS
			2569/11/28

As Found

Allowable Error: 5.00 ppm

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
Zero Gas :	0.00	-1.50	-30.00	Pass
Span Gas :	76.00	76.90	18.00	Pass

1.90

As Left

Allowable Error: 5.00 ppm

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
Zero Gas :	0.00	0.00	0.00	Pass
Span Gas :	76.00	-1520.00	Fault	3.30

Remarks:

Work Order NO.		Plant	Work Team	Date
50211477		CPL	INST-04	20/03/87
Work Order Description				
<p align="center"><b>PM 1M Inspection and Calibration</b></p> <p align="center">AT-45-202      AT-12-301      AT-12-302 A&amp;B</p>				
<b>List</b>	<b>Report by</b>	<b>Approve by</b>		
<b>Signature</b>				
<b>Name</b>				
<b>Date</b>	20/03/2587	20/03/2024		

Save to IPAD

Send Update

Close Work

# PM 1M Inspection and Calibration

**UGE**  
UGE GROUP (THAILAND)

Tag No.	AT-4000 (ppm)	Service	New GDS Outlet	Equipment	Micro Reader Analyser (ppm)
Manufacturer	Age	Model	Accessories	Range	0.1-500 ppm
Serial No.	P/N: 2100-01-1110000000 / P/N: 2100-01-00000000 / P/N: 1100-01-00000000			Adjusted Temp	1000 °C

Standard Gas (ppm)	Serial No.	Certificate No.	Expired Date
--------------------	------------	-----------------	--------------

Zero Gas, Nitrogen :	0	-	-
----------------------	---	---	---

Span Gas NO <sub>2</sub> :	250.00	3696/22	D878128	2567/11/22
----------------------------	--------	---------	---------	------------

As Found			Allowable Error:	10.00 ppm
----------	--	--	------------------	-----------

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
--------------------	---------------	-----------	--------	-----------------

Zero Gas :	0.00	-0.10	-1.00	Pass	35.00
------------	------	-------	-------	------	-------

Span Gas :	250.00	247.00	-30.00	Pass
------------	--------	--------	--------	------

As Left			Allowable Error:	10.00 ppm
---------	--	--	------------------	-----------

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
--------------------	---------------	-----------	--------	-----------------

Zero Gas :	0.00	0.00	0.00	Pass	40.00
------------	------	------	------	------	-------

Span Gas :	250.00	-2500.00	-2500.00	Fault
------------	--------	----------	----------	-------

Remark:					
---------	--	--	--	--	--

Tag No.	AT-4000 (ppm)	Service	New GDS Outlet	Equipment	Micro Reader Analyser (ppm)
Manufacturer	Age	Model	Accessories	Range	0.1-500 ppm
Serial No.	P/N: 2100-01-1110000000 / P/N: 2100-01-00000000 / P/N: 1100-01-00000000			Adjusted Temp	1000 °C

Standard Gas (ppm)	Serial No.	Certificate No.	Expired Date
--------------------	------------	-----------------	--------------

Zero Gas, Nitrogen :	0	-	-
----------------------	---	---	---

Span Gas NO <sub>2</sub> :	76.00	3693/22	A00560SV	2567/11/29
----------------------------	-------	---------	----------	------------

As Found			Allowable Error:	5.00 ppm
----------	--	--	------------------	----------

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
--------------------	---------------	-----------	--------	-----------------

Zero Gas :	0.00	-0.10	-2.00	Pass	0.40
------------	------	-------	-------	------	------

Span Gas :	76.00	77.00	20.00	Pass
------------	-------	-------	-------	------

As Left			Allowable Error:	5.00 ppm
---------	--	--	------------------	----------

Standard Gas (ppm)	Reading (ppm)	% OffSpec	Result	Process Reading
--------------------	---------------	-----------	--------	-----------------

Zero Gas :	0.00	0.00	0.00	Pass	0.60
------------	------	------	------	------	------

Span Gas :	76.00	-1520.00	-1520.00	Fault
------------	-------	----------	----------	-------

Remark:					
---------	--	--	--	--	--

Work Report				UBG											
Work Order NO.	Plant	Work Team	Date												
50212957	CPL	INST-04	30/04/24												
Work Order Description															
PM 1M Inspection and Calibration															
AT-45-202		AT-12-301		AT-12-302 A&B											
<table><tr><td>List</td><td>Report by</td><td>Approve by</td></tr><tr><td>Signature</td><td colspan="2" rowspan="3"></td></tr><tr><td>Name</td></tr><tr><td>Date</td></tr><tr><td></td><td>30/04/2024</td><td>30/04/2024</td></tr></table>					List	Report by	Approve by	Signature			Name	Date		30/04/2024	30/04/2024
List	Report by	Approve by													
Signature															
Name															
Date															
	30/04/2024	30/04/2024													
<div>Save to IPADSend UpdateClose Work</div>															

PM 1M Inspection and Calibration						UBG
Tag No.	AT-45-202 (NO)	Service :	Nox GAS Outlet	Equipment:	Nitric Oxide Analyzer (NO)	
Manufacturer :	ABB	Model :	A02040	Range :	0 - 500 ppm	
S/N No. :	P-No : 240210-111000000000 / A-No : 0240183063100 / F-No : 3.390788.8			Ambient Temp:	10-35 °C	
Standard Gas (ppm)		Serial No.		Certificate No.	Expired Date	
Zero Gas, Nitrogen :	0	-		-	-	
Span Gas NO :	255.00	3696/22	D878128	2024/11/22		
As Found					Allowable Error: 10.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :	0.00	-1.00		-10.00	Pass	
Span Gas :	255.00	245.00		-100.00	Fault	
As Left					Allowable Error: 10.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :	0.00	0.00		0.00	Pass	
Span Gas :	255.00	255.00		0.00	Pass	
Remark:						
Tag No.:	AT-45-202 (NO2)	Service :	Nox GAS Outlet	Equipment:	Nitric Oxide Analyzer (NO2)	
Manufacturer :	ABB	Model :	A02040	Range :	0 - 100 ppm	
S/N No. :	P-No : 240210-111000000000 / A-No : 0240183063100 / F-No : 3.390788.8			Ambient Temp:	10-35 °C	
Standard Gas (ppm)		Serial No.		Certificate No.	Expired Date	
Zero Gas, Nitrogen :	0	-		-	-	
Span Gas NO2 :	78.00	3693/22	A00560VS	2026/11/28		
As Found					Allowable Error: 5.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :	0.00	-1.00		-20.00	Pass	
Span Gas :	78.00	78.80		16.00	Pass	
As Left					Allowable Error: 5.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :				0.00	Pass	
Span Gas :	78.00			-1520.00	Fault	
Remark:						

Work Report				UBG											
Work Order NO.	Plant	Work Team	Date												
50207890	CPL	INST-04	23/01/67												
Work Order Description															
PM 1M Inspection and Calibration															
AT-45-202		AT-12-301		AT-12-302 A&B											
<table><tr><td>List</td><td>Report by</td><td>Approve by</td></tr><tr><td>Signature</td><td colspan="2" rowspan="3"></td></tr><tr><td>Name</td></tr><tr><td>Date</td></tr><tr><td></td><td>23/01/2567</td><td>23/01/2024</td></tr></table>					List	Report by	Approve by	Signature			Name	Date		23/01/2567	23/01/2024
List	Report by	Approve by													
Signature															
Name															
Date															
	23/01/2567	23/01/2024													
<div>Save to IPADSend UpdateClose Work</div>															

PM 1M Inspection and Calibration						UBG
Tag No.	AT-45-202 (NO)	Service :	Nox GAS Outlet	Equipment:	Nitric Oxide Analyzer (NO)	
Manufacturer :	ABB	Model :	A02040	Range :	0 - 500 ppm	
S/N No. :	P-No : 240210-111000000000 / A-No : 0240183063100 / F-No : 3.390788.8			Ambient Temp:	10-35 °C	
Standard Gas (ppm)		Serial No.		Certificate No.	Expired Date	
Zero Gas, Nitrogen :	0	-		-	-	
Span Gas NO :	255.00	3696/22	D878128	2567/11/22		
As Found					Allowable Error: 10.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :	0.00	0.00		0.00	Pass	
Span Gas :	255.00	250.00		-50.00	Pass	
As Left					Allowable Error: 10.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :	0.00			0.00	Pass	
Span Gas :	255.00			-2550.00	Fault	
Remark:						
Tag No.:	AT-45-202 (NO2)	Service :	Nox GAS Outlet	Equipment:	Nitric Oxide Analyzer (NO2)	
Manufacturer :	ABB	Model :	A02040	Range :	0 - 100 ppm	
S/N No. :	P-No : 240210-111000000000 / A-No : 0240183063100 / F-No : 3.390788.8			Ambient Temp:	10-35 °C	
Standard Gas (ppm)		Serial No.		Certificate No.	Expired Date	
Zero Gas, Nitrogen :	0	-		-	-	
Span Gas NO2 :	78.00	3693/22	A00560VS	2567/11/28		
As Found					Allowable Error: 5.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :	0.00	-1.00		-20.00	Pass	
Span Gas :	78.00	77.00		20.00	Pass	
As Left					Allowable Error: 5.00 ppm	
Standard Gas (ppm)		Reading (ppm)		% OffSpec	Result	
Zero Gas :	0.00			0.00	Pass	
Span Gas :	78.00			-1520.00	Fault	
Remark:						

ภาคผนวก ข.11

---

เอกสารตรวจสอบความถูกต้องของ CEMS (RATA)

# Relative Accuracy Determination for CEMS : UBE Chemical (Asia) Public Co., Ltd.: Waste Gas Treatment Off Gas

DATE

September 20,2023

Run No.	Time		O <sub>2</sub>	NO <sub>x</sub>		
	Start	End	%	ppm@7% O <sub>2</sub>		
			Instrumental RM	Instrumental RM	CEMS	Diff(d <sub>i</sub> )
1	11:10 AM	11:30 AM	5.73	63.60	74.84	-11.24
2	11:31 AM	11:51 AM	5.67	59.93	52.70	7.23
3	11:52 AM	12:12 PM	5.64	54.06	58.05	-3.99
4	12:13 PM	12:33 PM	5.62	45.21	46.96	-1.75
5	12:55 PM	1:15 PM	5.57	56.07	48.34	7.73
6	1:16 PM	1:36 PM	5.60	56.84	58.29	-1.44
7	1:37 PM	1:57 PM	5.58	59.89	53.72	6.17
8	1:58 PM	2:18 PM	5.53	77.39	75.31	2.08
9	2:40 PM	3:00 PM	5.55	73.32	60.10	13.22
10	3:01 PM	3:21 PM	5.51	104.80	98.08	6.72
11	3:22 PM	3:42 PM	5.56	119.52	111.03	8.49
12	3:43 PM	4:03 PM	5.60	56.92	95.09	-38.18
Average			5.60	68.96	69.37	-0.41
Confidence Coefficient			-	8.6722		
Relative Accuracy			-	5.59		
Performance Specification : RA			-	10%**		

\* Instrumental RM and CEMS data are on a consistent basis, that is, dry and actual oxygen.

\*\* 10% of Emission Standard value (162.5 ppmvd@7%O<sub>2</sub> for NO<sub>x</sub>)




ภาคผนวก ข.12

---


เอกสารบันทึก CEMS

ระหว่างเดือนมกราคม ถึงมิถุนายน พ.ศ.2567

ผลการตรวจวัด NO<sub>x</sub> จาก CEMs ระหว่างเดือนมกราคม ถึงมิถุนายน พ.ศ.2567




เดือนมกราคม




เดือนกุมภาพันธ์

ที่มา : โครงการโรงงานผลิตคาโปรแลคตัมฯ บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)

ผลการตรวจวัด NO<sub>x</sub> จาก CEMs ระหว่างเดือนมกราคม ถึงมิถุนายน พ.ศ.2567 (ต่อ)



เดือนมีนาคม




เดือนเมษายน


ที่มา : โครงการโรงงานผลิตคาโปรแลคตั้มฯ บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)



ผลการตรวจวัด NO<sub>x</sub> จาก CEMs ระหว่างเดือนมกราคม ถึงมิถุนายน พ.ศ.2567 (ต่อ)



เดือนพฤษภาคม



เดือนมิถุนายน

ที่มา : โครงการโรงงานผลิตคาโปรแลคตัมฯ บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)

ภาคผนวก ข.13

---

PM Plan ประจำปี พ.ศ.2567



## CPL Plant

Issue date : 29/01/2024

**clarification sheet**  
 id: Jm24-Dec'24


[illegible]

## Summary of PM change in FY2024

Plant

Count of Source

### Quantity of PM Change & Reason for FY2024




## Summary of PM change in FY2024

Plant

Count of Source


### Activity on each Equipment Ranking



Plant

Count of Purpose of Change


### Quantity of purpose for PM Change in FY2024



Plant

Count of Purpose of Change


### Adjustment on each Equipment Ranking



## Update : 01/07/2024 15:22

01/01/2024 15:22

Place subject here: " " " " " "

P:\19CAE\_KPT\HTN\PM Master Plan\DN\_Master Plan : PM\_Master Plan



## Update: 01/03/2024 15:21

**Update :**

01/03/2024 15:21


பின்வரும் உரைகள் பொருள்: 1) 2) 3) 4)



- |                |   |  |
|----------------|---|--|
| CreatedMO      | = | Create Work Order Completed                              |
| OnHoldOrder    | = | Waiting Create Work Order                                |
| CompletedMO    | = | Work Order Completed                                     |
| StartedPlan    | = | PM Plan Start Completed (New PM Plan or Restart PM Plan) |
| Scheduled Hold | = | Waiting Create Work Order Next Cycle                     |

P:\9CAE\_KPT\MTD\PM Master Plan\VTN\_Master Plan : PM\_Master Plan

Plasma select here:

P:\9CAE\_XPT\MTN\PM Master Plan\PM\_Master Plan : PM\_Master Plan

## Update: 01/03/2024 15:21

01/03/2024 15:21

Bitte selektieren:

CreatedMO	=	Create Work Order Completed
OnHoldOrder	=	Waiting Create Work Order
CompletedMO	=	Work Order Completed
StartedPlan	=	PM Plan Start Completed (New PM Plan or Restart PM Plan)
Scheduled Hold	=	Waiting Create Work Order Next Cycle

P:\9CAE\_KPI\MTN\PM Master Plan\PM\_Master Plan : PM\_Master Plan



## Update : 01/07/2024 13:21

**Update :**

These are the results:



- |                 |   |  |
|-----------------|---|--|
| CreatedMO       | = | Create Work Order Completed                              |
| OnHoldOrder     | = | Waiting Create Work Order                                |
| CompletedMO     | = | Work Order Completed                                     |
| StartedPlan     | = | PM Plan Start Completed (New PM Plan or Restart PM Plan) |
| Scheduled Field | = | Waiting Create Work Order Next Cycle                     |

100390	100390	PH 1H ADJUST GLAND PACKING (GENERAL EQ)		1H	CreatedMO OnHoldOrder CreatedMO	2011 2011 2020																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		</
--------	--------	---	--	----	---------------------------------------	----------------------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

# PM MASTER PLAN 2024

Update : 06/02/2024 15:21

User	(Nil)
Site	CPI
Worktype	MECH

Please select here! 11/11/11



- CreateWO = Create Work Order Completed
- OnHoldOrder = Waiting Create Work Order
- CompletedWO = Work Order Completed
- StartedPlan = PM Plan Start Completed (New PM Plan or Restart PM Plan)
- Scheduled Hold = Waiting Create Work Order Next Cycle

Item No	Item Name	Item Description	Item Category	Item Unit	Item Quantity	Item Status	Item Date	Item Time	Item Location	Item Notes
10004579	A	103552	106537	PM 3Y Overhaul Pump 1410-P08	PUMP, HORIZONTAL END SUCTION	3Y	CreateWO	2018	2018	
10004580	B	102390	103194	PM 3Y Major overhaul pump 1410-P10	PUMP, HORIZONTAL END SUCTION	3Y	OnHoldOrder	2018	2018	
10004601	A	103154	106538	PM 3Y Overhaul Pump 1410-P15A	PUMP, HORIZONTAL END SUCTION	3Y	CompletedWO	2018	2018	
10004608	A	103555	106539	PM 3Y Overhaul Pump 1410-P15B	PUMP, HORIZONTAL END SUCTION	3Y	OnHoldOrder	2018	2018	
10004611	A	103952	106527	PM 3Y OVERHAUL PUMP 1410-P16A	PUMP, HORIZONTAL END SUCTION	3Y	CompletedWO	2020	1900	
10024968	B	102568	103176	PM 3Y Major overhaul pump 1410-P18	PUMP, HORIZONTAL END SUCTION	3Y	OnHoldOrder	2018	2018	
10024978	A	200020	300176	PM 3Y MAJOR OVERHAUL PUMP	PUMP, HORIZONTAL END SUCTION	3Y	OnHoldOrder	2018	1900	
10004626	A	102391	103195	PM 3Y Overhaul driving unit 1410-Q1	CONVEYOR, TROUGHED BELT	3Y	CreateWO	2018	2018	
		102392	103196	PM 3Y Replace conveyor belt 1410-Q1	CONVEYOR, TROUGHED BELT	3Y	OnHoldOrder	2018	2018	
		200080	300241	PM 15N REPLACE PRIMARY SCRAPER 1410-Q01	CONVEYOR, TROUGHED BELT	15H	OnHoldOrder	2018	1900	
10004628	A	102393	103197	PM 3Y Overhaul driving unit 1410-Q3	CONVEYOR, TROUGHED BELT	3Y	CompletedWO	2018	2018	
		102394	103198	PM 3Y Replace conveyor belt 1410-Q3	CONVEYOR, TROUGHED BELT	3Y	OnHoldOrder	2018	2018	
10004629	A	102395	103199	PM 3Y Overhaul driving unit 1410-Q3_1	CONVEYOR, TROUGHED BELT	3Y	CompletedWO	2018	2018	
		102397	103201	PM 3Y Replace conveyor belt 1410-Q3_1	CONVEYOR, TROUGHED BELT	3Y	OnHoldOrder	2018	2018	
10004632	A	100515	100515	PM 3Y INTERNAL INSPECTION	CONVEYOR, BUCKET ELEVATOR	3Y	OnHoldOrder	2018	2018	
		102396	103200	PM 3Y Overhaul driving unit 1410-Q4	CONVEYOR, BUCKET ELEVATOR	3Y	CompletedWO	2018	2018	
		102398	103202	PM 3Y Replace conveyor belt 1410-Q4	CONVEYOR, BUCKET ELEVATOR	3Y	OnHoldOrder	2018	2018	
10004634	A	102399	103203	PM 3Y Overhaul driving unit 1410-Q6	CONVEYOR, TROUGHED BELT	3Y	CompletedWO	2018	2018	
		102400	103204	PM 3Y Replace conveyor belt 1410-Q6	CONVEYOR, TROUGHED BELT	3Y	OnHoldOrder	2018	2018	
10004636	A	102401	103205	PM 3Y Overhaul driving unit 1410-Q7	CONVEYOR, TROUGHED BELT	3Y	CompletedWO	2018	2018	
		102402	103206	PM 3Y Replace conveyor belt 1410-Q7	CONVEYOR, TROUGHED BELT	3Y	OnHoldOrder	2018	2018	
10004642	A	102418	103242	PM 3Y Filter overhaul 1410-S4-1	SEPARATOR, VIBRATING SCREEN	3Y	OnHoldOrder	2018	2018	
		102439	103243	PM 6Y Major overhaul 1410-S4-1	SEPARATOR, VIBRATING SCREEN	6Y	OnHoldOrder	2018	2018	
		102473	103277	PM 1Y REPLACE DRIVING BELT 1410-S4-1	SEPARATOR, VIBRATING SCREEN	1Y	OnHoldOrder	2018	2018	
		200008	300711	PM 1H RETIGHTEN SCREEN 1410-S04_1	SEPARATOR, VIBRATING SCREEN	1H	OnHoldOrder	2018	1900	
10004667	A	102102	102893	PM 1Y REPLACE DRIVING BELT 1410-S4-2	SEPARATOR, VIBRATING SCREEN	1Y	OnHoldOrder	2018	2018	
		102440	103244	PM 3Y Filter overhaul 1410-S4-2	SEPARATOR, VIBRATING SCREEN	3Y	OnHoldOrder	2018	2018	
		102441	103245	PM 6Y Major overhaul 1410-S4-2	SEPARATOR, VIBRATING SCREEN	6Y	OnHoldOrder	2018	2018	
		200020	300710	PM 1H RETIGHTEN SCREEN 1410-S04-2	SEPARATOR, VIBRATING SCREEN	1H	OnHoldOrder	2018	1900	
10004669	B	102443	103247	PM 3Y Major overhaul 1410-S5	SEPARATOR, CENTRAL CONE SCREEN	3Y	OnHoldOrder	2018	2018	
		104637	109910	PM 15N INTERNAL INSPECT & REPLACE SCREEN	SEPARATOR, CENTRAL CONE SCREEN	15H	OnHoldOrder	2018	2018	
10004672	B	100428	100428	PM 3Y OVERHAUL OIL PUMP OF CENTRIFUGE	PUMP, PISTON PLUNGER	3Y	CompletedWO	2021	2020	
10004675	A	102445	103249	PM 3Y Major overhaul 1410-S6	SEPARATOR, CENTRAL CONE SCREEN	3Y	OnHoldOrder	2018	2018	

## Update : 01/03/2024 15:21

Year	(AN)
Site	CPL
Method	MECH

Press select home



- |                |   |  |
|----------------|---|--|
| CreatedMO      | = | Create Work Order Completed                              |
| OnHoldOrder    | = | Waiting Create Work Order                                |
| CompletedMO    | = | Work Order Completed                                     |
| StartedPlan    | = | PM Plan Start Completed (New PM Plan or Restart PM Plan) |
| Scheduled Hold | = | Waiting Create Work Order Next Cycle                     |

[illegible]



Year	(All)
Site	CPL
MinDep	MECH

- |                |   |  |
|----------------|---|--|
| CreatedMO      | = | Create Work Order Completed                              |
| OnHoldOrder    | = | Waiting Create Work Order                                |
| CompletedMO    | = | Work Order Completed                                     |
| StartedPlan    | = | PM Plan Start Completed (New PM Plan or Restart PM Plan) |
| Scheduled Hold | = | Waiting Create Work Order Next Cycle                     |

P:\19CAE\_KPD\NTN\PM Master Plan\PM Master Plan : PM Master Plan

# PM MASTER PLAN 2024

Update 1

04/09/2024 15:51

Year	(All)
Site	CPL
WTD/Dept	MECH

Please select here: [P] [M] [B]



- CreatedMO = Create Work Order Completed
- OnHoldOrder = Waiting Create Work Order
- CompletedMO = Work Order Completed
- StartedPlan = PM Plan Start Completed (New PM Plan or Restart PM Plan)
- Scheduled Hold = Waiting Create Work Order Next Cycle

Item	Year	Month	Day	PM ID	PM Description	Equipment	Location	Category	Status	CreatedMO	OnHoldOrder	CompletedMO	StartedPlan	Scheduled Hold
100379	2024	03	10	100379	PM 1H ADJUST GLAND PACKING (ELBOW PUMP)	ELBOW PUMP	1H	CreatedMO	2024	03	10			
100506	2024	03	10	100506	PM 1H INSPECT BELT CONVEYOR	BELT CONVEYOR	1H	CreatedMO	2024	03	10			
1005147	2024	03	10	1005147	PM 3Y Major overhaul 1450-B1	BLOWER/FAN, CENTRI, S-STG	3Y	CreatedMO	2024	03	10			
1005149	2024	03	10	1005149	PM 3Y Major overhaul 1450-B2	BLOWER/FAN, CENTRI, S-STG	3Y	CreatedMO	2024	03	10			
1005151	2024	03	10	1005151	PM 3Y INTERNAL INSPECTION FIB	DRYER, FLUIDIZED-BED CONVEYOR	1Y	CreatedMO	2024	03	10			
1005171	2024	03	10	1005171	PM 1H INSPECT COMPRESSOR	COMPRESSOR, INTEG. GEAR, S-STG	1H	CreatedMO	2024	03	10			
1005215	2024	03	10	1005215	PM 3Y Major overhaul pump 1450-P1A	PUMP, HORIZONTAL END SUCTION	3Y	CreatedMO	2024	03	10			
1005220	2024	03	10	1005220	PM 3Y Major overhaul pump 1450-P1B	PUMP, HORIZONTAL END SUCTION	3Y	CreatedMO	2024	03	10			
1005224	2024	03	10	1005224	PM 3Y Major overhaul pump 1450-P2A	PUMP, HORIZONTAL END SUCTION	3Y	CreatedMO	2024	03	10			
1005228	2024	03	10	1005228	PM 3Y Major overhaul pump 1450-P2B	PUMP, HORIZONTAL END SUCTION	3Y	CreatedMO	2024	03	10			
1005277	2024	03	10	1005277	PM 3Y Major Overhaul pump 1450-P8	PUMP, ELBOW PROPELLER	3Y	CreatedMO	2024	03	10			
1005280	2024	03	10	1005280	PM 3Y Major overhaul pump 1450-P9A	PUMP, HORIZONTAL END SUCTION	3Y	CreatedMO	2024	03	10			
1005289	2024	03	10	1005289	PM 3Y Major overhaul pump 1450-P9B	PUMP, HORIZONTAL END SUCTION	3Y	CreatedMO	2024	03	10			
1005292	2024	03	10	1005292	PM 3Y Major Overhaul pump 1450-P10	PUMP, ELBOW PROPELLER	3Y	CreatedMO	2024	03	10			
1005294	2024	03	10	1005294	PM 3Y Overhaul driving unit 1450-Q1	CONVEYOR, TROUGHED BELT	3Y	CreatedMO	2024	03	10			
1005296	2024	03	10	1005296	PM 3Y Overhaul driving unit 1450-Q2	CONVEYOR, TROUGHED BELT	3Y	CreatedMO	2024	03	10			
1005300	2024	03	10	1005300	PM 3Y Major overhaul 1450-S1	SEPARATOR, CENTRI CONE SCREEN	3Y	CreatedMO	2024	03	10			
1005305	2024	03	10	1005305	PM 3Y OVERHAUL OIL PUMP OF CENTRIFUGE	PUMP, PISTON PLUNGER	3Y	CreatedMO	2024	03	10			
1005308	2024	03	10	1005308	PM 3Y PM Overhaul oil pump 1450-S08-P01	LUBE OIL PUMP OF 1450-S8	3Y	CreatedMO	2024	03	10			
1005376	2024	03	10	1005376	PM 3Y OVERHAUL PUSHER CENTRIFUGE	CENTRIFUGE, PUSHER TYPE	3Y	CreatedMO	2024	03	10			
1005379	2024	03	10	1005379	PM 3Y OVERHAUL PUSHER OIL PUMP	OIL PUMP OF 1450-S10	3Y	CreatedMO	2024	03	10			
1005421	2024	03	10	1005421	PM 3H INSPECT CONVEYOR 1460	CONVEYOR, TROUGHED BELT	1H	CreatedMO	2024	03	10			
1005472	2024	03	10	1005472	PM 3Y Major overhaul 1460-B1	BLOWER/FAN, CENTRI, S-STG	3Y	CreatedMO	2024	03	10			
1005479	2024	03	10	1005479	PM 3Y Major overhaul 1460-B2	BLOWER/FAN, CENTRI, S-STG	3Y	CreatedMO	2024	03	10			
1005484	2024	03	10	1005484	PM 3Y Major overhaul 1460-B3	BLOWER/FAN, CENTRI, S-STG	3Y	CreatedMO	2024	03	10			
1005490	2024	03	10	1005490	PM 3Y Major overhaul 1460-B4	BLOWER/FAN, CENTRI, S-STG	3Y	CreatedMO	2024	03	10			
1005492	2024	03	10	1005492	PM 3Y Major overhaul 1460-B5	BLOWER/FAN, CENTRI, S-STG	3Y	CreatedMO	2024	03	10			



Update : 01/03/2004 15:24

Update :

01/03/2014 15:21

Find out more here: [www.123.gov.uk](http://www.123.gov.uk)



CreatedMO	=	Create Work Order Completed
OnHoldOrder	=	Waiting Create Work Order
CompletedMO	=	Work Order Completed
StartedPlan	=	PM Plan Start Completed (New PM Plan or Restart PM Plan)
Scheduled Hold	=	Waiting Create Work Order Next Cycle

P:39CAE KPD02T0PH Master Plan/PH Master Plan : PH Master Plan

Yes ☒ No ☐ **AD**

1. The first step is to identify the problem or question that needs to be answered. This involves understanding the context and the specific requirements of the task.

\_\_\_\_\_



CreatedMO = Create Work Order Completed  
OnHoldOrder = Waiting Create Work Order  
CompletedMO = Work Order Completed  
StartedPlan = PM Plan Start Completed (New PM Plan or Restart PM Plan)  
Scheduled Hold = Waiting Create Work Order Next Cycle

[illegible]

# PM MASTER PLAN 2024

Update : 04/09/2024 15:25

Year	(All)
Site	CPL
PM Dept	MECH

Please select here: "Y" "N" "H"



- CreateWO = Create Work Order Completed
- OnHoldOrder = Waiting Create Work Order
- CompletedWO = Work Order Completed
- StartedPlan = PM Plan Start Completed (New PM Plan or Restart PM Plan)
- Scheduled Hold = Waiting Create Work Order Next Cycle

PM Plan ID	PM Plan Name	PM Plan Type	PM Plan Category	PM Plan Sub-Category	PM Plan Description	PM Plan Status	PM Plan Start Date	PM Plan End Date	PM Plan Duration	PM Plan Frequency	PM Plan Priority	PM Plan Owner	PM Plan Manager	PM Plan Created By	PM Plan Created Date	PM Plan Last Modified By	PM Plan Last Modified Date	PM Plan Next Cycle	PM Plan Next Cycle Date	PM Plan Next Cycle Status
1001286	PM 3Y MAJOR OVERHAUL TURBINE 4140-B1-T1	A	100325	100325	STEAM TURBINE, M-CONDEN, H-STG	3Y	OnHoldOrder	2011	2021	10	Y									
1002424	PM 3Y OVERHAUL FAN BLOWER 4140-B4	A	102933	102797	BLOWER/FAN, CENTRL, S-STG	3Y	OnHoldOrder	2011	2021	10	Y									
1002514	PM 3Y OVERHAUL FAN BLOWER 4140-B5	A	102227	104147	BLOWER/FAN, CENTRL, S-STG	3Y	OnHoldOrder	2011	2021	10	Y									
10011381	PM 6Y Mechanical cleaning plate heat ex.	A	103527	106479	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106495	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
10011386	PM 6Y Mechanical cleaning plate heat ex.	A	103527	106481	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106496	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
10011391	PM 6Y Mechanical cleaning plate heat ex.	A	103527	106483	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106497	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
10011396	PM 6Y Mechanical cleaning plate heat ex.	A	103527	106485	HEAT EXCHANGER, FIN TUBE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106498	HEAT EXCHANGER, FIN TUBE	6Y	OnHoldOrder	2018	2024	6	Y									
10011400	PM 3Y CLEANSING PLATE HEAT EXCHANGER	A	103264	104999	HEAT EXCHANGER, VOLUME	3Y	OnHoldOrder	2016	2019	3	Y									
10011405	PM 6Y Mechanical cleaning plate heat ex.	A	103527	106487	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106499	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
10011410	PM 6Y Mechanical cleaning plate heat ex.	A	103527	106489	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Inspection plate heat ex.		106490		HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106500	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
10011414	PM 3Y MAJOR OVERHAUL PUMP 4140-P1	A	100341	100341	PUMP, VERTICAL SUMP	3Y	OnHoldOrder	2011	2021	10	Y									
10011417	PM 3Y MAJOR OVERHAUL PUMP 4140-P2	A	100342	100342	PUMP, VERTICAL SUMP	3Y	OnHoldOrder	2011	2021	10	Y									
10011420	PM 3Y MAJOR OVERHAUL PUMP 4140-P3	A	100343	100343	PUMP, VERTICAL SUMP	3Y	OnHoldOrder	2011	2021	10	Y									
10011423	PM 3Y MAJOR OVERHAUL PUMP 4140-P4	A	100344	100344	PUMP, VERTICAL SUMP	3Y	OnHoldOrder	2011	2021	10	Y									
10011426	PM 3Y MAJOR OVERHAUL PUMP 4140-P5	A	100345	100345	PUMP, VERTICAL SUMP	3Y	OnHoldOrder	2011	2021	10	Y									
10025131	PM 3M CHILLER UNIT 4140-CH1 (REC'D)	B	102651	103459	COMPRESSOR, SCREW OIL-FLOOD	3M	OnHoldOrder	2012	2023	1	Y									
10011511	PM 3Y MAJOR OVERHAUL BLOWER 4150-B1	A	100348	100348	COMPRESSOR, SING. SHAFT, S-STG	3Y	OnHoldOrder	2011	2021	10	Y									
10011523	PM 3Y MAJOR OVERHAUL 4150-B1-PLA	A	100361	100361	PUMP, GEAR EXTERNAL	3Y	OnHoldOrder	2011	2021	10	Y									
10011524	PM 3Y MAJOR OVERHAUL 4150-B1-P18	C	100362	100362	PUMP, GEAR EXTERNAL	3Y	OnHoldOrder	2011	2021	10	Y									
10011537	PM 3Y MAJOR OVERHAUL 4150-B1-T1	A	100363	100363	STEAM TURBINE, M-CONDEN, S-STG	3Y	OnHoldOrder	2011	2021	10	Y									
200003	PM 15M MICROSTRUCTURE ANALYSIS KIV BLADE		300102		STEAM TURBINE, M-CONDEN, S-STG	15M	OnHoldOrder	2022	2022	1	Y									
10011580	PM 3Y REPLACE DOORBT 4150-E1TD 4150-E2	A	104011	108595	HEAT EXCHANGER, FIRE TUBE	3Y	OnHoldOrder	2020	2023	3	Y									
10011607	PM 6Y Mechanical cleaning plate heat ex.	B	103527	106491	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106501	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
10011610	PM 6Y Mechanical cleaning plate heat ex.	B	103527	106493	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
	PM 6Y Chemical Cleaning Plate Heat Ex.		103528	106502	HEAT EXCHANGER, PLATE	6Y	OnHoldOrder	2018	2024	6	Y									
10011615	PM 3Y REPLACE EXHAUST 4150-F1 TO 4150-E1	A	104910	108594	FURNACE	3Y	OnHoldOrder	2020	2023	3	Y									
10011669	PM 2Y OVERHAUL BFW PUMP 4150-P4D	B	100376	100376	PUMP, RADIAL SPLIT, H-STG	2Y	OnHoldOrder	2011	2020	9	Y									
10011672	PM 2Y OVERHAUL BFW PUMP 4150-P4C	B	100377	100377	PUMP, RADIAL SPLIT, H-STG	2Y	OnHoldOrder	2011	2020	9	Y									
10011685	PM 3Y INSPECT NOZZLE 4150-G2	A	104215	108800	SCRUBBER, REVERSE JET	3Y	OnHoldOrder	2020	2023	3	Y									
10011718	PM 10Y REPLACE DENSIFIER	A	103690	103957	SEPARATOR, VEST ELIMINATOR	10Y	OnHoldOrder	2016	2026	10	Y									
10011839	PM 3Y Major overhaul 4480-Y2-A1	A	103238	104148	AGITATOR, MECHANICAL	3Y	OnHoldOrder	2016	2019	3	Y									



## Update : 01/03/2024 15:21

- CreatedMO = Create Work Order Completed
- OnHoldOrder = Waiting Create Work Order
- CompletedMO = Work Order Completed
- StartedPlan = PM Plan Start Completed (New PM Plan or Restart PM Plan)
- Scheduled Hold = Waiting Create Work Order Next Cycle


1001850	A	101849	101850	PH 3Y OVERHAUL BLOWER #300-B1	BLOWER/FAN, LOBE	3Y	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019	2019
---------	---	--------	--------	-------------------------------	------------------	----	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------

## Update : 01/03/2024 15:21

**Update :**

01/03/2024 15:21

Please select here: ☐ ☐ ☐

P:\9346 KPTMTN\PM Master Plan\PM\_Master Plan : PM\_Master Plan

## ภาคผนวก ข.14

---

### เอกสารการตรวจสอบประสิทธิภาพ ของระบบ Waste Gas Treatment

4  
a.p. ...

FM-LC9-00-001:02/07/2015-Rev.03

1210-C1 Nd Column

FM-LC9-00-001:02/07/2018:Rev.0

Operate Date: 9/2/19  
Recorded by: 25  
Checked by: 03

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCIM 2500 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
LC-25-002	500 mm	5.71	4.5	4.03	4.01	4.06	
FI-25-001	1.01 M/H	0.45	0.41	0.45	0.45	0.32	
FC-25-002	5 M/H	1.48	0.41	0.82	1.82	2.1	
FI-25-001	440 M/H	5.41	5.41	5.50	5.50	5.53	
LI-25-001	1256 mm	1.41	1.41	1.41	1.41	1.41	
PC-25-001	1.6 kg/cm <sup>2</sup>	1.41	1.41	1.41	1.41	1.41	
PC-25-002	2.5 kg/cm <sup>2</sup>	5.51	5.51	5.51	5.51	5.51	
2500-F1	A A/B	5	5	5	5	5	

SCIM 2501 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
PC-25-021	1.8 kg/cm <sup>2</sup>						
O.P.C-25-021	%						
ST-25-021	>8000 rpm						
FC-25-021	12500 Am/H						
TC-25-021	-8.4 °C						
TI-25-022	150 °C						
PI-25-022	13 kg/cm <sup>2</sup>						
LI-25-022	220 mm						
PI-25-023	6.5 kg/cm <sup>2</sup>						
FI-25-022	550 NM/H						
LI-25-021	-12 mm						
LC-25-024	-1155 mm						
LC-25-023	-596 mm						
TC-12-115	-5.2 °C						
TC-12-129	-5.6 °C						
LC-25-023	776 mm						
PC-25-023	6929 Am/H						
FI-25-024	35352 NM/H						
FI-25-025	39829 NM/H						
Circulate 1210-E5	1025 M/H						

Remark:

Operate Date: 9/2/19  
Recorded by: 75  
Checked by: 03

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCIM 2500 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
FI-25-005	153.9 M/H						
TC-25-002	4.4 °C						
LC-25-004	40 mm						
PC-25-003	3.351 kg/cm <sup>2</sup>						
FI-25-005	M/H						

SCIM 2511 Unit -NO.2 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
TC-12-143	-6.0 °C	-5.5	-5.7	-7.6	-6.8	-6.9	
LC-25-124	530 mm	4.9	4.9	5.6	6.5	6.7	
TC-12-144	-5.2 °C	-7.0	-7.1	-6.1	-5.2	-5.2	
LC-25-125	630 mm	6.6	6.6	6.9	6.7	6.0	
LI-25-121	130.79 A	70.1	70.5	85	85	85	
ZI-25-121	95.8 %	99.7	99.1	99.2	99.1	99.0	
VE-25-129	1.6 mm/s	0.70	0.60	0.7	0.7	0.7	
VE-25-121	-0.5 mm/s	-5.0	-5.3	-3.0	-3.0	-3.0	
VE-25-122	0.51 mm/s	7.1	7.1	7.1	7.1	7.1	
VE-25-123	-0.12 mm/s	-7.1	-7.1	-2.9	-2.9	-2.9	
VE-25-124	0.23 mm/s	5.4	5.4	5.4	5.4	5.4	
VE-25-127	4.66 mm/s	7.4	6.6	7.4	7.4	7.4	
VE-25-128	3.25 mm/s	8.1	8.1	8.1	8.1	8.1	
TE-25-121A	53.11 °C	53.11	53.11	53	53	53	
TE-25-121B	51.61 °C	51.61	51.61	51	51	51	
TE-25-122A	75.89 °C	75.89	75.89	75	75	75	
TE-25-122B	77.29 °C	77.29	77.29	77	77	77	
TE-25-122C	76.41 °C	76.41	76.41	76	76	76	

SCIM 2511 Unit -NO.2 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
PC-25-121	1.8 kg/cm <sup>2</sup>	1.8	1.8	1.8	1.8	1.8	
PI-25-122	15.2 kg/cm <sup>2</sup>	15.2	15.2	15.2	15.2	15.2	
PC-25-123	18.2 kg/cm <sup>2</sup>	18.2	18.2	18.2	18.2	18.2	
PI-25-123	%	9.4	9.4	9.4	9.4	9.4	
PI-25-124	1.9 kg/cm <sup>2</sup>	1.9	1.9	2.0	2.0	2.0	
PI-25-125	3.2 kg/cm <sup>2</sup>	3.2	3.2	3.2	3.2	3.2	
PI-25-126	18.4 kg/cm <sup>2</sup>	18.4	18.4	18.4	18.4	18.4	
TI-25-123	70 °C	70	70	70	70	70	
TI-25-124	86.48 °C	86.48	86.48	86.48	86.48	86.48	
TI-25-125	59.6 °C	59.6	59.6	59.6	59.6	59.6	
TI-25-126	39.89 °C	39.89	39.89	39.89	39.89	39.89	
LC-25-121	30 mm	30	30	30	30	30	
LCV-25-121	197 %	197	197	197	197	197	
FOI-25-121	3.00 kg/cm <sup>2</sup>	3.00	3.00	3.00	3.00	3.00	
FOI-25-122	0.29 kg/cm <sup>2</sup>	0.29	0.29	0.29	0.29	0.29	
2510-F1	A A/B	A	A	A	A	A	
2510-F2	A A/B	A	A	A	A	A	

Remark:

Operate Date: 9/2/19  
Recorded by: 75  
Checked by: 03

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCIM 2503 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
REM-SP-201	1.6-1.7 kg/cm <sup>2</sup>						
PI-25-201	1.6-1.7 kg/cm <sup>2</sup>						
ZI-25-201	>99 %						
LI-25-201	165-171 Amp						
REM-SP-301	1.58 kg/cm <sup>2</sup>	1.48	1.48	1.48	1.48	1.48	
PI-25-301	1.7 kg/cm <sup>2</sup>	1.7	1.7	1.7	1.7	1.7	
ZI-25-301	99.8 %	99.8	99.8	99.8	99.8	99.8	
LI-25-301	177-185 Amp	177	177	177	177	177	
TC-25-021	-11 °C	-9.2	-9.2	-9.2	-9.2	-9.2	
PC-25-021	1.7-1.8 kg/cm <sup>2</sup>	1.71	1.71	1.71	1.71	1.71	
FI-25-024	37000 M/H	37000	37000	37000	37000	37000	
PI-25-021	81-82 °C	81.8	81.8	81.8	81.8	81.8	
PI-25-022	14.5-15.0 kg/cm <sup>2</sup>	14.5	14.5	14.5	14.5	14.5	
PI-25-023	82 °C	82	82	82	82	82	
PI-25-024	14.5-15.0 kg/cm <sup>2</sup>	14.5	14.5	14.5	14.5	14.5	
LI-25-022	-30 mm	-30	-30	-30	-30	-30	
LC-25-023	630 mm	630	630	630	630	630	
FI-25-022	590-600 M/H	590	590	590	590	590	
PI-25-203	5.5 kg/cm <sup>2</sup>	5.5	5.5	5.5	5.5	5.5	
PI-25-203	5.5 kg/cm <sup>2</sup>	5.5	5.5	5.5	5.5	5.5	
LI-25-023	12 °C	12	12	12	12	12	
LC-25-024	-1045 mm	-1045	-1045	-1045	-1045	-1045	
TC-12-115	-5 °C	-7.1	-7.1	-6.6	-5.5	-5.8	
TC-12-025	-920 mm	-920	-920	-920	-920	-920	
TC-12-129	-5 °C	-4.3	-4.3	-6.0	-7.0	-7.1	
FI-12-129	1390 M/H	1390	1390	1390	1390	1390	
FI-12-116	1269 M/H	1269	1269	1269	1269	1269	
LI-25-021	-13 mm	-13	-13	-13	-13	-13	

Remark:

Operate Date: 9/2/19  
Recorded by: 75  
Checked by: 03

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCIM 2530 Unit -2500 NO.4 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
TI-25-311	-9 °C	-7.1	-7.1	-6.6	-5.4	-5.6	
VI-25-305	0.66-1.0 mm/s	0.7	0.7	0.8	0.7	0.7	
VI-25-306	1.39 mm/s	1.3	1.3	1.3	1.3	1.3	
VI-25-307	1.36 mm/s	1.3	1.3	1.3	1.3	1.3	
VI-25-302	47 mm/s	47.3	47.3	47	47	47	
VI-25-301	44 mm/s	44.7	44.7	44	44	44	
TI-25-301A	30 °C	30	30	30	30	30	
TI-25-302A	82 °C	82	82	82	82	82	
TI-25-303A	80 °C	79	79	79	79	79	
TI-25-302C	82 °C	82	82	82	82	82	
TI-25-301B	48 °C	48	48	48	48	48	
VI-25-303	45 mm/s	45	45	45	45	45	
VI-25-304	46 mm/s	46	46	46	46	46	
VI-25-306	1.4 kg/cm <sup>2</sup>	1.4	1.4	1.4	1.4	1.4	
TI-25-314	37-38 °C	37.3	37.3	37	37	37	
2530-P2A/B	A or B	A	A	A	A	A	
2530-P1A/B	A or B	A	A	A	A	A	
PI-25-304	17.6 kg/cm <sup>2</sup>	17.6	17.6	17.6	17.6	17.6	
PI-25-301	0.44 kg/cm <sup>2</sup>	0.44	0.44	0.44	0.44	0.44	
PI-25-305	17.2 kg/cm <sup>2</sup>	17.2	17.2	17.2	17.2	17.2	
PI-25-312	kg/cm <sup>2</sup>						
PI-25-302	2.18 kg/cm <sup>2</sup>	2.18	2.18	2.18	2.18	2.18	
PI-25-302	15 kg/cm <sup>2</sup>	15	15	15	15	15	
TI-25-313	55 °C	55	55	55	55	55	
TI-25-313	13.5 °C	13.5	13.5	13.5	13.5	13.5	
SP-PC-303	5.5 kg/cm <sup>2</sup>	5.5	5.5	5.5	5.5	5.5	
OP-PC-303	-0.31 %	-0.31	-0.31	-0.31	-0.31	-0.31	

SCIM 4500 Unit -WASTE GAS TREATMENT

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
FI-45-001	19260 NM/H	19260	19260	19260	19260	19260	
FC-45-003	1.32 M/H	1.32	1.32	1.32	1.32	1.32	
FI-45-004	174 M/H	174	174	174	174	174	
FI-45-005	194 M/H	194	194	194	194	194	
FC-45-006	132 NM/H	132	132	132	132	132	
PI-45-001	14.25 kg/cm <sup>2</sup>	14.25	14.25	14.25	14.25	14.25	
PI-45-002	13.79 kg/cm <sup>2</sup>	13.79	13.79	13.79	13.79	13.79	
PI-45-001	85 °C	85	85	85	85	85	
LI-45-001	21.6 Amp	21.6	21.6	21.6	21.6	21.6	
FI-45-003	193.9 °C	193.9	193.9	193.9	193.9	193.9	
TC-45-004	312 °C	312	312	312	312	312	
FI-45-006	379 °C	379	379	379	379	379	
TC-45-005	468 °C	468	468	468	468	468	
PI-45-022	0.03 kg/cm <sup>2</sup>	0.03	0.03	0.03	0.03	0.03	
FI-45-023	kg/cm <sup>2</sup>						
PC-45-024	1100 kg/cm <sup>2</sup>	1100	1100	1100	1100	1100	
PI-00-001	2.76 kg/cm <sup>2</sup>	2.76	2.76	2.76	2.76	2.76	
FC-45-021	NM/H						
FC-45-022	44.2 NM/H	44.2	44.2	44.2	44.2	44.2	
FC-45-023	2329 NM/H	2329	2329	2329	2329	2329	
PI-45-023	Ratio	Ratio	Ratio	Ratio	Ratio	Ratio	
PI-11-523A	2.03 kg/cm <sup>2</sup>	2.03	2.03	2.03	2.03	2.03	
PC-45-003	-420 mm/H <sub>2</sub> O	-420	-420	-420	-420	-420	
TI-45-002	262 °C	262	262	262	262	262	
TI-45-008	290 °C	290	290	290	290	290	
FI-45-005	317 °C	317	317	317	317	317	
FI-45-006	589 mm/H <sub>2</sub> O	589	589	589	589	589	

Remark:



E UNIT (1200 UNIT)		Recorded by _____		Checked by _____		SCM 1236 UNIT 1230 DS RECOVERY					
Item	Unit	Time									
		02:00	06:00	10:00	14:00	18:00	22:00				
PI-12-305	84 mmH <sub>2</sub> O	-1	0	0	-1	2					
PC-12-301	-25 mmH <sub>2</sub> O	-69	-61		-74	-87					
PI-12-302	-340 mmH <sub>2</sub> O	-94	-93	146	-74	-505					
PI-12-303	265 mmH <sub>2</sub> O	93	93	950	923	399					
PI-12-307	2.73 kg/cm <sup>2</sup>	1.51	1.51	1.62	1.46	1.47					
PI-12-308	1 kg/cm <sup>2</sup>	6.5	6.5	9.49	9.70	9.78					
PI-12-309	793 mmH <sub>2</sub> O	659	673	723	644	577					
PD-12-301	80 mmH <sub>2</sub> O	71	71	74	69	14					
PC-12-301	16800 NmHr	1165	1145	18045	18045	16333					
FI-12-302	12.3 mHr	19.5	16.5	28.6	19.6	19.6					
FI-12-303	1.86 mHr	1.99	1.11	2.0	0.14	0.13					
FC-12-304	0.47 NmHr	1.4	1.0	1.0	1.0	1.22					
FC-12-306	8.2 NmHr	1.8	2.0	4.2	4.7	3.8					
FI-12-307	1173 NmHr	164	164	871	1023	1146					
FI-12-308	11 mHr	7.3	7.3	7.1	6.5	6.6					
FI-12-308	38 NmHr	11.3	10.7	11.3	10.5	9.12					
TC-12-301	14.6 °C	16.2	16.2	15.0	15.4	15.6					
TC-12-307	180.3 °C	187.8	186	186	206	207					
TC-12-301	178.6 °C	60.3	60.3	55.4	56.7	59.0					
TC-12-304	330 °C	333	333	337	337	337					
TI-12-305	338.8 °C	333	333	337	337	337					
TI-12-306	239.2 °C	233	233	240	194	194					
TI-12-307	101.9 °C	101	101.5	101	101	101					
LC-12-301	50 %	60.1	60.1	60	50	50					
AF-12-301	10 Vpp	7.1	7.1	7.1	7.2	7.9					
AF-12-302A	4 ppm	9.7	9.7	40	88.2	75.5					
AI-12-302B	5 ppm	413.4	414	61.1	9.162	7.84					

Item		Unit	Time							
			00:00	04:00	08:00	12:00	16:00	20:00		
FC-12-101	26446	NM/Hr	235.70	255.11	339.22	319.54	153.32	174.6		
FC-12-102	2779	NM/Hr	244.73	289.93	319.94	319.54	248.7			
FI-12-101	0.006	-	0.0073	0.0079	0.004	0.004	0.00			
II-12-101	32	Amps	24.6	24.6	31.76	31.94	21.11			
TC-12-104	2211	mml/GLO	130.4	130.5	130.5	130.5	130.5			
TC-12-101	-6.9	C	1.13	1.13	1.13	1.13	1.13			
TC-12-102	778	C	700	700	700	700	700			
TC-12-103	727	C	700	700	700	700	700			
TC-12-104	765	C	700	700	700	700	700			
TC-12-105	777	C	700	700	700	700	700			
TC-12-106	714	C	700	700	700	700	700			
TC-12-107	215	C	215	215	215	215	215			
TC-12-108	102.9	C	101.1	102.9	102.9	102.9	102.9			
TC-12-109	25.8	C	25.8	25.8	25.8	25.8	25.8			
FP-12-105	8.85	M/H	9.46	9.46	9.46	9.46	9.46			
FI-12-119	9.35	TOTI	9.35	9.35	9.35	9.35	9.35			
PC-12-101	15.3	kg/cm <sup>2</sup>	15.4	15.4	15.4	15.4	15.4			
AC-12-101	6	pH	6	6	6	6	6			
AI-12-102	1.15	pH	1.15	1.15	1.15	1.15	1.15			
AI-12-108	4.2	pH	4.2	4.2	4.2	4.2	4.2			
AI-12-110	498	Mic/mc	498	498	498	498	498			
AT-12-P10	A	AVI	A	A	A	A	A			
I-C-12-101	ON	ON-OFF	ON	ON	ON	ON	ON			
HC-12-104	0	%	0	0	0	0	0			
HC-12-105	0	%	0	0	0	0	0			
HC-12-106	68	%	68	68	68	68	68			
FI-12-103	90	m/hr	9.94	9.94	9.94	9.94	9.94			
FI-12-104	5	m/hr	5.00	5.00	5.00	5.00	5.00			
FI-12-118	0	Ratio	0	0	0	0	0			

INE UNIT (1200 UNIT)		Recorded by <u>21200</u>	Checked by <u>21200</u>		1968 Chemical Waste Public Lab		
SCHIM 1211A UNIT 1218 AMINE PRODUCT							
Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
FE-12-121	12716 Nm	17730	17720	17670	17630	17570	17540
FE-12-122	1350 Nm/A	1600	1200	930	1700	1544	1490
FE-12-122	1350 Nm	2000	2000	1810	1700	1500	1450
FE-12-121	0.098	0.0	0.0	0.037	0.031	0.021	0.011
FI-12-104	23 Amp	21.8	24.8	21.9	21.7	20.4	21.9
FI-12-111	1850 mmf/O	1000	1000	1000	1000	1000	1000
TC-12-132	770 °C	76.0	72.0	71.0	71.1	70.5	71.1
TC-12-133A	779 °C	76.0	72.0	71.0	71.1	70.5	71.1
TC-12-134A	205.8 °C	20.4	20.4	20.4	20.4	20.4	20.4
TC-12-135	53.1 °C	53.9	55.0	55.0	55.0	55.0	55.0
TC-12-136	101.2 °C	101.8	101.8	101.8	101.8	101.8	101.8
TC-12-137A	72.4 °C	72.7	72.7	72.7	72.7	72.7	72.7
FI-12-123	2.94 m/A	2.94	2.94	2.94	2.94	2.94	2.94
FI-12-124	2.08 m/A	2.08	2.08	2.08	2.08	2.08	2.08
FI-12-125	5.83 m/A	5.83	5.83	5.83	5.83	5.83	5.83
FI-12-126	5.18 m/A	5.18	5.18	5.18	5.18	5.18	5.18
FE-12-126	15.15T	15.15T	15.15T	15.15T	15.15T	15.15T	15.15T
AC-12-110	15.4 pH	15.4	15.4	15.4	15.4	15.4	15.4
AC-12-111	15.4 pH	15.4	15.4	15.4	15.4	15.4	15.4
AI-12-111	342 Micro	342	342	342	342	342	342
AI-12-112	9.5 pH	9.5	9.5	9.5	9.5	9.5	9.5
LC-12-111	0 cm	0	0	0	0	0	0
LS-12-111	ON ONOFF	ON	ON	ON	ON	ON	ON
HW-12-109	32 %	32	32	32	32	32	32
HW-12-110	48 %	48	48	48	48	48	48
FE-12-102	NM	17730	17720	17670	17630	17570	17540

Item		Unit	Time							
			08:00	08:30	09:00	12:00	16:00	20:00		
TF-12-110	78.8	°C	78.8	84.0	74.4	71.5	77.9	76.4		
TF-12-112	-1.4	°C	-1.8	-1.2	-3.0	-2.0	-1.5	-1.1		
TF-12-113	-4.5	°C	-6.2	-6.4	-7.4	-7.1	-7.0	-7.4		
TF-12-114	-5.2	°C	-5.7	-5.9	-5.1	-5.8	-5.1	-4.7		
AI-12-103		psi								
AI-12-104		psi								
AI-12-105	8.22	pH	8.6	8.5	8.70	8.73	8.67	8.71		
PF-12-106	3762	M/NI	3695	3743	3743	3710	3746	3747		
PF-12-107	1208	M/NI	1204	1204	1211	1211	1211	1211		
PF-12-127		M/NI	6605	6605	6611	6605	6611	6611		
FC-12-108	60	M/NI	60.45	60.5	60.5	60.5	60.5	60.5		
FC-12-109	7	M/NI	7.5	7.5	7.5	7.5	7.5	7.5		
FC-12-110	1182	Wt	1182	1182	1182	1182	1182	1182		
PH-12-111	53.2	M/NI	53.2	53.2	53.2	53.2	53.2	53.2		
PF-12-110	1.13	Ratio	1.13	1.13	1.13	1.13	1.13	1.13		
PI-12-108	0.775	mm	0.775	0.775	0.775	0.775	0.775	0.775		
LI-12-107	1.079	mm	1.079	1.079	1.079	1.079	1.079	1.079		
TI-12-118	-0.7	°C	-0.7	-0.7	-0.7	-0.7	-0.7	-0.7		
TI-12-119	-1.9	°C	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9		
II-12-102	34	Amp	34	34	34	34	34	34		
1210-P2	A	A/B	A	A	A	A	A	A		
1210-P3	A	A/B	A	A	A	A	A	A		
1210-P6	A/C	A/B/C	A	A	A	A	A	A		
LC-12-103	350	mm	350	350	350	350	350	350		
LC-12-106	300	mm	300	300	300	300	300	300		

[illegible]

Operate Date: \_\_\_\_\_ Recorded by: \_\_\_\_\_ UBE  
Checked by: \_\_\_\_\_

### DCS LOG SHEET AMINE UNIT (1200 UNIT)

#### SCHM 1221 UNIT 1220 AW & SI PRODUCTION

Item	Unit	02:00	04:00	06:00	08:00	10:00	12:00	14:00	16:00	18:00	20:00
FI-12-201	21643 NM/H	199.34	199.34	199.34	199.34	199.34	199.34	199.34	199.34	199.34	199.34
TI-12-201	-8.1 °C	-7.2	-7.6	-7.7	-7.5	-7.5	-7.5	-7.5	-7.5	-7.5	-7.5
FC-12-101	1.32 kg/cm <sup>2</sup>	1.27	1.41	1.39	1.31	1.34	1.34	1.34	1.34	1.34	1.34
FC-12-202	530 M/H	544	544	544	544	544	544	544	544	544	544
TC-12-202	0.82 kg/cm <sup>2</sup>	0.81	1.04	1.03	1.05	1.05	1.05	1.05	1.05	1.05	1.05
TI-12-202	49 °C	51.9	51.9	51.9	51.9	51.9	51.9	51.9	51.9	51.9	51.9
TC-12-203	35 °C	36.6	36.6	36.6	36.6	36.6	36.6	36.6	36.6	36.6	36.6
LI-12-203	>3000 mm	3000	3000	3000	3000	3000	3000	3000	3000	3000	3000
TI-12-204	21.4 °C	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.2
TI-12-205	22.3 °C	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8
FC-12-204	44.8 M/H	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8
PI-12-204	0.23 MPa	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23
FC-12-205	61 M/H	61	61	61	61	61	61	61	61	61	61
AC-12-201	314 g/l	314	314	314	314	314	314	314	314	314	314
AC-12-202	343 g/l	343	343	343	343	343	343	343	343	343	343
LI-12-204	>3000 mm	3000	3000	3000	3000	3000	3000	3000	3000	3000	3000
1220-P1	A A/B	A	A	A	A	A	A	A	A	A	A
1220-P4	A A/B	A	A	A	A	A	A	A	A	A	A
1220-P3	A/C A/B/C	A	A	A	A	A	A	A	A	A	A
1220-P6	A A/B	A	A	A	A	A	A	A	A	A	A
TI-12-206	33.7 °C	33.7	33.7	33.7	33.7	33.7	33.7	33.7	33.7	33.7	33.7
LC-12-202	2000 mm	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000

#### SCHM 1222 Unit 1200 SI PRODUCT

Item	Unit	02:00	04:00	06:00	08:00	10:00	12:00	14:00	16:00	18:00	20:00
FI-12-208	39.7 M/H	39.7	39.7	39.7	39.7	39.7	39.7	39.7	39.7	39.7	39.7
FC-12-120	7.4 kg/cm <sup>2</sup>	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
FC-12-211	25.3 kg/cm <sup>2</sup>	25.3	25.3	25.3	25.3	25.3	25.3	25.3	25.3	25.3	25.3
PI-12-204	0.2 kg/cm <sup>2</sup>	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Remark: \_\_\_\_\_

Page 3 of 8

Operate Date: \_\_\_\_\_ Recorded by: \_\_\_\_\_ UBE  
Checked by: \_\_\_\_\_

### DCS LOG SHEET AMINE UNIT (1200 UNIT)

#### SCHM 1222 Unit 1200 SI PRODUCT

Item	Unit	02:00	04:00	06:00	08:00	10:00	12:00	14:00	16:00	18:00	20:00
AI-1-106	14.4 %Vol	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4
AI-1-101	13.1 %Vol	13.1	13.1	13.1	13.1	13.1	13.1	13.1	13.1	13.1	13.1
TI-12-208	32.6 °C	32.6	32.6	32.6	32.6	32.6	32.6	32.6	32.6	32.6	32.6
AC-12-204	646 pH	646	646	646	646	646	646	646	646	646	646
FC-12-209	608 M/H	608	608	608	608	608	608	608	608	608	608
TC-12-209	43.9 °C	43.9	43.9	43.9	43.9	43.9	43.9	43.9	43.9	43.9	43.9
FC-12-206	192 M/H	192	192	192	192	192	192	192	192	192	192
FI-12-206	0.49 Ratio	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49
FI-12-207	39 M/H	39	39	39	39	39	39	39	39	39	39
LI-12-205	7000 mm	7000	7000	7000	7000	7000	7000	7000	7000	7000	7000
AC-12-203	1158 g/l	1158	1158	1158	1158	1158	1158	1158	1158	1158	1158
TI-12-207	44.2 °C	44.2	44.2	44.2	44.2	44.2	44.2	44.2	44.2	44.2	44.2
HC-12-201	61 %	61	61	61	61	61	61	61	61	61	61
1220-P2	A A/B	A	A	A	A	A	A	A	A	A	A
1220-P3	A A/B	A	A	A	A	A	A	A	A	A	A
1220-P7	A A/B	A	A	A	A	A	A	A	A	A	A
1220-P8	A A/B	A	A	A	A	A	A	A	A	A	A
1220-P9	A A/B	A	A	A	A	A	A	A	A	A	A

#### SCHM 2500 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
TI-02-021	28.11 °C	28.11	28.11	28.11	28.11	28.11	28.11
FI-15-001	34 M/H	34	34	34	34	34	34
FC-15-003	M	M	M	M	M	M	M
FI-15-004	-1.2 Tons/hr	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2
FI-25-024	0.24 kg/cm <sup>2</sup>	0.24	0.24	0.24	0.24	0.24	0.24
FI-25-083	89.1 M/H	89.1	89.1	89.1	89.1	89.1	89.1
2500-U1	ON/OFF	ON/OFF	ON/OFF	ON/OFF	ON/OFF	ON/OFF	ON/OFF
TC-12-115	-6.2 °C	-6.2	-6.2	-6.2	-6.2	-6.2	-6.2
LC-12-001	>450 mm	>450	>450	>450	>450	>450	>450
TC-25-081	5 °C	5	5	5	5	5	5

Remark: \_\_\_\_\_

Operate Date: \_\_\_\_\_ Recorded by: \_\_\_\_\_ UBE  
Checked by: \_\_\_\_\_

### DCS LOG SHEET AMINE UNIT (1200 UNIT)

#### SCHM 2500 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
LC-25-002	500 mm	500	500	500	500	500	500
FI-25-001	1.01 M/H	1.01	1.01	1.01	1.01	1.01	1.01
FC-25-002	5 M/H	5	5	5	5	5	5
FI-25-081	440 M/H	440	440	440	440	440	440
LI-25-081	1256 mm	1256	1256	1256	1256	1256	1256
FC-25-001	1.6 kg/cm <sup>2</sup>	1.6	1.6	1.6	1.6	1.6	1.6
FC-25-002	3.5 kg/cm <sup>2</sup>	3.5	3.5	3.5	3.5	3.5	3.5
2500-P1	A A/B	A	A	A	A	A	A

#### SCHM 2501 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
FC-25-021	1.8 kg/cm <sup>2</sup>	1.8	1.8	1.8	1.8	1.8	1.8
O.P.P.C-021	%	%	%	%	%	%	%
SI-25-021	>8000 rpm	>8000	>8000	>8000	>8000	>8000	>8000
FC-25-021	12500 Am/H	12500	12500	12500	12500	12500	12500
TC-25-021	-8.4 °C	-8.4	-8.4	-8.4	-8.4	-8.4	-8.4
TI-25-021	150 °C	150	150	150	150	150	150
FI-25-022	13 kg/cm <sup>2</sup>	13	13	13	13	13	13
LI-25-022	220 mm	220	220	220	220	220	220
FI-25-023	6.5 kg/cm <sup>2</sup>	6.5	6.5	6.5	6.5	6.5	6.5
FI-25-022	550 M/H	550	550	550	550	550	550
LI-25-021	-12 mm	-12	-12	-12	-12	-12	-12
LC-25-024	-1156 mm	-1156	-1156	-1156	-1156	-1156	-1156
LC-25-025	-399 mm	-399	-399	-399	-399	-399	-399
TC-12-115	-5.3 °C	-5.3	-5.3	-5.3	-5.3	-5.3	-5.3
LC-12-129	-5.6 °C	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6
LC-25-023	776 mm	776	776	776	776	776	776
FC-25-021	6929 Am/H	6929	6929	6929	6929	6929	6929
FI-25-024	33357 NM/H	33357	33357	33357	33357	33357	33357
FI-25-025	39820 NM/H	39820	39820	39820	39820	39820	39820
Circulate 1210-E5	1028 M/H	1028	1028	1028	1028	1028	1028

Remark: \_\_\_\_\_

Page 4 of 8

Operate Date: \_\_\_\_\_ Recorded by: \_\_\_\_\_ UBE  
Checked by: \_\_\_\_\_

### DCS LOG SHEET AMINE UNIT (1200 UNIT)

#### SCHM 2502 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
TI-25-051	64.2 °C	64.2	64.2	64.2	64.2	64.2	64.2
TI-25-052	92.9 °C	92.9	92.9	92.9	92.9	92.9	92.9
TI-25-053	92.4 °C	92.4	92.4	92.4	92.4	92.4	92.4
TI-25-054	92.1 °C	92.1	92.1	92.1	92.1	92.1	92.1
TI-25-055	82.6 °C	82.6	82.6	82.6	82.6	82.6	82.6
TI-25-056	78.8 °C	78.8	78.8	78.8	78.8	78.8	78.8
TI-25-057	73 °C	73	73	73	73	73	73
TI-25-058	53.1 °C	53.1	53.1	53.1	53.1	53.1	53.1
PI-25-081	73.1 mmHg	73.1	73.1	73.1	73.1	73.1	73.1
LC-25-082	mm	mm	mm	mm	mm	mm	mm
FI-25-082	16.5 T/H	16.5	16.5	16.5	16.5	16.5	16.5
FC-90-091	22.51 kg/cm <sup>2</sup>	22.51	22.51	22.51	22.51	22.51	22.51
2500-K-91	service	service	service	service	service	service	service
2500-K1-72	stand by	stand by	stand by	stand by	stand by	stand by	stand by
2500-P2	A/B	A/B	A/B	A/B	A/B	A/B	A/B

#### VIBRA. AXIAL DISP. Unit -2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
XVI-25-051	29.66 mm	29.66	29.66	29.66	29.66	29.66	29.66
YVI-25-051	28.41 mm	28.41	28.41	28.41	28.41	28.41	28.41
XVI-25-052	29.37 mm	29.37	29.37	29.37	29.37	29.37	29.37
ZI-25-051	0.41 mm	0.41	0.41	0.41	0.41	0.41	0.41
ZI-25-052	0.81 mm	0.81	0.81	0.81	0.81	0.81	0.81
XVI-25-053	10.92 mm	10.92	10.92	10.92	10.92	10.92	10.92
YVI-25-053	28.73 mm	28.73	28.73	28.73	28.73	28.73	28.73
XVI-25-054	13.87 mm	13.87	13.87	13.87	13.87	13.87	13.87
YVI-25-054	13.05 mm	13.05	13.05	13.05	13.05	13.05	13.05
ZI-25-053	-0.19 mm	-0.19	-0.19	-0.19	-0.19	-0.19	-0.19
ZI-25-054	-0.25 mm	-0.25	-0.25	-0.25	-0.25	-0.25	-0.25

Remark: \_\_\_\_\_

Operate Date: \_\_\_\_\_

DCS LOG SHEET AM

SCHM 2500 Unit -2500 AMMONIA REFRIGERATION

2500-E4

Item	Unit	Time	02:00	06:00	10:00	14:00	18:00	22:00
FI-25-005	151.9 M/H							
TC-25-082	4.4 °C							
LC-25-004	60 mm							
FC-25-003	3.351 kg/cm <sup>2</sup>							
FI-25-005	M/H							

2510 NO.2 AMMONIA REFRIGERATION

SCHM 2511 Unit NO.2 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
TC-12-143	-6.0 °C	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0
TC-12-124	-5.2 °C	-5.2	-5.2	-5.2	-5.2	-5.2	-5.2
LC-25-125	630 mm	630	630	630	630	630	630
LI-25-121	1320.79 A	1320.79	1320.79	1320.79	1320.79	1320.79	1320.79
ZF-25-121	95.8 %	95.8	95.8	95.8	95.8	95.8	95.8
VE-25-121	1.6 mm/s	1.6	1.6	1.6	1.6	1.6	1.6
VE-25-121	0.5 mm/s	0.5	0.5	0.5	0.5	0.5	0.5
VE-25-122	0.51 mm/s	0.51	0.51	0.51	0.51	0.51	0.51
VE-25-121	-0.12 mm/s	-0.12	-0.12	-0.12	-0.12	-0.12	-0.12
VE-25-124	0.23 mm/s	0.23	0.23	0.23	0.23	0.23	0.23
VE-25-127	4.66 mm/s	4.66	4.66	4.66	4.66	4.66	4.66
VE-25-128	3.75 mm/s	3.75	3.75	3.75	3.75	3.75	3.75
TE-25-121A	53.1 °C	53.1	53.1	53.1	53.1	53.1	53.1
TE-25-121B	51.61 °C	51.61	51.61	51.61	51.61	51.61	51.61
TE-25-122A	75.89 °C	75.89	75.89	75.89	75.89	75.89	75.89
TE-25-122B	77.29 °C	77.29	77.29	77.29	77.29	77.29	77.29
TE-25-122C	76.41 °C	76.41	76.41	76.41	76.41	76.41	76.41

Remark: \_\_\_\_\_

**Recorded by**

Checked by \_\_\_\_\_

SCHM 4500 Unit-WASTE GAS TREATMENT									
Item	Unit	Time							
		02:00	06:00	10:00	14:00	18:00	22:00		
FI-45-001	19260 NM/H	14910	7815	14915	15724	11177	11111		
FC-45-003	1.19 NM/H	0.015	0.019	0.019	0.015	0.011	0.011		
FI-45-004	174 NM/H	146.5	136.5	114.5	114.9	100.9	100.5		
FI-45-005	194 NM/H	195	182	158.9	175.5	174.3	174.3		
FC-45-006	132 NM/H	143	132.5	109.3	109.8	100.5	100.5		
PI-45-001	14.25 kg/Hcm	14.4	14.4	14.4	14.25	14.25	14.25		
PI-45-002	13.75 kg/Hcm	14.0	14.0	14.1	14.0	14.0	14.0		
FI-45-001	8.5 NM/H	543.2	543.2	414.1	416	417	416		
FI-45-001	216 Amp	215.5	215.5	215.5	216	217	217		
TC-45-003	193.9 °C	194	194.9	190.9	192.5	193.5	193.5		
TC-45-004	312 °C	312	312	317	321	315	315		
FI-45-006	379 °C	379	379	374	375	375	375		
TC-45-003	458 °C	455	457	455	454	454	454		
PI-45-222	0.03 kg/Hcm	0.04	0.04	0.04	0.04	0.04	0.04		
PI-45-023	kg/Hcm								
FC-45-024	1100 kg/Hcm	1309	1199	1404	1397	1351	1351		
PI-00-021	2.76 kg/Hcm	1.76	1.85	1.135	1.543	1.1	1.1		
FC-45-021	NM/H								
FC-45-022	442 NM/H	505.9	441	527	433.9	436	436		
FC-45-023	2339 NM/H	2180	2300	3161	2527	2100	2111		
EY-45-023	1.89 Ratio	2.00	2.00	1.6	1.74	1.45	1.45		
PC-11-523 A	2.03 kg/Hcm	2.03	2.03	2.03	2.03	2.03	2.03		
FI-45-003	-520 mm/H <sup>2</sup> O	14.91	14.91	14.91	14.91	14.91	14.91		
FI-45-002	26.2 °C	26.4	26.4	26.7	26.5	26.4	26.4		
FI-45-003	280 °C	280	280	280	280	280	280		
FI-45-005	317 °C	317	317	317	317	317	317		
FI-45-006	500 °C	500	500	500	500	500	500		

Recorded by \_\_\_\_\_

CHECKED BY  
M 1234 JIN

[illegible]

FM/CP-00-001: TARDIS 1-0-0-0

Recorded by \_\_\_\_\_

1) Checked by \_\_\_\_\_

SCHM 1211A UNIT 1210 AMINE PRODUCT										
Item	Unit	Time								
		00:00	04:30	08:00	12:30	16:00				
FC-12-121	12716 Nm/h	2980	10810	11021	11728	11197				
FC-12-122	1350 Nm/h	1404	11235	11400	11068	11884				
FQ-12-122	Nm	20706	91400	92007	10200	61600				
FI-12-121	0.898 -	0.056	0.055	0.088	0.016	0.016				
II-12-104	23 Amp	9456	244.3	98.0	60.0	0.08				
PI-12-111	1850 mm/H <sub>2</sub> O	14987	1985	1746	2817	282.5				
TC-12-132	770 °C	730.0	763.4	765.0	789.1	764.4				
TI-12-133A	779 °C	742.4	760.5	762.1	789.1	764.4				
TI-12-134	205.8 °C	20706	2454.0	98.1	60.0	20.0				
TI-12-135	53.1 °C	92.5	925.0	98.1	60.0	20.0				
TI-12-136	101.2 °C	92.5	925.0	98.1	60.0	20.0				
TI-12-137A	724 °C	885.5	92.1	919.9	919.9	47.9				
FI-12-123	2.94 mm/h	5.0	6.0	60.0	60.0	60.0				
FI-12-124	2.08 mm/h	1.92	1.9	1.52	1.31	1.3				
FI-12-125	5.03 mm/h	6.84	6.0	5.77	5.11	6.0				
FI-12-126	5.18 mm/h	5.92	6.0	6.00	5.40	5.0				
FI-12-126	none	100.0	100.0	100.0	100.0	100.0				
PC-12-110	15.4 kg/H <sub>2</sub> O	15.0	15.0	15.0	15.0	15.0				
AC-12-110	15 pH	0.0	0.1	0.1	0.0	0.1				
AF-12-111	342 Mto/ht	15.0	14.07	14.02	13.12	14.01				
AF-12-112	9.5 pH	8.66	8.6	8.5	8.4	8.5				
LC-12-111	0 mm	13	1.5	1.7	1.9	1.5				
LS-12-111	ON ON/OFF	0.0	0.1	0.1	0.1	0.1				
HW-12-109	32 %	0.0	0.1	0.1	0.1	0.1				
RV-12-110	48 %	0.0	0.0	0.0	0.0	0.0				
FQ-12-102	NM	30.0	3.0	3.0	3.0	3.0				

USE

Operate Date: \_\_\_\_\_

**DCS LOG SHEET AMINE UNIT (1200 UNIT)**

Recorded by: \_\_\_\_\_

999

Operate Date: \_\_\_\_\_

DCS LOG SHEET AMINE UNIT (1200 UNIT)

Recorded by: \_\_\_\_\_

Checked by: \_\_\_\_\_

UAE Chemical Field Public Corporation

04

1220 - C1 AW Production

Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
FI-12-201	22643 Nm <sup>3</sup> /H	20.00	20.00	20.00	20.00	20.00	20.00
TC-12-201	-1.1 °C	-20.00	-20.00	-20.00	-20.00	-20.00	-20.00
PC-12-101	5.32 kg/H	5.32	5.32	5.32	5.32	5.32	5.32
FC-12-202	58.9 M/H	1.28	1.3	1.3	1.3	1.3	1.3
FI-12-203	530 M/H	44.5	44.5	44.5	44.5	44.5	44.5
FC-12-203	0.82 kg/cm <sup>2</sup>	2.01	2.02	2.02	2.02	2.02	2.02
TI-12-201	49 °C	51.7	50.6	50.6	50.6	50.6	50.6
TC-12-203	35 °C	43.7	43.7	43.7	43.7	43.7	43.7
LI-12-203	>3000 mm	3000	3000	3000	3000	3000	3000
TI-12-204	31.4 °C	31.4	31.4	31.4	31.4	31.4	31.4
TI-12-205	32.3 °C	32.3	32.3	32.3	32.3	32.3	32.3
FC-12-204	64.8 M/H	1.42	1.42	1.42	1.42	1.42	1.42
FY-12-204	0.73 Ratio	0.73	0.73	0.73	0.73	0.73	0.73
FC-12-205	61 M/H	0.52	0.52	0.52	0.52	0.52	0.52
AC-12-201	914 #	914	914	914	914	914	914
AC-12-202	943 #	943	943	943	943	943	943
LI-12-204	>1000 mm	1000	1000	1000	1000	1000	1000
1220-P1	A A/B	A	A	A	A	A	A
1220-P4	A A/B	A	A	A	A	A	A
1220-P5	A/C A/B/C	A	A	A	A	A	A
1220-P6	A A/B	A	A	A	A	A	A
LI-12-206	33.7 °C	33.7	33.7	33.7	33.7	33.7	33.7
LC-12-202	2000 mm	2000	2000	2000	2000	2000	2000

1220 - C2 Si Column

Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
AI-41-406	14.4 MVol	14.4	14.4	14.4	14.4	14.4	14.4
AI-41-701	13.1 MVol	13.1	13.1	13.1	13.1	13.1	13.1
TC-12-205	32.6 °C	32.6	32.6	32.6	32.6	32.6	32.6
AC-12-204	6.46 pH	6.46	6.46	6.46	6.46	6.46	6.46
FI-12-205	668 M/H	61.1	61.1	61.1	61.1	61.1	61.1
TC-12-209	43.9 °C	43.9	43.9	43.9	43.9	43.9	43.9
FC-12-206	19.2 M/H	1.45	1.45	1.45	1.45	1.45	1.45
FY-12-206	0.49 Ratio	0.49	0.49	0.49	0.49	0.49	0.49
TI-12-207	39 M/H	39.3	39.3	39.3	39.3	39.3	39.3
LI-12-205	7000 mm	55.2	55.2	55.2	55.2	55.2	55.2
AC-12-203	1152 g/t	1152	1152	1152	1152	1152	1152
TI-12-207	44.8 °C	44.8	44.8	44.8	44.8	44.8	44.8
HC-12-201	61 %	61	61	61	61	61	61
1220-P2	A A/B	A	A	A	A	A	A
1220-P3	A A/B	A	A	A	A	A	A
1220-P7	A A/B	A	A	A	A	A	A
1220-P8	A A/B	A	A	A	A	A	A
1220-P9	A A/B	A	A	A	A	A	A

2500 Ammonia Refrigeration

Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
TI-00-002	-28.11 °C	-28.11	-28.11	-28.11	-28.11	-28.11	-28.11
FI-25-003	34 M <sup>3</sup> /H	28.50	28.50	28.50	28.50	28.50	28.50
FQ-25-003	M <sup>3</sup>	52.34	52.34	52.34	52.34	52.34	52.34
FI-25-004	-1.2 Tco/H	0.24	0.24	0.24	0.24	0.24	0.24
FI-25-024	0.24 kg/cm <sup>2</sup>	0.24	0.24	0.24	0.24	0.24	0.24
FI-25-033	89.1 M <sup>3</sup> /H	0.24	0.24	0.24	0.24	0.24	0.24
2500-UI	M <sup>3</sup> /H	-	-	-	-	-	-
LI-12-012	- ON/OFF	-	-	-	-	-	-
LC-12-001	>450 mm	450	450	450	450	450	450
TC-25-001	5 °C	4.4	4.4	4.4	4.4	4.4	4.4

Remark:

Remark:

Operate Date: \_\_\_\_\_

2500 Ammonia Refrigeration

**DCS LOG SHEET AMINE UNIT (1200 UNIT)**

SCHM 2500 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	Time					
		02:00	06:00	10:00	14:00	18:00	22:00
LC-25-002	500 mm	4776	4776	4730	4730		
FI-25-001	1.01 M/H	1.03	1.03	1.03	1.03		1.03
FC-25-002	5 M/H	3.54	3.54	3.54	3.54		
FI-25-001	440 M/H	9.24	9.24	9.24	9.24		9.24
LI-25-001	1256 mm	1926	1926	1916	1916		1.90M
PC-25-001	1.6 kg/cm <sup>2</sup>	1.05	1.05	1.05	1.05		1.05
PC-25-002	3.5 kg/cm <sup>2</sup>	5.14	5.14	5.14	5.14		5.14
2500-P1	A/B	B	B	B	B		5-3

SCHM 2501 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	Time
PC-25-021	1.8 kg/cm <sup>2</sup>	
O.P.CC-021	%	
SI-25-021	>8000 rpm	
FC-25-021	12500 Am/H	
TC-25-021	-8.4 °C	
TI-25-022	150 °C	
FI-25-022	13 kg/cm <sup>2</sup>	
LI-25-022	220 mm	
FI-25-023	6.5 kg/cm <sup>2</sup>	
FI-25-022	530 Nm/H	
LI-25-021	-12 mm	
LC-25-024	-1156 mm	
LC-25-025	-396 mm	
TC-12-115	-3.5 °C	
TC-12-129	-5.6 °C	
LC-25-023	716 mm	
FC-25-023	6929 Am/H	
FI-25-024	35357 Nm/H	
FI-25-025	39820 Nm/H	
Circulate 1210-ES	1028 M/H	

Remark: \_\_\_\_\_

Record by: \_\_\_\_\_

SCHM 2502 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	Time					
		07:00	06:00	10:00	14:00	18:00	22:00
TI-25-031	64.8 °C						
TI-25-032	32.9 °C						
TI-25-033	92.4 °C						
TI-25-034	92.1 °C						
TI-25-035	82.6 °C						
TI-25-036	78.8 °C						
TI-25-037	73 °C						
TI-25-038	53.1 °C						
FI-25-001	73.1 mm/HgA						
LC-25-002	mm						
FI-25-002	16.5 T/H						
PC-00-091	22.51 kg/cm <sup>2</sup>						
2500-K1-P1	service -						
2500-K1-T2	stand by -						
2500-P2	A/B A/D						

VIBRA - AXIAL DISP. Unit -2500 AMMONIA REFRIGERATION

Item	Unit	Time
XVI-25-031	29.66 um	
XVI-25-031	28.41 um	
XVI-25-032	29.37 um	
XVI-25-032	22.12 um	
ZI-25-031	0.41 um	
ZI-25-032	0.01 um	
XVI-25-033	10.92 um	
XVI-25-033	28.73 um	
XVI-25-034	13.97 um	
XVI-25-034	13.85 um	
ZI-25-033	-0.19 um	
ZI-25-034	-0.25 um	

Remark: \_\_\_\_\_

Page 2 of 2

Operate Date: \_\_\_\_\_

SCRM 2500 Unit -2500

**DCS LOG SHEET AMINE UNIT (1200 UNIT)**

Record by: \_\_\_\_\_

Checked by: \_\_\_\_\_

USE Chemicals (White) Pallet Count: \_\_\_\_\_

**2500-E4**

**AMMONIA REFRIGERATION**

Item	Unit	Time					
		02:00	06:00	10:00	14:00	18:00	22:00
FI-25-085	153.9 M3/Hr						
TC-25-082	4.4 °C						
LC-25-004	4.0 mm						
PC-25-003	3.351 kg/cm <sup>2</sup>						
FI-25-005	M3/Hr						

**SCRM 2511 Unit NO.2 AMMONIA REFRIGERATION**


Item	Unit	Time					
		02:00	06:00	10:00	14:00	18:00	22:00
TC-12-143	-6.0 °C	-0.7	-1.0	-6.0	-6.3		-6.4
LC-25-124	520 mm	6.01	6.25	6.04	6.00		6.03
TC-12-144	-5.2 °C	-4.0	-4.1	-4.1	-4.1		-4.6
LC-25-125	630 mm	6.77	6.73	6.23	6.22		5.78
II-25-121	130.79 A	198.8	135.4	140.2	155.2		157
ZT-25-121	95.8 %	95.39	96.25	99.10	99.1		99.1
VE-25-129	1.6 mm/s	0.6	0.6	0.6	0.6		0.6
VE-25-121	-0.5 mm/s	-3.17	-3.1	-3.10	-3.17		-3.0
VE-25-122	0.51 mm/s	-3.01	-2.85	-2.74	-2.75		-2.4
VE-25-123	-0.12 mm/s	-1.93	-1.86	-1.91	-1.71		-1.72
VE-25-124	0.23 mm/s	-2.02	-1.99	-1.97	-1.94		-1.91
VE-25-127	4.66 mm/s	2.16	2.16	2.26	2.24		2.18
VE-25-128	3.73 mm/s	5.73	5.74	5.63	5.67		5.67
TE-25-121A	53.11 °C	51.28	52.17	56.2	56.1		56
TE-25-121B	51.61 °C	51.74	52.89	55.2	55.2		55
TE-25-122A	75.89 °C	71.1	81.59	80.8	80.7		84
TE-25-122B	77.29 °C	81.1	81.74	84.0	84.0		84
TE-25-122C	76.41 °C	74.4	80.4	85.1	83.2		84

**2510 NO.2 AMMONIA REFRIGERATION**

Item	Unit	Time					
		02:00	06:00	10:00	14:00	18:00	22:00
PC-25-121	1.8 kg/cm <sup>2</sup>	1.7	1.6	1.6	1.6		1.6
FI-25-122	13.2 kg/cm <sup>2</sup>	14.26	14.5	14.5	14.6		14.6
PC-25-123	18.2 kg/cm <sup>2</sup>	14.7	14.2	16.3	16.4		16.7
FI-25-123	%						
FI-25-124	1.9 kg/cm <sup>2</sup>	2.0	2.0	2.0	2.0		2.0
FI-25-125	3.2 kg/cm <sup>2</sup>	12.4	12.9	12.2	12.2		12.4
PC-25-126	18.4 kg/cm <sup>2</sup>	12.0	12.0	12.0	12.0		12.0
TI-25-123	70 °C	-9.21	-9.4	-9.4	-9.4		-9.4
TI-25-124	86.48 °C	84.44	85.7	84.2	84.2		84
TI-25-125	59.6 °C	59.59	61.29	60.2	60.1		60
TI-25-126	39.89 °C	34.52	36.03	41.2	41.2		41
LCV-25-121	30 mm	46.5	36.6	46.2	43.2		44
PCV-25-121	19.7 mm	14.7	8.4	8.8	8.4		9.2
PDI-25-121	3.00 kg/cm <sup>2</sup>	2.2	2.2	2.7	2.7		2.3
PDI-25-122	0.20 kg/cm <sup>2</sup>	0.3	0.3	0.3	0.3		0.3
2510-P1	A / B	A	A	A	A		A
2510-P2	A / B	A	A	A	A		A

Remark: \_\_\_\_\_

Item		Unit	Time					
			02:00	06:00	10:00	14:00	18:00	22:00
REM-SP-201	1.6-1.7	kg/dm2	1.65	1.65	1.65	1.65		
PIC-25-201	1.6-1.7	kg/dm2	1.7	1.7	1.72	1.72		1.65
21-25-201	>99 %	%	99.99	99.99	99.99	99.99		1.65
II-25-201	165-171	Amp	164.97	165.55	166.2	166.2		99.9
REM-SP-301	1.58	kg/dm2	1.63	1.65	1.65	1.65		1.65
21-25-301	1.7	kg/dm2	1.7	1.65	1.65	1.65		1.65
ZI-25-301	99.8 %	%	99.79	99.8	99.8	99.8		1.65
II-25-301	177-185	Amp	177.18	178.45	179.2	179.2		99.7
ZS-25-021	-11 °C	°C	-11.6	-11.4	-11.4	-11.4		99.5
PC-25-021	1.7-1.8	kg/dm2	1.7	1.78	1.81	1.81		1.74
FI-25-024	37000	M/H	37015	37015	37335	37335		26185
TI-25-212	81-82 °C	°C	82.16	82.16	82.7	82.7		79
FI-25-202	64.5-15.0	kg/dm2	64.5	64.5	64.5	64.5		15
TI-25-022	82 °C	°C	82.4	82.4	82.0	82.0		15
FI-25-302	64.5-15.0	kg/dm2	64.5	64.5	64.5	64.5		15
FI-25-022	3.8-14.6	kg/dm2	14.59	14.55	14.0	14.0		15
LI-25-022	-30 mm	mm	95.4	95.4	95.6	95.6		95.6
LI-25-023	630 mm	mm	585	578	600	600		400
FI-25-022	590-690	M/H	618	618	633	633		576
PIC-25-205	5.5 kg/dm2	kg/dm2	5.55	5.55	5.59	5.59		5.55
PIC-25-203	5.55 kg/dm2	kg/dm2	5.55	5.55	5.59	5.59		5.50
TI-25-023	12 °C	°C	12.4	12.4	12.9	12.9		5.55
FI-25-024	-1085 mm	mm	-1044	-1049	-1074	-1074		5.55
TC-12-115	-5 °C	°C	-6.6	-6.6	-6.6	-6.6		-10.1
LI-25-025	-920 mm	mm	-1160	-1178	-1180	-1180		-6.8
TC-12-129	-5 °C	°C	-9.1	-9.1	-2.2	-2.7		-10.1
FI-12-129	1390	M/H	1358	135	1382	1386		9.5
FI-12-116	1269	M/H	1194	1194	1183	1167		8.4
LI-25-021	-13 mm	mm	-13	-13	-13	-13		-13


  
 JBE Chemicals Private Limited  
 Chennai

MINE UNIT (1200 UNIT)

Recorded by \_\_\_\_\_  
 Checked by \_\_\_\_\_

SCHEM 2520 UNIT 2500 NO.3 AMMONIA REFRIGERATION

2520 NO.3 AMMONIA REFRIGERATION

Item	Unit	Time					
		02:00	06:00	10:00	14:00	18:00	22:00
TT-25-211	-9.2 °C	-9.2	-9.5	-9.6	-9.5		
VI-25-205	0.65 mm/s	0.6	0.8	0.7	0.7		-1.0
VI-25-206	1.25 mm/s	1.4	1.4	1.4	1.4		0.57
VI-25-207	1.37 mm/s	1.4	1.4	1.4	1.4		1.4
VI-25-202	46 mm/s	43.8	43.8	44.0	44.0		1.4
VI-25-201	43 mm/s	43.8	43.8	44.0	44.0		1.4
TI-25-201A	51 °C	51.0	50.8	51.0	51.0		45
TI-25-204	85 °C	75.0	77.0	79.0	79.0		5.1
TI-25-202B	85 °C	75.0	77.0	79.0	79.0		7.7
TI-25-202C	81 °C	71.0	73.0	75.0	75.0		7.7
TI-25-201B	51 °C	51.0	51.0	51.0	51.0		7.7
VI-25-203	42 mm/s	40.0	40.0	40.0	40.0		5.1
VI-25-204	47 mm/s	45.0	45.0	45.0	45.0		4.0
PI-25-206	1.38 kg/cm <sup>2</sup>	1.35	1.35	1.35	1.35		4.8
TI-25-214	39.40 °C	1.35	1.35	1.35	1.35		1.4
2520-PIA/B	A or B	A	A	A	A		1.4
2520-PIA/B	A or B	A	A	A	A		1.4
PI-25-204	47 kg/cm <sup>2</sup>	12.5	18.6	12.4	12.4		1.4
PDH-25-201	0.09 kg/cm <sup>2</sup>	0.07	0.07	0.07	0.07		1.4
PI-25-205	17.6 kg/cm <sup>2</sup>	18.4	18.4	18.4	18.4		0.8
PDH-25-212	- kg/cm <sup>2</sup>	18.4	18.4	18.4	18.4		1.4
PDH-25-202	2.74 kg/cm <sup>2</sup>	2.45	2.44	2.43	2.43		2.4
PI-25-202	15 kg/cm <sup>2</sup>	15.0	15.1	15.1	15.1		1.4
TE-25-215	54 °C	70.4	62.7	63.7	63.7		1.4
TI-25-213	11.8 °C	14.5	14.3	13.7	13.5		1.4
SP-PC-203	5.5 kg/cm <sup>2</sup>	5.9	5.5	5.7	5.4		1.4
OPF-PC-203	99.5 %	25.4	20.5	21.2	21.2		6.4
							32.5

Remark: \_\_\_\_\_

Operate Date		SCHM 2530 UNIT 2500 NO.4 AMMONIA REFRIGERATION		DCS LOG SHEET AM					
Item	Unit	Time							
		02:00	06:00	10:00	14:00	18:00	22:00		
TP-25-311	-9 °C	-9.62	-9.75	-9.27	-9.77				-10
VI-25-305	0.64-1.0 mm/s	1.0	1.14	0.81	1.01				0.97
VI-25-306	1.39 mm/s	1.92	1.65	1.5	1.63				1.93
VI-25-307	1.36 mm/s	1.48	1.45	1.45	1.47				1.49
VI-25-302	47 mm/s	47.05	47.88	47.2	47.2				
VI-25-301	44 mm/s	44.16	44.16	44.16	44.16				2.7
TI-25-301A	50 °C	50.0	50.0	50.0	50.1				34
TI-25-302A	82 °C	82	82	82	82				8.2
TI-25-302B	80 °C	77.0	80.0	87.0	80				82
TI-25-302C	82 °C	82	82	82	82				7.9
TI-25-301B	48 °C	48.0	72.0	28	87				8.1
VI-25-301	45 mm/s	45.0	50.0	50.0	50				50
VI-25-304	46 mm/s	46.19	46.36	46.22	46.24				4.0
PI-25-306	1.4 kg/cm2	1.3	1.56	1.3	1.70				1.5
TI-25-314	57-38 °C	3.77	55.75	57.7	52.1				1.95
2530-P2A/B	A or B	A	A	A	A				30.5
2530-P1A/B	A or B	A	A	A	A				A
PI-25-304	17.6 kg/cm2	17.9	17.6	12.7	17.7				9.6
PDI-25-301	0.44 kg/cm2	0.55	0.55	0.71	0.71				6.73
PI-25-305	17.2 kg/cm2	17.29	17.29	18.7	17.36				17.2
PDI-25-312	- kg/cm2								
PDI-25-302	2.18 kg/cm2	2.16	2.16	2.16	2.16				2.7
TI-25-302	15 °C	15.1	15.05	15.01	15.01				15.1
TI-25-315	55 °C	55.24	55.87	57.9	57.9				56.6
TI-25-313	13.5 °C	13.55	13.5	13.5	13.5				23.7
SP PC-303	5.5 kg/cm2	5.5	6.0	6.0	6.0				6.0
OP PC-303	-0.31 %	-0.19	-0.24						-0.0

2530 NO.4 AMMONIA REFRIGERATION

Remark:

Recorded by _____		UPE Checksheet (Initial Public Complaint)		UPB			
Checked by _____		Date _____		Time _____			
SCHEM 4500 Unit-WASTE GAS TREATMENT							
Item	Unit	Time					
		02:00	06:00	10:00	14:00		
FI-45-001	19760 NM/H	16549	16525	18350	18430		
FC-45-001	1.19 NM/H	0.394	1.030	1.030	1.030		
FI-45-004	174 NM/H	11654	11628	11654	11654		
FI-45-005	194 NM/H	11654	11654	11654	11654		
FC-45-006	132 NM/H	11654	11654	11654	11654		
FI-45-001	1623 NM/H	11654	11654	11654	11654		
FI-45-002	13.79 kg/Sec	11654	11654	11654	11654		
TI-45-001	85 C	28.9	32.8	32.8	32.8		
TI-45-001	21.6 Amp	22.5	24.6	24.6	24.6		
FI-45-003	193.9 C	0	0	0	0		
TC-45-004	312 C	1816	1825	1825	1825		
FI-45-006	379 C	2215	2215	2215	2215		
TC-45-009	458 C	3001	3101	3101	3101		
FI-45-022	0.03 kg/Sec	0.034	0.034	0.034	0.034		
PI-45-023	kg/Sec	0.034	0.034	0.034	0.034		
FC-45-024	1190 kg/Sec	SSS	SSS	SSS	SSS		
PI-80-001	2.76 kg/Sec	SSS	SSS	SSS	SSS		
FC-45-021	NM/H	1.59	1.59	1.59	1.59		
FC-45-022	44.2 NM/H	14146	14146	14146	14146		
FC-45-023	2139 NM/H	14525	14525	14525	14525		
FY-45-023	1.19 Ratio	1.161	1.16	1.16	1.16		
PC-11-523 A	2.03 kg/Sec	2.03	2.03	2.03	2.03		
FC-45-013	4620 mmH <sub>2</sub> O	4475	4475	4475	4475		
TI-45-001	262 C	28.5	28.5	28.5	28.5		
TI-45-008	290 C	28.5	28.5	28.5	28.5		
TI-45-005	317 C	28.5	28.5	28.5	28.5		
PI-45-006	589 mmH <sub>2</sub> O	590	590	590	590		

Operate Date		DCS LOG SHEET AM							
SCHIM 4500 Unit-WASTE GAS TREATMENT									
Items	Unit	Time							
		02:00	06:09	10:08	14:00	18:08	22:00		
HC-45-002	106 %	100	105	104	104		100		
4500-P1	A A/B/C	A/C	A/C	B/C	A/C		A/C		
AC-45-001	7 pH	8.24	8.23	8.24	8.20		8.24		
FI-45-007	M/H	0.82	0.85	0.82	0.83		0.77		
LC-45-001	1450 mm	1440	1426	1426	1420		1444		
TO-45-101	15.6 °C	17.0	20.0	22.0	16.0		20		
TO-45-102	460 °C	103.6	106.7	107.0	110.0		452		
TC-45-103	190 °C	190	191.0	191.0	191		191.6		
HC-45-102	106.9 %	100	100	100	100		100		
LC-45-101	350 mm	360	390	390	380		380		
4510-P1	A A/B	D	B	B	B		B		
PI-45-102	-207 mmH2O	-245	-242	-419	-410		-412		
FC-45-101	9680 NM/H	9403	9836	9820	9911		9753		
FC-45-102	NM/H	0	0	0	0		-		
FC-45-103	6.6 M/H	6.52	6.55	6.62	6.63		6.61		
II-45-101	127.2 A	144.2	132.7	181.0	112.0		111.5		
1200-P1	ON OFF	-	-	-	-		-		
LI1210	%	54.5	54.3	57.0	42.2		46.7		
1200-P2	ON OFF	-	-	-	-		-		
LI1211	%	50.3	53.8	57.2	49.0		52.7		
1200-P3	ON OFF	-	-	-	-		-		
LI1219	%	55.2	59.4	58.2	61.6		63.4		
DI				50N	ON		ON		
PI				54.1	SY		57.7		
				6.4	6.4		6.3		

Unit 4500 WG Treatment

Remark:

INE UNIT (200 UNIT)		Recorded by _____		Checked by _____		887 Columbia Road, Public County, Pa 15201	
		SCHM 1230 UNIT 1238 DS RECOVERY					
Item	Unit	Time					
		02:00	06:00	10:00	14:00	18:00	22:00
PF-12-305	84 mmH <sub>2</sub> O	11.6	-1.1	-	-5.7		5
PC-12-301	-25 mmH <sub>2</sub> O	-11.6	-2.4	-11.4	-1.9		2.02
PF-12-302	-340 mmH <sub>2</sub> O	-14.5	-2.1	-5.2	-5.1		-5.91
PF-12-303	265 mmH <sub>2</sub> O	5.25	2.2	6.4	6.2		5.71
PF-12-307	2.73 kg/cm <sup>2</sup>	1.21	2.4	6.4	1.24		1.22
PF-12-308	1 kg/cm <sup>2</sup>	1.1	1.02	1.02	1.07		1.10
PF-12-309	793 mmH <sub>2</sub> O	7.91	7.92	7.92	7.91		7.95
FD-12-301	80 mmH <sub>2</sub> O	9.7	4.5	9.8	9.2		4.1
FC-12-301	16800 NmH <sub>2</sub> O	11.6	11.75	11.6	11.6		11.6
PF-12-302	12.3 mH <sub>2</sub> O	14.4	1.4	14.4	1.4		4.4
FI-12-303	0.6 mH <sub>2</sub> O	2.1	1.52	1.4	1.7		1.7
FC-12-304	0.47 mH <sub>2</sub> O	1.16	1.12	1.1	1.1		1.15
FC-12-306	8.2 NmH <sub>2</sub> O	9.1	9.1	9.2	9.2		9.2
FC-12-307	1173 NmH <sub>2</sub> O	12.0	12.0	12.0	12.0		12.0
FI-12-308	11 mH <sub>2</sub> O	15.1	14.5	17.1	15.2		15.1
FI-12-308	38 NmH <sub>2</sub> O	24.5	24.5	22.0	22.0		21.4
TI-12-301	14.6 °C	9.14	9.12	20.2	20.2		19
TI-12-302	180.7 °C	14.9	14.9	14.9	14.9		14
TC-12-303	178.4 °C	19.2	19.2	19.2	19.2		18.9
TC-12-304	330 °C	21.5	21.5	21.5	21.5		21.5
TI-12-305	338.8 °C	21.7	21.7	21.7	21.7		21.7
TI-12-306	239.2 °C	21.7	21.7	21.7	21.7		21.7
TI-12-307	101.9 °C	9.2	11.1	10.2	9.2		10.1
LC-12-301	50 %	4.4	4.4	4.4	4.4		4.4
AI-12-301	10 Vol%	7.5	7.4	7.4	7.6		7.4
AI-12-302A	4 ppm	2.6	2.6	2.6	2.6		2.6
AI-12-302B	5 ppm	2.5	2.5	2.5	2.4		2.4

Location	Lat	Long	Alt	Remarks
1201	12.00	120.00	1200	Remarks
1202	12.00	120.00	1200	Remarks
1203	12.00	120.00	1200	Remarks
1204	12.00	120.00	1200	Remarks
1205	12.00	120.00	1200	Remarks
1206	12.00	120.00	1200	Remarks
1207	12.00	120.00	1200	Remarks
1208	12.00	120.00	1200	Remarks
1209	12.00	120.00	1200	Remarks
1210	12.00	120.00	1200	Remarks
1211	12.00	120.00	1200	Remarks
1212	12.00	120.00	1200	Remarks
1213	12.00	120.00	1200	Remarks
1214	12.00	120.00	1200	Remarks
1215	12.00	120.00	1200	Remarks
1216	12.00	120.00	1200	Remarks
1217	12.00	120.00	1200	Remarks
1218	12.00	120.00	1200	Remarks
1219	12.00	120.00	1200	Remarks
1220	12.00	120.00	1200	Remarks
1221	12.00	120.00	1200	Remarks
1222	12.00	120.00	1200	Remarks
1223	12.00	120.00	1200	Remarks
1224	12.00	120.00	1200	Remarks
1225	12.00	120.00	1200	Remarks
1226	12.00	120.00	1200	Remarks
1227	12.00	120.00	1200	Remarks
1228	12.00	120.00	1200	Remarks
1229	12.00	120.00	1200	Remarks
1230	12.00	120.00	1200	Remarks
1231	12.00	120.00	1200	Remarks
1232	12.00	120.00	1200	Remarks
1233	12.00	120.00	1200	Remarks
1234	12.00	120.00	1200	Remarks
1235	12.00	120.00	1200	Remarks
1236	12.00	120.00	1200	Remarks
1237	12.00	120.00	1200	Remarks
1238	12.00	120.00	1200	Remarks
1239	12.00	120.00	1200	Remarks
1240	12.00	120.00	1200	Remarks
1241	12.00	120.00	1200	Remarks
1242	12.00	120.00	1200	Remarks
1243	12.00	120.00	1200	Remarks
1244	12.00	120.00	1200	Remarks
1245	12.00	120.00	1200	Remarks
1246	12.00	120.00	1200	Remarks
1247	12.00	120.00	1200	Remarks
1248	12.00	120.00	1200	Remarks
1249	12.00	120.00	1200	Remarks
1250	12.00	120.00	1200	Remarks
1251	12.00	120.00	1200	Remarks
1252	12.00	120.00	1200	Remarks
1253	12.00	120.00	1200	Remarks
1254	12.00	120.00	1200	Remarks
1255	12.00	120.00	1200	Remarks
1256	12.00	120.00	1200	Remarks
1257	12.00	120.00	1200	Remarks
1258	12.00	120.00	1200	Remarks
1259	12.00	120.00	1200	Remarks
1260	12.00	120.00	1200	Remarks
1261	12.00	120.00	1200	Remarks
1262	12.00	120.00	1200	Remarks
1263	12.00	120.00	1200	Remarks
1264	12.00	120.00	1200	Remarks
1265	12.00	120.00	1200	Remarks
1266	12.00	120.00	1200	Remarks
1267	12.00	120.00	1200	Remarks
1268	12.00	120.00	1200	Remarks
1269	12.00	120.00	1200	Remarks
1270	12.00	120.00	1200	Remarks
1271	12.00	120.00	1200	

UBE

UPE Chemicals (Pvt) Public Company Limited

Recorded by *Mr. [Signature]*

Operate Date: 15/11/14

DCS LOG SHEET AMINE UNIT (1200 UNIT) Checked by \_\_\_\_\_

2500 Ammonia Refrigeration

SCHM 2500 Unit -2500 AMMONIA REFRIGERATION											
Item	Unit	Time									
		02:00	04:00	06:00	08:00	10:00	12:00	14:00	16:00	18:00	20:00
LC-25-002	500 mm	500	490	480	470	460	450	440	430	420	410
FI-25-001	1.01 M/H	1.01	1.01	1.01	1.01	1.01	1.01	1.01	1.01	1.01	1.01
FC-25-002	5 M/H	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
FI-25-004	440 M/H	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8
LI-25-001	1256 mm	1540	1540	1540	1540	1540	1540	1540	1540	1540	1540
PC-25-001	1.6 kg/cm <sup>2</sup>	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
PC-25-002	3.5 kg/cm <sup>2</sup>	5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3
2500-P1	A A/B	B	B	B	B	B	B	B	B	B	B
SCHM 2501 Unit -2500 AMMONIA REFRIGERATION											
PC-25-021	1.8 kg/cm <sup>2</sup>										
O.P.P.C-021	%										
SI-25-021	>8000 rpm										
FC-25-021	12500 A/m <sup>2</sup>										
TC-25-021	-8.4 °C										
LI-25-022	150 °C										
LI-25-022	13 kg/cm <sup>2</sup>										
LI-25-022	220 mm										
PI-25-023	6.5 kg/cm <sup>2</sup>										
FI-25-022	550 NM/H										
LI-25-021	-12 mm										
LC-25-024	-1156 mm										
LC-25-025	-396 mm										
TC-12-115	-5.5 °C										
TC-12-129	-5.6 °C										
LC-25-023	776 mm										
FC-25-023	6929 A/m <sup>2</sup>										
FI-25-024	33357 NM/H										
FI-25-025	39820 NM/H										
Circulate 1210-ES	1028 M/H										

Remark:

2500 Ammonia Refrigeration

SCHM 2502 Unit -2500 AMMONIA REFRIGERATION											
Item	Unit	Time									
		02:00	04:00	06:00	08:00	10:00	12:00	14:00	16:00	18:00	20:00
TI-25-051	64.8 °C										
TI-25-052	52.9 °C										
TI-25-053	92.4 °C										
TI-25-054	92.1 °C										
TI-25-055	82.6 °C										
TI-25-056	78.8 °C										
TI-25-057	73 °C										
TI-25-058	53.3 °C										
PI-25-081	73.1 mmHgA										
LC-25-082	mm										
FI-25-082	16.5 T/H										
PC-00-091	22.51 kg/cm <sup>2</sup>										
2500-K1-P1	service -										
2500-K1-T2	stand by -										
2500-P2	A/B A/B										
VIBRA - AXIAL DISP. Unit -2500 AMMONIA REFRIGERATION											
XVI-25-051	29.66 um										
YVI-25-051	28.41 um										
XVI-25-052	29.37 um										
YVI-25-052	22.12 um										
ZI-25-051	0.41 um										
ZI-25-052	0.01 um										
XVI-25-053	10.92 um										
YVI-25-053	28.73 um										
XVI-25-054	13.97 um										
YVI-25-054	13.05 um										
ZI-25-053	-0.19 um										
ZI-25-054	-0.25 um										

Remark:

Page 4 of 8

FM-LCS-00-001-0207/2018/Rev.03

UBE

UBE Chemicals (Pvt) Public Company Limited

Recorded by *Mr. [Signature]*

Operate Date: 15/11/14

DCS LOG SHEET AMINE UNIT (1200 UNIT) Checked by \_\_\_\_\_

SCHM 1221 UNIT 1220 AW & SI PRODUCTION									
Item	Unit	Time							
		00:00	04:00	08:00	12:00	16:00	20:00		
FI-12-201	22643 NM/H	1510	15355	15405	15405	15405	15405		
LI-12-201	-8.1 °C	1.7	1.7	1.7	1.7	1.7	1.7		
PC-12-101	1.32 kg/cm <sup>2</sup>	1.31	1.31	1.31	1.31	1.31	1.31		
FC-12-202	58.9 M/H	53.5	53.5	53.5	53.5	53.5	53.5		
FI-12-203	530 M/H	703	711	711	711	711	711		
PC-12-203	0.82 kg/cm <sup>2</sup>	1.04	1.04	1.04	1.04	1.04	1.04		
LI-12-202	49 °C	50.5	50.5	50.5	50.5	50.5	50.5		
TC-12-203	35 °C	35.0	35.0	35.0	35.0	35.0	35.0		
LI-12-203	>3000 mm	1115	1115	1115	1115	1115	1115		
LI-12-204	31.4 °C	31.4	31.4	31.4	31.4	31.4	31.4		
TC-12-203	32.3 °C	31.3	31.3	31.3	31.3	31.3	31.3		
FC-12-204	44.8 M/H	45.10	45.10	45.10	45.10	45.10	45.10		
FI-12-204	0.73 Ratio	0.71	0.71	0.71	0.71	0.71	0.71		
FC-12-205	61 M/H	54.12	54.12	54.12	54.12	54.12	54.12		
AC-12-201	914 g/l	921	921	921	921	921	921		
AC-12-202	943 g/l	947	947	947	947	947	947		
LI-12-204	>3000 mm	1111	1111	1111	1111	1111	1111		
1220-P1	A A/B	A	A	A	A	A	A		
1220-P4	A A/B	B	B	B	B	B	B		
1220-P5	A/C A/B/C	A/C	A/C	A/C	A/C	A/C	A/C		
1220-P6	A A/B	A	A	A	A	A	A		
LI-12-205	33.7 °C	33.3	33.3	33.3	33.3	33.3	33.3		
LC-12-202	2000 mm	5600	5600	5600	5600	5600	5600		
SCHM 1222 Unit 1220 SI PRODUCT									
Item	Unit	Time							
		00:00	04:00	08:00	12:00	16:00	20:00		
FI-12-203	39.7 M/H	39.7	39.7	39.7	39.7	39.7	39.7		
FC-12-120	7.4 KNM/H	9.3	9.3	9.3	9.3	9.3	9.3		
FI-12-211	25.3 KNM/H	10.1	10.1	10.1	10.1	10.1	10.1		
LI-12-204	0.2 kg/cm <sup>2</sup>	0.3	0.3	0.3	0.3	0.3	0.3		

1220-C2 SI Column

SCHM 1222 Unit 1220 SI PRODUCT									
Item	Unit	Time							
		00:00	04:00	08:00	12:00	16:00	20:00		
AI-41-406	144 %Vol								
AI-41-701	131 %Vol	16.7	17.2	17.4	17.4	17.4	17.4		
TC-12-200	52.6 °C	51.6	52.1	52.5	52.5	52.5	52.5		
AC-12-204	6.46 pH	6.46	6.43	6.40	6.40	6.40	6.40		
FI-12-209	668 M/H	135	140	140	140	140	140		
TC-12-209	43.9 °C	43.3	43.6	44.0	44.0	44.0	44.0		
FC-12-206	19.2 M/H	15.44	15.47	15.51	15.51	15.51	15.51		
FY-12-206	4.09 Ratio	0.373	0.373	0.373	0.373	0.373	0.373		
FI-12-207	39 M/H	39.7	39.7	39.7	39.7	39.7	39.7		
LI-12-205	7000 mm	7944	7953	7953	7953	7953	7953		
AC-12-203	1158 g/l	1149	1149	1149	1149	1149	1149		
LI-12-207	44.2 °C	44.3	44.4	44.5	44.5	44.5	44.5		
HC-12-201	61 %	59	59	59	59	59	59		
1220-P2	A A/B	B	B	B	B	B	B		
1220-P3	A A/B	B	B	B	B	B	B		
1220-P7	A A/B	A	A	A	A	A	A		
1220-P8	A A/B	A	A	A	A	A	A		
1220-P9	A A/B	B	B	B	B	B	B		
SCHM 2500 Unit -2500 AMMONIA REFRIGERATION									
Item	Unit	Time							
		02:00	06:00	10:00	14:00	18:00	22:00		
FI-00-002	-28.11 °C	-27.46	-27.51	-27.4	-27.4	-27.4	-27.4		
FI-25-003	34 M/H	31.17	31.43	31.71	31.71	31.71	31.71		
FQ-25-003	m <sup>3</sup>	19495	19494	19494	19494	19494	19494		
FI-25-004	-1.2 Temp/Hr								
FI-25-024	0.21 kg/cm <sup>2</sup>	0.24	0.19	0.15	0.15	0.15	0.15		
FI-25-083	8.91 M3/H								
2500-1	- ON/OFF								
TC-12-116	-6.2 °C	-7.5	-7.1	-6.3	-6.1	-6.1	-6.1		
LC-25-001	>450 mm	194	194	194	194	194	194		
TC-25-001	5 °C	5.1	5.1	5.1	5.1	5.1	5.1		

2500 Ammonia Refrigeration

Remark:

Page 3 of 8

FM-LCS-00-001-0207/2018/Rev.03

UBE UBE Chemicals (Pvt) Public Company Limited

Recorded by *Mr. [Signature]*

UBE UBE Chemicals (Pvt) Public Company Limited

Operate Date: 15/11/14

DCS LOG SHEET AMINE UNIT (1200 UNIT) Checked by \_\_\_\_\_

SCHM 1212 UNIT 1210 AMINE PRODUCT							
Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
TI-12-110	78.8 °C	78.8	78.8	78.8	78.8	78.8	78.8
TI-12-112	-1.4 °C	-1.4	-1.4	-1.4	-1.4	-1.4	-1.4
TI-12-113	-4.5 °C	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5
TI-12-114	-5.2 °C	-5.2	-5.2	-5.2	-5.2	-5.2	-5.2
AI-12-103	- g/l						
AI-12-104	- ppm						
AI-12-105	8.22 pH	5.70	5.46	5.46	5.46	5.46	5.46
FI-12-106	2762 M/H	4471	4471	4471	4471	4471	4471
FI-12-107	1208 M/H	135	135	135	135	135	135
FI-12-127	M/H	419	419	419	419	419	419
FC-12-108	60 M/H	10.31	10.31	10.31	10.31	10.31	10.31
FC-12-109	7 M/H	7.51	7.51	7.51	7.51	7.51	7.51
FC-12-110	1182 M/H	1014	1014	1014	1014	1014	1014
FI-12-111	53.2 M/H	10.26	10.26	10.26	10.26	10.26	10.26
FI-12-110	1.13 Ratio	1.17	1.17	1.17	1.17	1.17	1.17
PI-12-108	0.075 kg/cm <sup>2</sup>	0.075	0.075	0.075	0.075	0.075	0.075
LI-12-107	1759 mm	1509	1509	1509	1509	1509	1509
LI-12-118	-0.7 °C	-0.7	-0.7	-0.7	-0.7	-0.7	-0.7
TI-12-119	-1.9 °C	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9
LI-12-102	34 Amp	35.52	35.52	35.52	35.52	35.52	35.52
1210-P2	A A/B	B	B	B	B	B	B
1210-P3	A A/B	A	A	A	A	A	A
1210-P6	A/C A/B/C	A/C	A/C	A/C	A/C	A/C	A/C
LC-12-105	350 mm	355	355	355	355	355	355
LC-12-106	300 mm	300	300	300	300	300	300

Remark:

SCHM 1213 UNIT 1210 AMINE PRODUCT							
Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
TI-12-120	-0.9 °C	-1.7	-2.4	-2.4	-2.4	-2.4	-2.4
TI-12-121	39.9 °C	42.1	42.1	42.1	42.1	42.1	42.1
FI-12-106	0.27 kg/cm <sup>2</sup>	0.913	0.993	0.993	0.993	0.993	0.993
FI-12-112	26.24 KMM/H	21.50	21.50	21.50	21.50	21.50	21.50
FC-12-113	18.9 KMM/H	15.45	15.45	15.45	15.45	15.45	15.45
FC-12-114	4.18 M/H	5.19	5.19	5.19	5.19	5.19	5.19
FI-12-115	71.9 M/H	61.95	61.95	61.95	61.95	61.95	61.95
FI-12-116	1195 M/H	1171	1171	1171	1171	1171	1171
FI-12-128	M/H	419	419	419	419	419	419
II-12-103	419 Amp	51	51	51	51	51	51
AC-12-406	23 pH	9.57	9.57	9.57	9.57	9.57	9.57
AC-12-107	270 mm	300.1	300.1	300.1	300.1	300.1	300.1
PC-12-407	0.67 kg/cm <sup>2</sup>	0.917	0.959	0.959	0.959	0.959	0.959
TI-12-122	34.5 °C	43.7	43.7	43.7	43.7	43.7	43.7
TI-12-123	40.9 °C	48.0	48.0	48.0	48.0	48.0	48.0
TI-12-125	107.7 °C	107.7	107.7	107.7	107.7	107.7	107.7
TI-12-128	108.1 °C	117.7	117.7	117.7	117.7	117.7	117.7
FI-12-117	64.8 M/H	54.59	55.19	55.19	55.19	55.19	55.19
LI-12-109	> 1500 mm	1497	1497	1497	1497	1497	1497
1210-P4	A A/B	B	B	B	B	B	B
1210-P5	A A/B	A	A	A	A	A	A
1210-P7	A A/B	A	A	A	A	A	A
HC-12-102	56 %	51	47	46	44	44	44
FG-12-112	KMM	720.97	720.97	720.97	720.97	720.97	720.97
FQ-12-115	M/H	1759.93	1759.93	1759.93	1759.93	1759.93	1759.93
TI-12-124	9.7 °C	9.4	9.4	9.4	9.4	9.4	9.4
TI-12-126	49.7 °C	53.7	53.7	53.7	53.7	53.7	53.7
TI-12-127	26.9 °C	29.4	29.4	29.4	29.4	29.4	29.4
FY-12-114	0.79 Ratio	0.73	0.577	0.51	0.51	0.51	0.51

Remark:

1210-C1 Nd Column

1210-C2 DS Column

Page 2 of 8

FM-LCS-00-001-0207/2018/Rev.03

UBE

UBE Chemicals (Pvt) Public Company Limited

Recorded by *Mr. [Signature]*

23

Operate Date 15/11/14

# DCS LOG SHEET AMINE UNIT (1200 UNIT)

Checked by \_\_\_\_\_

1210-R1,1-2 Anmonia Oxidizer

SCHM 1211 Unit 1210 AMINE PRODUCT							
Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
FC-12-101	26446 NM/H	15147	15147	15147	15147	15147	15147
FC-12-102	2779 NM/H	9171	9171	9171	9171	9171	9171
FI-12-101	0.096 -	0.095	0.095	0.095	0.095	0.095	0.095
LI-12-101	32 Amp	30.54	30.54	30.54	30.54	30.54	30.54
FI-12-104	2211 mmH <sub>2</sub> O	3155	3155	3155	3155	3155	3155
TI-12-101	-6.9 °C	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3
TC-12-102	770 °C	714	714	714	714	714	714
TC-12-103	757 °C	750	750	750	750	750	750
TI-12-104	765 °C	765	765	765	765	765	765
TI-12-105	773 °C	773	773	773	773	773	773
TI-12-106	214 °C	111.3	106.1	106.1	106.1	106.1	106.1
TI-12-107	215 °C	315.7	308.9	308.9	308.9	308.9	308.9
TI-12-108	102.8 °C	100.2	97.6	97.6	97.6	97.6	97.6
TI-12-109	105.9 °C	104.4	101.8	101.8	101.8	101.8	101.8
FI-12-105	8.05 M/H	9.44	9.44	9.44	9.44	9.44	9.44
FI-12-119	9.35 M/H	10.31	10.31	10.31	10.31	10.31	10.31
PC-12-102	1.53 kg/cm <sup>2</sup>	1.51	1.51	1.51	1.51	1.51	1.51
AC-12-101	6 pH	4.55	4.55	4.55	4.55	4.55	4.55
AI-12-102	1.15 pH	0.53	0.53	0.53	0.53	0.53	0.53
AI-12-108	4.2 pH	11.05	11.05	11.05	11.05	11.05	11.05
AI-12-109	498 M/c s/c	11.05	11.05	11.05	11.05	11.05	11.05
1210-P10	A A/B	B	B	B	B	B	B
LC-12-101	ON ON-OFF	ON	ON	ON	ON	ON	ON
HC-12-104	0 %	0	0	0	0	0	0
HC-12-105	0 %	55	55	55	55	55	55
HC-12-106	68 %	90	90	90	90	90	90
FI-12-103	90 m <sup>3</sup> /hr	4.7	4.7	4.7	4.7	4.7	4.7
FI-12-104	5 m <sup>3</sup> /hr	3.1	3.1	3.1	3.1	3.1	3.1
FI-12-118	0 Ratio	0	0	0	0	0	0

Remark:

1210-R1-3 Anmonia Oxidizer

SCHM 1211A Unit 1210 AMINE PRODUCT							
Item	Unit	Time					
		00:00	04:00	08:00	12:00	16:00	20:00
FC-12-121	12716 NM/H	15147	15147	15147	15147	15147	15147
FC-12-122	1330 NM/H	1472	1472	1472	1472	1472	1472
FQ-12-122	NM	9171	9171	9171	9171	9171	9171
FI-12-121	0.098 -	0.095	0.095	0.095	0.095	0.095	0.095
FI-12-104	23 Amp	30.54	30.54	30.54	30.54	30.54	30.54
FI-12-111	1830 mmH <sub>2</sub> O	3055	3055	3055	3055	3055	3055
TC-12-132	770 °C	714	714	714	714	714	714
TI-12-131A	778 °C	714	714	714	714	714	714
TI-12-134A	209.1 °C	208.2	208.2	208.2	208.2	208.2	208.2
TI-12-135	53.1 °C	53.1	53.1	53.1	53.1	53.1	53.1
TI-12-136	101.2 °C	97.6	97.6	97.6	97.6	97.6	97.6
TI-12-137A	72.4 °C	69.9	69.9	69.9	69.9	69.9	69.9
FI-12-123	2.94 m <sup>3</sup> /h	5.31	5.31	5.31	5.31	5.31	5.31
FI-12-124	2.06 m <sup>3</sup> /h	1.73	1.73	1.73	1.73	1.73	1.73
FI-12-125	5.03 m <sup>3</sup> /h	5.31	5.31	5.31	5.31	5.31	5.31
FI-12-126	1.58 m <sup>3</sup> /h	5.31	5.31	5.31	5.31	5.31	5.31
FQ-12-126	unit	15574	15574	15574	15574	15574	15574
PC-12-110	15.4 kg/cm <sup>2</sup>	15.0	15.0	15.0	15.0	15.0	15.0
AC-12-111	1.5 pH	4.2	4.2	4.2	4.2	4.2	4.2
AI-12-111	342 M/c w/c	154	154	154	154	154	154
AI-12-112	9.5 pH	9.4	9.4	9.4	9.4	9.4	9.4
LC-12-111	0 mm	4	4	4	4	4	4
1S-12-111	ON ON/OFF	ON	ON	ON	ON	ON	ON
HV-12-109	32 %	50	50	50	50	50	50
HV-12-110	48 %	30	30	30	30	30	30
FQ-12-102	NM	9171	9171	9171	9171	9171	9171

Remark:

Page 1 of 8

FM-LCS-00-001-0207/2018/Rev.03



Recorded by *hml* 23  
 UBE  
 Unit 4500 WG Treatment  
 Operate Date 15/4/14 DCS LOG SHEET AMINE UNIT (1200 UNIT) Checked by *hml*  
 SCHM 4500 Unit-WASTE GAS TREATMENT

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
HC-45-002	106 %	106	106	106	106	106	106
4500-P1	A A/B/C	AC	AC	AC	AC	AC	AC
AC-45-001	7 pH	5.58	5.70	5.77	5.81	5.78	5.77
FI-45-007	M/H	0	0	0	0	0	0
LC-45-001	1450 mm	1495	1495	1495	1495	1495	1495
TC-45-101	15.6 °C	91.0	91.7	91.7	91.4	91.4	91.4
TC-45-102	460 °C	449.1	449.1	449.1	449.1	449.1	449.1
TC-45-103	190 °C	146.4	146.4	146.4	146.4	146.4	146.4
HC-45-102	106.9 %	107	107	107	107	107	107
LC-45-101	350 mm	350	350	350	350	350	350
4510-P1	A A/B	B	B	B	B	B	B
PI-45-102	-207 mmH2O	207.5	207.5	207.5	207.5	207.5	207.5
FC-45-101	9080 NM/H	9080	9080	9080	9080	9080	9080
FC-45-102	NM/H	0	0	0	0	0	0
FC-45-103	0.6 M/H	0.507	0.504	0.504	0.504	0.504	0.504
HC-45-101	127.2 A	101.3	101.3	101.3	101.3	101.3	101.3
1200-P1	ON OFF	OH	OH	OH	OH	OH	OH
121210	%	0.43	0.43	0.43	0.43	0.43	0.43
1200-P2	ON OFF	OH	OH	OH	OH	OH	OH
121211	%	0.43	0.43	0.43	0.43	0.43	0.43
1200-P3	ON OFF	OH	OH	OH	OH	OH	OH
121212	%	0.43	0.43	0.43	0.43	0.43	0.43
1200-P4	ON OFF	OH	OH	OH	OH	OH	OH
121213	%	0.43	0.43	0.43	0.43	0.43	0.43

Remark:

Page 8 of 8

FM-LS-00-001/0207/2018/Rev.03

Recorded by *hml* 23  
 UBE  
 Unit 4500 WG Treatment  
 Operate Date 15/4/14 DCS LOG SHEET AMINE UNIT (1200 UNIT) Checked by *hml*  
 SCHM 4500 Unit-WASTE GAS TREATMENT

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
FI-45-001	19260 NM/H	19260	19260	19260	19260	19260	19260
FC-45-003	1.19 M/H	0.935	0.935	0.935	0.935	0.935	0.935
FC-45-004	174 M/H	174	174	174	174	174	174
FI-45-005	194 M/H	173.8	173.7	173.7	173.7	173.7	173.7
FC-45-006	132 NM/H	126.2	126.2	126.2	126.2	126.2	126.2
FI-45-007	14.25 kg/cm2	10.97	10.97	10.97	10.97	10.97	10.97
PI-45-002	13.79 kg/cm2	10.97	10.97	10.97	10.97	10.97	10.97
TI-45-001	85 °C	36.0	36.0	36.0	36.0	36.0	36.0
II-45-001	21.6 Amp	39.8	39.8	39.8	39.8	39.8	39.8
TI-45-003	193.0 °C	141.3	141.3	141.3	141.3	141.3	141.3
TC-45-004	312 °C	294.6	294.6	294.6	294.6	294.6	294.6
TC-45-006	379 °C	311.4	311.4	311.4	311.4	311.4	311.4
TC-45-009	468 °C	355.4	355.4	355.4	355.4	355.4	355.4
PI-45-022	0.03 kg/cm2	0.029	0.029	0.029	0.029	0.029	0.029
FC-45-023	1100 kg/cm2	1253	1253	1253	1253	1253	1253
PI-00-001	2.76 kg/cm2	1.917	1.917	1.917	1.917	1.917	1.917
FC-45-021	NM/H	0	0	0	0	0	0
FC-45-022	44.2 NM/H	20.35	20.35	20.35	20.35	20.35	20.35
FC-45-023	2329 NM/H	194.4	194.4	194.4	194.4	194.4	194.4
FI-45-023	1.89 Ratio	1.15	1.15	1.15	1.15	1.15	1.15
PI-11-523	1.03 kg/cm2	0.021	0.021	0.021	0.021	0.021	0.021
FC-45-003	-420 mmH2O	-21.6	-21.6	-21.6	-21.6	-21.6	-21.6
TI-45-002	26.2 °C	22.7	22.7	22.7	22.7	22.7	22.7
TI-45-008	290 °C	277.4	277.4	277.4	277.4	277.4	277.4
TI-45-005	317 °C	301.6	301.6	301.6	301.6	301.6	301.6
PI-45-006	589 mmH2O	597	597	597	597	597	597

Remark:

Page 7 of 8

FM-LS-00-001/0207/2018/Rev.03

Recorded by *hml* 23  
 UBE  
 AMMONIA REFRIGERATION  
 Operate Date 15/4/14 DCS LOG SHEET AMINE UNIT (1200 UNIT) Checked by *hml*  
 SCHM 2503 Unit-2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
REM-SP-201	1.6-1.7 kg/cm2	1.70	1.70	1.70	1.70	1.70	1.70
PI-25-201	1.6-1.7 kg/cm2	1.71	1.71	1.71	1.71	1.71	1.71
25-25-201	299 %	91.33	91.33	91.33	91.33	91.33	91.33
II-25-201	165-171 Amp	171.43	171.43	171.43	171.43	171.43	171.43
REM-SP-301	1.58 kg/cm2	1.58	1.58	1.58	1.58	1.58	1.58
PI-25-301	1.7 kg/cm2	1.71	1.71	1.71	1.71	1.71	1.71
25-25-301	99.8 %	99.76	99.76	99.76	99.76	99.76	99.76
II-25-301	177-183 Amp	177.95	177.95	177.95	177.95	177.95	177.95
TC-25-021	-11 °C	-11.6	-11.6	-11.6	-11.6	-11.6	-11.6
PI-25-021	1.7-1.8 kg/cm2	1.71	1.71	1.71	1.71	1.71	1.71
25-25-021	37000 M/H	37000	37000	37000	37000	37000	37000
TI-25-213	81-82 °C	81.4	81.4	81.4	81.4	81.4	81.4
PI-25-202	14.5-15.0 kg/cm2	15.07	15.07	15.07	15.07	15.07	15.07
TI-25-212	82 °C	81.7	81.7	81.7	81.7	81.7	81.7
PI-25-203	14.5-15.0 kg/cm2	15.07	15.07	15.07	15.07	15.07	15.07
PI-25-022	13.8-14.8 kg/cm2	13.81	13.81	13.81	13.81	13.81	13.81
LI-25-022	-30 mm	89.3	89.3	89.3	89.3	89.3	89.3
LC-25-023	630 mm	107	107	107	107	107	107
FI-25-022	590-690 M/H	597	597	597	597	597	597
PI-25-303	5.5 kg/cm2	5.71	5.71	5.71	5.71	5.71	5.71
PI-25-304	5.5 kg/cm2	5.70	5.70	5.70	5.70	5.70	5.70
TI-25-023	12 °C	13.4	13.4	13.4	13.4	13.4	13.4
TC-25-024	-108.5 mm	-109.4	-109.4	-109.4	-109.4	-109.4	-109.4
TC-12-115	-5 °C	-5.1	-5.1	-5.1	-5.1	-5.1	-5.1
LC-25-025	-920 mm	-919.7	-919.7	-919.7	-919.7	-919.7	-919.7
TC-12-129	-5 °C	-5.7	-5.7	-5.7	-5.7	-5.7	-5.7
FI-12-129	1390 M/H	1390	1390	1390	1390	1390	1390
FI-12-116	1269 M/H	1269	1269	1269	1269	1269	1269
LI-25-021	-13 mm	-13	-13	-13	-13	-13	-13

Remark:

Page 6 of 8

FM-LS-00-001/0207/2018/Rev.03

Recorded by *hml* 23  
 UBE  
 AMMONIA REFRIGERATION  
 Operate Date 15/4/14 DCS LOG SHEET AMINE UNIT (1200 UNIT) Checked by *hml*  
 SCHM 2503 Unit-2500 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
PI-25-211	-9.2 °C	-10.43	-10.43	-10.43	-10.43	-10.43	-10.43
VI-25-205	0.65 mm/s	0.31	0.31	0.31	0.31	0.31	0.31
VI-25-206	1.25 mm/s	1.18	1.18	1.18	1.18	1.18	1.18
VI-25-207	1.37 mm/s	1.18	1.18	1.18	1.18	1.18	1.18
VI-25-208	46 mm/s	46.11	46.11	46.11	46.11	46.11	46.11
VI-25-209	43 mm/s	46.11	46.11	46.11	46.11	46.11	46.11
TI-25-201A	51 °C	51	51	51	51	51	51
TI-25-202A	85 °C	85	85	85	85	85	85
TI-25-203A	85 °C	85	85	85	85	85	85
TI-25-204A	81 °C	81	81	81	81	81	81
VI-25-204	42 mm/s	42	42	42	42	42	42
VI-25-205	1.38 kg/cm2	1.31	1.31	1.31	1.31	1.31	1.31
25-25-214	39-40 °C	39.4	39.4	39.4	39.4	39.4	39.4
2520-P2A/B	A or B	A	A	A	A	A	A
2520-P1A/B	A or B	B	B	B	B	B	B
PI-25-204	47 kg/cm2	15.16	15.16	15.16	15.16	15.16	15.16
PDI-25-201	0.09 kg/cm2	0.09	0.09	0.09	0.09	0.09	0.09
PI-25-205	17.6 kg/cm2	17.1	17.1	17.1	17.1	17.1	17.1
PDI-25-212	- kg/cm2	0	0	0	0	0	0
PDI-25-203	2.74 kg/cm2	2.11	2.11	2.11	2.11	2.11	2.11
PI-25-202	15 kg/cm2	15.04	15.04	15.04	15.04	15.04	15.04
TI-25-215	54 °C	54.30	54.30	54.30	54.30	54.30	54.30
TI-25-213	11.8 °C	11.8	11.8	11.8	11.8	11.8	11.8
SP-PC-203	5.5 kg/cm2	5.40	5.40	5.40	5.40	5.40	5.40
OP-PC-203	99.5 %	99.51	99.51	99.51	99.51	99.51	99.51

Remark:

Page 5 of 8

FM-LS-00-001/0207/2018/Rev.03

6. 5

Page 1 of 8

FM-LC9-00-001.02/07/2018:Rev.03

Page 3 of 8



Recorded by \_\_\_\_\_

Checked by \_\_\_\_\_

Operate Date \_\_\_\_\_

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCHM 2500 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	Time	02:00	06:00	10:00	14:00	18:00	22:00
LC-25-002	500 mm		410	410	410	410	410	410
FC-25-001	1.01 M/H		1.2	1.2	1.2	1.2	1.2	1.2
FC-25-002	5 M/H		1.2	1.2	1.2	1.2	1.2	1.2
PI-25-001	400 M/H		1.2	1.2	1.2	1.2	1.2	1.2
LI-25-001	1256 mm		1.2	1.2	1.2	1.2	1.2	1.2
PC-25-001	1.6 kg/cm2		1.2	1.2	1.2	1.2	1.2	1.2
PC-25-002	3.5 kg/cm2		1.2	1.2	1.2	1.2	1.2	1.2
2500-P1	A A/B		1.2	1.2	1.2	1.2	1.2	1.2
SCHM 2501 Unit -2500 AMMONIA REFRIGERATION								
PC-25-011	1.5 kg/cm2							
OP-PC-021	%							
SI-25-011	>8000 rpm							
PC-25-021	12500 A/B/H							
TC-25-021	-5.4 °C							
TI-25-022	150 °C							
PI-25-022	12 kg/cm2							
LI-25-022	220 mm							
PI-25-023	6.5 kg/cm2							
PI-25-022	550 NM/H							
LI-25-021	-12 mm							
LC-25-024	-1156 mm							
LC-25-025	-596 mm							
TC-12-115	-5.5 °C							
TC-12-119	-5.6 °C							
LC-25-023	776 mm							
FC-25-023	6919 Am/H							
FI-25-024	35357 NM/H							
FI-25-025	39820 NM/H							
Circulate 1216-ES	1028 M/H							

Remark: \_\_\_\_\_

Recorded by \_\_\_\_\_

Checked by \_\_\_\_\_

Operate Date \_\_\_\_\_

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCHM 2500 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	Time	02:00	06:00	10:00	14:00	18:00	22:00
PI-25-005	1513 M/H							
TC-25-002	4.4 °C							
LC-25-004	40 mm							
PC-25-003	3.351 kg/cm2							
FI-25-005	M/H							
SCHM 2511 Unit -NO.2 AMMONIA REFRIGERATION								
TC-12-143	-6.0 °C							
LC-25-124	530 mm							
LC-12-144	-5.2 °C							
LC-25-125	630 mm							
TI-25-121	130.29 A							
ZI-25-121	95.8 %							
VE-25-129	1.6 mm/s							
VE-25-121	-0.5 mm/s							
VE-25-122	0.51 mm/s							
VE-25-123	-0.12 mm/s							
VE-25-124	0.23 mm/s							
VE-25-127	4.46 mm/s							
VE-25-128	3.75 mm/s							
TE-25-121A	53.11 °C							
TE-25-121B	51.61 °C							
TE-25-22A	75.89 °C							
TE-25-22B	77.29 °C							
TE-25-22C	76.41 °C							

Remark: \_\_\_\_\_

Recorded by \_\_\_\_\_

Checked by \_\_\_\_\_

Operate Date \_\_\_\_\_

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCHM 2503 Unit -2500 AMMONIA REFRIGERATION

Item	Unit	Time	02:00	06:00	10:00	14:00	18:00	22:00
REM-SP-201	1.6-1.7 kg/cm2							
PI-25-201	1.6-1.7 kg/cm2							
FI-25-201	>99 %							
II-25-201	165-171 Amp							
REM-SP-301	1.58 kg/cm2							
PI-25-301	1.7 kg/cm2							
ZI-25-301	99.8 %							
II-25-301	177-185 Amp							
TC-25-021	-11 °C							
PC-25-021	1.7-1.8 kg/cm2							
FI-25-024	37003 M/H							
FI-25-025	81-82 °C							
PI-25-202	14.5-15.0 kg/cm2							
TC-25-312	82 °C							
PI-25-302	14.5-15.0 kg/cm2							
PI-25-022	13.8-14.6 kg/cm2							
LI-25-022	-30 mm							
LC-25-023	630 mm							
FI-25-022	590-690 M/H							
PI-25-203	5.5 kg/cm2							
PI-25-303	5.55 kg/cm2							
TC-25-023	12 °C							
LC-25-024	-1085 mm							
TC-12-115	-5 °C							
LC-25-025	-920 mm							
TC-12-129	-5 °C							
FI-12-129	1390 M/H							
FI-12-116	1269 M/H							
LI-25-021	-13 mm							

Remark: \_\_\_\_\_

Recorded by \_\_\_\_\_

Checked by \_\_\_\_\_

Operate Date \_\_\_\_\_

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCHM 2530 Unit -2500 NO.4 AMMONIA REFRIGERATION

Item	Unit	Time	02:00	06:00	10:00	14:00	18:00	22:00
TI-25-311	-9 °C							
VI-25-305	0.66-1.8 mm/s							
VI-25-306	1.35 mm/s							
VI-25-307	1.36 mm/s							
VI-25-302	47 mm/s							
VI-25-301	44 mm/s							
TI-25-301A	50 °C							
TI-25-302A	82 °C							
TI-25-302B	80 °C							
TI-25-302C	82 °C							
TI-25-301B	48 °C							
VI-25-303	45 mm/s							
VI-25-304	46 mm/s							
PI-25-306	1.4 kg/cm2							
TI-25-314	37-38 °C							
2530-P2A/B	A or B							
2530-P1A/B	A or B							
PI-25-304	17.6 kg/cm2							
POI-25-301	0.44 kg/cm2							
PI-25-305	17.2 kg/cm2							
POI-25-312	kg/cm2							
POI-25-302	2.74 kg/cm2							
PI-25-302	15 kg/cm2							
TI-25-315	54 °C							
TI-25-313	11.8 °C							
SP-PC-303	5.5 kg/cm2							
OP-PC-303	-0.31 %							

Remark: \_\_\_\_\_

Operate Date: 30/6/24 **DCS LOG SHEET AMINE UNIT (1200 UNIT)** Recorded by: Allyson Checked by: Allyson

**SCHM 4500 Unit-WASTE GAS TREATMENT**

Item	Unit	02:00	04:00	06:00	08:00	10:00	12:00	14:00	16:00	18:00	20:00	22:00
HC-45-002	106 %	100	100	100	100	100	100	100	100	100	100	100
4500-P1	A A/B/C	8-2	8-2	8-2	8-2	8-2	8-2	8-2	8-2	8-2	8-2	8-2
AC-45-001	7 pH	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2
FI-45-007	M/H	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94
LC-45-001	1450 mm	1440	1440	1440	1440	1440	1440	1440	1440	1440	1440	1440
TC-45-001	15.6 °C	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6
TC-45-002	460 °C	460	460	460	460	460	460	460	460	460	460	460
TC-45-003	190 °C	190	190	190	190	190	190	190	190	190	190	190
HC-45-002	106.9 %	106.9	106.9	106.9	106.9	106.9	106.9	106.9	106.9	106.9	106.9	106.9
LC-45-101	350 mm	350	350	350	350	350	350	350	350	350	350	350
4510-P1	A A/B	207	207	207	207	207	207	207	207	207	207	207
FI-45-102	207 mm/H	207	207	207	207	207	207	207	207	207	207	207
FC-45-101	5680 Nm3/hr	5680	5680	5680	5680	5680	5680	5680	5680	5680	5680	5680
FC-45-102	Nm3/hr	5680	5680	5680	5680	5680	5680	5680	5680	5680	5680	5680
FC-45-103	0.6 M(H)	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
FI-45-101	127.2 A	127.2	127.2	127.2	127.2	127.2	127.2	127.2	127.2	127.2	127.2	127.2
1200-P1	ON OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
LI12130	%	54	52	52	52	52	52	52	52	52	52	52
1200-P2	ON OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
LI12131	%	50	50	50	50	50	50	50	50	50	50	50
1200-P3	ON OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
LI12119	%	59	55	55	55	55	55	55	55	55	55	55
1200-P4	ON OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
LI12122	%	62	62	62	62	62	62	62	62	62	62	62
AI12113		7.3	7.2	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1

Remark:

Operate Date: 30/6/24 **DCS LOG SHEET AMINE UNIT (1200 UNIT)** Recorded by: Allyson Checked by: Allyson

**SCHM 1230 UNIT 1230 DS RECOVERY**

Item	Unit	02:00	04:00	06:00	08:00	10:00	12:00	14:00	16:00	18:00	20:00	22:00
PI-12-325	24 mm/H	24	24	24	24	24	24	24	24	24	24	24
FC-12-301	25 mm/H	25	25	25	25	25	25	25	25	25	25	25
PI-12-302	340 mm/H	340	340	340	340	340	340	340	340	340	340	340
FI-12-303	265 mm/H	265	265	265	265	265	265	265	265	265	265	265
FI-12-307	2.73 kg/cm	2.73	2.73	2.73	2.73	2.73	2.73	2.73	2.73	2.73	2.73	2.73
PI-12-308	1 kg/cm	1	1	1	1	1	1	1	1	1	1	1
PI-12-309	793 mm/H	793	793	793	793	793	793	793	793	793	793	793
PI-12-301	80 mm/H	80	80	80	80	80	80	80	80	80	80	80
FC-12-301	16800 Nm3/hr	16800	16800	16800	16800	16800	16800	16800	16800	16800	16800	16800
FI-12-302	12.3 m3/hr	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3
FI-12-303	1.86 m3/hr	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86
FC-12-304	0.47 m3/hr	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47
FC-12-306	8.2 Nm3/hr	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2
FC-12-307	1173 Nm3/hr	1173	1173	1173	1173	1173	1173	1173	1173	1173	1173	1173
FI-12-305	11 m3/hr	11	11	11	11	11	11	11	11	11	11	11
FI-12-308	28 Nm3/hr	28	28	28	28	28	28	28	28	28	28	28
TI-12-301	14.6 °C	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6
TI-12-302	190.7 °C	190.7	190.7	190.7	190.7	190.7	190.7	190.7	190.7	190.7	190.7	190.7
TC-12-303	178.4 °C	178.4	178.4	178.4	178.4	178.4	178.4	178.4	178.4	178.4	178.4	178.4
TC-12-304	330 °C	330	330	330	330	330	330	330	330	330	330	330
TI-12-305	338.8 °C	338.8	338.8	338.8	338.8	338.8	338.8	338.8	338.8	338.8	338.8	338.8
TI-12-306	239.2 °C	239.2	239.2	239.2	239.2	239.2	239.2	239.2	239.2	239.2	239.2	239.2
TI-12-307	101.5 °C	101.5	101.5	101.5	101.5	101.5	101.5	101.5	101.5	101.5	101.5	101.5
LC-12-301	50 %	50	50	50	50	50	50	50	50	50	50	50
AI-12-301	19 Vol%	19	19	19	19	19	19	19	19	19	19	19
AI-12-302A	4 ppm	4	4	4	4	4	4	4	4	4	4	4
AI-12-302B	5 ppm	5	5	5	5	5	5	5	5	5	5	5

Remark:

Check by: DCS/SS **DCS Log Sheet Interlock IIX Unit** Date: 30/6/24

Approved by: GM

Scanned by: GM

Date/Shift: 30/6/24

Interlock Group	Location	Normal Bypass	Normal Bypass	Remark	Normal Bypass	Normal Bypass	Remark
INT-1201 INT FEED STOP	Feed						
INT-1201 A/B FEED STOP	Feed						
INT-1201 B/C FEED STOP	Feed						
INT-1201 C/A FEED STOP	Feed						
INT-1201 D/E FEED STOP	Feed						
INT-1201 E/F FEED STOP	Feed						
INT-1201 F/G FEED STOP	Feed						
INT-1201 G/H FEED STOP	Feed						
INT-1201 H/I FEED STOP	Feed						
INT-1201 I/J FEED STOP	Feed						
INT-1201 J/K FEED STOP	Feed						
INT-1201 K/L FEED STOP	Feed						
INT-1201 L/M FEED STOP	Feed						
INT-1201 M/N FEED STOP	Feed						
INT-1201 N/O FEED STOP	Feed						
INT-1201 O/P FEED STOP	Feed						
INT-1201 P/Q FEED STOP	Feed						
INT-1201 Q/R FEED STOP	Feed						
INT-1201 R/S FEED STOP	Feed						
INT-1201 S/T FEED STOP	Feed						
INT-1201 T/U FEED STOP	Feed						
INT-1201 U/V FEED STOP	Feed						
INT-1201 V/W FEED STOP	Feed						
INT-1201 W/X FEED STOP	Feed						
INT-1201 X/Y FEED STOP	Feed						
INT-1201 Y/Z FEED STOP	Feed						
INT-1201 Z/A FEED STOP	Feed						
INT-1201 A/B FEED STOP	Feed						
INT-1201 B/C FEED STOP	Feed						
INT-1201 C/D FEED STOP	Feed						
INT-1201 D/E FEED STOP	Feed						
INT-1201 E/F FEED STOP	Feed						
INT-1201 F/G FEED STOP	Feed						
INT-1201 G/H FEED STOP	Feed						
INT-1201 H/I FEED STOP	Feed						
INT-1201 I/J FEED STOP	Feed						
INT-1201 J/K FEED STOP	Feed						
INT-1201 K/L FEED STOP	Feed						
INT-1201 L/M FEED STOP	Feed						
INT-1201 M/N FEED STOP	Feed						
INT-1201 N/O FEED STOP	Feed						
INT-1201 O/P FEED STOP	Feed						
INT-1201 P/Q FEED STOP	Feed						
INT-1201 Q/R FEED STOP	Feed						
INT-1201 R/S FEED STOP	Feed						
INT-1201 S/T FEED STOP	Feed						
INT-1201 T/U FEED STOP	Feed						
INT-1201 U/V FEED STOP	Feed						
INT-1201 V/W FEED STOP	Feed						
INT-1201 W/X FEED STOP	Feed						
INT-1201 X/Y FEED STOP	Feed						
INT-1201 Y/Z FEED STOP	Feed						
INT-1201 Z/A FEED STOP	Feed						

Operate Date: 30/6/24 **DCS LOG SHEET AMINE UNIT (1200 UNIT)** Recorded by: Allyson Checked by: Allyson

**SCHM 1211 UNIT 1210 AMINE PRODUCT**

Item	Unit	00:00	04:00	08:00	12:00	16:00	20:00
FC-12-101	26445 Nm3/hr	26445	26445	26445	26445	26445	26445
FC-12-102	2779 Nm3/hr	2779	2779	2779	2779	2779	2779
FI-12-101	0.096 %	0.096	0.096	0.096	0.096	0.096	0.096
FI-12-101	32 Amp	32	32	32	32	32	32
FI-12-104	2311 mm/H	2311	2311	2311	2311	2311	2311
TI-12-101	-6.9 °C	-6.9	-6.9	-6.9	-6.9	-6.9	-6.9
TC-12-102	770 °C	770	770	770	770	770	770
TC-12-103	757 °C	757	757	757	757	757	757
TI-12-104	765 °C	765	765	765	765	765	765
TI-12-105	773 °C	773	773	773	773	773	773
TI-12-106	714 °C	714	714	714	714	714	714
TI-12-107	215 °C	215	215	215	215	215	215
TI-12-108	162.9 °C	162.9	162.9	162.9	162.9	162.9	162.9
TI-12-109	55.8 °C	55.8	55.8	55.8	55.8	55.8	55.8
FI-12-105	8.05 M(H)	8.05	8.05	8.05	8.05	8.05	8.05
FI-12-119	9.35 M(H)	9.35	9.35	9.35	9.35	9.35	9.35
FC-12-103	15.3 kg/cm	15.3	15.3	15.3	15.3	15.3	15.3
AC-12-101	6 pH	6	6	6	6	6	6
AI-12-102	1.15 pH	1.15	1.15	1.15	1.15	1.15	1.15
AI-12-103	4.2 pH	4.2	4.2	4.2	4.2	4.2	4.2
AI-12-109	498 M(H)	498	498	498	498	498	498
1210-P10	A A/B	A	A	A	A	A	A
LC-12-101	ON ON-OFF	ON	ON	ON	ON	ON	ON
HC-12-104	0 %	0	0	0	0	0	0
HC-12-105	0 %	0	0	0	0	0	0
HC-12-106	63 %	63	63	63	63	63	63
FI-12-103	90 m3/hr	90	90	90	90	90	90
FI-12-104	5 m3/hr	5	5	5	5	5	5
FI-12-118	0 Ratio	0	0	0	0	0	0

Remark:

Operate Date: 30/6/24 DCS LOG SHEET AMINE UNIT (1200 UNIT)

Recorded by: Allyson

Checked by: Allyson

UNIT (1200 UNIT)

SCHM 1211A UNIT 1210 AMINE PRODUCT

1210-R1-3 Ammonia Oxidizer

Item	Unit	Time						
		00:00	04:00	08:00	12:00	16:00	20:00	
FC-12-121	12716 Nm <sup>3</sup> /h	12716	12716	12716	12716	12716	12716	12716
FC-12-122	1390 Nm <sup>3</sup> /h	1390	1390	1390	1390	1390	1390	1390
FI-12-121	0.096 %	0.096	0.096	0.096	0.096	0.096	0.096	0.096
FI-12-122	0.096 %	0.096	0.096	0.096	0.096	0.096	0.096	0.096
LI-12-104	23 Armp	23	23	23	23	23	23	23
PI-12-111	1850 mm <sup>3</sup> /h	1850	1850	1850	1850	1850	1850	1850
TC-12-132	770 °C	770	770	770	770	770	770	770
TI-12-133A	779 °C	779	779	779	779	779	779	779
TI-12-134A	205.8 °C	205.8	205.8	205.8	205.8	205.8	205.8	205.8
TI-12-135	53.1 °C	53.1	53.1	53.1	53.1	53.1	53.1	53.1
TI-12-136	101.2 °C	101.2	101.2	101.2	101.2	101.2	101.2	101.2
TI-12-137A	72.4 °C	72.4	72.4	72.4	72.4	72.4	72.4	72.4
FI-12-123	2.94 m <sup>3</sup> /h	2.94	2.94	2.94	2.94	2.94	2.94	2.94
FI-12-124	2.08 m <sup>3</sup> /h	2.08	2.08	2.08	2.08	2.08	2.08	2.08
FI-12-125	5.03 m <sup>3</sup> /h	5.03	5.03	5.03	5.03	5.03	5.03	5.03
FI-12-126	5.18 m <sup>3</sup> /h	5.18	5.18	5.18	5.18	5.18	5.18	5.18
FC-12-126	1040 Nm <sup>3</sup> /h	1040	1040	1040	1040	1040	1040	1040
PC-12-110	15.4 kg/cm <sup>2</sup>	15.4	15.4	15.4	15.4	15.4	15.4	15.4
AC-12-110	1.5 pH	1.5	1.5	1.5	1.5	1.5	1.5	1.5
AI-12-111	342 m <sup>3</sup> /s	342	342	342	342	342	342	342
AI-12-112	9.5 pH	9.5	9.5	9.5	9.5	9.5	9.5	9.5
LC-12-111	0 mm	0	0	0	0	0	0	0
LS-12-111	ON ON/OFF	ON	ON	ON	ON	ON	ON	ON
RV-12-109	32 ON/OFF	32	32	32	32	32	32	32
JIV-12-110	48 %	48	48	48	48	48	48	48
FQ-12-102	12000 Nm <sup>3</sup> /h	12000	12000	12000	12000	12000	12000	12000

Remark :

Recorded by *Atkinson* USE Chemistry Dept. Policy Committee Liaison

Checked by \_\_\_\_\_

SCHM 1222 Unit 1200 Si PRODUCT									
Item	Unit	Time							
		00:00	04:00	08:00	12:00	16:00	20:00		
AI-41-005	14.4 %Vol								
AI-41-701	13.1 %Vol	16.0	16.0	16.5	16.5	16.5	11.1		
TI-12-208	52.6 °C	00.7	00.7	0.8	0.8	0.8	0.8		
AC-13-204	6.46 pH	1.63	1.63	1.62	1.62	1.62	1.62		
FI-12-209	54.8 M/N	6.26	6.26	6.10	6.10	6.10	6.10		
TO-12-209	63.9 °C	40.3	40.3	40.1	40.1	40.1	40.1		
LC-12-206	19.2 M/N	14.24	14.2	14.2	14.2	14.2	14.2		
FY-12-206	0.49 Ratio	0.565	0.565	0.575	0.575	0.575	0.575		
FI-12-207	39 M/N	0.719	0.719	0.719	0.719	0.719	0.719		
LI-12-265	7000 mm	6001	6001	6001	6001	6001	6001		
AC-12-203	1158 g/L	1169	1169	1170	1170	1170	1170		
TH-12-207	44.2 °C	44.4	44.4	44.4	44.4	44.4	44.4		
HC-12-201	61 %	60	60	60	60	60	60		
1220-P2	A A/R	P	P	P	P	P	P		
1220-P3	A A/B	P	P	P	P	P	P		
1220-P7	A A/B	A	A	A	A	A	A		
1220-P8	A A/B	A	A	A	A	A	A		
1220-P9	A A/B	A	A	A	A	A	A		

SCHM 2590 Unit 2500 AMMONIA REFRIGERATION									
Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00		
TI-00-002	-28.11 °C	-28.20	-27.09	-26.1	-25.1	-24.1	-17.75		
FI-25-003	34 M/N	0.187	0.174	0.17	0.16	0.15	0.15		
FQ-25-003	M	710.00	710.00	710.00	710.00	710.00	710.00		
FQ-25-004	-1.2 TaurH	0.88	0.84	0.74	0.75	0.75	0.75		
FI-25-024	0.24 kg/cm2								
FI-25-033	89.1 M/N								
2200-U1	ON/OFF								
TC-12-116	-6.2 °C	-7.2	-7.1	-7.1	-7.1	-7.1	-7.1		
LC-25-001	>450 mm	3.01	3.00	3.00	3.00	3.00	3.00		
22-25-081	5 °C	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7		

2500 Ammonia Refrigeration									
Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00		
TI-00-002	-28.11 °C	-28.20	-27.09	-26.1	-25.1	-24.1	-17.75		
FI-25-003	34 M/N	0.187	0.174	0.17	0.16	0.15	0.15		
FQ-25-003	M	710.00	710.00	710.00	710.00	710.00	710.00		
FQ-25-004	-1.2 TaurH	0.88	0.84	0.74	0.75	0.75	0.75		
FI-25-024	0.24 kg/cm2								
FI-25-033	89.1 M/N								
2200-U1	ON/OFF								
TC-12-116	-6.2 °C	-7.2	-7.1	-7.1	-7.1	-7.1	-7.1		
LC-25-001	>450 mm	3.01	3.00	3.00	3.00	3.00	3.00		
22-25-081	5 °C	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7		

Remark:									

Recorded by APM/af

Checked by \_\_\_\_\_

2500 Ammonia Refrigeration		2500 Ammonia Refrigeration					
Item	Unit	Time					
		02:00	06:00	10:00	14:00	18:00	22:00
TI-25-051	64.8 °C						
TI-25-052	52.9 °C						
TI-25-053	92.4 °C						
TI-25-054	92.1 °C						
TI-25-055	82.6 °C						
TI-25-056	78.3 °C						
TI-25-057	73 °C						
TI-25-058	53.1 °C						
PI-25-081	73.1 mmHgA						
LC-25-082	mm						
FI-25-082	16.3 T/H						
PC-06-091	22.51 kg/Dcm						
2500-K1-F1	service						
2500-K1-T2	stand by						
2500-T2	A/B A/B						
VIBRA.-AXIAL DISP. Unit -2500 AMMONIA REFRIGERATION							
XVI-25-051	29.66 um						
VVI-25-051	28.41 um						
XVI-25-052	29.37 um						
VVI-25-052	22.12 um						
ZI-25-051	0.41 um						
ZI-25-052	0.01 um						
XVI-25-053	10.92 um						
VVI-25-053	28.73 um						
XVI-25-054	13.97 um						
VVI-25-054	13.05 um						
ZI-25-053	-0.19 um						
ZI-25-054	-0.25 um						

Recorded by Alphonse 26

**Checked by** \_\_\_\_\_

SCHM 2511 Unit-NO.2 AMMONIA REFRIGERATION									
Item	Unit	Time							
		02:00	06:00	10:00	14:00	18:00	22:00		
PC-25-121	1.8 kg/cm <sup>2</sup>	1.20	1.20	1.2	1.2	1.2	1.2	1.2	1.2
PI-25-122	15.2 kg/cm <sup>2</sup>	14.7	14.7	14.7	14.2	14.2	14.2	14.2	14.2
PC-25-123	18.2 kg/cm <sup>2</sup>	0.0	120	170	0.0	120	0.0	120	0.0
PI-25-123	%								
PI-25-124	1.9 kg/cm <sup>2</sup>	1.0	1.0	1.0	2.0	2.0	2.0	2.0	2.0
PI-25-125	3.2 kg/cm <sup>2</sup>	12.5	12.5	12.5	15.0	15.0	15.0	15.0	15.0
PI-25-126	18.4 kg/cm <sup>2</sup>	10.0	11.5	12.5	12.5	12.5	12.5	12.5	12.5
TI-25-123	70 °C	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0
TI-25-124	85.48 °C	85.48	85.48	85.48	85.48	85.48	85.48	85.48	85.48
TI-25-125	59.6 °C	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6
TI-25-126	39.89 °C	40.81	40.81	40.81	40.81	40.81	40.81	40.81	40.81
LC-25-121	30 mm	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
LCV-25-121	19.7 %	19.7	19.7	19.7	19.7	19.7	19.7	19.7	19.7
PD1-25-121	3.00 kg/cm <sup>2</sup>	3.00	3.00	3.0	3.3	3.3	3.3	3.3	3.3
PD1-25-122	0.20 kg/cm <sup>2</sup>	0.30	0.30	0.3	0.3	0.3	0.3	0.3	0.3
2510-PI	A A/B	A	A	A	A	A	A	A	A
2510-PI2	A A/B	A	A	A	A	A	A	A	A

Recorded by 11/10/74 2

UNIT 2500 NO 3 AMMONIA DEFENDER

[illegible]

Operate Date: 30/6/14

Recorded by: *Althipham*

Checked by: *Althipham*

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCHM 2530 UNIT 2580 NO.4 AMMONIA REFRIGERATION

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
TI-25-311	-2 °C	-9.83	-9.77	-9.77	-9.72	-9.72	-9.71
VI-25-305	0.66-1.0 cm/s	1.04	1.11	1.11	1.09	1.09	1.10
VI-25-306	1.39 mm/s	1.64	1.63	1.13	1.13	1.13	1.13
VI-25-307	1.36 mm/s	1.28	1.28	1.50	1.50	1.50	1.44
VI-25-302	47 mm/s	17.04	16.78	16.7	16.7	16.7	17.1
VI-25-301	44 mm/s	14.16	14.16	14.16	14.16	14.16	14.16
TI-25-301A	50 °C	48	48	50	50	50	51
TI-25-302A	82 °C	79	78	78	78	78	79
TI-25-302B	80 °C	79	79	79	79	79	79
TI-25-302C	82 °C	76	76	76	76	76	76
TI-25-301B	48 °C	49	49	49	49	49	49
VI-25-303	45 mm/s	14.17	14.17	14.17	14.17	14.17	14.17
VI-25-304	46 mm/s	14.16	14.16	14.16	14.16	14.16	14.16
PI-25-306	1.4 kg/cm <sup>2</sup>	1.40	1.39	1.37	1.37	1.37	1.36
TI-25-314	37.38 °C	37.07	36.47	37.1	37.1	37.1	37.14
2530-PIA/B	A or B	A	A	A	A	A	A
2530-PIA/B	A	A	A	A	A	A	A
PI-25-304	17.6 kg/cm <sup>2</sup>	17.67	17.67	17.67	17.67	17.67	17.67
PI-25-301	0.44 kg/cm <sup>2</sup>	0.45	0.45	0.45	0.45	0.45	0.45
PI-25-305	17.2 kg/cm <sup>2</sup>	17.63	17.63	17.63	17.63	17.63	17.63
PI-25-312	kg/cm <sup>2</sup>	17.63	17.63	17.63	17.63	17.63	17.63
PI-25-302	2.18 kg/cm <sup>2</sup>	2.17	2.17	2.17	2.17	2.17	2.17
PI-25-302	15 kg/cm <sup>2</sup>	15.07	15.07	15.07	15.07	15.07	15.07
TI-25-315	55 °C	56.04	56.04	56.04	56.04	56.04	56.04
TI-25-313	12.5 °C	12.14	12.14	12.14	12.14	12.14	12.14
SP-PC-303	5.5 kg/cm <sup>2</sup>	5.41	5.41	5.41	5.41	5.41	5.41
OP-PC-303	-0.31 %	-0.31	-0.31	-0.31	-0.31	-0.31	-0.31

Remark:

Operate Date: 30/6/14

Recorded by: *Althipham*

Checked by: *Althipham*

DCS LOG SHEET AMINE UNIT (1200 UNIT)

SCHM 4500 Unit-WASTE GAS TREATMENT

Item	Unit	02:00	06:00	10:00	14:00	18:00	22:00
HC-45-002	106 %	100	100	100	100	100	100
4500-PI	A A/B/C	150	150	150	150	150	150
AC-45-001	7 pH	9.26	9.26	9.26	9.26	9.26	9.26
FI-45-007	M/H	1.79	1.79	1.79	1.79	1.79	1.79
LC-45-001	1450 mm	1450	1450	1450	1450	1450	1450
TC-45-101	15.6 °C	15.6	15.6	15.6	15.6	15.6	15.6
TC-45-102	460 °C	460	460	460	460	460	460
TC-45-103	190 °C	190	190	190	190	190	190
HC-45-102	106.9 %	100	100	100	100	100	100
LC-45-101	350 mm	350	350	350	350	350	350
4510-PI	A A/B	10	10	10	10	10	10
PI-45-102	-207 mmH <sub>2</sub> O	-207	-207	-207	-207	-207	-207
FC-45-101	9680 mmH <sub>2</sub> O	9680	9680	9680	9680	9680	9680
FC-45-102	mmH <sub>2</sub> O	9680	9680	9680	9680	9680	9680
FC-45-103	0.6 M/H	0.6	0.6	0.6	0.6	0.6	0.6
II-45-101	127.2 A	127.2	127.2	127.2	127.2	127.2	127.2
1200-PI	ON OFF	ON	OFF	OFF	OFF	OFF	OFF
1212120	%	0.45	0.45	0.45	0.45	0.45	0.45
1200-P2	ON OFF	OFF	OFF	OFF	OFF	OFF	OFF
1212121	%	0.45	0.45	0.45	0.45	0.45	0.45
1200-P3	ON OFF	ON	OFF	OFF	OFF	OFF	OFF
1212119	%	0.45	0.45	0.45	0.45	0.45	0.45
1800-P4	ON OFF	ON	OFF	OFF	OFF	OFF	OFF
2112122	%	0.45	0.45	0.45	0.45	0.45	0.45
PI-45-005	pH	8.7	8.7	8.7	8.7	8.7	8.7

Remark:

## ภาคผนวก ข.15

---

### คู่มือการปฏิบัติงาน (Work Instruction) ในการควบคุมระบบ Waste Gas Treatment กรณี Shutdown แบบปกติและแบบฉุกเฉิน

WORK	การบำบัดก๊าซพิษของ Section 4500	Date : 8 Jan. 2019
INSTRUCTION	( Waste Gas Treatment Section )	Page : 1 of 2
Doc. No. : WI-LC9-45-004		Rev. no : 01



WORK	การบำบัดก๊าซพิษของ Section 4500	Date : 8 Jan. 2019
INSTRUCTION	( Waste Gas Treatment Section )	Page : 2 of 2
Doc. No. : WI-LC9-45-004		Rev. no : 01



ภาคผนวก ข.16

---

เอกสารตรวจสอบประสิทธิภาพของระบบควบคุมกำมะถัน  
(4140-C6)


CPL SA 4140 Section2

Conducted by :   
Conducted on : Jan 31, 2024 04:00:00  
Completed on : Jan 31, 2024 05:40:47




Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.







CPL SA 4140 Section2




Conducted by :   
Conducted on : Feb 11, 2024 04:00:00  
Completed on : Feb 11, 2024 05:22:49

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.





CPL SA 4140 Section2

Conducted by : 



Conducted on : Mar 31, 2024 16:00:00





Completed on : Mar 31, 2024 18:47:47

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.








CPL SA 4140 Section2

Conducted by :   
Conducted on : Apr 01, 2024 16:00:00  
Completed on : Apr 01, 2024 17:19:37

Report created with Advansoft ODM


**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.





CPL SA 4140 Section2


Conducted by :   
Conducted on : May 30, 2024 16:00:00  
Completed on : May 30, 2024 16:39:19


Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.


**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.







CPL SA 4140 Section2




Conducted by :   
Conducted on : Jun 18, 2024 16:00:00  
Completed on : Jun 18, 2024 16:28:04

**Disclaimer**

The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**

In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.



ภาคผนวก ข.17

---

คู่มือการตั้งอุณหภูมิในการหยุดระบบการผลิตอัตโนมัติ





ภาคผนวก ข.18

---

แผนควบคุมภาวะฉุกเฉินสำหรับระบบควบคุมกัมมันต์ (4140-C6)




WORK	การทดสอบประสิทธิภาพของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 1 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01



Printed by : korbus kettat on 30/11/2560 11:25

WORK	การทดสอบประสิทธิภาพของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 1 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01




Printed by : korbus kettat on 30/11/2560 11:25

WORK	การทดสอบประสิทธิภาพของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 3 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01




Printed by : korbus kettat on 30/11/2560 11:25

WORK	การทดสอบประสิทธิภาพของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 4 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01




Printed by : korbus kettat on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 5 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01



Printed by : korbus kettet on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 6 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01




Printed by : korbus kettet on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 7 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01




Printed by : korbus kettet on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 8 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01



Printed by : korbus kettet on 30/11/2560 11:25

WORK	การดูแลรักษาของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 9 of 18
Doc. No. : WI-SA9-10-007		Rev.no : 01



Printed by : korbua kettet on 30/11/2560 11:25

WORK	การดูแลรักษาของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 10 of 18
Doc. No. : WI-SA9-10-007		Rev.no : 01



Printed by : korbua kettet on 30/11/2560 11:25

WORK	การดูแลรักษาของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 11 of 18
Doc. No. : WI-SA9-10-007		Rev.no : 01



Printed by : korbua kettet on 30/11/2560 11:25

WORK	การดูแลรักษาของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 12 of 18
Doc. No. : WI-SA9-10-007		Rev.no : 01



Printed by : korbua kettet on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 13 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01



Printed by : korbuu kettat on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 14 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01



Printed by : korbuu kettat on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 15 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01



Printed by : korbuu kettat on 30/11/2560 11:25

WORK	การปฏิบัติการผลิตของหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 16 of 18
Doc. No. : WI-SA9-10-007		Rev. no : 01




Printed by : korbuu kettat on 30/11/2560 11:25

WORK	การแยกกรดซัลฟิวริกจากหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 17 of 18
Doc.No. : WI-SA9-10-007		Rev.no : 01



WORK	การแยกกรดซัลฟิวริกจากหน่วยผลิต	Date : 16 May 2017
INSTRUCTION	Sulphuric Acid Unit	Page : 18 of 18
Doc.No. : WI-SA9-10-007		Rev.no : 01



## ภาคผนวก ข.19

---

### เอกสารการตรวจสอบระบบกำจัดกลิ่นกำมะถัน

CPL SA 4110 to 4130 Section1



Conducted by :   
Conducted on : Jan 31, 2024 08:00:00  
Completed on : Jan 31, 2024 09:05:10

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.







CPL SA 4110 to 4130 Section1

Conducted by :



Conducted on :

Feb 01, 2024 20:00:00

Completed on :

Feb 01, 2024 21:39:13





Report created with Advansoft ODM



**Disclaimer**

The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**

In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.





CPL SA 4110 to 4130 Section1

Conducted by :

Conducted on : Mar 08, 2024 08:00:00



Completed on : Mar 08, 2024 09:28:56

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.


**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.







CPL SA 4110 to 4130 Section2

Conducted by : 




Conducted on : Apr 01, 2024 14:00:00


Completed on : Apr 01, 2024 15:06:19

Report created with Advansoft ODM


**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.





CPL SA 4110 to 4130 Section1

Conducted by :   
Conducted on : May 01, 2024 08:00:00  
Completed on : May 01, 2024 09:57:36






**Disclaimer**

The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.


**Confidentiality Statement**

In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.





CPL SA 4110 to 4130 Section1


Conducted by :   
Conducted on : Jun 19, 2024 08:00:00  
Completed on : Jun 19, 2024 09:32:32

**Disclaimer**

The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**

In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.





ภาคผนวก ข.20

---

เอกสารขึ้นทะเบียนบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน



ที่ อก ๐๓๑๓/ ๓ ๐ ๔ ๐ ๐

กรมโรงงานอุตสาหกรรม  
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท  
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๐๓ พฤศจิกายน ๒๕๖๔

เรื่อง หนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

เรียน ผู้รับใบอนุญาตประกอบกิจการโรงงาน บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)

อ้างถึง คำขอเลขที่ ๑๔๐๗ ลงรับวันที่ ๒๐ ตุลาคม ๒๕๖๔

ตามคำขอที่อ้างถึง ท่านแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ของ  
บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน) ทะเบียนโรงงานเลขที่ ข ๓-๔๔-๑/๓๙ uly ประกอบกิจการ  
ผลิตคาโปรแลคตัม และปุ๋ยแอมโมเนียซัลเฟต ตั้งอยู่ ณ เลขที่ ๑๔๐/๖ หมู่ที่ ๔ เขตประกอบการอุตสาหกรรม  
บริษัท ไออาร์พีซี จำกัด (มหาชน) ตำบลตะพง อำเภอเมืองระยอง จังหวัดระยอง โทรศัพท์ ๐ ๓๘๙๒ ๘๗๐๐

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว รับแจ้งการให้มีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน  
และให้ท่านยื่นคำขอแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงานครั้งต่อไป ภายในวันที่ ๑๙ พฤศจิกายน ๒๕๖๗  
โดยมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ดังนี้

ผู้จัดการสิ่งแวดล้อม			นายเก่งกาจ ปัทมรัตน์		
ลำดับ	ผู้ควบคุมระบบบำบัด	เลขทะเบียน	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑			✓	✓	✓
๒			✓		
๓			✓	✓	✓
๔				✓	
๕			✓		
๖			✓		
ลำดับ			มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑			✓		✓
๒			✓		
๓				✓	
๔			✓		
๕			✓		
๖			✓		
๗					✓
๘				✓	✓
๙				✓	
๑๐				✓	✓
๑๑				✓	✓

ลำดับ ๑๒...



ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑๒			✓	
๑๓			✓	
๑๔			✓	
๑๕			✓	
๑๖			✓	
๑๗			✓	
๑๘				✓
๑๙				✓
๒๐				✓
๒๑			✓	✓
๒๒				✓
๒๓				✓
๒๔			✓	✓
๒๕				✓
๒๖		✓		
๒๗		✓		
๒๘			✓	
๒๙				✓
๓๐				✓
๓๑				✓
๓๒			✓	
๓๓			✓	
๓๔				✓
๓๕		✓		
๓๖		✓	✓	✓

หมายเหตุ ๑. การแจ้งการมี/ยกเลิก/เพิ่มเติม/เปลี่ยนแปลง บุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ต้องส่งหนังสือฉบับนี้ด้วย

๒. ยกเลิกหนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ที่ อก ๐๓๑๓/๖๘๖๐ ลงวันที่ ๒ มิถุนายน ๒๕๖๓

จึงเรียนมาเพื่อโปรดทราบ

ขอแสดงความนับถือ



ผู้อำนวยการกองส่งเสริมเทคโนโลยีสิ่งแวดล้อมโรงงาน  
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

กองส่งเสริมเทคโนโลยีสิ่งแวดล้อมโรงงาน

กลุ่มกำกับบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

โทรศัพท์ ๐ ๒๔๓๐ ๖๓๑๕ ต่อ ๒๔๐๕

โทรสาร ๐ ๒๔๓๐ ๖๓๑๕ ต่อ ๒๔๙๙

ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

## ภาคผนวก ข.21

---

### เอกสารชี้แจงระบบควบคุมมลสาร

receive date 19/05/11



ที่ รย 0028(3)/1222

สำนักงานอุตสาหกรรมจังหวัดระยอง  
140/20 ถนนสุขุมวิท ระยอง 21000

28 เม.ย. 2554

เรื่อง การขอใช้เชื้อเพลิงประเภทสารอินทรีย์ผสมกับเตาเผา HEAT TRANSFER SALT (HTS) FURNACE

เรียน กรรมการผู้จัดการบริษัท อุเบะ เคมีคอลส์ (เอเชีย) จำกัด (มหาชน)

อ้างถึง หนังสือบริษัทฯ เลขที่ รย UCHA/0031/54 ลงวันที่ 28 กุมภาพันธ์ 2554

ตามหนังสือที่อ้างถึง บริษัท อุเบะ เคมีคอลส์ (เอเชีย) จำกัด (มหาชน) ประกอบกิจการโรงงานผลิตคาโปรแลคตัมและปุ๋ยแอมโมเนียมซัลเฟต ตั้งอยู่ ณ เลขที่ 140/6 หมู่ที่ 4 ตำบลตะพง อำเภอเมือง จังหวัดระยอง ทะเบียนโรงงานเลขที่ ข 3-44-1/39 รย ได้แจ้งความประสงค์จะขอใช้เชื้อเพลิงประเภทสารอินทรีย์ผสม ซึ่งมีคุณสมบัติคล้ายก๊าซ แอลพีจี เพื่อนำไปใช้เป็นเชื้อเพลิงที่เตาเผา HTS FURNACE ในกระบวนการผลิตของหน่วยผลิตไซโคลเฮกซาโนน โดยเชื้อเพลิงดังกล่าวได้นำมาจาก บริษัท ยางสังเคราะห์ไทย จำกัด ซึ่งเป็นโรงงานในกลุ่มเดียวกันและส่งผ่านมาตามท้องที่ นั้น

สำนักงานอุตสาหกรรมจังหวัดระยอง ได้พิจารณาแล้วเห็นว่าเดิมบริษัทฯ ได้มีการใช้แก๊ส แอลพีจี ร่วมกับก๊าซไฮโดรเจนเป็นเชื้อเพลิงที่เตาเผา HTS FURNACE อยู่แล้ว ดังนั้น กรณีที่ขอใช้เชื้อเพลิงประเภทสารอินทรีย์ผสม ซึ่งมีคุณสมบัติคล้ายก๊าซ แอลพีจี มาใช้ร่วมด้วยจึงไม่ขัดข้องในการใช้เชื้อเพลิงดังกล่าว แต่อย่างไรก็ตาม บริษัทฯ จะต้องควบคุมอัตราการระบายมลสารจากปล่องของแหล่งกำเนิดให้มีค่าเป็นไปตามมาตรการป้องกันและลดผลกระทบต่อสิ่งแวดล้อม ที่สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม ให้ความเห็นชอบ คือ  $\text{NO}_x$  ไม่เกิน  $60 \text{ mg/Nm}^3$  ( $0.07$  กรัมต่อวินาที)

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ



นักวิเคราะห์นโยบายและแผนชำนาญการพิเศษ ศึกษาราชการแทน  
อุตสาหกรรมจังหวัดระยอง

ฝ่ายโรงงานอุตสาหกรรม

โทรศัพท์ 0 3861 2038, 0 3880 8177

โทรสาร 0 3880 8178

E-mail : moi\_rayong@industry.go.th

เว็บไซต์ : รย. gov. th

ก8-1


## UBE Chemicals (Asia) Public Company Limited

(Office : 87/2 CRC Tower, All Seasons Place, 9th Floor,  
Wireless Road, Lumpini, Pathumwan, Bangkok 10330, Thailand  
Tel. 66-2-263-6600 Fax. 66-2-263-6688

Factory : 148/6 Moo 4, Tambol Tapong, Muang Rayong District,  
Rayong Province 21000, Thailand  
Tel. 66-38-928-700 Fax. 66-38-928-865

<http://www.ube.co.th>

**UBE**  
UBE GROUP (THAILAND)



ที่ รง. UCHA 0186/53

1 ตุลาคม 2553

เรื่อง ขอชี้แจงการประกอบกิจการโรงงานในส่วนหน่วยไอน้ำจากปล่องระบาย.

เรียน อุตสาหกรรมจังหวัดระยอง

ตามที่ บ.อุเบเคมีคอลส์ (เอเชีย) จำกัด (มหาชน) ซึ่งตั้งอยู่ เลขที่ 140/6 หมู่ที่ 4 ตำบลตะพง อำเภอเมือง จังหวัดระยอง ทะเบียนโรงงานเลขที่ ข2ข3-44-1/39 รบ ผลิตภัณฑ์ โพรแลกติกและโพลิเอไมด์ชนิดแข็ง ปัจจุบันการเดินเครื่องจักรในส่วนโรงงาน AR Boiler มีปัญหาหม้อน้ำชำรุดไม่สามารถใช้งานได้ อนึ่ง AR Boiler ได้ถูกติดตั้งในปี 2549 มีหน้าที่เผารละลายด่างใช้แล้ว (Spent Alkali) เพื่อให้ได้สารละลายโซเดียมคาร์บอเนตและนำกลับมาใช้ใหม่ (Recycle) และยังได้อิอน้ำ (Steam) กลับมาใช้ในกระบวนการผลิตซึ่งเป็นการนำความร้อนกลับมาใช้ใหม่ (Heat Recovery) เป็นการประหยัดพลังงานและลดปริมาณไอน้ำที่ออกสู่ปล่องระบาย เมื่อเทียบกับจากการเผาด้วยเตาเผาเดิม (Quenching Process)

จากปัญหาหม้อน้ำชำรุดดังกล่าว ทำให้ทางบริษัทฯ จำเป็นต้องใช้เตาเผาเดิม ซึ่งไม่มีการผลิตไอน้ำ ความร้อนจากการเผาไหม้ดังกล่าวจะถูกถ่ายเทไปยังน้ำ (Quenching Process) ทำให้มีน้ำระเหยกลายเป็นไอถูกส่งไปยังปล่องระบาย ซึ่งถ้าสังเกตจากลักษณะภายนอกจะเห็นเป็นพวยไอน้ำสีขาวออกมาจากปล่องระบาย โดยเฉพาะอย่างยิ่งหากในอากาศมีความชื้นมากขึ้นจะทำให้มองเห็นไอน้ำได้ชัดเจนมากขึ้น

ส่วนหม้อไอน้ำที่ชำรุด ขณะนี้ทางบริษัทฯ กำลังปรับปรุงแก้ไข และต้องใช้เวลาในการซ่อมแซมประมาณ 8-12 เดือน

บริษัทฯ ขอเรียนชี้แจงมายังท่านว่าตลอดระยะเวลาที่ผ่านมาบริษัทได้ตระหนักและถือเป็นความรับผิดชอบในการประกอบกิจการไม่ให้เกิดผลกระทบแก่ผู้เกี่ยวข้องโดยรอบโรงงาน ซึ่งโรงงานได้ดำเนินการตรวจวัดคุณภาพอากาศและน้ำทิ้ง โดยว่าจ้างบริษัท ภายนอกที่ได้รับรองมาตรฐานจากหน่วยงานราชการ ผลจากการตรวจนั้นพบค่าต่างๆอยู่ในเกณฑ์มาตรฐานที่กฎหมายกำหนด และบริษัทฯ ก็ได้รายงานค่าคุณภาพอากาศและน้ำทิ้งจากโรงงานต่อหน่วยงานราชการที่เกี่ยวข้องอย่างสม่ำเสมอ แต่อย่างไรก็ตามบริษัทฯ ก็มีความมุ่งมั่นที่จะพัฒนาและปรับปรุงการดำเนินงานของโรงงานให้ดียิ่งขึ้นตลอดเวลา เพื่อมิให้เกิดผลกระทบด้านมลภาวะต่อชุมชน

จึงเรียนมาเพื่อโปรดทราบ

ขอแสดงความนับถือ



ผู้จัดการโรงงาน

ภาคผนวก ข.22

---

## เอกสารการตรวจสอบประสิทธิภาพของ AR Boiler

LOG SHEET #4620 (DCS)

DATE 01 Jan 2016



Page 1 of 2

FM-PDS-WL-005:11/07/2023:Rev.07

LOG SHEET #4620 (DCS)

DATE 07 Feb 2016



Page 1 of 2

FM-PDS-WL-005:11/07/2023:Rev.07

LOG SHEET #4620 (DCS)

DATE 09 Mar 24



Page 1 of 2

FM-PDS-WL-005:22/02/2024:Rev.08

LOG SHEET #4620 (DCS)


DATE 21 - 1 - 24



Page 1 of 2

FM-PDS-WL-005:11/07/2023:Rev.07



DATE 06 May 24DATE 21 / 6 / 24DATE 03 Jun 24



ภาคผนวก ข.23


เอกสารการบันทึกปริมาณน้ำเสียที่เข้าระบบบำบัดน้ำเสีย

บันทึกปริมาณน้ำเสียที่เข้าสู่ระบบบำบัดน้ำเสีย

โครงการโรงงานผลิตคาปโรรแลกต์มฯ บริษัท อุเบะ เคมิคอลส์ (เอเชีย) จำกัด (มหาชน)

ระหว่างเดือนมกราคม ถึงมิถุนายน พ.ศ.2567

รายการ	เดือน					
	มกราคม	กุมภาพันธ์	มีนาคม	เมษายน	พฤษภาคม	มิถุนายน
ปริมาณน้ำเสียที่ เข้าสู่ระบบบำบัด (ลูกบาศก์เมตร)	77,581	76,214	79,758	83,515	92,017	93,991



ภาคผนวก ข.24

---

เอกสารการตรวจสอบระบบบำบัดน้ำเสีย

4700-V32 : (2)					
1	Level	0.0	%		
2	Pressure	0	kg/cm2	1 - 3	"EQ on Standby"
4700-P29A : (3)					
1	EQUIPMENT Status	Stand By			
2	pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P11 : (3)					
1	EQUIPMENT Status	Stand By			
2	ON/OFF	NR			"EQ on Standby"
3	pressure discharge pump	0	kg/cm2	1 - 3	"EQ on Standby"
4700-P28A : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-015A	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P10A : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P10B : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P15 : (2)					
1	pressure discharge	0	kg/cm2	0 - 3	"EQ on Standby"
2	Level lube Oil	0	%	> 50	"EQ on Standby"

4700-B3 : (1)					
1	PG-023	NR			"EQ on Standby"
4700-S5 : (4)					
1	A/C-005	0	pH	1 - 8	"EQ on Standby"
2	A/C-005	0	TEMP	30 - 40	"EQ on Standby"
3	LG-002	0	%	200 - 1000	"EQ on Standby"
4	CHEM. FEED H2SO4	NR			"EQ on Standby"
4700-P16 : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-024	NR			"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P1A : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001A	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1B : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001B	3	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1C : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-001C	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P8A : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			

4700-P8B : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
4700-P32A : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4	Current	0	Amp.	15 - 25	"EQ on Standby"
4700-P32B : (4)					
1	EQUIPMENT Status	Duty			
2	Pressure discharge	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4	Current	19.9	Amp.	15 - 25	
4700-V30S : (1)					
1	Site check	Normal			
4700-E2 : (2)					
1	TG-101 Air	32	C	30 - 40	
2	TG-102 CW	30	C	25 - 36	
4700-E3 : (2)					
1	TG-103 Air	32	C	30 - 40	
2	TG-104 CW	30	C	25 - 36	
4700-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.81	kg/cm2	0.5 - 1	
3	Temp	80	C	70 - 90	
4	DP air filter	-0.001	kg/cm2	> -0.05	

5	Oil Press	2.6	Bar	> 2	
4700-B1B : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002B	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002C	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1D : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002D	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-101C	0	kg/cm2	0.6 - 1	"EQ on Standby"
3	CURRENT	0	Amps	110 - 140	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B2A : (5)					
1	EQUIPMENT Status	Stand By			
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"

5	Oil Press	0	Bar	2 - 6.5	"EQ on Standby"
4710-B2B : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.73	kg/cm2	0.7 - 1	
3	Temp	94	C	80 - 110	
4	DP air filter	-0.004	kg/cm2	> -0.05	
5	Oil Press	3.4	Bar	2 - 6.5	
4710-B2C : (4)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.73	kg/cm2	0.7 - 1	
3	Temp	93	C	80 - 110	
4	Oil Press	4.1	Bar	> 2	
4710-B2D : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.73	kg/cm2	0.7 - 1	
3	Temp	96	C	80 - 110	
4	DP air filter	-0.012	kg/cm2	> -0.05	
5	Oil Press	2.9	Bar	2 - 6.5	
4710-B2E : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.73	kg/cm2	0.7 - 1	
3	Temp	94	C	80 - 110	
4	DP air filter	-0.031	kg/cm2	> -0.05	
5	Oil Press	3	Bar	2 - 6.5	



No signature is required as this is an electronic document

CPL UT 4700 (1)

Conducted by :   
Conducted on : Feb 15, 2024 07:00:00  
Completed on : Feb 15, 2024 10:58:43

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.

No	Description	Value	EU	Lo - HI	Remarks
V32C (2) : (6) t <sup>1</sup>					
GPE (4) t <sup>1</sup>					
UT : (525) t <sup>1</sup>					
UT_4700 (1) : (133) t <sup>1</sup>					
Work Summary : (1)					
1	Production Load	100	%		
4700-V1 : (1)					
1	FQ-001	2.59448e+000	m3		
2.59448e+000					
4700-E1A : (4)					
1	INLET TG-001A EFFLUENT TEMP.	50	C	50 - 75	
2	OUTLET TG-002A EFFLUENT TEMP.	35	C	30 - 45	
3	INLET TG-003A COOLING WATER	32	C	25 - 35	
4	OUTLET TG-004A COOLING WATER	34	C	30 - 40	
4700-E1B : (4)					
1	INLET TG-001B EFFLUENT TEMP.	50	C	50 - 75	
2	OUTLET TG-002B EFFLUENT TEMP.	35	C	30 - 45	
3	INLET TG-003B COOLING WATER	32	C	30 - 35	
4	OUTLET TG-004B COOLING WATER	34	C	30 - 40	
4700-P39 : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	2 - 5	"EQ on Standby"
3	Pressure FW seal	0	kg/cm2	2 - 4	"EQ on Standby"
4	Flow FW seal	0	x 0.1 M3/hr	1 - 5	"EQ on Standby"
4700-P40 : (4)					

1	EQUIPMENT Status	Duty			
2	Discharge pressure	4	kg/cm2	2 - 5	
3	Pressure FW seal	2.6	kg/cm2	2 - 4	
4	Flow FW seal	0	x 0.1 M3/hr	2 - 5	
4700-V11 : (1)					
1	FI47003	42864			
4710-V4 Aeration_1 : (6) t <sup>1</sup>					
1	AT-101	2.4	DO	2 - 4.8	
2	AT-101	37.5	TEMP	30 - 40	
3	AT-102	3.7	DO	2 - 4.8	
4	AT-102	37.2	TEMP	30 - 40	
5	AT-103	3.0	DO	2 - 4.8	
6	AT-103	37.5	TEMP	30 - 40	
4710-V2 : (5)					
1	MIXER V2-A1	Running			
2	pH AIC-001	6.8	pH	1 - 14	
3	Temp AIC-001	38.5	TEMP	25 - 40	
4	H2SO4 FEED	Running			
5	NaOH FEED	Running			
4710-V3 : (1)					
1	H3PO4 feed	Running			
4700-V4 Aeration_2 : (4)					
1	DO chamber 1/2	2.5	DO	2 - 4	
2	Temp chamber 1/2	37.4	TEMP	30 - 40	
3	DO chamber 3/4	2.3	DO	1 - 3	
4	Temp chamber 3/4	37.5	TEMP	30 - 40	

4700-V32 : (2) t <sup>1</sup>					
1	Level	1	%		
2	Pressure	0	kg/cm2	1 - 3	
4700-P29A : (3)					
1	EQUIPMENT Status	Stand By			
2	pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P11 : (3)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
3	pressure discharge pump	1.5	kg/cm2	1 - 3	
4700-P28A : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-016A	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P10A : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P10B : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P15 : (2)					
1	pressure discharge	0	kg/cm2	0 - 3	
2	Level lube Oil	50	%	> 50	

4700-B3 : (1)					
1	PG-023	Running			
4700-S5 : (4) t <sup>1</sup>					
1	AIC-005	0	pH	1 - 8	"EQ on Standby"
2	AIC-005	0	TEMP	30 - 40	"EQ on Standby"
3	LG-002	0	%	200 - 1000	"EQ on Standby"
4	CHEM. FEED H2SO4	Stand By			
4700-P16 : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-024	NR			"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P1A : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001A	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1B : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001B	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1C : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-001C	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P8A : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			

4700-P8B : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
4700-P32A : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4	Current	0	Amps	15 - 25	"EQ on Standby"
4700-P32B : (4)					
1	EQUIPMENT Status	Duty			
2	Pressure discharge	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4	Current	19.8	Amps	15 - 25	
4700-V30S : (1)					
1	Site check	Normal			
4700-E2 : (2)					
1	TG-101 Air	34	C	30 - 40	
2	TG-102 CW	32	C	25 - 36	
4700-E3 : (2)					
1	TG-103 Air	33	C	30 - 40	
2	TG-104 CW	32	C	25 - 36	
4700-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.61	kg/cm2	0.5 - 1	
3	Temp	80	C	70 - 90	
4	DP air filter	-0.001	kg/cm2	> -0.05	

5	Oil Press	2.6	Bar	> 2	
4700-B1B : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002B	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002C	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1D : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002D	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-101C	0	kg/cm2	0.6 - 1	"EQ on Standby"
3	CURRENT	0	Amps	110 - 140	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.73	kg/cm2	0.7 - 1	
3	Temp	84	C	80 - 110	
4	DP air filter	-0.014	kg/cm2	> -0.05	

5	Oil Press	5.7	Bar	2 - 6.5	
4710-B2B : (5)					
1	EQUIPMENT Status	Stand By			
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"
5	Oil Press	0	Bar	2 - 6.5	"EQ on Standby"
4710-B2C : (4)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.72	kg/cm2	0.7 - 1	
3	Temp	82	C	80 - 110	
4	Oil Press	3.5	Bar	> 2	
4710-B2D : (5)					
1	EQUIPMENT Status	Stand By			
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"
5	Oil Press	0	Bar	2 - 6.5	"EQ on Standby"
4710-B2E : (5)					
1	EQUIPMENT Status	Stand By			
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"
5	Oil Press	0	Bar	2 - 6.5	"EQ on Standby"



CPL UT 4700 (1)

Conducted by :   
Conducted on : Mar 31, 2024 19:00:00  
Completed on : Mar 31, 2024 20:47:02

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.

No	Description	Value	EU	Lo - Hi	Remarks
EQUIPMENT (RUC)					
CPL (4024)					
UT (525) :					
UT_4700 (1) : (133) :					
Work Summary : (1)					
1	Production Load	100	%		
4700-V1 : (1)					
1	FQ-001	2.69078e+006	m3		
2.69078e+006					
4700-E1A : (4)					
1	INLET TG-001A EFFLUENT TEMP.	52	C	50 - 75	
2	OUTLET TG-002A EFFLUENT TEMP.	37	C	30 - 45	
3	INLET TG-003A COOLING WATER	33	C	25 - 35	
4	OUTLET TG-004A COOLING WATER	34	C	30 - 40	
4700-E1B : (4)					
1	INLET TG-001B EFFLUENT TEMP.	62	C	50 - 75	
2	OUTLET TG-002B EFFLUENT TEMP.	37	C	30 - 45	
3	INLET TG-003B COOLING WATER	33	C	30 - 35	
4	OUTLET TG-004B COOLING WATER	34	C	30 - 40	
4700-P39 : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	2 - 5	"No Reading"
3	Pressure FW seal	0	kg/cm2	2 - 4	"No Reading"
4	Flow FW seal	0	x 0.1 M3/hr	1 - 5	"No Reading"
4700-P40 : (4)					

1	EQUIPMENT Status	Run			
2	Discharge pressure	4	kg/cm2	2 - 5	
3	Pressure FW seal	3.5	kg/cm2	2 - 4	
4	Flow FW seal	5	x 0.1 M3/hr	2 - 5	
4700-V11 : (1)					
1	FI47003	42864			
4710-V4 Aeration_1 : (6)					
1	AT-101	2.9	DO	2 - 4.8	
2	AT-101	40	TEMP	30 - 40	
3	AT-102	2.9	DO	2 - 4.8	
4	AT-102	39.7	TEMP	30 - 40	
5	AT-103	2.7	DO	2 - 4.8	
6	AT-103	40	TEMP	30 - 40	
4710-V2 : (5)					
1	MIXER V2-A1	Running			
2	pH A/C-001	6.7	pH	1 - 14	
3	Temp A/C-001	38.7	TEMP	25 - 40	
4	H2SO4 FEED	Running			
5	NaOH FEED	Running			
4710-V3 : (1)					
1	H3PO4 feed	Running			
4700-V4 Aeration_2 : (4) :					
1	DO chamber 1/2	3.9	DO	2 - 4	
2	Temp chamber 1/2	39.9	TEMP	30 - 40	
3	DO chamber 3/4	3.1	DO	1 - 3	
4	Temp chamber 3/4	39.7	TEMP	30 - 40	



4700-V32 : (2) 1'					
1	Level	74.3	%		
2	Pressure	0	kg/cm2	1 - 3	
4700-P29A : (3)					
1	EQUIPMENT Status	Stand By			
2	pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P11 : (3)					
1	EQUIPMENT Status	Stand By			
2	ON/OFF	NR			"EQ on Standby"
3	pressure discharge pump	0	kg/cm2	1 - 3	"EQ on Standby"
4700-P28A : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-016A	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P10A : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P10B : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P15 : (2)					
1	pressure discharge	0	kg/cm2	0 - 3	
2	Level lube Oil	50	%	> 50	

4700-B3 : (1) 1'					
1	PG-023	Stand By			
4700-S5 : (4) 1'					
1	AIC-005	0	pH	1 - 8	"EQ on Standby"
2	AIC-005	0	TEMP	30 - 40	"EQ on Standby"
3	LG-002	0	%	200 - 1000	"EQ on Standby"
4	CHEM. FEED H2SO4	Stand By			
4700-P16 : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-024	NR			"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P1A : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001A	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1B : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001B	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1C : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-001C	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P8A : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			


4700-P8B : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
4700-P32A : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4	Current	0	Amp.	15 - 25	"EQ on Standby"
4700-P32B : (4)					
1	EQUIPMENT Status	Duty			
2	Pressure discharge	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4	Current	20.1	Amp.	15 - 25	
4700-V30S : (1)					
1	Site check	Normal			
4700-E2 : (2)					
1	TG-101 Air	33	C	30 - 40	
2	TG-102 CW	34	C	25 - 36	
4700-E3 : (2)					
1	TG-103 Air	33	C	30 - 40	
2	TG-104 CW	34	C	25 - 36	
4700-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.61	kg/cm2	0.5 - 1	
3	Temp	81	C	70 - 90	
4	DP air filter	-0.001	kg/cm2	> -0.05	

5	Oil Press	2.8	Bar	> 2	
4700-B1B : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002B	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002C	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1D : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002D	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-101C	0	kg/cm2	0.6 - 1	"EQ on Standby"
3	CURRENT	0	Amps	110 - 140	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	97	C	80 - 110	
4	DP air filter	-0.003	kg/cm2	> -0.05	

5	Oil Press	2.6	Bar	2 - 8.5	
4710-B2B : (5)					
1	EQUIPMENT Status	Stand By			
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"
5	Oil Press	0	Bar	2 - 8.5	"EQ on Standby"
4710-B2C : (4)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	94	C	80 - 110	
4	Oil Press	3.4	Bar	> 2	
4710-B2D : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	98	C	80 - 110	
4	DP air filter	-0.008	kg/cm2	> -0.05	
5	Oil Press	2.8	Bar	2 - 8.5	
4710-B2E : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.74	kg/cm2	0.7 - 1	
3	Temp	100	C	80 - 110	
4	DP air filter	-0.009	kg/cm2	> -0.05	
5	Oil Press	3	Bar	2 - 8.5	



CPL UT 4700 (1)

Conducted by :   
Conducted on : Apr 28, 2024 19:00:00  
Completed on : Apr 28, 2024 21:03:10

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of this assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.

No	Description	Value	EU	Lo - HI	Remarks
OBE (4001) (H01)					
CPL (4001)					
UT : (525) 1'					
UT_4700 (1) : (133) 1'					
Work Summary : (1)					
1	Production Load	100	%		
4700-V1 : (1)					
1	FQ-001	2.75561e+000	m3		
2.75561e+000					
4700-E1A : (4)					
1	INLET TG-001A EFFLUENT TEMP.	63	C	50 - 75	
2	OUTLET TG-002A EFFLUENT TEMP.	35	C	30 - 45	
3	INLET TG-003A COOLING WATER	34	C	25 - 35	
4	OUTLET TG-004A COOLING WATER	33	C	30 - 40	
4700-E1B : (4)					
1	INLET TG-001B EFFLUENT TEMP.	63	C	50 - 75	
2	OUTLET TG-002B EFFLUENT TEMP.	35	C	30 - 45	
3	INLET TG-003B COOLING WATER	34	C	30 - 35	
4	OUTLET TG-004B COOLING WATER	35	C	30 - 40	
4700-P39 : (4)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	Pressure discharge	0	kg/cm2	2 - 5	"EQ on Standby"
3	Pressure FW seal	0	kg/cm2	2 - 4	"EQ on Standby"
4	Flow FW seal	0	x 0.1 M3/hr	1 - 5	"EQ on Standby"
4700-P40 : (4)					

1	EQUIPMENT Status	Duty			
2	Discharge pressure	4	kg/cm2	2 - 5	
3	Pressure FW seal	5.6	kg/cm2	2 - 4	
4	Flow FW seal	5	x 0.1 M3/hr	2 - 5	
4700-V11 : (1)					
1	FI47003	42984			
4710-V4 Aeration_1 : (5)					
1	AT-101	2.2	DO	2 - 4.5	
2	AT-101	39	TEMP	30 - 40	
3	AT-102	2.5	DO	2 - 4.8	
4	AT-102	38.9	TEMP	30 - 40	
5	AT-103	3	DO	2 - 4.8	
6	AT-103	39.3	TEMP	30 - 40	
4710-V2 : (5)					
1	MIXER V2-A1	Running			
2	pH AIC-001	9	pH	1 - 14	
3	Temp AIC-001	38.2	TEMP	25 - 40	
4	H2SO4 FEED	Running			
5	NaOH FEED	Running			
4710-V3 : (1)					
1	H3PO4 feed	Running			
4700-V4 Aeration_2 : (4) 1'					
1	DO chamber 1/2	3.6	DO	2 - 4	
2	Temp chamber 1/2	38.8	TEMP	30 - 40	
3	DO chamber 3/4	2.7	DO	1 - 3	
4	Temp chamber 3/4	38.8	TEMP	30 - 40	

4700-V32 : (2) 1'					
1	Level	1	%		
2	Pressure	0	kg/cm2	1 - 3	
4700-P29A : (3)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P11 : (3)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
3	pressure discharge pump	1	kg/cm2	1 - 3	
4700-P28A : (3)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	PG-016A	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P10A : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P10B : (3)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	pressure discharge	0		1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P15 : (2) 1'					
1	pressure discharge	0	kg/cm2	0 - 3	
2	Level lube Oil	0	%	> 50	

4700-B3 : (1)					
1	PG-023	NR			"EQ on Standby"
4700-SS : (4)					
1	AIC-005	0	pH	1 - 6	"EQ on Standby"
2	AIC-005	0	TEMP	30 - 40	"EQ on Standby"
3	LG-002	0	%	200 - 1000	"EQ on Standby"
4	CHEM. FEED H2SO4	NR			"EQ on Standby"
4700-P16 : (3)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	PG-024	NR			"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P1A : (3) 1'					
1	EQUIPMENT Status	Stand By			
2	PG-001A	0	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1B : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001B	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1C : (3) 2'					
1	EQUIPMENT Status	Stand By			
2	PG-001C	0	kg/cm2	1 - 3	
3	Level lube Oil	0	%	> 50	
4700-P8A : (2) 1'					
1	EQUIPMENT Status	Stand By			
2	ON/OFF	Stand By			

4700-P8B : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
4700-F32A : (4)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	Pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4	Current	0	Amp.	15 - 25	"EQ on Standby"
4700-P32B : (4)					
1	EQUIPMENT Status	Duty			
2	Pressure discharge	1.5	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4	Current	20.3	Amp.	15 - 25	
4700-V30S : (1)					
1	Site check	Normal			
4700-E2 : (2)					
1	TG-101 Air	32	C	30 - 40	
2	TG-102 CW	34	C	25 - 38	
4700-E3 : (2)					
1	TG-103 Air	34	C	30 - 40	
2	TG-104 CW	34	C	25 - 38	
4700-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.8	kg/cm2	0.5 - 1	
3	Temp	80	C	70 - 90	
4	DP air filter	-0.001	kg/cm2	> -0.05	

5	Oil Press	2.7	Bar	> 2	
4700-B1B : (4)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	PG-002B	0	kg/cm2	0.5 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1C : (4) 3 <sup>rd</sup>					
1	EQUIPMENT Status	Stand By			
2	PG-002C	0	kg/cm2	0.5 - 0.8	
3	CURRENT	0	Amps	55 - 75	
4	Level Oil	0	%	> 50	
4700-B1D : (4)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	PG-002D	0	kg/cm2	0.5 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B1C : (4)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	PG-101C	0	kg/cm2	0.5 - 1	"EQ on Standby"
3	CURRENT	0	Amps	110 - 140	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B2A : (5)					
1	EQUIPMENT Status	NR			"EQ on Standby"
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"

5	Oil Press	0	Bar	2 - 6.5	"EQ on Standby"
4710-B2B : (5)					
1	EQUIPMENT Status	NR			"EQ under Maintenance"
2	PRESS	0	kg/cm2	0.7 - 1	"EQ under Maintenance"
3	Temp	0	C	80 - 110	"EQ under Maintenance"
4	DP air filter	0	kg/cm2	> -0.05	"EQ under Maintenance"
5	Oil Press	0	Bar	2 - 6.5	"EQ under Maintenance"
4710-B2C : (4)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.7	kg/cm2	0.7 - 1	
3	Temp	92	C	80 - 110	
4	Oil Press	2.3	Bar	> 2	
4710-B2D : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.71	kg/cm2	0.7 - 1	
3	Temp	96	C	80 - 110	
4	DP air filter	-0.001	kg/cm2	> -0.05	
5	Oil Press	2.9	Bar	2 - 6.5	
4710-B2E : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.7	kg/cm2	0.7 - 1	
3	Temp	95	C	80 - 110	
4	DP air filter	-0.006	kg/cm2	> -0.05	
5	Oil Press	3	Bar	2 - 6.5	



CPL UT 4700 (1)

Conducted by :   
Conducted on : May 12, 2024 19:00:00  
Completed on : May 12, 2024 21:00:11

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.

No	Description	Value	EU	Lo - HI	Remarks
UBB Chemical (Pty) Ltd					
CPL (4864)					
UT : (525)					
UT_4700 (1) : (133)					
Work Summary : (1)					
1	Production Load	100	%		
4700-V1 : (1)					
1	FQ-001	2.79175e+006	m3		
2.79175e+006					
4700-E1A : (4)					
1	INLET TG-001A EFFLUENT TEMP.	64	C	50 - 75	
2	OUTLET TG-002A EFFLUENT TEMP.	36	C	30 - 45	
3	INLET TG-003A COOLING WATER	33	C	25 - 35	
4	OUTLET TG-004A COOLING WATER	34	C	30 - 40	
4700-E1B : (4)					
1	INLET TG-001B EFFLUENT TEMP.	64	C	50 - 75	
2	OUTLET TG-002B EFFLUENT TEMP.	36	C	30 - 45	
3	INLET TG-003B COOLING WATER	34	C	30 - 35	
4	OUTLET TG-004B COOLING WATER	34	C	30 - 40	
4700-P39 : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	2 - 5	*EQ on Standby*
3	Pressure FW seal	0	kg/cm2	2 - 4	*EQ on Standby*
4	Flow FW seal	0	x 0.1 M3/hr	1 - 5	*EQ on Standby*
4700-P40 : (4)					

1	EQUIPMENT Status	Run			
2	Discharge pressure	4	kg/cm2	2 - 5	
3	Pressure FW seal	3.6	kg/cm2	2 - 4	
4	Flow FW seal	5	x 0.1 M3/hr	2 - 5	
4700-V11 : (1)					
1	FI47003	4284			
4710-V4 Aeration_1 : (6)					
1	AT-101	2.6	DO	2 - 4.8	
2	AT-101	39.3	TEMP	30 - 40	
3	AT-102	2.5	DO	2 - 4.8	
4	AT-102	39.9	TEMP	30 - 40	
5	AT-103	2	DO	2 - 4.8	
6	AT-103	40	TEMP	30 - 40	
4710-V2 : (5)					
1	MIXER V2-A1	Running			
2	pH AIC-001	6.8	pH	1 - 14	
3	Temp AIC-001	38.8	TEMP	25 - 40	
4	H2SO4 FEED	Running			
5	NaOH FEED	Running			
4710-V3 : (1)					
1	H3PO4 feed	Running			
4700-V4 Aeration_2 : (4)					
1	DO chamber 1/2	2	DO	2 - 4	
2	Temp chamber 1/2	39.9	TEMP	30 - 40	
3	DO chamber 3/4	3	DO	1 - 3	
4	Temp chamber 3/4	39.8	TEMP	30 - 40	

4700-V32 : (2)					
1	Level	1	%		
2	Pressure	0	kg/cm2	1 - 3	"EQ on Standby"
4700-P23A : (3)					
1	EQUIPMENT Status	Stand By			
2	pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P11 : (3)					
1	EQUIPMENT Status	Stand By			
2	ON/OFF	NR			"EQ on Standby"
3	pressure discharge pump	0	kg/cm2	1 - 3	"EQ on Standby"
4700-P28A : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-016A	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P10A : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.5		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P10B : (3)					
1	EQUIPMENT Status	Duty			
2	pressure discharge	1.5		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P15 : (2)					
1	pressure discharge	0	kg/cm2	0 - 3	"EQ on Standby"
2	Level lube Oil	0	%	> 50	"EQ on Standby"

4700-B3 : (1)					
1	PG-023	NR			"EQ on Standby"
4700-S5 : (4)					
1	A/C-005	0	pH	1 - 5	"EQ on Standby"
2	A/C-005	0	TEMP	30 - 40	"EQ on Standby"
3	LG-002	0	%	200 - 1000	"EQ on Standby"
4	CHEM. FEED H2SO4	NR			"EQ on Standby"
4700-P16 : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-024	NR			"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P1A : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001A	1.5	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1B : (3)					
1	EQUIPMENT Status	Duty			
2	PG-001B	1.5	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1C : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-001C	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P8A : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			

4700-P8B : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
4700-P32A : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4	Current	0	Amp.	15 - 25	"EQ on Standby"
4700-P32B : (4)					
1	EQUIPMENT Status	Duty			
2	Pressure discharge	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4	Current	15.5	Amp.	15 - 25	
4700-V30S : (1)					
1	Site check	Normal			
4700-E2 : (2)					
1	TG-101 Air	54	C	30 - 40	
2	TG-102 CW	54	C	25 - 36	
4700-E3 : (2)					
1	TG-103 Air	35	C	30 - 40	
2	TG-104 CW	35	C	25 - 36	
4700-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.61	kg/cm2	0.5 - 1	
3	Temp	61	C	70 - 90	
4	DP air filter	-0.002	kg/cm2	> -0.05	

5	Oil Press	2.6	Bar	> 2	
4700-B1B : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002B	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002C	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1D : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002D	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-101C	0	kg/cm2	0.6 - 1	"EQ on Standby"
3	CURRENT	0	Amps	110 - 140	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	97	C	80 - 110	
4	DP air filter	-0.006	kg/cm2	> -0.05	

5	Oil Press	3.7	Bar	2 - 6.5	
4710-B2B : (5)					
1	EQUIPMENT Status	Under Repa...			
Under Repair					
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"
5	Oil Press	0	Bar	2 - 6.5	"EQ on Standby"
4710-B2C : (4)					
1	EQUIPMENT Status	Down			
2	PRESS	0.74	kg/cm2	0.7 - 1	
3	Temp	86	C	80 - 110	
4	Oil Press	3.9	Bar	> 2	
4710-B2D : (5)					
1	EQUIPMENT Status	Down			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	89	C	80 - 110	
4	DP air filter	-0.003	kg/cm2	> -0.05	
5	Oil Press	2.9	Bar	2 - 6.5	
4710-B2E : (5)					
1	EQUIPMENT Status	Down			
2	PRESS	0.74	kg/cm2	0.7 - 1	
3	Temp	100	C	80 - 110	
4	DP air filter	-0.004	kg/cm2	> -0.05	
5	Oil Press	3	Bar	2 - 6.5	



CPL UT 4700 (1)

Conducted by :

Conducted on : Jun 05, 2024 19:00:00

Completed on : Jun 05, 2024 21:57:36

Report created with Advansoft ODM

**Disclaimer**  
The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which we observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

**Confidentiality Statement**  
In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.

No	Description	Value	EU	Lo - Hi	Remarks
USEC-110 (MFLU)					
CPL (484)					
UT: (525)					
UT_4700 (1): (133) 3'					
Work Summary : (1)					
1	Production Load	100	%		
4700-V1 : (1)					
1	FQ-001	2.84731e+006	m3		
2.84731e+006					
4700-E1A : (4)					
1	INLET TG-001A EFFLUENT TEMP.	62	C	50 - 75	
2	OUTLET TG-002A EFFLUENT TEMP.	36	C	30 - 45	
3	INLET TG-003A COOLING WATER	34	C	25 - 35	
4	OUTLET TG-004A COOLING WATER	34	C	30 - 40	
4700-E1B : (4)					
1	INLET TG-001B EFFLUENT TEMP.	62	C	50 - 75	
2	OUTLET TG-002B EFFLUENT TEMP.	36	C	30 - 45	
3	INLET TG-003B COOLING WATER	34	C	30 - 35	
4	OUTLET TG-004B COOLING WATER	36	C	30 - 40	
4700-P39 : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	2 - 5	"EQ on Standby"
3	Pressure FW seal	0	kg/cm2	2 - 4	"EQ on Standby"
4	Flow FW seal	0	x 0.1 M3/hr	1 - 5	"EQ on Standby"
4700-P40 : (4)					

1	EQUIPMENT Status	Run			
2	Discharge pressure	1	kg/cm2	2 - 5	
3	Pressure FW seal	3.5	kg/cm2	2 - 4	
4	Flow FW seal	0	x 0.1 M3/hr	2 - 5	
4700-V11 : (1)					
1	F147003	42964			
4710-V4 Aeration_1 : (6) 3'					
1	AT-101	2.2	DO	2 - 4.5	
2	AT-101	40.1	TEMP	30 - 40	
3	AT-102	2.4	DO	2 - 4.8	
4	AT-102	40	TEMP	30 - 40	
5	AT-103	1.7	DO	2 - 4.8	
6	AT-103	40.2	TEMP	30 - 40	
4710-V2 : (5)					
1	MIXER V2-A1	Running			
2	pH AIC-001	8.5	pH	1 - 14	
3	Temp AIC-001	38.9	TEMP	25 - 40	
4	H2SO4 FEED	Running			
5	NaOH FEED	Running			
4710-V3 : (1)					
1	H3PO4 feed	Running			
4700-V4 Aeration_2 : (4)					
1	DO chamber 1/2	2.9	DO	2 - 4	
2	Temp chamber 1/2	38.9	TEMP	30 - 40	
3	DO chamber 3/4	1.5	DO	1 - 3	
4	Temp chamber 3/4	38.8	TEMP	30 - 40	

4700-V32 : (2)					
1	Level	6.9	%		
2	Pressure	0	kg/cm2	1 - 3	"EQ on Standby"
4700-P29A : (3)					
1	EQUIPMENT Status	Stand By			
2	pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P11 : (3)					
1	EQUIPMENT Status	Stand By			
2	ON/OFF	NR			"EQ on Standby"
3	pressure discharge pump	0	kg/cm2	1 - 3	"EQ on Standby"
4700-P28A : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-016A	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P10A : (3)					
1	EQUIPMENT Status	Run			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P10B : (3)					
1	EQUIPMENT Status	Run			
2	pressure discharge	1.8		1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P15 : (2)					
1	pressure discharge	0	kg/cm2	0 - 3	"EQ on Standby"
2	Level lube Oil	0	%	> 50	"EQ on Standby"

4700-B3 : (1)					
1	PG-023	NR			"EQ on Standby"
4700-S5 : (4)					
1	AIC-005	0	pH	1 - 8	"EQ on Standby"
2	AIC-005	0	TEMP	30 - 40	"EQ on Standby"
3	LG-002	0	%	200 - 1000	"EQ on Standby"
4	CHEM. FEED H2SO4	NR			"EQ on Standby"
4700-P16 : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-024	NR			"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P1A : (3)					
1	EQUIPMENT Status	Run			
2	PG-001A	1.7	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1B : (3)					
1	EQUIPMENT Status	Run			
2	PG-001B	1.7	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4700-P1C : (3)					
1	EQUIPMENT Status	Stand By			
2	PG-001C	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4700-P8A : (2)					
1	EQUIPMENT Status	Run			
2	ON/OFF	Running			



4700-P8B : (2)					
1	EQUIPMENT Status	Duty			
2	ON/OFF	Running			
4700-P32A : (4)					
1	EQUIPMENT Status	Duty			
2	Pressure discharge	2	kg/cm2	1 - 3	
3	Level lube Oil	50	%	> 50	
4	Current	19.5	Amp.	15 - 25	
4700-P32B : (4)					
1	EQUIPMENT Status	Stand By			
2	Pressure discharge	0	kg/cm2	1 - 3	"EQ on Standby"
3	Level lube Oil	0	%	> 50	"EQ on Standby"
4	Current	0	Amp.	15 - 25	"EQ on Standby"
4700-V30S : (1)					
1	Site check	Normal			
4700-E2 : (2)					
1	TG-101 Air	34	C	30 - 40	
2	TG-102 CW	34	C	25 - 35	
4700-E3 : (2)					
1	TG-103 Air	35	C	30 - 40	
2	TG-104 CW	35	C	25 - 35	
4700-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.61	kg/cm2	0.5 - 1	
3	Temp	82	C	70 - 90	
4	DP air filter	-0.002	kg/cm2	> -0.05	

5	Oil Press	2.5	Bar	> 2	
4700-B1B : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002B	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002C	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4700-B1D : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-002D	0	kg/cm2	0.6 - 0.8	"EQ on Standby"
3	CURRENT	0	Amps	55 - 75	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B1C : (4)					
1	EQUIPMENT Status	Stand By			
2	PG-101C	0	kg/cm2	0.8 - 1	"EQ on Standby"
3	CURRENT	0	Amps	110 - 140	"EQ on Standby"
4	Level Oil	0	%	> 50	"EQ on Standby"
4710-B2A : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	97	C	80 - 110	
4	DP air filter	-0.009	kg/cm2	> -0.05	

5	Oil Press	3.8	Bar	2 - 6.5	
4710-B2B : (5)					
1	EQUIPMENT Status	Under Repair			
Under Repair					
2	PRESS	0	kg/cm2	0.7 - 1	"EQ on Standby"
3	Temp	0	C	80 - 110	"EQ on Standby"
4	DP air filter	0	kg/cm2	> -0.05	"EQ on Standby"
5	Oil Press	0	Bar	2 - 6.5	"EQ on Standby"
4710-B2C : (4)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	97	C	80 - 110	
4	Oil Press	1.6	Bar	> 2	
4710-B2D : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.74	kg/cm2	0.7 - 1	
3	Temp	100	C	80 - 110	
4	DP air filter	-0.004	kg/cm2	> -0.05	
5	Oil Press	2.9	Bar	2 - 6.5	
4710-B2E : (5)					
1	EQUIPMENT Status	Duty			
2	PRESS	0.75	kg/cm2	0.7 - 1	
3	Temp	102	C	80 - 110	
4	DP air filter	-0.006	kg/cm2	> -0.05	
5	Oil Press	3.1	Bar	2 - 6.5	

