

ภาคผนวกที่ 9

หนังสือรับรองผลการตรวจวัดคุณภาพน้ำทิ้ง

---

## TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหญิง (ปราจีนบุรี)  
ของบริษัท หยงซิง สตีล (ไทยแลนด์) จำกัด  
**Sample Type** : Wastewater  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : April 24, 2024

**Work Request No.** : 268/24  
**Sample Received Date** : April 24, 2024  
**Report No.** : 692/24  
**Reported Date** : May 6, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
240424/18	บ่อน้ำหน้าของโครงการ						
		pH <sup>1/</sup>	Electrometric Method (4500-H <sup>+</sup> B)	April 24, 2024	7.2	-	Yellow, Sediment
		Biochemical Oxygen Demand <sup>1/</sup>	5-Day BOD Test, Azide Modification Method (5210 B)	April 25-30, 2024	30.0	mg/L	Yellow, Sediment
		Oil & Grease <sup>1/</sup>	Liquid-Liquid, Partition-Gravimetric Method (5520 B)	April 25, 2024	10.8	mg/L	Yellow, Sediment
		Settleable Solids <sup>1/</sup>	Imhoff cone (2540 F)	April 26, 2024	<0.1	ml/L	Yellow, Sediment
		Sulfide <sup>1/</sup>	Iodometric Method (4500-S <sup>2-</sup> F)	April 30, 2024	<1.0	mg/L	Yellow, Sediment
		Total Dissolved Solids	Dried at 180 °C Method (2540 C)	April 25, 2024	168	mg/L	Yellow, Sediment
		Total Suspended Solids	Dried at 103-105 °C Method (2540 D)	April 25, 2024	38.2	mg/L	Yellow, Sediment

Method : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

Remarks : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

: <sup>1/</sup> Parameter are not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

May 6, 2024

Kasidit Yasongkram

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

May 6, 2024

STS Group

## TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหญิง (ปราจีนบุรี)  
ของ บริษัท หญิงชิ่ง สตีล (ไทยแลนด์) จำกัด  
**Sample Type** : Water supply  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : April 24, 2024

**Work Request No.** : 268/24  
**Sample Received Date** : April 24, 2024  
**Report No.** : 693/24  
**Reported Date** : May 6, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
240424/19	น้ำใช้โครงการ	Total Dissolved Solids	Dried at 180 °C Method (2540 C)	April 25, 2024	110	mg/L	Clear

**Method** : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

**Remarks** : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

May 6, 2024

Kasidit Y

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

May 6, 2024

STS Group



## Analysis / Test Report

**Client :** STS Green Co., Ltd.

3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani Thailand 12150

**P/O :**

**Project Name :** โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงซิง (ปราจีนบุรี) ของบริษัท หยงซิง สตีล (ไทยแลนด์) จำกัด

**Project Location :**

**Lot ID: 2446509**

Date Received : Apr 25, 2024

Date Reported : Jul 10, 2024

Report Number : 2974761-1 Rev. No.1

Page 1 of 1

<b>Sample Number</b>	2446509-1
<b>Sampled Date</b>	Apr 24, 2024 11:30 AM
<b>Sample Description</b>	บ่อน้ำของโครงการ
<b>Date Analysis Commenced</b>	Apr 26, 2024
<b>Condition of Sample</b>	Contained in one plastic bottle, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Water Testing</b>						
Total Kjeldahl Nitrogen as N	mg/L	0.15	1.0	21.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Norg (C)	Bangkok

**Note :** This Analysis test report is reissued to supersede report No.2974761-1, Date Reported : May 02, 2024 due to revise client information.

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

*Suwimon C.*

Suwimon Chairuangwut  
Scientist (3)

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197

ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

3540-911/EMAIL

Life Sciences

[www.alsglobal.com](http://www.alsglobal.com)

S:\Reports\_All\_NoGL.rpt ( 8:53AM)

RIGHT SOLUTIONS RIGHT PARTNER



## TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหญิงชิง (ปราจีนบุรี)  
ของบริษัท หยงชิง สติล (ไทยแลนด์) จำกัด  
**Sample Type** : Wastewater  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : May 4, 2024

**Work Request No.** : 292/24  
**Sample Received Date** : May 5, 2024  
**Report No.** : 724/24  
**Reported Date** : May 14, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
050524/7	บ่อหน้าของโครงการ						
		pH <sup>1/</sup>	Electrometric Method (4500-H <sup>+</sup> B)	May 4, 2024	7.2	-	Yellow, Sediment
		Biochemical Oxygen Demand <sup>1/</sup>	5-Day BOD Test, Azide Modification Method (5210 B)	May 5-10, 2024	48.8	mg/L	Yellow, Sediment
		Oil & Grease <sup>1/</sup>	Liquid-Liquid, Partition-Gravimetric Method (5520 B)	May 6, 2024	<5.0	mg/L	Yellow, Sediment
		Settleable Solids <sup>1/</sup>	Imhoff cone (2540 F)	May 5, 2024	<0.1	ml/L	Yellow, Sediment
		Sulfide <sup>1/</sup>	Iodometric Method (4500-S <sup>2-</sup> F)	May 8, 2024	<1.0	mg/L	Yellow, Sediment
		Total Dissolved Solids	Dried at 180 °C Method (2540 C)	May 7, 2024	244	mg/L	Yellow, Sediment
		Total Suspended Solids	Dried at 103-105 °C Method (2540 D)	May 7, 2024	22.6	mg/L	Yellow, Sediment

**Method** : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

**Remarks** : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

: <sup>1/</sup> Parameter are not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

May 14, 2024

Kasidit Yasongkram

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

May 14, 2024

## TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงชิง (ปราจีนบุรี)  
ของ บริษัท หยงชิง สตีล (ไทยแลนด์) จำกัด  
**Sample Type** : Water supply  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : May 4, 2024

**Work Request No.** : 292/24  
**Sample Received Date** : May 5, 2024  
**Report No.** : 725/24  
**Reported Date** : May 14, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
050524/8	น้ำใช้โครงการ	Total Dissolved Solids	Dried at 180 °C Method (2540 C)	May 7, 2024	118	mg/L	Clear

**Method** : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

**Remarks** : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

May 14, 2024

Kasidit Y

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

May 14, 2024

STS Group



## Analysis / Test Report

**Client :** STS Green Co., Ltd.

3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani Thailand 12150

**P/O :**

**Project Name :** โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงชิง (ปราจีนบุรี) ของ บริษัท หยงชิง สตีล (ไทยแลนด์) จำกัด

**Project Location :**

**Lot ID: 2450448**

Date Received : May 06, 2024

Date Reported : Jul 12, 2024

Report Number : 2983185-1 Rev. No.1

Page 1 of 1

<b>Sample Number</b>	2450448-1
<b>Sampled Date</b>	May 04, 2024 12:30 PM
<b>Sample Description</b>	บ่อน้ำของโครงการ
<b>Date Analysis Commenced</b>	May 07, 2024
<b>Condition of Sample</b>	Contained in one plastic bottle, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Water Testing</b>						
Total Kjeldahl Nitrogen as N	mg/L	0.15	1.0	88.6	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Norg (C)	Bangkok

**Note :** This Analysis test report is reissued to supersede report No.2983185-1, Date Reported : May 10, 2024 due to revise client information.

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

*Suwimon C.*

Suwimon Chairuangwut  
Scientist (3)

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197

ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

3540-91/ EMAIL

Life Sciences

[www.alsglobal.com](http://www.alsglobal.com)

S:\Reports\_All\_NoGL.rpt (1:44PM)

RIGHT SOLUTIONS RIGHT PARTNER



## TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงชิง (ปราจีนบุรี)  
ของ บริษัท หยงชิง สตีล (ไทยแลนด์) จำกัด  
**Sample Type** : Wastewater  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : June 13, 2024

**Work Request No.** : 376/24  
**Sample Received Date** : June 13, 2024  
**Report No.** : 1020/24  
**Reported Date** : June 20, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
130624/27	บ่อน้ำของโครงการ						
		pH <sup>11</sup>	Electrometric Method (4500-H <sup>+</sup> B)	June 13, 2024	6.2	-	Turbid, Sediment
		Biochemical Oxygen Demand <sup>11</sup>	5-Day BOD Test, Azide Modification Method (5210 B)	June 14-19, 2024	6.9	mg/L	Turbid, Sediment
		Oil & Grease <sup>11</sup>	Liquid-Liquid, Partition-Gravimetric Method (5520 B)	June 17, 2024	<5.0	mg/L	Turbid, Sediment
		Settleable Solids <sup>11</sup>	Imhoff cone (2540 F)	June 14, 2024	<0.1	ml/L	Turbid, Sediment
		Sulfide <sup>11</sup>	Iodometric Method (4500-S <sup>2-</sup> F)	June 18, 2024	<1.0	mg/L	Turbid, Sediment
		Total Dissolved Solids	Dried at 180 °C Method (2540 C)	June 17, 2024	118	mg/L	Turbid, Sediment
		Total Suspended Solids	Dried at 103-105 °C Method (2540 D)	June 18, 2024	<10.0	mg/L	Turbid, Sediment

**Method** : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

**Remarks** : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

: <sup>11</sup> Parameter are not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

June 20, 2024

Kasidit Y

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

June 20, 2024



## TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหญิง (ปราจีนบุรี)  
ของ บริษัท หยงซิง สติล (ไทยแลนด์) จำกัด  
**Sample Type** : Water supply  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : June 13, 2024

**Work Request No.** : 376/24  
**Sample Received Date** : June 13, 2024  
**Report No.** : 1021/24  
**Reported Date** : June 20, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
130624/28	น้ำใช้โครงการ	Total Dissolved Solids	Dried at 180 °C Method (2540 C)	June 17, 2024	102	mg/L	Turbid, Sediment

**Method** : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

**Remarks** : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

June 20, 2024

Kasidit Y

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

June 20, 2024

STS Group



## Analysis / Test Report

**Client :** STS Green Co., Ltd.

3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani Thailand 12150

**P/O :**

**Project Name :** โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงชิง (ปราจีนบุรี) ของ  
บริษัท หยงชิง สตีล (ไทยแลนด์) จำกัด

**Project Location :**

**Lot ID: 2468064**

Date Received : Jun 14, 2024

Date Reported : Jul 12, 2024

Report Number : 3025628-1 Rev. No.1

Page 1 of 1

**Sample Number** 2468064-1  
**Sampled Date** Jun 13, 2024 9:30 AM  
**Sample Description** บ่อน้ำของโครงการ  
**Date Analysis Commenced** Jun 17, 2024  
**Condition of Sample** Contained in one plastic bottle

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Water Testing</b>						
Total Kjeldahl Nitrogen as N	mg/L	0.15	1.0	3.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Norg (C)	Bangkok

**Note :** This Analysis test report is reissued to supersede report No.3025628-1, Date Reported : Jun 20, 2024 due to revise client information.

**Remark :**

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

Results apply to the sample(s) as submitted, unless the sampling was conducted by  
ALS. No part of this report may be reproduced in any form without written consent  
from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that  
this report is not reproduced except in full.

Approved by

*Suwimon C.*

Suwimon Chairuangwut  
Scientist (3)

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197

ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

3540-91/ EMAIL

Life Sciences

www.alsglobal.com

S:\Reports\_All\_NoGL.rpt ( 1:33PM)

RIGHT SOLUTIONS RIGHT PARTNER

## TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงชิง (ปราจีนบุรี)  
ของบริษัทยิงชิง สตีล (ไทยแลนด์) จำกัด  
**Sample Type** : Wastewater  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : May 10, 2024

**Work Request No.** : 306/24  
**Sample Received Date** : May 11, 2024  
**Report No.** : 834/24  
**Reported Date** : May 17, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
110524/4	Manhole บ่อที่ 1						
		pH <sup>11</sup>	Electrometric Method (4500-H <sup>+</sup> B)	May 10, 2024	7.1	-	Black, Sediment
		Biochemical Oxygen Demand <sup>11</sup>	5-Day BOD Test, Azide Modification Method (5210 B)	May 11-16, 2024	75.0	mg/L	Black, Sediment
		Oil & Grease <sup>11</sup>	Liquid-Liquid, Partition-Gravimetric Method (5520 B)	May 13, 2024	5.2	mg/L	Black, Sediment
		Settleable Solids <sup>11</sup>	Imhoff cone (2540 F)	May 14, 2024	0.1	ml/L	Black, Sediment
		Sulfide <sup>11</sup>	Iodometric Method (4500-S <sup>2-</sup> F)	May 14, 2024	<1.0	mg/L	Black, Sediment
		Total Dissolved Solids	Dried at 180 °C Method (2540 C)	May 15, 2024	310	mg/L	Black, Sediment
		Total Suspended Solids	Dried at 103-105 °C Method (2540 D)	May 14, 2024	22.0	mg/L	Black, Sediment

**Method** : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

**Remarks** : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

: <sup>11</sup> Parameter are not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

May 17, 2024

Kasidit Y

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

May 17, 2024



# TEST REPORT

**Client** : STS GREEN CO., LTD.  
**Address** : 3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani 12150, Thailand  
**Project Name** : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงชิง (ปราจีนบุรี)  
ของ บริษัท หยงชิง สตีล (ไทยแลนด์) จำกัด  
**Sample Type** : Wastewater  
**Sampling By** : Environmental Monitoring Section/STS GREEN COMPANY LIMITED  
**Sampling Date** : May 10, 2024

**Work Request No.** : 306/24  
**Sample Received Date** : May 11, 2024  
**Report No.** : 835/24  
**Reported Date** : May 17, 2024

ID.No.	Sample Name	Parameters	Analytical Methods	Analytical Date	Results	Units	Sample Description
110524/5	Manhole บ่อที่ 2						
		pH <sup>1/</sup>	Electrometric Method (4500-H <sup>+</sup> B)	May 10, 2024	7.9	-	Turbid, Sediment
		Biochemical Oxygen Demand <sup>1/</sup>	5-Day BOD Test, Azide Modification Method (5210 B)	May 11-16, 2024	32.2	mg/L	Turbid, Sediment
		Oil & Grease <sup>1/</sup>	Liquid-Liquid, Partition-Gravimetric Method (5520 B)	May 13, 2024	<5.0	mg/L	Turbid, Sediment
		Settleable Solids <sup>1/</sup>	Imhoff cone (2540 F)	May 14, 2024	0.1	ml/L	Turbid, Sediment
		Sulfide <sup>1/</sup>	Iodometric Method (4500-S <sup>2-</sup> F)	May 14, 2024	<1.0	mg/L	Turbid, Sediment
		Total Dissolved Solids	Dried at 180 °C Method (2540 C)	May 15, 2024	250	mg/L	Turbid, Sediment
		Total Suspended Solids	Dried at 103-105 °C Method (2540 D)	May 14, 2024	<10.0	mg/L	Turbid, Sediment

**Method** : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23<sup>rd</sup> edition, 2017.

**Remarks** : Reported results refer to submitted samples only. This analytical report will not be reproduced in part for such purposes.

: Sampling is not accredited ISO/IEC 17025.

: <sup>1/</sup> Parameter are not accredited ISO/IEC 17025.

Pudchamon Phettoon

(Ms. Pudchamon Phettoon)

Chemist

May 17, 2024

Kasidit Yasongkram

(Mr. Kasidit Yasongkram)

Laboratory Supervisor

May 17, 2024





## Analysis / Test Report

**Client :** STS Green Co., Ltd.

3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani Thailand 12150

**P/O :**

**Project Name :** โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงชิง (ปราจีนบุรี) ของ บริษัท หยงชิง สตีล (ไทยแลนด์) จำกัด

**Project Location :**

**Lot ID: 2453122**

Date Received : May 13, 2024

Date Reported : Jul 12, 2024

Report Number : 2990040-1 Rev. No.1

Page 1 of 2

<b>Sample Number</b>	2453122-1
<b>Sampled Date</b>	May 10, 2024 12:20 PM
<b>Sample Description</b>	Manhole บ่อที่ 1
<b>Date Analysis Commenced</b>	May 14, 2024
<b>Condition of Sample</b>	Contained in one plastic bottle, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Water Testing</b>						
Total Kjeldahl Nitrogen as N	mg/L	0.15	1.0	28.6	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Norg (C)	Bangkok

**Note :** This Analysis test report is reissued to supersede report No.2990040-1, Date Reported : May 17, 2024 due to revise client information.

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

*Suwimon C.*

Suwimon Chairuangwut  
Scientist (3)

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197

ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

3540-917 EMAIL

Life Sciences

www.alsglobal.com

S:\Reports\_All\_NoGL.rpt ( 1:46PM)

RIGHT SOLUTIONS RIGHT PARTNER



## Analysis / Test Report

Client : STS Green Co., Ltd.

3/23 Moo 5, Lat Sawai, Lam Luk Ka, Pathum Thani Thailand 12150

P/O :

Project Name : โครงการอาคารอยู่อาศัยสวัสดิการสำหรับพนักงานหยงซิง (ปราจีนบุรี) ของ  
บริษัท หยงซิง สตีล (ไทยแลนด์) จำกัด

Project Location :

Lot ID: 2453122

Date Received : May 13, 2024

Date Reported : Jul 12, 2024

Report Number : 2990040-1 Rev. No.1

Page 2 of 2

Sample Number	2453122-2
Sampled Date	May 10, 2024 11:50 AM
Sample Description	Manhole บ่อที่ 2
Date Analysis Commenced	May 14, 2024
Condition of Sample	Contained in one plastic bottle, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Water Testing</b>						
Total Kjeldahl Nitrogen as N	mg/L	0.15	1.0	40.9	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Norg (C)	Bangkok

**Note :** This Analysis test report is reissued to supersede report No.2990040-1, Date Reported : May 17, 2024 due to revise client information.

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

Results apply to the sample(s) as submitted, unless the sampling was conducted by  
ALS. No part of this report may be reproduced in any form without written consent  
from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that  
this report is not reproduced except in full.

Approved by

*Suwimon C.*

Suwimon Chairuangwut  
Scientist (3)

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197

ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

3540-91/ EMAIL

Life Sciences

www.alsglobal.com

S:\Reports\All\_NoGL.rpt ( 1:46PM)

RIGHT SOLUTIONS RIGHT PARTNER