

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
01/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 07:00	0	0.17	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 12:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 13:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 14:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 15:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 16:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 17:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 18:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 19:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 20:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 21:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 22:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/01/2024 23:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	0	0	---	---	---	
MinDate	01/01/2024 00:00	01/01/2024 00:00	01/01/2024 00:00	01/01/2024 00:00	01/01/2024 00:00	
Maximum	0	0.17	---	---	---	
MaxDate	01/01/2024 00:00	01/01/2024 07:00	01/01/2024 00:00	01/01/2024 00:00	01/01/2024 00:00	
Avg	0	0.01	---	---	---	
Num	25	25	0	0	0	
Data[%]	100	100	---	---	---	
STD	0	0	---	---	---	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
01/01/2024 00:00	48.52	0	95.76	0.6	37.2	
01/01/2024 01:00	48.52	0	95.83	0.6	36.9	
01/01/2024 02:00	48.51	0	95.92	0.7	36.6	
01/01/2024 03:00	48.51	0	95.91	0.7	36.4	
01/01/2024 04:00	48.51	0	95.84	0.7	37.1	
01/01/2024 05:00	48.51	0	95.84	0.7	37.5	
01/01/2024 06:00	48.51	0	95.81	0.7	37.6	
01/01/2024 07:00	48.48	0	95.66	0.7	38.6	
01/01/2024 08:00	47.91	0	95.26	0.6	38.8	
01/01/2024 09:00	47.4	0	95.03	0.6	39	
01/01/2024 10:00	46.83	0	94.89	0.5	39	
01/01/2024 11:00	46.39	0	94.77	0.5	39	
01/01/2024 12:00	46.25	0	94.74	0.5	39.1	
01/01/2024 13:00	46.07	0	94.82	0.4	39.2	
01/01/2024 14:00	45.95	0	94.8	0.4	39	
01/01/2024 15:00	45.91	0.21	94.59	0.4	38.7	
01/01/2024 16:00	46.59	0	94.74	0.4	37.9	
01/01/2024 17:00	47.29	0	94.92	0.3	37.8	
01/01/2024 18:00	47.65	0	95.04	0.4	37.7	
01/01/2024 19:00	47.95	0	95.35	0.5	37.7	
01/01/2024 20:00	47.99	0	95.39	0.5	38	
01/01/2024 21:00	48.28	0	95.58	0.5	37.8	
01/01/2024 22:00	48.5	0	95.66	0.6	37.7	
01/01/2024 23:00	48.73	0	95.76	0.6	37.1	
02/01/2024 00:00	48.78	0	95.77	0.7	37.3	
Minimum	45.91	0	94.59	0.3	36.4	
MinDate	01/01/2024 15:00	01/01/2024 00:00	01/01/2024 15:00	01/01/2024 17:00	01/01/2024 03:00	
Maximum	48.78	0.21	95.92	0.7	39.2	
MaxDate	02/01/2024 00:00	01/01/2024 15:00	01/01/2024 02:00	01/01/2024 02:00	01/01/2024 13:00	
Avg	47.7	0.01	95.35	0.6	37.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	1	0	0.5	0.1	0.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
02/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 07:00	0	0.36	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 12:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 13:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 14:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 15:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 16:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 17:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 18:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 19:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 20:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 21:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 22:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
02/01/2024 23:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
03/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	0	0	---	---	---	
MinDate	02/01/2024 00:00	02/01/2024 00:00	02/01/2024 00:00	02/01/2024 00:00	02/01/2024 00:00	
Maximum	0	0.36	---	---	---	
MaxDate	02/01/2024 00:00	02/01/2024 07:00	02/01/2024 00:00	02/01/2024 00:00	02/01/2024 00:00	
Avg	0	0.01	---	---	---	
Num	25	25	0	0	0	
Data[%]	100	100	---	---	---	
STD	0	0.1	---	---	---	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
02/01/2024 00:00	48.78	0	95.77	0.7	37.3	
02/01/2024 01:00	48.79	0	95.78	0.7	37.3	
02/01/2024 02:00	48.82	0	95.8	0.7	37.2	
02/01/2024 03:00	48.86	0	95.81	0.7	36.9	
02/01/2024 04:00	48.86	0	95.83	0.7	35.9	
02/01/2024 05:00	48.89	0	95.91	0.8	36.4	
02/01/2024 06:00	48.9	0	95.99	0.8	36	
02/01/2024 07:00	48.91	0	96.11	0.8	35.9	
02/01/2024 08:00	47.9	0	96.05	0.7	35.2	
02/01/2024 09:00	44.58	0	96.35	0.7	27.8	
02/01/2024 10:00	44.58	0	96.1	0.7	28.5	
02/01/2024 11:00	44.57	0	96.15	0.6	30	
02/01/2024 12:00	44.51	0	95.93	0.6	31	
02/01/2024 13:00	44.5	0	95.67	0.5	32.3	
02/01/2024 14:00	44.45	0	95.61	0.4	32.5	
02/01/2024 15:00	44.4	0.15	95.33	0.3	32.5	
02/01/2024 16:00	44.43	0	95.26	0	31.7	
02/01/2024 17:00	45.05	0	95.38	0	32.1	
02/01/2024 18:00	47.36	0	95.07	0	36.5	
02/01/2024 19:00	47.96	0	95.45	0	36.1	
02/01/2024 20:00	48.36	0	95.66	0	35.5	
02/01/2024 21:00	45.84	0	96.56	0.2	28.6	
02/01/2024 22:00	44.99	0	96.66	0.4	26.2	
02/01/2024 23:00	44.87	0	96.71	0.5	26.2	
03/01/2024 00:00	44.76	0	96.03	0.6	26	
Minimum	44.4	0	95.07	0	26	
MinDate	02/01/2024 15:00	02/01/2024 00:00	02/01/2024 18:00	02/01/2024 16:00	03/01/2024 00:00	
Maximum	48.91	0.15	96.71	0.8	37.3	
MaxDate	02/01/2024 07:00	02/01/2024 15:00	02/01/2024 23:00	02/01/2024 05:00	02/01/2024 00:00	
Avg	46.56	0.01	95.88	0.5	32.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	2	0	0.4	0.3	3.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
03/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 07:00	0	0.31	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 12:00	0	0.03	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 13:00	0	0.07	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 14:00	0	0.07	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 15:00	0	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 16:00	10.55	0.52	ShutDown	ShutDown	ShutDown	GT11 S/D
03/01/2024 17:00	27.37	0.06	91.57	0	49.2	
03/01/2024 18:00	32.18	0.01	93.04	0	32.4	
03/01/2024 19:00	32.12	0	93.01	0	33.5	
03/01/2024 20:00	32.05	0	93.12	0	34.8	
03/01/2024 21:00	35.2	0	94.34	0	38.9	
03/01/2024 22:00	45.59	0	96.02	0	32.1	
03/01/2024 23:00	45.8	0	96.84	0	31.9	
04/01/2024 00:00	45.77	0	97.11	0	31.6	
Minimum	0	0	91.57	0	31.6	
MinDate	03/01/2024 00:00	03/01/2024 00:00	03/01/2024 17:00	03/01/2024 17:00	04/01/2024 00:00	
Maximum	45.8	0.52	97.11	0	49.2	
MaxDate	03/01/2024 23:00	03/01/2024 16:00	04/01/2024 00:00	03/01/2024 17:00	03/01/2024 17:00	
Avg	12.27	0.04	94.38	0	35.6	
Num	25	25	8	8	8	
Data[%]	100	100	32	32	32	
STD	17.9	0.1	2	0	6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
03/01/2024 00:00	44.76	0	96.03	0.6	26	
03/01/2024 01:00	44.82	0	96.08	0.6	26.3	
03/01/2024 02:00	44.75	0	96.37	0.7	26.9	
03/01/2024 03:00	44.71	0	95.95	0.7	26.9	
03/01/2024 04:00	44.77	0	96.41	0.7	27	
03/01/2024 05:00	44.68	0	95.52	0.7	27	
03/01/2024 06:00	44.53	0	95.17	0.7	27.3	
03/01/2024 07:00	44.54	0	95.54	0.7	27.8	
03/01/2024 08:00	44.62	0	95.85	0.6	28.3	
03/01/2024 09:00	44.92	0	96.14	0.4	28.9	
03/01/2024 10:00	44.88	0	95.92	0.2	30.1	
03/01/2024 11:00	44.91	0	95.58	0	31.3	
03/01/2024 12:00	44.88	0	95.54	0	32.4	
03/01/2024 13:00	44.86	0	95.34	0	33.2	
03/01/2024 14:00	44.86	0	95.37	0	33.6	
03/01/2024 15:00	45.03	0.34	95.24	0	33.7	
03/01/2024 16:00	37.19	0	93.87	0	34.8	
03/01/2024 17:00	27.31	0	92.52	0	42	
03/01/2024 18:00	32.11	0	92.97	0	33.1	
03/01/2024 19:00	32.06	0	92.50	0	36.4	
03/01/2024 20:00	31.99	0	93.06	0	38.1	
03/01/2024 21:00	15.36	0	<Samp	<Samp	<Samp	GT12 S/D
03/01/2024 22:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
03/01/2024 23:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	92.52	0	26	
MinDate	03/01/2024 22:00	03/01/2024 00:00	03/01/2024 17:00	03/01/2024 11:00	03/01/2024 00:00	
Maximum	45.03	0.34	96.41	0.7	42	
MaxDate	03/01/2024 15:00	03/01/2024 15:00	03/01/2024 04:00	03/01/2024 02:00	03/01/2024 17:00	
Avg	35.7	0.01	95.13	0.3	31	
Num	25	25	21	21	21	
Data[%]	100	100	84	84	84	
STD	15.4	0.1	1.3	0.3	4.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
04/01/2024 00:00	45.77	0	97.11	0	31.6	
04/01/2024 01:00	45.78	0	97.12	0	31.6	
04/01/2024 02:00	45.73	0	97.07	0	31.8	
04/01/2024 03:00	45.75	0	97.12	0	31.8	
04/01/2024 04:00	45.76	0	96.97	0	31.7	
04/01/2024 05:00	45.8	0	96.9	0	31.5	
04/01/2024 06:00	45.88	0	96.7	0	31.5	
04/01/2024 07:00	46.05	0.25	96.87	0	31.7	
04/01/2024 08:00	47.06	0	96.57	0	35.3	
04/01/2024 09:00	47.64	0	95.85	0	38.2	
04/01/2024 10:00	47.38	0	95.62	0	39	
04/01/2024 11:00	46.92	0	95.88	0	39.3	
04/01/2024 12:00	42.81	0.05	96.97	0	37	
04/01/2024 13:00	31.58	0.09	94.14	0	36.5	
04/01/2024 14:00	33.44	0.07	94.6	0	27.1	
04/01/2024 15:00	33.4	0.09	94.29	0	26.8	
04/01/2024 16:00	33.24	0.09	93.64	0	26.5	
04/01/2024 17:00	33.06	0.01	93.34	0	27.2	
04/01/2024 18:00	33.04	0	93.27	0	28	
04/01/2024 19:00	33.02	0	93.47	0	28.5	
04/01/2024 20:00	33.2	0.01	93.58	0	28.3	
04/01/2024 21:00	33.25	0	93.8	0	28.3	
04/01/2024 22:00	30.89	0	93.65	0	94	
04/01/2024 23:00	2.19	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	93.27	0	26.5	
MinDate	05/01/2024 00:00	04/01/2024 00:00	04/01/2024 18:00	04/01/2024 00:00	04/01/2024 16:00	
Maximum	47.64	0.25	97.12	0	39.3	
MaxDate	04/01/2024 09:00	04/01/2024 07:00	04/01/2024 01:00	04/01/2024 00:00	04/01/2024 11:00	
Avg	37.15	0.03	95.41	0	31.9	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	12.6	0.1	1.5	0	4.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
04/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 12:00	5.5	0	ShutDown	ShutDown	ShutDown	GT12 S/D
04/01/2024 13:00	31.5	0	93.74	0.2	43.5	
04/01/2024 14:00	33.37	0	94.41	0	37	
04/01/2024 15:00	33.34	0.28	94.26	0	36.3	
04/01/2024 16:00	33.18	0	93.66	0	35.9	
04/01/2024 17:00	32.99	0	93.4	0	38.6	
04/01/2024 18:00	32.97	0	93.4	0	40.5	
04/01/2024 19:00	32.96	0	93.6	0	41.8	
04/01/2024 20:00	33.14	0	93.74	0.1	41.1	
04/01/2024 21:00	33.19	0	93.78	0.2	41.5	
04/01/2024 22:00	30.86	0	93.48	0.3	43.7	
04/01/2024 23:00	46.26	0	96.09	0.4	43.7	
05/01/2024 00:00	47.71	0	95.98	0.5	42.2	
Minimum	0	0	93.4	0	35.9	
MinDate	04/01/2024 00:00	04/01/2024 00:00	04/01/2024 17:00	04/01/2024 14:00	04/01/2024 16:00	
Maximum	47.71	0.28	96.09	0.5	43.7	
MaxDate	05/01/2024 00:00	04/01/2024 15:00	04/01/2024 23:00	05/01/2024 00:00	04/01/2024 22:00	
Avg	17.08	0.01	94.13	0.1	40.5	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.1	0.1	0.9	0.2	2.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 07:00	0	0.19	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 12:00	8.12	0.31	ShutDown	ShutDown	ShutDown	GT11 S/D
05/01/2024 13:00	31.98	0.04	94.77	0	37.3	
05/01/2024 14:00	33.94	0.08	94.79	0	29.3	
05/01/2024 15:00	33.9	0.03	94.44	0	29.1	
05/01/2024 16:00	33.78	0.02	94.24	0	28.4	
05/01/2024 17:00	33.61	0.02	93.78	0	27.5	
05/01/2024 18:00	33.59	0	93.89	0	27.1	
05/01/2024 19:00	33.42	0	93.83	0	28	
05/01/2024 20:00	33.52	0	93.81	0	27.8	
05/01/2024 21:00	33.68	0	94.33	0	26.8	
05/01/2024 22:00	33.48	0.03	95.34	0	32.9	
05/01/2024 23:00	24.62	0.1	92.31	0	50.4	
06/01/2024 00:00	27.97	0.03	92.57	0	49.7	
Minimum	0	0	92.31	0	26.8	
MinDate	05/01/2024 00:00	05/01/2024 00:00	05/01/2024 23:00	05/01/2024 13:00	05/01/2024 21:00	
Maximum	33.94	0.31	95.34	0	50.4	
MaxDate	05/01/2024 14:00	05/01/2024 12:00	05/01/2024 22:00	05/01/2024 13:00	05/01/2024 23:00	
Avg	15.82	0.03	93.97	0	32.9	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	16.3	0.1	0.9	0	8.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/01/2024 00:00	47.71	0	95.98	0.5	42.2	
05/01/2024 01:00	48.13	0	96.34	0.6	43	
05/01/2024 02:00	48.12	0	96.46	0.7	42.4	
05/01/2024 03:00	48.02	0	96.45	0.7	43.4	
05/01/2024 04:00	47.54	0	96.26	0.7	43.7	
05/01/2024 05:00	47.28	0	96.31	0.7	42.8	
05/01/2024 06:00	47.28	0	96.27	0.6	42.3	
05/01/2024 07:00	47.43	0	96.23	0.5	42.7	
05/01/2024 08:00	47.93	0	95.63	0.4	48.9	
05/01/2024 09:00	47.82	0	95.17	0.3	48.4	
05/01/2024 10:00	47.18	0	95.09	0.2	48	
05/01/2024 11:00	46.69	0	94.98	0.1	48	
05/01/2024 12:00	40.89	0	95.03	0	47.1	
05/01/2024 13:00	31.93	0	94.29	0	40.7	
05/01/2024 14:00	33.87	0	94.63	0	34.8	
05/01/2024 15:00	33.83	0.21	94.45	0	34.6	
05/01/2024 16:00	33.71	0	94.36	0	34	
05/01/2024 17:00	33.54	0	93.93	0	32.9	
05/01/2024 18:00	33.53	0	93.88	0	33	
05/01/2024 19:00	33.36	0	93.7	0	36.1	
05/01/2024 20:00	33.46	0	93.83	0	35.5	
05/01/2024 21:00	33.62	0	94.28	0.1	33.9	
05/01/2024 22:00	33.4	0	95.21	0.3	36.7	
05/01/2024 23:00	24.57	0	92.22	0.4	50.7	
06/01/2024 00:00	27.9	0	92.29	0.5	45.3	
Minimum	24.57	0	92.22	0	32.9	
MinDate	05/01/2024 23:00	05/01/2024 00:00	05/01/2024 23:00	05/01/2024 12:00	05/01/2024 17:00	
Maximum	48.13	0.21	96.46	0.7	50.7	
MaxDate	05/01/2024 01:00	05/01/2024 15:00	05/01/2024 02:00	05/01/2024 02:00	05/01/2024 23:00	
Avg	39.95	0.01	94.93	0.3	41.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.9	0	1.2	0.3	5.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
06/01/2024 00:00	27.97	0.03	92.57	0	49.7	
06/01/2024 01:00	30.73	0.02	93	0	42.3	
06/01/2024 02:00	31.6	0.03	93.31	0	38.5	
06/01/2024 03:00	31.54	0	93.36	0	38.5	
06/01/2024 04:00	31.42	0.03	93.27	0	39.6	
06/01/2024 05:00	31.21	0.01	92.99	0	41.6	
06/01/2024 06:00	31.22	0	92.78	0	41.5	
06/01/2024 07:00	31.21	0.37	92.72	0	41.5	
06/01/2024 08:00	31.64	0	92.88	0	37.7	
06/01/2024 09:00	31.94	0	92.95	0	34.5	
06/01/2024 10:00	32.08	0	93.32	0	31.8	
06/01/2024 11:00	32.08	0	93.76	0	30.3	
06/01/2024 12:00	31.94	0.02	93.83	0	29.8	
06/01/2024 13:00	41.95	0.02	97.79	0	35.5	
06/01/2024 14:00	45.74	0.02	101.26	0	39.2	
06/01/2024 15:00	45.81	0.02	101.22	0	38.9	
06/01/2024 16:00	45.7	0	100.96	0	38.1	
06/01/2024 17:00	45.7	0	101.57	0	33.6	
06/01/2024 18:00	45.81	0	101.9	0	31.4	
06/01/2024 19:00	45.73	0	102.02	0	30.5	
06/01/2024 20:00	45.97	0	102.16	0	30.1	
06/01/2024 21:00	46.03	0	101.97	0	30	
06/01/2024 22:00	42.44	0	100.26	0	31.9	
06/01/2024 23:00	31.9	0	93.5	0	34.2	
07/01/2024 00:00	31.71	0	92.74	0	35.3	
Minimum	27.97	0	92.57	0	29.8	
MinDate	06/01/2024 00:00	06/01/2024 03:00	06/01/2024 00:00	06/01/2024 00:00	06/01/2024 12:00	
Maximum	46.03	0.37	102.16	0	49.7	
MaxDate	06/01/2024 21:00	06/01/2024 07:00	06/01/2024 20:00	06/01/2024 00:00	06/01/2024 00:00	
Avg	36.84	0.02	96.32	0	36.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7	0.1	4.1	0	5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
06/01/2024 00:00	27.9	0	92.29	0.5	45.3	
06/01/2024 01:00	30.67	0	92.57	0.6	47.1	
06/01/2024 02:00	31.53	0	92.91	0.6	47.2	
06/01/2024 03:00	31.48	0	92.97	0.6	46.8	
06/01/2024 04:00	31.36	0	92.88	0.7	47	
06/01/2024 05:00	31.15	0	92.65	0.7	47.6	
06/01/2024 06:00	31.16	0	92.38	0.7	48.8	
06/01/2024 07:00	31.15	0	92.31	0.7	49.5	
06/01/2024 08:00	31.58	0	92.44	0.6	49.1	
06/01/2024 09:00	31.87	0	92.65	0.5	48.3	
06/01/2024 10:00	32.02	0	93.01	0.4	44.8	
06/01/2024 11:00	32.02	0	93.36	0.3	42.6	
06/01/2024 12:00	31.88	0	93.4	0.1	42.2	
06/01/2024 13:00	41.86	0	97.47	0	42.9	
06/01/2024 14:00	45.64	0	100.67	0	45.1	
06/01/2024 15:00	45.73	0.15	100.86	0	44.6	
06/01/2024 16:00	45.62	0	100.75	0	43.5	
06/01/2024 17:00	45.61	0	101.44	0	38	
06/01/2024 18:00	45.74	0	101.85	0	35.6	
06/01/2024 19:00	45.66	0	101.84	0	34.5	
06/01/2024 20:00	45.9	0	101.93	0	34	
06/01/2024 21:00	45.94	0	102.53	0.1	33.8	
06/01/2024 22:00	42.35	0	101.76	0.3	35.2	
06/01/2024 23:00	31.83	0	94.34	0.4	44.5	
07/01/2024 00:00	31.64	0	93.41	0.5	44.1	
Minimum	27.9	0	92.29	0	33.8	
MinDate	06/01/2024 00:00	06/01/2024 00:00	06/01/2024 00:00	06/01/2024 13:00	06/01/2024 21:00	
Maximum	45.94	0.15	102.53	0.7	49.5	
MaxDate	06/01/2024 21:00	06/01/2024 15:00	06/01/2024 21:00	06/01/2024 04:00	06/01/2024 07:00	
Avg	36.77	0.01	96.19	0.3	43.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7	0	4.2	0.3	5.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
07/01/2024 00:00	31.71	0	92.74	0	35.3	
07/01/2024 01:00	31.74	0.03	92.6	0	35.1	
07/01/2024 02:00	31.71	0	92.47	0	35.8	
07/01/2024 03:00	31.61	0.01	92.35	0	35.9	
07/01/2024 04:00	31.51	0	92.39	0	35.1	
07/01/2024 05:00	31.27	0	92.15	0	38	
07/01/2024 06:00	31.14	0	91.63	0	38.9	
07/01/2024 07:00	30.77	0.31	91.37	0	40.3	
07/01/2024 08:00	30.76	0	91.46	0	39.1	
07/01/2024 09:00	30.89	0	91.79	0	37.3	
07/01/2024 10:00	30.94	0	91.99	0	35.8	
07/01/2024 11:00	30.98	0	92.19	0	34.5	
07/01/2024 12:00	30.82	0	92.47	0	34.7	
07/01/2024 13:00	30.87	0.02	92.5	0	33.7	
07/01/2024 14:00	30.94	0.02	92.55	0	32.7	
07/01/2024 15:00	30.95	0	92.31	0	32.6	
07/01/2024 16:00	30.14	0	91.95	0	35.5	
07/01/2024 17:00	31.02	0	92.06	0	43.8	
07/01/2024 18:00	41.28	0	97.88	0	28	
07/01/2024 19:00	41.23	0	98.23	0	28	
07/01/2024 20:00	41.3	0	98.11	0	27.8	
07/01/2024 21:00	30.97	0	94.61	0	42.3	
07/01/2024 22:00	27.57	0.01	91.88	0	48.9	
07/01/2024 23:00	27.54	0	91.88	0	49.1	
08/01/2024 00:00	27.46	0.02	91.92	0	50	
Minimum	27.46	0	91.37	0	27.8	
MinDate	08/01/2024 00:00	07/01/2024 00:00	07/01/2024 07:00	07/01/2024 00:00	07/01/2024 20:00	
Maximum	41.3	0.31	98.23	0	50	
MaxDate	07/01/2024 20:00	07/01/2024 07:00	07/01/2024 19:00	07/01/2024 00:00	08/01/2024 00:00	
Avg	31.88	0.02	92.94	0	37.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	3.7	0.1	2	0	6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
07/01/2024 00:00	31.64	0	93.41	0.5	44.1	
07/01/2024 01:00	31.68	0	93.24	0.5	44.6	
07/01/2024 02:00	31.65	0	93.08	0.6	44.9	
07/01/2024 03:00	31.55	0	92.95	0.6	44.4	
07/01/2024 04:00	31.45	0	92.98	0.7	44.3	
07/01/2024 05:00	31.21	0	92.8	0.7	45.2	
07/01/2024 06:00	31.08	0	92.36	0.7	46.2	
07/01/2024 07:00	30.71	0	92.17	0.7	46.4	
07/01/2024 08:00	30.69	0	92.32	0.7	46.5	
07/01/2024 09:00	30.83	0	92.48	0.6	46.4	
07/01/2024 10:00	30.87	0	92.74	0.6	46.3	
07/01/2024 11:00	30.92	0	92.87	0.5	46.4	
07/01/2024 12:00	30.76	0	93.12	0.3	46.2	
07/01/2024 13:00	30.81	0	93.15	0.2	46.3	
07/01/2024 14:00	30.87	0	93.21	0	46.3	
07/01/2024 15:00	30.89	0.34	92.98	0	46.4	
07/01/2024 16:00	30.08	0	92.72	0	45.8	
07/01/2024 17:00	30.94	0	93.03	0	42.8	
07/01/2024 18:00	41.21	0	98.28	0	30.2	
07/01/2024 19:00	41.16	0	98.6	0	30.1	
07/01/2024 20:00	41.23	0	98.48	0	29.8	
07/01/2024 21:00	30.91	0	94.8	0	40.9	
07/01/2024 22:00	27.51	0	92.69	0	43.8	
07/01/2024 23:00	27.48	0	92.77	0	43.9	
08/01/2024 00:00	27.4	0	92.79	0	44.4	
Minimum	27.4	0	92.17	0	29.8	
MinDate	08/01/2024 00:00	07/01/2024 00:00	07/01/2024 07:00	07/01/2024 14:00	07/01/2024 20:00	
Maximum	41.23	0.34	98.6	0.7	46.5	
MaxDate	07/01/2024 20:00	07/01/2024 15:00	07/01/2024 19:00	07/01/2024 04:00	07/01/2024 08:00	
Avg	31.82	0.01	93.6	0.3	43.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	3.7	0.1	1.9	0.3	5.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/01/2024 00:00	27.46	0.02	91.92	0	50	
08/01/2024 01:00	27.5	0.01	91.82	0	49.3	
08/01/2024 02:00	27.52	0.01	91.72	0	49.3	
08/01/2024 03:00	27.51	0	91.69	0	49.3	
08/01/2024 04:00	27.48	0	91.55	0	49.3	
08/01/2024 05:00	27.47	0	91.43	0	50	
08/01/2024 06:00	27.53	0	91.31	0	50.2	
08/01/2024 07:00	27.51	0.23	91.21	0	49.6	
08/01/2024 08:00	28.03	0	91.71	0	47.1	
08/01/2024 09:00	41.19	0	94.18	0	39.4	
08/01/2024 10:00	47.14	0	94.5	0	35.4	
08/01/2024 11:00	46.89	0	95.5	0	35.4	
08/01/2024 12:00	40.26	0.09	95.48	0	37.8	
08/01/2024 13:00	32.52	0.18	94.74	0	30.6	
08/01/2024 14:00	34.26	0.09	95.77	0	23.9	
08/01/2024 15:00	34.29	0.1	95.34	0	23.4	
08/01/2024 16:00	34.17	0.04	94.86	0	23.4	
08/01/2024 17:00	34.02	0	94.54	0	23.3	
08/01/2024 18:00	33.91	0	94.19	0	23.4	
08/01/2024 19:00	33.74	0	94.01	0	23.4	
08/01/2024 20:00	33.87	0.01	94.17	0	23.4	
08/01/2024 21:00	34.05	0	94.46	0	23.2	
08/01/2024 22:00	31.22	0	94.04	0	30.6	
08/01/2024 23:00	1.87	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/U
Minimum	0	0	91.21	0	23.2	
MinDate	09/01/2024 00:00	08/01/2024 03:00	08/01/2024 07:00	08/01/2024 00:00	08/01/2024 21:00	
Maximum	47.14	0.23	95.77	0	50.2	
MaxDate	08/01/2024 10:00	08/01/2024 07:00	08/01/2024 14:00	08/01/2024 00:00	08/01/2024 06:00	
Avg	30.46	0.03	93.48	0	36.6	
Num	25	25	23	23	21	
Data[%]	100	100	92	92	92	
STD	10.6	0.1	1.6	0	11.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/01/2024 00:00	27.4	0	92.79	0	44.4	
08/01/2024 01:00	27.44	0	92.76	0.1	43.7	
08/01/2024 02:00	27.46	0	92.66	0.1	43.7	
08/01/2024 03:00	27.44	0	92.58	0.2	43.8	
08/01/2024 04:00	27.43	0	92.4	0.2	44.2	
08/01/2024 05:00	27.41	0	92.3	0.2	44.9	
08/01/2024 06:00	27.46	0	92.31	0.2	44.9	
08/01/2024 07:00	27.45	0	92.43	0.1	44.6	
08/01/2024 08:00	27.97	0	92.84	0.1	44.2	
08/01/2024 09:00	6.24	0	ShutDown	ShutDown	ShutDown	GT12 S/D
08/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
08/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
08/01/2024 12:00	8.58	0	ShutDown	ShutDown	ShutDown	GT12 S/D
08/01/2024 13:00	32.41	0	95.21	0	41.5	
08/01/2024 14:00	34.19	0	95.24	0	36.6	
08/01/2024 15:00	34.22	0.25	94.91	0	35.6	
08/01/2024 16:00	34.11	0	94.55	0	35.4	
08/01/2024 17:00	33.95	0	94.27	0	35.4	
08/01/2024 18:00	33.84	0	93.98	0	35.8	
08/01/2024 19:00	33.67	0	93.8	0	36	
08/01/2024 20:00	33.8	0	93.94	0	36	
08/01/2024 21:00	33.98	0	94.07	0	35.4	
08/01/2024 22:00	31.33	0	93.55	0	40.3	
08/01/2024 23:00	47.21	0	95.79	0	45.9	
09/01/2024 00:00	48.56	0	95.36	0	46.8	
Minimum	0	0	92.3	0	35.4	
MinDate	08/01/2024 10:00	08/01/2024 00:00	08/01/2024 05:00	08/01/2024 00:00	08/01/2024 16:00	
Maximum	48.56	0.25	95.79	0.2	46.8	
MaxDate	09/01/2024 00:00	08/01/2024 15:00	08/01/2024 23:00	08/01/2024 03:00	09/01/2024 00:00	
Avg	27.74	0.01	93.7	0.1	40.9	
Num	25	25	21	21	21	
Data[%]	100	100	84	84	84	
STD	12.1	0.1	1.2	0.1	4.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
#REF!	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 07:00	0	0.18	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 09:00	0	0.02	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 10:00	0	0.12	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 11:00	0	0.16	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 12:00	8.16	0.54	ShutDown	ShutDown	ShutDown	GT11 S/D
09/01/2024 13:00	32.36	0.17	95.17	0	36.2	
09/01/2024 14:00	34.38	0.18	95.51	0	27.8	
09/01/2024 15:00	34.35	0.1	94.93	0	27.3	
09/01/2024 16:00	34.17	0.07	94.43	0	27.3	
09/01/2024 17:00	33.92	0.01	93.99	0	27.3	
09/01/2024 18:00	33.79	0	93.5	0	27.2	
09/01/2024 19:00	33.63	0	93.77	0	26.8	
09/01/2024 20:00	33.82	0	93.86	0	26.6	
09/01/2024 21:00	33.98	0	94.5	0	26.6	
09/01/2024 22:00	31.45	0.02	94.19	0	32.7	
09/01/2024 23:00	46.91	0	95.78	0	38.8	
10/01/2024 00:00	48.67	0	95.21	0	39	
Minimum	0	0	93.77	0	26.6	
MinDate	09/01/2024 00:00	09/01/2024 00:00	09/01/2024 19:00	09/01/2024 13:00	09/01/2024 20:00	
Maximum	48.67	0.54	95.78	0	39	
MaxDate	10/01/2024 00:00	09/01/2024 12:00	09/01/2024 23:00	09/01/2024 13:00	10/01/2024 00:00	
Avg	17.58	0.06	94.6	0	30.3	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.7	0	5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/01/2024 00:00	48.56	0	95.36	0	46.8	
09/01/2024 01:00	48.69	0	95.85	0.1	46.7	
09/01/2024 02:00	48.82	0	95.93	0.1	46.5	
09/01/2024 03:00	48.81	0	95.99	0.2	45.6	
09/01/2024 04:00	48.73	0	96.06	0.3	44.5	
09/01/2024 05:00	48.67	0	96.19	0.4	43.5	
09/01/2024 06:00	48.51	0	96.33	0.5	42.3	
09/01/2024 07:00	48.49	0	96.46	0.5	42.3	
09/01/2024 08:00	48.45	0	96.11	0.5	43.4	
09/01/2024 09:00	47.99	0	95.82	0.5	45.8	
09/01/2024 10:00	47.38	0	95.75	0.5	45.9	
09/01/2024 11:00	46.75	0	95.58	0.5	46.2	
09/01/2024 12:00	41.29	0	95.12	0.4	45.4	
09/01/2024 13:00	32.31	0	94.68	0.4	37.8	
09/01/2024 14:00	34.31	0	95.31	0.3	31.8	
09/01/2024 15:00	34.28	0.19	94.86	0.4	31.1	
09/01/2024 16:00	34.11	0	94.63	0.4	31.3	
09/01/2024 17:00	33.85	0	94.28	0.5	31.7	
09/01/2024 18:00	33.71	0	94.23	0.5	31.8	
09/01/2024 19:00	33.56	0	94.13	0.6	31.8	
09/01/2024 20:00	33.75	0	94.22	0.6	31.4	
09/01/2024 21:00	33.91	0	94.57	0.7	31.1	
09/01/2024 22:00	31.36	0	94.12	0.8	36	GT12 S/D
09/01/2024 23:00	2.02	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	94.12	0	31.1	
MinDate	10/01/2024 00:00	09/01/2024 00:00	09/01/2024 22:00	09/01/2024 00:00	09/01/2024 15:00	
Maximum	48.82	0.19	96.46	0.8	46.8	
MaxDate	09/01/2024 02:00	09/01/2024 15:00	09/01/2024 07:00	09/01/2024 22:00	09/01/2024 00:00	
Avg	38.33	0.01	95.29	0.4	39.7	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.3	0	0.8	0.2	6.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
10/01/2024 00:00	48.67	0	95.21	0	39	
10/01/2024 01:00	48.96	0	95.21	0	38.6	
10/01/2024 02:00	48.95	0	95.91	0	38	
10/01/2024 03:00	48.97	0	95.91	0	37.5	
10/01/2024 04:00	48.79	0	95.89	0	37.2	
10/01/2024 05:00	48.56	0	96.17	0	36.1	
10/01/2024 06:00	48.59	0	96.23	0	35.7	
10/01/2024 07:00	48.47	0.4	96.39	0	35.2	
10/01/2024 08:00	48.54	0	96.29	0	36.7	
10/01/2024 09:00	47.96	0.02	95.91	0	37.8	
10/01/2024 10:00	47.3	0.05	95.66	0	37.7	
10/01/2024 11:00	46.71	0.13	95.78	0	38	
10/01/2024 12:00	46.26	0.05	96.05	0	38.6	
10/01/2024 13:00	31.46	0.17	94.28	0	37.1	
10/01/2024 14:00	34.47	0.07	95.05	0	25.6	
10/01/2024 15:00	34.45	0.02	94.78	0	25.3	
10/01/2024 16:00	34.28	0	94.48	0	25.1	
10/01/2024 17:00	34.07	0	94.24	0	24.9	
10/01/2024 18:00	34.05	0	94.14	0	24.4	
10/01/2024 19:00	33.94	0	93.97	0	24.3	
10/01/2024 20:00	34	0	93.98	0	24.1	
10/01/2024 21:00	34.12	0	94.52	0	24	
10/01/2024 22:00	31.49	0.02	94.2	0	29.9	
10/01/2024 23:00	2.32	0.05	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	93.97	0	24	
MinDate	11/01/2024 00:00	10/01/2024 00:00	10/01/2024 19:00	10/01/2024 00:00	10/01/2024 21:00	
Maximum	48.97	0.4	96.39	0	39	
MaxDate	10/01/2024 03:00	10/01/2024 07:00	10/01/2024 07:00	10/01/2024 00:00	10/01/2024 00:00	
Avg	38.62	0.04	95.25	0	32.6	
Num	25	25	23	23	12	
Data[%]	100	100	92	92	92	
STD	13.3	0.1	0.9	0	6.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
10/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 12:00	1.49	0	ShutDown	ShutDown	ShutDown	GT12 S/D
10/01/2024 13:00	29.25	0	94.56	1	43.7	
10/01/2024 14:00	34.41	0	95.67	0.8	33.2	
10/01/2024 15:00	34.39	0.37	95.28	0.7	32.6	
10/01/2024 16:00	34.22	0	95.06	0.7	32.4	
10/01/2024 17:00	34	0	94.87	0.7	32.4	
10/01/2024 18:00	33.98	0	94.78	0.7	31.8	
10/01/2024 19:00	33.87	0	94.58	0.7	31.8	
10/01/2024 20:00	33.93	0	94.57	0.8	31.5	
10/01/2024 21:00	34.05	0	94.99	0.8	31.4	
10/01/2024 22:00	31.47	0	94.62	0.9	35.8	
10/01/2024 23:00	46.79	0	95.53	0.9	43.3	
11/01/2024 00:00	48.68	0	95.25	0.9	44.4	
Minimum	0	0	94.56	0.7	31.4	
MinDate	10/01/2024 00:00	10/01/2024 00:00	10/01/2024 13:00	10/01/2024 15:00	10/01/2024 21:00	
Maximum	48.68	0.37	96.53	1	44.4	
MaxDate	11/01/2024 00:00	10/01/2024 15:00	10/01/2024 23:00	10/01/2024 13:00	11/01/2024 00:00	
Avg	17.22	0.01	95.06	0.8	35.4	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.6	0.1	0.6	0.1	5.2	

Date & Time	11GT LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 07:00	0	0.3	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 10:00	0	0.06	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 11:00	0	0.06	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 12:00	8.04	0.47	ShutDown	ShutDown	ShutDown	GT11 S/D
11/01/2024 13:00	32.31	0.07	94.81	0	34.1	
11/01/2024 14:00	34.37	0.03	95.9	0	26.1	
11/01/2024 15:00	34.21	0.01	95.34	0	25.9	
11/01/2024 16:00	34.22	0	94.92	0	25.9	
11/01/2024 17:00	34.02	0	94.82	0	25.8	
11/01/2024 18:00	33.91	0	94.67	0	25.7	
11/01/2024 19:00	33.41	0	94.47	0	28.5	
11/01/2024 20:00	33.68	0	94.41	0	25.7	
11/01/2024 21:00	33.92	0	94.7	0	25.2	
11/01/2024 22:00	31.34	0	94.43	0	30.9	
11/01/2024 23:00	46.93	0	96.02	0	36.4	
12/01/2024 00:00	48.63	0	95.57	0	35.9	
Minimum	0	0	94.41	0	25.2	
MinDate	11/01/2024 00:00	11/01/2024 00:00	11/01/2024 20:00	11/01/2024 13:00	11/01/2024 21:00	
Maximum	48.63	0.47	96.02	0	36.4	
MaxDate	12/01/2024 00:00	11/01/2024 12:00	11/01/2024 23:00	11/01/2024 13:00	11/01/2024 23:00	
Avg	17.55	0.04	95.01	0	28.8	
Num	25	25	12	12	12	
Date[%]	100	100	48	48	48	
STD	18.5	0.1	0.6	0	4.3	

Date & Time	12GT LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/01/2024 00:00	48.68	0	95.25	0.9	44.4	
11/01/2024 01:00	48.74	0	95.41	0.9	44.4	
11/01/2024 02:00	48.82	0	95.77	1	43.7	
11/01/2024 03:00	48.83	0	95.87	1	43.4	
11/01/2024 04:00	48.78	0	95.92	1.1	42.8	
11/01/2024 05:00	48.59	0	96.09	1.1	41.5	
11/01/2024 06:00	48.52	0	96.09	1.1	40.9	
11/01/2024 07:00	48.49	0	96.24	1.1	40.3	
11/01/2024 08:00	48.58	0	96.09	1.1	42.1	
11/01/2024 09:00	48.13	0	95.79	1	43.2	
11/01/2024 10:00	47.73	0	95.62	1	43.4	
11/01/2024 11:00	47.37	0	95.88	0.9	43.8	
11/01/2024 12:00	41.51	0	95.43	0.9	43.2	
11/01/2024 13:00	32.24	0	94.64	0.9	36.3	
11/01/2024 14:00	34.31	0	95.41	0.8	30.4	
11/01/2024 15:00	34.15	0.32	95.14	0.8	30.2	
11/01/2024 16:00	34.15	0	94.85	0.8	30.3	
11/01/2024 17:00	33.95	0	94.79	0.8	30.3	
11/01/2024 18:00	33.84	0	94.71	0.8	30.4	
11/01/2024 19:00	33.35	0	94.51	0.8	34.5	
11/01/2024 20:00	33.62	0	94.47	0.9	31.5	
11/01/2024 21:00	33.86	0	94.58	0.9	30.4	
11/01/2024 22:00	31.25	0	94.13	1	34.6	
11/01/2024 23:00	2.07	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	94.13	0.8	30.2	
MinDate	12/01/2024 00:00	11/01/2024 00:00	11/01/2024 22:00	11/01/2024 14:00	11/01/2024 15:00	
Maximum	48.83	0.32	96.24	1.1	44.4	
MaxDate	11/01/2024 03:00	11/01/2024 15:00	11/01/2024 07:00	11/01/2024 04:00	11/01/2024 00:00	
Avg	38.38	0.01	95.33	0.9	38.1	
Num	25	25	23	23	23	
Date[%]	100	100	92	92	92	
STD	13.3	0.1	0.6	0.1	5.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/01/2024 00:00	48.63	0	95.57	0	35.9	
12/01/2024 01:00	48.84	0	95.95	0	36.1	
12/01/2024 02:00	48.82	0	96.07	0	35.8	
12/01/2024 03:00	48.78	0	96.17	0	35.4	
12/01/2024 04:00	48.75	0	96.16	0	35.1	
12/01/2024 05:00	48.58	0	96.32	0	34.2	
12/01/2024 06:00	48.6	0	96.35	0	34.2	
12/01/2024 07:00	48.55	0.24	96.51	0	33.8	
12/01/2024 08:00	48.6	0	96.39	0	35	
12/01/2024 09:00	48.26	0	95.86	0	35.9	
12/01/2024 10:00	47.75	0	95.87	0	36.3	
12/01/2024 11:00	47.2	0	95.89	0	36.8	
12/01/2024 12:00	42.33	0.01	96.49	0	37.9	
12/01/2024 13:00	32.24	0.02	94.25	0	32.5	
12/01/2024 14:00	34.36	0	95.04	0	23.9	
12/01/2024 15:00	34.31	0	94.49	0	23.8	
12/01/2024 16:00	34.26	0	94.33	0	23.8	
12/01/2024 17:00	34.11	0	94.16	0	23.7	
12/01/2024 18:00	34.04	0	94.15	0	23.3	
12/01/2024 19:00	33.8	0	94.04	0	23.2	
12/01/2024 20:00	33.88	0	93.9	0	23.3	
12/01/2024 21:00	34.06	0	94.34	0	23.3	
12/01/2024 22:00	33.68	0	95.19	0	29.5	
12/01/2024 23:00	24.35	0	92.29	0	45.2	
13/01/2024 00:00	26.63	0	92.78	0	44.1	
Minimum	24.35	0	92.29	0	23.2	
MinDate	12/01/2024 23:00	12/01/2024 00:00	12/01/2024 23:00	12/01/2024 00:00	12/01/2024 19:00	
Maximum	48.84	0.24	96.51	0	45.2	
MaxDate	12/01/2024 01:00	12/01/2024 07:00	12/01/2024 07:00	12/01/2024 00:00	12/01/2024 23:00	
Avg	40.54	0.01	95.15	0	32.1	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	8.3	0	1.2	0	6.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 12:00	7.09	0	ShutDown	ShutDown	ShutDown	GT12 S/D
12/01/2024 13:00	32.18	0	95	1.1	38.2	
12/01/2024 14:00	34.3	0	95.44	1	32.1	
12/01/2024 15:00	34.24	0.25	95.12	0.9	31.9	
12/01/2024 16:00	34.2	0	95.01	0.9	31.9	
12/01/2024 17:00	34.05	0	94.86	0.9	31.7	
12/01/2024 18:00	33.97	0	94.92	0.9	31.3	
12/01/2024 19:00	33.73	0	94.8	0.9	31.4	
12/01/2024 20:00	33.82	0	94.73	0.9	31.6	
12/01/2024 21:00	33.99	0	94.93	1	31.5	
12/01/2024 22:00	33.62	0	95.94	1	35.1	
12/01/2024 23:00	24.29	0	92.67	1.1	46.4	
13/01/2024 00:00	26.58	0	92.67	1.1	43.9	
Minimum	0	0	92.67	0.9	31.3	
MinDate	12/01/2024 00:00	12/01/2024 00:00	12/01/2024 23:00	12/01/2024 15:00	12/01/2024 18:00	
Maximum	34.3	0.25	95.94	1.1	46.4	
MaxDate	12/01/2024 14:00	12/01/2024 15:00	12/01/2024 22:00	12/01/2024 13:00	12/01/2024 23:00	
Avg	15.84	0.01	94.64	1	34.8	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	16.5	0.1	1	0.1	5.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
13/01/2024 00:00	26.63	0	92.78	0	44.1	
13/01/2024 01:00	28.82	0	93.33	0	41.7	
13/01/2024 02:00	31.17	0	93.81	0	34	
13/01/2024 03:00	31.44	0	93.79	0	33.3	
13/01/2024 04:00	31.76	0	93.91	0	32.1	
13/01/2024 05:00	31.73	0	93.89	0	32.2	
13/01/2024 06:00	31.66	0	93.74	0	32.6	
13/01/2024 07:00	31.59	0.18	93.73	0	33	
13/01/2024 08:00	31.53	0	94.12	0	32.8	
13/01/2024 09:00	31.78	0	94.42	0	31.4	
13/01/2024 10:00	31.85	0	94.09	0	29.6	
13/01/2024 11:00	31.81	0	94.15	0	28.5	
13/01/2024 12:00	31.69	0	94.19	0	28.2	
13/01/2024 13:00	41.83	0	98.38	0	30.9	
13/01/2024 14:00	45.49	0	101.75	0	32.1	
13/01/2024 15:00	45.68	0	101.88	0	29	
13/01/2024 16:00	45.9	0	101.76	0	26.9	
13/01/2024 17:00	45.58	0	101.26	0	26.9	
13/01/2024 18:00	45.48	0	101.75	0	26.8	
13/01/2024 19:00	45.35	0	101.87	0	26.5	
13/01/2024 20:00	45.53	0	101.98	0	26.2	
13/01/2024 21:00	45.74	0	102.59	0	26.2	
13/01/2024 22:00	42.2	0	101.63	0	28.2	
13/01/2024 23:00	31.66	0	94.4	0	31.6	
14/01/2024 00:00	31.4	0	93.52	0	32.7	
Minimum	26.63	0	92.78	0	26.2	
MinDate	13/01/2024 00:00	13/01/2024 00:00	13/01/2024 00:00	13/01/2024 00:00	13/01/2024 20:00	
Maximum	45.9	0.18	102.59	0	44.1	
MaxDate	13/01/2024 16:00	13/01/2024 07:00	13/01/2024 21:00	13/01/2024 00:00	13/01/2024 00:00	
Avg	36.61	0.01	96.91	0	31.1	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7	0	3.9	0	4.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
13/01/2024 00:00	26.58	0	92.67	1.1	43.9	
13/01/2024 01:00	28.77	0	93.28	1.1	42.2	
13/01/2024 02:00	31.11	0	93.68	1.1	43	
13/01/2024 03:00	31.37	0	93.59	1.2	43	
13/01/2024 04:00	31.7	0	93.7	1.2	42.8	
13/01/2024 05:00	31.67	0	93.72	1.2	42.6	
13/01/2024 06:00	31.61	0	93.53	1.2	42.9	
13/01/2024 07:00	31.52	0	93.58	1.2	42.9	
13/01/2024 08:00	31.47	0	93.95	1.2	42.6	
13/01/2024 09:00	31.72	0	94.2	1.1	44	
13/01/2024 10:00	31.78	0	93.88	1.1	44.9	
13/01/2024 11:00	31.75	0	93.87	1	43.9	
13/01/2024 12:00	31.63	0	93.88	1	44	
13/01/2024 13:00	41.74	0	98.16	1	42.1	
13/01/2024 14:00	45.41	0	101.31	0.9	42.2	
13/01/2024 15:00	45.61	0.19	101.71	0.9	37.3	
13/01/2024 16:00	45.82	0	101.83	0.9	34	
13/01/2024 17:00	45.5	0	101.21	1	33.6	
13/01/2024 18:00	45.41	0	101.61	1.1	33.6	
13/01/2024 19:00	45.27	0	101.72	1.1	33.2	
13/01/2024 20:00	45.45	0	101.82	1.1	33	
13/01/2024 21:00	45.66	0	102.24	1.1	33	
13/01/2024 22:00	42.13	0	101.14	1.2	34.3	
13/01/2024 23:00	31.6	0	93.96	1.1	42.6	
14/01/2024 00:00	31.34	0	93.08	1.2	42.4	
Minimum	26.58	0	92.67	0.9	33	
MinDate	13/01/2024 00:00	13/01/2024 00:00	13/01/2024 00:00	13/01/2024 14:00	13/01/2024 20:00	
Maximum	45.82	0.19	102.24	1.2	44.9	
MaxDate	13/01/2024 16:00	13/01/2024 15:00	13/01/2024 21:00	13/01/2024 03:00	13/01/2024 00:00	
Avg	36.54	0.01	96.68	1.1	40.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7	0	3.9	0.1	4.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
14/01/2024 00:00	31.4	0	93.52	0	32.7	
14/01/2024 01:00	31.46	0	93.46	0	33.1	
14/01/2024 02:00	31.51	0	93.45	0	32.6	
14/01/2024 03:00	31.21	0	93.38	0	33.8	
14/01/2024 04:00	30.92	0	93.29	0	34.9	
14/01/2024 05:00	30.75	0	93.19	0	35.6	
14/01/2024 06:00	30.51	0	93.06	0	36.4	
14/01/2024 07:00	30.28	0.36	93.1	0	37.6	
14/01/2024 08:00	30.29	0	93.46	0	36.8	
14/01/2024 09:00	30.28	0	92.84	0	35.7	
14/01/2024 10:00	30.24	0	93.03	0	35.8	
14/01/2024 11:00	30.27	0	93.29	0	35.1	
14/01/2024 12:00	30.33	0	93.46	0	34.4	
14/01/2024 13:00	30.27	0	93.43	0	34.1	
14/01/2024 14:00	30.32	0	93.43	0	33.2	
14/01/2024 15:00	30.31	0	92.91	0	32.3	
14/01/2024 16:00	30.3	0	92.72	0	32.9	
14/01/2024 17:00	33.77	0	93.38	0	33.1	
14/01/2024 18:00	44.27	0	100.29	0	24.9	
14/01/2024 19:00	44.51	0	101.23	0	25.1	
14/01/2024 20:00	44.63	0	101.29	0	25.2	
14/01/2024 21:00	34.08	0	97.04	0	31.9	
14/01/2024 22:00	30.53	0	93.18	0	34.1	
14/01/2024 23:00	30.52	0	92.88	0	34.7	
15/01/2024 00:00	30.51	0	92.75	0	35	
Minimum	30.24	0	92.72	0	24.9	
MinDate	14/01/2024 10:00	14/01/2024 00:00	14/01/2024 16:00	14/01/2024 00:00	14/01/2024 18:00	
Maximum	44.63	0.36	101.29	0	37.6	
MaxDate	14/01/2024 20:00	14/01/2024 07:00	14/01/2024 20:00	14/01/2024 00:00	14/01/2024 07:00	
Avg	32.94	0.01	94.28	0	33.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0.1	2.6	0	3.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
14/01/2024 00:00	31.34	0	93.08	1.2	42.4	
14/01/2024 01:00	31.4	0	93.04	1.2	43	
14/01/2024 02:00	31.45	0	93.06	1.2	42.5	
14/01/2024 03:00	31.15	0	92.98	1.3	42.2	
14/01/2024 04:00	30.85	0	92.9	1.3	42.1	
14/01/2024 05:00	30.69	0	92.76	1.3	42.1	
14/01/2024 06:00	30.45	0	92.66	1.3	42.3	
14/01/2024 07:00	30.22	0	92.65	1.3	42.6	
14/01/2024 08:00	30.22	0	92.96	1.2	42.1	
14/01/2024 09:00	30.23	0	92.66	1.2	42.5	
14/01/2024 10:00	30.18	0	92.79	1.2	44.3	
14/01/2024 11:00	30.21	0	92.93	1.1	45.7	
14/01/2024 12:00	30.28	0	93.02	1.1	45.7	
14/01/2024 13:00	30.21	0	93.09	1	46	
14/01/2024 14:00	30.26	0	93.1	0.9	46.2	
14/01/2024 15:00	30.25	0.37	92.62	0.9	45.8	
14/01/2024 16:00	30.24	0	92.42	0.8	46	
14/01/2024 17:00	33.7	0	93.34	0.8	45.1	
14/01/2024 18:00	44.19	0	100.14	0.8	31.4	
14/01/2024 19:00	44.43	0	101	0.8	31.3	
14/01/2024 20:00	44.55	0	101.1	0.9	31.4	
14/01/2024 21:00	34	0	96.6	1	38.4	
14/01/2024 22:00	30.47	0	93.18	1.1	41.5	
14/01/2024 23:00	30.45	0	92.91	1.1	41.7	
15/01/2024 00:00	30.45	0	92.9	1.1	42	
Minimum	30.18	0	92.42	0.8	31.3	
MinDate	14/01/2024 10:00	14/01/2024 00:00	14/01/2024 16:00	14/01/2024 16:00	14/01/2024 19:00	
Maximum	44.55	0.37	101.1	1.3	46.2	
MaxDate	14/01/2024 20:00	14/01/2024 15:00	14/01/2024 20:00	14/01/2024 03:00	14/01/2024 14:00	
Avg	32.47	0.01	94	1.1	41.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0.1	2.7	0.2	4.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
15/01/2024 00:00	30.51	0	92.75	0	35	
15/01/2024 01:00	30.51	0	92.83	0	34.9	
15/01/2024 02:00	30.55	0	92.9	0	34.8	
15/01/2024 03:00	30.47	0	92.72	0	36.2	
15/01/2024 04:00	30.48	0	92.2	0	36.9	
15/01/2024 05:00	30.46	0	91.97	0	36.9	
15/01/2024 06:00	30.48	0	91.77	0	37.5	
15/01/2024 07:00	30.67	0.3	91.78	0	36.9	
15/01/2024 08:00	29	0	91.83	0	37.9	
15/01/2024 09:00	22.28	0	<Samp	<Samp		CEMS Error
15/01/2024 10:00	22.6	0	90.35	0	51.3	
15/01/2024 11:00	22.6	0	90.69	0	50.7	
15/01/2024 12:00	22.61	0	90.94	0	51.2	
15/01/2024 13:00	31.43	0	93.05	0	30.9	
15/01/2024 14:00	34.14	0	94.49	0	21.7	
15/01/2024 15:00	34.16	0	94.45	0	21.8	
15/01/2024 16:00	34.05	0	94.12	0	21.9	
15/01/2024 17:00	33.91	0	93.77	0	21.8	
15/01/2024 18:00	33.84	0	93.56	0	21.3	
15/01/2024 19:00	33.69	0	93.62	0	20.8	
15/01/2024 20:00	33.75	0	93.73	0	20.8	
15/01/2024 21:00	33.96	0	94.21	0	20.6	
15/01/2024 22:00	31.13	0	93.85	0	28	
15/01/2024 23:00	2.23	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	90.35	0	20.6	
MinDate	16/01/2024 00:00	15/01/2024 00:00	15/01/2024 10:00	15/01/2024 00:00	15/01/2024 21:00	
Maximum	34.16	0.3	94.49	0	51.3	
MaxDate	15/01/2024 15:00	15/01/2024 07:00	15/01/2024 14:00	15/01/2024 00:00	15/01/2024 10:00	
Avg	27.98	0.01	92.8	0	32.3	
Num	25	25	22	22	20	
Data[%]	100	100	88	88	88	
STD	9	0.1	1.2	0	10.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
15/01/2024 00:00	30.45	0	92.9	1.1	42	
15/01/2024 01:00	30.45	0	92.94	1.1	41.5	
15/01/2024 02:00	30.49	0	92.87	1.2	41.4	
15/01/2024 03:00	30.4	0	92.73	1.2	43.7	
15/01/2024 04:00	30.41	0	92.22	1.2	44.7	
15/01/2024 05:00	30.4	0	91.97	1.2	45.1	
15/01/2024 06:00	30.42	0	91.85	1.1	45.5	
15/01/2024 07:00	30.61	0	91.74	1.1	45.7	
15/01/2024 08:00	28.94	0	91.23	1.1	47.9	
15/01/2024 09:00	18.72	0	Maintenance	Maintenance	Maintenance	CEMS Error
15/01/2024 10:00	18.44	0	Maintenance	Maintenance	Maintenance	CEMS Error
15/01/2024 11:00	18.49	0	Maintenance	Maintenance	Maintenance	CEMS Error
15/01/2024 12:00	18.63	0	Maintenance	Maintenance	Maintenance	CEMS Error
15/01/2024 13:00	30.18	0	<Samp	<Samp	<Samp	CEMS Error
15/01/2024 14:00	34.07	0	94.33	0.4	29.7	
15/01/2024 15:00	34.09	0.3	94.33	0.3	29.6	
15/01/2024 16:00	33.98	0	94.08	0.1	29.6	
15/01/2024 17:00	33.85	0	93.79	0	29.5	
15/01/2024 18:00	33.78	0	93.71	0	28.7	
15/01/2024 19:00	33.62	0	93.67	0	28.5	
15/01/2024 20:00	33.69	0	93.73	0.2	29.1	
15/01/2024 21:00	33.9	0	94.09	0.4	27.8	
15/01/2024 22:00	31.12	0	93.68	0.6	33.3	
15/01/2024 23:00	46.92	0	95.99	0.7	37.2	
16/01/2024 00:00	48.68	0	95.74	0.8	37.4	
Minimum	18.44	0	91.23	0	27.8	
MinDate	15/01/2024 10:00	15/01/2024 00:00	15/01/2024 08:00	15/01/2024 17:00	15/01/2024 21:00	
Maximum	48.68	0.3	95.99	1.2	47.9	
MaxDate	16/01/2024 00:00	15/01/2024 15:00	15/01/2024 23:00	15/01/2024 02:00	15/01/2024 08:00	
Avg	30.99	0.01	93.38	0.7	36.9	
Num	25	25	20	20	20	
Data[%]	100	100	80	80	80	
STD	7.2	0.1	1.3	0.5	7.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 07:00	0	0.24	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 12:00	7.97	0.34	ShutDown	ShutDown	ShutDown	GT11 S/D
16/01/2024 13:00	32.17	0.06	94.19	0	36.7	
16/01/2024 14:00	34.17	0.11	95.37	0	29.2	
16/01/2024 15:00	34.22	0.04	95.04	0	29.1	
16/01/2024 16:00	34.13	0.01	94.73	0	28.8	
16/01/2024 17:00	33.92	0	94.13	0	28.5	
16/01/2024 18:00	33.94	0.01	94.12	0	27.9	
16/01/2024 19:00	33.74	0.01	94	0	27.1	
16/01/2024 20:00	33.81	0	94.01	0	27.1	
16/01/2024 21:00	34.01	0	94.18	0	26.8	
16/01/2024 22:00	31.22	0	93.77	0	33.7	
16/01/2024 23:00	47.23	0	95.77	0	39.1	
17/01/2024 00:00	48.89	0	95.73	0	39.5	
Minimum	0	0	93.77	0	26.8	
MinDate	16/01/2024 00:00	16/01/2024 00:00	16/01/2024 22:00	16/01/2024 13:00	16/01/2024 21:00	
Maximum	48.89	0.34	95.77	0	39.5	
MaxDate	17/01/2024 00:00	16/01/2024 12:00	16/01/2024 23:00	16/01/2024 13:00	17/01/2024 00:00	
Avg	17.58	0.03	94.59	0	31.1	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.7	0	4.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/01/2024 00:00	48.68	0	95.74	0.8	37.4	
16/01/2024 01:00	48.86	0	95.98	0.9	36.7	
16/01/2024 02:00	48.85	0	95.94	0.9	37.7	
16/01/2024 03:00	48.75	0	96.1	1	38.2	
16/01/2024 04:00	48.58	0	96.12	1	37.3	
16/01/2024 05:00	48.41	0	96.22	1	37	
16/01/2024 06:00	48.27	0	96.05	1	36.6	
16/01/2024 07:00	48.32	0	96.06	0.9	37.1	
16/01/2024 08:00	48.46	0	95.68	0.8	40	
16/01/2024 09:00	48.26	0	95.19	0.7	40.7	
16/01/2024 10:00	47.82	0	95.28	0.5	40.1	
16/01/2024 11:00	47.18	0	95.29	0.3	39.7	
16/01/2024 12:00	41.39	0	94.83	0.2	39.7	
16/01/2024 13:00	32.06	0	93.87	0	33.9	
16/01/2024 14:00	34.11	0	94.67	0	27.9	
16/01/2024 15:00	34.16	0.23	94.49	0	27.8	
16/01/2024 16:00	34.06	0	94.23	0	27.4	
16/01/2024 17:00	33.85	0	93.71	0	27.3	
16/01/2024 18:00	33.87	0	93.75	0	26.8	
16/01/2024 19:00	33.67	0	93.64	0	26.2	
16/01/2024 20:00	33.75	0	93.73	0	26.3	
16/01/2024 21:00	33.95	0	93.76	0	26.1	
16/01/2024 22:00	31.06	0	93.32	0	32.4	
16/01/2024 23:00	1.68	0	ShutDown	ShutDown	ShutDown	GT12 S/D
17/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.32	0	26.1	
MinDate	17/01/2024 00:00	16/01/2024 00:00	16/01/2024 22:00	16/01/2024 13:00	16/01/2024 21:00	
Maximum	48.86	0.23	96.22	1	40.7	
MaxDate	16/01/2024 01:00	16/01/2024 15:00	16/01/2024 05:00	16/01/2024 03:00	16/01/2024 09:00	
Avg	38.32	0.01	94.94	0.4	33.9	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.4	0	1	0.4	5.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/01/2024 00:00	48.89	0	95.73	0	39.5	
17/01/2024 01:00	48.88	0	96.17	0	39.9	
17/01/2024 02:00	48.9	0	96.47	0	40.1	
17/01/2024 03:00	48.8	0	96.34	0	40.3	
17/01/2024 04:00	48.9	0	96.51	0	39.3	
17/01/2024 05:00	48.63	0	96.03	0	37.2	
17/01/2024 06:00	48.5	0	95.11	0	37.6	
17/01/2024 07:00	48.37	0.18	94.93	0	37.5	
17/01/2024 08:00	48.57	0	94.7	0	39	
17/01/2024 09:00	48.4	0	94.24	0	39.3	
17/01/2024 10:00	47.82	0	94.24	0	39	
17/01/2024 11:00	47.28	0	94.57	0	38.9	
17/01/2024 12:00	42.32	0	95.74	0	39.3	
17/01/2024 13:00	32.33	0.06	94.41	0	35.4	
17/01/2024 14:00	34.3	0.19	95.38	0	26.9	
17/01/2024 15:00	34.34	0.11	94.72	0	26.3	
17/01/2024 16:00	34.09	0.05	94.38	0	26.1	
17/01/2024 17:00	33.91	0.01	94	0	25.9	
17/01/2024 18:00	33.78	0	93.81	0	25.4	
17/01/2024 19:00	33.59	0	93.65	0	25.2	
17/01/2024 20:00	33.77	0	93.74	0	25.1	
17/01/2024 21:00	33.89	0	94.14	0	24.9	
17/01/2024 22:00	31.3	0.01	93.92	0	31.5	
17/01/2024 23:00	2.25	0.06	ShutDown	ShutDown	ShutDown	GT11 SD
18/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	0	0	93.65	0	24.9	
MinDate	18/01/2024 00:00	17/01/2024 00:00	17/01/2024 19:00	17/01/2024 00:00	17/01/2024 21:00	
Maximum	48.9	0.19	96.51	0	40.3	
MaxDate	17/01/2024 02:00	17/01/2024 14:00	17/01/2024 04:00	17/01/2024 00:00	17/01/2024 03:00	
Avg	38.47	0.03	94.91	0	33.9	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.3	0.1	0.9	0	6.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 12:00	7.3	0	ShutDown	ShutDown	ShutDown	GT12 SD
17/01/2024 13:00	32.21	0	94.72	0	42.1	
17/01/2024 14:00	34.24	0	95.55	0	36.9	
17/01/2024 15:00	34.28	0.17	95.01	0	35.6	
17/01/2024 16:00	34.04	0	94.59	0	35.5	
17/01/2024 17:00	33.85	0	94.06	0	35.4	
17/01/2024 18:00	33.71	0	93.92	0	34.7	
17/01/2024 19:00	33.53	0	93.75	0	35.3	
17/01/2024 20:00	33.7	0	93.93	0	34.8	
17/01/2024 21:00	33.83	0	94.2	0.1	34.4	
17/01/2024 22:00	31.28	0	93.67	0.3	38.7	
17/01/2024 23:00	46.82	0	96.08	0.4	44.4	
18/01/2024 00:00	48.63	0	95.85	0.5	44.5	
Minimum	0	0	93.75	0	34.4	
MinDate	17/01/2024 00:00	17/01/2024 00:00	17/01/2024 19:00	17/01/2024 13:00	17/01/2024 21:00	
Maximum	48.63	0.17	96.08	0.5	44.5	
MaxDate	18/01/2024 00:00	17/01/2024 15:00	17/01/2024 23:00	18/01/2024 00:00	18/01/2024 00:00	
Avg	17.5	0.01	94.63	0.1	37.7	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.4	0	0.8	0.2	3.8	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG SO2@7%O2	11HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 07:00	0	0.35	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 12:00	8.14	0.36	ShutDown	ShutDown	ShutDown	GT11 S/D
18/01/2024 13:00	32.18	0.08	94.29	0	37.5	
18/01/2024 14:00	34.22	0.07	95.34	0	29.1	
18/01/2024 15:00	34.23	0.01	94.74	0	29	
18/01/2024 16:00	34.12	0.01	94.41	0	28.5	
18/01/2024 17:00	34.04	0.01	93.98	0	27.2	
18/01/2024 18:00	34.03	0.01	94	0	26.7	
18/01/2024 19:00	33.72	0	93.88	0	26.8	
18/01/2024 20:00	33.8	0	94.02	0	26.6	
18/01/2024 21:00	34	0	94.64	0	26.4	
18/01/2024 22:00	31.39	0.02	94.29	0	32.6	
18/01/2024 23:00	46.98	0	95.92	0	38.2	
19/01/2024 00:00	48.69	0	95.34	0	38.6	
Minimum	0	0	93.88	0	26.4	
MinDate	18/01/2024 00:00	18/01/2024 00:00	18/01/2024 19:00	18/01/2024 13:00	18/01/2024 21:00	
Maximum	48.69	0.36	95.92	0	38.6	
MaxDate	19/01/2024 00:00	18/01/2024 12:00	18/01/2024 23:00	18/01/2024 13:00	19/01/2024 00:00	
Avg	17.58	0.04	94.57	0	30.6	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.7	0	4.8	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG SO2@7%O2	12HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/01/2024 00:00	48.63	0	95.85	0.5	44.5	
18/01/2024 01:00	48.65	0	96.13	0.6	44.4	
18/01/2024 02:00	48.63	0	96.44	0.7	43.7	
18/01/2024 03:00	48.66	0	96.37	0.7	43.4	
18/01/2024 04:00	48.59	0	96.36	0.8	43	
18/01/2024 05:00	48.53	0	96.5	0.8	42.6	
18/01/2024 06:00	48.44	0	96.67	0.9	42.3	
18/01/2024 07:00	48.28	0	96.88	0.9	41.6	
18/01/2024 08:00	48.37	0	96.65	0.8	43.3	
18/01/2024 09:00	47.66	0	95.53	0.8	47.8	
18/01/2024 10:00	47.24	0	95.29	0.6	47.5	
18/01/2024 11:00	46.78	0	95.49	0.5	47.4	
18/01/2024 12:00	41.04	0	94.79	0.3	47.5	
18/01/2024 13:00	32.11	0	94	0.1	40.9	
18/01/2024 14:00	34.16	0	94.65	0	34.9	
18/01/2024 15:00	34.17	0.36	94.3	0	34.8	
18/01/2024 16:00	34.05	0	94.03	0	34.1	
18/01/2024 17:00	33.98	0	93.73	0	32.5	
18/01/2024 18:00	33.96	0	93.81	0	32	
18/01/2024 19:00	33.65	0	93.69	0	32.6	
18/01/2024 20:00	33.73	0	93.81	0	32.4	
18/01/2024 21:00	33.93	0	93.99	0.1	31.9	
18/01/2024 22:00	31.31	0	93.5	0.3	36.4	
18/01/2024 23:00	2.01	0	ShutDown	ShutDown	ShutDown	GT12 SD
19/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
Minimum	0	0	93.5	0	31.9	
MinDate	19/01/2024 00:00	18/01/2024 00:00	18/01/2024 22:00	18/01/2024 14:00	18/01/2024 21:00	
Maximum	48.66	0.36	96.88	0.9	47.8	
MaxDate	18/01/2024 03:00	18/01/2024 15:00	18/01/2024 07:00	18/01/2024 06:00	18/01/2024 09:00	
Avg	38.26	0.01	95.15	0.4	40.2	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.2	0.1	1.2	0.4	5.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/01/2024 00:00	48.69	0	95.34	0	38.6	
19/01/2024 01:00	48.85	0	95.9	0	38.7	
19/01/2024 02:00	48.85	0	96.01	0	38.5	
19/01/2024 03:00	48.79	0	96.05	0	38.1	
19/01/2024 04:00	48.75	0	96.11	0	37.7	
19/01/2024 05:00	48.55	0	96.27	0	36.8	
19/01/2024 06:00	48.47	0	96.3	0	36.7	
19/01/2024 07:00	48.41	0.29	96.52	0	36.4	
19/01/2024 08:00	48.4	0	96.47	0	37.7	
19/01/2024 09:00	47.41	0	95.63	0	39.1	
19/01/2024 10:00	46.8	0	95.26	0	39.1	
19/01/2024 11:00	46.41	0	95.34	0	39.2	
19/01/2024 12:00	41.99	0.01	96.01	0	40.7	
19/01/2024 13:00	32.23	0.03	94.22	0	36.5	
19/01/2024 14:00	34.16	0.02	94.87	0	26.2	
19/01/2024 15:00	34.21	0.02	94.49	0	26	
19/01/2024 16:00	34.1	0	94.02	0	25.7	
19/01/2024 17:00	33.92	0	93.68	0	25.5	
19/01/2024 18:00	33.77	0	93.59	0	25.1	
19/01/2024 19:00	33.57	0	93.58	0	25	
19/01/2024 20:00	33.8	0	93.71	0	24.8	
19/01/2024 21:00	33.94	0	94.04	0	25	
19/01/2024 22:00	33.53	0	94.75	0	31	
19/01/2024 23:00	24.1	0	91.66	0	49.6	
20/01/2024 00:00	24.49	0	91.18	0	48.6	
Minimum	24.1	0	91.18	0	24.8	
MinDate	19/01/2024 23:00	19/01/2024 00:00	20/01/2024 00:00	19/01/2024 00:00	19/01/2024 20:00	
Maximum	48.85	0.29	96.52	0	49.6	
MaxDate	19/01/2024 01:00	19/01/2024 07:00	19/01/2024 07:00	19/01/2024 00:00	19/01/2024 23:00	
Avg	40.25	0.01	94.84	0	34.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	8.4	0.1	1.4	0	7.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 12:00	7.04	0	ShutDown	ShutDown	ShutDown	GT12 S/D
19/01/2024 13:00	32.16	0	94.93	0	44.4	
19/01/2024 14:00	34.09	0	95.28	0	36.4	
19/01/2024 15:00	34.15	0.3	94.93	0	35.8	
19/01/2024 16:00	34.04	0	94.6	0	35.2	
19/01/2024 17:00	33.85	0	94.27	0	35.2	
19/01/2024 18:00	33.71	0	94.23	0	34.7	
19/01/2024 19:00	33.5	0	94.17	0	34.7	
19/01/2024 20:00	33.74	0	94.25	0	34.5	
19/01/2024 21:00	33.87	0	94.46	0.1	34.7	
19/01/2024 22:00	33.48	0	95.09	0.2	38	
19/01/2024 23:00	24.04	0	92.18	0.4	51.7	
20/01/2024 00:00	24.42	1.15	91.5	0.5	51	
Minimum	0	0	91.5	0	34.5	
MinDate	19/01/2024 00:00	19/01/2024 00:00	20/01/2024 00:00	19/01/2024 13:00	19/01/2024 20:00	
Maximum	34.15	1.15	95.28	0.5	51.7	
MaxDate	19/01/2024 15:00	20/01/2024 00:00	19/01/2024 14:00	20/01/2024 00:00	19/01/2024 23:00	
Avg	15.68	0.06	94.16	0.1	38.9	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	16.3	0.2	1.2	0.2	6.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/01/2024 00:00	24.49	0	91.18	0	48.6	
20/01/2024 01:00	27.31	0	91.87	0	46.7	
20/01/2024 02:00	29.46	0	92.74	0	42.4	
20/01/2024 03:00	30.92	0	93.05	0	37.1	
20/01/2024 04:00	31.4	0	93.3	0	34.9	
20/01/2024 05:00	31.46	0	93.33	0	34.7	
20/01/2024 06:00	31.38	0	93.4	0.1	35.1	
20/01/2024 07:00	31.24	0.23	93.55	0.1	35.3	
20/01/2024 08:00	31.15	0	93.64	0.1	35.5	
20/01/2024 09:00	31.36	0	93.88	0.1	33.5	
20/01/2024 10:00	31.36	0	94.08	0	32.7	
20/01/2024 11:00	31.35	0.03	94.08	0.1	31.9	
20/01/2024 12:00	31.2	0.04	93.99	0	31.9	
20/01/2024 13:00	41.51	0.04	98.05	0	31.4	
20/01/2024 14:00	45.25	0	101.78	0	29.7	
20/01/2024 15:00	45.3	0	101.59	0	28.8	
20/01/2024 16:00	45.34	0	101.62	0	28.5	
20/01/2024 17:00	45.27	0	101.7	0	28.1	
20/01/2024 18:00	45.23	0	101.64	0	27.6	
20/01/2024 19:00	45.21	0	101.59	0	27.4	
20/01/2024 20:00	45.25	0	101.57	0	27	
20/01/2024 21:00	45.23	0	101.88	0	26.8	
20/01/2024 22:00	41.64	0	100.76	0	29.2	
20/01/2024 23:00	31.27	0	93.52	0	33.7	
21/01/2024 00:00	31.19	0	92.72	0	33.8	
Minimum	24.49	0	91.18	0	26.8	
MinDate	20/01/2024 00:00	20/01/2024 00:00	20/01/2024 00:00	20/01/2024 00:00	20/01/2024 21:00	
Maximum	45.34	0.23	101.88	0.1	48.6	
MaxDate	20/01/2024 16:00	20/01/2024 07:00	20/01/2024 21:00	20/01/2024 06:00	20/01/2024 00:00	
Avg	36.07	0.01	96.42	0	33.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0	4.1	0	5.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/01/2024 00:00	24.42	1.15	91.5	0.5	51	
20/01/2024 01:00	27.25	0.04	92.11	0.6	46.5	
20/01/2024 02:00	29.4	0.08	93	0.7	45.3	
20/01/2024 03:00	30.86	0.08	93.29	0.8	45.4	
20/01/2024 04:00	31.33	0.08	93.48	0.8	44.7	
20/01/2024 05:00	31.39	0.08	93.54	0.9	44.5	
20/01/2024 06:00	31.32	0.08	93.57	0.9	44.6	
20/01/2024 07:00	31.18	0.08	93.75	0.9	44.3	
20/01/2024 08:00	31.09	0.08	93.85	0.9	44.6	
20/01/2024 09:00	31.3	0.08	94.11	0.9	44.9	
20/01/2024 10:00	31.3	0.08	94.26	0.8	46.8	
20/01/2024 11:00	31.29	0.08	94.24	0.8	48.2	
20/01/2024 12:00	31.14	0.03	94.12	0.7	49.8	
20/01/2024 13:00	41.45	0	98.42	0.7	43.4	
20/01/2024 14:00	45.17	0	101.87	0.6	39	
20/01/2024 15:00	45.22	0.01	101.91	0.6	37.5	
20/01/2024 16:00	45.27	0.05	102	0.6	37.2	
20/01/2024 17:00	45.19	0.04	102.07	0.6	36.9	
20/01/2024 18:00	45.15	0.04	102.11	0.6	35.6	
20/01/2024 19:00	45.14	0.02	102.09	0.7	35.1	
20/01/2024 20:00	45.16	0.01	102.04	0.7	34.5	
20/01/2024 21:00	45.15	0.01	102.2	0.8	34.2	
20/01/2024 22:00	41.57	0	100.94	0.8	35.5	
20/01/2024 23:00	31.21	0	94.2	0.8	44.5	
21/01/2024 00:00	31.13	0.21	93.65	0.8	44	
Minimum	24.42	0	91.5	0.5	34.2	
MinDate	20/01/2024 00:00	20/01/2024 13:00	20/01/2024 00:00	20/01/2024 00:00	20/01/2024 21:00	
Maximum	45.27	1.15	102.2	0.9	51	
MaxDate	20/01/2024 16:00	20/01/2024 00:00	20/01/2024 21:00	20/01/2024 05:00	20/01/2024 00:00	
Avg	36	0.1	96.73	0.7	42.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0.2	4.1	0.1	5.1	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/01/2024 00:00	31.19	0	92.72	0	33.8	
21/01/2024 01:00	31.21	0	92.85	0	33.2	
21/01/2024 02:00	31.25	0	92.92	0	32.8	
21/01/2024 03:00	31.14	0	92.9	0	33	
21/01/2024 04:00	31.19	0	92.85	0	32.9	
21/01/2024 05:00	31.1	0	92.75	0	33.4	
21/01/2024 06:00	31.04	0	92.84	0.1	33.8	
21/01/2024 07:00	30.9	0.2	92.94	0.1	34.5	
21/01/2024 08:00	30.85	0	93.29	0.1	33.9	
21/01/2024 09:00	30.95	0	93.58	0	33.3	
21/01/2024 10:00	30.92	0.06	93.79	0	32.1	
21/01/2024 11:00	30.96	0.03	93.81	0	31.2	
21/01/2024 12:00	30.91	0.03	93.54	0	31.3	
21/01/2024 13:00	30.92	0.02	93.43	0	30.8	
21/01/2024 14:00	30.97	0	93.07	0	30.7	
21/01/2024 15:00	30.95	0	92.98	0	30.8	
21/01/2024 16:00	30.92	0	92.78	0	31.6	
21/01/2024 17:00	34.37	0	93.47	0	31.2	
21/01/2024 18:00	44.91	0	100.65	0	25.7	
21/01/2024 19:00	44.91	0	101.33	0	26	
21/01/2024 20:00	44.93	0	101.32	0	25.7	
21/01/2024 21:00	34.47	0	96.89	0	31.6	
21/01/2024 22:00	30.96	0	92.7	0	33.1	
21/01/2024 23:00	30.92	0	92.64	0	33	
22/01/2024 00:00	30.94	0	92.79	0	33	
Minimum	30.85	0	92.64	0	25.7	
MinDate	21/01/2024 08:00	21/01/2024 00:00	21/01/2024 23:00	21/01/2024 00:00	21/01/2024 18:00	
Maximum	44.93	0.2	101.33	0.1	34.5	
MaxDate	21/01/2024 20:00	21/01/2024 07:00	21/01/2024 19:00	21/01/2024 06:00	21/01/2024 07:00	
Avg	32.95	0.01	94.19	0	31.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0	2.7	0	2.5	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/01/2024 00:00	31.13	0.21	93.65	0.8	44	
21/01/2024 01:00	31.16	0	93.81	0.9	43.3	
21/01/2024 02:00	31.19	0	93.88	0.9	42.9	
21/01/2024 03:00	31.08	0	93.92	0.9	42.7	
21/01/2024 04:00	31.13	0	93.91	1	42.9	
21/01/2024 05:00	31.03	0	93.76	1	43	
21/01/2024 06:00	30.98	0	93.89	1	43.3	
21/01/2024 07:00	30.84	0	93.94	1	43.4	
21/01/2024 08:00	30.79	0	94.21	1	43.4	
21/01/2024 09:00	30.88	4.35	94.05	0.9	45.1	
21/01/2024 10:00	30.85	3.28	94.13	0.8	45.3	
21/01/2024 11:00	30.9	5.06	94.17	0.8	45.3	
21/01/2024 12:00	30.84	4.97	93.9	0.7	45.3	
21/01/2024 13:00	30.86	1.89	93.73	0.7	45.4	
21/01/2024 14:00	30.91	3.36	93.42	0.7	43.7	
21/01/2024 15:00	30.89	6.25	93.45	0.7	44.6	
21/01/2024 16:00	30.86	2.5	93.25	0.7	45.9	
21/01/2024 17:00	34.3	5.69	94.03	0.6	43.6	
21/01/2024 18:00	44.82	4.35	101.26	0.7	33.2	
21/01/2024 19:00	44.83	8.21	101.91	0.7	33.1	
21/01/2024 20:00	44.85	7.4	101.89	0.8	32.9	
21/01/2024 21:00	34.4	1.27	97.23	0.8	40.4	
21/01/2024 22:00	30.89	0.42	93.55	0.8	43.4	
21/01/2024 23:00	30.86	2.11	93.57	0.9	42.9	
22/01/2024 00:00	30.88	6.11	93.71	0.9	42.9	
Minimum	30.79	0	93.25	0.6	32.9	
MinDate	21/01/2024 08:00	21/01/2024 01:00	21/01/2024 16:00	21/01/2024 17:00	21/01/2024 20:00	
Maximum	44.85	8.21	101.91	1	45.9	
MaxDate	21/01/2024 20:00	21/01/2024 19:00	21/01/2024 04:00	21/01/2024 16:00		
Avg	32.89	2.7	94.89	0.8	42.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	2.7	2.7	0.1	3.7	

HRSG12 Flue
Gas TSP valve
has swung

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/01/2024 00:00	30.94	0	92.79	0	33	
22/01/2024 01:00	30.9	0	92.86	0	32.9	
22/01/2024 02:00	30.92	0	92.9	0	32.6	
22/01/2024 03:00	30.94	0	92.89	0	32.2	
22/01/2024 04:00	30.98	0	93.11	0.1	31.9	
22/01/2024 05:00	30.96	0	93.15	0.1	32	
22/01/2024 06:00	31	0.3	93.22	0.1	31.8	
22/01/2024 07:00	31.17	0.12	93.39	0.1	31.1	
22/01/2024 08:00	29.78	0	93.54	0.1	33.1	
22/01/2024 09:00	3.13	0.05	ShutDown	ShutDown	ShutDown	GT11 S/D
22/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
22/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
22/01/2024 12:00	1.7	0.15	ShutDown	ShutDown	ShutDown	GT11 S/D
22/01/2024 13:00	31.59	0	95.06	0.1	27.3	
22/01/2024 14:00	34.19	0	94.63	0.1	27.2	
22/01/2024 15:00	34.28	0	94.2	0	27.2	
22/01/2024 16:00	34.18	0	93.71	0	27.3	
22/01/2024 17:00	33.99	0	93.5	0	27.3	
22/01/2024 18:00	33.95	0	93.31	0	27.3	
22/01/2024 19:00	33.69	0	93.27	0	27.3	
22/01/2024 20:00	33.75	0	93.13	0	26.9	
22/01/2024 21:00	33.9	0	93.07	0	26.3	
22/01/2024 22:00	31.09	0	93.17	0	32.9	
22/01/2024 23:00	47.06	0	95.63	0	38.2	
23/01/2024 00:00	48.8	0	95.9	0.1	38.6	
Minimum	0	0	92.79	0	26.3	
MinDate	22/01/2024 10:00	22/01/2024 00:00	22/01/2024 00:00	22/01/2024 00:00	22/01/2024 21:00	
Maximum	48.8	0.3	95.9	0.1	38.6	
MaxDate	23/01/2024 00:00	22/01/2024 06:00	23/01/2024 00:00	22/01/2024 04:00	23/01/2024 00:00	
Avg	28.52	0.02	93.64	0	31.2	
Num	25	25	21	21	21	
Data[%]	100	100	84	84	84	
STD	13	0.1	0.9	0	3.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/01/2024 00:00	30.88	6.11	93.71	0.9	42.9	
22/01/2024 01:00	30.84	0	93.83	0.9	42.5	
22/01/2024 02:00	30.86	0.02	93.85	1	41.9	
22/01/2024 03:00	30.88	0.01	93.89	1	41.2	
22/01/2024 04:00	30.92	0.01	93.64	1	41.2	
22/01/2024 05:00	30.9	0.02	93.55	1	41	
22/01/2024 06:00	30.93	0.03	93.59	1	40.9	
22/01/2024 07:00	31.11	0.01	93.78	1	41	
22/01/2024 08:00	29.72	0	94	1	42.9	
22/01/2024 09:00	45.4	0	96.19	0.9	39.6	
22/01/2024 10:00	47.79	0	95.24	0.8	40.2	
22/01/2024 11:00	47.65	0	95.66	0.8	40.2	
22/01/2024 12:00	46.46	0	96.09	0.8	38.9	
22/01/2024 13:00	31.7	0	94.47	0.8	33.9	
22/01/2024 14:00	34.12	0.22	94.98	0.7	27.7	
22/01/2024 15:00	34.22	0.05	94.87	0.7	27.8	
22/01/2024 16:00	34.11	0.01	94.62	0.6	28	
22/01/2024 17:00	33.92	0	94.43	0.6	28.2	
22/01/2024 18:00	33.88	0	94.31	0.7	28.4	
22/01/2024 19:00	33.63	0	94.28	0.7	28.7	
22/01/2024 20:00	33.68	0	94.09	0.7	28.3	
22/01/2024 21:00	33.84	0	93.99	0.7	27.8	
22/01/2024 22:00	31	0	93.88	0.8	33.2	
22/01/2024 23:00	2.03	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.55	0.6	27.7	
MinDate	23/01/2024 00:00	22/01/2024 01:00	22/01/2024 05:00	22/01/2024 16:00	22/01/2024 14:00	
Maximum	47.79	6.11	96.19	1	42.9	
MaxDate	22/01/2024 10:00	22/01/2024 00:00	22/01/2024 09:00	22/01/2024 02:00	22/01/2024 00:00	
Avg	32.02	0.26	94.39	0.8	35.9	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	10.9	1.2	0.8	0.1	6.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/01/2024 00:00	48.8	0	95.9	0.1	38.6	
23/01/2024 01:00	48.89	0	96.42	0.1	38.4	
23/01/2024 02:00	48.91	0	96.55	0.1	38.2	
23/01/2024 03:00	48.93	0	96.64	0.1	37.9	
23/01/2024 04:00	48.9	0	96.72	0.1	37.5	
23/01/2024 05:00	48.78	0	96.71	0.2	37.3	
23/01/2024 06:00	48.85	0.26	96.07	0.2	37.2	
23/01/2024 07:00	48.71	0.06	95.16	0.2	36.4	
23/01/2024 08:00	48.77	0	94.73	0.3	37.6	
23/01/2024 09:00	48.62	0	94.52	0.3	37.8	
23/01/2024 10:00	48.12	0	94.66	0.2	37.7	
23/01/2024 11:00	47.65	0	94.8	0.2	37.6	
23/01/2024 12:00	43.95	0	96.2	0.2	36	
23/01/2024 13:00	32.3	0	94.22	0.2	33.8	
23/01/2024 14:00	34.25	0	94.71	0.2	25.7	
23/01/2024 15:00	34.24	0	94.59	0.2	25.7	
23/01/2024 16:00	34.06	0	94.5	0.2	25.9	
23/01/2024 17:00	33.94	0	94.26	0.2	25	
23/01/2024 18:00	33.85	0	94.26	0.1	24.4	
23/01/2024 19:00	33.74	0	94.21	0.2	24.6	
23/01/2024 20:00	33.86	0	94.24	0.2	24.8	
23/01/2024 21:00	34.04	0	94.78	0.2	24.3	
23/01/2024 22:00	31.23	0	94.42	0.2	30.8	
23/01/2024 23:00	47.41	0	96.24	0.2	35.3	
24/01/2024 00:00	48.82	0	95.47	0.2	36.1	
Minimum	31.23	0	94.21	0.1	24.3	
MinDate	23/01/2024 22:00	23/01/2024 00:00	23/01/2024 19:00	23/01/2024 00:00	23/01/2024 21:00	
Maximum	48.93	0.26	96.72	0.3	38.6	
MaxDate	23/01/2024 03:00	23/01/2024 06:00	23/01/2024 04:00	23/01/2024 08:00	23/01/2024 00:00	
Avg	42.38	0.01	95.24	0.2	33	
Num	25	25	25	25	25	
Data1%	100	100	100	100	100	
STD	7.5	0.1	0.9	0.1	5.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 12:00	5.7	0	ShutDown	ShutDown	ShutDown	GT12 S/D
23/01/2024 13:00	32.17	0	95.13	1.1	39.9	
23/01/2024 14:00	34.19	0.17	94.53	1	34.6	
23/01/2024 15:00	34.18	0.09	94.49	0.9	34.6	
23/01/2024 16:00	34	0.11	94.42	0.9	34.9	
23/01/2024 17:00	33.87	0.17	94.22	0.8	33.4	
23/01/2024 18:00	33.79	0.23	94.16	0.8	32.7	
23/01/2024 19:00	33.67	0.21	94.22	0.9	34.1	
23/01/2024 20:00	33.8	0.17	94.23	0.9	34.8	
23/01/2024 21:00	33.97	0.2	94.58	0.9	32.8	
23/01/2024 22:00	31.08	0.22	94.15	0.9	37.2	
23/01/2024 23:00	1.77	0.16	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 00:00	0	0.07	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	94.15	0.8	32.7	
MinDate	23/01/2024 00:00	23/01/2024 00:00	23/01/2024 22:00	23/01/2024 17:00	23/01/2024 18:00	
Maximum	34.19	0.23	95.13	1.1	39.9	
MaxDate	23/01/2024 14:00	23/01/2024 18:00	23/01/2024 13:00	23/01/2024 13:00	23/01/2024 13:00	
Avg	13.69	0.07	94.41	0.9	34.9	
Num	25	25	10	10	10	
Data1%	100	100	40	40	40	
STD	16.5	0.1	0.3	0.1	2.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/01/2024 00:00	48.82	0	95.47	0.2	36.1	
24/01/2024 01:00	48.84	0	95.92	0.2	36.9	
24/01/2024 02:00	48.84	0	95.71	0.2	36.7	
24/01/2024 03:00	48.84	0	95.59	0.2	37.3	
24/01/2024 04:00	48.59	0	95.68	0.2	36.3	
24/01/2024 05:00	48.35	0	95.89	0.2	35.8	
24/01/2024 06:00	48.27	0.26	96	0.1	35.4	
24/01/2024 07:00	48.28	0	96.33	0.1	35	
24/01/2024 08:00	48.64	0	96.26	0	36	
24/01/2024 09:00	48.98	0	96.03	0	37.7	
24/01/2024 10:00	48.93	0	95.87	0	38.4	
24/01/2024 11:00	48.65	0	95.9	0	38.7	
24/01/2024 12:00	43.15	0	96.46	0	36.9	
24/01/2024 13:00	32.18	0	93.23	0	34.3	
24/01/2024 14:00	34.21	0.01	93.82	0	26.3	
24/01/2024 15:00	34.16	0.03	93.66	0	26.2	
24/01/2024 16:00	34.07	0.09	93.83	0	26	
24/01/2024 17:00	33.86	0.1	93.72	0	25.5	
24/01/2024 18:00	33.74	0.12	93.61	0	25.3	
24/01/2024 19:00	33.52	0.09	93.4	0	26.1	
24/01/2024 20:00	33.65	0.08	93.38	0	25.9	
24/01/2024 21:00	33.76	0.06	93.5	0	25.7	
24/01/2024 22:00	31.06	0	92.97	0	23.5	
24/01/2024 23:00	2.1	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	92.97	0	23.3	
MinDate	25/01/2024 00:00	24/01/2024 00:00	24/01/2024 22:00	24/01/2024 08:00	24/01/2024 18:00	
Maximum	48.98	0.26	96.46	0.2	38.7	
MaxDate	24/01/2024 09:00	24/01/2024 06:00	24/01/2024 12:00	24/01/2024 00:00	24/01/2024 11:00	
Avg	38.54	0.04	94.88	0.1	32.7	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.4	0.1	1.3	0.1	5.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/01/2024 00:00	0	0.07	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 01:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 02:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 03:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 11:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 12:00	6.75	0.1	ShutDown	ShutDown	ShutDown	GT12 S/D
24/01/2024 13:00	32.11	0.2	93.36	0	42.7	
24/01/2024 14:00	34.15	0.51	93.96	0	37.3	
24/01/2024 15:00	34.1	0.06	93.99	0	37	
24/01/2024 16:00	34.01	0.06	94.2	0	36.9	
24/01/2024 17:00	33.8	0.08	94.14	0	36	
24/01/2024 18:00	33.68	0.1	94.07	0	36.5	
24/01/2024 19:00	33.46	0.09	93.8	0	39.7	
24/01/2024 20:00	33.59	0.1	93.69	0	39	
24/01/2024 21:00	33.7	0.06	93.66	0	37.8	
24/01/2024 22:00	31.09	0	93.08	0	42.5	
24/01/2024 23:00	46.84	0	95.05	0	48.8	
25/01/2024 00:00	48.44	0	94.8	0	49.1	
Minimum	0	0	93.08	0	36	
MinDate	24/01/2024 00:00	24/01/2024 04:00	24/01/2024 22:00	24/01/2024 13:00	24/01/2024 17:00	
Maximum	48.44	0.51	95.05	0	49.1	
MaxDate	25/01/2024 00:00	24/01/2024 14:00	24/01/2024 23:00	24/01/2024 13:00	25/01/2024 00:00	
Avg	17.43	0.06	93.98	0	40.3	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.4	0.1	0.5	0	4.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
25/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 06:00	0	0.19	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 11:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 12:00	7.79	0.43	ShutDown	ShutDown	ShutDown	GT11 S/D
25/01/2024 13:00	32.19	0.11	94.32	0	38.5	
25/01/2024 14:00	34.17	0.14	94.68	0	30	
25/01/2024 15:00	34.08	0.13	94.38	0	29.7	
25/01/2024 16:00	33.99	0.14	94.3	0	29.5	
25/01/2024 17:00	33.7	0.13	93.72	0	29.1	
25/01/2024 18:00	33.79	0.04	93.59	0	28.6	
25/01/2024 19:00	33.7	0.02	93.68	0	28.1	
25/01/2024 20:00	33.84	0.01	93.85	0	28.1	
25/01/2024 21:00	33.97	0.01	94.36	0	28.4	
25/01/2024 22:00	31.49	0.04	93.84	0	35.6	
25/01/2024 23:00	2.51	0.06	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	93.59	0	28.1	
MinDate	25/01/2024 00:00	25/01/2024 00:00	25/01/2024 18:00	25/01/2024 13:00	25/01/2024 19:00	
Maximum	34.17	0.43	94.68	0	38.5	
MaxDate	25/01/2024 14:00	25/01/2024 12:00	25/01/2024 14:00	25/01/2024 13:00	25/01/2024 13:00	
Avg	13.81	0.06	94.07	0	30.6	
Num	25	25	10	10	10	
Data[%]	100	100	40	40	40	
STD	16.5	0.1	0.4	0	3.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
25/01/2024 00:00	48.44	0	94.8	0	49.1	
25/01/2024 01:00	48.71	0	95.54	0	49.4	
25/01/2024 02:00	48.75	0	95.81	0	49.6	
25/01/2024 03:00	48.65	0	95.84	0	48.5	
25/01/2024 04:00	48.54	0	95.89	0	47.5	
25/01/2024 05:00	48.42	0	95.74	0	46.4	
25/01/2024 06:00	48.3	0	95.99	0	45.2	
25/01/2024 07:00	48.35	0	95.96	0	45.4	
25/01/2024 08:00	48.64	0	95.87	0	47.4	
25/01/2024 09:00	48.73	0	95.46	0	49.4	
25/01/2024 10:00	48.26	0.03	95.31	0	49.3	
25/01/2024 11:00	47.8	0.07	95.6	0	48.6	
25/01/2024 12:00	41.89	0.1	94.93	0	46.7	
25/01/2024 13:00	32.31	0.42	93.7	0	40.4	
25/01/2024 14:00	34.11	0.09	94.12	0	34.6	
25/01/2024 15:00	34.01	0.09	93.99	0	34.5	
25/01/2024 16:00	33.92	0.08	93.81	0	34.3	
25/01/2024 17:00	33.65	0.05	93.33	0	34.4	
25/01/2024 18:00	33.72	0.02	93.15	0	33.7	
25/01/2024 19:00	33.64	0.33	93.3	0	33.1	
25/01/2024 20:00	33.78	0.05	93.39	0	33.4	
25/01/2024 21:00	33.91	0.06	93.7	0	33.7	
25/01/2024 22:00	31.44	0.08	92.86	0	40.5	
25/01/2024 23:00	46.73	0.03	95.21	0	44.6	
26/01/2024 00:00	48.73	0.04	95.44	0	44.8	
Minimum	31.44	0	92.86	0	33.1	
MinDate	25/01/2024 22:00	25/01/2024 00:00	25/01/2024 22:00	25/01/2024 00:00	25/01/2024 19:00	
Maximum	48.75	0.42	95.99	0	49.6	
MaxDate	25/01/2024 02:00	25/01/2024 13:00	25/01/2024 06:00	25/01/2024 00:00	25/01/2024 02:00	
Avg	42.14	0.06	94.75	0	42.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.4	0.1	1.1	0	6.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 06:00	0	0.38	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 12:00	7.67	0.35	ShutDown	ShutDown	ShutDown	GT11 S/D
26/01/2024 13:00	32.14	0.13	94.35	0	38.7	
26/01/2024 14:00	34.1	0.25	95.05	0	29.9	
26/01/2024 15:00	34.09	0.26	95.16	0	29.8	
26/01/2024 16:00	34.01	0.24	94.81	0	29.3	
26/01/2024 17:00	33.91	0.21	94.52	0	28.8	
26/01/2024 18:00	33.87	0.21	94.1	0	28.4	
26/01/2024 19:00	33.61	0.19	93.85	0	29.2	
26/01/2024 20:00	33.72	0.11	93.83	0	29	
26/01/2024 21:00	33.92	0.1	94.44	0	27.7	
26/01/2024 22:00	33.56	0.14	95.4	0	33.9	
26/01/2024 23:00	24.12	0.15	91.88	0.1	52	
27/01/2024 00:00	27.48	0.03	91.97	0.1	51.6	
Minimum	0	0	91.88	0	27.7	
MinDate	26/01/2024 00:00	26/01/2024 00:00	26/01/2024 23:00	26/01/2024 13:00	26/01/2024 21:00	
Maximum	34.1	0.38	95.4	0.1	52	
MaxDate	26/01/2024 14:00	26/01/2024 06:00	26/01/2024 22:00	26/01/2024 23:00	26/01/2024 23:00	
Avg	15.85	0.11	94.11	0	34	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	16.4	0.1	1.1	0	8.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/12/2022 00:00	49.08	0.92	97.84	0	44.9	
26/12/2022 01:00	NoData	NoData	NoData	NoData	NoData	Error
26/12/2022 02:00	NoData	NoData	NoData	NoData	NoData	Error
26/01/2024 03:00	48.76	0.42	95.85	0	44.5	
26/01/2024 04:00	48.65	1.08	95.97	0	44.1	
26/01/2024 05:00	48.56	0.61	95.87	0	43.2	
26/01/2024 06:00	48.44	0.32	96.04	0	42.1	
26/01/2024 07:00	48.42	0.07	96.2	0	41.5	
26/01/2024 08:00	48.67	0.59	96.04	0	42.3	
26/01/2024 09:00	48.94	0.45	95.96	0	44	
26/01/2024 10:00	48.83	0.17	95.8	0	45.6	
26/01/2024 11:00	48.54	0.36	95.7	0	46.6	
26/01/2024 12:00	42.76	<Samp	95.13	0	43.6	Calibration
26/01/2024 13:00	32.16	0.48	93.74	0	38.7	
26/01/2024 14:00	34.04	0.1	94.43	0	32.2	
26/01/2024 15:00	34.02	0.24	94.69	0	31.9	
26/01/2024 16:00	33.95	0.08	94.29	0	31.4	
26/01/2024 17:00	33.84	0.04	93.79	0	31.2	
26/01/2024 18:00	33.81	0.04	93.57	0	30.8	
26/01/2024 19:00	33.55	0.01	93.51	0	33.5	
26/01/2024 20:00	33.65	0.39	93.52	0	33.1	
26/01/2024 21:00	33.86	<Samp	94.04	0	30.9	Calibration
26/01/2024 22:00	33.5	0.1	94.79	0	34.5	
26/01/2024 23:00	24.06	0.39	91.71	0.1	50.1	
27/01/2024 00:00	27.42	0.01	92.06	0.3	45.5	
Minimum	24.06	0.01	91.71	0	30.8	
MinDate	26/01/2024 23:00	26/01/2024 19:00	26/01/2024 23:00	26/01/2024 00:00	26/01/2024 18:00	
Maximum	48.94	1.08	96.2	0.3	50.1	
MaxDate	26/01/2024 09:00	26/01/2024 04:00	26/01/2024 07:00	27/01/2024 00:00	26/01/2024 23:00	
Avg	40.59	0.27	94.78	0	39.9	
Num	25	23	25	25	25	
Data[%]	100	100	100	100	100	
STD	8.5	0.3	1.3	0.1	6.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/01/2024 00:00	27.48	0.03	91.97	0.1	51.6	
27/01/2024 01:00	28.85	0.01	92.41	0.1	49.6	
27/01/2024 02:00	30.98	0.08	93.09	0.2	42.7	
27/01/2024 03:00	31.33	0.11	93.26	0.2	41.7	
27/01/2024 04:00	31.62	0.13	93.29	0.2	41	
27/01/2024 05:00	31.5	0.08	93.05	0.2	41.7	
27/01/2024 06:00	31.37	0.36	92.56	0.2	42.3	
27/01/2024 07:00	31.34	0	92.4	0.2	42.1	
27/01/2024 08:00	31.38	0	92.48	0.1	41.5	
27/01/2024 09:00	31.74	0	92.75	0.1	39.5	
27/01/2024 10:00	31.81	0	92.96	0.1	38.6	
27/01/2024 11:00	31.85	0	93.25	0.1	37.4	
27/01/2024 12:00	31.78	0	93.53	0.1	35.8	
27/01/2024 13:00	42.01	0.01	98.05	0.1	36.1	
27/01/2024 14:00	45.55	0.03	101.11	0.1	36.2	
27/01/2024 15:00	45.56	0.01	100.89	0.1	36.6	
27/01/2024 16:00	45.42	0.06	100.96	0.1	34.9	
27/01/2024 17:00	45.28	0.01	101.11	0.1	32.7	
27/01/2024 18:00	45.33	0.01	101.08	0.1	31.5	
27/01/2024 19:00	45.31	0	100.95	0.1	31.4	
27/01/2024 20:00	45.69	0.01	101.14	0.1	31.5	
27/01/2024 21:00	45.96	0	101.63	0.1	31.5	
27/01/2024 22:00	42.37	0.01	100.8	0.1	33.1	
27/01/2024 23:00	31.78	0	93.38	0.1	36.6	
28/01/2024 00:00	31.61	0	92.53	0.2	37.1	
Minimum	27.48	0	91.97	0.1	31.4	
MinDate	27/01/2024 00:00	27/01/2024 07:00	27/01/2024 00:00	27/01/2024 00:00	27/01/2024 19:00	
Maximum	45.96	0.36	101.63	0.2	51.6	
MaxDate	27/01/2024 21:00	27/01/2024 06:00	27/01/2024 21:00	27/01/2024 02:00	27/01/2024 00:00	
Avg	36.6	0.04	96.03	0.1	38.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7	0.1	4	0	5.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/01/2024 00:00	27.42	0.01	92.06	0.3	45.5	
27/01/2024 01:00	28.78	0	92.55	0.4	46.6	
27/01/2024 02:00	30.92	0.03	93.15	0.5	45.6	
27/01/2024 03:00	31.27	0.07	93.23	0.5	45.7	
27/01/2024 04:00	31.56	0.1	93.27	0.6	46.2	
27/01/2024 05:00	31.44	0.08	93.09	0.6	46.9	
27/01/2024 06:00	31.3	0.05	92.61	0.6	47.7	
27/01/2024 07:00	31.28	0.04	92.52	0.5	48.1	
27/01/2024 08:00	31.32	0.06	92.43	0.4	48.3	
27/01/2024 09:00	31.68	0.06	92.7	0.2	48.1	
27/01/2024 10:00	31.75	0.07	92.94	0	47.8	
27/01/2024 11:00	31.79	0.12	93.23	0	47.5	
27/01/2024 12:00	31.72	0.2	93.51	0	46.7	
27/01/2024 13:00	41.88	0.24	97.89	0	41.1	
27/01/2024 14:00	45.47	0.22	101.6	0	38.8	
27/01/2024 15:00	45.48	0.23	101.48	0	39.3	
27/01/2024 16:00	45.34	0.18	101.71	0	36.9	
27/01/2024 17:00	45.2	<Samp	102.09	0	33.8	Calibration
27/01/2024 18:00	45.26	0.06	102.07	0	32.8	
27/01/2024 19:00	45.23	0.01	101.98	0	32.3	
27/01/2024 20:00	45.61	0.4	102.17	0.2	32.8	
27/01/2024 21:00	45.88	0.01	102.4	0.3	32.8	
27/01/2024 22:00	42.3	0.03	101.42	0.4	34.4	
27/01/2024 23:00	31.72	0.06	94.19	0.5	44.3	
28/01/2024 00:00	31.55	0.01	93.53	0.6	43.9	
Minimum	27.42	0	92.06	0	32.3	
MinDate	27/01/2024 00:00	27/01/2024 01:00	27/01/2024 00:00	27/01/2024 10:00	27/01/2024 19:00	
Maximum	45.88	0.4	102.4	0.6	48.3	
MaxDate	27/01/2024 21:00	27/01/2024 20:00	27/01/2024 21:00	27/01/2024 04:00	27/01/2024 08:00	
Avg	36.53	0.1	96.39	0.3	42.2	
Num	25	24	25	25	25	
Data[%]	100	96	100	100	100	
STD	7	0.1	4.3	0.2	6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/01/2024 00:00	31.61	0	92.53	0.2	37.1	
28/01/2024 01:00	31.55	0	92.42	0.2	37.4	
28/01/2024 02:00	31.5	0	92.41	0.2	37.6	
28/01/2024 03:00	31.27	0	92.3	0.2	38.6	
28/01/2024 04:00	31.08	0	92.17	0.3	39.7	
28/01/2024 05:00	30.96	0	91.96	0.3	40.3	
28/01/2024 06:00	30.73	0.28	91.78	0.3	41.2	
28/01/2024 07:00	30.38	0	91.91	0.3	42.9	
28/01/2024 08:00	30.29	0	91.97	0.2	42.8	
28/01/2024 09:00	30.27	0	91.71	0.2	41.7	
28/01/2024 10:00	30.33	0	91.88	0.2	40.4	
28/01/2024 11:00	30.38	0.02	92.34	0.2	39.2	
28/01/2024 12:00	30.35	0.08	92.47	0.2	38.1	
28/01/2024 13:00	30.44	0.11	92.78	0.2	37.7	
28/01/2024 14:00	30.39	0.1	92.64	0.2	37.3	
28/01/2024 15:00	30.42	0.09	92.38	0.2	36.7	
28/01/2024 16:00	30.41	0.1	92.11	0.2	37.2	
28/01/2024 17:00	33.88	0.04	92.93	0.2	36.1	
28/01/2024 18:00	44.43	0	100.5	0.2	28.5	
28/01/2024 19:00	44.5	0	101.31	0.2	28.6	
28/01/2024 20:00	44.42	0	101.28	0.2	28.5	
28/01/2024 21:00	33.91	0.03	96.67	0.2	35.8	
28/01/2024 22:00	30.43	0.09	92.64	0.2	38.2	
28/01/2024 23:00	30.36	0.06	92.42	0.2	39	
29/01/2024 00:00	30.38	0.1	92.37	0.2	38.9	
Minimum	30.27	0	91.71	0.2	28.3	
MinDate	28/01/2024 09:00	28/01/2024 00:00	28/01/2024 09:00	28/01/2024 00:00	28/01/2024 18:00	
Maximum	44.5	0.28	101.31	0.3	42.9	
MaxDate	28/01/2024 19:00	28/01/2024 06:00	28/01/2024 19:00	28/01/2024 04:00	28/01/2024 07:00	
Avg	32.59	0.04	93.52	0.2	37.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0.1	3	0	3.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/01/2024 00:00	31.55	0.01	93.53	0.6	43.9	
28/01/2024 01:00	31.49	0.01	93.42	0.6	43.8	
28/01/2024 02:00	31.44	0.05	93.43	0.7	43.6	
28/01/2024 03:00	31.21	0.06	93.33	0.8	43.5	
28/01/2024 04:00	31.01	0.07	93.2	0.8	43.6	
28/01/2024 05:00	30.89	0.05	92.92	0.8	43.8	
28/01/2024 06:00	30.67	0.03	92.83	0.8	43.8	
28/01/2024 07:00	30.31	0.02	92.84	0.8	44.6	
28/01/2024 08:00	30.23	0.08	93.15	0.8	45.1	
28/01/2024 09:00	30.2	0.14	92.75	0.7	45.6	
28/01/2024 10:00	30.26	0.19	92.92	0.5	45.2	
28/01/2024 11:00	30.32	0.24	93.35	0.4	45.2	
28/01/2024 12:00	30.29	0.25	93.45	0.3	44.8	
28/01/2024 13:00	30.37	0.24	93.94	0.2	44.9	
28/01/2024 14:00	30.33	0.23	93.62	0.1	44.7	
28/01/2024 15:00	30.36	0.2	93.46	0.1	44	
28/01/2024 16:00	30.35	<Samp	93.23	0	42.7	Calibration
28/01/2024 17:00	33.82	0.05	94.15	0.1	40.4	
28/01/2024 18:00	44.36	0.04	100.5	0.3	29.8	
28/01/2024 19:00	44.43	0.03	101.06	0.5	29.9	
28/01/2024 20:00	44.35	0.03	100.91	0.6	29.6	
28/01/2024 21:00	33.82	0.05	96.52	0.6	38	
28/01/2024 22:00	30.36	0.07	93.55	0.7	41.8	
28/01/2024 23:00	30.29	0.09	93.51	0.8	42.5	
29/01/2024 00:00	30.31	0.07	93.52	0.8	42.3	
Minimum	30.2	0.01	92.75	0	29.6	
MinDate	28/01/2024 09:00	28/01/2024 00:00	28/01/2024 09:00	28/01/2024 16:00	28/01/2024 20:00	
Maximum	44.43	0.25	101.06	0.8	45.6	
MaxDate	28/01/2024 19:00	28/01/2024 12:00	28/01/2024 19:00	28/01/2024 03:00	28/01/2024 09:00	
Avg	32.52	0.1	94.36	0.5	41.9	
Num	25	24	25	25	25	
Data[%]	100	96	100	100	100	
STD	4.6	0.1	2.5	0.3	4.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/01/2024 00:00	30.38	0.1	92.37	0.2	38.9	
29/01/2024 01:00	30.4	0.04	92.27	0.2	38.5	
29/01/2024 02:00	30.35	0	92.1	0.3	39.3	
29/01/2024 03:00	30.32	0	91.6	0.3	40	
29/01/2024 04:00	30.34	0	91.25	0.3	40.5	
29/01/2024 05:00	30.33	0	91.08	0.3	41.1	
29/01/2024 06:00	30.35	0.19	91.11	0.2	41.4	
29/01/2024 07:00	30.43	0	91.15	0.2	41.1	
29/01/2024 08:00	30.12	0	91.32	0.2	39.5	
29/01/2024 09:00	43.7	0	93.95	0.2	39	
29/01/2024 10:00	48	0	94.94	0.2	36.5	
29/01/2024 11:00	47.66	0	95.86	0.2	36.4	
29/01/2024 12:00	43.16	0.03	96.23	0.2	37	
29/01/2024 13:00	33.5	0.16	95.12	0.2	33.5	
29/01/2024 14:00	34.1	0.16	95.18	0.1	24.5	
29/01/2024 15:00	34.14	0.09	94.51	0.1	24.1	
29/01/2024 16:00	34.06	0.1	94.31	0.1	23.9	
29/01/2024 17:00	33.8	0.06	94	0.1	23.6	
29/01/2024 18:00	33.72	0.01	93.92	0.1	23.3	
29/01/2024 19:00	33.57	0	93.87	0.1	23.6	
29/01/2024 20:00	33.75	0	94.09	0.2	23	
29/01/2024 21:00	33.92	0	94.61	0.2	22.6	
29/01/2024 22:00	31.09	0.04	94.44	0.2	29.6	
29/01/2024 23:00	1.99	0.08	ShutDown	ShutDown	ShutDown	GT11 SD
30/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	0	0	91.08	0.1	22.6	
MinDate	30/01/2024 00:00	29/01/2024 02:00	29/01/2024 05:00	29/01/2024 14:00	29/01/2024 21:00	
Maximum	48	0.19	96.23	0.3	41.4	
MaxDate	29/01/2024 10:00	29/01/2024 06:00	29/01/2024 12:00	29/01/2024 02:00	29/01/2024 06:00	
Avg	31.72	0.04	93.45	0.2	33.1	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	10.7	0.1	1.7	0.1	7.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/01/2024 00:00	30.31	0.07	93.52	0.8	42.3	
29/01/2024 01:00	30.34	0.05	93.44	0.9	41.8	
29/01/2024 02:00	30.29	0.03	93	0.9	42.1	
29/01/2024 03:00	30.26	0	92.7	0.9	43.1	
29/01/2024 04:00	30.28	0	92.49	0.9	44	
29/01/2024 05:00	30.27	0	92.34	0.9	44.1	
29/01/2024 06:00	30.28	0	92.32	0.9	44.3	
29/01/2024 07:00	30.37	0	92.26	0.8	44.4	
29/01/2024 08:00	30.05	0	92.47	0.7	45	
29/01/2024 09:00	4.4	0.01	ShutDown	ShutDown	ShutDown	GT12 SD
29/01/2024 10:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 SD
29/01/2024 11:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 SD
29/01/2024 12:00	5.63	0.15	ShutDown	ShutDown	ShutDown	GT12 SD
29/01/2024 13:00	30.92	0.18	95.86	0.2	46.2	
29/01/2024 14:00	34.04	0.15	94.79	0	36.6	
29/01/2024 15:00	34.07	0.13	94.3	0	35.7	
29/01/2024 16:00	33.98	0.37	94.13	0	35.2	
29/01/2024 17:00	33.74	0.04	93.85	0	35.1	
29/01/2024 18:00	33.65	0.01	93.77	0	34.8	
29/01/2024 19:00	33.5	0	93.7	0.2	36.8	
29/01/2024 20:00	33.68	0	93.94	0.3	35	
29/01/2024 21:00	33.85	0	94.29	0.5	33.8	
29/01/2024 22:00	31.15	0.02	94	0.6	38.4	
29/01/2024 23:00	47.18	0.04	96.16	0.7	43.2	
30/01/2024 00:00	48.64	0.05	95.48	0.8	44.8	
Minimum	0	0	92.26	0	33.8	
MinDate	29/01/2024 10:00	29/01/2024 03:00	29/01/2024 07:00	29/01/2024 14:00	29/01/2024 21:00	
Maximum	48.64	0.37	96.16	0.9	46.2	
MaxDate	30/01/2024 00:00	29/01/2024 16:00	29/01/2024 23:00	29/01/2024 01:00	29/01/2024 13:00	
Avg	28.44	0.06	93.75	0.5	40.3	
Num	25	25	21	21	21	
Data[%]	100	100	84	84	84	
STD	12.5	0.1	1.2	0.4	4.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
30/01/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 06:00	0	0.38	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 10:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 11:00	0	0.03	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 12:00	7.87	0.47	ShutDown	ShutDown	ShutDown	GT11 S/D
30/01/2024 13:00	32.12	0.17	94.89	0.3	35.7	
30/01/2024 14:00	34.14	0.11	94.87	0.3	27.1	
30/01/2024 15:00	34.08	0.07	94.46	0.3	27	
30/01/2024 16:00	33.93	0.05	94.31	0.4	27.1	
30/01/2024 17:00	33.7	0.02	94.23	0.3	27.3	
30/01/2024 18:00	33.53	0.04	94	0.4	28.4	
30/01/2024 19:00	33.49	0.02	93.98	0.3	28.9	
30/01/2024 20:00	33.78	0.01	94.11	0.4	27.6	
30/01/2024 21:00	33.92	0.02	94.61	0.4	26.8	
30/01/2024 22:00	31.13	0.03	94.26	0.4	33.4	
30/01/2024 23:00	47.46	0	96.33	0.4	36.5	
31/01/2024 00:00	48.86	0	95.84	0.4	36.8	
Minimum	0	0	93.98	0.3	26.8	
MinDate	30/01/2024 00:00	30/01/2024 00:00	30/01/2024 19:00	30/01/2024 13:00	30/01/2024 21:00	
Maximum	48.86	0.47	96.33	0.4	36.8	
MaxDate	31/01/2024 00:00	30/01/2024 12:00	30/01/2024 23:00	30/01/2024 16:00	31/01/2024 00:00	
Avg	17.52	0.06	94.66	0.4	30.2	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.7	0.1	4.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
30/01/2024 00:00	48.64	0.05	95.48	0.8	44.8	
30/01/2024 01:00	48.63	0.04	95.85	0.8	44.5	
30/01/2024 02:00	48.7	0.04	95.86	0.9	45.1	
30/01/2024 03:00	48.74	0.03	96.01	0.9	44.1	
30/01/2024 04:00	48.67	0.04	96.03	1	43.2	
30/01/2024 05:00	48.51	0	96.2	1	42.1	
30/01/2024 06:00	48.3	0	96.33	1	41.5	
30/01/2024 07:00	48.15	0	96.25	1	41.5	
30/01/2024 08:00	48.36	0	95.83	1	44.3	
30/01/2024 09:00	48.44	0	95.62	1	45.9	
30/01/2024 10:00	48.02	0.04	95.67	0.9	45.6	
30/01/2024 11:00	47.59	0.09	95.84	0.9	46.1	
30/01/2024 12:00	41.56	0.09	95.57	0.9	44.7	
30/01/2024 13:00	32.03	0.08	94.39	0.9	38.3	
30/01/2024 14:00	34.08	0.06	94.31	0.9	31.2	
30/01/2024 15:00	34.01	0	94.28	0.9	31.4	
30/01/2024 16:00	33.85	0.23	94.16	1	31.9	
30/01/2024 17:00	33.64	0.07	94.07	1	32.8	
30/01/2024 18:00	33.47	0.08	93.93	1	35.4	
30/01/2024 19:00	33.42	0.07	93.92	1	36.5	
30/01/2024 20:00	33.72	0.06	94.05	1	34.3	
30/01/2024 21:00	33.85	0.05	94.39	1	33.1	
30/01/2024 22:00	30.96	0.06	93.94	1.1	38	
30/01/2024 23:00	1.68	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 00:00	0	0.05	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.92	0.8	31.2	
MinDate	31/01/2024 00:00	30/01/2024 05:00	30/01/2024 19:00	30/01/2024 00:00	30/01/2024 14:00	
Maximum	48.74	0.23	96.33	1.1	46.1	
MaxDate	30/01/2024 03:00	30/01/2024 16:00	30/01/2024 06:00	30/01/2024 22:00	30/01/2024 11:00	
Avg	38.28	0.05	95.13	1	39.8	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.4	0	0.9	0.1	5.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
31/01/2024 00:00	48.86	0	95.84	0.4	36.8	
31/01/2024 01:00	48.91	0	96.38	0.5	36.3	
31/01/2024 02:00	48.99	0.01	96.36	0.5	36.8	
31/01/2024 03:00	48.93	0	96.41	0.5	36	
31/01/2024 04:00	48.69	0	96.55	0.5	34.9	
31/01/2024 05:00	48.48	0	96.71	0.5	33.9	
31/01/2024 06:00	48.47	0.32	96.8	0.5	33.7	
31/01/2024 07:00	48.28	0	96.91	0.6	33.1	
31/01/2024 08:00	48.61	0	96.74	0.6	34.8	
31/01/2024 09:00	48.73	0	96.29	0.5	37.4	
31/01/2024 10:00	48.26	0	96.24	0.5	37.8	
31/01/2024 11:00	47.94	0	96.23	0.5	37.9	
31/01/2024 12:00	42.72	0.04	96.64	0.5	37.5	
31/01/2024 13:00	32.12	0.05	94.67	0.5	32.8	
31/01/2024 14:00	34.1	0.01	95.54	0.4	25.8	
31/01/2024 15:00	34.12	0.02	95.08	0.4	25.6	
31/01/2024 16:00	33.93	0	94.55	0.4	25.6	
31/01/2024 17:00	33.68	0	94.42	0.3	25.4	
31/01/2024 18:00	33.57	0	94.2	0.3	25.5	
31/01/2024 19:00	33.52	0	94.11	0.3	25.9	
31/01/2024 20:00	33.77	0	94.34	0.4	25.4	
31/01/2024 21:00	33.96	0	94.76	0.4	25	
31/01/2024 22:00	31.13	0	94.39	0.4	31.6	
31/01/2024 23:00	1.93	0.02	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	94.11	0.3	25	
MinDate	01/02/2024 00:00	31/01/2024 00:00	31/01/2024 19:00	31/01/2024 17:00	31/01/2024 21:00	
Maximum	48.99	0.32	96.91	0.6	37.9	
MaxDate	31/01/2024 02:00	31/01/2024 06:00	31/01/2024 07:00	31/01/2024 07:00	31/01/2024 11:00	
Avg	38.47	0.02	95.66	0.5	32	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.4	0.1	1	0.1	5.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
31/01/2024 00:00	0	0.05	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 01:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 02:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 03:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 04:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 06:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 07:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 08:00	0	0.04	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 09:00	0	0.13	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 10:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 11:00	0	0.23	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 12:00	6.78	0.22	ShutDown	ShutDown	ShutDown	GT12 S/D
31/01/2024 13:00	32.03	0.19	94.14	1.2	38.4	
31/01/2024 14:00	34.03	0.15	94.88	1.1	33.9	
31/01/2024 15:00	34.06	0.18	94.72	1	33.3	
31/01/2024 16:00	33.86	0.24	94.25	0.9	33.4	
31/01/2024 17:00	33.62	0.03	94.12	0.9	33.5	
31/01/2024 18:00	33.51	0	93.94	0.9	34.6	
31/01/2024 19:00	33.46	0	93.91	1	36	
31/01/2024 20:00	33.7	0	94.11	1	34.7	
31/01/2024 21:00	33.9	0	94.3	1	33.4	
31/01/2024 22:00	31.2	0	93.83	1.1	37.8	
31/01/2024 23:00	47.3	0	96.17	1.1	43	
01/02/2024 00:00	48.71	0	95.6	1.1	42.9	
Minimum	0	0	93.83	0.9	33.3	
MinDate	31/01/2024 00:00	31/01/2024 05:00	31/01/2024 22:00	31/01/2024 16:00	31/01/2024 15:00	
Maximum	48.71	0.24	96.17	1.2	43	
MaxDate	01/02/2024 00:00	31/01/2024 16:00	31/01/2024 23:00	31/01/2024 13:00	31/01/2024 23:00	
Avg	17.45	0.07	94.5	1	36.2	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.4	0.1	0.7	0.1	3.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
01/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 06:00	0	0.26	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 11:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 12:00	8.09	0.46	ShutDown	ShutDown	ShutDown	GT11 S/D
01/02/2024 13:00	32.29	0.07	94.3	0.4	32.4	
01/02/2024 14:00	34.11	0	94.75	0.4	26.4	
01/02/2024 15:00	34.1	0	94.79	0.4	26	
01/02/2024 16:00	33.92	0	94.76	0.4	25.9	
01/02/2024 17:00	33.76	0	94.53	0.4	25.9	
01/02/2024 18:00	33.61	0	94.23	0.4	26	
01/02/2024 19:00	33.5	0	94.04	0.4	26.8	
01/02/2024 20:00	33.85	0	94.04	0.4	26.2	
01/02/2024 21:00	34.05	0	94.62	0.4	25.8	
01/02/2024 22:00	31.33	0	94.32	0.5	32.5	
01/02/2024 23:00	47.31	0	96.14	0.5	37.2	
02/02/2024 00:00	48.88	0	95.45	0.5	37.3	
Minimum	0	0	94.04	0.4	25.8	
MinDate	01/02/2024 00:00	01/02/2024 00:00	01/02/2024 19:00	01/02/2024 13:00	01/02/2024 21:00	
Maximum	48.88	0.46	96.14	0.5	37.3	
MaxDate	02/02/2024 00:00	01/02/2024 12:00	01/02/2024 23:00	01/02/2024 22:00	02/02/2024 00:00	
Avg	17.55	0.03	94.66	0.4	29	
Num	25	25	12	12	12	
Data1 %1	100	100	48	48	48	
STD	18.5	0.1	0.6	0	4.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
01/02/2024 00:00	48.71	0	95.6	1.1	42.9	
01/02/2024 01:00	48.75	0	96.02	1.1	42.6	
01/02/2024 02:00	48.92	0	96.06	1.1	43.1	
01/02/2024 03:00	48.88	0	96.13	1.2	42.8	
01/02/2024 04:00	48.6	0	96.24	1.2	41.5	
01/02/2024 05:00	48.34	0.03	96.45	1.2	40.3	
01/02/2024 06:00	48.29	0.03	96.53	1.2	39.8	
01/02/2024 07:00	48.31	0	96.59	1.2	39.8	
01/02/2024 08:00	48.54	0.03	96.33	1.2	42.3	
01/02/2024 09:00	48.3	0.09	95.76	1.1	45	
01/02/2024 10:00	47.73	0.07	95.89	1.1	44.9	
01/02/2024 11:00	47.55	0.37	95.86	1	44.5	
01/02/2024 12:00	41.45	0	95.36	1	42	
01/02/2024 13:00	32.2	0	94.18	1	34.8	
01/02/2024 14:00	34.04	0	94.54	1	30.5	
01/02/2024 15:00	34.04	0	94.53	1	30.1	
01/02/2024 16:00	33.85	0.37	94.56	1	30	
01/02/2024 17:00	33.69	0	94.38	1	30.3	
01/02/2024 18:00	33.55	0	94.07	1	31.5	
01/02/2024 19:00	33.45	0	93.97	1	33.7	
01/02/2024 20:00	33.79	0	93.97	1	31.9	
01/02/2024 21:00	33.98	0	94.2	1.1	30.6	
01/02/2024 22:00	31.2	0	93.76	1.1	35.7	
01/02/2024 23:00	1.83	0	ShutDown	ShutDown	ShutDown	GT12 S/D
02/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.76	1	30	
MinDate	02/02/2024 00:00	01/02/2024 00:00	01/02/2024 22:00	01/02/2024 11:00	01/02/2024 16:00	
Maximum	48.92	0.37	96.59	1.2	45	
MaxDate	01/02/2024 02:00	01/02/2024 11:00	01/02/2024 07:00	01/02/2024 03:00	01/02/2024 09:00	
Avg	38.32	0.04	95.26	1.1	37.9	
Num	25	25	23	23	23	
Data1 %1	100	100	92	92	92	
STD	13.4	0.1	1	0.1	5.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/02/2024 00:00	48.88	0	95.45	0.5	37.3	
02/02/2024 01:00	48.96	0	95.81	0.5	37.2	
02/02/2024 02:00	48.97	0	95.78	0.5	37.3	
02/02/2024 03:00	48.98	0	95.78	0.5	37	
02/02/2024 04:00	48.85	0	95.94	0.6	36.2	
02/02/2024 05:00	48.6	0	96.11	0.6	35.2	
02/02/2024 06:00	48.6	0.21	96.21	0.6	34.8	
02/02/2024 07:00	48.41	0	96.35	0.6	34.2	
02/02/2024 08:00	48.65	0	96.07	0.6	36.1	
02/02/2024 09:00	48.37	0	95.71	0.6	36.8	
02/02/2024 10:00	47.86	0	95.64	0.6	37.1	
02/02/2024 11:00	47.48	0	95.89	0.6	36.7	
02/02/2024 12:00	42.98	0.01	96.82	0.5	35.3	
02/02/2024 13:00	32.22	0.03	94.7	0.5	31.6	
02/02/2024 14:00	34.16	0	94.93	0.4	24.5	
02/02/2024 15:00	34.09	0	94.52	0.4	24.2	
02/02/2024 16:00	33.86	0	94.36	0.4	23.8	
02/02/2024 17:00	33.64	0	94.31	0.4	23.6	
02/02/2024 18:00	33.64	0	94.07	0.4	23.7	
02/02/2024 19:00	33.58	0	94.1	0.4	24	
02/02/2024 20:00	33.91	0	94.16	0.4	23.8	
02/02/2024 21:00	34.08	0	94.56	0.4	23.6	
02/02/2024 22:00	37.34	0	96.22	0.5	24.8	
02/02/2024 23:00	37.9	0	96.98	0.5	25.2	
03/02/2024 00:00	26.99	0	93.33	0.5	45	
Minimum	26.99	0	93.33	0.4	23.6	
MinDate	03/02/2024 00:00	02/02/2024 00:00	03/02/2024 00:00	02/02/2024 14:00	02/02/2024 17:00	
Maximum	48.98	0.21	96.98	0.6	45	
MaxDate	02/02/2024 03:00	02/02/2024 06:00	02/02/2024 23:00	02/02/2024 04:00	03/02/2024 00:00	
Avg	41.24	0.01	95.35	0.5	31.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.6	0	1	0.1	6.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 01:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 04:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 08:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 09:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 10:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 11:00	0	0.09	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 12:00	6.54	0.09	ShutDown	ShutDown	ShutDown	GT12 SD
02/02/2024 13:00	32.12	0.07	94.69	1.2	37	
02/02/2024 14:00	34.1	0	94.85	1	33	
02/02/2024 15:00	34.03	0	94.63	1	32.6	
02/02/2024 16:00	33.79	0	94.52	1	32	
02/02/2024 17:00	33.57	0	94.55	1	31.9	
02/02/2024 18:00	33.58	0	94.33	1	32.4	
02/02/2024 19:00	33.51	0	94.37	1	33.7	
02/02/2024 20:00	33.84	0	94.39	1	32.4	
02/02/2024 21:00	34.02	0	94.63	1	31.9	
02/02/2024 22:00	37.28	0	96.28	1.1	31.9	
02/02/2024 23:00	37.83	0	96.97	1.1	31.8	
03/02/2024 00:00	26.94	0	93.45	1.2	43.9	
Minimum	0	0	93.45	1	31.8	
MinDate	02/02/2024 00:00	02/02/2024 00:00	03/02/2024 00:00	02/02/2024 14:00	02/02/2024 23:00	
Maximum	37.83	0.09	96.97	1.2	43.9	
MaxDate	02/02/2024 23:00	02/02/2024 11:00	02/02/2024 23:00	02/02/2024 13:00	03/02/2024 00:00	
Avg	16.45	0.02	94.8	1.1	33.7	
Num	25	16	12	12	12	
Data[%]	100	64	48	48	48	
STD	17.1	0	0.9	0.1	3.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/02/2024 00:00	26.99	0	93.33	0.5	45	
03/02/2024 01:00	28.45	0	92.89	0.5	43.5	
03/02/2024 02:00	31.05	0	93.31	0.5	36.1	
03/02/2024 03:00	31.51	0	93.5	0.5	34.5	
03/02/2024 04:00	31.66	0	93.71	0.5	33.8	
03/02/2024 05:00	31.49	0	93.64	0.6	34.4	
03/02/2024 06:00	31.33	0.44	93.49	0.6	35.1	
03/02/2024 07:00	31.11	0	93.59	0.6	35.9	
03/02/2024 08:00	30.99	0	93.57	0.6	36	
03/02/2024 09:00	31.1	0	93.79	0.5	34.7	
03/02/2024 10:00	31.19	0	93.93	0.5	33.6	
03/02/2024 11:00	31.23	0	94.14	0.5	32.4	
03/02/2024 12:00	31.2	0.02	94.14	0.5	31.6	
03/02/2024 13:00	41.65	0.03	98.45	0.5	30.1	
03/02/2024 14:00	45.27	0.01	102.35	0.5	28.3	
03/02/2024 15:00	45.31	0	102.22	0.4	27.7	
03/02/2024 16:00	45.28	0	102.1	0.4	28	
03/02/2024 17:00	45.27	0	102.03	0.4	27.4	
03/02/2024 18:00	45.28	0	101.94	0.4	27.3	
03/02/2024 19:00	45.24	0	101.66	0.4	27.2	
03/02/2024 20:00	45.23	0	101.43	0.4	26.9	
03/02/2024 21:00	45.27	0	101.83	0.4	26.7	
03/02/2024 22:00	41.68	0	101.08	0.4	28.6	
03/02/2024 23:00	31.07	0	94.02	0.4	34.2	
04/02/2024 00:00	31.04	0	93.08	0.5	34.4	
Minimum	26.99	0	92.89	0.4	26.7	
MinDate	03/02/2024 00:00	03/02/2024 00:00	03/02/2024 01:00	03/02/2024 15:00	03/02/2024 21:00	
Maximum	45.31	0.44	102.35	0.6	45	
MaxDate	03/02/2024 15:00	03/02/2024 06:00	03/02/2024 14:00	03/02/2024 05:00	03/02/2024 00:00	
Avg	36.28	0.02	96.77	0.5	32.5	
Num	25	25	25	25	25	
Data1%	100	100	100	100	100	
STD	7	0.1	4	0.1	4.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/02/2024 00:00	26.94	0	93.45	1.2	43.9	
03/02/2024 01:00	28.39	0	93.06	1.2	42.6	
03/02/2024 02:00	30.99	0	93.48	1.1	43.5	
03/02/2024 03:00	31.45	0	93.63	1.1	43.6	
03/02/2024 04:00	31.6	0	93.82	1.2	43.7	
03/02/2024 05:00	31.43	0	93.72	1.2	43.7	
03/02/2024 06:00	31.27	0	93.54	1.2	43.8	
03/02/2024 07:00	31.04	0	93.62	1.2	43.8	
03/02/2024 08:00	30.93	0	93.66	1.2	43.7	
03/02/2024 09:00	31.04	0.37	93.92	1.1	44.1	
03/02/2024 10:00	31.13	0.2	94.01	1	44.6	
03/02/2024 11:00	31.16	0.17	94.2	1	44.9	
03/02/2024 12:00	31.14	0.22	94.3	1	44.6	
03/02/2024 13:00	41.59	0.24	98.73	0.9	39.7	
03/02/2024 14:00	45.19	0.21	102.42	0.9	36.1	
03/02/2024 15:00	45.23	0.12	102.39	0.9	35.2	
03/02/2024 16:00	45.2	0.1	102.31	0.9	35.6	
03/02/2024 17:00	45.2	0.1	102.29	0.9	35.1	
03/02/2024 18:00	45.2	0.08	102.18	0.9	34.8	
03/02/2024 19:00	45.16	0.04	101.96	0.9	34.5	
03/02/2024 20:00	45.16	0	101.85	1	33.8	
03/02/2024 21:00	45.2	0	101.97	1	33.4	
03/02/2024 22:00	41.63	0	101	1	34.5	
03/02/2024 23:00	31.01	0	94.17	1	42.5	
04/02/2024 00:00	30.98	0	93.26	1.1	42.5	
Minimum	26.94	0	93.06	0.9	33.4	
MinDate	03/02/2024 00:00	03/02/2024 00:00	03/02/2024 01:00	03/02/2024 13:00	03/02/2024 21:00	
Maximum	45.23	0.37	102.42	1.2	44.9	
MaxDate	03/02/2024 15:00	03/02/2024 09:00	03/02/2024 14:00	03/02/2024 00:00	03/02/2024 11:00	
Avg	36.21	0.07	96.92	1	40.3	
Num	25	25	25	25	25	
Data1%	100	100	100	100	100	
STD	7	0.1	4.1	0.1	4.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
04/02/2024 00:00	31.04	0	93.08	0.5	34.4	
04/02/2024 01:00	31.07	0	93.26	0.5	34.2	
04/02/2024 02:00	31.1	0	93.16	0.5	34	
04/02/2024 03:00	31.02	0	93.16	0.5	34.3	
04/02/2024 04:00	31.03	0	93.16	0.5	34.2	
04/02/2024 05:00	30.98	0	93.23	0.5	34.4	
04/02/2024 06:00	30.85	0.34	93.25	0.5	34.6	
04/02/2024 07:00	30.86	0	93.29	0.5	34.7	
04/02/2024 08:00	30.86	0	93.6	0.5	33.9	
04/02/2024 09:00	30.93	0	93.54	0.5	33.4	
04/02/2024 10:00	30.98	0	93.72	0.5	32	
04/02/2024 11:00	30.97	0.01	93.8	0.5	31.4	
04/02/2024 12:00	30.94	0.03	93.87	0.5	30.5	
04/02/2024 13:00	30.97	0.03	93.81	0.5	30.1	
04/02/2024 14:00	31.1	0.01	93.78	0.5	29.1	
04/02/2024 15:00	31.04	0	93.58	0.4	29.4	
04/02/2024 16:00	31.02	0	93.38	0.4	29.7	
04/02/2024 17:00	34.42	0	94.11	0.4	30.3	
04/02/2024 18:00	44.89	0	101.1	0.4	26	
04/02/2024 19:00	44.95	0	101.64	0.4	25.5	
04/02/2024 20:00	44.92	0	101.46	0.4	25.4	
04/02/2024 21:00	34.48	0	96.94	0.4	30.5	
04/02/2024 22:00	30.89	0	93.22	0.4	32.6	
04/02/2024 23:00	30.88	0	92.99	0.4	32.7	
05/02/2024 00:00	30.86	0	93.03	0.4	32.8	
Minimum	30.85	0	92.99	0.4	25.4	
MinDate	04/02/2024 06:00	04/02/2024 00:00	04/02/2024 23:00	04/02/2024 15:00	04/02/2024 20:00	
Maximum	44.95	0.34	101.64	0.5	34.7	
MaxDate	04/02/2024 19:00	04/02/2024 06:00	04/02/2024 19:00	04/02/2024 00:00	04/02/2024 07:00	
Avg	32.92	0.02	94.53	0.5	31.6	
Num	25	25	25	25	25	
Data1 %1	100	100	100	100	100	
STD	4.6	0.1	2.7	0.1	2.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
04/02/2024 00:00	30.98	0	93.26	1.1	42.5	
04/02/2024 01:00	31.01	0	93.44	1.1	42.4	
04/02/2024 02:00	31.03	0	93.33	1.1	42.3	
04/02/2024 03:00	30.96	0	93.33	1.2	42.3	
04/02/2024 04:00	30.97	0	93.31	1.2	42.2	
04/02/2024 05:00	30.9	0.01	93.41	1.2	42.1	
04/02/2024 06:00	30.8	0.08	93.46	1.2	42	
04/02/2024 07:00	30.8	0.06	93.48	1.2	42	
04/02/2024 08:00	30.8	0.07	93.79	1.2	41.7	
04/02/2024 09:00	30.87	0.32	93.83	1.1	42.7	
04/02/2024 10:00	30.9	0.11	93.96	1.1	42.8	
04/02/2024 11:00	30.91	0.19	94.04	1	42.4	
04/02/2024 12:00	30.88	0.2	94.07	1	42.5	
04/02/2024 13:00	30.91	0.18	93.97	0.9	42.7	
04/02/2024 14:00	31.03	0.16	94	0.9	42.3	
04/02/2024 15:00	30.97	0.1	93.78	0.8	41.9	
04/02/2024 16:00	30.96	0.08	93.67	0.8	42	
04/02/2024 17:00	34.36	0.05	94.61	0.8	41.3	
04/02/2024 18:00	44.8	0.04	101.48	0.8	33.1	
04/02/2024 19:00	44.88	0.04	101.84	0.8	32.7	
04/02/2024 20:00	44.84	0.01	101.64	0.9	31.7	
04/02/2024 21:00	34.41	0	96.93	0.9	37.7	
04/02/2024 22:00	30.83	0	93.7	0.9	40.6	
04/02/2024 23:00	30.82	0	93.46	1	40.7	
05/02/2024 00:00	30.8	0	93.52	1	40.6	
Minimum	30.8	0	93.26	0.8	31.7	
MinDate	04/02/2024 06:00	04/02/2024 00:00	04/02/2024 00:00	04/02/2024 15:00	04/02/2024 20:00	
Maximum	44.88	0.32	101.84	1.2	42.8	
MaxDate	04/02/2024 19:00	04/02/2024 09:00	04/02/2024 19:00	04/02/2024 03:00	04/02/2024 10:00	
Avg	32.86	0.07	94.77	1	40.7	
Num	25	25	25	25	25	
Data1 %1	100	100	100	100	100	
STD	4.6	0.1	2.7	0.1	3.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/02/2024 00:00	30.86	0	93.03	0.4	32.8	
05/02/2024 01:00	30.94	0	93.18	0.5	32.4	
05/02/2024 02:00	30.94	0	93.19	0.5	32.1	
05/02/2024 03:00	30.93	0	93.18	0.5	31.8	
05/02/2024 04:00	30.95	0	93.14	0.5	31.7	
05/02/2024 05:00	30.93	0	93.08	0.5	32.2	
05/02/2024 06:00	30.98	0.26	93.03	0.5	32.3	
05/02/2024 07:00	31.08	0	93.19	0.5	31.9	
05/02/2024 08:00	29.74	0.01	93.41	0.5	33.2	
05/02/2024 09:00	2.96	0.05	ShutDown	ShutDown	ShutDown	GT11 S/D
05/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/02/2024 11:00	0	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
05/02/2024 12:00	4.01	0.33	ShutDown	ShutDown	ShutDown	GT11 S/D
05/02/2024 13:00	32.27	0.2	95.55	0.5	34.4	
05/02/2024 14:00	34.31	0.22	95.42	0.5	27.8	
05/02/2024 15:00	34.3	0.13	94.9	0.5	27.6	
05/02/2024 16:00	34.1	0.05	94.64	0.5	27.7	
05/02/2024 17:00	33.98	0.04	94.34	0.5	27.6	
05/02/2024 18:00	33.94	0.03	94.08	0.4	28.1	
05/02/2024 19:00	33.79	0.03	93.73	0.4	27.5	
05/02/2024 20:00	33.95	0	93.75	0.4	26.4	
05/02/2024 21:00	34.1	0	94.15	0.4	26.1	
05/02/2024 22:00	31.53	0	93.99	0.4	31.4	
05/02/2024 23:00	46.84	0	95.9	0.5	37.2	
06/02/2024 00:00	48.83	0	95.4	0.5	37.5	
Minimum	0	0	93.03	0.4	26.1	
MinDate	05/02/2024 10:00	05/02/2024 00:00	05/02/2024 00:00	05/02/2024 00:00	05/02/2024 21:00	
Maximum	48.83	0.33	95.9	0.5	37.5	
MaxDate	06/02/2024 00:00	05/02/2024 12:00	05/02/2024 23:00	05/02/2024 01:00	06/02/2024 00:00	
Avg	28.65	0.06	94.01	0.5	30.9	
Num	25	25	21	21	21	
Data[%]	100	100	84	84	84	
STD	12.8	0.1	0.9	0	3.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/02/2024 00:00	30.8	0	93.52	1	40.6	
05/02/2024 01:00	30.88	0	93.74	1.1	40.5	
05/02/2024 02:00	30.88	0.01	93.75	1.1	40.1	
05/02/2024 03:00	30.88	0.03	93.77	1.1	40	
05/02/2024 04:00	30.89	0.02	93.74	1.1	39.9	
05/02/2024 05:00	30.87	0	93.64	1.1	40.1	
05/02/2024 06:00	30.92	0	93.58	1.2	40.2	
05/02/2024 07:00	31.02	0	93.75	1.2	40.1	
05/02/2024 08:00	29.69	0.01	93.88	1.2	41.3	
05/02/2024 09:00	45.77	0.23	96.39	1.1	37.9	
05/02/2024 10:00	47.66	0.1	95.03	1	39.1	
05/02/2024 11:00	47.34	0.2	95.51	1	39.5	
05/02/2024 12:00	44.17	0.14	95.97	0.9	38.6	
05/02/2024 13:00	32.2	0.09	95.03	0.9	32.7	
05/02/2024 14:00	34.25	0.07	95.67	0.8	27.7	
05/02/2024 15:00	34.25	0.02	95.25	0.7	27.6	
05/02/2024 16:00	34.03	0	95	0.7	27.7	
05/02/2024 17:00	33.91	0	94.73	0.7	27.8	
05/02/2024 18:00	33.87	0	94.54	0.7	28.4	
05/02/2024 19:00	33.72	0	94.27	0.7	28	
05/02/2024 20:00	33.89	0	94.17	0.7	26.8	
05/02/2024 21:00	34.04	3.38	94.42	0.8	26.5	
05/02/2024 22:00	31.46	0	94.15	0.9	31.1	
05/02/2024 23:00	2.25	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.52	0.7	26.5	
MinDate	06/02/2024 00:00	05/02/2024 00:00	05/02/2024 00:00	05/02/2024 15:00	05/02/2024 21:00	
Maximum	47.66	3.38	96.39	1.2	41.3	
MaxDate	05/02/2024 10:00	05/02/2024 21:00	05/02/2024 09:00	05/02/2024 06:00	05/02/2024 08:00	
Avg	31.99	0.17	94.5	0.9	34.9	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	10.8	0.7	0.8	0.2	6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/02/2024 00:00	48.83	0	95.4	0.5	37.5	
06/02/2024 01:00	48.77	0	95.69	0.5	37.2	
06/02/2024 02:00	48.82	0	95.83	0.5	37.1	
06/02/2024 03:00	48.8	0	95.77	0.5	36.9	
06/02/2024 04:00	48.79	0	95.85	0.6	36.8	
06/02/2024 05:00	48.83	0	95.94	0.6	36.8	
06/02/2024 06:00	48.78	0.19	96	0.6	36.4	
06/02/2024 07:00	48.76	0	96.12	0.6	36.4	
06/02/2024 08:00	48.62	0	96.08	0.6	36.5	
06/02/2024 09:00	48.18	0	95.94	0.6	37.2	
06/02/2024 10:00	47.71	0	95.75	0.6	38	
06/02/2024 11:00	47.13	0	95.98	0.6	38.2	
06/02/2024 12:00	42.55	0	96.7	0.6	37.7	
06/02/2024 13:00	32.17	0.03	94.81	0.6	33.4	
06/02/2024 14:00	34.19	0	95.41	0.5	25.9	
06/02/2024 15:00	34.25	0	95.2	0.5	25.9	
06/02/2024 16:00	34.22	0	95.01	0.5	25.6	
06/02/2024 17:00	34.03	0	94.85	0.4	25.4	
06/02/2024 18:00	33.94	0	94.65	0.4	25.5	
06/02/2024 19:00	33.83	0	94.21	0.4	25.3	
06/02/2024 20:00	33.9	0	94.07	0.4	25.1	
06/02/2024 21:00	34.12	0	94.47	0.4	24.7	
06/02/2024 22:00	31.29	0	94.16	0.5	30.7	
06/02/2024 23:00	2.36	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	94.07	0.4	24.7	
MinDate	07/02/2024 00:00	06/02/2024 00:00	06/02/2024 20:00	06/02/2024 17:00	06/02/2024 21:00	
Maximum	48.83	0.19	96.7	0.6	38.2	
MaxDate	06/02/2024 00:00	06/02/2024 06:00	06/02/2024 12:00	06/02/2024 04:00	06/02/2024 11:00	
Avg	38.51	0.01	95.39	0.5	32.6	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.3	0	0.7	0.1	5.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 06:00	0	0.02	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 07:00	0	0.73	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 08:00	0	0.13	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 09:00	0	3.75	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 10:00	0	3.19	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 12:00	6.86	0	ShutDown	ShutDown	ShutDown	GT12 S/D
06/02/2024 13:00	32.19	0	95.25	0.9	30.5	
06/02/2024 14:00	34.34	0	95.63	0.8	32.8	
06/02/2024 15:00	34.2	0	95.31	0.7	32.5	
06/02/2024 16:00	34.15	0	95.14	0.7	32.1	
06/02/2024 17:00	33.96	0	95	0.7	31.9	
06/02/2024 18:00	33.88	0	94.87	0.7	32.1	
06/02/2024 19:00	33.76	0	94.3	0.7	32.2	
06/02/2024 20:00	33.84	0	94.16	0.8	31.9	
06/02/2024 21:00	34.06	<Samp	94.46	0.8	31.4	Reset analyzer.
06/02/2024 22:00	31.27	0.34	94	0.9	35.7	
06/02/2024 23:00	46.83	0.32	96.39	0.9	41.6	
07/02/2024 00:00	48.64	0.33	95.39	0.9	42.4	
Minimum	0	0	94	0.7	31.4	
MinDate	06/02/2024 00:00	06/02/2024 00:00	06/02/2024 22:00	06/02/2024 15:00	06/02/2024 21:00	
Maximum	48.64	3.75	96.39	0.9	42.4	
MaxDate	07/02/2024 00:00	06/02/2024 09:00	06/02/2024 23:00	06/02/2024 13:00	07/02/2024 00:00	
Avg	17.52	0.37	94.99	0.8	34.6	
Num	25	24	12	12	12	
Data[%]	100	96	48	48	48	
STD	18.5	1	0.7	0.1	4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
07/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 06:00	0	0.38	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 11:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 12:00	8.1	0.4	ShutDown	ShutDown	ShutDown	GT11 S/D
07/02/2024 13:00	32.17	0.12	95.57	0.6	33.4	
07/02/2024 14:00	34.22	0.03	95.66	0.6	26.6	
07/02/2024 15:00	34.25	0	95.25	0.5	26.5	
07/02/2024 16:00	34.13	0	95.07	0.5	26.5	
07/02/2024 17:00	34	0	94.82	0.5	26.4	
07/02/2024 18:00	33.93	0	94.56	0.5	26	
07/02/2024 19:00	33.83	0	94.41	0.5	25.8	
07/02/2024 20:00	33.98	0	94.37	0.5	25.6	
07/02/2024 21:00	34.1	0	94.65	0.5	25.4	
07/02/2024 22:00	31.32	0	94.24	0.5	31.1	
07/02/2024 23:00	47.17	0	96.18	0.5	36.3	
08/02/2024 00:00	48.68	0	95.47	0.6	36.7	
Minimum	0	0	94.24	0.5	25.4	
MinDate	07/02/2024 00:00	07/02/2024 00:00	07/02/2024 22:00	07/02/2024 15:00	07/02/2024 21:00	
Maximum	48.68	0.4	96.18	0.6	36.7	
MaxDate	08/02/2024 00:00	07/02/2024 12:00	07/02/2024 23:00	07/02/2024 13:00	08/02/2024 00:00	
Avg	17.6	0.04	95.02	0.5	28.9	
Num	25	25	12	12	23	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.6	0	4.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
07/02/2024 00:00	48.64	0.33	95.39	0.9	42.4	
07/02/2024 01:00	48.81	0.13	95.61	1	42.9	
07/02/2024 02:00	48.86	0.21	95.69	1	42.9	
07/02/2024 03:00	48.85	0.24	95.66	1	42.8	
07/02/2024 04:00	48.82	0.23	95.71	1	42.6	
07/02/2024 05:00	48.73	0.2	95.85	1	41.8	
07/02/2024 06:00	48.82	0.24	96.46	1.1	42	
07/02/2024 07:00	48.59	<Samp	95.69	1.1	40.9	calibration
07/02/2024 08:00	48.56	0.09	95.8	1	42.2	
07/02/2024 09:00	48.04	0.08	95.64	1	43.2	
07/02/2024 10:00	47.42	0.17	95.42	0.9	43.9	
07/02/2024 11:00	47.17	0.22	95.72	0.9	43.7	
07/02/2024 12:00	41.42	0.2	95.58	0.8	41.9	
07/02/2024 13:00	32.21	0.2	95.07	0.8	35	
07/02/2024 14:00	34.16	0.13	95.13	0.8	30.5	
07/02/2024 15:00	34.19	0.06	95.04	0.7	30.5	
07/02/2024 16:00	34.07	0.05	94.95	0.7	30.5	
07/02/2024 17:00	33.93	<Samp	94.81	0.6	30.6	calibration
07/02/2024 18:00	33.86	0.69	94.59	0.7	30.3	
07/02/2024 19:00	33.76	0.22	94.49	0.7	30.1	
07/02/2024 20:00	33.92	0.06	94.32	0.7	30.1	
07/02/2024 21:00	34.04	0.63	94.34	0.8	29.8	
07/02/2024 22:00	31.21	0	93.83	0.9	33.9	
07/02/2024 23:00	1.86	0.35	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 00:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.83	0.6	29.8	
MinDate	08/02/2024 00:00	07/02/2024 22:00	07/02/2024 22:00	07/02/2024 17:00	07/02/2024 21:00	
Maximum	48.86	0.69	96.46	1.1	43.9	
MaxDate	07/02/2024 02:00	07/02/2024 18:00	07/02/2024 06:00	07/02/2024 06:00	07/02/2024 10:00	
Avg	38.4	0.22	95.25	0.9	37.6	
Num	25	22	23	23	23	
Data[%]	100	88	92	92	92	
STD	13.4	0.2	0.6	0.1	5.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
08/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 06:00	0	0.38	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 11:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 12:00	8.1	0.4	ShutDown	ShutDown	ShutDown	GT11 S/D
08/02/2024 13:00	32.17	0.12	95.57	0.6	33.4	
08/02/2024 14:00	34.22	0.03	95.66	0.6	26.6	
08/02/2024 15:00	34.25	0	95.25	0.5	26.5	
08/02/2024 16:00	34.13	0	95.07	0.5	26.5	
08/02/2024 17:00	34	0	94.82	0.5	26.4	
08/02/2024 18:00	33.93	0	94.56	0.5	26	
08/02/2024 19:00	33.83	0	94.41	0.5	25.8	
08/02/2024 20:00	33.98	0	94.37	0.5	25.6	
08/02/2024 21:00	34.1	0	94.65	0.5	25.4	
08/02/2024 22:00	31.32	0	94.24	0.5	31.1	
08/02/2024 23:00	47.17	0	96.18	0.5	36.3	
09/02/2024 00:00	48.68	0	95.47	0.6	36.7	
Minimum	0	0	94.24	0.5	25.4	
MinDate	07/02/2024 00:00	07/02/2024 00:00	07/02/2024 22:00	07/02/2024 15:00	07/02/2024 21:00	
Maximum	48.68	0.4	96.18	0.6	36.7	
MaxDate	08/02/2024 00:00	07/02/2024 12:00	07/02/2024 23:00	07/02/2024 13:00	08/02/2024 00:00	
Avg	17.6	0.04	95.02	0.5	28.9	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.6	0	4.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
08/02/2024 00:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 01:00	0	0.09	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 02:00	0	0.1	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 03:00	0	0.13	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 04:00	0	0.24	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 05:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 06:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 07:00	0	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 08:00	0	0.23	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 09:00	0	0.22	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 10:00	0	0.57	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 11:00	0	0.16	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 12:00	6.43	0.25	ShutDown	ShutDown	ShutDown	GT12 S/D
08/02/2024 13:00	31.95	0.67	94.79	1	37.5	
08/02/2024 14:00	34.11	0.5	95.62	0.8	33.6	
08/02/2024 15:00	33.81	0.3	94.9	0.7	33.4	
08/02/2024 16:00	33.91	<Samp	94.71	0.6	33.4	calibration
08/02/2024 17:00	33.78	<Samp	94.53	0.6	33.4	calibration
08/02/2024 18:00	33.71	0.08	94.22	0.6	33	
08/02/2024 19:00	33.6	0.02	94.03	0.6	32.3	
08/02/2024 20:00	33.63	0	94.13	0.7	32	
08/02/2024 21:00	33.8	0	94.22	0.8	31.3	
08/02/2024 22:00	31.15	0	93.91	0.9	35.6	
08/02/2024 23:00	47.09	0	96.19	0.9	41.3	
09/02/2024 00:00	48.54	0.03	95.28	0.9	41.8	
Minimum	0	0	93.91	0.6	31.3	
MinDate	08/02/2024 00:00	08/02/2024 20:00	08/02/2024 22:00	08/02/2024 16:00	08/02/2024 21:00	
Maximum	48.54	0.67	96.19	1	41.8	
MaxDate	09/02/2024 00:00	08/02/2024 13:00	08/02/2024 23:00	08/02/2024 13:00	09/02/2024 00:00	
Avg	17.42	0.19	94.71	0.8	34.9	
Num	25	20	12	12	12	
Data[%]	100	80	48	48	48	
STD	18.4	0.2	0.7	0.1	3.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
#REF!	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 06:00	0	0.28	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 12:00	7.79	0.24	ShutDown	ShutDown	ShutDown	GT11 S/D
09/02/2024 13:00	32.43	0.01	95.09	0.7	33.5	
09/02/2024 14:00	34.15	0	95.5	0.6	27.9	
09/02/2024 15:00	34.1	0	95.13	0.6	27.5	
09/02/2024 16:00	34.02	0	95.15	0.6	27.3	
09/02/2024 17:00	33.85	0	94.63	0.6	26.7	
09/02/2024 18:00	33.82	0	94.19	0.5	26.5	
09/02/2024 19:00	33.61	0	93.99	0.5	26.3	
09/02/2024 20:00	33.68	0	94.07	0.5	26.2	
09/02/2024 21:00	33.9	0	94.61	0.5	25.9	
09/02/2024 22:00	33.47	0	95.82	0.6	30.2	
09/02/2024 23:00	24.31	0	92.88	0.6	46.6	
10/02/2024 00:00	26.45	0	93.02	0.6	45.8	
Minimum	0	0	92.88	0.5	25.9	
MinDate	09/02/2024 00:00	09/02/2024 00:00	09/02/2024 23:00	09/02/2024 18:00	09/02/2024 21:00	
Maximum	34.15	0.28	95.82	0.7	46.6	
MaxDate	09/02/2024 14:00	09/02/2024 06:00	09/02/2024 22:00	09/02/2024 13:00	09/02/2024 23:00	
Avg	15.82	0.02	94.51	0.6	30.9	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	16.4	0.1	0.9	0.1	7.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
09/02/2024 00:00	48.54	0.03	95.28	0.9	41.8	
09/02/2024 01:00	48.76	0.13	95.57	0.9	42.6	
09/02/2024 02:00	48.81	0.07	95.67	1	42.3	
09/02/2024 03:00	48.76	0.03	95.68	1	42.3	
09/02/2024 04:00	48.78	0.05	95.83	1	42.1	
09/02/2024 05:00	48.72	0.18	95.88	1	41.4	
09/02/2024 06:00	48.58	0.2	96.01	1.1	40.6	
09/02/2024 07:00	48.35	0.15	95.98	1.1	39.8	
09/02/2024 08:00	48.37	0.14	95.96	1	41.3	
09/02/2024 09:00	47.86	0.17	95.43	1	42.6	
09/02/2024 10:00	47.29	<Samp	95.31	0.9	42.7	Calibration
09/02/2024 11:00	47.1	0.46	95.41	0.9	42.9	
09/02/2024 12:00	41.35	0.55	95.26	0.9	41.5	
09/02/2024 13:00	32.34	0.13	94.48	0.8	35.5	
09/02/2024 14:00	34.09	0.1	95.03	0.7	31.3	
09/02/2024 15:00	34.03	0.33	94.58	0.7	30.8	
09/02/2024 16:00	33.95	0.04	94.71	0.7	30.8	
09/02/2024 17:00	33.78	0.34	94.34	0.7	30.2	
09/02/2024 18:00	33.75	0.88	94.06	0.7	30.1	
09/02/2024 19:00	33.54	0.05	93.89	0.7	30.8	
09/02/2024 20:00	33.62	0.33	93.94	0.8	30.9	
09/02/2024 21:00	33.84	0.06	94.27	0.7	29.6	
09/02/2024 22:00	33.41	0.09	95.25	0.8	32.3	
09/02/2024 23:00	24.25	0.37	92.44	0.9	45.8	
10/02/2024 00:00	26.4	0.55	92.42	0.9	43.3	
Minimum	24.25	0.03	92.42	0.7	29.6	
MinDate	09/02/2024 23:00	09/02/2024 00:00	10/02/2024 00:00	09/02/2024 14:00	09/02/2024 21:00	
Maximum	48.81	0.88	96.01	1.1	46.6	
MaxDate	09/02/2024 02:00	09/02/2024 18:00	09/02/2024 06:00	09/02/2024 06:00	09/02/2024 23:00	
Avg	40.33	0.23	94.91	0.9	37.8	
Num	25	24	25	25	25	
Data[%]	100	96	100	100	100	
STD	8.4	0.2	1	0.1	5.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
10/02/2024 00:00	26.45	0	93.02	0.6	43.8	
10/02/2024 01:00	28.83	0	93.7	0.6	43.4	
10/02/2024 02:00	31.36	0	94.2	0.6	35.3	
10/02/2024 03:00	31.74	0	94.38	0.7	34	
10/02/2024 04:00	31.91	0	94.52	0.7	33.4	
10/02/2024 05:00	31.89	0	94.53	0.7	33.5	
10/02/2024 06:00	31.89	0.21	94.5	0.7	33.6	
10/02/2024 07:00	31.61	0	94.44	0.7	34.6	
10/02/2024 08:00	31.67	0	94.63	0.7	34.5	
10/02/2024 09:00	31.99	0	94.83	0.7	33.3	
10/02/2024 10:00	32	0.03	94.72	0.7	31.8	
10/02/2024 11:00	31.92	0	93.84	0.6	33.1	
10/02/2024 12:00	31.8	0	93.69	0.6	33.9	
10/02/2024 13:00	42.12	0	97.78	0.6	32.7	
10/02/2024 14:00	45.82	0	101.19	0.6	31.9	
10/02/2024 15:00	46	0	101.46	0.6	32.3	
10/02/2024 16:00	45.8	0	101.61	0.6	31.7	
10/02/2024 17:00	45.71	0	101.94	0.6	31.2	
10/02/2024 18:00	45.71	0	101.95	0.6	30.4	
10/02/2024 19:00	45.77	0	101.82	0.6	29.5	
10/02/2024 20:00	45.97	0	101.91	0.6	29.5	
10/02/2024 21:00	46.06	0	102.39	0.6	29.4	
10/02/2024 22:00	42.52	0.01	101.4	0.6	31	
10/02/2024 23:00	31.88	0	93.61	0.6	35.3	
11/02/2024 00:00	31.61	0	91.97	0.6	37.3	
Minimum	26.45	0	91.97	0.6	29.4	
MinDate	10/02/2024 00:00	10/02/2024 00:00	11/02/2024 00:00	10/02/2024 00:00	10/02/2024 21:00	
Maximum	46.06	0.21	102.39	0.7	43.8	
MaxDate	10/02/2024 21:00	10/02/2024 06:00	10/02/2024 21:00	10/02/2024 03:00	10/02/2024 00:00	
Avg	36.8	0.01	96.96	0.6	33.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.1	0	3.8	0	3.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
10/02/2024 00:00	26.4	0.55	92.42	0.9	43.3	
10/02/2024 01:00	28.77	0.1	93.1	0.9	41.2	
10/02/2024 02:00	31.3	0.1	93.52	0.9	41.7	
10/02/2024 03:00	31.67	<Samp	93.68	0.9	41.7	Calibration
10/02/2024 04:00	31.85	0.51	93.83	1	41.6	
10/02/2024 05:00	31.82	0.11	93.87	1	41.4	
10/02/2024 06:00	31.83	0.11	93.79	1	41.4	
10/02/2024 07:00	31.55	0.1	93.7	1	41.6	
10/02/2024 08:00	31.6	<Samp	93.87	1	42	Calibration
10/02/2024 09:00	31.93	0.16	94.2	0.9	43.3	
10/02/2024 10:00	31.94	0.24	94.02	0.8	42.7	
10/02/2024 11:00	31.85	0.17	93.1	0.8	43.4	
10/02/2024 12:00	31.74	0.05	92.87	0.8	43.8	
10/02/2024 13:00	42.06	0.07	97.87	0.9	37.4	
10/02/2024 14:00	45.74	0.1	102.32	0.9	34.3	
10/02/2024 15:00	45.92	0.1	102.36	0.9	34.8	
10/02/2024 16:00	45.72	0.15	102.45	0.9	34.2	
10/02/2024 17:00	45.63	0.2	102.94	0.9	33.3	
10/02/2024 18:00	45.63	0.26	102.91	0.8	32.4	
10/02/2024 19:00	45.69	0.25	102.7	0.8	31.4	
10/02/2024 20:00	45.89	0.19	102.82	0.8	31.4	
10/02/2024 21:00	45.98	0.18	103.07	0.8	31.2	
10/02/2024 22:00	42.44	0.22	101.76	0.8	32.8	
10/02/2024 23:00	31.81	0.15	94.19	0.9	44.4	
11/02/2024 00:00	31.55	0.41	92.77	0.9	46.7	
Minimum	26.4	0.05	92.42	0.8	31.2	
MinDate	10/02/2024 00:00	10/02/2024 12:00	10/02/2024 00:00	10/02/2024 10:00	10/02/2024 21:00	
Maximum	45.98	0.55	103.07	1	46.7	
MaxDate	10/02/2024 21:00	10/02/2024 00:00	10/02/2024 21:00	10/02/2024 04:00	11/02/2024 00:00	
Avg	36.73	0.19	96.97	0.9	38.9	
Num	25	25	25	25	25	
Data[%]	100	92	100	100	100	
STD	7.1	0.1	4.4	0.1	5	

Date & Time	11Gt_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/02/2024 00:00	31.61	0	91.97	0.6	37.3	
11/02/2024 01:00	31.55	0	91.65	0.6	38.2	
11/02/2024 02:00	31.42	0	91.51	0.6	39.4	
11/02/2024 03:00	31.22	0	91.55	0.5	40.9	
11/02/2024 04:00	30.84	0	91.03	0.5	43.2	
11/02/2024 05:00	30.59	0	90.74	0.5	44.4	
11/02/2024 06:00	30.44	0.15	90.39	0.5	44.9	
11/02/2024 07:00	30.26	0	90.42	0.5	45.8	
11/02/2024 08:00	30.26	0	90.53	0.5	45.7	
11/02/2024 09:00	30.09	0	90.88	0.5	45.9	
11/02/2024 10:00	30.14	0	91.19	0.5	44.6	
11/02/2024 11:00	30.2	0.01	91.46	0.5	42.4	
11/02/2024 12:00	30.15	0.05	91.79	0.5	41.1	
11/02/2024 13:00	30.19	0.07	91.99	0.5	39.6	
11/02/2024 14:00	30.14	0.09	91.97	0.5	38.9	
11/02/2024 15:00	30.24	0.08	91.88	0.5	38.8	
11/02/2024 16:00	30.18	0.14	91.77	0.4	38.7	
11/02/2024 17:00	33.7	0.08	92.52	0.4	37.8	
11/02/2024 18:00	44.32	0	99.49	0.4	30.5	
11/02/2024 19:00	44.43	0.05	100.38	0.3	29.9	
11/02/2024 20:00	44.41	0	100.31	0.3	29.9	
11/02/2024 21:00	33.92	0.1	95.98	0.3	38.2	
11/02/2024 22:00	30.31	0.01	91.79	0.3	42.9	
11/02/2024 23:00	30.33	0	91.39	0.3	43.1	
12/02/2024 00:00	30.33	0	91.19	0.3	43	
Minimum	30.09	0	90.39	0.3	29.9	
MinDate	11/02/2024 09:00	11/02/2024 00:00	11/02/2024 06:00	11/02/2024 19:00	11/02/2024 19:00	
Maximum	44.43	0.15	100.38	0.6	45.9	
MaxDate	11/02/2024 19:00	11/02/2024 06:00	11/02/2024 19:00	11/02/2024 00:00	11/02/2024 09:00	
Avg	32.45	0.03	92.63	0.5	40.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0	3	0.1	4.7	

Date & Time	12Gt_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/02/2024 00:00	31.55	0.41	92.77	0.9	46.7	
11/02/2024 01:00	31.49	0.06	92.29	0.9	47.4	
11/02/2024 02:00	31.36	0.05	92.21	0.9	47.7	
11/02/2024 03:00	31.16	0.05	92.28	0.9	47.7	
11/02/2024 04:00	30.77	0.05	91.73	0.8	48.3	
11/02/2024 05:00	30.52	0	91.47	0.8	48.2	
11/02/2024 06:00	30.38	0	91.34	0.7	48.2	
11/02/2024 07:00	30.21	0.02	91.24	0.5	48.4	
11/02/2024 08:00	30.19	0.01	91.29	0.3	48.5	
11/02/2024 09:00	30.03	0.04	91.61	0	48.4	
11/02/2024 10:00	30.08	0.1	91.99	0	48	
11/02/2024 11:00	30.14	0.18	92.4	0	47.5	
11/02/2024 12:00	30.09	0.25	92.64	0	47.6	
11/02/2024 13:00	30.14	0.27	92.85	0	47.6	
11/02/2024 14:00	30.08	0.28	92.74	0	47.2	
11/02/2024 15:00	30.18	0.27	92.82	0	47.5	
11/02/2024 16:00	30.12	0.27	92.74	0	47.2	
11/02/2024 17:00	33.62	0.26	93.68	0	45	
11/02/2024 18:00	44.24	0.25	100.54	0	33	
11/02/2024 19:00	44.34	0.23	101.21	0	32.1	
11/02/2024 20:00	44.34	0.2	101.16	0	32.1	
11/02/2024 21:00	33.84	0.19	96.54	0	41.3	
11/02/2024 22:00	30.25	0.18	92.5	0	46.8	
11/02/2024 23:00	30.26	0.11	92.14	0	47.2	
12/02/2024 00:00	30.27	0.39	92.03	0	47.3	
Minimum	30.03	0	91.24	0	32.1	
MinDate	11/02/2024 09:00	11/02/2024 05:00	11/02/2024 07:00	11/02/2024 09:00	11/02/2024 19:00	
Maximum	44.34	0.41	101.21	0.9	48.5	
MaxDate	11/02/2024 19:00	11/02/2024 00:00	11/02/2024 19:00	11/02/2024 00:00	11/02/2024 08:00	
Avg	32.39	0.16	93.45	0.3	45.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0.1	3	0.4	5.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/02/2024 00:00	30.33	0	91.19	0.3	43	
12/02/2024 01:00	30.32	0	90.99	0.2	43.9	
12/02/2024 02:00	30.24	0	91.01	0.2	44.9	
12/02/2024 03:00	30.21	0	90.85	0.2	45.1	
12/02/2024 04:00	30.25	0	90.85	0.2	44.8	
12/02/2024 05:00	30.22	0	90.75	0.1	45	
12/02/2024 06:00	30.25	0.32	90.61	0.1	45.1	
12/02/2024 07:00	30.5	0	90.55	0.1	44	
12/02/2024 08:00	29.51	0	90.45	0.1	44.1	
12/02/2024 09:00	47.19	0	94.77	0.1	34.4	
12/02/2024 10:00	48.22	0	95.2	0.2	36	
12/02/2024 11:00	48.04	0	95.48	0.3	37.1	
12/02/2024 12:00	43.35	0.01	95.84	0.3	37.6	
12/02/2024 13:00	32.04	0.02	93.62	0.3	33.5	
12/02/2024 14:00	34.09	0.02	94.44	0.3	24.9	
12/02/2024 15:00	34.11	0.01	94.23	0.3	25	
12/02/2024 16:00	33.95	0.01	93.82	0.3	24.9	
12/02/2024 17:00	33.74	0	93.47	0.2	24.8	
12/02/2024 18:00	33.65	0	93.17	0.2	24.6	
12/02/2024 19:00	33.54	0	93.01	0.2	24.5	
12/02/2024 20:00	33.64	0	92.93	0.1	24.4	
12/02/2024 21:00	33.86	0	93.33	0.1	24.4	
12/02/2024 22:00	33.21	0	92.88	0.1	31.9	
12/02/2024 23:00	2.49	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	90.45	0.1	24.4	
MinDate	13/02/2024 00:00	12/02/2024 00:00	12/02/2024 08:00	12/02/2024 05:00	12/02/2024 20:00	
Maximum	48.22	0.32	95.84	0.3	45.1	
MaxDate	12/02/2024 10:00	12/02/2024 06:00	12/02/2024 12:00	12/02/2024 00:00	12/02/2024 03:00	
Avg	31.8	0.02	92.78	0.2	35.1	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	10.9	0.1	1.8	0.1	8.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/02/2024 00:00	30.27	0.39	92.03	0	47.3	
12/02/2024 01:00	30.27	0.06	91.64	0	47.7	
12/02/2024 02:00	30.18	0.05	91.9	0	47.8	
12/02/2024 03:00	30.15	0.07	91.84	0	48	
12/02/2024 04:00	30.19	0.08	91.82	0	48.4	
12/02/2024 05:00	30.16	0.09	91.67	0	48.5	
12/02/2024 06:00	30.19	0.08	91.42	0	47.9	
12/02/2024 07:00	30.43	0.07	91.58	0	47.7	
12/02/2024 08:00	28.82	0.08	91.26	0	51.1	
12/02/2024 09:00	1.35	0.1	ShutDown	ShutDown	ShutDown	GT12 S/D
12/02/2024 10:00	0	0.15	ShutDown	ShutDown	ShutDown	GT12 S/D
12/02/2024 11:00	0	0.22	ShutDown	ShutDown	ShutDown	GT12 S/D
12/02/2024 12:00	5.34	0.27	ShutDown	ShutDown	ShutDown	GT12 S/D
12/02/2024 13:00	31.98	0.34	95.14	0	43.2	
12/02/2024 14:00	34.03	0.36	94.4	0	37.7	
12/02/2024 15:00	34.05	0.34	94.38	0	37.8	
12/02/2024 16:00	33.88	0.29	93.91	0	37.3	
12/02/2024 17:00	33.68	0.57	93.57	0	37.5	
12/02/2024 18:00	33.58	<Samp	93.27	0	37.4	Calibration
12/02/2024 19:00	33.47	0.06	93.1	0	37.9	
12/02/2024 20:00	33.57	<Samp	92.99	0	37.9	Calibration
12/02/2024 21:00	33.79	<Samp	93.34	0	36.9	Calibration
12/02/2024 22:00	31.16	0.51	92.72	0	42.4	
12/02/2024 23:00	46.39	0.51	95.02	0	48.2	
13/02/2024 00:00	48.36	<Samp	95.11	0	47.8	Calibration
Minimum	0	0.05	91.26	0	36.9	
MinDate	12/02/2024 10:00	12/02/2024 02:00	12/02/2024 08:00	12/02/2024 00:00	12/02/2024 21:00	
Maximum	48.36	0.87	95.14	0	51.1	
MaxDate	13/02/2024 00:00	12/02/2024 17:00	12/02/2024 13:00	12/02/2024 00:00	12/02/2024 08:00	
Avg	28.21	0.24	92.96	0	43.6	
Num	25	21	21	21	21	
Data[%]	100	84	84	84	84	
STD	12.7	0.2	1.3	0	5.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 06:00	0	0.26	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 12:00	7.88	0.38	ShutDown	ShutDown	ShutDown	GT11 S/D
13/02/2024 13:00	32.18	0.14	94.55	0.3	39.9	
13/02/2024 14:00	34.27	0.08	95.15	0.3	31.1	
13/02/2024 15:00	34.28	0.03	94.81	0.3	30.7	
13/02/2024 16:00	34.13	0.01	94.52	0.3	30.5	
13/02/2024 17:00	34.01	0.03	94.07	0.3	30	
13/02/2024 18:00	33.94	0.04	93.84	0.2	29.6	
13/02/2024 19:00	33.66	0	93.68	0.2	28.6	
13/02/2024 20:00	33.75	0	93.94	0.3	27.9	
13/02/2024 21:00	33.95	0.01	94.74	0.3	27.7	
13/02/2024 22:00	31.29	0.01	94.2	0.4	35.1	
13/02/2024 23:00	46.72	0	95.78	0.5	40.2	
14/02/2024 00:00	48.72	0	95.87	0.5	39.1	
Minimum	0	0	93.68	0.2	27.7	
MinDate	13/02/2024 00:00	13/02/2024 00:00	13/02/2024 19:00	13/02/2024 18:00	13/02/2024 21:00	
Maximum	48.72	0.38	95.87	0.5	40.2	
MaxDate	14/02/2024 00:00	13/02/2024 12:00	14/02/2024 00:00	13/02/2024 23:00	13/02/2024 23:00	
Avg	17.55	0.04	94.6	0.3	32.5	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.7	0.1	4.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/02/2024 00:00	48.36	<Samp	95.11	0	47.8	
13/02/2024 01:00	48.58	<Samp	95.75	0	47.7	
13/02/2024 02:00	48.65	0.39	96	0	47.7	
13/02/2024 03:00	48.57	0.03	96.06	0	47.7	
13/02/2024 04:00	48.46	0.05	96.14	0	47	
13/02/2024 05:00	48.29	0.04	96.32	0	46	
13/02/2024 06:00	48.25	0.04	96.34	0	46	
13/02/2024 07:00	48.16	0.04	96.45	0	45.5	
13/02/2024 08:00	48.25	0.07	95.94	0	48.3	
13/02/2024 09:00	48.16	0.41	95.47	0	49	
13/02/2024 10:00	47.7	0.25	95.39	0	48.1	
13/02/2024 11:00	47.04	0.79	95.61	0	47.8	
13/02/2024 12:00	41.4	0.38	95.11	0	47.6	
13/02/2024 13:00	32.13	0.52	94.09	0	41.6	
13/02/2024 14:00	34.2	<Samp	94.66	0	35.3	Calibration
13/02/2024 15:00	34.22	0.01	94.52	0	34.9	
13/02/2024 16:00	34.07	<Samp	94.29	0	34.5	Calibration
13/02/2024 17:00	33.96	0.73	93.95	0	34	
13/02/2024 18:00	33.86	<Samp	93.74	0	33.6	Calibration
13/02/2024 19:00	33.6	0.32	93.58	0	32.6	
13/02/2024 20:00	33.68	0.06	93.52	0	32	
13/02/2024 21:00	33.88	0.08	94.56	0	31.5	
13/02/2024 22:00	31.22	0.08	93.85	0	37.9	
13/02/2024 23:00	2.46	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 00:00	0	0.43	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0.01	93.58	0	31.5	
MinDate	14/02/2024 00:00	13/02/2024 15:00	13/02/2024 19:00	13/02/2024 00:00	13/02/2024 21:00	
Maximum	48.65	0.79	96.42	0	49	
MaxDate	13/02/2024 02:00	13/02/2024 11:00	13/02/2024 07:00	13/02/2024 00:00	13/02/2024 09:00	
Avg	35.29	0.25	95.06	0	41.9	
Num	25	19	23	23	23	
Data[%]	100	76	92	92	92	
STD	13.2	0.2	1	0	6.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
14/02/2024 00:00	48.72	0	95.87	0.5	39.1	
14/02/2024 01:00	48.87	0	96.72	0.5	38.6	
14/02/2024 02:00	48.94	0	96.95	0.5	38.3	
14/02/2024 03:00	48.91	0	96.97	0.5	37.5	
14/02/2024 04:00	48.86	0	97.02	0.5	37	
14/02/2024 05:00	48.81	0	97.22	0.5	36.5	
14/02/2024 06:00	48.62	0.21	97.2	0.5	36.5	
14/02/2024 07:00	48.4	0	97.38	0.5	36.2	
14/02/2024 08:00	48.5	0	96.86	0.5	39.4	
14/02/2024 09:00	48.09	0	96.56	0.5	40.2	
14/02/2024 10:00	47.12	0	95.85	0.5	40.5	
14/02/2024 11:00	46.74	0	95.92	0.6	40	
14/02/2024 12:00	42.78	0.01	96.65	0.6	40.1	
14/02/2024 13:00	32.17	0.02	94.56	0.6	36.2	
14/02/2024 14:00	34.23	0.03	95.21	0.6	27.3	
14/02/2024 15:00	34.24	0	94.82	0.6	26.1	
14/02/2024 16:00	34.1	0	94.74	0.6	25.9	
14/02/2024 17:00	33.89	0	94.53	0.6	25.3	
14/02/2024 18:00	33.84	0	94.34	0.5	25.1	
14/02/2024 19:00	33.73	0	94.17	0.5	25	
14/02/2024 20:00	33.83	0	94.12	0.6	25	
14/02/2024 21:00	34.03	0	94.74	0.6	25	
14/02/2024 22:00	31.21	0	94.46	0.6	31.7	
14/02/2024 23:00	2.01	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	94.12	0.5	25	
MinDate	15/02/2024 00:00	14/02/2024 00:00	14/02/2024 20:00	14/02/2024 00:00	14/02/2024 19:00	
Maximum	48.94	0.21	97.38	0.6	40.5	
MaxDate	14/02/2024 02:00	14/02/2024 06:00	14/02/2024 07:00	14/02/2024 11:00	14/02/2024 10:00	
Avg	38.43	0.01	95.78	0.5	33.6	
Num	25	25	23	23	23	
Data1 %1	100	100	92	92	92	
STD	13.3	0	1.2	0.1	6.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
14/02/2024 00:00	0	0.43	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 01:00	0	0.12	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 02:00	0	0.07	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 03:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 04:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 05:00	0	0.12	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 06:00	0	0.16	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 07:00	0	0.16	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 08:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 09:00	0	0.28	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 10:00	0	0.35	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 11:00	0	0.33	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 12:00	6.42	0.36	ShutDown	ShutDown	ShutDown	GT12 S/D
14/02/2024 13:00	32.07	0.37	94.13	0	41.9	
14/02/2024 14:00	34.17	0.32	94.86	0	35.7	
14/02/2024 15:00	34.18	0.46	94.66	0	33.6	
14/02/2024 16:00	34.04	<Samp	94.54	0	33.2	Calibration
14/02/2024 17:00	33.82	<Samp	94.41	0	32.3	Calibration
14/02/2024 18:00	33.78	0.06	94.26	0	32.3	
14/02/2024 19:00	33.67	0.05	94.08	0	32.6	
14/02/2024 20:00	33.77	0.06	94.08	0.2	32.7	
14/02/2024 21:00	33.96	0.08	94.51	0.3	32.4	
14/02/2024 22:00	31.26	0.09	94.11	0.4	36.9	
14/02/2024 23:00	47.04	0.1	96.3	0.5	42.9	
15/02/2024 00:00	48.67	0.09	95.52	0.6	43.6	
Minimum	0	0.05	94.08	0	32.3	
MinDate	14/02/2024 00:00	14/02/2024 19:00	14/02/2024 19:00	14/02/2024 13:00	14/02/2024 17:00	
Maximum	48.67	0.46	96.3	0.6	43.6	
MaxDate	15/02/2024 00:00	14/02/2024 15:00	14/02/2024 23:00	15/02/2024 00:00	15/02/2024 00:00	
Avg	17.47	0.19	94.62	0.2	35.8	
Num	25	23	12	12	12	
Data1 %1	100	92	48	48	48	
STD	18.5	0.1	0.7	0.2	4.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
15/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 06:00	0	0.4	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 11:00	0	0.02	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 12:00	0.87	0.22	ShutDown	ShutDown	ShutDown	GT11 S/D
15/02/2024 13:00	25.68	0.13	94.05	0.8	44.1	
15/02/2024 14:00	34.32	0.01	95.13	0.8	26.7	
15/02/2024 15:00	34.32	0	94.46	0.8	26.3	
15/02/2024 16:00	34.08	0	93.99	0.8	26.1	
15/02/2024 17:00	33.91	0	93.8	0.7	26.1	
15/02/2024 18:00	33.85	0	93.69	0.7	26.1	
15/02/2024 19:00	33.71	0	93.49	0.7	26	
15/02/2024 20:00	33.84	0	93.46	0.7	25.9	
15/02/2024 21:00	34.06	0	93.94	0.7	25.8	
15/02/2024 22:00	31.21	0	93.7	0.7	31.9	
15/02/2024 23:00	47.1	0	95.89	0.7	37.2	
16/02/2024 00:00	48.72	0	95.38	0.8	37.8	
Minimum	0	0	93.46	0.7	25.8	
MinDate	15/02/2024 00:00	15/02/2024 00:00	15/02/2024 20:00	15/02/2024 17:00	15/02/2024 21:00	
Maximum	48.72	0.4	95.89	0.8	44.1	
MaxDate	16/02/2024 00:00	15/02/2024 06:00	15/02/2024 23:00	15/02/2024 13:00	15/02/2024 13:00	
Avg	17.03	0.03	94.25	0.7	30	
Num	25	25	12	12	12	
Data1[%]	100	100	48	48	48	
STD	18.5	0.1	0.8	0.1	6.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
15/02/2024 00:00	48.67	0.09	95.52	0.8	43.6	
15/02/2024 01:00	48.8	0.09	95.97	0.8	44	
15/02/2024 02:00	48.84	0.06	96.06	0.7	43.8	
15/02/2024 03:00	48.88	0.07	96.18	0.8	42.8	
15/02/2024 04:00	48.67	0.09	96.2	0.8	41.9	
15/02/2024 05:00	48.59	0.06	96.37	0.8	41.3	
15/02/2024 06:00	48.47	0.05	96.51	0.8	40.3	
15/02/2024 07:00	48.46	0.04	96.54	0.8	40.4	
15/02/2024 08:00	48.58	0.06	96.23	0.9	42.3	
15/02/2024 09:00	48.24	0.14	95.98	0.8	42.5	
15/02/2024 10:00	47.48	<Samp	95.69	0.8	43.1	Error
15/02/2024 11:00	43.36	<Samp	96.43	0.7	39.9	Error
15/02/2024 12:00	46.17	<Samp	95.98	0.7	44.8	Error
15/02/2024 13:00	32.54	<Samp	95.38	0.7	39.9	Error
15/02/2024 14:00	34.25	<Samp	95.38	0.6	29.9	Error
15/02/2024 15:00	34.24	0.31	95.15	0.6	29.5	Error
15/02/2024 16:00	34.01	0.28	94.86	0.6	29.4	Error
15/02/2024 17:00	33.85	0.08	94.76	0.6	29.5	Error
15/02/2024 18:00	33.79	<Samp	94.69	0.6	29.6	Error
15/02/2024 19:00	33.64	0.47	94.53	0.7	29.9	Error
15/02/2024 20:00	33.78	0.08	94.57	0.7	30	Error
15/02/2024 21:00	34	<Samp	94.89	0.7	29.5	Error
15/02/2024 22:00	31.1	0.09	94.44	0.7	34.3	Error
15/02/2024 23:00	1.89	0.05	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 00:00	0	0.05	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0.06	94.38	0.6	29.4	
MinDate	16/02/2024 00:00	15/02/2024 07:00	15/02/2024 13:00	15/02/2024 06:00	15/02/2024 16:00	
Maximum	48.88	0.47	96.54	0.8	44.8	
MaxDate	15/02/2024 13:00	15/02/2024 19:00	15/02/2024 07:00	15/02/2024 07:00	15/02/2024 12:00	
Avg	38.41	0.12	95.54	0.7	37.5	
Num	23	16	23	23	23	
Data1[%]	100	72	92	92	92	
STD	13.3	0.1	0.8	0.1	6.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/02/2024 00:00	48.72	0	95.38	0.8	37.6	
16/02/2024 01:00	48.77	0	95.8	0.8	37.4	
16/02/2024 02:00	48.8	0	95.92	0.8	37.4	
16/02/2024 03:00	48.8	0	96.05	0.8	37.2	
16/02/2024 04:00	48.79	0	96.1	0.8	37	
16/02/2024 05:00	48.68	0	96.06	0.8	36.4	
16/02/2024 06:00	48.6	0.34	96.14	0.8	35.8	
16/02/2024 07:00	48.58	0	96.41	0.8	35.4	
16/02/2024 08:00	48.46	0	96.18	0.8	36.9	
16/02/2024 09:00	48.12	0	96.17	0.8	37.2	
16/02/2024 10:00	47.93	0	96.36	0.8	37.1	
16/02/2024 11:00	47.47	0	95.89	0.8	37	
16/02/2024 12:00	43.68	0	97	0.8	35.2	
16/02/2024 13:00	32.08	0	94.83	0.8	31.1	
16/02/2024 14:00	35.38	0	95.75	0.8	25.5	
16/02/2024 15:00	35.52	0	95.56	0.8	25.1	
16/02/2024 16:00	35.09	0	95.11	0.7	24.8	
16/02/2024 17:00	34.76	0	94.8	0.7	24.6	
16/02/2024 18:00	34.7	0	94.6	0.7	24.4	
16/02/2024 19:00	34.48	0	94.45	0.7	24.3	
16/02/2024 20:00	34.73	0	94.58	0.7	24.2	
16/02/2024 21:00	35.36	0	95.24	0.7	24.3	
16/02/2024 22:00	33.84	0	95.57	0.7	28.9	
16/02/2024 23:00	24.38	0	92.3	0.8	46.3	
17/02/2024 00:00	28.17	0	92.85	0.8	44.4	
Minimum	24.38	0	92.3	0.7	24.2	
MinDate	16/02/2024 23:00	16/02/2024 00:00	16/02/2024 23:00	16/02/2024 16:00	16/02/2024 20:00	
Maximum	48.8	0.34	97	0.8	46.3	
MaxDate	16/02/2024 02:00	16/02/2024 06:00	16/02/2024 12:00	16/02/2024 00:00	16/02/2024 23:00	
Avg	40.96	0.01	95.4	0.8	33	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	8	0.1	1.1	0	6.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/02/2024 00:00	0	0.05	ShutDown	ShutDown	ShutDown	
16/02/2024 01:00	0	0.05	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 02:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 03:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 04:00	0	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 05:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 06:00	0	0.22	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 07:00	0	0.23	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 08:00	0	0.27	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 09:00	0	0.36	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 10:00	0	0.39	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 11:00	0	0.53	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 12:00	5.79	0.34	ShutDown	ShutDown	ShutDown	GT12 S/D
16/02/2024 13:00	32.35	<Samp	95.69	0.9	36.7	Error
16/02/2024 14:00	32.86	<Samp	95.05	0.8	35.6	Error
16/02/2024 15:00	32.65	<Samp	94.57	0.8	36.1	Error
16/02/2024 16:00	32.64	<Samp	94.33	0.7	37.1	Error
16/02/2024 17:00	32.64	<Samp	94.22	0.7	37.6	Error
16/02/2024 18:00	32.65	<Samp	94.13	0.7	38.8	Error
16/02/2024 19:00	32.65	<Samp	94.14	0.8	40.2	Error
16/02/2024 20:00	32.63	<Samp	94.19	0.8	40.9	Error
16/02/2024 21:00	32.63	Maintenance	94.38	0.8	40.9	Error
16/02/2024 22:00	33.41	<Samp	95.48	0.8	35.2	Error
16/02/2024 23:00	24.32	<Samp	92.5	0.9	47.6	Error
17/02/2024 00:00	28.12	0.08	92.94	0.9	43.1	Error
Minimum	0	0.05	92.5	0.7	35.6	
MinDate	16/02/2024 00:00	16/02/2024 00:00	16/02/2024 23:00	16/02/2024 16:00	16/02/2024 14:00	
Maximum	33.41	0.53	95.69	0.9	47.6	
MaxDate	16/02/2024 22:00	16/02/2024 11:00	16/02/2024 13:00	16/02/2024 13:00	16/02/2024 23:00	
Avg	15.41	0.21	94.3	0.8	39.2	
Num	25	14	12	12	12	
Data[%]	100	58	48	48	48	
STD	16	0.1	0.9	0.1	3.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/02/2024 00:00	28.17	0	92.85	0.8	44.4	
17/02/2024 01:00	28.66	0	93.12	0.8	42.4	
17/02/2024 02:00	30.2	0	93.3	0.8	38	
17/02/2024 03:00	31.54	0	93.27	0.8	33.3	
17/02/2024 04:00	31.75	0	93.68	0.8	32.4	
17/02/2024 05:00	31.66	0	93.63	0.8	32.8	
17/02/2024 06:00	31.6	0.28	93.55	0.8	33.3	
17/02/2024 07:00	31.31	0	93.59	0.8	34.3	
17/02/2024 08:00	31.28	0	93.65	0.8	33.9	
17/02/2024 09:00	31.33	0	93.81	0.8	33	
17/02/2024 10:00	31.27	0	93.99	0.8	32.5	
17/02/2024 11:00	31.22	0.03	94.11	0.8	31.5	
17/02/2024 12:00	31.25	0.1	93.7	0.8	31.2	
17/02/2024 13:00	41.63	0.03	98.27	0.8	29.4	
17/02/2024 14:00	32.95	0.03	98.54	0.8	36.8	
17/02/2024 15:00	41.15	0	98.39	0.8	30.8	
17/02/2024 16:00	45.34	0	101.59	0.8	27.2	
17/02/2024 17:00	45.24	0	101.23	0.8	27.4	
17/02/2024 18:00	45.24	0	101.02	0.8	27.4	
17/02/2024 19:00	45.22	0	100.91	0.8	27.3	
17/02/2024 20:00	45.21	0	100.98	0.8	27.1	
17/02/2024 21:00	45.25	0	101.34	0.8	27.2	
17/02/2024 22:00	41.72	0	100.47	0.8	29.5	
17/02/2024 23:00	31.18	0	93.8	0.8	34.1	
18/02/2024 00:00	31.12	0	93.18	0.8	34.4	
Minimum	28.17	0	92.85	0.8	27.1	
MinDate	17/02/2024 00:00	17/02/2024 00:00	17/02/2024 00:00	17/02/2024 00:00	17/02/2024 20:00	
Maximum	45.34	0.28	101.59	0.8	44.4	
MaxDate	17/02/2024 16:00	17/02/2024 06:00	17/02/2024 16:00	17/02/2024 00:00	17/02/2024 00:00	
Avg	35.7	0.02	98.25	0.8	32.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.5	0.1	3.5	0	4.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/02/2024 00:00	28.12	0.08	92.94	0.9	43.1	
17/02/2024 01:00	28.6	0.13	93.17	0.9	42.7	
17/02/2024 02:00	30.14	0.13	93.35	0.9	43.1	
17/02/2024 03:00	31.47	0.08	93.57	0.9	43.5	
17/02/2024 04:00	31.69	0.08	93.64	1	43.5	
17/02/2024 05:00	31.59	0.15	93.61	1	43.5	
17/02/2024 06:00	31.54	0.87	93.53	1	43.8	
17/02/2024 07:00	31.26	0.09	93.5	1	43.7	
17/02/2024 08:00	31.22	0.1	93.55	1	43.8	
17/02/2024 09:00	31.28	0.15	93.8	1	44.5	
17/02/2024 10:00	31.22	0.41	93.97	0.9	45.2	
17/02/2024 11:00	31.16	0.14	94.07	0.8	44.8	
17/02/2024 12:00	31.18	0.36	93.7	0.8	43.6	
17/02/2024 13:00	41.55	0.04	98.43	0.8	37.9	
17/02/2024 14:00	32.92	0.35	99.54	0.8	38.9	
17/02/2024 15:00	41.01	<Samp	100.17	0.8	35.2	Calibrate
17/02/2024 16:00	45.27	<Samp	101.92	0.9	33.6	Calibrate
17/02/2024 17:00	45.16	0.22	101.66	0.9	34	
17/02/2024 18:00	45.17	0.63	101.51	0.9	34	
17/02/2024 19:00	45.15	0.01	101.32	0.9	33.9	
17/02/2024 20:00	45.14	0.01	101.39	0.9	33.5	
17/02/2024 21:00	45.18	0.02	101.57	1	33.6	
17/02/2024 22:00	41.65	0.38	100.6	1	35.3	
17/02/2024 23:00	31.12	0.41	94.29	1	44.3	
18/02/2024 00:00	31.06	0.18	93.57	0.9	44.3	
Minimum	28.12	0.01	92.94	0.8	33.5	
MinDate	17/02/2024 00:00	17/02/2024 19:00	17/02/2024 00:00	17/02/2024 11:00	17/02/2024 20:00	
Maximum	45.27	0.67	101.92	1	45.2	
MaxDate	17/02/2024 16:00	17/02/2024 06:00	17/02/2024 16:00	17/02/2024 04:00	17/02/2024 10:00	
Avg	35.63	0.19	96.49	0.9	40.3	
Num	25	23	25	25	25	
Data[%]	100	92	100	100	100	
STD	6.5	0.2	3.7	0.1	4.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/02/2024 00:00	31.12	0	93.18	0.8	34.4	
18/02/2024 01:00	31.17	0	93.08	0.8	34	
18/02/2024 02:00	31.12	0	93.11	0.8	33.9	
18/02/2024 03:00	31.06	0	93.15	0.8	33.9	
18/02/2024 04:00	31.13	0	93.08	0.8	33.6	
18/02/2024 05:00	31.07	0	93.22	0.8	33.9	
18/02/2024 06:00	31.03	0.21	93.24	0.8	34.2	
18/02/2024 07:00	30.96	0	93.34	0.8	34.4	
18/02/2024 08:00	30.98	0	93.47	0.8	33.9	
18/02/2024 09:00	31.06	0	93.28	0.8	33	
18/02/2024 10:00	31.1	0	93.47	0.8	31.8	
18/02/2024 11:00	31.16	0	93.59	0.7	30.5	
18/02/2024 12:00	31.1	0	93.68	0.7	29.9	
18/02/2024 13:00	31.14	0	93.74	0.7	28.9	
18/02/2024 14:00	31.1	0	93.65	0.7	28.5	
18/02/2024 15:00	31.08	0	93.19	0.7	28.6	
18/02/2024 16:00	31.17	0	92.94	0.6	28.5	
18/02/2024 17:00	34.62	0	93.55	0.6	29.8	
18/02/2024 18:00	45.06	0	100.32	0.6	26	
18/02/2024 19:00	45.12	0	100.85	0.6	25.9	
18/02/2024 20:00	45.06	0	100.82	0.6	25.6	
18/02/2024 21:00	34.68	0	96.68	0.7	30.9	
18/02/2024 22:00	31.1	0	93.15	0.7	32.7	
18/02/2024 23:00	31.02	0	93.11	0.7	33	
19/02/2024 00:00	31.04	0	93.06	0.7	32.8	
Minimum	30.96	0	92.94	0.6	25.6	
MinDate	18/02/2024 07:00	18/02/2024 00:00	18/02/2024 16:00	18/02/2024 16:00	18/02/2024 20:00	
Maximum	45.12	0.21	100.85	0.8	34.4	
MaxDate	18/02/2024 19:00	18/02/2024 06:00	18/02/2024 19:00	18/02/2024 00:00	18/02/2024 00:00	
Avg	33.05	0.01	94.32	0.7	31.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0	2.5	0.1	2.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/02/2024 00:00	31.06	0.18	93.57	0.9	44.3	
18/02/2024 01:00	31.11	0.18	93.44	1	44.2	
18/02/2024 02:00	31.07	0.19	93.46	0.9	43.8	
18/02/2024 03:00	31	0.22	93.47	0.9	43.6	
18/02/2024 04:00	31.07	0.19	93.41	0.9	43.5	
18/02/2024 05:00	31.02	0.16	93.48	0.9	43.4	
18/02/2024 06:00	30.97	0.12	93.46	1	43.5	
18/02/2024 07:00	30.91	0.15	93.6	1	43.5	
18/02/2024 08:00	30.93	0.19	93.74	1	43.7	
18/02/2024 09:00	31.01	0.22	93.66	0.9	44.4	
18/02/2024 10:00	31.04	0.24	93.77	0.8	44.5	
18/02/2024 11:00	31.1	0.27	93.88	0.8	44.8	
18/02/2024 12:00	31.03	0.28	93.9	0.7	44.7	
18/02/2024 13:00	31.08	0.28	94.02	0.7	44.6	
18/02/2024 14:00	31.04	0.26	93.84	0.6	44.5	
18/02/2024 15:00	31.02	0.23	93.43	0.6	44.2	
18/02/2024 16:00	31.11	0.18	93.13	0.6	43.7	
18/02/2024 17:00	34.56	0.14	94.12	0.6	42.2	
18/02/2024 18:00	44.98	0.1	100.56	0.6	32.6	
18/02/2024 19:00	45.04	0.12	101.48	0.6	32.1	
18/02/2024 20:00	44.98	0.1	101.4	0.7	31.7	
18/02/2024 21:00	34.59	0.1	96.95	0.7	39.1	
18/02/2024 22:00	31.05	0.08	93.5	0.8	42.7	
18/02/2024 23:00	30.95	0.33	93.45	0.8	42.6	
19/02/2024 00:00	30.98	0.19	93.43	0.8	42.3	
Minimum	30.91	0.08	93.13	0.6	31.7	
MinDate	18/02/2024 07:00	18/02/2024 22:00	18/02/2024 16:00	18/02/2024 14:00	18/02/2024 20:00	
Maximum	45.04	0.33	101.48	1	44.8	
MaxDate	18/02/2024 19:00	18/02/2024 23:00	18/02/2024 19:00	18/02/2024 01:00	18/02/2024 11:00	
Avg	32.99	0.19	94.66	0.8	42.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0.1	2.6	0.1	4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
19/02/2024 00:00	31.04	0	93.06	0.7	32.8	
19/02/2024 01:00	31.07	0	93.1	0.7	32.6	
19/02/2024 02:00	31.03	0	93.15	0.7	32.6	
19/02/2024 03:00	31.05	0	93.1	0.7	32.6	
19/02/2024 04:00	31.03	0	93.22	0.8	32.6	
19/02/2024 05:00	31.05	0	93.21	0.8	32.6	
19/02/2024 06:00	31.08	0.38	93.22	0.8	32.6	
19/02/2024 07:00	31.27	0	93.44	0.8	31.8	
19/02/2024 08:00	29.99	0	93.65	0.8	32.4	
19/02/2024 09:00	1.9	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
19/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/02/2024 12:00	6.62	0.08	ShutDown	ShutDown	ShutDown	GT11 S/D
19/02/2024 13:00	32.26	0	94.73	0.8	36.1	
19/02/2024 14:00	34.32	0	94.72	0.7	28.5	
19/02/2024 15:00	34.32	0	94.2	0.7	28.1	
19/02/2024 16:00	34.31	0	93.94	0.7	28	
19/02/2024 17:00	34.07	0	93.62	0.7	27.7	
19/02/2024 18:00	33.97	0	93.42	0.7	27.2	
19/02/2024 19:00	33.73	0	93.37	0.7	26.7	
19/02/2024 20:00	33.84	0	93.47	0.7	26.6	
19/02/2024 21:00	33.97	0	93.96	0.7	26.4	
19/02/2024 22:00	31.42	0	93.65	0.7	32	
19/02/2024 23:00	46.67	0	96.17	0.7	38	
20/02/2024 00:00	48.67	0	95.36	0.8	38.2	
Minimum	0	0	93.06	0.7	26.4	
MinDate	19/02/2024 10:00	19/02/2024 00:00	19/02/2024 00:00	19/02/2024 00:00	19/02/2024 21:00	
Maximum	48.67	0.38	96.17	0.8	38.2	
MaxDate	20/02/2024 00:00	19/02/2024 06:00	19/02/2024 23:00	19/02/2024 04:00	20/02/2024 00:00	
Avg	28.76	0.02	93.8	0.7	31.2	
Num	25	25	21	21	23	
Data[%]	100	100	84	84	92	
STD	12.7	0.1	0.8	0	3.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
19/02/2024 00:00	30.98	0.19	93.43	0.8	42.3	
19/02/2024 01:00	31.01	0.22	93.45	0.8	42.3	
19/02/2024 02:00	30.97	0.22	93.5	0.9	42.2	
19/02/2024 03:00	30.98	0.26	93.48	0.9	42.1	
19/02/2024 04:00	30.97	0.04	93.6	0.9	42	
19/02/2024 05:00	30.98	0.05	93.57	0.9	42.1	
19/02/2024 06:00	31.01	0.02	93.56	0.9	42.1	
19/02/2024 07:00	31.21	0.02	93.81	0.9	42	
19/02/2024 08:00	30.18	0.07	93.96	0.9	43.1	
19/02/2024 09:00	46.79	0.05	96.77	0.8	38.2	
19/02/2024 10:00	47.7	0.03	95.61	0.8	39.4	
19/02/2024 11:00	47.14	0.05	95.94	0.8	39.6	
19/02/2024 12:00	41.96	0.07	95.71	0.7	39.7	
19/02/2024 13:00	32.2	0.06	94.61	0.7	34.2	
19/02/2024 14:00	34.26	0.03	94.88	0.7	28.5	
19/02/2024 15:00	34.26	0.02	94.54	0.6	28.3	
19/02/2024 16:00	34.25	0	94.2	0.5	28.1	
19/02/2024 17:00	34.01	0	93.91	0.5	27.9	
19/02/2024 18:00	33.91	0.34	94.02	0.6	27.6	
19/02/2024 19:00	33.67	0.09	93.88	0.6	27.6	
19/02/2024 20:00	33.78	0.08	93.92	0.7	27.6	
19/02/2024 21:00	33.91	0.06	94.15	0.7	27	
19/02/2024 22:00	31.34	0.05	93.67	0.8	31.8	
19/02/2024 23:00	2.09	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 00:00	0	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.43	0.5	27	
MinDate	20/02/2024 00:00	19/02/2024 16:00	19/02/2024 00:00	19/02/2024 16:00	19/02/2024 21:00	
Maximum	47.7	0.34	96.77	0.9	43.1	
MaxDate	19/02/2024 10:00	19/02/2024 09:00	19/02/2024 02:00	19/02/2024 08:00		
Avg	31.98	0.09	94.27	0.8	35.9	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	10.7	0.1	0.9	0.1	6.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/02/2024 00:00	48.67	0	95.36	0.8	38.2	
20/02/2024 01:00	48.74	0	95.74	0.8	38	
20/02/2024 02:00	48.71	0	95.99	0.8	37.7	
20/02/2024 03:00	48.71	0	95.86	0.8	37.4	
20/02/2024 04:00	48.73	0	95.71	0.8	37.3	
20/02/2024 05:00	48.76	0	95.35	0.8	37.3	
20/02/2024 06:00	48.74	0.34	95.4	0.8	37.1	
20/02/2024 07:00	48.68	0	95.54	0.9	37.1	
20/02/2024 08:00	48.33	0	95.26	0.9	37.5	
20/02/2024 09:00	47.83	0	95.17	0.9	37.9	
20/02/2024 10:00	47.34	0	94.99	0.8	38.3	
20/02/2024 11:00	47.09	0	95.25	0.8	37.9	
20/02/2024 12:00	42.23	0.02	95.75	0.8	37.4	
20/02/2024 13:00	32.31	0.02	93.9	0.8	33.2	
20/02/2024 14:00	34.53	0	94.83	0.8	27.1	
20/02/2024 15:00	34.34	0	94.2	0.8	26.9	
20/02/2024 16:00	34.25	0	93.95	0.7	26.8	
20/02/2024 17:00	34.04	0	93.58	0.7	26.2	
20/02/2024 18:00	33.94	0	93.24	0.7	25.7	
20/02/2024 19:00	33.76	0	93.26	0.7	25.3	
20/02/2024 20:00	33.8	0	93.3	0.7	25.1	
20/02/2024 21:00	33.95	0	93.75	0.7	25	
20/02/2024 22:00	31.33	0	93.5	0.7	30.8	
20/02/2024 23:00	2.33	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	93.24	0.7	25	
MinDate	21/02/2024 00:00	20/02/2024 00:00	20/02/2024 18:00	20/02/2024 16:00	20/02/2024 21:00	
Maximum	48.76	0.34	95.99	0.9	38.3	
MaxDate	20/02/2024 05:00	20/02/2024 06:00	20/02/2024 02:00	20/02/2024 07:00	20/02/2024 10:00	
Avg	38.45	0.02	94.73	0.8	33.1	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.5	0.1	1	0.1	5.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/02/2024 00:00	0	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 01:00	0	0.16	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 02:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 03:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 04:00	0	0.13	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 05:00	0	0.13	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 06:00	0	0.19	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 07:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 08:00	0	0.21	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 09:00	0	0.22	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 10:00	0	0.28	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 11:00	0	0.35	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 12:00	7.4	0.39	ShutDown	ShutDown	ShutDown	GT12 S/D
20/02/2024 13:00	32.23	0.33	95.66	0.9	38.6	
20/02/2024 14:00	33.99	0.64	95.27	0.7	35.2	
20/02/2024 15:00	34.27	<Samp	94.9	0.6	34.8	Calibration
20/02/2024 16:00	34.18	0.62	94.62	0.5	34.7	
20/02/2024 17:00	33.97	0.08	94.43	0.5	33.9	
20/02/2024 18:00	33.87	0.43	93.79	0.5	33.3	
20/02/2024 19:00	33.7	0	93.75	0.6	33	
20/02/2024 20:00	33.73	0	93.81	0.7	33.1	
20/02/2024 21:00	33.89	0.02	94.22	0.7	32.8	
20/02/2024 22:00	31.3	0.03	93.86	0.8	37	
20/02/2024 23:00	46.68	0.03	95.98	0.8	42.9	
21/02/2024 00:00	48.52	0.52	95.21	0.8	43.4	
Minimum	0	0	93.75	0.5	32.8	
MinDate	20/02/2024 00:00	20/02/2024 19:00	20/02/2024 19:00	20/02/2024 16:00	20/02/2024 21:00	
Maximum	48.52	0.64	95.98	0.9	43.4	
MaxDate	21/02/2024 00:00	20/02/2024 14:00	20/02/2024 23:00	20/02/2024 13:00	21/02/2024 00:00	
Avg	17.51	0.23	94.62	0.7	36.1	
Num	25	24	12	12	12	
Data[%]	100	96	48	48	48	
STD	18.4	0.2	0.8	0.1	3.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
21/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 06:00	0	0.28	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 12:00	7.62	0.29	ShutDown	ShutDown	ShutDown	GT11 S/D
21/02/2024 13:00	32.28	0	94.92	0.8	35.9	
21/02/2024 14:00	34.3	0	95.41	0.8	28.9	
21/02/2024 15:00	34.37	0	94.91	0.8	28.1	
21/02/2024 16:00	34.26	0	94.79	0.8	28	
21/02/2024 17:00	33.94	0	94.38	0.8	27.3	
21/02/2024 18:00	33.93	0	94.11	0.7	26.7	
21/02/2024 19:00	33.78	0	94.17	0.7	26.4	
21/02/2024 20:00	33.84	0	94.12	0.8	26.1	
21/02/2024 21:00	33.99	0	94.76	0.8	25.9	
21/02/2024 22:00	31.35	0	94.56	0.8	31.7	
21/02/2024 23:00	46.67	0	96.16	0.8	37.7	
22/02/2024 00:00	48.73	0	95.25	0.8	37.8	
Minimum	0	0	94.11	0.7	25.9	
MinDate	21/02/2024 00:00	21/02/2024 00:00	21/02/2024 18:00	21/02/2024 18:00	21/02/2024 21:00	
Maximum	48.73	0.29	96.16	0.8	37.8	
MaxDate	22/02/2024 00:00	21/02/2024 12:00	21/02/2024 23:00	21/02/2024 13:00	22/02/2024 00:00	
Avg	17.57	0.02	94.8	0.8	30	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	18.5	0.1	0.6	0	4.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
21/02/2024 00:00	48.52	0.52	95.21	0.8	43.4	
21/02/2024 01:00	48.69	<Samp	95.33	0.8	43.5	Calibration
21/02/2024 02:00	48.74	0.78	95.54	0.9	43.5	
21/02/2024 03:00	48.69	<Samp	95.58	0.9	43.3	Calibration
21/02/2024 04:00	48.67	0.05	95.57	0.9	42.9	
21/02/2024 05:00	48.48	0.01	95.66	1	41.6	
21/02/2024 06:00	48.44	0	95.76	1		
21/02/2024 07:00	48.35	0	95.92	1	41.3	
21/02/2024 08:00	48.24	0	95.53	0.9	43.1	
21/02/2024 09:00	47.62	0.02	95.23	0.8	44.2	
21/02/2024 10:00	47.08	0.08	95.03	0.8	45	
21/02/2024 11:00	46.9	0.07	95.35	0.7	45.2	
21/02/2024 12:00	41.76	0.08	95.25	0.7	44.2	
21/02/2024 13:00	32.23	0.08	94.4	0.7	38.2	
21/02/2024 14:00	34.23	0.07	94.88	0.6	33.4	
21/02/2024 15:00	34.3	0.06	94.66	0.6	32.6	
21/02/2024 16:00	34.19	0.04	94.39	0.5	32.3	
21/02/2024 17:00	33.88	0	94.03	0.4	31.8	
21/02/2024 18:00	33.86	0	93.61	0.5	31.1	
21/02/2024 19:00	33.71	0	93.66	0.6	30.9	
21/02/2024 20:00	33.78	0	93.66	0.6	30.8	
21/02/2024 21:00	33.92	0	94.2	0.7	30.6	
21/02/2024 22:00	31.28	0	93.93	0.8	35.1	
21/02/2024 23:00	2.13	0	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.61	0.4	30.6	
MinDate	22/02/2024 00:00	21/02/2024 06:00	21/02/2024 18:00	21/02/2024 17:00	21/02/2024 21:00	
Maximum	48.74	0.78	95.92	1	45.2	
MaxDate	21/02/2024 02:00	21/02/2024 02:00	21/02/2024 07:00	21/02/2024 05:00	21/02/2024 11:00	
Avg	38.31	0.08	94.89	0.7	38.7	
Num	25	23	23	23	23	
Data[%]	100	92	92	92	92	
STD	13.2	0.2	0.7	0.2	5.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/02/2024 00:00	48.73	0	95.25	0.8	37.8	
22/02/2024 01:00	48.76	0	95.69	0.9	37.5	
22/02/2024 02:00	48.81	0	95.77	0.9	37.3	
22/02/2024 03:00	48.85	0	95.71	0.9	37.2	
22/02/2024 04:00	48.87	0	95.71	0.9	37	
22/02/2024 05:00	48.75	0	95.83	0.9	36.5	
22/02/2024 06:00	48.75	0.21	95.85	0.9	36.4	
22/02/2024 07:00	48.72	0	95.77	0.9	36.4	
22/02/2024 08:00	48.48	0	95.81	0.9	36.6	
22/02/2024 09:00	48.04	0	95.44	0.9	37.3	
22/02/2024 10:00	47.26	0	95.17	0.9	38.1	
22/02/2024 11:00	46.93	0	95.51	0.9	38.2	
22/02/2024 12:00	42.66	0	96.52	0.9	38.9	
22/02/2024 13:00	32.32	0	94.57	0.9	33.8	
22/02/2024 14:00	34.78	0	95.41	0.9	26.4	
22/02/2024 15:00	34.5	0	95	0.8	26	
22/02/2024 16:00	34.29	0	94.71	0.8	25.8	
22/02/2024 17:00	34.1	0	94.03	0.8	25.8	
22/02/2024 18:00	33.99	0	93.68	0.7	25.3	
22/02/2024 19:00	33.75	0	93.55	0.7	24.9	
22/02/2024 20:00	33.88	0	93.71	0.7	24.8	
22/02/2024 21:00	34.01	0	94.23	0.8	24.5	
22/02/2024 22:00	31.39	0	94.08	0.8	30.3	
22/02/2024 23:00	2.43	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	93.55	0.7	24.5	
MinDate	23/02/2024 00:00	22/02/2024 00:00	22/02/2024 19:00	22/02/2024 18:00	22/02/2024 21:00	
Maximum	48.87	0.21	96.52	0.9	38.9	
MaxDate	22/02/2024 04:00	22/02/2024 06:00	22/02/2024 12:00	22/02/2024 01:00	22/02/2024 12:00	
Avg	38.52	0.01	95.09	0.8	32.7	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.3	0	0.8	0.1	5.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 03:00	0	0.24	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 04:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 05:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 06:00	0	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 07:00	0	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 08:00	0	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 09:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 10:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 11:00	0	0.23	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 12:00	6.78	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
22/02/2024 13:00	32.25	0.44	94.64	0.9	39.6	
22/02/2024 14:00	34.03	0.05	95.1	0.7	34.7	
22/02/2024 15:00	34.43	0.33	95.05	0.7	34	
22/02/2024 16:00	34.25	0.05	94.75	0.6	33.8	
22/02/2024 17:00	34.04	0.04	94.41	0.5	33.7	
22/02/2024 18:00	33.93	0.02	94.13	0.5	33.2	
22/02/2024 19:00	33.69	0	93.95	0.6	32.9	
22/02/2024 20:00	33.8	0	93.98	0.6	32	
22/02/2024 21:00	33.94	0	94.36	0.7	32.3	
22/02/2024 22:00	31.34	0	94.09	0.7	36.3	
22/02/2024 23:00	46.6	0	96.09	0.7	42.7	
23/02/2024 00:00	48.61	0.02	95	0.8	43.6	
Minimum	0	0	93.95	0.5	32.3	
MinDate	22/02/2024 00:00	22/02/2024 00:00	22/02/2024 19:00	22/02/2024 17:00	22/02/2024 21:00	
Maximum	48.61	0.44	96.09	0.9	43.6	
MaxDate	23/02/2024 00:00	22/02/2024 13:00	22/02/2024 23:00	22/02/2024 13:00	23/02/2024 00:00	
Avg	17.51	0.1	94.63	0.7	35.8	
Num	25	24	12	12	12	
Data[%]	100	96	48	48	48	
STD	18.5	0.1	0.6	0.1	3.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 06:00	0	0.15	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 12:00	7.74	0.29	ShutDown	ShutDown	ShutDown	GT11 S/D
23/02/2024 13:00	31.83	0.03	95.28	0.9	27.1	
23/02/2024 14:00	33.76	0.03	95.32	0.9	27.1	
23/02/2024 15:00	33.79	0.01	94.94	0.9	26.8	
23/02/2024 16:00	33.5	0	94.65	0.9	26.9	
23/02/2024 17:00	33.31	0	94.1	0.8	27.1	
23/02/2024 18:00	33.24	0	93.71	0.8	27.1	
23/02/2024 19:00	33.18	0	93.61	0.8	27.8	
23/02/2024 20:00	33.49	0	93.66	0.8	27.1	
23/02/2024 21:00	33.63	0	94.24	0.8	26.6	
23/02/2024 22:00	33.33	0	95.45	0.8	32.6	
23/02/2024 23:00	24.14	0	92.56	0.9	47.7	
24/02/2024 00:00	26.8	0	92.88	0.9	46.9	
Minimum	0	0	92.56	0.8	26.6	
MinDate	23/02/2024 00:00	23/02/2024 00:00	23/02/2024 23:00	23/02/2024 17:00	23/02/2024 21:00	
Maximum	33.79	0.29	95.45	0.9	47.7	
MaxDate	23/02/2024 15:00	23/02/2024 12:00	23/02/2024 22:00	23/02/2024 13:00	23/02/2024 23:00	
Avg	15.67	0.02	94.2	0.9	31.5	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	16.2	0.1	1	0.1	7.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/02/2024 00:00	48.61	0.02	95	0.8	43.6	
23/02/2024 01:00	48.69	0.01	95.28	0.8	43.5	
23/02/2024 02:00	48.71	0.03	95.47	0.8	43.3	
23/02/2024 03:00	48.73	0.23	95.49	0.8	43.1	
23/02/2024 04:00	48.67	0.09	95.53	0.9	42.9	
23/02/2024 05:00	48.33	0.1	95.7	0.9	41.4	
23/02/2024 06:00	48.15	0.1	95.92	0.9	40.6	
23/02/2024 07:00	47.88	0.09	96.05	0.9	39.8	
23/02/2024 08:00	48.03	0.17	95.71	0.9	42.4	
23/02/2024 09:00	47.82	0.17	95.32	2.8	Calib	Calibrate
23/02/2024 10:00	47.42	0.17	95.18	96.2	Calib	Calibrate
23/02/2024 11:00	46.89	0.21	95.46	0	34.5	
23/02/2024 12:00	41.44	0.24	95.74	0	39.7	
23/02/2024 13:00	31.75	0.47	94.74	0	34.6	
23/02/2024 14:00	33.69	<Samp	95.05	0	29.7	waiting for spare part
23/02/2024 15:00	33.72	<Samp	94.89	0	29.4	waiting for spare part
23/02/2024 16:00	33.43	<Samp	94.65	0	29.7	waiting for spare part
23/02/2024 17:00	33.25	Maintenance	94.34	0	30.1	waiting for spare part
23/02/2024 18:00	33.16	<Samp	94.04	0	31.4	waiting for spare part
23/02/2024 19:00	32.12	Audit	93.99	0	33.5	waiting for spare part
23/02/2024 20:00	33.42	0.28	94.01	0	31.9	
23/02/2024 21:00	33.58	0.06	94.19	0	30.7	
23/02/2024 22:00	33.27	0.08	95.17	0	33.7	
23/02/2024 23:00	24.07	0.1	92.23	0	45.8	
24/02/2024 00:00	26.74	0.1	92.4	0	43	
Minimum	24.07	0.01	92.23	0	29.4	
MinDate	23/02/2024 23:00	23/02/2024 01:00	23/02/2024 23:00	23/02/2024 11:00	23/02/2024 15:00	
Maximum	48.73	0.47	96.05	96.2	45.8	
MaxDate	23/02/2024 03:00	23/02/2024 13:00	23/02/2024 07:00	23/02/2024 10:00	23/02/2024 10:00	
Avg	40.1	0.14	94.86	4.3	41.1	
Num	25	19	25	25	25	
Data[%]	100	76	100	100	100	
STD	8.4	0.1	1	19.2	16.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/02/2024 00:00	26.8	0	92.88	0.9	46.9	
24/02/2024 01:00	29.47	0	93.57	0.9	42.7	
24/02/2024 02:00	31.24	0	93.86	0.9	36.9	
24/02/2024 03:00	31.36	0	93.94	0.9	36.4	
24/02/2024 04:00	31.18	0	93.9	1	36.9	
24/02/2024 05:00	31.11	0	93.87	1	37.3	
24/02/2024 06:00	31.11	0.34	94	1	37.3	
24/02/2024 07:00	30.95	0	94.15	1	37.7	
24/02/2024 08:00	30.76	0	94.14	1	37.7	
24/02/2024 09:00	30.88	0	94.31	1	37.3	
24/02/2024 10:00	30.74	0	94.37	1	37.1	
24/02/2024 11:00	30.71	0	94.43	1	37	
24/02/2024 12:00	30.74	0	94.41	0.9	36.2	
24/02/2024 13:00	41.12	0.01	98.69	0.9	32.2	
24/02/2024 14:00	44.84	0	102.3	0.9	30.4	
24/02/2024 15:00	44.88	0	102.07	0.9	29.9	
24/02/2024 16:00	44.9	0	101.76	0.9	29.6	
24/02/2024 17:00	44.8	0	101.67	0.9	29.6	
24/02/2024 18:00	44.79	0	101.47	0.9	29.4	
24/02/2024 19:00	44.78	0	101.32	0.9	29.4	
24/02/2024 20:00	44.71	0	101.11	0.9	29.6	
24/02/2024 21:00	44.69	0	101.33	0.9	29.3	
24/02/2024 22:00	41.17	0	100.49	0.9	31.6	
24/02/2024 23:00	30.78	0	93.58	0.9	37	
25/02/2024 00:00	30.72	0	92.81	0.9	37.3	
Minimum	26.8	0	92.81	0.9	29.3	
MinDate	24/02/2024 00:00	24/02/2024 00:00	25/02/2024 00:00	24/02/2024 00:00	24/02/2024 21:00	
Maximum	44.9	0.34	102.3	1	46.9	
MaxDate	24/02/2024 16:00	24/02/2024 06:00	24/02/2024 14:00	24/02/2024 04:00	24/02/2024 00:00	
Avg	35.97	0.01	96.82	0.9	34.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.9	0.1	3.7	0	4.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/02/2024 00:00	26.74	0.1	92.4	0	43	
24/02/2024 01:00	29.41	0.13	93.1	0	41.8	
24/02/2024 02:00	31.19	0.19	93.4	0	42.2	
24/02/2024 03:00	31.29	0.21	93.46	0	41.9	
24/02/2024 04:00	31.11	0.23	93.42	0	41.7	
24/02/2024 05:00	31.05	0.24	93.36	0	41.6	
24/02/2024 06:00	31.05	0.24	93.46	0	41.7	
24/02/2024 07:00	30.89	0.3	93.58	0	41.6	
24/02/2024 08:00	30.7	0.37	93.64	0	41.6	
24/02/2024 09:00	30.81	0.29	93.71	0	42.8	
24/02/2024 10:00	30.68	0.29	93.74	0	43.6	
24/02/2024 11:00	30.65	0.29	93.78	0	43.9	
24/02/2024 12:00	30.67	<Samp	93.86	0	43.1	waiting for spare part
24/02/2024 13:00	41.05	<Samp	98.58	0	35.1	waiting for spare part
24/02/2024 14:00	44.77	<Samp	102.58	0	31.4	waiting for spare part
24/02/2024 15:00	44.8	0.94	102.44	0	31	waiting for spare part
24/02/2024 16:00	44.82	0.27	102.15	0	30.6	
24/02/2024 17:00	44.72	0.07	102.03	0	30.3	
24/02/2024 18:00	44.71	0.06	101.82	0	30.1	
24/02/2024 19:00	44.7	0.06	101.78	0	30	
24/02/2024 20:00	44.64	0.03	101.66	0	30.2	
24/02/2024 21:00	44.62	0	101.73	0	29.8	
24/02/2024 22:00	41.09	0.2	100.62	0	31.6	
24/02/2024 23:00	30.72	0.08	94.19	0	41.1	
25/02/2024 00:00	30.65	0.09	93.68	0	41.1	
Minimum	26.74	0	92.4	0	29.8	
MinDate	24/02/2024 00:00	24/02/2024 21:00	24/02/2024 00:00	24/02/2024 00:00	24/02/2024 21:00	
Maximum	44.82	0.94	102.58	0	43.9	
MaxDate	24/02/2024 16:00	24/02/2024 15:00	24/02/2024 14:00	24/02/2024 00:00	24/02/2024 11:00	
Avg	35.9	0.21	96.73	0	37.7	
Num	25	22	25	25	25	
Data[%]	100	88	100	100	100	
STD	6.9	0.2	4.1	0	5.7	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG SO2@7%O2	11HRSG NOx@7%O2	Remark
	WW	mg/m3	Degree C	ppm	ppm	
25/02/2024 00:00	30.72	0	92.81	0.9	37.3	
25/02/2024 01:00	30.73	0	92.84	0.9	37.1	
25/02/2024 02:00	30.73	0	92.85	0.9	36.9	
25/02/2024 03:00	30.66	0	92.86	0.9	37	
25/02/2024 04:00	30.72	0	92.78	0.9	37	
25/02/2024 05:00	30.7	0	92.77	1	37.1	
25/02/2024 06:00	30.65	0.28	92.88	1	37.4	
25/02/2024 07:00	30.69	0	92.96	1	37.2	
25/02/2024 08:00	30.79	0	93.15	1	36.4	
25/02/2024 09:00	30.88	0	93.49	1	35.4	
25/02/2024 10:00	29.46	0	93.6	1	36.9	
25/02/2024 11:00	26.96	0.01	91.2	1.2	46.4	
25/02/2024 12:00	46.73	0	93.53	9.4	ShutDown	HRSG11 trip
25/02/2024 13:00	38.16	0	53.89	24.1	ShutDown	HRSG11 trip
25/02/2024 14:00	15.64	0.09	ShutDown	ShutDown	ShutDown	HRSG11 trip
25/02/2024 15:00	28.53	0	92.19	0.9	38.2	
25/02/2024 16:00	30.93	0	93.4	0.9	32.4	
25/02/2024 17:00	34.33	0	94.12	0.9	32.1	
25/02/2024 18:00	44.88	0	100.5	0.9	28	
25/02/2024 19:00	44.91	0	100.65	0.9	27.9	
25/02/2024 20:00	45.26	0	101.01	0.9	27.7	
25/02/2024 21:00	34.8	0	96.72	0.9	32	
25/02/2024 22:00	31.31	0	92.79	0.9	32.8	
25/02/2024 23:00	31.32	0	92.8	0.9	32.9	
26/02/2024 00:00	31.34	0	92.85	0.9	32.9	
Minimum	15.64	0	53.89	0.9	27.7	
MinDate	25/02/2024 14:00	25/02/2024 00:00	25/02/2024 13:00	25/02/2024 00:00	25/02/2024 20:00	
Maximum	46.73	0.28	101.01	24.1	46.4	
MaxDate	25/02/2024 12:00	25/02/2024 06:00	25/02/2024 20:00	25/02/2024 13:00	25/02/2024 13:00	
Avg	32.87	0.02	91.03	2.3	42.7	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	6.7	0.1	10.9	5	29.9	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG SO2@7%O2	12HRSG NOx@7%O2	Remark
	WW	mg/m3	Degree C	ppm	ppm	
25/02/2024 00:00	30.65	0.09	93.68	0	41.1	
25/02/2024 01:00	30.67	0.15	93.71	0	40.9	
25/02/2024 02:00	30.66	0.24	93.79	0	40.8	
25/02/2024 03:00	30.6	0.25	93.75	0	40.5	
25/02/2024 04:00	30.67	0.25	93.67	0	40.6	
25/02/2024 05:00	30.64	0.26	93.66	0	40.7	
25/02/2024 06:00	30.59	0.27	93.76	0	40.7	
25/02/2024 07:00	30.62	0.28	93.81	0	40.4	
25/02/2024 08:00	30.73	0.34	94.09	0	41	
25/02/2024 09:00	30.82	0.41	94.42	0	41.5	
25/02/2024 10:00	33.91	<Samp	95.08	0	33.5	
25/02/2024 11:00	34.34	<Samp	99.91	0	30.2	waiting for spare part
25/02/2024 12:00	2.13	<Samp	ShutDown	ShutDown	ShutDown	GT trip
25/02/2024 13:00	28.92	Maintenance	99.05	0	44.8	waiting for spare part
25/02/2024 14:00	35.29	Maintenance	93.94	0	41.2	waiting for spare part
25/02/2024 15:00	36.89	0.28	95.21	0	33.9	waiting for spare part
25/02/2024 16:00	30.87	0	93.2	0	32.9	waiting for spare part
25/02/2024 17:00	34.27	<Samp	94.05	0	33.6	waiting for spare part
25/02/2024 18:00	44.61	<Samp	101.19	0	32	waiting for spare part
25/02/2024 19:00	44.83	<Samp	101.89	0	31.5	waiting for spare part
25/02/2024 20:00	45.19	<Samp	101.87	0	31.5	waiting for spare part
25/02/2024 21:00	34.76	<Samp	97.37	0	33	waiting for spare part
25/02/2024 22:00	31.25	<Samp	93.61	0	33.4	waiting for spare part
25/02/2024 23:00	31.26	<Samp	93.47	0	33.7	waiting for spare part
26/02/2024 00:00	31.29	<Samp	93.53	0	33.6	waiting for spare part
Minimum	2.13	0	89.05	0	30.2	
MinDate	25/02/2024 12:00	25/02/2024 16:00	25/02/2024 13:00	25/02/2024 00:00	25/02/2024 11:00	
Maximum	45.19	0.41	101.89	0	44.8	
MaxDate	25/02/2024 20:00	25/02/2024 09:00	25/02/2024 19:00	25/02/2024 00:00	25/02/2024 13:00	
Avg	32.27	0.24	95.07	0	37	
Num	25	12	24	24	24	
Data[%]	100	48	96	96	96	
STD	7.9	0.1	3.1	0	4.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/02/2024 00:00	31.34	0	92.85	0.9	32.9	
26/02/2024 01:00	31.34	0	92.9	1	32.9	
26/02/2024 02:00	31.34	0	92.94	1	32.8	
26/02/2024 03:00	31.51	0	92.97	1	32.9	
26/02/2024 04:00	31.28	0	93.03	1	32.8	
26/02/2024 05:00	31.26	0	92.95	1	32.8	
26/02/2024 06:00	31.26	0.21	92.85	1	33	
26/02/2024 07:00	31.39	0	93.1	1	32.4	
26/02/2024 08:00	29.79	0	93.43	1	35.1	
26/02/2024 09:00	45.26	0	95.65	1	34.4	
26/02/2024 10:00	47.62	0	95	1	33.6	
26/02/2024 11:00	46.94	0	95.23	1	33.8	
26/02/2024 12:00	42.51	0	95.59	1	34.3	
26/02/2024 13:00	32.15	0	94.47	1	31.2	
26/02/2024 14:00	34.18	0	95	0.9	22.6	
26/02/2024 15:00	34.21	0	94.65	0.9	22.2	
26/02/2024 16:00	34.15	0	94.6	0.9	22.1	
26/02/2024 17:00	33.96	0	94.23	0.8	22	
26/02/2024 18:00	33.92	0	94.02	0.8	21.8	
26/02/2024 19:00	33.74	0	94.05	0.8	21.6	
26/02/2024 20:00	33.94	0	94.1	0.8	21.7	
26/02/2024 21:00	34.16	0	94.55	0.8	21.9	
26/02/2024 22:00	31.46	0	94.22	0.9	28	
26/02/2024 23:00	2.34	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
27/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	92.85	0.8	21.6	
MinDate	27/02/2024 00:00	26/02/2024 00:00	26/02/2024 00:00	26/02/2024 17:00	26/02/2024 19:00	
Maximum	47.62	0.21	95.65	1	35.1	
MaxDate	26/02/2024 10:00	26/02/2024 06:00	26/02/2024 09:00	26/02/2024 01:00	26/02/2024 08:00	
Avg	32.03	0.01	94.02	0.9	29.1	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	10.6	0	0.9	0.1	5.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/12/2022 00:00	49.08	0.92	97.84	0	44.9	
26/12/2022 01:00	NoData	NoData	NoData	NoData	NoData	Error
26/12/2022 02:00	NoData	NoData	NoData	NoData	NoData	Error
26/02/2024 03:00	31.25	0.09	93.51	0	33.8	
26/02/2024 04:00	31.22	0.16	93.62	0	33.6	
26/02/2024 05:00	31.2	0.24	93.56	0	33.4	
26/02/2024 06:00	31.2	0.24	93.52	0	33.8	
26/02/2024 07:00	31.33	0.23	93.6	0	32.9	
26/02/2024 08:00	29.72	0.27	93.91	0	35.2	
26/02/2024 09:00	3.01	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
26/02/2024 10:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
26/02/2024 11:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
26/02/2024 12:00	5.92	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
26/02/2024 13:00	32.09	<Samp	96.52	0	32.5	
26/02/2024 14:00	34.12	0.45	95.19	0	23.8	
26/02/2024 15:00	34.15	0.06	94.9	0	23.2	
26/02/2024 16:00	34.09	0.03	94.92	0	22.9	
26/02/2024 17:00	33.9	0	94.57	0	22.7	
26/02/2024 18:00	33.85	0	94.35	0	22.3	
26/02/2024 19:00	33.67	0	94.38	0	22.3	
26/02/2024 20:00	33.87	0	94.45	0	22.3	
26/02/2024 21:00	34.09	0	94.71	0	22.6	
26/02/2024 22:00	31.44	0	94.25	0	28.2	
26/02/2024 23:00	46.72	0	96.26	0	40.5	
27/02/2024 00:00	48.7	<Samp	95.23	0	42.4	Calibration
Minimum	0	0	93.5	0	22.3	
MinDate	26/02/2024 10:00	26/02/2024 17:00	26/02/2024 02:00	26/02/2024 00:00	26/02/2024 18:00	
Maximum	48.7	0.45	96.52	0	42.4	
MaxDate	27/02/2024 00:00	26/02/2024 14:00	26/02/2024 13:00	26/02/2024 00:00	27/02/2024 00:00	
Avg	28.78	0.14	94.38	0	30	
Num	25	18	21	21	21	
Data[%]	100	72	84	84	84	
STD	12.7	0.2	0.9	0	6.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 06:00	0	0.44	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 12:00	7.81	0.23	ShutDown	ShutDown	ShutDown	GT11 SD
27/02/2024 13:00	31.19	0	94.57	1	39.7	
27/02/2024 14:00	32.25	0	94.45	1	29.2	
27/02/2024 15:00	32.25	0	94.21	1	31	
27/02/2024 16:00	32.24	0	93.91	1	29.8	
27/02/2024 17:00	32.24	0	93.74	0.9	30.9	
27/02/2024 18:00	32.25	0	93.57	0.9	31.6	
27/02/2024 19:00	32.25	0	93.5	0.9	32.2	
27/02/2024 20:00	32.25	0	93.51	0.9	32.7	
27/02/2024 21:00	32.25	0	93.94	0.9	33	
27/02/2024 22:00	29.83	0	93.71	1	37.6	
27/02/2024 23:00	46.74	0	95.94	1	37.8	
28/02/2024 00:00	48.59	0	95.29	1	38	
Minimum	0	0	93.5	0.9	29.2	
MinDate	27/02/2024 00:00	27/02/2024 00:00	27/02/2024 19:00	27/02/2024 17:00	27/02/2024 14:00	
Maximum	48.59	0.44	95.94		39.7	
MaxDate	28/02/2024 00:00	27/02/2024 06:00	27/02/2024 23:00	27/02/2024 13:00	27/02/2024 13:00	
Avg	16.89	0.03	94.2	1	33.6	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	17.9	0.1	0.8	0.1	3.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/02/2024 00:00	48.7	<Samp	95.23	0	42.4	Calibration
27/02/2024 01:00	48.7	<Samp	95.66	0	42.4	Calibration
27/02/2024 02:00	48.66	<Samp	95.85	0	41.9	Calibration
27/02/2024 03:00	48.75	<Samp	95.9	0	41.7	Calibration
27/02/2024 04:00	48.77	0.89	95.9	0	41.5	
27/02/2024 05:00	48.67	0.1	95.82	0	41.1	
27/02/2024 06:00	48.57	0.41	95.93	0	40.3	
27/02/2024 07:00	48.52	0.28	96.16	0	39.6	
27/02/2024 08:00	48.37	0.15	95.97	0	41	
27/02/2024 09:00	48.13	0.06	95.78	0	41.2	
27/02/2024 10:00	47.41	0.09	95.56	0	41.9	
27/02/2024 11:00	47.04	0.13	95.74	0	42.5	
27/02/2024 12:00	42.28	0.17	95.14	0	41	
27/02/2024 13:00	32.95	0.19	95.1	0	33.2	
27/02/2024 14:00	36.78	0.2	96.07	0	23.1	
27/02/2024 15:00	36.65	0.17	96.06	0	23.9	
27/02/2024 16:00	36.49	0.1	95.8	0	22.5	
27/02/2024 17:00	36.09	0.06	95.41	0	22.3	
27/02/2024 18:00	35.83	0.03	95.19	0	22.2	
27/02/2024 19:00	35.32	0.04	94.52	0	21.8	
27/02/2024 20:00	35.63	0.05	95	0	22	
27/02/2024 21:00	36.07	0.04	95.41	0	22.2	
27/02/2024 22:00	33.19	0	95.02	0	27.5	
27/02/2024 23:00	2.13	0	ShutDown	ShutDown	ShutDown	GT12 SD
28/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 SD
Minimum	0	0	94.92	0	21.8	
MinDate	28/02/2024 00:00	27/02/2024 22:00	27/02/2024 19:00	27/02/2024 00:00	27/02/2024 19:00	
Maximum	48.77	0.89	96.16	0	42.5	
MaxDate	27/02/2024 04:00	27/02/2024 04:00	27/02/2024 07:00	27/02/2024 00:00	27/02/2024 11:00	
Avg	39.19	0.15	95.59	0	33.9	
Num	25	21	23	23	23	
Data[%]	100	84	92	92	92	
STD	13	0.2	0.4	0	9.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/02/2024 00:00	48.59	0	95.29	1	38	
28/02/2024 01:00	48.6	0	95.88	1	37.7	
28/02/2024 02:00	48.67	0	96.01	1	37.6	
28/02/2024 03:00	48.67	0	95.93	1	37.4	
28/02/2024 04:00	48.75	0	95.96	1	37.1	
28/02/2024 05:00	48.66	0	96.03	1.1	37	
28/02/2024 06:00	48.66	0.34	96.04	1.1	37	
28/02/2024 07:00	48.59	0	96.22	1.1	37	
28/02/2024 08:00	48.23	0	96.02	1.1	37	
28/02/2024 09:00	47.77	0	95.97	1.1	37.5	
28/02/2024 10:00	47.28	0	95.81	1.1	37.7	
28/02/2024 11:00	47.01	0	95.81	1.1	37.6	
28/02/2024 12:00	43.2	0	96.59	1	36.8	
28/02/2024 13:00	32.31	0	94.3	1	31.7	
28/02/2024 14:00	34.28	0	94.23	1	24.9	
28/02/2024 15:00	34.3	0	94.68	1	25.2	
28/02/2024 16:00	34.26	0	94.71	1	25.2	
28/02/2024 17:00	34.05	0	94.39	1	25.1	
28/02/2024 18:00	33.99	0	94.12	0.9	24.7	
28/02/2024 19:00	33.84	0	93.9	0.9	24.5	
28/02/2024 20:00	34.03	0	93.93	0.9	24.3	
28/02/2024 21:00	34.19	0	94.49	0.9	24.2	
28/02/2024 22:00	31.47	0	94.17	1	29.9	
28/02/2024 23:00	2.36	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	93.9	0.9	24.2	
MinDate	29/02/2024 00:00	28/02/2024 00:00	28/02/2024 19:00	28/02/2024 18:00	28/02/2024 21:00	
Maximum	48.75	0.34	96.59	1.1	38	
MaxDate	28/02/2024 04:00	28/02/2024 06:00	28/02/2024 12:00	28/02/2024 05:00	28/02/2024 00:00	
Avg	38.47	0.01	95.24	1	32.4	
Num	25	25	23	23	23	
Data[%]	100	100	92	92	92	
STD	13.2	0.1	0.9	0.1	6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 02:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 03:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 04:00	0	0.04	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 05:00	0	0.05	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 06:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 07:00	0	0.28	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 08:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 09:00	0	0.67	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 10:00	0	0.38	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 11:00	0	0.17	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 12:00	6.16	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
28/02/2024 13:00	32.21	<Samp	94.19	0	30.1	GT12 S/D
28/02/2024 14:00	34.22	0.37	94.36	0	23.2	
28/02/2024 15:00	34.24	0.06	94.9	0	23.5	
28/02/2024 16:00	34.19	0.14	94.96	0	23.3	
28/02/2024 17:00	33.99	0.12	94.68	0	23.1	
28/02/2024 18:00	33.92	0.03	94.52	0	22.8	
28/02/2024 19:00	33.77	0	94.32	0	22.6	
28/02/2024 20:00	33.96	0	94.38	0	22.5	
28/02/2024 21:00	34.12	0	94.59	0	22.5	
28/02/2024 22:00	31.44	0	94.19	0	27.9	
28/02/2024 23:00	46.65	0.01	96.21	0	40.1	
29/02/2024 00:00	48.53	0	95.04	0	42.1	
Minimum	0	0	94.19	0	22.5	
MinDate	28/02/2024 00:00	28/02/2024 00:00	28/02/2024 13:00	28/02/2024 13:00	28/02/2024 20:00	
Maximum	48.53	0.67	96.21	0	42.1	
MaxDate	29/02/2024 00:00	28/02/2024 09:00	28/02/2024 23:00	28/02/2024 13:00	29/02/2024 00:00	
Avg	17.5	0.11	94.7	0	27	
Num	25	23	12	12	12	
Data[%]	100	92	48	48	48	
STD	18.5	0.2	0.6	0	7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
29/02/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 06:00	0	0.28	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 12:00	7.71	0.24	ShutDown	ShutDown	ShutDown	GT11 SD
29/02/2024 13:00	32.38	0	94.36	1.1	33.6	
29/02/2024 14:00	34.44	0	95.02	1	26.6	
29/02/2024 15:00	34.37	0	94.76	1	26.8	
29/02/2024 16:00	34.11	0	94.48	1	26.6	
29/02/2024 17:00	33.88	0	94.12	1	26.3	
29/02/2024 18:00	33.83	0	93.85	1	26.2	
29/02/2024 19:00	33.77	0	93.85	1	26	
29/02/2024 20:00	33.91	0	94.05	1	26	
29/02/2024 21:00	33.97	0	94.53	1	25.9	
29/02/2024 22:00	33.95	0	94.56	1	25.8	
29/02/2024 23:00	33.91	0	94.62	1	25.7	
01/03/2024 00:00	36.61	0	94.86	1.1	37.4	
Minimum	0	0	93.85	1	25.7	
MinDate	29/02/2024 00:00	29/02/2024 00:00	29/02/2024 18:00	29/02/2024 14:00	29/02/2024 23:00	
Maximum	36.61	0.28	95.02	1.1	37.4	
MaxDate	01/03/2024 00:00	29/02/2024 06:00	29/02/2024 14:00	29/02/2024 13:00	01/03/2024 00:00	
Avg	16.67	0.02	94.42	1	27.7	
Num	25	25	12	12	12	
Data[%]	100	100	48	48	48	
STD	17.2	0.1	0.4	0	3.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
29/02/2024 00:00	48.53	0	95.04	0	42.1	
29/02/2024 01:00	48.54	0.02	95.41	0	42.1	
29/02/2024 02:00	48.55	0.06	95.64	0	41.9	
29/02/2024 03:00	48.56	0.1	95.71	0	41.8	
29/02/2024 04:00	48.53	0.15	95.67	0	41.6	
29/02/2024 05:00	48.55	0.12	95.69	0	41.4	
29/02/2024 06:00	48.5	0.03	95.71	0	40.4	
29/02/2024 07:00	48.42	0	95.97	0	40.3	
29/02/2024 08:00	48.38	0.02	95.97	0	42.6	
29/02/2024 09:00	47.8	0.12	95.63	0	41.4	
29/02/2024 10:00	47.64	0.08	95.63	0	40.9	
29/02/2024 11:00	47.14	0.13	95.97	0	41.1	
29/02/2024 12:00	41.92	0.13	95.69	0	38.2	
29/02/2024 13:00	32.32	0.06	94.49	0	28.9	
29/02/2024 14:00	34.37	0.27	94.81	0	21.6	
29/02/2024 15:00	34.31	0.1	94.77	0	21.7	
29/02/2024 16:00	34.05	0.17	94.62	0	21.5	
29/02/2024 17:00	33.81	0.14	94.27	0	21.5	
29/02/2024 18:00	33.77	0.08	94.06	0	21.4	
29/02/2024 19:00	33.71	0.05	94.06	0	21.4	
29/02/2024 20:00	33.85	0.06	94.18	0	21.4	
29/02/2024 21:00	33.9	0.08	94.44	0	21.4	
29/02/2024 22:00	33.89	0.08	94.42	0	21.3	
29/02/2024 23:00	33.85	0.12	94.42	0	21.2	
01/03/2024 00:00	16.67	0.15	<Samp	<Samp	<Samp	Error
Minimum	16.67	0	94.05	0	21.2	
MinDate	01/03/2024 00:00	29/02/2024 00:00	29/02/2024 18:00	29/02/2024 00:00	29/02/2024 23:00	
Maximum	48.56	0.27	95.97	0	42.6	
MaxDate	29/02/2024 03:00	29/02/2024 14:00	29/02/2024 07:00	29/02/2024 00:00	29/02/2024 08:00	
Avg	40.38	0.09	95.09	0	32.5	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	8.6	0.1	0.7	0	9.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
01/03/2024 00:00	36.61	0	94.86	1.1	37.4	
01/03/2024 01:00	48.59	0	95.52	1	37.7	
01/03/2024 02:00	48.62	0	95.68	1.1	37.6	
01/03/2024 03:00	48.6	0	95.82	1.1	37.4	
01/03/2024 04:00	48.51	0	95.84	1.1	37	
01/03/2024 05:00	48.2	0	96.08	1.2	35.6	
01/03/2024 06:00	48.27	0.21	96.47	1.2	35.7	
01/03/2024 07:00	48.33	0	96.49	1.2	36.2	
01/03/2024 08:00	34.29	0	95.29	1.2	37.4	
01/03/2024 09:00	34.05	0	94.96	1.1	25.4	
01/03/2024 10:00	34.07	0	95.41	1.1	25.4	
01/03/2024 11:00	33.99	0	95.61	1.1	25.7	
01/03/2024 12:00	21.52	0	92.64	1.2	53.1	
01/03/2024 13:00	34.04	0	95.06	1	27.1	
01/03/2024 14:00	34.05	0	95.43	1	24.8	
01/03/2024 15:00	34	0	94.78	1	24.7	
01/03/2024 16:00	33.69	0	94.46	1	24.4	
01/03/2024 17:00	33.46	0	94.39	1	24.4	
01/03/2024 18:00	33.57	0	94.19	0.9	24.2	
01/03/2024 19:00	33.37	0	93.86	0.9	24.4	
01/03/2024 20:00	33.61	0	93.96	0.9	24.3	
01/03/2024 21:00	33.84	0	94.61	0.9	23.9	
01/03/2024 22:00	37.1	0	96.2	1	24.9	
01/03/2024 23:00	37.86	0	97.24	1	25.2	
02/03/2024 00:00	31.31	0	95.59	1	38.5	
Minimum	21.52	0	92.64	0.9	23.9	
MinDate	01/03/2024 12:00	01/03/2024 00:00	01/03/2024 12:00	01/03/2024 18:00	01/03/2024 21:00	
Maximum	48.62	0.21	97.24	1.2	53.1	
MaxDate	01/03/2024 02:00	01/03/2024 06:00	01/03/2024 23:00	01/03/2024 05:00	01/03/2024 12:00	
Avg	37.73	0.01	95.22	1.1	30.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.4	0	1	0.1	7.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
01/03/2024 00:00	16.67	0.15	<Samp	<Samp	<Samp	GT12 S/D
01/03/2024 01:00	0	0.1	ShutDown	ShutDown	ShutDown	GT12 S/D
01/03/2024 02:00	0	0.12	ShutDown	ShutDown	ShutDown	GT12 S/D
01/03/2024 03:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
01/03/2024 04:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
01/03/2024 05:00	0	0.21	ShutDown	ShutDown	ShutDown	GT12 S/D
01/03/2024 06:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
01/03/2024 07:00	0	0.21	ShutDown	ShutDown	ShutDown	GT12 S/D
01/03/2024 08:00	21.13	0.26	<Samp	<Samp	<Samp	GT12 S/D
01/03/2024 09:00	33.99	0.32	95.09	0	23.8	DUST waiting for spare part
01/03/2024 10:00	34.01	<Samp	95.21	0	23.8	DUST waiting for spare part
01/03/2024 11:00	33.94	<Samp	95.35	0	24	DUST waiting for spare part
01/03/2024 12:00	21.75	<Samp	93.81	0	52.1	DUST waiting for spare part
01/03/2024 13:00	34.01	<Samp	95.02	0	25.2	DUST waiting for spare part
01/03/2024 14:00	34	<Samp	95.19	0	22.9	DUST waiting for spare part
01/03/2024 15:00	33.94	<Samp	94.8	0	22.8	DUST waiting for spare part
01/03/2024 16:00	33.62	<Samp	94.58	0	22.3	DUST waiting for spare part
01/03/2024 17:00	33.39	Maintenance	94.41	0	22.4	DUST waiting for spare part
01/03/2024 18:00	33.31	Maintenance	94.26	0	22.4	DUST waiting for spare part
01/03/2024 19:00	33.3	Maintenance	93.98	0	23.2	DUST waiting for spare part
01/03/2024 20:00	33.55	<Samp	94.02	0	22.8	DUST waiting for spare part
01/03/2024 21:00	33.78	0.08	94.37	0	22.1	DUST waiting for spare part
01/03/2024 22:00	37.05	0.1	95.93	0	23.3	DUST waiting for spare part
01/03/2024 23:00	37.78	0.12	96.92	0	23.6	DUST waiting for spare part
02/03/2024 00:00	31.24	0.17	95.23	0	36.1	DUST waiting for spare part
Minimum	0	0.08	92.81	0	22.1	
MinDate	01/03/2024 01:00	01/03/2024 21:00	01/03/2024 09:00	01/03/2024 12:00	01/03/2024 21:00	
Maximum	37.78	0.32	96.92	0	52.1	
MaxDate	01/03/2024 23:00	01/03/2024 09:00	01/03/2024 23:00	01/03/2024 09:00	01/03/2024 12:00	
Num	22.82	0.17	94.82	0	25.8	
Avg	25	14	16	16	16	
Data[%]	100	56	64	64	64	
STD	15.3	0.1	0.9	0	7.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	HW	mg/m3	Degree C.	ppm	ppm	
02/03/2024 00:00	31.31	0	95.59	1	36.5	
02/03/2024 01:00	30.67	0	93.74	1	36.8	
02/03/2024 02:00	31.66	0	93.81	1	33	
02/03/2024 03:00	31.67	0	93.86	1	32.7	
02/03/2024 04:00	31.35	0	93.82	1	33.6	
02/03/2024 05:00	31.12	0	93.62	1	34.7	
02/03/2024 06:00	31.05	0.15	93.62	1.1	35.1	
02/03/2024 07:00	30.87	0	93.73	1.1	35.4	
02/03/2024 08:00	34.29	0	94.71	1.1	34.3	
02/03/2024 09:00	44.95	0	102.38	1.1	27.6	
02/03/2024 10:00	45.04	0	103.32	1.1	28	
02/03/2024 11:00	45.04	0	103.33	1.1	28.5	
02/03/2024 12:00	31.1	0	95.87	1	31.8	
02/03/2024 13:00	44.88	0	100.1	1	28.9	
02/03/2024 14:00	45.09	0	102.02	1	28	
02/03/2024 15:00	45.1	0	101.13	1	27.8	
02/03/2024 16:00	45.06	0	100.59	1	28	
02/03/2024 17:00	44.91	0	101.23	1	27.6	
02/03/2024 18:00	44.95	0	101.31	1	27.2	
02/03/2024 19:00	45.03	0	101.02	1	26.7	
02/03/2024 20:00	44.99	0	100.86	1	26.5	
02/03/2024 21:00	44.94	0	101.25	1	26.3	
02/03/2024 22:00	44.9	0	101.32	1	26.1	
02/03/2024 23:00	44.82	0	101.22	1	26	
03/03/2024 00:00	34.28	0	96.74	1	32.2	
Minimum	30.67	0	93.62	1	26	
MinDate	02/03/2024 01:00	02/03/2024 00:00	02/03/2024 05:00	02/03/2024 00:00	02/03/2024 23:00	
Maximum	45.1	0.15	103.33	1.1	38.5	
MaxDate	02/03/2024 15:00	02/03/2024 06:00	02/03/2024 11:00	02/03/2024 06:00	02/03/2024 00:00	
Avg	39.16	0.01	98.41	1	30.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.7	0	3.7	0	3.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	HW	mg/m3	Degree C.	ppm	ppm	
02/03/2024 00:00	31.24	0.17	95.23	0	36.1	
02/03/2024 01:00	30.6	0.19	93.5	0	34.7	
02/03/2024 02:00	31.61	0.22	93.57	0	31.5	
02/03/2024 03:00	31.61	0.24	93.6	0	31.3	
02/03/2024 04:00	31.29	0.26	93.59	0	32.2	
02/03/2024 05:00	31.05	0.32	93.4	0	33.1	
02/03/2024 06:00	30.99	0.34	93.39	0	33.4	
02/03/2024 07:00	30.81	0.32	93.49	0	33.6	
02/03/2024 08:00	34.22	0.3	94.51	0	33.5	
02/03/2024 09:00	44.88	0.27	102.05	0	30.2	
02/03/2024 10:00	44.96	0.32	102.97	0	31.3	
02/03/2024 11:00	44.96	0.41	102.99	0	32	
02/03/2024 12:00	30.98	0.41	96.17	0	31	
02/03/2024 13:00	44.83	0.42	101.01	0	32	
02/03/2024 14:00	45.02	0.41	102.76	0	31.2	
02/03/2024 15:00	45.02	0.39	101.92	0	30.4	
02/03/2024 16:00	44.98	0.41	101.51	0	30.3	
02/03/2024 17:00	44.83	0	102.31	0	30.5	
02/03/2024 18:00	44.87	0	102.41	0	29.8	DUST waiting for spare part
02/03/2024 19:00	44.96	Audit	102.16	0	28.8	DUST waiting for spare part
02/03/2024 20:00	44.91	Maintenance	102.05	0	28.4	DUST waiting for spare part
02/03/2024 21:00	44.87	Maintenance	102.11	0	27.8	DUST waiting for spare part
02/03/2024 22:00	44.83	Maintenance	102.15	0	27.5	DUST waiting for spare part
02/03/2024 23:00	44.73	Maintenance	102.08	0	27.3	DUST waiting for spare part
03/03/2024 00:00	34.21	Maintenance	97.46	0	31.1	DUST waiting for spare part
Minimum	30.6	0	93.39	0	27.3	
MinDate	02/03/2024 01:00	02/03/2024 17:00	02/03/2024 06:00	02/03/2024 00:00	02/03/2024 23:00	
Maximum	45.02	0.42	102.99	0	36.1	
MaxDate	02/03/2024 14:00	02/03/2024 13:00	02/03/2024 11:00	02/03/2024 00:00	02/03/2024 00:00	
Avg	39.09	0.28	98.74	0	31.2	
Num	25	19	25	25	25	
Data[%]	100	76	100	100	100	
STD	6.7	0.1	4.1	0	2.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/03/2024 00:00	34.28	0	96.74	1	32.2	
03/03/2024 01:00	30.75	0	92.77	1	34.2	
03/03/2024 02:00	30.8	0	92.65	1	34	
03/03/2024 03:00	30.7	0	92.65	1	34.3	
03/03/2024 04:00	30.74	0	92.69	1	34.1	
03/03/2024 05:00	30.71	0	92.77	1.1	34	
03/03/2024 06:00	30.64	0.36	92.81	1.1	34.3	
03/03/2024 07:00	30.6	0	92.96	1.1	34	
03/03/2024 08:00	30.64	0	93.32	1.1	33.5	
03/03/2024 09:00	30.71	0	93.43	1	32.9	
03/03/2024 10:00	30.66	0	93.55	1	32.3	
03/03/2024 11:00	30.65	0	93.59	1	31.5	
03/03/2024 12:00	30.68	0	93.5	1	30.8	
03/03/2024 13:00	30.68	0	93.47	1	30.5	
03/03/2024 14:00	30.75	0	93.45	1	30.1	
03/03/2024 15:00	30.77	0	93.29	1	29.4	
03/03/2024 16:00	30.8	0	93.18	1	29.4	
03/03/2024 17:00	30.78	0	93.06	0.9	29.8	
03/03/2024 18:00	41.2	0	97.32	0.9	27.3	
03/03/2024 19:00	44.83	0	101.22	1	24.9	
03/03/2024 20:00	42.55	0	99.94	1	24.2	
03/03/2024 21:00	41.18	0	98.92	0.9	23.5	
03/03/2024 22:00	41.16	0	98.94	0.9	23.3	
03/03/2024 23:00	27.26	0	93.52	1	41.6	
04/03/2024 00:00	27.34	0	92.32	1	42.9	
Minimum	27.26	0	92.32	0.9	23.3	
MinDate	03/03/2024 23:00	03/03/2024 00:00	04/03/2024 00:00	03/03/2024 17:00	03/03/2024 22:00	
Maximum	44.83	0.36	101.22	1.1	42.9	
MaxDate	03/03/2024 19:00	03/03/2024 06:00	03/03/2024 19:00	03/03/2024 05:00	04/03/2024 00:00	
Avg	32.87	0.01	94.48	1	31.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.9	0.1	2.6	0.1	4.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/03/2024 00:00	34.21	Maintenance	97.46	0	31.1	DUST waiting for spare part
03/03/2024 01:00	30.69	Maintenance	93.62	0	32.1	DUST waiting for spare part
03/03/2024 02:00	30.75	Maintenance	93.45	0	32	DUST waiting for spare part
03/03/2024 03:00	30.64	Maintenance	93.45	0	32.2	DUST waiting for spare part
03/03/2024 04:00	30.68	Maintenance	93.53	0	32	DUST waiting for spare part
03/03/2024 05:00	30.65	Maintenance	93.57	0	32	DUST waiting for spare part
03/03/2024 06:00	30.58	Maintenance	93.57	0	32.3	DUST waiting for spare part
03/03/2024 07:00	30.54	Maintenance	93.75	0	31.9	DUST waiting for spare part
03/03/2024 08:00	30.59	Maintenance	94.07	0	31.3	DUST waiting for spare part
03/03/2024 09:00	30.65	Maintenance	94.07	0	30.9	DUST waiting for spare part
03/03/2024 10:00	30.58	Maintenance	94.27	0	30.2	DUST waiting for spare part
03/03/2024 11:00	30.59	Maintenance	94.06	0	29.4	DUST waiting for spare part
03/03/2024 12:00	30.62	Maintenance	93.91	0	29	DUST waiting for spare part
03/03/2024 13:00	30.62	Maintenance	93.86	0	28.4	DUST waiting for spare part
03/03/2024 14:00	30.69	Maintenance	93.87	0	28	DUST waiting for spare part
03/03/2024 15:00	30.71	Maintenance	93.8	0	27.3	DUST waiting for spare part
03/03/2024 16:00	30.74	Maintenance	93.78	0	27.2	DUST waiting for spare part
03/03/2024 17:00	30.71	Maintenance	93.65	0	27.7	DUST waiting for spare part
03/03/2024 18:00	41.14	Maintenance	98.15	0	27.9	DUST waiting for spare part
03/03/2024 19:00	44.76	Maintenance	102.03	0	26.3	DUST waiting for spare part
03/03/2024 20:00	42.49	Maintenance	100.61	0	23.7	DUST waiting for spare part
03/03/2024 21:00	41.11	Maintenance	99.34	0	21.8	DUST waiting for spare part
03/03/2024 22:00	41.08	Maintenance	99.36	0	21.7	DUST waiting for spare part
03/03/2024 23:00	27.19	Maintenance	94.01	0	38.1	DUST waiting for spare part
04/03/2024 00:00	27.27	Maintenance	93.91	0	38.8	DUST waiting for spare part
Minimum	27.19	---	92.91	0	21.7	
MinDate	03/03/2024 23:00	03/03/2024 00:00	04/03/2024 00:00	03/03/2024 00:00	03/03/2024 22:00	
Maximum	44.76	---	102.03	0	38.8	
MaxDate	03/03/2024 19:00	03/03/2024 00:00	03/03/2024 19:00	03/03/2024 00:00	04/03/2024 00:00	
Avg	32.81	---	95.13	0	29.7	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.9	---	2.6	0	4.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/03/2024 00:00	27.34	0	92.32	1	42.9	
04/03/2024 01:00	27.31	0	92.18	1	42.8	
04/03/2024 02:00	27.38	0	92.15	1	42.3	
04/03/2024 03:00	27.35	0	92.08	1.1	42.7	
04/03/2024 04:00	27.35	0	92.1	1.1	43	
04/03/2024 05:00	27.37	0	92.11	1.1	42.7	
04/03/2024 06:00	27.38	0.28	92.22	1.1	42.8	
04/03/2024 07:00	27.56	0	92.34	1.1	42.4	
04/03/2024 08:00	30.35	0	93.05	1.1	35.4	
04/03/2024 09:00	33.8	0	94.39	1.1	20.7	
04/03/2024 10:00	33.92	0	94.56	1	20.9	
04/03/2024 11:00	34.06	0	94.76	1	20.8	
04/03/2024 12:00	21.42	0	92.12	1.1	53	
04/03/2024 13:00	34.32	0	94.77	1	23.1	
04/03/2024 14:00	34.16	0	95.18	1	21.1	
04/03/2024 15:00	34.19	0	94.56	0.9	20.7	
04/03/2024 16:00	34.05	0	94.21	0.9	20.8	
04/03/2024 17:00	33.9	0	94.1	0.9	20.7	
04/03/2024 18:00	33.79	0	93.91	0.9	20.7	
04/03/2024 19:00	33.74	0	93.89	0.9	20.5	
04/03/2024 20:00	33.96	0	94.13	0.9	20.3	
04/03/2024 21:00	34.2	0	94.56	0.9	20.4	
04/03/2024 22:00	34.28	0	94.6	0.9	20.4	
04/03/2024 23:00	34.16	0	94.64	0.9	20.3	
05/03/2024 00:00	16.37	0.01	<Samp	<Samp	<Samp	GT11 S/D
Minimum	16.37	0	92.08	0.9	20.3	
MinDate	05/03/2024 00:00	04/03/2024 00:00	04/03/2024 03:00	04/03/2024 15:00	04/03/2024 20:00	
Maximum	34.32	0.28	95.18	1.1	53	
MaxDate	04/03/2024 13:00	04/03/2024 06:00	04/03/2024 14:00	04/03/2024 03:00	04/03/2024 12:00	
Avg	30.55	0.01	93.54	1	30.1	
Num	25	25	24	24	24	
Data (%)	100	100	96	96	96	
STD	4.7	0.1	1.1	0.1	11.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/03/2024 00:00	27.27	Maintenance	92.91	0	38.8	DUST waiting for spare part
04/03/2024 01:00	27.27	Maintenance	92.75	0	38.6	DUST waiting for spare part
04/03/2024 02:00	27.32	Maintenance	92.74	0	38.3	DUST waiting for spare part
04/03/2024 03:00	27.29	Maintenance	92.71	0	38.4	DUST waiting for spare part
04/03/2024 04:00	27.29	Maintenance	92.72	0	38.7	DUST waiting for spare part
04/03/2024 05:00	27.32	Maintenance	92.7	0	38.4	DUST waiting for spare part
04/03/2024 06:00	27.32	Maintenance	92.79	0	38.6	DUST waiting for spare part
04/03/2024 07:00	27.5	Maintenance	92.92	0	38.1	DUST waiting for spare part
04/03/2024 08:00	30.3	Maintenance	93.73	0	32.3	DUST waiting for spare part
04/03/2024 09:00	33.74	Maintenance	94.89	0	18.8	DUST waiting for spare part
04/03/2024 10:00	33.86	Maintenance	95.06	0	18.9	DUST waiting for spare part
04/03/2024 11:00	34	Maintenance	95.18	0	18.7	DUST waiting for spare part
04/03/2024 12:00	21.12	Maintenance	92.58	0	52.1	DUST waiting for spare part
04/03/2024 13:00	34.25	Maintenance	95.01	0	21.1	DUST waiting for spare part
04/03/2024 14:00	34.09	Maintenance	95.35	0	19.1	DUST waiting for spare part
04/03/2024 15:00	34.12	Maintenance	94.75	0	18.5	DUST waiting for spare part
04/03/2024 16:00	33.59	Maintenance	94.45	0	18.7	DUST waiting for spare part
04/03/2024 17:00	33.84	Maintenance	94.37	0	18.5	DUST waiting for spare part
04/03/2024 18:00	33.72	Maintenance	94.05	0	18.3	DUST waiting for spare part
04/03/2024 19:00	33.68	Maintenance	94.02	0	18.2	DUST waiting for spare part
04/03/2024 20:00	33.9	Maintenance	94.32	0	18.1	DUST waiting for spare part
04/03/2024 21:00	34.13	Maintenance	94.72	0	18.2	DUST waiting for spare part
04/03/2024 22:00	34.21	Maintenance	94.79	0	18.1	DUST waiting for spare part
04/03/2024 23:00	34.11	Maintenance	94.75	0	18	DUST waiting for spare part
05/03/2024 00:00	36.65	Maintenance	95.14	0	31.4	DUST waiting for spare part
Minimum	21.12	---	92.58	0	18	
MinDate	04/03/2024 12:00	04/03/2024 00:00	04/03/2024 12:00	04/03/2024 00:00	04/03/2024 23:00	
Maximum	36.65	---	95.35	0	52.1	
MaxDate	05/03/2024 00:00	04/03/2024 00:00	04/03/2024 14:00	04/03/2024 00:00	04/03/2024 12:00	
Avg	31.29	---	93.98	0	27.4	
Num	25	0	25	25	25	
Data (%)	100	---	100	100	100	
STD	3.9	---	1	0	10.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/03/2024 00:00	16.37	0.01	<Samp	<Samp	<Samp	GT11 S/D
05/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/03/2024 06:00	0	0.21	ShutDown	ShutDown	ShutDown	GT11 S/D
05/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
05/03/2024 08:00	20.42	0.09	<Samp	<Samp	<Samp	GT11 S/D
05/03/2024 09:00	34.27	0	94.5	1	27.4	
05/03/2024 10:00	34.12	0	94.79	1	27.5	
05/03/2024 11:00	34.1	0.04	94.93	1	27.5	
05/03/2024 12:00	21.71	0.21	92.32	1.1	52.2	
05/03/2024 13:00	35.65	0.01	95.4	1	29.9	
05/03/2024 14:00	36.38	0	96.5	1	28.5	
05/03/2024 15:00	36.37	0	96.24	1	28.5	
05/03/2024 16:00	36.07	0	95.79	1	28.6	
05/03/2024 17:00	35.64	0	95.15	1	27.3	
05/03/2024 18:00	35.7	0	95	0.9	27	
05/03/2024 19:00	35.44	0	94.73	0.9	26.6	
05/03/2024 20:00	35.75	0	94.74	0.9	26.4	
05/03/2024 21:00	36.17	0	95.34	0.9	26.5	
05/03/2024 22:00	36.19	0	95.6	1	26.3	
05/03/2024 23:00	35.81	0	95.55	1	26.1	
06/03/2024 00:00	36.79	0	94.68	1	36.4	
Minimum	0	0	92.32	0.9	26.1	
MinDate	05/03/2024 01:00	05/03/2024 01:00	05/03/2024 12:00	05/03/2024 18:00	05/03/2024 23:00	
Maximum	36.79	0.21	96.5	1.1	52.2	
MaxDate	06/03/2024 00:00	05/03/2024 06:00	05/03/2024 14:00	05/03/2024 12:00	05/03/2024 12:00	
Avg	23.72	0.02	95.1	1	29.5	
Num	25	25	16	16	16	
Data(%)	100	100	64	64	64	
STD	16	0.1	0.9	0.1	6.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/03/2024 00:00	36.65	Maintenance	95.14	0	31.4	DUST waiting for spare part
05/03/2024 01:00	48.35	Maintenance	95.51	0	34.6	DUST waiting for spare part
05/03/2024 02:00	48.38	Maintenance	95.06	0	34.4	DUST waiting for spare part
05/03/2024 03:00	48.5	Maintenance	95.35	0	34.3	DUST waiting for spare part
05/03/2024 04:00	48.42	Maintenance	95.5	0	33.8	DUST waiting for spare part
05/03/2024 05:00	48.16	Maintenance	95.55	0	32.2	DUST waiting for spare part
05/03/2024 06:00	48.26	Maintenance	95.99	0	32.8	DUST waiting for spare part
05/03/2024 07:00	48.15	Maintenance	95.93	0	32.3	DUST waiting for spare part
05/03/2024 08:00	34.81	Maintenance	95.32	0	31.2	DUST waiting for spare part
05/03/2024 09:00	34.22	Maintenance	95.39	0	18.1	DUST waiting for spare part
05/03/2024 10:00	34.06	Maintenance	95.66	0	18	DUST waiting for spare part
05/03/2024 11:00	34.05	Maintenance	95.78	0	18	DUST waiting for spare part
05/03/2024 12:00	21.34	Maintenance	92.84	0	49.7	DUST waiting for spare part
05/03/2024 13:00	32.83	Maintenance	95.03	0	21.5	DUST waiting for spare part
05/03/2024 14:00	31.97	Maintenance	94.99	0	10.5	DUST waiting for spare part
05/03/2024 15:00	31.97	Maintenance	94.82	0	19.3	DUST waiting for spare part
05/03/2024 16:00	31.97	Maintenance	94.49	0	19.4	DUST waiting for spare part
05/03/2024 17:00	31.97	Maintenance	94.24	0	19.9	DUST waiting for spare part
05/03/2024 18:00	31.97	<Samp	94.01	0	20.9	DUST waiting for spare part
05/03/2024 19:00	31.97	0.04	93.83	0	21.5	DUST waiting for spare part
05/03/2024 20:00	31.96	0.01	93.78	0	22	DUST waiting for spare part
05/03/2024 21:00	31.95	0.01	94.04	0	22.3	DUST waiting for spare part
05/03/2024 22:00	31.96	0.05	94.26	0	22.3	DUST waiting for spare part
05/03/2024 23:00	32.26	0.08	94.34	0	21.6	DUST waiting for spare part
06/03/2024 00:00	16.09	0.13	<Samp	<Samp	<Samp	DUST waiting for spare part
Minimum	16.09	0.01	92.84	0	18	
MinDate	06/03/2024 00:00	05/03/2024 20:00	05/03/2024 12:00	05/03/2024 00:00	05/03/2024 10:00	
Maximum	48.5	0.13	95.99	0	49.7	
MaxDate	05/03/2024 03:00	06/03/2024 00:00	05/03/2024 06:00	05/03/2024 00:00	05/03/2024 12:00	
Avg	36.09	0.05	94.67	0	26.3	
Num	25	6	24	24	24	
Data(%)	100	24	96	96	96	
STD	8.8	0	0.8	0	8.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/03/2024 00:00	36.79	0	94.68	1	36.4	
06/03/2024 01:00	48.36	0	95.63	1	36.8	
06/03/2024 02:00	48.42	0	95.44	1	36.7	
06/03/2024 03:00	48.42	0	95.74	1.1	36.4	
06/03/2024 04:00	48.48	0	95.81	1.1	36.3	
06/03/2024 05:00	48.55	0	95.89	1.1	36.3	
06/03/2024 06:00	48.56	0.15	96.17	1.1	36.1	
06/03/2024 07:00	48.47	0	96.15	1.1	35.7	
06/03/2024 08:00	34.08	0	95.7	1.1	36	
06/03/2024 09:00	33.67	0	95.35	1.1	26.1	
06/03/2024 10:00	32.07	0	95.02	1.1	29.4	
06/03/2024 11:00	32.07	0	95.1	1.1	27.9	
06/03/2024 12:00	21.8	0	92.83	1.2	49.6	
06/03/2024 13:00	33.06	0	95.07	1.1	27.1	
06/03/2024 14:00	32.5	0	95.23	1	24.9	
06/03/2024 15:00	32.51	0	94.85	1.1	24.9	
06/03/2024 16:00	32.5	0	94.58	1	24.4	
06/03/2024 17:00	32.52	0	94.29	1	24.3	
06/03/2024 18:00	31.97	0	93.69	1	28	
06/03/2024 19:00	31.76	0	93.51	0.9	29.9	
06/03/2024 20:00	32.01	0	93.73	0.9	29.9	
06/03/2024 21:00	34.15	0	94.81	0.9	24	
06/03/2024 22:00	34.17	0	94.98	1	24	
06/03/2024 23:00	34.05	0	94.93	1	23.7	
07/03/2024 00:00	16.1	0.01	<Samp	<Samp	<Samp	GT11 S/D
Minimum	16.1	0	92.83	0.9	23.7	
MinDate	07/03/2024 00:00	06/03/2024 00:00	06/03/2024 12:00	06/03/2024 19:00	06/03/2024 23:00	
Maximum	48.56	0.15	96.17	1.2	49.6	
MaxDate	06/03/2024 06:00	06/03/2024 06:00	06/03/2024 06:00	06/03/2024 12:00	06/03/2024 12:00	
Avg	36.28	0.01	94.97	1	31	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	8.8	0	0.9	0.1	6.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/03/2024 00:00	16.09	0.13	<Samp	<Samp	<Samp	GT12 S/D
06/03/2024 01:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
06/03/2024 02:00	0	0.17	ShutDown	ShutDown	ShutDown	GT12 S/D
06/03/2024 03:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
06/03/2024 04:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 S/D
06/03/2024 05:00	0	0.17	ShutDown	ShutDown	ShutDown	GT12 S/D
06/03/2024 06:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
06/03/2024 07:00	0	0.2	ShutDown	ShutDown	ShutDown	GT12 S/D
06/03/2024 08:00	21.36	0.24	<Samp	<Samp	<Samp	GT12 S/D
06/03/2024 09:00	34.5	0.25	95.35	0	23.8	
06/03/2024 10:00	36.27	0.25	95.28	0	24.9	
06/03/2024 11:00	36.27	0.27	95.47	0	25.2	
06/03/2024 12:00	22.01	0.28	92.95	0	48.5	
06/03/2024 13:00	35.8	0.27	95.79	0	26.7	
06/03/2024 14:00	36.25	0.26	96.56	0	25.1	
06/03/2024 15:00	36.19	0.28	96.38	0	25.2	
06/03/2024 16:00	35.95	0.26	96.02	0	24.7	
06/03/2024 17:00	35.62	0.24	95.62	0	24.1	
06/03/2024 18:00	36.02	0.34	95.16	0	23.8	
06/03/2024 19:00	36	0	94.89	0	23.5	
06/03/2024 20:00	36.16	0	95.23	0	23.5	
06/03/2024 21:00	34.08	0	94.67	0	22.4	
06/03/2024 22:00	34.11	0.03	94.98	0	22.3	
06/03/2024 23:00	33.99	0.03	94.51	0	22.1	
07/03/2024 00:00	36.88	0.05	95.09	0	35.5	
Minimum	0	0	92.95	0	22.1	
MinDate	06/03/2024 01:00	06/03/2024 19:00	06/03/2024 12:00	06/03/2024 09:00	06/03/2024 23:00	
Maximum	36.88	0.34	96.56	0	48.5	
MaxDate	07/03/2024 00:00	06/03/2024 18:00	06/03/2024 14:00	06/03/2024 09:00	06/03/2024 12:00	
Avg	23.74	0.18	95.35	0	28.3	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16	0.1	0.9	0	6.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
07/03/2024 00:00	16.1	0.01	<Samp	<Samp	<Samp	
07/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/03/2024 06:00	0	0.34	ShutDown	ShutDown	ShutDown	GT11 S/D
07/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/03/2024 08:00	21.78	0.06	<Samp	<Samp	<Samp	GT11 S/D
07/03/2024 09:00	34.29	0	95.4	1.1	26.5	
07/03/2024 10:00	34.38	0	95.8	1.1	27.1	
07/03/2024 11:00	34.32	0	95.84	1.1	27.3	
07/03/2024 12:00	21.66	0.04	92.88	1.2	52.4	
07/03/2024 13:00	34.53	0	95.49	1.1	29.5	
07/03/2024 14:00	34.39	0	96.01	1.1	27.8	
07/03/2024 15:00	34.23	0	95.46	1.1	27.6	
07/03/2024 16:00	34.15	0	95.02	1	27	
07/03/2024 17:00	33.97	0	94.62	1	26.7	
07/03/2024 18:00	33.91	0	94.27	0.9	26.3	
07/03/2024 19:00	33.85	0	94.18	0.9	25.7	
07/03/2024 20:00	34.09	0	94.38	0.9	25.5	
07/03/2024 21:00	34.12	0	94.75	1	25.3	
07/03/2024 22:00	34.2	0	94.94	1	25	
07/03/2024 23:00	34.12	0	94.99	1	24.9	
08/03/2024 00:00	36.45	0	94.9	1	35.3	
Minimum	0	0	92.88	0.9	24.9	
MinDate	07/03/2024 01:00	07/03/2024 01:00	07/03/2024 12:00	07/03/2024 18:00	07/03/2024 23:00	
Maximum	36.45	0.34	96.01	1.2	52.4	
MaxDate	08/03/2024 00:00	07/03/2024 06:00	07/03/2024 14:00	07/03/2024 12:00	07/03/2024 12:00	
Avg	22.98	0.02	94.93	1	28.7	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.4	0.1	0.8	0.1	6.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
07/03/2024 00:00	36.88	0.05	95.09	0	35.5	
07/03/2024 01:00	48.31	0.17	95.54	0	40.7	
07/03/2024 02:00	48.41	0.2	95.13	0	40.9	
07/03/2024 03:00	48.49	0.15	95.33	0	41	
07/03/2024 04:00	48.55	0.08	95.47	0	40.9	
07/03/2024 05:00	48.47	0.06	95.58	0	40.7	
07/03/2024 06:00	48.4	0.08	96.02	0	40.1	
07/03/2024 07:00	48.32	0.08	95.98	0	39.3	
07/03/2024 08:00	33.73	0.13	94.78	0	34.7	
07/03/2024 09:00	34.23	0.18	94.62	0	21.7	
07/03/2024 10:00	34.32	0.22	95.35	0	22.2	
07/03/2024 11:00	34.26	0.27	95.38	0	22.5	
07/03/2024 12:00	21.51	0.27	92.48	0	50.2	
07/03/2024 13:00	34.45	0.27	95.23	0	24.8	
07/03/2024 14:00	34.32	0.28	95.65	0	22.8	
07/03/2024 15:00	34.16	0.26	95.24	0	22.4	
07/03/2024 16:00	34.08	0.21	94.96	0	21.7	
07/03/2024 17:00	33.91	0.19	94.75	0	21.3	
07/03/2024 18:00	33.84	0.27	94.49	0	21	
07/03/2024 19:00	33.79	0.03	94.26	0	20.7	
07/03/2024 20:00	34.03	0	94.34	0	20.6	
07/03/2024 21:00	34.06	0	94.62	0	20.4	
07/03/2024 22:00	34.14	0	94.69	0	20.2	
07/03/2024 23:00	34.07	0	94.7	0	20	
08/03/2024 00:00	16.82	0	<Samp	<Samp	<Samp	
Minimum	16.82	0	92.48	0	20	
MinDate	08/03/2024 00:00	07/03/2024 20:00	07/03/2024 12:00	07/03/2024 00:00	07/03/2024 23:00	
Maximum	48.55	0.28	96.02	0	50.2	
MaxDate	07/03/2024 04:00	07/03/2024 14:00	07/03/2024 06:00	07/03/2024 00:00	07/03/2024 12:00	
Avg	37.02	0.14	95	0	29.4	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	8.4	0.1	0.7	0	9.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/03/2024 00:00	36.45	0	94.9	1	35.3	
08/03/2024 01:00	48.11	0	95.46	1	36.4	
08/03/2024 02:00	48.22	0	95.05	1	36.4	
08/03/2024 03:00	48.24	0	95.11	1.1	36.5	
08/03/2024 04:00	48.31	0	95.29	1.1	36.4	
08/03/2024 05:00	48.3	0	95.39	1.1	36.2	
08/03/2024 06:00	48.3	0.28	95.78	1.1	36.1	
08/03/2024 07:00	48.26	0	95.34	1.1	36	
08/03/2024 08:00	35.21	0	95.08	1.1	35.4	
08/03/2024 09:00	34.26	0	95.16	1.1	25	
08/03/2024 10:00	34.21	0	95.43	1.1	25.3	
08/03/2024 11:00	34.15	0	95.51	1.1	25.5	
08/03/2024 12:00	21.56	0	92.56	1.2	53.1	
08/03/2024 13:00	34.15	0	94.97	1	27.3	
08/03/2024 14:00	34.14	0	95.35	1	25.3	
08/03/2024 15:00	34.17	0	94.98	1	25.2	
08/03/2024 16:00	33.89	0	94.47	1	25.1	
08/03/2024 17:00	33.74	0	94.13	0.9	24.4	
08/03/2024 18:00	33.74	0	94.08	0.9	24.2	
08/03/2024 19:00	33.65	0	94.04	0.9	23.9	
08/03/2024 20:00	33.84	0	94.23	0.9	23.6	
08/03/2024 21:00	34.03	0	94.61	1	23.6	
08/03/2024 22:00	37.03	0	96.12	1	24.6	
08/03/2024 23:00	37.93	0	97.29	1	25.1	
09/03/2024 00:00	30.37	0	94.81	1	38	
Minimum	21.56	0	92.56	0.9	23.6	
MinDate	08/03/2024 12:00	08/03/2024 00:00	08/03/2024 12:00	08/03/2024 17:00	08/03/2024 20:00	
Maximum	48.31	0.28	97.29	1.2	53.1	
MaxDate	08/03/2024 04:00	08/03/2024 06:00	08/03/2024 23:00	08/03/2024 12:00	08/03/2024 12:00	
Avg	37.77	0.01	95.01	1	30.6	
Num	25	25	25	25	25	
Data1%	100	100	100	100	100	
STD	7.3	0.1	0.9	0.1	7.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/03/2024 00:00	16.82	0	<Samp	<Samp	<Samp	GT12 S/D
08/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
08/03/2024 02:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
08/03/2024 03:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
08/03/2024 04:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
08/03/2024 05:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
08/03/2024 06:00	0	0.02	ShutDown	ShutDown	ShutDown	GT12 S/D
08/03/2024 07:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
08/03/2024 08:00	20.28	0.03	<Samp	<Samp	<Samp	GT12 S/D
08/03/2024 09:00	34.2	0.05	95.07	0	23.2	
08/03/2024 10:00	34.14	0.11	94.98	0	23.5	
08/03/2024 11:00	34.09	0.19	95.16	0	23.6	
08/03/2024 12:00	21.37	0.19	92.21	0	52.3	
08/03/2024 13:00	34.07	0.18	94.67	0	25.3	
08/03/2024 14:00	34.08	0.17	94.99	0	23.2	
08/03/2024 15:00	34.11	0.11	94.82	0	22.9	
08/03/2024 16:00	33.82	0.1	94.33	0	22.7	
08/03/2024 17:00	33.68	0.08	94.12	0	22	
08/03/2024 18:00	33.67	0.4	94.18	0	21.8	
08/03/2024 19:00	33.59	0.05	94.06	0	21.6	
08/03/2024 20:00	33.78	0.05	94.18	0	21.4	
08/03/2024 21:00	33.96	0.03	94.4	0	21.5	
08/03/2024 22:00	36.96	0.03	95.89	0	22.8	
08/03/2024 23:00	37.86	0.04	96.94	0	23.3	
09/03/2024 00:00	30.32	0.06	94.52	0	35	
Minimum	0	0	92.21	0	21.4	
MinDate	08/03/2024 01:00	08/03/2024 00:00	08/03/2024 12:00	08/03/2024 09:00	08/03/2024 20:00	
Maximum	37.86	0.4	96.94	0	52.3	
MaxDate	08/03/2024 23:00	08/03/2024 18:00	08/03/2024 23:00	08/03/2024 09:00	08/03/2024 12:00	
Avg	22.83	0.08	94.66	0	25.4	
Num	25	25	16	16	16	
Data1%	100	100	64	64	64	
STD	15.3	0.1	1	0	7.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/03/2024 00:00	30.37	0	94.81	1	38	
09/03/2024 01:00	28.49	0	93.15	1	41.9	
09/03/2024 02:00	28.7	0	93.23	1	41.1	
09/03/2024 03:00	28.6	0	93.09	1.1	41.3	
09/03/2024 04:00	28.46	0	93.06	1.1	41.7	
09/03/2024 05:00	28.27	0	92.93	1.1	42.6	
09/03/2024 06:00	28.24	0.23	92.97	1.1	42.7	
09/03/2024 07:00	28.03	0	93.11	1.1	43.5	
09/03/2024 08:00	31.69	0	94.04	1.1	40.4	
09/03/2024 09:00	42.23	0	99.34	1.1	26.9	
09/03/2024 10:00	42.3	0	99.95	1.1	26.9	
09/03/2024 11:00	42.33	0	100.04	1.1	27	
09/03/2024 12:00	28.34	0	94.09	1.1	41.3	
09/03/2024 13:00	42.32	0	98.89	1.1	27.6	
09/03/2024 14:00	42.36	0	100.25	1.1	26.6	
09/03/2024 15:00	42.42	0	99.89	1.1	26.7	
09/03/2024 16:00	42.24	0	99.67	1.1	26.5	
09/03/2024 17:00	41.9	0	99.57	1.1	25.8	
09/03/2024 18:00	41.88	0	99.48	1.1	25.8	
09/03/2024 19:00	41.94	0	99.2	1.1	25.8	
09/03/2024 20:00	42.28	0	99.35	1	25.8	
09/03/2024 21:00	42.37	0	100	1	25.8	
09/03/2024 22:00	42.45	0	99.99	1.1	25.8	
09/03/2024 23:00	42.38	0	100	1.1	25.7	
10/03/2024 00:00	31.74	0	95.74	1.1	36.9	
Minimum	28.03	0	92.93	1	25.7	
MinDate	09/03/2024 07:00	09/03/2024 00:00	09/03/2024 05:00	09/03/2024 00:00	09/03/2024 23:00	
Maximum	42.45	0.23	100.25	1.1	43.5	
MaxDate	09/03/2024 22:00	09/03/2024 06:00	09/03/2024 14:00	09/03/2024 03:00	09/03/2024 07:00	
Avg	36.49	0.01	97.03	1.1	32.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.7	0	3.1	0	7.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/03/2024 00:00	30.32	0.06	94.52	0	35	
09/03/2024 01:00	28.44	0.05	92.91	0	38.4	
09/03/2024 02:00	28.64	0.04	92.9	0	37.9	
09/03/2024 03:00	28.54	0.04	92.88	0	38	
09/03/2024 04:00	28.4	0.09	92.84	0	38.4	
09/03/2024 05:00	28.21	0.08	92.73	0	39.1	
09/03/2024 06:00	28.19	0.08	92.75	0	39.1	
09/03/2024 07:00	27.97	0.09	92.85	0	39.7	
09/03/2024 08:00	31.58	0.16	93.9	0	37.5	
09/03/2024 09:00	42.14	0.17	99.79	0	26.5	
09/03/2024 10:00	42.23	0.15	100.45	0	26.8	
09/03/2024 11:00	42.26	0.14	100.55	0	27.2	
09/03/2024 12:00	28.28	0.14	94.71	0	38.8	
09/03/2024 13:00	42.16	0.17	99.5	0	27.8	
09/03/2024 14:00	42.3	0.15	100.44	0	26.7	
09/03/2024 15:00	42.34	0.14	100.32	0	26.4	
09/03/2024 16:00	42.16	0.21	100.08	0	25.8	
09/03/2024 17:00	41.83	0.24	100.02	0	24.7	
09/03/2024 18:00	41.81	0.43	99.62	0	24.7	
09/03/2024 19:00	41.87	0.03	99.72	0	24.7	
09/03/2024 20:00	42.2	0	99.83	0	25	
09/03/2024 21:00	42.3	0	100.2	0	24.9	
09/03/2024 22:00	42.37	0	100.18	0	24.9	
09/03/2024 23:00	42.31	0	100.16	0	24.9	
10/03/2024 00:00	31.68	0	95.97	0	34.6	
Minimum	27.97	0	92.73	0	24.7	
MinDate	09/03/2024 07:00	09/03/2024 20:00	09/03/2024 05:00	09/03/2024 00:00	09/03/2024 17:00	
Maximum	42.37	0.43	100.55	0	39.7	
MaxDate	09/03/2024 22:00	09/03/2024 18:00	09/03/2024 11:00	09/03/2024 00:00	09/03/2024 07:00	
Avg	36.42	0.11	97.2	0	31.1	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.7	0.1	3.4	0	6.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
10/03/2024 00:00	31.74	0	95.74	1.1	36.9	
10/03/2024 01:00	28.39	0	92.55	1.1	41.7	
10/03/2024 02:00	28.36	0	92.46	1.1	41.6	
10/03/2024 03:00	28.05	0	92.5	1.1	42.9	
10/03/2024 04:00	27.64	0	92.52	1.1	44.1	
10/03/2024 05:00	27.38	0	92.47	1.1	44.8	
10/03/2024 06:00	27.3	0.17	92.44	1.1	45.1	
10/03/2024 07:00	27.19	0	92.4	1.2	45.2	
10/03/2024 08:00	27.11	0	92.43	1.1	45.3	
10/03/2024 09:00	27.13	0	92.53	1.1	45.3	
10/03/2024 10:00	27.15	0	92.8	1.1	44.9	
10/03/2024 11:00	27.16	0	92.84	1.1	44.8	
10/03/2024 12:00	27.19	0	93.07	1.1	44	
10/03/2024 13:00	27.21	0	92.56	1.1	42.8	
10/03/2024 14:00	27.24	0	92.71	1.1	42.8	
10/03/2024 15:00	27.24	0	92.62	1.1	42.6	
10/03/2024 16:00	27.23	0	92.35	1.1	42.8	
10/03/2024 17:00	27.16	0	92.22	1.1	43.1	
10/03/2024 18:00	37.61	0	95.75	1	29.8	
10/03/2024 19:00	40.95	0	98.42	1	24.6	
10/03/2024 20:00	40.94	0	98.45	1	24.4	
10/03/2024 21:00	40.93	0	98.86	1	24.3	
10/03/2024 22:00	40.89	0	98.9	1	24.3	
10/03/2024 23:00	26.98	0	93.66	1.1	42.1	
11/03/2024 00:00	27.07	0	92.48	1.1	42.8	
Minimum	26.98	0	92.22	1	24.3	
MinDate	10/03/2024 23:00	10/03/2024 00:00	10/03/2024 17:00	10/03/2024 18:00	10/03/2024 21:00	
Maximum	40.95	0.17	98.9	1.2	45.3	
MaxDate	10/03/2024 19:00	10/03/2024 06:00	10/03/2024 22:00	10/03/2024 07:00	10/03/2024 08:00	
Avg	30.13	0.01	93.83	1.1	39.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	5.3	0	2.3	0	7.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
10/03/2024 00:00	31.68	0	95.97	0	34.6	
10/03/2024 01:00	28.33	0	93.1	0	38.3	
10/03/2024 02:00	28.3	0	92.94	0	38.3	
10/03/2024 03:00	27.99	0	92.84	0	39.4	
10/03/2024 04:00	27.57	0	92.85	0	40.2	
10/03/2024 05:00	27.33	0.01	92.86	0	40.6	
10/03/2024 06:00	27.25	0.01	92.8	0	41.3	
10/03/2024 07:00	27.13	0.01	92.73	0	41.5	
10/03/2024 08:00	27.06	0	92.79	0	41.8	
10/03/2024 09:00	27.07	0.02	92.91	0	41.4	
10/03/2024 10:00	27.09	0.06	93.16	0	41.1	
10/03/2024 11:00	27.1	0.08	93.14	0	41	
10/03/2024 12:00	27.13	0.1	93.36	0	40.4	
10/03/2024 13:00	27.15	0.04	92.74	0	39	
10/03/2024 14:00	27.19	0	92.84	0	39.1	
10/03/2024 15:00	27.19	0	92.98	0	39.4	
10/03/2024 16:00	27.17	0	92.73	0	39.4	
10/03/2024 17:00	27.11	0	92.74	0	39.7	
10/03/2024 18:00	37.54	0	96.48	0	27.9	
10/03/2024 19:00	40.88	<Samp	98.95	0	22.3	Calibrate
10/03/2024 20:00	40.87	<Samp	98.82	0	22.2	Calibrate
10/03/2024 21:00	40.86	0.08	99.01	0	22	
10/03/2024 22:00	40.81	0.09	99.04	0	22	
10/03/2024 23:00	26.93	0.09	93.86	0	39.5	
11/03/2024 00:00	27.01	0.2	92.84	0	40.1	
Minimum	26.93	0	92.73	0	22	
MinDate	10/03/2024 23:00	10/03/2024 00:00	10/03/2024 07:00	10/03/2024 00:00	10/03/2024 21:00	
Maximum	40.88	0.2	99.04	0	41.8	
MaxDate	10/03/2024 19:00	11/03/2024 00:00	10/03/2024 22:00	10/03/2024 00:00	10/03/2024 08:00	
Avg	30.07	0.03	94.18	0	36.5	
Num	25	23	25	25	25	
Data[%]	100	92	100	100	100	
STD	5.3	0.1	2.3	0	7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/03/2024 00:00	27.07	0	92.48	1.1	42.8	
11/03/2024 01:00	27.09	0	92.27	1.1	42.9	
11/03/2024 02:00	27.07	0	92.22	1.1	42.7	
11/03/2024 03:00	27.09	0	92.28	1.1	42.6	
11/03/2024 04:00	27.1	0	92.39	1.1	42.4	
11/03/2024 05:00	27.09	0	92.4	1.2	42.3	
11/03/2024 06:00	27.11	0.34	92.42	1.2	42.3	
11/03/2024 07:00	27.39	0	92.65	1.2	42.2	
11/03/2024 08:00	30.87	0	93.6	1.2	35.7	
11/03/2024 09:00	33.92	0	94.87	1.1	21.8	
11/03/2024 10:00	34.19	0	95.18	1.1	21.9	
11/03/2024 11:00	34.17	0	95.41	1.1	21.8	
11/03/2024 12:00	21.93	0	92.45	1.2	45.8	
11/03/2024 13:00	34.39	0	94.62	1.1	22.9	
11/03/2024 14:00	34.28	0	94.76	1	21.4	
11/03/2024 15:00	34.3	0	94.25	1	21.2	
11/03/2024 16:00	34.11	0	94.53	1	21	
11/03/2024 17:00	33.84	0	94.22	1	21.2	
11/03/2024 18:00	33.74	0	93.92	1	21.3	
11/03/2024 19:00	33.81	0	94	1	21.2	
11/03/2024 20:00	33.99	0	94.13	1	21.2	
11/03/2024 21:00	34.13	0	94.47	1	21.2	
11/03/2024 22:00	34.02	0	94.34	1	21.2	
11/03/2024 23:00	33.97	0	94.36	1	21.1	
12/03/2024 00:00	16.22	0	<Samp	<Samp	<Samp	GT11 S/D
Minimum	16.22	0	92.22	1	21	
MinDate	12/03/2024 00:00	11/03/2024 00:00	11/03/2024 02:00	11/03/2024 14:00	11/03/2024 16:00	
Maximum	34.39	0.34	95.41	1.2	45.8	
MaxDate	11/03/2024 13:00	11/03/2024 06:00	11/03/2024 11:00	11/03/2024 05:00	11/03/2024 12:00	
Avg	30.52	0.01	93.68	1.1	30.1	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	4.8	0.1	1.1	0.1	10.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/03/2024 00:00	27.01	0.2	92.84	0	40.1	
11/03/2024 01:00	27.03	0.24	92.63	0	40.2	
11/03/2024 02:00	27.01	0.18	92.62	0	40.1	
11/03/2024 03:00	27.02	0.16	92.67	0	39.8	
11/03/2024 04:00	27.04	0.21	92.73	0	39.8	
11/03/2024 05:00	27.04	0.23	92.77	0	39.5	
11/03/2024 06:00	27.05	0.25	92.8	0	39.3	
11/03/2024 07:00	27.33	0.26	93.01	0	38.5	
11/03/2024 08:00	30.61	0.25	94.01	0	32.8	
11/03/2024 09:00	33.86	0.24	95.21	0	18.7	
11/03/2024 10:00	34.13	0.28	95.43	0	18.8	
11/03/2024 11:00	34.12	0.24	95.72	0	18.8	
11/03/2024 12:00	21.89	0.78	92.85	0	45.6	
11/03/2024 13:00	34.34	<Samp	95.08	0	19.9	DUST waiting for spare part
11/03/2024 14:00	34.21	Maintenance	95.16	0	18.1	DUST waiting for spare part
11/03/2024 15:00	34.24	Maintenance	94.91	0	17.8	DUST waiting for spare part
11/03/2024 16:00	34.05	Maintenance	94.91	0	17.7	DUST waiting for spare part
11/03/2024 17:00	33.78	Audit	94.62	0	17.9	DUST waiting for spare part
11/03/2024 18:00	33.68	Maintenance	94.34	0	18.1	DUST waiting for spare part
11/03/2024 19:00	33.75	Maintenance	94.42	0	18	DUST waiting for spare part
11/03/2024 20:00	33.92	Maintenance	94.66	0	18.1	DUST waiting for spare part
11/03/2024 21:00	34.06	Maintenance	94.85	0	18.1	DUST waiting for spare part
11/03/2024 22:00	33.95	Maintenance	94.74	0	17.9	DUST waiting for spare part
11/03/2024 23:00	33.91	Maintenance	94.72	0	17.8	DUST waiting for spare part
12/03/2024 00:00	36.7	Audit	95.19	0	31.6	DUST waiting for spare part
Minimum	21.89	0.16	92.62	0	17.7	
MinDate	11/03/2024 12:00	11/03/2024 03:00	11/03/2024 02:00	11/03/2024 00:00	11/03/2024 16:00	
Maximum	36.7	0.78	95.72	0	45.6	
MaxDate	12/03/2024 00:00	11/03/2024 12:00	11/03/2024 11:00	11/03/2024 00:00	11/03/2024 12:00	
Avg	31.28	0.27	94.11	0	27.1	
Num	25	13	25	25	25	
Data[%]	100	52	100	100	100	
STD	3.9	0.2	1.1	0	10.7	

Date & Time	11CT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/03/2024 00:00	16.22	0	<Samp	<Samp	<Samp	GT11 S/D
12/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
12/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
12/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
12/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
12/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
12/03/2024 06:00	0	0.28	ShutDown	ShutDown	ShutDown	GT11 S/D
12/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
12/03/2024 08:00	20.49	0.06	<Samp	<Samp	<Samp	GT11 S/D
12/03/2024 09:00	34.42	0	94.78	1.1	27.5	
12/03/2024 10:00	34.38	0	95.1	1.1	27.7	
12/03/2024 11:00	34.32	0	95.54	1.1	27.8	
12/03/2024 12:00	21.91	0	92.6	1.2	31.7	
12/03/2024 13:00	34.14	0	94.65	1.1	29.4	
12/03/2024 14:00	34.35	0	95.46	1.1	27.9	
12/03/2024 15:00	34.38	0	94.93	1.1	27.8	
12/03/2024 16:00	34.18	0	94.74	1	27.6	
12/03/2024 17:00	33.99	0	94.59	1	27.2	
12/03/2024 18:00	33.86	0	94.26	1	26.9	
12/03/2024 19:00	33.86	0	94.26	1	26.6	
12/03/2024 20:00	33.93	0	94.29	1	26.3	
12/03/2024 21:00	34.07	0	94.44	1	26.4	
12/03/2024 22:00	34.09	0	94.46	1	26.5	
12/03/2024 23:00	33.95	0	94.51	1	25.9	
13/03/2024 00:00	36.75	0	94.91	1.1	36.9	
Minimum	0	0	92.6	1	25.9	
MinDate	12/03/2024 01:00	12/03/2024 00:00	12/03/2024 12:00	12/03/2024 16:00	12/03/2024 23:00	
Maximum	36.75	0.28	95.54	1.2	51.7	
MaxDate	13/03/2024 00:00	12/03/2024 06:00	12/03/2024 11:00	12/03/2024 12:00	12/03/2024 12:00	
Avg	22.93	0.01	94.69	1.1	29.4	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.4	0.1	0.7	0.1	6.5	

Date & Time	12CT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/03/2024 00:00	36.7	Audit	95.19	0	31.6	DUST waiting for spare part
12/03/2024 01:00	48.37	Maintenance	95.54	0	35.3	DUST waiting for spare part
12/03/2024 02:00	48.45	Maintenance	95.04	0	35.3	DUST waiting for spare part
12/03/2024 03:00	48.55	Maintenance	95.28	0	35.4	DUST waiting for spare part
12/03/2024 04:00	48.44	Maintenance	95.48	0	34.8	DUST waiting for spare part
12/03/2024 05:00	48.16	Maintenance	95.75	0	33.3	DUST waiting for spare part
12/03/2024 06:00	48.3	Maintenance	95.23	0	34.1	DUST waiting for spare part
12/03/2024 07:00	48.3	Maintenance	95.88	0	34.1	DUST waiting for spare part
12/03/2024 08:00	34.67	Maintenance	95.11	0	31.1	DUST waiting for spare part
12/03/2024 09:00	34.35	Maintenance	94.78	0	17.9	DUST waiting for spare part
12/03/2024 10:00	34.32	Maintenance	94.93	0	17.9	DUST waiting for spare part
12/03/2024 11:00	34.27	Maintenance	95.17	0	18	DUST waiting for spare part
12/03/2024 12:00	21.86	Maintenance	92.53	0	46.6	DUST waiting for spare part
12/03/2024 13:00	34.04	Maintenance	94.79	0	19.7	DUST waiting for spare part
12/03/2024 14:00	34.28	Maintenance	95.23	0	17.9	DUST waiting for spare part
12/03/2024 15:00	34.31	Maintenance	94.89	0	17.8	DUST waiting for spare part
12/03/2024 16:00	34.11	<Samp	94.73	0	17.7	DUST waiting for spare part
12/03/2024 17:00	33.93	<Samp	94.47	0	17.6	DUST waiting for spare part
12/03/2024 18:00	33.79	Maintenance	94.14	0	17.6	DUST waiting for spare part
12/03/2024 19:00	33.79	Audit	94.21	0	17.5	DUST waiting for spare part
12/03/2024 20:00	33.67	Maintenance	94.28	0	17.4	DUST waiting for spare part
12/03/2024 21:00	34.01	Maintenance	94.24	0	17.4	DUST waiting for spare part
12/03/2024 22:00	34.03	Maintenance	94.22	0	17.6	DUST waiting for spare part
12/03/2024 23:00	33.89	Maintenance	94.31	0	17.2	DUST waiting for spare part
13/03/2024 00:00	16.18	Maintenance	<Samp	<Samp	<Samp	GT12 S/D
Minimum	16.18	---	92.53	0	17.2	
MinDate	13/03/2024 00:00	12/03/2024 00:00	12/03/2024 12:00	12/03/2024 00:00	12/03/2024 23:00	
Maximum	48.55	---	96.23	0	46.6	
MaxDate	12/03/2024 03:00	12/03/2024 00:00	12/03/2024 06:00	12/03/2024 00:00	12/03/2024 12:00	
Avg	37.01	---	94.85	0	25	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	8.4	---	0.8	0	9.2	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG SO2@7%O2	11HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
13/03/2024 00:00	36.75	0	94.91	1.1	36.9	
13/03/2024 01:00	48.56	0	95.62	1.1	37.6	
13/03/2024 02:00	48.63	0	95.78	1.1	37.6	
13/03/2024 03:00	48.69	0	96.05	1.1	37.6	
13/03/2024 04:00	48.66	0	96.22	1.1	37.5	
13/03/2024 05:00	48.34	0	96.25	1.1	36.5	
13/03/2024 06:00	48.34	0.21	96.61	1.2	36.4	
13/03/2024 07:00	48.46	0	96.63	1.2	37.2	
13/03/2024 08:00	34.35	0	95.5	1.2	37.7	
13/03/2024 09:00	34.31	0	94.87	1.1	26.4	
13/03/2024 10:00	34.34	0	95.09	1.1	26.5	
13/03/2024 11:00	34.27	0	95.26	1.1	26.8	
13/03/2024 12:00	21.64	0	92.26	1.2	55.1	
13/03/2024 13:00	34.37	0	94.52	1.1	28.2	
13/03/2024 14:00	34.28	0	94.78	1	25.6	
13/03/2024 15:00	34.22	0	94.89	1	25.7	
13/03/2024 16:00	34.09	0	94.53	1.1	26.2	
13/03/2024 17:00	33.87	0	94.18	1	26	
13/03/2024 18:00	33.77	0	93.83	1	25.7	
13/03/2024 19:00	33.76	0	93.71	1	25.5	
13/03/2024 20:00	33.95	0	94.02	1	25.4	
13/03/2024 21:00	34.05	0	94.41	1	25.3	
13/03/2024 22:00	34.06	0	94.72	1	25	
13/03/2024 23:00	34.02	0	94.61	1.1	24.8	
14/03/2024 00:00	16.63	0.01	<Samp	<Samp	<Samp	GT11 S/D
Minimum	16.63	0	92.26	1	24.8	
MinDate	14/03/2024 00:00	13/03/2024 00:00	13/03/2024 12:00	13/03/2024 14:00	13/03/2024 23:00	
Maximum	48.69	0.21	96.63	1.2	55.1	
MaxDate	13/03/2024 03:00	13/03/2024 06:00	13/03/2024 07:00	13/03/2024 08:00	13/03/2024 12:00	
Avg	37.06	0.01	94.97	1.1	31.4	
Num	25	25	24	24	24	
Data(%)	100	100	96	96	96	
STD	8.4	0	1	0.1	7.5	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG SO2@7%O2	12HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
13/03/2024 00:00	16.18	Maintenance	<Samp	<Samp	<Samp	GT12 S/D
13/03/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
13/03/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
13/03/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
13/03/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
13/03/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
13/03/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
13/03/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
13/03/2024 08:00	21.16	Maintenance	<Samp	<Samp	<Samp	GT12 S/D
13/03/2024 09:00	34.25	Maintenance	95.02	0	23.8	DUST waiting for spare part
13/03/2024 10:00	34.28	Maintenance	95.05	0	23.9	DUST waiting for spare part
13/03/2024 11:00	34.21	Maintenance	95.18	0	24.2	DUST waiting for spare part
13/03/2024 12:00	21.44	Maintenance	92.27	0	64.2	DUST waiting for spare part
13/03/2024 13:00	34.31	Maintenance	94.55	0	25.3	DUST waiting for spare part
13/03/2024 14:00	34.21	Maintenance	94.6	0	22.6	DUST waiting for spare part
13/03/2024 15:00	34.16	Maintenance	94.84	0	22.9	DUST waiting for spare part
13/03/2024 16:00	34.03	Maintenance	94.5	0	23.4	DUST waiting for spare part
13/03/2024 17:00	33.8	Maintenance	94.33	0	23.1	DUST waiting for spare part
13/03/2024 18:00	33.7	Maintenance	93.98	0	22.6	DUST waiting for spare part
13/03/2024 19:00	33.7	Maintenance	93.74	0	22.7	DUST waiting for spare part
13/03/2024 20:00	33.89	Maintenance	94.01	0	22.6	DUST waiting for spare part
13/03/2024 21:00	33.99	Maintenance	94.26	0	22.5	DUST waiting for spare part
13/03/2024 22:00	33.99	Maintenance	94.56	0	22.5	DUST waiting for spare part
13/03/2024 23:00	33.96	Maintenance	94.55	0	22.1	DUST waiting for spare part
14/03/2024 00:00	36.62	Maintenance	94.79	0	36.2	DUST waiting for spare part
Minimum	0		92.27	0	22.1	
MinDate	13/03/2024 01:00	13/03/2024 00:00	13/03/2024 12:00	13/03/2024 09:00	13/03/2024 23:00	
Maximum	36.62		96.18	0	64.2	
MaxDate	14/03/2024 00:00	13/03/2024 00:00	13/03/2024 11:00	13/03/2024 09:00	13/03/2024 12:00	
Avg	22.88	---	94.39	0	25.9	
Num	25	0	16	16	16	
Data(%)	100	---	64	64	64	
STD	15.3	---	9.7	0	8.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MMV	mg/m3	Degree C.	ppm	ppm	
14/03/2024 00:00	16.63	0.01	<Samp	<Samp	<Samp	GT11 S/D
14/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
14/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
14/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
14/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
14/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
14/03/2024 06:00	0	0.15	ShutDown	ShutDown	ShutDown	GT11 S/D
14/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
14/03/2024 08:00	20.63	0.08	<Samp	<Samp	<Samp	GT11 S/D
14/03/2024 09:00	34.4	0	95.38	1.1	27.7	
14/03/2024 10:00	34.37	0	95.51	1.1	27.8	
14/03/2024 11:00	34.37	0.02	95.58	1.1	27.9	
14/03/2024 12:00	21.69	0.03	92.43	1.2	54.4	
14/03/2024 13:00	34.38	0	94.98	1.1	29.8	
14/03/2024 14:00	34.28	0.02	95.71	1.1	28.6	
14/03/2024 15:00	34.36	0.02	95.46	1.1	28.9	
14/03/2024 16:00	34.18	0	95.14	1.1	28.8	
14/03/2024 17:00	33.98	0	94.45	1	27	
14/03/2024 18:00	33.94	0	94.1	1	26.8	
14/03/2024 19:00	33.85	0	94.15	1	26.5	
14/03/2024 20:00	34.02	0	94.16	1	26.2	
14/03/2024 21:00	34.11	0	94.74	1	26	
14/03/2024 22:00	34.09	0	94.86	1	26	
14/03/2024 23:00	33.94	0	94.8	1	25.7	
15/03/2024 00:00	36.36	0	94.74	1.1	36.8	
Minimum	0	0	92.43	1	25.7	
MinDate	14/03/2024 01:00	14/03/2024 01:00	14/03/2024 12:00	14/03/2024 17:00	14/03/2024 23:00	
Maximum	36.36	0.15	95.71	1.2	54.4	
MaxDate	15/03/2024 00:00	14/03/2024 06:00	14/03/2024 14:00	14/03/2024 12:00	14/03/2024 12:00	
Avg	22.94	0.01	94.77	1.1	29.7	
Num	25	25	16	16	16	
Data (%)	100	100	64	64	64	
STD	15.4	0	0.8	0.1	7.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MMV	mg/m3	Degree C.	ppm	ppm	
14/03/2024 00:00	36.62	Maintenance	94.79	0	36.2	DUST waiting for spare part
14/03/2024 01:00	48.54	Maintenance	95.44	0	42.7	DUST waiting for spare part
14/03/2024 02:00	48.57	Maintenance	95.1	0	42.5	DUST waiting for spare part
14/03/2024 03:00	48.63	Maintenance	95.51	0	42.3	DUST waiting for spare part
14/03/2024 04:00	48.57	Maintenance	95.58	0	41.6	DUST waiting for spare part
14/03/2024 05:00	48.33	Maintenance	95.76	0	40.2	DUST waiting for spare part
14/03/2024 06:00	48.48	Maintenance	96.01	0	41	DUST waiting for spare part
14/03/2024 07:00	48.34	Maintenance	95.95	0	40.7	DUST waiting for spare part
14/03/2024 08:00	34.88	Maintenance	95.07	0	35.7	DUST waiting for spare part
14/03/2024 09:00	34.33	Maintenance	95.21	0	22.1	DUST waiting for spare part
14/03/2024 10:00	34.31	Maintenance	95.4	0	22.2	DUST waiting for spare part
14/03/2024 11:00	34.31	Maintenance	95.53	0	22.2	DUST waiting for spare part
14/03/2024 12:00	21.42	Maintenance	92.38	0	52.7	DUST waiting for spare part
14/03/2024 13:00	34.3	<Samp	94.89	0	24.3	DUST waiting for spare part
14/03/2024 14:00	34.21	<Samp	95.48	0	22.7	DUST waiting for spare part
14/03/2024 15:00	34.29	Audit	95.34	0	22.9	DUST waiting for spare part
14/03/2024 16:00	34.11	Maintenance	95.14	0	22.6	DUST waiting for spare part
14/03/2024 17:00	33.92	<Samp	94.58	0	21	DUST waiting for spare part
14/03/2024 18:00	33.88	Maintenance	94.24	0	21.1	DUST waiting for spare part
14/03/2024 19:00	33.79	Maintenance	94.06	0	20.9	DUST waiting for spare part
14/03/2024 20:00	33.96	Maintenance	94.11	0	20.7	DUST waiting for spare part
14/03/2024 21:00	34.05	Maintenance	94.53	0	20.6	DUST waiting for spare part
14/03/2024 22:00	34.02	Maintenance	94.71	0	20.6	DUST waiting for spare part
14/03/2024 23:00	33.87	Maintenance	94.6	0	20.4	DUST waiting for spare part
15/03/2024 00:00	16.83	Maintenance	<Samp	<Samp	<Samp	GT12 S/D
Minimum	16.83	---	92.38	0	20.4	
MinDate	15/03/2024 00:00	14/03/2024 00:00	14/03/2024 12:00	14/03/2024 00:00	14/03/2024 23:00	
Maximum	48.63	---	96.01	0	52.7	
MaxDate	14/03/2024 03:00	14/03/2024 00:00	14/03/2024 06:00	14/03/2024 00:00	14/03/2024 12:00	
Avg	37.06	---	94.98	0	30	
Num	25	0	24	24	24	
Data (%)	100	---	96	96	96	
STD	8.4	---	0.8	0	10.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
15/03/2024 00:00	36.36	0	94.74	1.1	38.8	
15/03/2024 01:00	48.42	0	95.42	1.1	37.7	
15/03/2024 02:00	48.49	0	95.11	1.1	37.5	
15/03/2024 03:00	48.54	0	95.3	1.1	37.3	
15/03/2024 04:00	48.52	0	95.32	1.1	37.2	
15/03/2024 05:00	48.38	0	95.49	1.2	36.6	
15/03/2024 06:00	48.4	0.36	96.11	1.2	36.5	
15/03/2024 07:00	48.3	0	96.01	1.2	36.6	
15/03/2024 08:00	34.19	0	95.16	1.2	37	
15/03/2024 09:00	34.3	0	94.87	1.2	25.5	
15/03/2024 10:00	34.32	0	95.29	1.1	25.7	
15/03/2024 11:00	34.26	0	95.31	1.1	25.6	
15/03/2024 12:00	21.61	0	92.36	1.2	53.3	
15/03/2024 13:00	34.26	0	94.49	1.1	27.8	
15/03/2024 14:00	34.23	0	95.13	1.1	25.6	
15/03/2024 15:00	34.22	0	94.86	1.1	25.4	
15/03/2024 16:00	33.91	0	93.78	1.1	25.2	
15/03/2024 17:00	33.66	0	93.95	1.1	24.6	
15/03/2024 18:00	33.61	0	93.84	1.1	24.5	
15/03/2024 19:00	33.68	0	93.86	1.1	24.5	
15/03/2024 20:00	33.94	0	93.82	1.1	24.5	
15/03/2024 21:00	34.1	0	94.25	1.1	24.5	
15/03/2024 22:00	37.12	0	95.85	1.1	25.7	
15/03/2024 23:00	38.89	0	97.24	1.1	26.6	
16/03/2024 00:00	31.6	0	95.57	1.2	38.4	
Minimum	21.61	0	92.36	1.1	24.5	
MinDate	15/03/2024 12:00	15/03/2024 00:00	15/03/2024 12:00	15/03/2024 00:00	15/03/2024 18:00	
Maximum	48.54	0.36	97.24	1.2	53.3	
MaxDate	15/03/2024 03:00	15/03/2024 06:00	15/03/2024 23:00	15/03/2024 05:00	15/03/2024 12:00	
Avg	37.89	0.01	94.93	1.1	31.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0.1	1	0	7.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
15/03/2024 00:00	16.83	Maintenance	<Samp	<Samp	<Samp	
15/03/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/03/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/03/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/03/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/03/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/03/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/03/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/03/2024 08:00	21.35	Maintenance	<Samp	<Samp	<Samp	DUST waiting for spare part
15/03/2024 09:00	34.24	Maintenance	95.57	0	22.7	DUST waiting for spare part
15/03/2024 10:00	34.26	Maintenance	95.61	0	22.8	DUST waiting for spare part
15/03/2024 11:00	34.21	Maintenance	95.5	0	22.6	DUST waiting for spare part
15/03/2024 12:00	21.36	Maintenance	92.8	0	51.8	DUST waiting for spare part
15/03/2024 13:00	34.21	Maintenance	94.98	0	24.6	DUST waiting for spare part
15/03/2024 14:00	34.17	Maintenance	95.5	0	22.2	DUST waiting for spare part
15/03/2024 15:00	34.15	Maintenance	95.34	0	21.9	DUST waiting for spare part
15/03/2024 16:00	33.85	Maintenance	94.03	0	21.7	DUST waiting for spare part
15/03/2024 17:00	33.59	Maintenance	94.27	0	21.8	DUST waiting for spare part
15/03/2024 18:00	33.54	Maintenance	94.17	0	21.4	DUST waiting for spare part
15/03/2024 19:00	33.62	Maintenance	94.15	0	21.4	DUST waiting for spare part
15/03/2024 20:00	33.87	Maintenance	94.12	0	21.5	DUST waiting for spare part
15/03/2024 21:00	34.04	Maintenance	94.47	0	21.6	DUST waiting for spare part
15/03/2024 22:00	37.05	Maintenance	96.03	0	23.1	DUST waiting for spare part
15/03/2024 23:00	38.83	Maintenance	97.49	0	24.1	DUST waiting for spare part
16/03/2024 00:00	31.52	Maintenance	95.79	0	35	DUST waiting for spare part
Minimum	0	---	92.8	0	21.4	
MinDate	15/03/2024 01:00	15/03/2024 00:00	15/03/2024 12:00	15/03/2024 09:00	15/03/2024 18:00	
Maximum	38.83	---	97.49	0	51.6	
MaxDate	15/03/2024 23:00	15/03/2024 00:00	15/03/2024 23:00	15/03/2024 09:00	15/03/2024 12:00	
Avg	22.99	---	94.99	0	25	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	15.4	---	1.1	0	7.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/03/2024 00:00	31.6	0	95.57	1.2	38.4	
16/03/2024 01:00	28.51	0	92.94	1.2	42.4	
16/03/2024 02:00	28.47	0	92.79	1.2	42.4	
16/03/2024 03:00	28.32	0	92.75	1.2	42.7	
16/03/2024 04:00	28.05	0	92.8	1.2	43.5	
16/03/2024 05:00	27.85	0	92.55	1.2	44.4	
16/03/2024 06:00	27.52	0.3	90.96	1.2	47.1	
16/03/2024 07:00	27.26	0	90.97	1.3	47.3	
16/03/2024 08:00	30.59	0	92.41	1.3	43.3	
16/03/2024 09:00	40.98	0	97.97	1.3	28.2	
16/03/2024 10:00	41.06	0	98.93	1.3	28.5	
16/03/2024 11:00	41.07	0	99.02	1.3	28.8	
16/03/2024 12:00	27.15	0	93.67	1.3	47.2	
16/03/2024 13:00	41.19	0	98.12	1.3	28.9	
16/03/2024 14:00	41.19	0	99.58	1.2	27.9	
16/03/2024 15:00	41.26	0	99.43	1.2	27.9	
16/03/2024 16:00	41.22	0	99.23	1.2	28	
16/03/2024 17:00	41.13	0	98.82	1.2	28	
16/03/2024 18:00	41.09	0	98.7	1.2	27.9	
16/03/2024 19:00	41.09	0	98.46	1.2	27.7	
16/03/2024 20:00	41.09	0	98.42	1.2	27.6	
16/03/2024 21:00	41.07	0	98.84	1.2	27.2	
16/03/2024 22:00	41	0	98.89	1.2	27	
16/03/2024 23:00	40.92	0	98.06	1.2	28.7	
17/03/2024 00:00	30.47	0	95.24	1.3	39.9	
Minimum	27.15	0	90.95	1.2	28.7	
MnDate	16/03/2024 12:00	16/03/2024 06:00	16/03/2024 06:00	16/03/2024 00:00	16/03/2024 23:00	
Maximum	41.26	0.3	99.56	1.3	47.3	
MaxDate	16/03/2024 15:00	16/03/2024 06:00	16/03/2024 14:00	16/03/2024 07:00	16/03/2024 07:00	
Avg	35.65	0.01	98.24	1.2	34.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.3	0.1	3.1	0	8.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/03/2024 00:00	31.52	Maintenance	95.79	0	35	DUST waiting for spare part
16/03/2024 01:00	28.44	Maintenance	93.26	0	38.1	DUST waiting for spare part
16/03/2024 02:00	28.4	Maintenance	93.11	0	38	DUST waiting for spare part
16/03/2024 03:00	28.25	Maintenance	93.11	0	38.3	DUST waiting for spare part
16/03/2024 04:00	27.99	Maintenance	93.09	0	38.9	DUST waiting for spare part
16/03/2024 05:00	27.79	Maintenance	92.8	0	39.6	DUST waiting for spare part
16/03/2024 06:00	27.57	Maintenance	91.06	0	42.6	DUST waiting for spare part
16/03/2024 07:00	27.2	Maintenance	91.19	0	43.3	DUST waiting for spare part
16/03/2024 08:00	30.55	Maintenance	92.74	0	40.3	DUST waiting for spare part
16/03/2024 09:00	40.9	Maintenance	98.13	0	25.6	DUST waiting for spare part
16/03/2024 10:00	40.99	Maintenance	99.98	0	25.8	DUST waiting for spare part
16/03/2024 11:00	41	Maintenance	99.21	0	26.3	DUST waiting for spare part
16/03/2024 12:00	27.09	Maintenance	93.88	0	42.8	DUST waiting for spare part
16/03/2024 13:00	41.11	Maintenance	98.61	0	27.2	DUST waiting for spare part
16/03/2024 14:00	41.11	Maintenance	99.67	0	26	DUST waiting for spare part
16/03/2024 15:00	41.19	Maintenance	99.69	0	26.1	DUST waiting for spare part
16/03/2024 16:00	41.14	Maintenance	99.54	0	26.1	DUST waiting for spare part
16/03/2024 17:00	41.06	Maintenance	99.22	0	25.7	DUST waiting for spare part
16/03/2024 18:00	41.03	Maintenance	99.17	0	25.3	DUST waiting for spare part
16/03/2024 19:00	41.03	Maintenance	98.85	0	25.1	DUST waiting for spare part
16/03/2024 20:00	41.02	Maintenance	98.86	0	24.7	DUST waiting for spare part
16/03/2024 21:00	41.01	Maintenance	99.03	0	24.3	DUST waiting for spare part
16/03/2024 22:00	40.92	Maintenance	99	0	24.1	DUST waiting for spare part
16/03/2024 23:00	40.84	Maintenance	99.21	0	23.9	DUST waiting for spare part
17/03/2024 00:00	30.4	Maintenance	95.37	0	36.4	DUST waiting for spare part
Minimum	27.09	---	91.06	0	23.9	
MnDate	16/03/2024 12:00	16/03/2024 00:00	16/03/2024 06:00	16/03/2024 00:00	16/03/2024 23:00	
Maximum	41.19	---	99.69	0	43.3	
MaxDate	16/03/2024 15:00	16/03/2024 00:00	16/03/2024 15:00	16/03/2024 00:00	16/03/2024 07:00	
Avg	35.58	---	96.5	0	31.6	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	6.3	---	3.1	0	7.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/03/2024 00:00	30.47	0	95.24	1.3	39.9	
17/03/2024 01:00	27.14	0	92.18	1.3	48.5	
17/03/2024 02:00	27.15	0	91.9	1.3	46.7	
17/03/2024 03:00	27.05	0	91.84	1.3	46.4	
17/03/2024 04:00	27.1	0	91.99	1.3	46	
17/03/2024 05:00	27.1	0	91.84	1.3	45.7	
17/03/2024 06:00	27.05	0.23	91.76	1.3	45.9	
17/03/2024 07:00	26.97	0	92.09	1.3	46.2	
17/03/2024 08:00	27.04	0	92.62	1.3	46.4	
17/03/2024 09:00	27.12	0	92.92	1.3	47	
17/03/2024 10:00	27.09	0.02	92.86	1.4	47.4	
17/03/2024 11:00	27.1	0.05	92.92	1.3	47.4	
17/03/2024 12:00	27.16	0.12	93.37	1.3	46.6	
17/03/2024 13:00	27.08	0.06	92.93	1.3	46.2	
17/03/2024 14:00	27.12	0.04	92.58	1.3	45.3	
17/03/2024 15:00	27.16	0.03	92.35	1.3	45	
17/03/2024 16:00	27.13	0	92.03	1.2	45.1	
17/03/2024 17:00	27.06	0	91.66	1.2	45.5	
17/03/2024 18:00	37.51	0	95.25	1.2	52.9	
17/03/2024 19:00	40.89	0	98.21	1.2	59.8	
17/03/2024 20:00	40.9	0	98.34	1.2	58.6	
17/03/2024 21:00	40.88	0	98.74	1.2	58.2	
17/03/2024 22:00	40.84	0	98.78	1.2	55.9	
17/03/2024 23:00	26.94	0	93.58	1.2	43.5	
18/03/2024 00:00	27.06	0	92.23	1.3	44.3	
Minimum	26.94	0	91.66	1.2	25.9	
MinDate	17/03/2024 23:00	17/03/2024 00:00	17/03/2024 17:00	17/03/2024 16:00	17/03/2024 22:00	
Maximum	40.9	0.23	98.78	1.4	47.4	
MaxDate	17/03/2024 20:00	17/03/2024 06:00	17/03/2024 22:00	17/03/2024 10:00	17/03/2024 10:00	
Avg	29.84	0.02	93.61	1.3	42.1	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	5.4	0.1	2.4	0.1	7.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/03/2024 00:00	30.4	Maintenance	95.37	0	36.4	DUST waiting for spare part
17/03/2024 01:00	27.08	Maintenance	92.93	0	42.4	DUST waiting for spare part
17/03/2024 02:00	27.09	Maintenance	92.62	0	42.8	DUST waiting for spare part
17/03/2024 03:00	27	Maintenance	92.64	0	42.6	DUST waiting for spare part
17/03/2024 04:00	27.05	Maintenance	92.76	0	41.8	DUST waiting for spare part
17/03/2024 05:00	27.04	Maintenance	92.59	0	41.7	DUST waiting for spare part
17/03/2024 06:00	26.98	Maintenance	92.44	0	42.2	DUST waiting for spare part
17/03/2024 07:00	26.91	Maintenance	92.74	0	42.7	DUST waiting for spare part
17/03/2024 08:00	26.97	Maintenance	93.23	0	42.4	DUST waiting for spare part
17/03/2024 09:00	27.05	Maintenance	93.57	0	42.4	DUST waiting for spare part
17/03/2024 10:00	27.03	Audit	93.64	0	43	DUST waiting for spare part
17/03/2024 11:00	27.05	Maintenance	93.75	0	43.1	DUST waiting for spare part
17/03/2024 12:00	27.1	Maintenance	94.19	0	42.4	DUST waiting for spare part
17/03/2024 13:00	27.02	Maintenance	93.72	0	42	DUST waiting for spare part
17/03/2024 14:00	27.06	Maintenance	93.36	0	41	DUST waiting for spare part
17/03/2024 15:00	27.1	Maintenance	93.37	0	40.7	DUST waiting for spare part
17/03/2024 16:00	27.07	Maintenance	93.12	0	40.8	DUST waiting for spare part
17/03/2024 17:00	27.01	Maintenance	92.78	0	42.1	DUST waiting for spare part
17/03/2024 18:00	37.47	Maintenance	96.36	0	50.1	DUST waiting for spare part
17/03/2024 19:00	40.81	Maintenance	98.7	0	53.8	DUST waiting for spare part
17/03/2024 20:00	40.82	<Samp	98.69	0	53.5	DUST waiting for spare part
17/03/2024 21:00	40.81	0.64	99.06	0	53.1	
17/03/2024 22:00	40.78	0.41	99.06	0	52.7	
17/03/2024 23:00	26.87	0.12	93.93	0	39.9	
18/03/2024 00:00	27.01	0.19	92.99	0	40.4	
Minimum	26.87	0.12	92.44	0	22.7	
MinDate	17/03/2024 23:00	17/03/2024 23:00	17/03/2024 06:00	17/03/2024 00:00	17/03/2024 22:00	
Maximum	40.82	0.64	99.06	0	53.1	
MaxDate	17/03/2024 20:00	17/03/2024 21:00	17/03/2024 21:00	17/03/2024 00:00	17/03/2024 11:00	
Avg	29.78	0.34	94.3	0	38.2	
Num	25	4	25	25	25	
Data(%)	100	16	100	100	100	
STD	5.4	0.2	2.2	0	7.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/03/2024 00:00	27.06	0	92.23	1.3	44.3	
18/03/2024 01:00	27.09	0	92.17	1.3	44.1	
18/03/2024 02:00	27.09	0	92.2	1.3	43.8	
18/03/2024 03:00	27.08	0	92.23	1.4	43.8	
18/03/2024 04:00	27.1	0	92.08	1.4	43.9	
18/03/2024 05:00	27.13	0	92.17	1.4	43.9	
18/03/2024 06:00	27.13	0.15	92.25	1.4	43.9	
18/03/2024 07:00	27.47	0	92.44	1.4	43.5	
18/03/2024 08:00	31.28	0	93.54	1.4	37.2	
18/03/2024 09:00	34.27	0	95.05	1.3	22.2	
18/03/2024 10:00	34.39	0	95.34	1.3	22.2	
18/03/2024 11:00	34.43	0	95.73	1.4	22.3	
18/03/2024 12:00	21.91	0.01	93.12	1.5	46.9	
18/03/2024 13:00	34.52	0	94.91	1.3	23.5	
18/03/2024 14:00	34.49	0	94.69	1.3	22.1	
18/03/2024 15:00	34.35	0	93.91	1.2	22.6	
18/03/2024 16:00	34.25	0	94.53	1.2	22	
18/03/2024 17:00	34.05	0	94.28	1.2	21.8	
18/03/2024 18:00	33.97	0	94.06	1.2	21.9	
18/03/2024 19:00	33.87	0	93.79	1.2	22.2	
18/03/2024 20:00	34.08	0	93.87	1.2	21.7	
18/03/2024 21:00	34.17	0	94.35	1.2	21.6	
18/03/2024 22:00	34.11	0	94.55	1.2	21.5	
18/03/2024 23:00	34	0	94.61	1.2	21.5	
19/03/2024 00:00	16.37	0.01	<Samp	<Samp	<Samp	GT11 S/D
Minimum	16.37	0	92.08	1.2	21.5	
MinDate	19/03/2024 00:00	18/03/2024 00:00	18/03/2024 04:00	18/03/2024 15:00	18/03/2024 22:00	
Maximum	34.52	0.15	95.73	1.5	46.9	
MaxDate	18/03/2024 13:00	18/03/2024 06:00	18/03/2024 11:00	18/03/2024 12:00	18/03/2024 12:00	
Avg	30.63	0.01	93.67	1.3	31	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	4.8	0	1.2	0.1	10.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/03/2024 00:00	27.01	0.19	92.99	0	40.4	
18/03/2024 01:00	27.03	0.42	93	0	40.1	
18/03/2024 02:00	27.03	0.15	93.02	0	39.8	
18/03/2024 03:00	27.02	0.21	93.12	0	39.7	
18/03/2024 04:00	27.04	0.25	92.95	0	39.8	
18/03/2024 05:00	27.07	0.21	92.99	0	39.7	
18/03/2024 06:00	27.07	0.3	93.11	0	39.7	
18/03/2024 07:00	27.41	0.08	93.26	0	38.8	
18/03/2024 08:00	31.17	0.07	94.46	0	33.6	
18/03/2024 09:00	34.2	0.05	95.41	0	18.9	
18/03/2024 10:00	34.32	0.18	95.59	0	18.9	
18/03/2024 11:00	34.36	0.23	95.95	0	19.1	
18/03/2024 12:00	21.89	Audit	93.42	0	45.2	
18/03/2024 13:00	34.48	<Samp	95.41	0	20.3	Calibrate
18/03/2024 14:00	34.43	<Samp	95.04	0	18.7	Calibrate
18/03/2024 15:00	34.29	0	94.34	0	19.5	
18/03/2024 16:00	34.19	0	95.03	0	18.7	
18/03/2024 17:00	33.98	0	94.88	0	18.4	
18/03/2024 18:00	33.9	0	94.49	0	18.6	
18/03/2024 19:00	33.81	0	94.24	0	18.9	
18/03/2024 20:00	34.02	0	94.35	0	18.5	
18/03/2024 21:00	34.1	0	94.68	0	18.4	
18/03/2024 22:00	34.06	0	94.81	0	18.2	
18/03/2024 23:00	33.93	0	94.91	0	18.2	
19/03/2024 00:00	36.54	0	95.22	0	32	
Minimum	21.89	0	92.95	0	18.2	
MinDate	18/03/2024 12:00	18/03/2024 15:00	18/03/2024 04:00	18/03/2024 00:00	18/03/2024 22:00	
Maximum	36.54	0.42	95.95	0	45.2	
MaxDate	19/03/2024 00:00	18/03/2024 01:00	18/03/2024 11:00	18/03/2024 00:00	18/03/2024 12:00	
Avg	31.37	0.11	94.27	0	27.7	
Num	25	22	25	25	25	
Data[%]	100	88	100	100	100	
STD	3.9	0.1	1	0	10.5	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG SO2@7%O2	11HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/03/2024 00:00	16.37	0.01	<Samp	<Samp	<Samp	GT11 S/D
19/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/03/2024 06:00	0	0.34	ShutDown	ShutDown	ShutDown	GT11 S/D
19/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
19/03/2024 08:00	22.12	0.05	<Samp	<Samp	<Samp	GT11 S/D
19/03/2024 09:00	34.41	0	95.35	1.3	27.8	
19/03/2024 10:00	34.43	0	95.63	1.2	27.7	
19/03/2024 11:00	34.33	0	95.53	1.3	27.6	
19/03/2024 12:00	21.96	0	92.67	1.3	51.4	
19/03/2024 13:00	34.37	0	94.77	1.2	29.3	
19/03/2024 14:00	34.43	0	95.31	1.2	27.7	
19/03/2024 15:00	34.4	0	94.53	1.2	27.2	
19/03/2024 16:00	34.04	0	93.84	1.2	27.2	
19/03/2024 17:00	33.82	0	93.58	1.2	28	
19/03/2024 18:00	33.79	0	93.67	1.2	28.3	
19/03/2024 19:00	33.77	0	93.78	1.3	27.9	
19/03/2024 20:00	33.98	0	93.82	1.3	26.9	
19/03/2024 21:00	34.1	0	94.41	1.3	26.4	
19/03/2024 22:00	34.07	0	94.47	1.3	26.4	
19/03/2024 23:00	34.07	0	94.48	1.3	26.1	
20/03/2024 00:00	36.85	0	94.86	1.4	37.7	
Minimum	0	0	92.67	1.2	26.1	
MinDate	19/03/2024 01:00	19/03/2024 01:00	19/03/2024 12:00	19/03/2024 10:00	19/03/2024 23:00	
Maximum	36.85	0.34	95.63	1.4	51.4	
MaxDate	20/03/2024 00:00	19/03/2024 06:00	19/03/2024 10:00	20/03/2024 00:00	19/03/2024 12:00	
Avg	23.01	0.02	94.42	1.3	29.6	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.4	0.1	0.8	0.1	6.4	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG SO2@7%O2	12HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/03/2024 00:00	36.54	0	95.22	0	32	
19/03/2024 01:00	48.45	0	95.75	0	35.6	
19/03/2024 02:00	48.54	0	95.25	0	35.7	
19/03/2024 03:00	48.51	0	95.54	0	35.7	
19/03/2024 04:00	48.45	0	95.6	0	35.6	
19/03/2024 05:00	48.18	0	95.82	0	34.1	
19/03/2024 06:00	48.37	0	96.13	0	35.4	
19/03/2024 07:00	48.25	0	95.56	0	35.3	
19/03/2024 08:00	33.69	0	95	0	31.6	
19/03/2024 09:00	34.35	0	95.24	0	18.2	
19/03/2024 10:00	34.37	0	95.25	0	18.1	
19/03/2024 11:00	34.27	0	95.23	0	18.1	
19/03/2024 12:00	21.95	0	92.43	0	45.3	
19/03/2024 13:00	34.29	0	94.88	0	19.9	
19/03/2024 14:00	34.36	0.34	95.39	0	18.1	
19/03/2024 15:00	34.34	0.34	94.58	0	17.7	
19/03/2024 16:00	33.98	0	93.64	0	18	
19/03/2024 17:00	33.75	0	93.42	0	19.1	
19/03/2024 18:00	33.72	0	93.71	0	19.5	
19/03/2024 19:00	33.71	0.04	93.91	0	18.7	
19/03/2024 20:00	33.92	0.01	93.94	0	17.9	
19/03/2024 21:00	34.03	0	94.42	0	17.4	
19/03/2024 22:00	34	0	94.41	0	17.4	
19/03/2024 23:00	34.01	0	94.45	0	17.2	
20/03/2024 00:00	16.29	0.02	<Samp	<Samp	<Samp	GT12 S/D
Minimum	16.29	0	92.43	0	17.2	
MinDate	20/03/2024 00:00	19/03/2024 00:00	19/03/2024 12:00	19/03/2024 00:00	19/03/2024 23:00	
Maximum	48.54	0.34	96.13	0	45.3	
MaxDate	19/03/2024 02:00	19/03/2024 14:00	19/03/2024 06:00	19/03/2024 00:00	19/03/2024 12:00	
Avg	36.97	0.03	94.78	0	25.5	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	8.4	0.1	0.9	0	9.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/03/2024 00:00	36.85	0	94.86	1.4	37.7	
20/03/2024 01:00	48.86	0	95.7	1.4	37.2	
20/03/2024 02:00	48.85	0	95.72	1.4	37.2	
20/03/2024 03:00	48.91	0	95.85	1.4	36.9	
20/03/2024 04:00	48.83	0	95.94	1.4	36.4	
20/03/2024 05:00	48.63	0	95.86	1.4	35.6	
20/03/2024 06:00	48.59	0.28	96.27	1.4	35.4	
20/03/2024 07:00	48.59	0	95.92	1.4	35.7	
20/03/2024 08:00	34.23	0	94.57	1.4	37.8	
20/03/2024 09:00	34.22	0	93.87	1.3	26.2	
20/03/2024 10:00	34.24	0	94.07	1.3	26	
20/03/2024 11:00	34.14	0	94.11	1.3	25.9	
20/03/2024 12:00	22.03	0	91.41	1.5	55.1	
20/03/2024 13:00	34.01	0	93.32	1.3	28	
20/03/2024 14:00	34.16	0	93.95	1.4	26.6	
20/03/2024 15:00	34.22	0	93.67	1.4	26.1	
20/03/2024 16:00	34.08	0	93.51	1.4	26.2	
20/03/2024 17:00	33.91	0	93.54	1.4	26.3	
20/03/2024 18:00	33.8	0	93.62	1.4	27	
20/03/2024 19:00	33.75	0	93.63	1.4	27.2	
20/03/2024 20:00	33.8	0	93.75	1.4	26.6	
20/03/2024 21:00	34.1	0	94.27	1.4	25.6	
20/03/2024 22:00	34.06	0	94.39	1.4	25.8	
20/03/2024 23:00	34.03	0	94.22	1.4	26	
21/03/2024 00:00	16.1	0.01	<Samp	<Samp	<Samp	GT11 S/D
Minimum	16.1	0	91.41	1.3	25.6	
MinDate	21/03/2024 00:00	20/03/2024 00:00	20/03/2024 12:00	20/03/2024 09:00	20/03/2024 21:00	
Maximum	48.91	0.28	96.27	1.5	55.1	
MaxDate	20/03/2024 03:00	20/03/2024 06:00	20/03/2024 06:00	20/03/2024 12:00	20/03/2024 12:00	
Avg	37.08	0.01	94.42	1.4	31.4	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	8.6	0.1	1.2	0	7.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/03/2024 00:00	16.29	0.02	<Samp	<Samp	<Samp	GT12 S/D
20/03/2024 01:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
20/03/2024 02:00	0	0.1	ShutDown	ShutDown	ShutDown	GT12 S/D
20/03/2024 03:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
20/03/2024 04:00	0	0.07	ShutDown	ShutDown	ShutDown	GT12 S/D
20/03/2024 05:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
20/03/2024 06:00	0	0.02	ShutDown	ShutDown	ShutDown	GT12 S/D
20/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
20/03/2024 08:00	21.37	0.01	<Samp	<Samp	<Samp	GT12 S/D
20/03/2024 09:00	34.16	0.01	93.95	0	23.1	
20/03/2024 10:00	34.18	0	93.95	0	22.9	
20/03/2024 11:00	34.09	0.04	93.98	0	22.8	
20/03/2024 12:00	22.04	0.05	91.1	0	50.7	
20/03/2024 13:00	33.91	0.17	93.2	0	25.1	
20/03/2024 14:00	34.1	0.38	93.72	0	23.7	
20/03/2024 15:00	34.15	0.2	93.67	0	22.9	
20/03/2024 16:00	34.01	0.27	93.67	0	23.4	
20/03/2024 17:00	33.85	0.29	93.74	0	23.7	
20/03/2024 18:00	33.73	0.28	93.83	0	24.4	
20/03/2024 19:00	33.69	0.26	93.89	0	24.8	
20/03/2024 20:00	33.83	0.25	94.07	0	24	
20/03/2024 21:00	34.03	0.24	94.45	0	22.8	
20/03/2024 22:00	34	0.58	94.61	0	23.2	
20/03/2024 23:00	33.96	0.09	94.43	0	23.4	
21/03/2024 00:00	36.91	0.36	94.79	0	36.9	
Minimum	0	0	91.1	0	22.8	
MinDate	20/03/2024 01:00	20/03/2024 07:00	20/03/2024 12:00	20/03/2024 09:00	20/03/2024 11:00	
Maximum	36.91	0.58	94.79	0	50.7	
MaxDate	21/03/2024 00:00	20/03/2024 22:00	21/03/2024 00:00	20/03/2024 09:00	20/03/2024 12:00	
Avg	22.89	0.16	93.82	0	26.1	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.3	0.1	0.8	0	7.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/03/2024 00:00	16.1	0.01	<Samp	<Samp	<Samp	GT11 S/D
21/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/03/2024 06:00	0	0.23	ShutDown	ShutDown	ShutDown	GT11 S/D
21/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
21/03/2024 08:00	21.56	0	<Samp	<Samp	<Samp	GT11 S/D
21/03/2024 09:00	34.2	0	93.47	1.4	28.4	
21/03/2024 10:00	34.16	0	93.3	1.4	28.3	
21/03/2024 11:00	34.15	0	93.63	1.4	28.1	
21/03/2024 12:00	22.29	0	91.58	1.5	52.3	
21/03/2024 13:00	34.26	0	93.93	1.4	30.3	
21/03/2024 14:00	34.19	0	94.73	1.4	27.9	
21/03/2024 15:00	34.22	0	94.67	1.4	29.7	
21/03/2024 16:00	34.11	0	94.2	1.3	27.2	
21/03/2024 17:00	33.65	0	93.68	1.3	26.3	
21/03/2024 18:00	33.78	0	93.65	1.3	26.3	
21/03/2024 19:00	33.64	0	93.68	1.3	26.1	
21/03/2024 20:00	33.87	0	93.73	1.3	26.1	
21/03/2024 21:00	34.13	0	94.11	1.4	26.2	
21/03/2024 22:00	34.11	0	94.13	1.4	26.1	
21/03/2024 23:00	33.99	0	94.18	1.4	26	
22/03/2024 00:00	36.75	0	94.35	1.4	37.7	
Minimum	0	0	91.58	1.3	26	
MinDate	21/03/2024 01:00	21/03/2024 01:00	21/03/2024 12:00	21/03/2024 16:00	21/03/2024 23:00	
Maximum	36.75	0.23	94.73	1.5	52.3	
MaxDate	22/03/2024 00:00	21/03/2024 06:00	21/03/2024 14:00	21/03/2024 12:00	21/03/2024 12:00	
Avg	22.93	0.01	93.81	1.4	29.6	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.3	0	0.7	0.1	6.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/03/2024 00:00	36.91	0.36	94.79	0	36.9	
21/03/2024 01:00	48.74	0.34	95.85	0	39.2	
21/03/2024 02:00	48.87	0.3	95.94	0	40.3	
21/03/2024 03:00	48.88	0.31	96.14	0	40	
21/03/2024 04:00	48.69	0.85	96.22	0	39.3	
21/03/2024 05:00	48.26	0.39	96.52	0	37.4	
21/03/2024 06:00	48.36	0.31	96.32	0	39.7	
21/03/2024 07:00	48.25	0.05	96.04	0	39.6	
21/03/2024 08:00	33.88	0.54	94.6	0	38.9	
21/03/2024 09:00	34.14	0.39	93.81	0	22.4	
21/03/2024 10:00	34.1	0.06	93.92	0	22.3	
21/03/2024 11:00	34.09	0.1	94.35	0	22.2	
21/03/2024 12:00	22.12	0.28	92.19	0	49.1	
21/03/2024 13:00	34.18	0.14	94.61	0	24.6	
21/03/2024 14:00	34.12	0.18	95.17	0	21.8	
21/03/2024 15:00	34.16	0.21	95.29	0	21.7	
21/03/2024 16:00	34.04	0.2	94.97	0	21.1	
21/03/2024 17:00	33.6	0.19	94.46	0	20.3	
21/03/2024 18:00	33.73	0.17	94.43	0	20.3	
21/03/2024 19:00	33.58	0.12	94.41	0	20.3	
21/03/2024 20:00	33.81	0.12	94.47	0	20.2	
21/03/2024 21:00	34.06	0.13	94.72	0	20.2	
21/03/2024 22:00	34.05	0.1	94.71	0	20.2	
21/03/2024 23:00	33.93	0.07	94.71	0	20.1	
22/03/2024 00:00	16.38	0.09	<Samp	<Samp	<Samp	GT12 S/D
Minimum	16.38	0.05	92.19	0	20.1	
MinDate	22/03/2024 00:00	21/03/2024 07:00	21/03/2024 12:00	21/03/2024 00:00	21/03/2024 23:00	
Maximum	48.88	0.85	96.52	0	49.1	
MaxDate	21/03/2024 03:00	21/03/2024 04:00	21/03/2024 05:00	21/03/2024 00:00	21/03/2024 12:00	
Avg	37	0.24	94.94	0	29.1	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	8.5	0.2	1	0	9.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/03/2024 00:00	36.75	0	94.35	1.4	37.7	
22/03/2024 01:00	48.62	0	95.27	1.4	37.4	
22/03/2024 02:00	48.79	0	95.49	1.4	37.1	
22/03/2024 03:00	48.84	0	95.78	1.4	36.8	
22/03/2024 04:00	48.68	0	95.87	1.5	36.1	
22/03/2024 05:00	48.47	0	96.02	1.5	34.9	
22/03/2024 06:00	48.46	0.17	96.41	1.5	34.8	
22/03/2024 07:00	48.44	0	96.62	1.5	35	
22/03/2024 08:00	35.87	0	96.14	1.5	37.2	
22/03/2024 09:00	34.2	0	94.77	1.5	25.4	
22/03/2024 10:00	34.18	0	94.87	1.4	25.4	
22/03/2024 11:00	34.12	0	95.04	1.4	25.6	
22/03/2024 12:00	22.41	0	92.6	1.6	49.3	
22/03/2024 13:00	34.24	0	93.69	1.4	26.9	
22/03/2024 14:00	34.19	0	94.05	1.3	24.7	
22/03/2024 15:00	34.18	0	93.97	1.3	25	
22/03/2024 16:00	34.02	0	94.12	1.3	24.9	
22/03/2024 17:00	33.81	0	93.85	1.3	24.5	
22/03/2024 18:00	33.72	0	93.38	1.3	24.4	
22/03/2024 19:00	33.57	0	92.88	1.3	24.4	
22/03/2024 20:00	33.81	0	92.98	1.3	24.2	
22/03/2024 21:00	33.96	0	93.32	1.3	24.1	
22/03/2024 22:00	36.86	0	94.84	1.4	25.4	
22/03/2024 23:00	37.6	0	95.91	1.4	26	
23/03/2024 00:00	29.81	0	93.7	1.4	41	
Minimum	22.41	0	92.6	1.3	24.1	
MinDate	22/03/2024 12:00	22/03/2024 00:00	22/03/2024 12:00	22/03/2024 14:00	22/03/2024 21:00	
Maximum	48.84	0.17	96.62	1.6	49.3	
MaxDate	22/03/2024 03:00	22/03/2024 06:00	22/03/2024 07:00	22/03/2024 12:00	22/03/2024 12:00	
Avg	37.9	0.01	94.64	1.4	30.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.4	0	1.2	0.1	7.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/03/2024 00:00	16.38	0.09		<Samp		GT12 S/D
22/03/2024 01:00	0	0.1	ShutDown	ShutDown	ShutDown	GT12 S/D
22/03/2024 02:00	0	0.07	ShutDown	ShutDown	ShutDown	GT12 S/D
22/03/2024 03:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
22/03/2024 04:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
22/03/2024 05:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
22/03/2024 06:00	0	0.04	ShutDown	ShutDown	ShutDown	GT12 S/D
22/03/2024 07:00	0	0.04	ShutDown	ShutDown	ShutDown	GT12 S/D
22/03/2024 08:00	19.43	0.09		<Samp		GT12 S/D
22/03/2024 09:00	34.14	<Samp	95.63	0	22.7	Calibrate
22/03/2024 10:00	34.12	0.41	95.49	0	22.8	Calibrate
22/03/2024 11:00	34.05	<Samp	95.58	0	22.9	Calibrate
22/03/2024 12:00	22.38	<Samp	93.26	0	46.6	Calibrate
22/03/2024 13:00	34.18	<Samp	94.58	0	23.7	Calibrate
22/03/2024 14:00	34.13	0	94.69	0	21.5	
22/03/2024 15:00	34.12	0	94.73	0	21.9	
22/03/2024 16:00	33.97	0	94.7	0	21.8	
22/03/2024 17:00	33.75	0	94.42	0	21.4	
22/03/2024 18:00	33.65	0	93.86	0	21.4	
22/03/2024 19:00	33.5	0	93.31	0	22	
22/03/2024 20:00	33.74	0	93.41	0	21.4	
22/03/2024 21:00	33.89	0	93.68	0	21.2	
22/03/2024 22:00	36.8	0	95.21	0	22.8	
22/03/2024 23:00	37.53	0	96.26	0	23.4	
23/03/2024 00:00	29.74	0	94.03	0	36.8	
Minimum	0	0	93.26	0	21.2	
MinDate	22/03/2024 01:00	22/03/2024 14:00	22/03/2024 12:00	22/03/2024 09:00	22/03/2024 21:00	
Maximum	37.53	0.41	96.26	0	46.6	
MaxDate	22/03/2024 23:00	22/03/2024 10:00	22/03/2024 23:00	22/03/2024 09:00	22/03/2024 12:00	
Avg	22.78	0.04	94.55	0	24.6	
Num	25	21	16	16	16	
Data[%]	100	84	64	64	64	
STD	15.3	0.1	0.9	0	6.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/03/2024 00:00	29.81	0	93.7	1.4	41	
23/03/2024 01:00	29.41	0	92.45	1.4	42.6	
23/03/2024 02:00	31.22	0	92.93	1.4	36.3	
23/03/2024 03:00	31.28	0	92.84	1.4	36.4	
23/03/2024 04:00	31.15	0	92.77	1.4	36.4	
23/03/2024 05:00	31.05	0	92.8	1.4	36.3	
23/03/2024 06:00	30.99	0.36	92.95	1.4	36.4	
23/03/2024 07:00	30.93	0	93	1.4	36.7	
23/03/2024 08:00	34.62	0	94.06	1.4	34.9	
23/03/2024 09:00	45.48	0	101.99	1.4	28.1	
23/03/2024 10:00	45.95	0	102.93	1.4	30.5	
23/03/2024 11:00	45.92	0	102.47	1.4	32.1	
23/03/2024 12:00	33.28	0	96.91	1.4	28.5	
23/03/2024 13:00	46.42	0	100.68	1.4	35.2	
23/03/2024 14:00	45.9	0	101.65	1.3	32.7	
23/03/2024 15:00	46.04	0	101.35	1.3	31.8	
23/03/2024 16:00	45.9	0	101.43	1.3	29.9	
23/03/2024 17:00	45.71	0	101.78	1.3	28.5	
23/03/2024 18:00	45.65	0	102.02	1.3	27.6	
23/03/2024 19:00	45.63	0	102.09	1.3	27.2	
23/03/2024 20:00	46.03	0	102.21	1.3	27.5	
23/03/2024 21:00	46.16	0	102.67	1.4	27.4	
23/03/2024 22:00	46.18	0	102.84	1.4	27.3	
23/03/2024 23:00	46.12	0	102.93	1.4	27	
24/03/2024 00:00	33.83	0	97.55	1.4	35.9	
Minimum	29.41	0	92.45	1.3	27	
MinDate	23/03/2024 01:00	23/03/2024 00:00	23/03/2024 01:00	23/03/2024 14:00	23/03/2024 23:00	
Maximum	46.42	0.36	102.93	1.4	42.6	
MaxDate	23/03/2024 13:00	23/03/2024 06:00	23/03/2024 10:00	23/03/2024 00:00	23/03/2024 01:00	
Avg	39.63	0.01	98.44	1.4	32.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0.1	4.4	0	4.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/03/2024 00:00	29.74	0	94.03	0	36.8	
23/03/2024 01:00	29.34	0.02	92.92	0	38.2	
23/03/2024 02:00	31.16	0.09	93.31	0	33.3	
23/03/2024 03:00	31.22	0.16	93.29	0	33.4	
23/03/2024 04:00	31.09	0.16	93.21	0	33.5	
23/03/2024 05:00	30.98	0.16	93.28	0	33.2	
23/03/2024 06:00	30.93	0.14	93.39	0	33.4	
23/03/2024 07:00	30.87	0.1	93.41	0	33.5	
23/03/2024 08:00	34.55	0.05	94.53	0	32.9	
23/03/2024 09:00	45.4	0.03	102.13	0	30.5	
23/03/2024 10:00	45.88	0.08	102.88	0	33.9	
23/03/2024 11:00	45.85	0.16	102.47	0	36.1	
23/03/2024 12:00	33.21	0.15	96.72	0	26.6	
23/03/2024 13:00	46.28	0.45	100.48	0	39.9	
23/03/2024 14:00	45.84	0	101.35	0	36.7	
23/03/2024 15:00	45.97	0	101.46	0	35.3	
23/03/2024 16:00	45.82	0	101.54	0	32.9	
23/03/2024 17:00	45.63	0	101.85	0	31.2	
23/03/2024 18:00	45.58	0	102.07	0	30	
23/03/2024 19:00	45.55	0	102.17	0	29.1	
23/03/2024 20:00	45.96	0	102.32	0	29.9	
23/03/2024 21:00	46.09	0	102.58	0	30	
23/03/2024 22:00	46.1	0	102.76	0	29.6	
23/03/2024 23:00	46.05	0	102.85	0	29.1	
24/03/2024 00:00	36.96	0	98.03	0	25.6	
Minimum	29.34	0	92.92	0	25.6	
MinDate	23/03/2024 01:00	23/03/2024 00:00	23/03/2024 01:00	23/03/2024 00:00	24/03/2024 00:00	
Maximum	46.28	0.45	102.88	0	39.9	
MaxDate	23/03/2024 13:00	23/03/2024 13:00	23/03/2024 10:00	23/03/2024 00:00	23/03/2024 13:00	
Avg	39.68	0.07	98.6	0	32.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0.1	4.2	0	3.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/03/2024 00:00	33.83	0	92.55	1.4	35.9	
24/03/2024 01:00	28.44	0	92.71	1.4	42.7	
24/03/2024 02:00	28.44	0	92.7	1.4	42.3	
24/03/2024 03:00	28.45	0	92.83	1.4	42	
24/03/2024 04:00	28.45	0	92.75	1.5	42.1	
24/03/2024 05:00	28.25	0	92.66	1.5	42.8	
24/03/2024 06:00	27.45	0.3	92.41	1.5	44.9	
24/03/2024 07:00	27.44	0	92.83	1.5	46.3	
24/03/2024 08:00	27.44	0	92.96	1.5	46.2	
24/03/2024 09:00	27.39	0	93.19	1.5	44.5	
24/03/2024 10:00	27.31	0	93.24	1.5	45.3	
24/03/2024 11:00	27.3	0	93.48	1.5	44.4	
24/03/2024 12:00	27.32	0	93.42	1.5	43.6	
24/03/2024 13:00	27.31	0	92.11	1.4	43.7	
24/03/2024 14:00	27.33	0	92.95	1.4	43.8	
24/03/2024 15:00	27.31	0	92.61	1.4	42.5	
24/03/2024 16:00	27.31	0	92.83	1.4	42.2	
24/03/2024 17:00	27.3	0	92.71	1.4	42.7	
24/03/2024 18:00	40.04	0	97.02	1.4	31.5	
24/03/2024 19:00	44.62	0	101.41	1.4	26.3	
24/03/2024 20:00	44.62	0	101.47	1.4	25.8	
24/03/2024 21:00	44.52	0	101.62	1.4	25.7	
24/03/2024 22:00	44.52	0	101.68	1.4	25.5	
24/03/2024 23:00	30.5	0	95.11	1.4	33.9	
25/03/2024 00:00	30.52	0	93.26	1.4	33.4	
Minimum	27.3	0	92.11	1.4	25.5	
MinDate	24/03/2024 11:00	24/03/2024 00:00	24/03/2024 13:00	24/03/2024 00:00	24/03/2024 22:00	
Maximum	44.62	0.3	101.68	1.5	46.3	
MaxDate	24/03/2024 19:00	24/03/2024 06:00	24/03/2024 22:00	24/03/2024 04:00	24/03/2024 07:00	
Avg	31.34	0.01	94.7	1.4	39.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.5	0.1	3.3	0	7.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/03/2024 00:00	36.96	0	98.03	0	25.6	
24/03/2024 01:00	35.34	0	94.95	0	19.9	
24/03/2024 02:00	35.32	0	94.94	0	19.7	
24/03/2024 03:00	35.68	0.03	94.96	0	19.4	
24/03/2024 04:00	34.12	0.02	94.47	0	19.1	
24/03/2024 05:00	33.88	0.02	94.21	0	19.5	
24/03/2024 06:00	34.44	0	94.41	0	19.1	
24/03/2024 07:00	34.09	0	94.57	0	22.1	
24/03/2024 08:00	33.9	0	94.68	0	22.4	
24/03/2024 09:00	33.93	0.03	94.97	0	21.1	
24/03/2024 10:00	33.92	0.11	95.06	0	21.5	
24/03/2024 11:00	33.84	0.18	95.31	0	21.3	
24/03/2024 12:00	34	1.07	95.3	0	21.1	
24/03/2024 13:00	33.87	<Samp	93.86	0	20.9	Calibrate
24/03/2024 14:00	33.89	<Samp	94.69	0	20.7	Calibrate
24/03/2024 15:00	33.93	0.7	94.5	0	20.4	
24/03/2024 16:00	33.94	<Samp	94.78	0	20.4	Calibrate
24/03/2024 17:00	33.99	0.1	94.79	0	20.5	
24/03/2024 18:00	42.04	0.35	98.61	0	27.2	
24/03/2024 19:00	44.54	0.34	101.87	0	28	
24/03/2024 20:00	44.55	0.05	101.92	0	27.5	
24/03/2024 21:00	44.44	0.06	101.9	0	27.1	
24/03/2024 22:00	44.44	0.07	101.97	0	26.8	
24/03/2024 23:00	30.44	0.19	95.15	0	31.9	
25/03/2024 00:00	30.46	0.15	93.26	0	31.6	
Minimum	30.44	0	93.26	0	19.1	
MinDate	24/03/2024 23:00	24/03/2024 00:00	25/03/2024 00:00	24/03/2024 00:00	24/03/2024 04:00	
Maximum	44.55	1.07	101.97	0	31.9	
MaxDate	24/03/2024 20:00	24/03/2024 12:00	24/03/2024 22:00	24/03/2024 00:00	24/03/2024 23:00	
Avg	35.97	0.16	96.13	0	23	
Num	25	22	25	25	25	
Data[%]	100	88	100	100	100	
STD	4.3	0.3	2.8	0	3.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
25/03/2024 00:00	30.52	0	93.26	1.4	33.4	
25/03/2024 01:00	30.52	0	93.32	1.4	33.5	
25/03/2024 02:00	30.49	0	93.33	1.4	33.5	
25/03/2024 03:00	30.49	0	93.25	1.4	33.3	
25/03/2024 04:00	30.5	0	93.33	1.4	33.2	
25/03/2024 05:00	30.53	0	93.37	1.5	33	
25/03/2024 06:00	30.56	0.21	93.46	1.5	33	
25/03/2024 07:00	30.71	0	93.65	1.4	32.4	
25/03/2024 08:00	32.43	0	94.61	1.4	28.1	
25/03/2024 09:00	33.95	0	95.27	1.4	21.1	
25/03/2024 10:00	34.07	0	95.47	1.4	20.9	
25/03/2024 11:00	34.11	0	95.75	1.4	21.2	
25/03/2024 12:00	22.01	0	92.97	1.5	45.4	
25/03/2024 13:00	34.24	0	94.42	1.4	22.7	
25/03/2024 14:00	34.26	0	94.77	1.3	20.8	
25/03/2024 15:00	34.22	0	94.97	1.3	20.9	
25/03/2024 16:00	34.14	0	95.24	1.4	20.8	
25/03/2024 17:00	33.52	0	94.64	1.3	20.8	
25/03/2024 18:00	33.89	0	94.17	1.3	20.8	
25/03/2024 19:00	33.74	0	94.19	1.3	20.6	
25/03/2024 20:00	33.96	0	94.26	1.3	20.5	
25/03/2024 21:00	34.11	0	94.5	1.3	20.4	
25/03/2024 22:00	34.07	0	94.82	1.3	20.4	
25/03/2024 23:00	34.03	0	94.71	1.3	20.4	
26/03/2024 00:00	16.43	0	<Samp	<Samp	<Samp	GT11 S/D
Minimum	16.43	0	92.97	1.3	20.4	
MinDate	26/03/2024 00:00	25/03/2024 00:00	25/03/2024 12:00	25/03/2024 14:00	25/03/2024 21:00	
Maximum	34.26	0.21	95.75	1.5	45.4	
MaxDate	25/03/2024 14:00	25/03/2024 06:00	25/03/2024 11:00	25/03/2024 05:00	25/03/2024 12:00	
Avg	31.68	0.01	94.24	1.4	26.3	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	4.2	0	0.8	0.1	7.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
25/03/2024 00:00	30.46	0.15	93.26	0	31.6	
25/03/2024 01:00	30.46	0.07	93.28	0	31.7	
25/03/2024 02:00	30.44	0.09	93.34	0	31.8	
25/03/2024 03:00	30.43	0.12	93.25	0	31.5	
25/03/2024 04:00	30.44	0.2	93.36	0	31.4	
25/03/2024 05:00	30.47	0.25	93.34	0	31.1	
25/03/2024 06:00	30.5	0.25	93.4	0	31.1	
25/03/2024 07:00	30.65	0.22	93.62	0	30.5	
25/03/2024 08:00	32.42	0.24	94.58	0	27.3	
25/03/2024 09:00	33.9	0.24	95.28	0	19.5	
25/03/2024 10:00	34	0.25	95.38	0	19.2	
25/03/2024 11:00	34.04	0.25	95.71	0	19.6	
25/03/2024 12:00	22.05	<Samp	93.01	0	44.3	Calibrate
25/03/2024 13:00	34.22	0.71	94.69	0	20.7	
25/03/2024 14:00	34.2	0.58	94.75	0	18.8	
25/03/2024 15:00	34.16	0.55	95.14	0	18.9	
25/03/2024 16:00	34.08	0.49	95.37	0	18.8	
25/03/2024 17:00	33.85	<Samp	95	0	18.9	Calibrate
25/03/2024 18:00	33.82	0.44	94.64	0	18.8	
25/03/2024 19:00	33.68	<Samp	94.36	0	18.7	Calibrate
25/03/2024 20:00	33.9	0.09	94.43	0	18.5	
25/03/2024 21:00	34.04	0.06	94.56	0	18.5	
25/03/2024 22:00	34.01	0.46	94.77	0	18.5	
25/03/2024 23:00	33.97	0.31	94.63	0	18.5	
26/03/2024 00:00	36.4	<Samp	95.11	0	31.8	Calibrate
Minimum	22.05	0.06	93.01	0	18.5	
MinDate	25/03/2024 12:00	25/03/2024 21:00	25/03/2024 12:00	25/03/2024 00:00	25/03/2024 20:00	
Maximum	36.4	0.71	95.71	0	44.3	
MaxDate	26/03/2024 00:00	25/03/2024 13:00	25/03/2024 11:00	25/03/2024 00:00	25/03/2024 12:00	
Avg	32.42	0.29	94.33	0	24.8	
Num	25	21	25	25	25	
Data[%]	100	84	100	100	100	
STD	2.8	0.2	0.8	0	7.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/03/2024 00:00	16.43	0	<Samp	<Samp	<Samp	GT11 S/D
26/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/03/2024 06:00	0	0.15	ShutDown	ShutDown	ShutDown	GT11 S/D
26/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
26/03/2024 08:00	20.69	0.04	<Samp	<Samp	<Samp	GT11 S/D
26/03/2024 09:00	34.31	0	95.26	1.4	27.7	
26/03/2024 10:00	34.3	0	95.34	1.4	27.8	
26/03/2024 11:00	34.21	0	95.57	1.4	27.7	
26/03/2024 12:00	22.07	0	93.2	1.5	49.1	
26/03/2024 13:00	34.44	0	95.17	1.4	29.4	
26/03/2024 14:00	34.34	0	95.53	1.4	27.7	
26/03/2024 15:00	34.24	0	95.03	1.4	27.6	
26/03/2024 16:00	34.13	0	94.59	1.3	27.3	
26/03/2024 17:00	33.77	0	94.13	1.3	27.1	
26/03/2024 18:00	33.7	0	93.95	1.3	26.9	
26/03/2024 19:00	33.66	0	94.02	1.3	26.5	
26/03/2024 20:00	34	0	94.23	1.3	26.4	
26/03/2024 21:00	34.04	0	94.62	1.3	26.3	
26/03/2024 22:00	34.02	0	94.68	1.3	26.3	
26/03/2024 23:00	33.94	0	94.7	1.3	26.1	
27/03/2024 00:00	36.59	0	94.95	1.4	37	
Minimum	0	0	93.2	1.3	26.1	
MinDate	26/03/2024 01:00	26/03/2024 00:00	26/03/2024 12:00	26/03/2024 16:00	26/03/2024 23:00	
Maximum	36.59	0.15	95.57	1.5	49.1	
MaxDate	27/03/2024 00:00	26/03/2024 06:00	26/03/2024 11:00	26/03/2024 12:00	26/03/2024 12:00	
Avg	22.92	0.01	94.69	1.4	29.2	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.4	0	0.7	0.1	5.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/03/2024 00:00	36.4	<Samp	95.11	0	31.6	
26/03/2024 01:00	48.32	<Samp	95.57	0	35.6	
26/03/2024 02:00	48.36	<Samp	95.2	0	35.6	
26/03/2024 03:00	48.46	0.06	95.36	0	35.7	
26/03/2024 04:00	48.5	0.77	95.39	0	35.7	
26/03/2024 05:00	48.54	0.27	95.4	0	35.5	
26/03/2024 06:00	48.6	<Samp	95.91	0	35.5	Calibrate
26/03/2024 07:00	48.47	0.08	95.62	0	35.1	
26/03/2024 08:00	34.78	0.09	95.07	0	31.3	
26/03/2024 09:00	34.24	0.05	95	0	18.5	
26/03/2024 10:00	34.24	0.09	95.13	0	18.5	
26/03/2024 11:00	34.15	0.13	95.35	0	18.4	
26/03/2024 12:00	22.08	0.16	93.13	0	44	
26/03/2024 13:00	34.4	0.41	95.31	0	20.1	
26/03/2024 14:00	34.27	0.06	95.48	0	18.3	
26/03/2024 15:00	34.18	0.31	95.15	0	18.1	
26/03/2024 16:00	34.07	0.03	94.88	0	17.9	
26/03/2024 17:00	33.71	0.39	94.47	0	18	
26/03/2024 18:00	33.64	0.43	94.3	0	18	
26/03/2024 19:00	33.61	0.09	94.29	0	17.8	
26/03/2024 20:00	33.94	0.46	94.47	0	17.7	
26/03/2024 21:00	33.97	0.09	94.65	0	17.7	
26/03/2024 22:00	33.95	0.14	94.67	0	17.6	
26/03/2024 23:00	33.98	0.67	94.68	0	17.6	
27/03/2024 00:00	16.3	0.37	<Samp	<Samp	<Samp	GT12 S/D
Minimum	16.3	0.03	93.13	0	17.6	
MinDate	27/03/2024 00:00	26/03/2024 16:00	26/03/2024 12:00	26/03/2024 00:00	26/03/2024 22:00	
Maximum	48.6	0.77	95.91	0	44	
MaxDate	26/03/2024 06:00	26/03/2024 04:00	26/03/2024 06:00	26/03/2024 00:00	26/03/2024 12:00	
Avg	37	0.25	94.98	0	25.4	
Num	25	21	24	24	24	
Data[%]	100	84	96	96	96	
STD	8.4	0.2	0.6	0	9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/03/2024 00:00	36.59	0	94.95	1.4	37	
27/03/2024 01:00	48.47	0	95.6	1.4	37.6	
27/03/2024 02:00	48.52	0	95.45	1.3	37.7	
27/03/2024 03:00	48.55	0	95.97	1.4	37.4	
27/03/2024 04:00	48.53	0	96.09	1.4	37.2	
27/03/2024 05:00	48.43	0	95.73	1.4	36.7	
27/03/2024 06:00	48.32	0.36	95.73	1.4	36.2	
27/03/2024 07:00	48.37	0	95.93	1.4	36.5	
27/03/2024 08:00	36.46	0	94.85	1.4	37.7	
27/03/2024 09:00	34.19	0	94.61	1.4	26.9	
27/03/2024 10:00	34.1	0	95.24	1.4	26.5	
27/03/2024 11:00	33.98	0	95.18	1.4	26.6	
27/03/2024 12:00	22.3	0	92.96	1.5	49.1	
27/03/2024 13:00	34.12	0	95.11	1.3	27.5	
27/03/2024 14:00	34.14	0	95.84	1.3	26.2	
27/03/2024 15:00	34.05	0	95.54	1.3	26.4	
27/03/2024 16:00	34.01	0	95.07	1.3	25.8	
27/03/2024 17:00	33.74	0	94.65	1.3	25.7	
27/03/2024 18:00	33.71	0	94.34	1.2	25.6	
27/03/2024 19:00	33.65	0	94.37	1.2	25.3	
27/03/2024 20:00	33.84	0	94.57	1.2	25.1	
27/03/2024 21:00	33.98	0	94.88	1.2	25	
27/03/2024 22:00	33.94	0	94.98	1.2	24.9	
27/03/2024 23:00	33.94	0	95.08	1.2	24.8	
28/03/2024 00:00	16.3	0.01	<Samp	<Samp	<Samp	GT11 SD
Minimum	16.3	0	92.96	1.2	24.8	
MinDate	28/03/2024 00:00	27/03/2024 00:00	27/03/2024 12:00	27/03/2024 18:00	27/03/2024 23:00	
Maximum	48.55	0.36	96.09	1.5	49.1	
MaxDate	27/03/2024 03:00	27/03/2024 06:00	27/03/2024 04:00	27/03/2024 12:00	27/03/2024 12:00	
Avg	37.05	0.01	95.11	1.3	31.1	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	8.4	0.1	0.7	0.1	6.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/03/2024 00:00	16.3	0.37	<Samp	<Samp	<Samp	GT12 S/D
27/03/2024 01:00	0	0.53	ShutDown	ShutDown	ShutDown	
27/03/2024 02:00	0	0.41	ShutDown	ShutDown	ShutDown	
27/03/2024 03:00	0	<Samp	ShutDown	ShutDown	ShutDown	
27/03/2024 04:00	0	<Samp	ShutDown	ShutDown	ShutDown	
27/03/2024 05:00	0	0.32	ShutDown	ShutDown	ShutDown	
27/03/2024 06:00	0	<Samp	ShutDown	ShutDown	ShutDown	
27/03/2024 07:00	0.22	<Samp	ShutDown	ShutDown	ShutDown	
27/03/2024 08:00	15.01	0.04	ShutDown	ShutDown	ShutDown	
27/03/2024 09:00	34.13	0.73	94.47	0	23.5	
27/03/2024 10:00	34.04	0.27	94.93	0	23.3	
27/03/2024 11:00	33.93	0.32	94.87	0	23.3	
27/03/2024 12:00	22.13	0.31	92.52	0	46.4	
27/03/2024 13:00	34.02	0.33	94.65	0	24	
27/03/2024 14:00	34.07	0.28	95.31	0	22.5	
27/03/2024 15:00	33.99	0.27	95.21	0	22.7	
27/03/2024 16:00	33.95	0.33	94.97	0	22	
27/03/2024 17:00	33.68	0.2	94.6	0	22	
27/03/2024 18:00	33.65	<Samp	94.3	0	22	DUST waiting for spare part
27/03/2024 19:00	33.6	Maintenance	94.18	0	21.7	DUST waiting for spare part
27/03/2024 20:00	33.78	<Samp	94.23	0	21.5	DUST waiting for spare part
27/03/2024 21:00	33.91	0.33	94.55	0	21.4	DUST waiting for spare part
27/03/2024 22:00	33.87	<Samp	94.59	0	21.3	DUST waiting for spare part
27/03/2024 23:00	33.87	<Samp	94.67	0	21.3	DUST waiting for spare part
28/03/2024 00:00	36.45	<Samp	95.17	0	34.8	DUST waiting for spare part
Minimum	0	0.04	92.52	0	21.3	
MinDate	27/03/2024 01:00	27/03/2024 08:00	27/03/2024 12:00	27/03/2024 09:00	27/03/2024 22:00	
Maximum	36.45	0.73	95.31	0	46.4	
MaxDate	28/03/2024 00:00	27/03/2024 09:00	27/03/2024 14:00	27/03/2024 09:00	27/03/2024 12:00	
Avg	22.58	0.34	94.57	0	24.6	
Num	25	15	16	16	16	
Data[%]	100	60	64	64	64	
STD	15.3	0.2	0.6	0	6.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
28/03/2024 00:00	16.3	0.01	<Samp	<Samp	<Samp	GT11 S/D
28/03/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
28/03/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
28/03/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
28/03/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
28/03/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
28/03/2024 06:00	0	0.3	ShutDown	ShutDown	ShutDown	GT11 S/D
28/03/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
28/03/2024 08:00	21.81	0.01	<Samp	<Samp	<Samp	GT11 S/D
28/03/2024 09:00	34.12	0	95.97	1.4	27.4	
28/03/2024 10:00	34.23	0	96.24	1.4	27.8	
28/03/2024 11:00	34.02	0	96.53	1.4	28.2	
28/03/2024 12:00	21.88	0	93.82	1.5	52.3	
28/03/2024 13:00	34.06	0	95.53	1.4	29.2	
28/03/2024 14:00	34.16	0	96.07	1.3	27.4	
28/03/2024 15:00	34.08	0	95.67	1.3	27.5	
28/03/2024 16:00	34.02	0	95.22	1.3	27.3	
28/03/2024 17:00	33.77	0	94.69	1.3	27.1	
28/03/2024 18:00	33.75	0	94.32	1.2	26.6	
28/03/2024 19:00	33.7	0	94.48	1.2	26.1	
28/03/2024 20:00	33.82	0	94.56	1.2	25.8	
28/03/2024 21:00	33.99	0	95.11	1.2	25.8	
28/03/2024 22:00	33.96	0	95.2	1.3	25.7	
28/03/2024 23:00	33.87	0	95.12	1.3	25.5	
29/03/2024 00:00	36.43	0	95.55	1.3	36.4	
Minimum	0	0	93.82	1.2	25.5	
MinDate	28/03/2024 01:00	28/03/2024 01:00	28/03/2024 12:00	28/03/2024 18:00	28/03/2024 23:00	
Maximum	36.43	0.3	96.53	1.5	52.3	
MaxDate	29/03/2024 00:00	28/03/2024 06:00	28/03/2024 11:00	28/03/2024 12:00	28/03/2024 12:00	
Avg	22.88	0.01	95.25	1.3	29.1	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.3	0.1	0.8	0.1	6.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
28/03/2024 00:00	36.45	<Samp	95.12	0	34.8	DUST waiting for spare part
28/03/2024 01:00	48.32	Maintenance	95.65	0	40.1	DUST waiting for spare part
28/03/2024 02:00	48.42	<Samp	95.24	0	40.3	DUST waiting for spare part
28/03/2024 03:00	48.4	<Samp	95.49	0	40.1	DUST waiting for spare part
28/03/2024 04:00	48.32	Maintenance	95.53	0	39.3	DUST waiting for spare part
28/03/2024 05:00	48.11	<Samp	95.72	0	37.9	DUST waiting for spare part
28/03/2024 06:00	48.25	Maintenance	96.14	0	38.3	DUST waiting for spare part
28/03/2024 07:00	48.18	Maintenance	95.86	0	38.1	DUST waiting for spare part
28/03/2024 08:00	33.76	<Samp	95.11	0	33.7	DUST waiting for spare part
28/03/2024 09:00	34.06	Maintenance	95.07	0	21.3	DUST waiting for spare part
28/03/2024 10:00	34.17	<Samp	95.36	0	21.7	DUST waiting for spare part
28/03/2024 11:00	33.96	<Samp	95.72	0	22	DUST waiting for spare part
28/03/2024 12:00	21.89	<Samp	92.97	0	48.5	DUST waiting for spare part
28/03/2024 13:00	33.99	<Samp	95.09	0	23.1	DUST waiting for spare part
28/03/2024 14:00	34.09	0.24	95.53	0	21.1	DUST waiting for spare part
28/03/2024 15:00	34.01	0.04	95.2	0	21.1	DUST waiting for spare part
28/03/2024 16:00	33.96	0	95.01	0	20.9	DUST waiting for spare part
28/03/2024 17:00	33.7	0	94.59	0	20.7	DUST waiting for spare part
28/03/2024 18:00	33.69	0	94.21	0	20.3	DUST waiting for spare part
28/03/2024 19:00	33.63	0.44	94.15	0	20	DUST waiting for spare part
28/03/2024 20:00	33.75	0.05	94.15	0	19.9	DUST waiting for spare part
28/03/2024 21:00	33.92	0.05	94.62	0	19.9	DUST waiting for spare part
28/03/2024 22:00	33.9	0.07	94.55	0	19.9	DUST waiting for spare part
28/03/2024 23:00	33.8	0.07	94.49	0	19.7	DUST waiting for spare part
29/03/2024 00:00	16.29	<Samp	<Samp	<Samp	<Samp	GT12 S/D
Minimum	16.29	0	92.97	0	19.7	
MinDate	29/03/2024 00:00	28/03/2024 16:00	28/03/2024 12:00	28/03/2024 00:00	28/03/2024 23:00	
Maximum	48.42	0.44	96.14	0	48.5	
MaxDate	28/03/2024 02:00	28/03/2024 19:00	28/03/2024 06:00	28/03/2024 00:00	28/03/2024 12:00	
Avg	36.84	0.1	95.03	0	28.4	
Num	25	10	24	24	24	
Data[%]	100	40	96	96	96	
STD	8.4	0.1	0.7	0	9.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/03/2024 00:00	36.43	0	95.55	1.3	36.4	
29/03/2024 01:00	48.23	0	95.94	1.3	37.1	
29/03/2024 02:00	48.3	0	95.52	1.3	36.8	
29/03/2024 03:00	48.38	0	95.75	1.4	36.6	
29/03/2024 04:00	48.39	0	95.78	1.4	36.5	
29/03/2024 05:00	48.23	0	95.88	1.4	35.6	
29/03/2024 06:00	48.27	0.23	96.17	1.4	35.9	
29/03/2024 07:00	48.14	0	96.28	1.4	36.1	
29/03/2024 08:00	34.55	0	95.68	1.4	36.55	
29/03/2024 09:00	34.18	0	95.59	1.4	25.4	
29/03/2024 10:00	34.08	0	95.96	1.4	25.6	
29/03/2024 11:00	34.06	0	96.14	1.4	25.9	
29/03/2024 12:00	22.07	0	93.83	1.5	49.3	
29/03/2024 13:00	34.11	0	95.54	1.4	28.5	
29/03/2024 14:00	34.01	0	95.85	1.3	25.4	
29/03/2024 15:00	33.94	0	95.71	1.3	24.9	
29/03/2024 16:00	33.67	0	95.15	1.3	25.4	
29/03/2024 17:00	33.39	0	94.4	1.2	25.1	
29/03/2024 18:00	33.36	0	94.16	1.2	25	
29/03/2024 19:00	33.39	0	94.16	1.2	24.6	
29/03/2024 20:00	33.67	0	94.3	1.2	24.3	
29/03/2024 21:00	33.81	0	94.78	1.2	24.3	
29/03/2024 22:00	36.93	0	96.48	1.2	25.5	
29/03/2024 23:00	37.7	0	97.52	1.3	26	
30/03/2024 00:00	30.31	0	95.32	1.3	38.3	
Minimum	22.07	0	93.83	1.2	24.3	
MinDate	29/03/2024 12:00	29/03/2024 00:00	29/03/2024 12:00	29/03/2024 17:00	29/03/2024 20:00	
Maximum	48.39	0.23	97.52	1.5	49.3	
MaxDate	29/03/2024 04:00	29/03/2024 06:00	29/03/2024 23:00	29/03/2024 12:00	29/03/2024 12:00	
Avg	37.66	0.01	95.5	1.3	30.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0	0.8	0.1	6.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/03/2024 00:00	16.29	<Samp	<Samp	<Samp	<Samp	GT12 S/D
29/03/2024 01:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
29/03/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
29/03/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
29/03/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
29/03/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
29/03/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
29/03/2024 07:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
29/03/2024 08:00	20.76	<Samp	<Samp	<Samp	<Samp	GT12 S/D
29/03/2024 09:00	34.13	0.02	95.52	0	22.2	
29/03/2024 10:00	34.01	0.85	95.55	0	22.3	
29/03/2024 11:00	33.99	0.23	95.68	0	22.5	
29/03/2024 12:00	22.06	Audit	93.68	0	46.8	
29/03/2024 13:00	34.04	0.86	95.39	0	24.9	
29/03/2024 14:00	33.94	<Samp	95.42	0	21.7	Calibrate
29/03/2024 15:00	33.88	0.09	95.28	0	21.2	
29/03/2024 16:00	33.61	0.39	94.83	0	21.7	
29/03/2024 17:00	33.33	0	94.37	0	21.5	
29/03/2024 18:00	33.3	0	94.18	0	21.4	
29/03/2024 19:00	33.33	0.27	94.07	0	21	
29/03/2024 20:00	33.6	0.02	94.03	0	20.9	
29/03/2024 21:00	33.75	0	94.32	0	20.9	
29/03/2024 22:00	36.85	0.01	96.07	0	22.3	
29/03/2024 23:00	37.63	0.07	97.13	0	22.8	
30/03/2024 00:00	30.26	0.18	94.9	0	34	
Minimum	0	0	93.68	0	20.9	
MinDate	29/03/2024 01:00	29/03/2024 17:00	29/03/2024 12:00	29/03/2024 09:00	29/03/2024 20:00	
Maximum	37.63	0.86	97.13	0	46.8	
MaxDate	29/03/2024 23:00	29/03/2024 13:00	29/03/2024 23:00	29/03/2024 09:00	29/03/2024 12:00	
Avg	22.75	0.21	95.03	0	24.3	
Num	25	14	16	16	16	
Data[%]	100	56	64	64	64	
STD	15.3	0.3	0.9	0	6.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
30/03/2024 00:00	30.31	0	95.32	1.3	38.3	
30/03/2024 01:00	28.42	0	93.64	1.3	42.1	
30/03/2024 02:00	28.44	0	93.58	1.3	41.8	
30/03/2024 03:00	28.34	0	93.43	1.3	42	
30/03/2024 04:00	28.1	0	93.31	1.4	42.8	
30/03/2024 05:00	27.9	0	93.14	1.4	43.4	
30/03/2024 06:00	27.74	0.17	93.14	1.4	43.9	
30/03/2024 07:00	27.57	0	93.37	1.4	44.2	
30/03/2024 08:00	31.01	0	94.38	1.4	40.9	
30/03/2024 09:00	41.31	0	99.64	1.3	27.4	
30/03/2024 10:00	41.35	0	100.06	1.4	27.5	
30/03/2024 11:00	41.31	0	100.36	1.4	27.9	
30/03/2024 12:00	25.78	0	94.62	1.4	44	
30/03/2024 13:00	41.46	0	98.75	1.3	29.4	
30/03/2024 14:00	41.35	0	99.85	1.3	27.7	
30/03/2024 15:00	41.35	0	99.69	1.3	27.5	
30/03/2024 16:00	41.33	0	99.75	1.3	27.9	
30/03/2024 17:00	41.28	0	99.2	1.3	27.4	
30/03/2024 18:00	41.25	0	98.77	1.2	27.2	
30/03/2024 19:00	41.23	0	98.63	1.2	26.8	
30/03/2024 20:00	41.21	0	98.67	1.2	26.5	
30/03/2024 21:00	41.16	0	99.07	1.2	26.4	
30/03/2024 22:00	41.13	0	99.34	1.2	26.3	
30/03/2024 23:00	41.1	0	99.26	1.3	26.2	
31/03/2024 00:00	30.71	0	95.37	1.3	38.4	
Minimum	25.78	0	93.14	1.2	26.2	
MinDate	30/03/2024 12:00	30/03/2024 00:00	30/03/2024 05:00	30/03/2024 18:00	30/03/2024 23:00	
Maximum	41.46	0.17	100.36	1.4	44.2	
MaxDate	30/03/2024 13:00	30/03/2024 06:00	30/03/2024 11:00	30/03/2024 04:00	30/03/2024 07:00	
Avg	35.69	0.01	96.97	1.3	33.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.5	0	2.8	0.1	7.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
30/03/2024 00:00	30.26	0.18	94.9	0	34	
30/03/2024 01:00	28.37	0.2	93.28	0	37.2	
30/03/2024 02:00	28.38	0.18	93.24	0	37	
30/03/2024 03:00	28.29	0.19	93.18	0	37.1	
30/03/2024 04:00	28.04	0.2	93.13	0	37.8	
30/03/2024 05:00	27.84	0.15	93	0	38.2	
30/03/2024 06:00	27.67	0.18	92.97	0	38.7	
30/03/2024 07:00	27.51	0.2	93.16	0	38.9	
30/03/2024 08:00	30.98	0.19	94.21	0	36.6	
30/03/2024 09:00	41.24	0.23	100.05	0	24.8	
30/03/2024 10:00	41.29	0.24	100.8	0	25.4	
30/03/2024 11:00	41.26	0.26	101.12	0	26.1	
30/03/2024 12:00	25.72	<Samp	95.34	0	41	Calibrate
30/03/2024 13:00	41.39	0.08	99.34	0	28.4	
30/03/2024 14:00	41.28	<Samp	99.99	0	25.5	Calibrate
30/03/2024 15:00	41.28	<Samp	99.85	0	25.4	Calibrate
30/03/2024 16:00	41.26	<Samp	100.22	0	26.2	Calibrate
30/03/2024 17:00	41.21	Maintenance	99.84	0	25.2	Calibrate
30/03/2024 18:00	41.18	<Samp	99.5	0	24.5	Calibrate
30/03/2024 19:00	41.16	Maintenance	99.29	0	23.8	Calibrate
30/03/2024 20:00	41.13	<Samp	99.17	0	23.4	Calibrate
30/03/2024 21:00	41.09	0.09	99.44	0	23.3	
30/03/2024 22:00	41.06	0.49	99.73	0	23.1	
30/03/2024 23:00	41.03	<Samp	99.74	0	22.9	Calibrate
31/03/2024 00:00	30.61	<Samp	95.78	0	34.2	Calibrate
Minimum	25.72	0.08	92.97	0	22.9	
MinDate	30/03/2024 12:00	30/03/2024 13:00	30/03/2024 06:00	30/03/2024 00:00	30/03/2024 23:00	
Maximum	41.39	0.49	101.12	0	41	
MaxDate	30/03/2024 13:00	30/03/2024 22:00	30/03/2024 11:00	30/03/2024 00:00	30/03/2024 12:00	
Avg	35.62	0.2	97.21	0	30.3	
Num	25	15	25	25	25	
Data[%]	100	60	100	100	100	
STD	6.5	0.1	3.2	0	6.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
31/03/2024 00:00	30.71	0	95.37	1.3	38.4	
31/03/2024 01:00	27.39	0	92.56	1.3	43.7	
31/03/2024 02:00	27.41	0	92.51	1.3	43.8	
31/03/2024 03:00	27.35	0	92.53	1.4	43.5	
31/03/2024 04:00	27.33	0	92.67	1.4	43.7	
31/03/2024 05:00	27.28	0	92.65	1.4	43.6	
31/03/2024 06:00	27.21	0.36	92.65	1.4	43.6	
31/03/2024 07:00	27.19	0	92.97	1.4	43.3	
31/03/2024 08:00	27.19	0	93.1	1.4	43.8	
31/03/2024 09:00	27.24	0	93.22	1.4	44.3	
31/03/2024 10:00	27.23	0	93.31	1.4	44.2	
31/03/2024 11:00	27.25	0	93.43	1.4	44.7	
31/03/2024 12:00	27.28	0	93.99	1.4	44.3	
31/03/2024 13:00	27.22	0	92.99	1.4	42.9	
31/03/2024 14:00	27.25	0	92.72	1.3	42.8	
31/03/2024 15:00	27.29	0	92.87	1.3	42.6	
31/03/2024 16:00	27.24	0	92.63	1.3	42.2	
31/03/2024 17:00	27.26	0	92.13	1.3	42.6	
31/03/2024 18:00	37.7	0	95.72	1.3	30.8	
31/03/2024 19:00	41.1	0	98.7	1.2	25.9	
31/03/2024 20:00	41.03	0	98.51	1.3	25.7	
31/03/2024 21:00	41.02	0	98.92	1.3	25.6	
31/03/2024 22:00	41.06	0	99.11	1.3	25.5	
31/03/2024 23:00	27.18	0	93.64	1.3	42.5	
01/04/2024 00:00	27.32	0	92.36	1.4	42.7	
Minimum	27.18	0	92.13	1.2	25.5	
MinDate	31/03/2024 23:00	31/03/2024 00:00	31/03/2024 17:00	31/03/2024 19:00	31/03/2024 22:00	
Maximum	41.1	0.36	99.11	1.4	44.7	
MaxDate	31/03/2024 19:00	31/03/2024 06:00	31/03/2024 22:00	31/03/2024 03:00	31/03/2024 11:00	
Avg	30.03	0.01	94.05	1.3	39.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	5.4	0.1	2.3	0.1	6.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
31/03/2024 00:00	30.61	<Samp	95.78	0	34.2	DUST waiting for spare part
31/03/2024 01:00	27.32	<Samp	92.92	0	38.6	DUST waiting for spare part
31/03/2024 02:00	27.35	<Samp	92.8	0	38.7	DUST waiting for spare part
31/03/2024 03:00	27.29	<Samp	92.79	0	38.5	DUST waiting for spare part
31/03/2024 04:00	27.27	<Samp	92.97	0	38.7	DUST waiting for spare part
31/03/2024 05:00	27.23	Maintenance	92.98	0	38.7	DUST waiting for spare part
31/03/2024 06:00	27.16	Maintenance	92.91	0	38.9	DUST waiting for spare part
31/03/2024 07:00	27.14	Maintenance	93.17	0	38.4	DUST waiting for spare part
31/03/2024 08:00	27.14	Maintenance	93.24	0	38.8	DUST waiting for spare part
31/03/2024 09:00	27.18	<Samp	93.38	0	39.7	DUST waiting for spare part
31/03/2024 10:00	27.18	0.18	93.59	0	40	DUST waiting for spare part
31/03/2024 11:00	27.19	<Samp	93.8	0	40.7	DUST waiting for spare part
31/03/2024 12:00	27.21	<Samp	94.27	0	40.4	DUST waiting for spare part
31/03/2024 13:00	27.17	Maintenance	93.39	0	39.2	DUST waiting for spare part
31/03/2024 14:00	27.18	<Samp	93.09	0	38.7	DUST waiting for spare part
31/03/2024 15:00	27.23	<Samp	93.38	0	38.7	DUST waiting for spare part
31/03/2024 16:00	27.19	Maintenance	93.17	0	38.2	DUST waiting for spare part
31/03/2024 17:00	27.2	Maintenance	92.75	0	38.2	DUST waiting for spare part
31/03/2024 18:00	37.64	<Samp	96.32	0	28	DUST waiting for spare part
31/03/2024 19:00	41.03	<Samp	99.24	0	22.8	DUST waiting for spare part
31/03/2024 20:00	40.96	<Samp	99.07	0	22.3	DUST waiting for spare part
31/03/2024 21:00	40.95	0.06	99.25	0	22.2	
31/03/2024 22:00	40.99	0.08	99.37	0	22.2	
31/03/2024 23:00	27.12	0.12	94.05	0	38	
01/04/2024 00:00	27.26	0.2	92.69	0	37.9	
Minimum	27.12	0.06	92.69	0	22.2	
MinDate	31/03/2024 23:00	31/03/2024 21:00	01/04/2024 00:00	31/03/2024 00:00	31/03/2024 21:00	
Maximum	41.03	0.2	99.37	0	40.7	
MaxDate	31/03/2024 19:00	01/04/2024 00:00	31/03/2024 22:00	31/03/2024 00:00	31/03/2024 11:00	
Avg	29.97	0.13	94.41	0	35.6	
Num	25	5	25	25	25	
Data[%]	100	20	100	100	100	
STD	5.4	0.1	2.3	0	6.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
01/04/2024 00:00	27.32	0	92.36	1.4	42.7	
01/04/2024 01:00	27.35	0	92.52	1.4	42.3	
01/04/2024 02:00	27.35	0	92.56	1.4	42.2	
01/04/2024 03:00	27.35	0	92.6	1.4	41.9	
01/04/2024 04:00	27.37	0	92.52	1.4	41.8	
01/04/2024 05:00	27.41	0	92.6	1.4	41.5	
01/04/2024 06:00	27.37	0.28	92.69	1.4	41.6	
01/04/2024 07:00	27.62	0	92.92	1.5	40.7	
01/04/2024 08:00	41.48	0	98.79	1.4	25	
01/04/2024 09:00	34.13	0	95.9	1.4	21.8	
01/04/2024 10:00	33.92	0	95.49	2.2	21.9	
01/04/2024 11:00	34.01	0	95.69	1.3	22.3	
01/04/2024 12:00	21.41	0.03	93.49	1.4	51.8	
01/04/2024 13:00	34.19	0	94.98	1.3	24.4	
01/04/2024 14:00	34.12	0	95.46	1.3	22.4	
01/04/2024 15:00	34.11	0	95.09	1.3	22.7	
01/04/2024 16:00	33.97	0	94.74	1.2	21.8	
01/04/2024 17:00	33.82	0	94.48	1.2	21.4	
01/04/2024 18:00	33.78	0	94.12	1.1	21.2	
01/04/2024 19:00	33.72	0	93.77	1.1	21.2	
01/04/2024 20:00	33.96	0	93.87	1.1	21.1	
01/04/2024 21:00	34.09	0	94.32	1.1	21	
01/04/2024 22:00	34.07	0	94.66	1.1	21	
01/04/2024 23:00	33.98	0	94.7	1.1	20.9	
02/04/2024 00:00	25.28	0	93.66	1.1	29.6	
Minimum	21.41	0	92.36	1.1	20.9	
MinDate	01/04/2024 12:00	01/04/2024 00:00	01/04/2024 00:00	01/04/2024 18:00	01/04/2024 23:00	
Maximum	41.48	0.28	98.79	2.2	51.8	
MaxDate	01/04/2024 08:00	01/04/2024 06:00	01/04/2024 08:00	01/04/2024 10:00	01/04/2024 12:00	
Avg	31.33	0.01	94.16	1.3	29.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.4	0.1	1.5	0.2	10.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
01/04/2024 00:00	27.26	0.2	92.69	0	37.9	
01/04/2024 01:00	27.29	0.15	92.83	0	37.7	
01/04/2024 02:00	27.29	0.17	92.86	0	37.4	
01/04/2024 03:00	27.29	0.2	92.89	0	37	
01/04/2024 04:00	27.3	0.18	92.83	0	36.9	
01/04/2024 05:00	27.34	0.19	92.93	0	36.7	
01/04/2024 06:00	27.3	0.32	92.99	0	36.8	
01/04/2024 07:00	27.56	0.3	93.19	0	35.9	
01/04/2024 08:00	41.41	0.31	99.19	0	23.2	
01/04/2024 09:00	34.08	<Samp	96.12	0	18.1	DUST waiting for spare part
01/04/2024 10:00	33.86	<Samp	95.74	0	18.3	DUST waiting for spare part
01/04/2024 11:00	33.95	<Samp	95.99	0	18.7	DUST waiting for spare part
01/04/2024 12:00	21.21	<Samp	93.93	0	52	DUST waiting for spare part
01/04/2024 13:00	34.12	Maintenance	95.4	0	21.1	DUST waiting for spare part
01/04/2024 14:00	34.06	Maintenance	95.65	0	19	DUST waiting for spare part
01/04/2024 15:00	34.05	<Samp	95.45	0	19.2	DUST waiting for spare part
01/04/2024 16:00	33.9	<Samp	95.11	0	17.9	DUST waiting for spare part
01/04/2024 17:00	33.75	Maintenance	94.91	0	17.4	DUST waiting for spare part
01/04/2024 18:00	33.72	Maintenance	94.43	0	17.2	DUST waiting for spare part
01/04/2024 19:00	33.66	Maintenance	94.05	0	17.3	DUST waiting for spare part
01/04/2024 20:00	33.89	Maintenance	94.11	0	17.2	DUST waiting for spare part
01/04/2024 21:00	34.02	<Samp	94.52	0	17.2	DUST waiting for spare part
01/04/2024 22:00	34.01	Maintenance	94.87	0	17.2	DUST waiting for spare part
01/04/2024 23:00	33.91	Maintenance	94.98	0	17.1	DUST waiting for spare part
02/04/2024 00:00	32.64	Maintenance	94.36	0	25.5	DUST waiting for spare part
Minimum	21.21	0.15	92.69	0	17.1	
MinDate	01/04/2024 12:00	01/04/2024 01:00	01/04/2024 00:00	01/04/2024 00:00	01/04/2024 23:00	
Maximum	41.41	0.32	99.19	0	52	
MaxDate	01/04/2024 08:00	01/04/2024 06:00	01/04/2024 08:00	01/04/2024 08:00	01/04/2024 12:00	
Avg	31.55	0.22	94.48	0	26	
Num	25	9	25	25	25	
Data[%]	100	36	100	100	100	
STD	4.2	0.1	1.5	0	10.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/04/2024 00:00	25.28	0	93.66	1.1	29.6	
02/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
02/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
02/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
02/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
02/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
02/04/2024 06:00	0	0.23	ShutDown	ShutDown	ShutDown	GT11 S/D
02/04/2024 07:00	9.72	0.03	ShutDown	ShutDown	ShutDown	GT11 S/D
02/04/2024 08:00	33.87	0	95.72	1.2	29.5	
02/04/2024 09:00	34.26	0	95.65	1.2	27.6	
02/04/2024 10:00	34.36	0	96.01	1.2	27.9	
02/04/2024 11:00	34.26	0	96.4	1.1	28.4	
02/04/2024 12:00	21.68	0	93.85	1.2	51.5	
02/04/2024 13:00	34.41	0	95.44	1.1	29.7	
02/04/2024 14:00	34.35	0	95.81	1.1	27.9	
02/04/2024 15:00	34.31	0	95.44	1	28	
02/04/2024 16:00	34.19	0	95.12	1	27.6	
02/04/2024 17:00	33.9	0	94.64	1	26.9	
02/04/2024 18:00	33.78	0	94.32	1	26.6	
02/04/2024 19:00	33.74	0	94.13	0.9	26.4	
02/04/2024 20:00	34.03	0	94.33	1	26.3	
02/04/2024 21:00	34.11	0	94.68	1	26.2	
02/04/2024 22:00	34.11	0	94.81	0.9	26	
02/04/2024 23:00	33.99	0	94.87	1	25.8	
03/04/2024 00:00	32.99	0	94.38	1	33.5	
Minimum	0	0	93.66	0.9	25.8	
MinDate	02/04/2024 01:00	02/04/2024 00:00	02/04/2024 00:00	02/04/2024 19:00	02/04/2024 23:00	
Maximum	34.41	0.23	96.4	1.2	51.5	
MaxDate	02/04/2024 13:00	02/04/2024 06:00	02/04/2024 11:00	02/04/2024 08:00	02/04/2024 12:00	
Avg	24.05	0.01	94.96	1.1	29.2	
Num	25	25	18	18	18	
Data[%]	100	100	72	72	72	
STD	14.8	0	0.8	0.1	5.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/04/2024 00:00	32.64	Maintenance	94.36	0	25.5	DUST waiting for spare part
02/04/2024 01:00	48.06	<Samp	96.27	0	33.5	DUST waiting for spare part
02/04/2024 02:00	48.19	<Samp	95.01	0	33.7	DUST waiting for spare part
02/04/2024 03:00	48.23	Maintenance	95.25	0	33.7	DUST waiting for spare part
02/04/2024 04:00	48.24	Audit	95.42	0	33.5	DUST waiting for spare part
02/04/2024 05:00	47.98	Maintenance	95.68	0	32.3	DUST waiting for spare part
02/04/2024 06:00	48.16	<Samp	96.34	0	32.8	DUST waiting for spare part
02/04/2024 07:00	40.08	<Samp	95.24	0	32	DUST waiting for spare part
02/04/2024 08:00	33.81	Maintenance	95.11	0	20	DUST waiting for spare part
02/04/2024 09:00	34.2	Audit	95.3	0	17.4	DUST waiting for spare part
02/04/2024 10:00	34.3	Maintenance	95.57	0	17.5	DUST waiting for spare part
02/04/2024 11:00	34.19	<Samp	96	0	17.8	DUST waiting for spare part
02/04/2024 12:00	21.63	<Samp	93.6	0	48.4	DUST waiting for spare part
02/04/2024 13:00	34.35	<Samp	95.12	0	19.4	DUST waiting for spare part
02/04/2024 14:00	34.28	Maintenance	95.32	0	17.4	DUST waiting for spare part
02/04/2024 15:00	34.25	<Samp	95.15	0	17.5	DUST waiting for spare part
02/04/2024 16:00	34.12	<Samp	94.81	0	17.1	DUST waiting for spare part
02/04/2024 17:00	33.83	<Samp	94.29	0	16.8	DUST waiting for spare part
02/04/2024 18:00	33.72	<Samp	94.04	0	16.8	DUST waiting for spare part
02/04/2024 19:00	33.68	Audit	93.83	0	16.8	DUST waiting for spare part
02/04/2024 20:00	33.97	Maintenance	94.1	0	16.8	DUST waiting for spare part
02/04/2024 21:00	34.04	Maintenance	94.32	0	16.7	DUST waiting for spare part
02/04/2024 22:00	34.04	Maintenance	94.38	0	16.6	DUST waiting for spare part
02/04/2024 23:00	33.93	Maintenance	94.47	0	16.5	DUST waiting for spare part
03/04/2024 00:00	24.67	Maintenance	93.74	0	26.3	DUST waiting for spare part
Minimum	21.63	---	93.6	0	16.5	
MinDate	02/04/2024 12:00	02/04/2024 00:00	02/04/2024 12:00	02/04/2024 00:00	02/04/2024 23:00	
Maximum	48.24	---	96.34	0	45.4	
MaxDate	02/04/2024 04:00	02/04/2024 00:00	02/04/2024 06:00	02/04/2024 00:00	02/04/2024 12:00	
Num	36.74	0	34.9	0	23.6	
Avg	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	7.3	---	0.8	0	8.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/04/2024 00:00	32.99	0	94.38	1	33.5	
03/04/2024 01:00	48.11	0	96.07	1	36.9	
03/04/2024 02:00	48.22	0	95.2	1	36.9	
03/04/2024 03:00	48.28	0	95.59	1	36.8	
03/04/2024 04:00	48.31	0	95.67	1.1	36.7	
03/04/2024 05:00	48.17	0	95.81	1.1	35.9	
03/04/2024 06:00	48.18	0.17	96	1.1	35.7	
03/04/2024 07:00	38.93	0	96.05	1.1	37.2	
03/04/2024 08:00	34.09	0	95.16	1	27.6	
03/04/2024 09:00	34.23	0	95.34	1	25.8	
03/04/2024 10:00	34.29	0	95.58	1	26.1	
03/04/2024 11:00	34.3	0	95.95	1	26.3	
03/04/2024 12:00	21.71	0	93.41	1.1	49.2	
03/04/2024 13:00	34.36	0	95.29	1	28.1	
03/04/2024 14:00	34.33	0	95.54	1	26.1	
03/04/2024 15:00	34.22	0	95.13	0.9	25.9	
03/04/2024 16:00	34.08	0	94.8	0.9	25.8	
03/04/2024 17:00	33.8	0	94.46	0.9	25.6	
03/04/2024 18:00	33.72	0	94.18	0.8	25.3	
03/04/2024 19:00	33.67	0	94.1	0.8	25	
03/04/2024 20:00	33.9	0	94	0.8	24.9	
03/04/2024 21:00	34.02	0	94.58	0.8	24.8	
03/04/2024 22:00	34.07	0	94.66	0.9	24.6	
03/04/2024 23:00	33.99	0	94.66	0.9	24.4	
04/04/2024 00:00	24.5	0	94	0.9	33	
Minimum	21.71	0	93.41	0.8	24.4	
MinDate	03/04/2024 12:00	03/04/2024 00:00	03/04/2024 12:00	03/04/2024 18:00	03/04/2024 23:00	
Maximum	48.31	0.17	96.07	1.1	49.2	
MaxDate	03/04/2024 04:00	03/04/2024 06:00	03/04/2024 01:00	03/04/2024 04:00	03/04/2024 12:00	
Avg	36.74	0.01	95.02	1	30.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0	0.8	0.1	6.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/04/2024 00:00	24.67	Maintenance	93.74	0	26.3	DUST waiting for spare part
03/04/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
03/04/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
03/04/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
03/04/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
03/04/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
03/04/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
03/04/2024 07:00	11.04	<Samp	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
03/04/2024 08:00	33.97	Maintenance	95.5	0	24.7	DUST waiting for spare part
03/04/2024 09:00	34.17	Maintenance	95.07	0	22.8	DUST waiting for spare part
03/04/2024 10:00	34.24	<Samp	95.34	0	23	DUST waiting for spare part
03/04/2024 11:00	34.24	<Samp	95.79	0	23.1	DUST waiting for spare part
03/04/2024 12:00	21.72	Maintenance	93.28	0	46.7	DUST waiting for spare part
03/04/2024 13:00	34.28	Maintenance	95.17	0	25.7	DUST waiting for spare part
03/04/2024 14:00	34.27	<Samp	95.32	0	22.6	DUST waiting for spare part
03/04/2024 15:00	34.15	Maintenance	95.05	0	22.4	DUST waiting for spare part
03/04/2024 16:00	34.02	<Samp	94.77	0	22.3	DUST waiting for spare part
03/04/2024 17:00	33.74	<Samp	94.33	0	22.1	DUST waiting for spare part
03/04/2024 18:00	33.65	Maintenance	94.12	0	21.9	DUST waiting for spare part
03/04/2024 19:00	33.61	Maintenance	94.01	0	21.7	DUST waiting for spare part
03/04/2024 20:00	33.63	Audit	93.89	0	21.7	DUST waiting for spare part
03/04/2024 21:00	33.86	<Samp	94.38	0	21.6	DUST waiting for spare part
03/04/2024 22:00	34.01	Maintenance	94.41	0	21.5	DUST waiting for spare part
03/04/2024 23:00	33.93	<Samp	94.48	0	21.2	DUST waiting for spare part
04/04/2024 00:00	33.17	<Samp	94.3	0	20.6	DUST waiting for spare part
Minimum	0	---	93.28	0	21.2	
MinDate	03/04/2024 01:00	03/04/2024 00:00	03/04/2024 12:00	03/04/2024 00:00	03/04/2024 23:00	
Maximum	34.28	---	95.79	0	46.7	
MaxDate	03/04/2024 13:00	03/04/2024 00:00	03/04/2024 11:00	03/04/2024 00:00	03/04/2024 12:00	
Avg	24.03	---	94.61	0	24.4	
Num	25	0	18	18	18	
Data[%]	100	---	72	72	72	
STD	14.7	---	0.7	0	5.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/04/2024 00:00	24.5	0	94	0.9	33	GT11 S/D
04/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
04/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
04/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
04/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
04/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
04/04/2024 06:00	0	0.36	ShutDown	ShutDown	ShutDown	GT11 S/D
04/04/2024 07:00	11.78	0.02	ShutDown	ShutDown	ShutDown	GT11 S/D
04/04/2024 08:00	34.03	0	95.18	1	28.7	
04/04/2024 09:00	34.23	0	95.16	1	26.9	
04/04/2024 10:00	34.29	0	95.52	1	27.1	
04/04/2024 11:00	34.24	0	95.88	0.9	27	
04/04/2024 12:00	21.87	0	93.19	1	49.1	
04/04/2024 13:00	34.33	0	94.92	0.9	28.3	
04/04/2024 14:00	34.13	0	95.44	0.9	27	
04/04/2024 15:00	34.34	0	95.39	0.9	26.8	
04/04/2024 16:00	34.13	0	95.09	0.9	28.2	
04/04/2024 17:00	33.87	0	94.64	0.8	26.3	
04/04/2024 18:00	33.81	0	94.3	0.7	26	
04/04/2024 19:00	33.68	0	94.08	0.7	25.8	
04/04/2024 20:00	33.88	0	94.2	0.8	25.6	
04/04/2024 21:00	34.05	0	94.78	0.7	25.5	
04/04/2024 22:00	34.07	0	95.06	0.7	25.3	
04/04/2024 23:00	33.96	0	94.87	0.7	25.3	
05/04/2024 00:00	32.98	0	94.37	0.8	33	
Minimum	0	0	93.19	0.7	25.3	
MinDate	04/04/2024 01:00	04/04/2024 00:00	04/04/2024 12:00	04/04/2024 18:00	04/04/2024 22:00	
Maximum	34.34	0.36	95.88	1	49.1	
MaxDate	04/04/2024 15:00	04/04/2024 06:00	04/04/2024 11:00	04/04/2024 08:00	04/04/2024 12:00	
Avg	24.09	0.02	94.78	0.9	28.6	
Num	25	25	18	18	18	
Data (%)	100	100	72	72	72	
STD	14.7	0.1	0.7	0.1	5.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/04/2024 00:00	33.17	<Samp	94.3	0	29.6	DUST waiting for spare part
04/04/2024 01:00	48.21	Maintenance	96.28	0	39.8	DUST waiting for spare part
04/04/2024 02:00	48.2	Maintenance	95.23	0	39.9	DUST waiting for spare part
04/04/2024 03:00	48.26	Maintenance	95.5	0	39.8	DUST waiting for spare part
04/04/2024 04:00	48.19	Maintenance	95.57	0	39.1	DUST waiting for spare part
04/04/2024 05:00	48	Maintenance	95.7	0	37.8	DUST waiting for spare part
04/04/2024 06:00	48.07	Maintenance	96.35	0	37.4	DUST waiting for spare part
04/04/2024 07:00	38.37	Maintenance	95.36	0	36.6	DUST waiting for spare part
04/04/2024 08:00	33.94	Maintenance	94.92	0	24	DUST waiting for spare part
04/04/2024 09:00	34.17	<Samp	95.08	0	22	DUST waiting for spare part
04/04/2024 10:00	34.23	<Samp	95.41	0	22.2	DUST waiting for spare part
04/04/2024 11:00	34.19	<Samp	95.79	0	22.1	DUST waiting for spare part
04/04/2024 12:00	21.86	Maintenance	93.23	0	45.2	DUST waiting for spare part
04/04/2024 13:00	34.28	<Samp	95.14	0	22.8	DUST waiting for spare part
04/04/2024 14:00	34.06	<Samp	95.27	0	21.6	DUST waiting for spare part
04/04/2024 15:00	34.28	<Samp	95.12	0	21.4	DUST waiting for spare part
04/04/2024 16:00	34.06	<Samp	94.8	0	23.2	DUST waiting for spare part
04/04/2024 17:00	33.8	Audit	94.45	0	22.1	DUST waiting for spare part
04/04/2024 18:00	33.75	<Samp	94.13	0	22.2	DUST waiting for spare part
04/04/2024 19:00	33.62	<Samp	93.91	0	22.1	DUST waiting for spare part
04/04/2024 20:00	33.82	<Samp	94.03	0	21.9	DUST waiting for spare part
04/04/2024 21:00	33.99	Audit	94.48	0	21.8	DUST waiting for spare part
04/04/2024 22:00	34.01	Maintenance	94.76	0	21.6	DUST waiting for spare part
04/04/2024 23:00	33.9	Maintenance	94.69	0	21.7	DUST waiting for spare part
05/04/2024 00:00	24.54	Maintenance	93.64	0	30.1	DUST waiting for spare part
Minimum	21.86	---	93.23	0	21.4	
MinDate	04/04/2024 12:00	04/04/2024 06:00	04/04/2024 12:00	04/04/2024 00:00	04/04/2024 15:00	
Maximum	48.26	---	96.35	0	45.2	
MaxDate	04/04/2024 03:00	04/04/2024 00:00	04/04/2024 06:00	04/04/2024 00:00	04/04/2024 12:00	
Avg	36.68	---	94.93	0	28.3	
Num	25	0	25	25	25	
Data (%)	100	---	100	100	100	
STD	7.3	---	0.8	0	8.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/04/2024 00:00	32.98	0	94.37	0.8	33	
05/04/2024 01:00	48.01	0	96.42	0.8	36.4	
05/04/2024 02:00	48.13	0	96.38	0.9	36.4	
05/04/2024 03:00	46.19	0	95.43	0.9	36.4	
05/04/2024 04:00	48.22	0	95.5	0.9	36.1	
05/04/2024 05:00	47.97	0	96.62	0.9	34.6	
05/04/2024 06:00	48.07	0.3	96.13	0.9	34.7	
05/04/2024 07:00	39.99	0	96.08	0.9	35.8	
05/04/2024 08:00	33.84	0	95.06	0.9	26.8	
05/04/2024 09:00	34.22	0	95.81	0.9	25	
05/04/2024 10:00	34.31	0	96.13	0.9	25.4	
05/04/2024 11:00	34.16	0	96.63	0.9	25.6	
05/04/2024 12:00	21.87	0	93.37	1	48.7	
05/04/2024 13:00	34.4	0	94.94	0.9	27	
05/04/2024 14:00	34.32	0	95.33	0.8	25.3	
05/04/2024 15:00	34.24	0	95.1	0.8	25.3	
05/04/2024 16:00	34.11	0	94.72	0.8	25.3	
05/04/2024 17:00	33.83	0	94.15	0.8	25	
05/04/2024 18:00	33.76	0	93.88	0.7	24.5	
05/04/2024 19:00	33.68	0	93.83	0.7	24	
05/04/2024 20:00	33.96	0	93.94	0.7	23.9	
05/04/2024 21:00	34.13	0	94.34	0.7	23.7	
05/04/2024 22:00	37.11	0	95.98	0.8	24.7	
05/04/2024 23:00	37.94	0	97.02	0.8	25.1	
06/04/2024 00:00	34.4	0	96.75	0.8	32.8	
Minimum	21.87	0	93.37	0.7	23.7	
MinDate	05/04/2024 12:00	05/04/2024 00:00	05/04/2024 12:00	05/04/2024 18:00	05/04/2024 21:00	
Maximum	48.22	0.3	97.02	1	48.7	
MaxDate	05/04/2024 04:00	05/04/2024 06:00	05/04/2024 23:00	05/04/2024 12:00	05/04/2024 12:00	
Avg	37.43	0.01	95.28	0.8	29.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.8	0.1	1	0.1	6.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/04/2024 00:00	24.54	Maintenance	93.64	0	30.1	GT12 S/D
05/04/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/04/2024 02:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
05/04/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/04/2024 04:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
05/04/2024 05:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
05/04/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/04/2024 07:00	9.9	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/04/2024 08:00	33.76	Maintenance	95.31	0	23.8	DUST waiting for spare part
05/04/2024 09:00	34.15	<Samp	95.04	0	22.1	DUST waiting for spare part
05/04/2024 10:00	34.25	<Samp	95.37	0	22.3	DUST waiting for spare part
05/04/2024 11:00	34.12	Maintenance	95.9	0	22.4	DUST waiting for spare part
05/04/2024 12:00	21.83	Maintenance	93.66	0	46.4	DUST waiting for spare part
05/04/2024 13:00	34.29	Maintenance	95.5	0	23.6	DUST waiting for spare part
05/04/2024 14:00	34.26	Maintenance	95.75	0	21.8	DUST waiting for spare part
05/04/2024 15:00	34.17	Maintenance	95.62	0	21.8	DUST waiting for spare part
05/04/2024 16:00	34.04	Maintenance	95.41	0	21.7	DUST waiting for spare part
05/04/2024 17:00	33.77	Maintenance	94.84	0	21.3	DUST waiting for spare part
05/04/2024 18:00	33.69	Maintenance	94.58	0	20.8	DUST waiting for spare part
05/04/2024 19:00	33.62	Maintenance	94.37	0	20.5	DUST waiting for spare part
05/04/2024 20:00	33.89	Maintenance	94.45	0	20.4	DUST waiting for spare part
05/04/2024 21:00	34.07	Maintenance	94.75	0	20.2	DUST waiting for spare part
05/04/2024 22:00	37.05	<Samp	96.39	0	21.5	DUST waiting for spare part
05/04/2024 23:00	37.86	<Samp	97.41	0	21.9	DUST waiting for spare part
06/04/2024 00:00	34.36	Maintenance	97.07	0	26.4	DUST waiting for spare part
Minimum	0	---	93.66	0	20.2	
MinDate	05/04/2024 01:00	05/04/2024 00:00	05/04/2024 12:00	05/04/2024 00:00	05/04/2024 21:00	
Maximum	37.86	---	97.41	0	46.4	
MaxDate	05/04/2024 23:00	05/04/2024 00:00	05/04/2024 23:00	05/04/2024 00:00	05/04/2024 12:00	
Avg	24.3	---	95.28	0	24	
Num	25	0	18	18	18	
Data[%]	100	---	72	72	72	
STD	15	---	1	0	6.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/04/2024 00:00	34.4	0	96.75	0.8	32.8	
06/04/2024 01:00	28.51	0	93.02	0.8	40.1	
06/04/2024 02:00	28.55	0	93.02	0.8	39.9	
06/04/2024 03:00	28.53	0	92.78	0.9	40	
06/04/2024 04:00	28.26	0	92.57	0.9	41	
06/04/2024 05:00	28.06	0	92.57	0.9	41.7	
06/04/2024 06:00	28.12	0.23	92.71	0.9	41.8	
06/04/2024 07:00	28.15	0	93.15	0.9	41.4	
06/04/2024 08:00	42.45	0	98.86	0.9	27.5	
06/04/2024 09:00	42.57	0	100.6	0.9	27.2	
06/04/2024 10:00	42.6	0	100.97	0.9	27.2	
06/04/2024 11:00	42.52	0	101.23	0.9	27	
06/04/2024 12:00	28.55	0	95.47	0.9	38.7	
06/04/2024 13:00	42.53	0	99.82	0.9	28	
06/04/2024 14:00	42.58	0	101.37	0.9	27	
06/04/2024 15:00	42.65	0	100.89	0.8	26.9	
06/04/2024 16:00	42.45	0	100.43	0.8	26.6	
06/04/2024 17:00	42.02	0	99.7	0.8	26.3	
06/04/2024 18:00	42.03	0	99.38	0.8	26.1	
06/04/2024 19:00	42.12	0	99.43	0.7	25.8	
06/04/2024 20:00	42.38	0	99.54	0.8	25.7	
06/04/2024 21:00	42.52	0	100.12	0.8	25.7	
06/04/2024 22:00	42.52	0	100.44	0.8	25.6	
06/04/2024 23:00	42.41	0	100.35	0.8	25.4	
07/04/2024 00:00	35.22	0	97.84	0.8	32	
Minimum	28.06	0	92.57	0.7	25.4	
MinDate	06/04/2024 05:00	06/04/2024 00:00	06/04/2024 04:00	06/04/2024 19:00	06/04/2024 23:00	
Maximum	42.65	0.23	101.37	0.9	41.8	
MaxDate	06/04/2024 15:00	06/04/2024 06:00	06/04/2024 14:00	06/04/2024 03:00	06/04/2024 06:00	
Avg	37.3	0.01	97.72	0.8	31.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.6	0	3.4	0.1	6.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/04/2024 00:00	34.36	Maintenance	97.07	0	29.4	DUST waiting for spare part
06/04/2024 01:00	28.45	Maintenance	93.48	0	35.0	DUST waiting for spare part
06/04/2024 02:00	28.5	Maintenance	93.48	0	35.4	DUST waiting for spare part
06/04/2024 03:00	28.47	Maintenance	93.15	0	35.8	DUST waiting for spare part
06/04/2024 04:00	28.2	<Samp	92.97	0	36.4	DUST waiting for spare part
06/04/2024 05:00	28	<Samp	92.96	0	37	DUST waiting for spare part
06/04/2024 06:00	28.06	<Samp	93.11	0	37	DUST waiting for spare part
06/04/2024 07:00	28.09	<Samp	93.47	0	36.8	DUST waiting for spare part
06/04/2024 08:00	42.18	<Samp	99.51	0	26.4	DUST waiting for spare part
06/04/2024 09:00	42.5	<Samp	101.05	0	26.5	DUST waiting for spare part
06/04/2024 10:00	42.52	<Samp	101.38	0	26.9	DUST waiting for spare part
06/04/2024 11:00	42.45	<Samp	101.55	0	26.8	DUST waiting for spare part
06/04/2024 12:00	28.5	<Samp	95.87	0	35.2	DUST waiting for spare part
06/04/2024 13:00	42.48	0	100.37	0	28.3	DUST waiting for spare part
06/04/2024 14:00	42.51	Maintenance	101.67	0	27.4	DUST waiting for spare part
06/04/2024 15:00	42.58	Maintenance	101.38	0	27.2	DUST waiting for spare part
06/04/2024 16:00	42.38	<Samp	101.11	0	26.3	DUST waiting for spare part
06/04/2024 17:00	41.95	0	100.43	0	24.8	DUST waiting for spare part
06/04/2024 18:00	41.95	0	100.13	0	24.3	DUST waiting for spare part
06/04/2024 19:00	42.06	0	100.04	0	24	DUST waiting for spare part
06/04/2024 20:00	42.32	<Samp	100.11	0	24	DUST waiting for spare part
06/04/2024 21:00	42.44	Maintenance	100.45	0	24.1	DUST waiting for spare part
06/04/2024 22:00	42.45	<Samp	100.75	0	24	DUST waiting for spare part
06/04/2024 23:00	42.34	0	100.86	0	23.7	DUST waiting for spare part
07/04/2024 00:00	35.14	<Samp	96.07	0	29.3	DUST waiting for spare part
Minimum	28	0	92.96	0	23.7	
MinDate	06/04/2024 05:00	06/04/2024 13:00	06/04/2024 05:00	06/04/2024 00:00	06/04/2024 23:00	
Maximum	42.58	0	101.67	0	37	
MaxDate	06/04/2024 15:00	06/04/2024 13:00	06/04/2024 14:00	06/04/2024 00:00	06/04/2024 05:00	
Avg	37.24	0	98.17	0	29.3	
Num	25	5	25	25	25	
Data[%]	100	20	100	100	100	
STD	6.6	0	3.4	0	5	

Date & Time	11GT_LOAD MW	11HRSG_DUST mg/m3	11HRSG_TEMP Degree C.	11HRSG_SO2@7%O2 ppm	11HRSG_NOx@7%O2 ppm	Remark
07/04/2024 00:00	35.22	0	97.84	0.8	32	
07/04/2024 01:00	28.48	0	92.98	0.8	39.3	
07/04/2024 02:00	28.46	0	92.85	0.8	39.1	
07/04/2024 03:00	28.21	0	92.76	0.8	39.7	
07/04/2024 04:00	27.75	0	92.71	0.8	41.1	
07/04/2024 05:00	27.44	0	92.58	0.9	42.3	
07/04/2024 06:00	27.35	0.17	92.64	0.9	42.5	
07/04/2024 07:00	23.5	0	92.19	0.9	44.9	
07/04/2024 08:00	12.98	0	ShutDown	ShutDown	ShutDown	Effect from ST10 S/D
07/04/2024 09:00	12.93	0	ShutDown	ShutDown	ShutDown	Effect from ST10 S/D
07/04/2024 10:00	14.44	0	ShutDown	ShutDown	ShutDown	Effect from ST10 S/D
07/04/2024 11:00	27.1	0	93.66	0.9	40.8	
07/04/2024 12:00	27.49	0	94.56	0.9	39.3	
07/04/2024 13:00	27.32	0	93.54	0.9	39.8	
07/04/2024 14:00	27.31	0	93.2	0.9	39.5	
07/04/2024 15:00	27.27	0	92.98	0.9	39.4	
07/04/2024 16:00	27.29	0	92.82	0.9	39.5	
07/04/2024 17:00	27.35	0	92.49	0.9	39.9	
07/04/2024 18:00	41.11	0	97.69	0.8	24.8	
07/04/2024 19:00	41.04	0	98.93	0.8	24.1	
07/04/2024 20:00	41.04	0	98.97	0.8	24	
07/04/2024 21:00	41.03	0	99.36	0.8	23.9	
07/04/2024 22:00	41.07	0	99.52	0.8	23.7	
07/04/2024 23:00	34	0	97.37	0.9	31	
08/04/2024 00:00	27.35	0	92.77	0.9	40.3	
Minimum	12.93	0	92.19	0.8	23.7	
MinDate	07/04/2024 09:00	07/04/2024 00:00	07/04/2024 07:00	07/04/2024 00:00	07/04/2024 22:00	
Maximum	41.11	0.17	99.52	0.9	44.9	
MaxDate	07/04/2024 18:00	07/04/2024 06:00	07/04/2024 22:00	07/04/2024 05:00	07/04/2024 07:00	
Avg	28.98	0.01	94.75	0.9	36	
Num	25	25	22	22	22	
Data[%]	100	100	88	88	88	
STD	8.1	0	2.7	0.1	7.2	

Date & Time	12GT_LOAD MW	12HRSG_DUST mg/m3	12HRSG_TEMP Degree C.	12HRSG_SO2@7%O2 ppm	12HRSG_NOx@7%O2 ppm	Remark
07/04/2024 00:00	35.14	<Samp	98.07	0	29.3	DUST waiting for spare part
07/04/2024 01:00	28.41	<Samp	93.43	0	35	DUST waiting for spare part
07/04/2024 02:00	28.4	0	93.35	0	34.9	DUST waiting for spare part
07/04/2024 03:00	28.16	0	93.24	0	35.5	DUST waiting for spare part
07/04/2024 04:00	27.69	<Samp	93.2	0	36.6	DUST waiting for spare part
07/04/2024 05:00	27.38	Maintenance	93.05	0	37.3	DUST waiting for spare part
07/04/2024 06:00	27.29	<Samp	93.12	0	37.5	DUST waiting for spare part
07/04/2024 07:00	23.44	<Samp	92.85	0	40.3	DUST waiting for spare part
07/04/2024 08:00	13.09	<Samp	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
07/04/2024 09:00	13.06	<Samp	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
07/04/2024 10:00	14.47	<Samp	ShutDown	ShutDown	ShutDown	DUST waiting for spare part
07/04/2024 11:00	27.03	<Samp	96.55	0	37.4	DUST waiting for spare part
07/04/2024 12:00	27.44	Maintenance	95.17	0	35.1	DUST waiting for spare part
07/04/2024 13:00	27.27	Maintenance	94.02	0	35.3	DUST waiting for spare part
07/04/2024 14:00	27.26	Maintenance	93.68	0	34.9	DUST waiting for spare part
07/04/2024 15:00	27.22	Maintenance	93.55	0	34.8	DUST waiting for spare part
07/04/2024 16:00	27.23	Maintenance	93.46	0	34.8	DUST waiting for spare part
07/04/2024 17:00	27.29	Maintenance	93.24	0	35.4	DUST waiting for spare part
07/04/2024 18:00	41.04	Maintenance	98.33	0	22.5	DUST waiting for spare part
07/04/2024 19:00	40.97	Maintenance	99.19	0	21.2	DUST waiting for spare part
07/04/2024 20:00	40.96	<Samp	99.21	0	21	DUST waiting for spare part
07/04/2024 21:00	40.96	<Samp	99.41	0	20.8	DUST waiting for spare part
07/04/2024 22:00	41	0	99.48	0	20.7	DUST waiting for spare part
07/04/2024 23:00	33.94	<Samp	97.23	0	28	DUST waiting for spare part
08/04/2024 00:00	27.29	Audit	93.09	0	35.9	DUST waiting for spare part
Minimum	13.06	0	92.85	0	20.7	
MinDate	07/04/2024 09:00	07/04/2024 02:00	07/04/2024 07:00	07/04/2024 00:00	07/04/2024 22:00	
Maximum	41.04	0	99.48	0	40.3	
MaxDate	07/04/2024 18:00	07/04/2024 02:00	07/04/2024 22:00	07/04/2024 00:00	07/04/2024 07:00	
Avg	28.94	0	95.27	0	32	
Num	25	3	22	22	22	
Data[%]	100	12	88	88	88	
STD	8.1	0	2.6	0	6.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/04/2024 00:00	27.35	0	92.77	0.9	40.3	
08/04/2024 01:00	27.34	0	92.45	0.9	40.1	
08/04/2024 02:00	27.37	0	92.44	0.9	40.1	
08/04/2024 03:00	27.34	0	92.47	0.9	40.2	
08/04/2024 04:00	27.35	0	92.56	0.9	40.3	
08/04/2024 05:00	27.35	0	92.5	0.9	40.5	
08/04/2024 06:00	27.33	0.36	92.66	1	40.8	
08/04/2024 07:00	27.69	0	92.82	1	39.7	
08/04/2024 08:00	41.1	0	98.63	0.9	24.5	
08/04/2024 09:00	33.81	0	95.58	0.9	22	
08/04/2024 10:00	33.88	0	95.13	0.9	22.4	
08/04/2024 11:00	33.99	0	95.76	0.9	22.5	
08/04/2024 12:00	21.44	0	93.27	1	51.2	
08/04/2024 13:00	34.25	0	94.96	0.9	24.3	
08/04/2024 14:00	34.26	0	95.47	0.9	22.6	
08/04/2024 15:00	34.4	0	95.08	0.8	22.5	
08/04/2024 16:00	34.09	0	94.67	0.8	22.1	
08/04/2024 17:00	33.67	0	94.1	0.8	22.1	
08/04/2024 18:00	33.67	0	93.78	0.7	22	
08/04/2024 19:00	33.66	0	93.71	0.7	21.7	
08/04/2024 20:00	33.84	0	93.9	0.7	21.6	
08/04/2024 21:00	34.03	0	94.55	0.7	21.5	
08/04/2024 22:00	34.09	0	94.76	0.8	21.2	
08/04/2024 23:00	33.96	0	94.79	0.8	21.1	
09/04/2024 00:00	25.16	0	93.84	0.8	29.7	
Minimum	21.44	0	92.44	0.7	21.1	
MinDate	08/04/2024 12:00	08/04/2024 00:00	08/04/2024 02:00	08/04/2024 18:00	08/04/2024 23:00	
Maximum	41.1	0.36	98.63	1	51.2	
MaxDate	08/04/2024 08:00	08/04/2024 06:00	08/04/2024 08:00	08/04/2024 06:00	08/04/2024 12:00	
Avg	31.3	0.01	94.11	0.9	29.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.3	0.1	1.5	0.1	9.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/04/2024 00:00	27.29	Audit	93.09	0	35.9	DUST waiting for spare part
08/04/2024 01:00	27.29	Maintenance	93.09	0	35.7	DUST waiting for spare part
08/04/2024 02:00	27.3	Maintenance	93.12	0	35.7	DUST waiting for spare part
08/04/2024 03:00	27.29	Maintenance	93.07	0	35.8	DUST waiting for spare part
08/04/2024 04:00	27.29	Maintenance	93.12	0	35.9	DUST waiting for spare part
08/04/2024 05:00	27.3	Maintenance	93.1	0	36	DUST waiting for spare part
08/04/2024 06:00	27.27	Maintenance	93.18	0	36.1	DUST waiting for spare part
08/04/2024 07:00	27.63	Maintenance	93.36	0	35.4	DUST waiting for spare part
08/04/2024 08:00	41.02	Maintenance	98.99	0	22.6	DUST waiting for spare part
08/04/2024 09:00	33.76	<Samp	95.55	0	18.2	DUST waiting for spare part
08/04/2024 10:00	33.82	Maintenance	95.14	0	18.5	DUST waiting for spare part
08/04/2024 11:00	33.94	<Samp	95.87	0	18.8	DUST waiting for spare part
08/04/2024 12:00	21.35	<Samp	93.46	0	51.1	DUST waiting for spare part
08/04/2024 13:00	34.19	Audit	95.22	0	20.9	DUST waiting for spare part
08/04/2024 14:00	34.19	Audit	95.67	0	19	DUST waiting for spare part
08/04/2024 15:00	34.17	Maintenance	95.4	0	18.8	DUST waiting for spare part
08/04/2024 16:00	34.02	Maintenance	95.14	0	18.1	DUST waiting for spare part
08/04/2024 17:00	33.61	Maintenance	94.67	0	17.9	DUST waiting for spare part
08/04/2024 18:00	33.59	<Samp	94.39	0	17.7	DUST waiting for spare part
08/04/2024 19:00	33.6	<Samp	94.26	0	17.4	DUST waiting for spare part
08/04/2024 20:00	33.77	<Samp	94.34	0	17.2	DUST waiting for spare part
08/04/2024 21:00	33.97	Audit	94.83	0	17.2	DUST waiting for spare part
08/04/2024 22:00	34.02	Maintenance	94.96	0	17	DUST waiting for spare part
08/04/2024 23:00	33.89	Maintenance	94.99	0	16.9	DUST waiting for spare part
09/04/2024 00:00	32.76	Maintenance	94.62	0	25.4	DUST waiting for spare part
Minimum	21.35	---	93.07	0	16.9	
MinDate	08/04/2024 12:00	08/04/2024 00:00	08/04/2024 03:00	08/04/2024 00:00	08/04/2024 23:00	
Maximum	41.02	---	98.99	0	51.1	
MaxDate	08/04/2024 08:00	08/04/2024 00:00	08/04/2024 08:00	08/04/2024 00:00	08/04/2024 12:00	
Avg	31.53	---	94.51	0	25.6	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.2	---	1.3	0	9.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/04/2024 00:00	25.16	0	93.84	0.8	29.7	
09/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/04/2024 06:00	0	0.3	ShutDown	ShutDown	ShutDown	GT11 S/D
09/04/2024 07:00	11.77	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
09/04/2024 08:00	34.16	0	95.31	0.9	28.2	
09/04/2024 09:00	34.28	0	95.92	0.9	27.6	
09/04/2024 10:00	34.34	0	96.21	0.9	28.2	
09/04/2024 11:00	34.24	0	96.45	0.9	28.3	
09/04/2024 12:00	21.44	0	92.99	1	52.4	
09/04/2024 13:00	34.39	0	95.17	0.9	29.5	
09/04/2024 14:00	34.25	0	95.87	0.9	27.7	
09/04/2024 15:00	34.19	0	95.57	0.9	27.6	
09/04/2024 16:00	33.93	0	94.98	0.9	27.6	
09/04/2024 17:00	33.62	0	95.02	0.8	26.9	
09/04/2024 18:00	33.66	0	94.55	0.8	26.6	
09/04/2024 19:00	33.6	0	94.55	0.8	26.3	
09/04/2024 20:00	33.75	0	94.39	0.8	26.5	
09/04/2024 21:00	33.94	0	94.81	0.8	26.3	
09/04/2024 22:00	34.02	0	94.99	0.8	26.1	
09/04/2024 23:00	33.96	0	94.83	0.8	26	
10/04/2024 00:00	32.75	0	94.5	0.9	33.3	
Minimum	0	0	92.99	0.8	26	
MinDate	09/04/2024 01:00	09/04/2024 00:00	09/04/2024 12:00	09/04/2024 00:00	09/04/2024 23:00	
Maximum	34.39	0.3	96.45	0.9	52.4	
MaxDate	09/04/2024 13:00	09/04/2024 06:00	09/04/2024 11:00	09/04/2024 12:00	09/04/2024 12:00	
Avg	24.06	0.01	95	0.9	29.2	
Num	25	25	18	18	18	
Data(%)	100	100	72	72	72	
STD	14.7	0.1	0.8	0.1	6.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/04/2024 00:00	32.76	Maintenance	94.62	0	25.4	DUST waiting for spare part
09/04/2024 01:00	47.81	Maintenance	95.19	0	33	DUST waiting for spare part
09/04/2024 02:00	47.97	Maintenance	94.87	0	33.2	DUST waiting for spare part
09/04/2024 03:00	48.01	<Samp	95.23	0	33	DUST waiting for spare part
09/04/2024 04:00	48.07	<Samp	95.28	0	32.8	DUST waiting for spare part
09/04/2024 05:00	47.78	Maintenance	95.5	0	31.1	DUST waiting for spare part
09/04/2024 06:00	47.87	Maintenance	95.04	0	30.8	DUST waiting for spare part
09/04/2024 07:00	38.14	Maintenance	94.92	0	31.6	DUST waiting for spare part
09/04/2024 08:00	34.09	Maintenance	95.01	0	17.7	DUST waiting for spare part
09/04/2024 09:00	34.21	Maintenance	95.33	0	16.8	DUST waiting for spare part
09/04/2024 10:00	34.29	Audit	95.62	0	17.1	DUST waiting for spare part
09/04/2024 11:00	34.18	Maintenance	95.11	0	17.1	DUST waiting for spare part
09/04/2024 12:00	20.85	Maintenance	92.58	0	51.5	DUST waiting for spare part
09/04/2024 13:00	34.28	Maintenance	94.97	0	18.9	DUST waiting for spare part
09/04/2024 14:00	34.18	Maintenance	95.58	0	16.6	DUST waiting for spare part
09/04/2024 15:00	34.12	Maintenance	95.35	0	16.6	DUST waiting for spare part
09/04/2024 16:00	33.86	Maintenance	94.68	0	16.6	DUST waiting for spare part
09/04/2024 17:00	33.56	Maintenance	94.8	0	16.4	DUST waiting for spare part
09/04/2024 18:00	33.6	Maintenance	94.6	0	16.2	DUST waiting for spare part
09/04/2024 19:00	33.55	Maintenance	94.61	0	16.2	DUST waiting for spare part
09/04/2024 20:00	33.69	Audit	94.35	0	16.3	DUST waiting for spare part
09/04/2024 21:00	33.88	Audit	94.58	0	16.2	DUST waiting for spare part
09/04/2024 22:00	33.96	Maintenance	94.62	0	16.2	DUST waiting for spare part
09/04/2024 23:00	33.9	Audit	94.54	0	16.1	DUST waiting for spare part
10/04/2024 00:00	25.27	Maintenance	93.87	0	25.3	DUST waiting for spare part
Minimum	20.85	---	92.58	0	16.1	DUST waiting for spare part
MinDate	09/04/2024 12:00	09/04/2024 00:00	09/04/2024 12:00	09/04/2024 00:00	09/04/2024 23:00	
Maximum	48.07	---	95.19	0	51.5	
MaxDate	09/04/2024 04:00	09/04/2024 00:00	09/04/2024 01:00	09/04/2024 00:00	09/04/2024 12:00	
Avg	36.56	---	94.96	0	23.1	
Num	25	0	25	25	25	
Data(%)	100	---	100	100	100	
STD	7.3	---	0.8	0	9.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
10/04/2024 00:00	32.75	0	94.5	0.9	33.3	
10/04/2024 01:00	47.8	0	96.2	0.9	37.3	
10/04/2024 02:00	47.97	0	95.03	0.9	38.4	
10/04/2024 03:00	48.1	0	95.46	0.9	38.4	
10/04/2024 04:00	48.15	0	95.62	0.9	38.2	
10/04/2024 05:00	48.1	0	95.71	0.9	37.6	
10/04/2024 06:00	48.21	0.23	96.14	1	37.1	
10/04/2024 07:00	38.7	0	95.61	1	37.7	
10/04/2024 08:00	34.17	0	95.02	0.9	27.2	
10/04/2024 09:00	34.06	0	95.73	0.9	25.5	
10/04/2024 10:00	34.02	0	95.73	0.9	26.1	
10/04/2024 11:00	33.93	0	95.67	0.9	26.2	
10/04/2024 12:00	21.95	0	92.84	1	47.5	
10/04/2024 13:00	34.07	0	95.42	0.9	27	
10/04/2024 14:00	33.99	0	93.58	0.9	26	
10/04/2024 15:00	33.91	0	92.24	0.8	26.1	
10/04/2024 16:00	33.63	0	93.28	0.8	25.6	
10/04/2024 17:00	33.47	0	93.82	0.9	25.2	
10/04/2024 18:00	33.41	0	94.04	0.9	25	
10/04/2024 19:00	33.46	0	94.17	0.9	24.6	
10/04/2024 20:00	33.73	0	94.36	0.9	24.3	
10/04/2024 21:00	33.93	0	94.98	0.9	24.4	
10/04/2024 22:00	34.03	0	95.26	0.9	24.4	
10/04/2024 23:00	33.96	0	95.22	0.9	24.2	
11/04/2024 00:00	24.82	0	94.36	0.9	32.5	
Minimum	21.95	0	92.24	0.8	24.2	
MinDate	10/04/2024 12:00	10/04/2024 00:00	10/04/2024 15:00	10/04/2024 15:00	10/04/2024 23:00	
Maximum	48.21	0.23	96.2	1	47.5	
MaxDate	10/04/2024 06:00	10/04/2024 06:00	10/04/2024 01:00	10/04/2024 06:00	10/04/2024 12:00	
Avg	36.57	0.01	94.8	0.9	30.4	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0	1	0	6.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
10/04/2024 00:00	25.27	Maintenance	93.87	0	25.3	DUST waiting for spare part
10/04/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
10/04/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
10/04/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
10/04/2024 04:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
10/04/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
10/04/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
10/04/2024 07:00	11.31	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
10/04/2024 08:00	34.07	Maintenance	95.44	0	23.9	DUST waiting for spare part
10/04/2024 09:00	34	Maintenance	95.36	0	22.3	DUST waiting for spare part
10/04/2024 10:00	33.95	Maintenance	95.37	0	22.8	DUST waiting for spare part
10/04/2024 11:00	33.87	<Samp	95.37	0	22.9	DUST waiting for spare part
10/04/2024 12:00	21.94	<Samp	92.79	0	45.3	DUST waiting for spare part
10/04/2024 13:00	33.95	Audit	95.45	0	23.5	DUST waiting for spare part
10/04/2024 14:00	33.93	<Samp	93.34	0	22.4	DUST waiting for spare part
10/04/2024 15:00	33.85	<Samp	92.15	0	22.7	DUST waiting for spare part
10/04/2024 16:00	33.57	<Samp	93.17	0	22.7	DUST waiting for spare part
10/04/2024 17:00	33.41	<Samp	93.75	0	22.1	DUST waiting for spare part
10/04/2024 18:00	33.36	<Samp	94.05	0	21.6	DUST waiting for spare part
10/04/2024 19:00	33.41	0.36	94.17	0	21	
10/04/2024 20:00	33.66	0.67	94.41	0	20.6	
10/04/2024 21:00	33.87	0.68	94.86	0	20.6	
10/04/2024 22:00	33.97	0.09	95.07	0	20.7	
10/04/2024 23:00	33.89	0.09	95.01	0	20.6	
11/04/2024 00:00	32.85	0.27	94.66	0	28.8	
Minimum	0	0.09	92.15	0	20.6	
MinDate	10/04/2024 01:00	10/04/2024 22:00	10/04/2024 15:00	10/04/2024 00:00	10/04/2024 20:00	
Maximum	34.07	0.68	95.45	0	45.3	
MaxDate	10/04/2024 08:00	10/04/2024 21:00	10/04/2024 13:00	10/04/2024 00:00	10/04/2024 12:00	
Avg	23.93	0.33	94.35	0	23.9	
Num	25	6	18	18	18	
Data[%]	100	24	72	72	72	
STD	14.6	0.2	1	0	5.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/04/2024 00:00	24.82	0	94.36	0.9	32.5	
11/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/04/2024 06:00	0	0.17	ShutDown	ShutDown	ShutDown	GT11 S/D
11/04/2024 07:00	11.69	0.02	ShutDown	ShutDown	ShutDown	GT11 S/D
11/04/2024 08:00	34.1	0	95.69	1	26.4	
11/04/2024 09:00	34.24	0	95.82	1	25.9	
11/04/2024 10:00	34.33	0	95.98	1	26.1	
11/04/2024 11:00	34.21	0	96.25	1	26.4	
11/04/2024 12:00	21.88	0	93.42	1.1	48.1	
11/04/2024 13:00	34.25	0	95.54	1	28.1	
11/04/2024 14:00	34.36	0	95.83	0.9	26.3	
11/04/2024 15:00	34.25	0	95.28	0.9	26	
11/04/2024 16:00	34.09	0	95.08	0.9	25.9	
11/04/2024 17:00	33.74	0	94.58	0.9	25.4	
11/04/2024 18:00	33.67	0	94.28	0.8	25.3	
11/04/2024 19:00	33.65	0	94.13	0.8	25.2	
11/04/2024 20:00	33.77	0	94.14	0.8	25.3	
11/04/2024 21:00	33.95	0	94.6	0.8	25.3	
11/04/2024 22:00	33.95	0	94.73	0.8	25.2	
11/04/2024 23:00	33.88	0	94.74	0.9	25.1	
12/04/2024 00:00	32.88	0	94.39	0.9	32.8	
Minimum	0	0	93.42	0.8	25.1	
MinDate	11/04/2024 01:00	11/04/2024 00:00	11/04/2024 12:00	11/04/2024 18:00	11/04/2024 23:00	
Maximum	34.36	0.17	96.25	1.1	48.1	
MaxDate	11/04/2024 14:00	11/04/2024 06:00	11/04/2024 11:00	11/04/2024 12:00	11/04/2024 12:00	
Avg	24.07	0.01	94.94	0.9	27.9	
Num	25	25	18	18	18	
Data[%]	100	100	72	72	72	
STD	14.7	0	0.8	0.1	5.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/04/2024 00:00	32.85	0.27	94.66	0	28.8	
11/04/2024 01:00	47.82	<Samp	96.53	0	38.5	DUST waiting for spare part
11/04/2024 02:00	47.94	0.02	95.12	0	38.9	
11/04/2024 03:00	48.06	0.01	95.16	0	38.7	
11/04/2024 04:00	48.07	0.03	95.34	0	38.6	
11/04/2024 05:00	48	0.01	95.38	0	37.8	
11/04/2024 06:00	48.07	0.09	96	0	37	
11/04/2024 07:00	38.37	0.08	95.1	0	35.8	
11/04/2024 08:00	34.03	<Samp	95.44	0	20.9	DUST waiting for spare part
11/04/2024 09:00	34.18	<Samp	96.18	0	20.2	DUST waiting for spare part
11/04/2024 10:00	34.27	Maintenance	96.35	0	20.4	DUST waiting for spare part
11/04/2024 11:00	34.14	<Samp	96.73	0	20.8	DUST waiting for spare part
11/04/2024 12:00	21.84	Maintenance	93.67	0	44.9	DUST waiting for spare part
11/04/2024 13:00	34.23	Maintenance	95.64	0	22.4	DUST waiting for spare part
11/04/2024 14:00	34.3	Maintenance	95.72	0	20.5	DUST waiting for spare part
11/04/2024 15:00	34.19	Maintenance	95.35	0	20	DUST waiting for spare part
11/04/2024 16:00	34.02	Maintenance	95.2	0	19.8	DUST waiting for spare part
11/04/2024 17:00	33.68	Maintenance	94.75	0	19.5	DUST waiting for spare part
11/04/2024 18:00	33.61	Maintenance	94.52	0	19.4	DUST waiting for spare part
11/04/2024 19:00	33.59	Maintenance	94.34	0	19.4	DUST waiting for spare part
11/04/2024 20:00	33.71	Maintenance	94.24	0	19.6	DUST waiting for spare part
11/04/2024 21:00	33.89	Maintenance	94.45	0	19.7	DUST waiting for spare part
11/04/2024 22:00	33.89	Maintenance	94.45	0	19.6	DUST waiting for spare part
11/04/2024 23:00	33.82	Maintenance	94.45	0	19.6	DUST waiting for spare part
12/04/2024 00:00	24.67	Maintenance	93.69	0	28.7	DUST waiting for spare part
Minimum	21.84	0.01	93.67	0	19.4	
MinDate	11/04/2024 12:00	11/04/2024 03:00	11/04/2024 12:00	11/04/2024 00:00	11/04/2024 18:00	
Maximum	48.07	0.27	96.73	0	44.9	
MaxDate	11/04/2024 04:00	11/04/2024 00:00	11/04/2024 11:00	11/04/2024 00:00	11/04/2024 12:00	
Avg	35.41	0.07	95.14	0	26.1	
Num	25	7	25	25	25	
Data[%]	100	28	100	100	100	
STD	7.3	0.1	0.8	0	6.9	

Date & Time	11CT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/04/2024 00:00	32.88	0	94.39	0.9	32.8	
12/04/2024 01:00	48.14	0	95.15	0.9	36.5	
12/04/2024 02:00	48.15	0	95.15	0.9	36.5	
12/04/2024 03:00	48.26	0	95.25	0.9	36.2	
12/04/2024 04:00	48.22	0	95.34	0.9	36.4	
12/04/2024 05:00	48.01	0	95.38	0.9	35.5	
12/04/2024 06:00	48.05	0.36	95.50	0.9	35.2	
12/04/2024 07:00	48.12	0	95.54	0.9	36	
12/04/2024 08:00	47.86	0	95.38	0.9	36.2	
12/04/2024 09:00	47.45	0	95.34	0.9	36.3	
12/04/2024 10:00	46.99	0	95.37	0.9	36.3	
12/04/2024 11:00	46.57	0	95.59	0.9	36.4	
12/04/2024 12:00	46.16	0	95.45	0.9	36.1	
12/04/2024 13:00	46.09	0	95.05	0.9	35.8	
12/04/2024 14:00	46.16	0	95.15	0.9	35	
12/04/2024 15:00	46.45	0	94.68	0.9	35.4	
12/04/2024 16:00	46.59	0	94.42	0.8	35.2	
12/04/2024 17:00	36.3	0	95.16	0.9	35.8	
12/04/2024 18:00	33.27	0	93.87	0.8	24.8	
12/04/2024 19:00	33.07	0	93.8	0.8	23.9	
12/04/2024 20:00	33.28	0	93.73	0.8	23.8	
12/04/2024 21:00	33.35	0	94.09	0.8	23.5	
12/04/2024 22:00	35.69	0	95.75	0.9	24.2	
12/04/2024 23:00	30.5	0	94.92	1	35	
13/04/2024 00:00	27.31	0	92.9	1	42.6	
Minimum	27.31	0	92.9	0.8	23.5	
MinDate	13/04/2024 00:00	12/04/2024 00:00	13/04/2024 00:00	12/04/2024 16:00	12/04/2024 21:00	
Maximum	48.26	0.36	96.15	1	42.6	
MaxDate	12/04/2024 03:00	12/04/2024 06:00	12/04/2024 01:00	12/04/2024 23:00	13/04/2024 00:00	
Avg	42.15	0.01	94.62	0.9	33.1	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0.1	0.8	0.1	6.2	

Date & Time	12CT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/04/2024 00:00	24.67	Maintenance	93.69	0	28.7	DUST waiting for spare part
12/04/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 08:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 09:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 10:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 11:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 12:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 13:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 14:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 15:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 16:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 17:00	13.78	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/04/2024 18:00	33.21	Maintenance	94.34	0	22.6	DUST waiting for spare part
12/04/2024 19:00	33.01	Maintenance	94.05	0	22.3	DUST waiting for spare part
12/04/2024 20:00	33.21	Maintenance	94.21	0	21.7	DUST waiting for spare part
12/04/2024 21:00	33.29	Maintenance	94.38	0	21.5	DUST waiting for spare part
12/04/2024 22:00	36.44	Maintenance	95.99	0	22.3	DUST waiting for spare part
12/04/2024 23:00	30.42	Maintenance	95.08	0	33	DUST waiting for spare part
13/04/2024 00:00	27.24	Maintenance	92.86	0	38.7	DUST waiting for spare part
Minimum	0	---	92.98	0	21.5	
MinDate	12/04/2024 01:00	12/04/2024 00:00	13/04/2024 00:00	12/04/2024 00:00	12/04/2024 21:00	
Maximum	36.44	---	95.99	0	38.7	
MaxDate	12/04/2024 22:00	12/04/2024 00:00	12/04/2024 22:00	12/04/2024 00:00	13/04/2024 00:00	
Avg	10.61	---	94.34	0	26.4	
Num	25	0	8	8	8	
Data[%]	100	---	32	32	32	
STD	15	---	0.9	0	6.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/04/2024 00:00	27.31	0	92.9	1	42.6	
13/04/2024 01:00	30.01	0	93.57	1	35.5	
13/04/2024 02:00	30.28	0	93.71	1	34.6	
13/04/2024 03:00	30.14	0	93.74	1	34.8	
13/04/2024 04:00	30.02	0	93.59	1	35.2	
13/04/2024 05:00	29.88	0	93.65	1	35.7	
13/04/2024 06:00	29.86	0.3	93.84	1	35.8	
13/04/2024 07:00	30.28	0	94	1	34.4	
13/04/2024 08:00	30.31	0	94.11	1	33.9	
13/04/2024 09:00	30.35	0	94.11	1	33.2	
13/04/2024 10:00	30.34	0	94.43	1	32.7	
13/04/2024 11:00	30.4	0	94.97	1	31.8	
13/04/2024 12:00	30.36	0	94.31	1	30.8	
13/04/2024 13:00	30.33	0	93.28	0.9	32.2	
13/04/2024 14:00	30.39	0	94.33	0.9	31	
13/04/2024 15:00	30.34	0	93.86	0.9	31.6	
13/04/2024 16:00	30.35	0	93.47	0.9	31.7	
13/04/2024 17:00	30.38	0	93.03	0.9	32.4	
13/04/2024 18:00	44.17	0	99.25	0.9	27.8	
13/04/2024 19:00	44.25	0	100.55	0.9	26.9	
13/04/2024 20:00	44.27	0	100.33	0.9	26.6	
13/04/2024 21:00	44.23	0	100.57	0.9	26.3	
13/04/2024 22:00	44.23	0	101.47	0.9	26.1	
13/04/2024 23:00	37.23	0	98.77	0.9	30	
14/04/2024 00:00	30.29	0	93.21	0.9	32.8	
Minimum	27.31	0	92.9	0.9	26.1	
MinDate	13/04/2024 00:00	13/04/2024 00:00	13/04/2024 00:00	13/04/2024 13:00	13/04/2024 22:00	
Maximum	44.27	0.3	101.47	1	42.6	
MaxDate	13/04/2024 20:00	13/04/2024 06:00	13/04/2024 22:00	13/04/2024 00:00	13/04/2024 00:00	
Avg	33.2	0.01	95.34	1	32.3	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	5.8	0.1	2.9	0.1	3.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/04/2024 00:00	27.24	Maintenance	92.96	0	38.7	DUST waiting for spare part
13/04/2024 01:00	29.95	Maintenance	93.34	0	33.3	DUST waiting for spare part
13/04/2024 02:00	30.22	Maintenance	93.44	0	32.6	DUST waiting for spare part
13/04/2024 03:00	30.08	<Samp	93.38	0	32.8	DUST waiting for spare part
13/04/2024 04:00	29.95	Maintenance	93.32	0	33.2	DUST waiting for spare part
13/04/2024 05:00	29.83	Maintenance	93.36	0	33.5	DUST waiting for spare part
13/04/2024 06:00	29.8	Maintenance	93.52	0	33.7	DUST waiting for spare part
13/04/2024 07:00	30.23	<Samp	93.68	0	32.4	DUST waiting for spare part
13/04/2024 08:00	30.25	<Samp	93.78	0	32	DUST waiting for spare part
13/04/2024 09:00	30.29	1.3	93.93	0	31.5	DUST waiting for spare part
13/04/2024 10:00	30.28	<Samp	94.05	0	31.1	DUST waiting for spare part
13/04/2024 11:00	30.34	<Samp	94.58	0	30.5	DUST waiting for spare part
13/04/2024 12:00	30.29	<Samp	94.02	0	29.4	DUST waiting for spare part
13/04/2024 13:00	30.26	<Samp	93.03	0	31.4	DUST waiting for spare part
13/04/2024 14:00	30.33	Maintenance	93.97	0	29.5	DUST waiting for spare part
13/04/2024 15:00	30.29	Maintenance	93.65	0	30.3	DUST waiting for spare part
13/04/2024 16:00	30.29	Maintenance	93.26	0	30.4	DUST waiting for spare part
13/04/2024 17:00	30.33	<Samp	93.02	0	31.1	DUST waiting for spare part
13/04/2024 18:00	44.09	0.01	99.34	0	28.6	DUST waiting for spare part
13/04/2024 19:00	44.18	0	101.47	0	28.3	DUST waiting for spare part
13/04/2024 20:00	44.19	<Samp	101.44	0	27.8	DUST waiting for spare part
13/04/2024 21:00	44.15	Maintenance	101.72	0	27.3	DUST waiting for spare part
13/04/2024 22:00	44.14	Maintenance	101.77	0	27	DUST waiting for spare part
13/04/2024 23:00	37.14	Maintenance	99	0	29.5	DUST waiting for spare part
14/04/2024 00:00	30.23	Maintenance	93.75	0	31.1	DUST waiting for spare part
Minimum	27.24	0	92.96	0	27	
MinDate	13/04/2024 00:00	13/04/2024 19:00	13/04/2024 00:00	13/04/2024 22:00		
Maximum	44.19	1.3	101.77	0	38.7	
MaxDate	13/04/2024 20:00	13/04/2024 09:00	13/04/2024 22:00	13/04/2024 00:00	13/04/2024 00:00	
Avg	33.13	0.44	95.31	0	31.1	
Num	25	3	25	25	25	
Data(%)	100	12	100	100	100	
STD	5.8	0.7	3.2	0	2.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MMV	mg/m3	Degree C.	ppm	ppm	
14/04/2024 00:00	30.29	0	93.21	0.9	32.8	
14/04/2024 01:00	30.28	0	93	0.9	32.4	
14/04/2024 02:00	30.36	0	93.05	0.9	32.3	
14/04/2024 03:00	30.27	0	93.06	0.9	32.3	
14/04/2024 04:00	30.36	0	93.23	0.9	32.1	
14/04/2024 05:00	30.28	0	93.03	0.9	32.2	
14/04/2024 06:00	30.34	0.26	93.34	0.9	32.1	
14/04/2024 07:00	30.24	0	93.34	0.9	32.2	
14/04/2024 08:00	30.35	0	93.7	0.9	31.2	
14/04/2024 09:00	30.31	0	93.81	0.9	30.8	
14/04/2024 10:00	30.3	0	94.04	0.9	30.2	
14/04/2024 11:00	30.39	0	94.03	0.9	29.3	
14/04/2024 12:00	30.33	0	94	0.9	29.2	
14/04/2024 13:00	30.28	0	93.7	0.9	29.6	
14/04/2024 14:00	30.3	0	93.47	0.8	29.4	
14/04/2024 15:00	30.42	0	93.22	0.8	29	
14/04/2024 16:00	30.53	0	92.97	0.8	28.5	
14/04/2024 17:00	30.55	0	92.62	0.8	29.1	
14/04/2024 18:00	44.45	0	99	0.8	26.5	
14/04/2024 19:00	44.51	0	100.91	0.8	25.7	
14/04/2024 20:00	44.44	0	101.07	0.8	25.2	
14/04/2024 21:00	41.45	0	99.49	0.8	28.7	
14/04/2024 22:00	48.07	0	96.8	0.8	32	
14/04/2024 23:00	48.11	0	95.28	0.8	31.6	
15/04/2024 00:00	48.09	0	95.52	0.8	31.6	
Minimum	30.24	0	92.62	0.8	25.2	
MinDate	14/04/2024 07:00	14/04/2024 00:00	14/04/2024 17:00	14/04/2024 14:00	14/04/2024 20:00	
Maximum	48.11	0.26	101.07	0.9	32.8	
MaxDate	14/04/2024 23:00	14/04/2024 06:00	14/04/2024 20:00	14/04/2024 00:00	14/04/2024 00:00	
Avg	34.61	0.01	94.76	0.9	30.2	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	7.1	0.1	2.6	0.1	2.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MMV	mg/m3	Degree C.	ppm	ppm	
14/04/2024 00:00	30.23	Maintenance	93.75	0	31.1	DUST waiting for spare part
14/04/2024 01:00	30.23	Maintenance	93.47	0	30.8	DUST waiting for spare part
14/04/2024 02:00	30.3	Maintenance	93.34	0	30.7	DUST waiting for spare part
14/04/2024 03:00	30.2	Maintenance	93.44	0	30.8	DUST waiting for spare part
14/04/2024 04:00	30.3	Maintenance	93.65	0	30.5	DUST waiting for spare part
14/04/2024 05:00	30.22	<Samp	93.48	0	30.6	DUST waiting for spare part
14/04/2024 06:00	30.28	<Samp	93.76	0	30.5	DUST waiting for spare part
14/04/2024 07:00	30.19	<Samp	93.71	0	30.4	DUST waiting for spare part
14/04/2024 08:00	30.3	<Samp	94.09	0	29.6	DUST waiting for spare part
14/04/2024 09:00	30.25	0.26	94.1	0	29.3	
14/04/2024 10:00	30.24	0.01	94.38	0	28.8	
14/04/2024 11:00	30.33	0.11	94.5	0	28	
14/04/2024 12:00	30.27	0.17	94.39	0	27.8	
14/04/2024 13:00	30.22	0.13	94.01	0	28.2	
14/04/2024 14:00	30.24	0.01	93.85	0	28.1	
14/04/2024 15:00	30.36	0	93.69	0	27.8	
14/04/2024 16:00	30.47	0	93.47	0	27.2	
14/04/2024 17:00	30.5	0	93.27	0	27.9	
14/04/2024 18:00	44.36	0	99.9	0	27.8	
14/04/2024 19:00	44.42	0	101.52	0	26.6	
14/04/2024 20:00	44.37	0	101.66	0	25.7	
14/04/2024 21:00	32.44	0	99.47	0	31	
14/04/2024 22:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
14/04/2024 23:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 00:00	0	0.53	ShutDown	ShutDown	ShutDown	
Minimum	0	0	93.27	0	25.7	
MinDate	14/04/2024 22:00	14/04/2024 15:00	14/04/2024 17:00	14/04/2024 00:00	14/04/2024 20:00	
Maximum	44.42	0.53	101.66	0	31.1	
MaxDate	14/04/2024 19:00	15/04/2024 00:00	14/04/2024 20:00	14/04/2024 00:00	14/04/2024 00:00	
Avg	28.43	0.09	95.04	0	29.1	
Num	25	14	22	22	22	
Data(%)	100	56	88	88	88	
STD	11.7	0.2	2.8	0	1.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
15/04/2024 00:00	48.09	0	95.52	0.8	31.6	
15/04/2024 01:00	48.17	0	95.58	0.8	31.4	
15/04/2024 02:00	48.22	0	95.58	0.8	31.3	
15/04/2024 03:00	48.27	0	95.66	0.8	31.2	
15/04/2024 04:00	48.31	0	95.63	0.8	31.3	
15/04/2024 05:00	48.35	0	95.7	0.9	31.4	
15/04/2024 06:00	48.36	0.17	95.64	0.8	31.4	
15/04/2024 07:00	48.21	0	95.75	0.8	31.3	
15/04/2024 08:00	47.86	0	95.73	0.8	31.1	
15/04/2024 09:00	47.43	0	95.61	0.8	31.3	
15/04/2024 10:00	47	0	95.68	0.8	31.5	
15/04/2024 11:00	46.54	0	95.08	0.8	31.4	
15/04/2024 12:00	43.39	0	97.04	0.8	31.4	
15/04/2024 13:00	29.46	0	94.26	0.8	31	
15/04/2024 14:00	30.47	0	93.61	0.8	26	
15/04/2024 15:00	30.54	0	93.27	0.8	26.1	
15/04/2024 16:00	30.48	0	93.01	0.8	26.5	
15/04/2024 17:00	30.46	0	92.76	0.8	27	
15/04/2024 18:00	44.32	0	99.12	0.8	24.6	
15/04/2024 19:00	44.33	0	100.94	0.8	23.8	
15/04/2024 20:00	44.33	0	101.01	0.8	23.7	
15/04/2024 21:00	44.28	0	101.34	0.8	23.6	
15/04/2024 22:00	41.33	0	99.76	0.8	22.8	
15/04/2024 23:00	33.71	0	96.71	0.8	30.4	
16/04/2024 00:00	27.01	0	92.43	0.8	40.5	
Minimum	27.01	0	92.43	0.8	22.8	
MinDate	16/04/2024 00:00	15/04/2024 00:00	16/04/2024 00:00	15/04/2024 00:00	15/04/2024 22:00	
Maximum	48.36	0.17	101.34	0.9	40.5	
MaxDate	15/04/2024 06:00	15/04/2024 06:00	15/04/2024 21:00	15/04/2024 09:00	16/04/2024 00:00	
Avg	41.96	0.01	96.14	0.8	29.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.7	0	2.5	0	4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
15/04/2024 00:00	0	0.53	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 01:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 02:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 03:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 04:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 05:00	0	0.1	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 06:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 08:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 09:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 10:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 11:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 12:00	5.85	0.17	ShutDown	ShutDown	ShutDown	GT12 S/D
15/04/2024 13:00	29.37	0.19	94.14	0	34.5	
15/04/2024 14:00	30.42	0.12	93.71	0	31	
15/04/2024 15:00	30.48	0.05	93.51	0	30.9	
15/04/2024 16:00	30.42	0.06	93.44	0	31.1	
15/04/2024 17:00	30.41	0.05	93.25	0	31.4	
15/04/2024 18:00	44.24	0.02	99.83	0	30.8	
15/04/2024 19:00	44.25	0	101.34	0	29.6	
15/04/2024 20:00	44.25	0	101.3	0	29.1	
15/04/2024 21:00	44.2	0	101.42	0	28.8	
15/04/2024 22:00	41.25	0	99.76	0	25.3	
15/04/2024 23:00	33.64	0	96.66	0	31.5	
16/04/2024 00:00	26.95	0	93.12	0	39.8	
Minimum	0	0	93.12	0	25.3	
MinDate	15/04/2024 00:00	15/04/2024 19:00	16/04/2024 00:00	15/04/2024 13:00	15/04/2024 22:00	
Maximum	44.25	0.53	101.42	0	39.8	
MaxDate	15/04/2024 19:00	15/04/2024 00:00	15/04/2024 21:00	15/04/2024 13:00	16/04/2024 00:00	
Avg	17.43	0.09	96.79	0	31.2	
Num	25	15	12	12	12	
Data[%]	100	60	48	48	48	
STD	18.7	0.1	3.6	0	3.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/04/2024 00:00	27.01	0	92.43	0.8	40.5	
16/04/2024 01:00	26.97	0	92.17	0.9	40.2	
16/04/2024 02:00	26.98	0	92.16	0.9	40	
16/04/2024 03:00	26.95	0	92.28	0.9	39.8	
16/04/2024 04:00	26.95	0	92.21	0.9	39.9	
16/04/2024 05:00	26.98	0	92.18	0.9	40	
16/04/2024 06:00	26.98	0.38	92.16	0.9	40	
16/04/2024 07:00	26.97	0	92.55	0.9	40.1	
16/04/2024 08:00	25.57	0	92.53	0.9	41.8	
16/04/2024 09:00	2.21	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 12:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 13:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 14:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 15:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 16:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 17:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 18:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 19:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 20:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 21:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 22:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
16/04/2024 23:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	92.16	0.8	39.8	
MnDate	16/04/2024 10:00	16/04/2024 00:00	16/04/2024 02:00	16/04/2024 00:00	16/04/2024 03:00	
Maximum	27.01	0.38	92.55	0.9	41.8	
MaxDate	16/04/2024 00:00	16/04/2024 06:00	16/04/2024 07:00	16/04/2024 01:00	16/04/2024 08:00	
Avg	9.74	0.01	92.3	0.9	40.3	
Num	25	25	9	9	9	
Data[%]	100	100	36	36	36	
STD	13.1	0.1	0.2	0	0.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/04/2024 00:00	26.95	0	93.12	0	39.8	
16/04/2024 01:00	26.91	0	93.09	0	39.6	
16/04/2024 02:00	26.92	0	93.06	0	39.5	
16/04/2024 03:00	26.9	0.03	93.12	0	39.4	
16/04/2024 04:00	26.89	0.09	93.11	0	39.6	
16/04/2024 05:00	26.92	0.06	93.08	0	39.6	
16/04/2024 06:00	26.92	0.06	93.03	0	39.6	
16/04/2024 07:00	26.92	0.08	93.35	0	39.6	
16/04/2024 08:00	25.57	0.19	93.3	0	42.2	
16/04/2024 09:00	44.06	0.14	96.39	0	34.3	
16/04/2024 10:00	45.99	0.15	96.56	0	38	
16/04/2024 11:00	46.01	0.26	97.14	0	39.7	
16/04/2024 12:00	45.94	0.09	97.07	0	40.1	
16/04/2024 13:00	46.06	0.16	96.77	0	39.4	
16/04/2024 14:00	45.84	0.19	96.62	0	39.2	
16/04/2024 15:00	45.84	0.07	96.34	0	39.1	
16/04/2024 16:00	46.18	0.07	96.3	0	38.1	
16/04/2024 17:00	46.1	0.01	96.39	0	35.9	
16/04/2024 18:00	46.18	0	96.7	0	34.1	
16/04/2024 19:00	46.2	0	96.86	0	32.5	
16/04/2024 20:00	46.13	0	97.28	0	31	
16/04/2024 21:00	46.16	0	97.53	0	30.3	
16/04/2024 22:00	46.18	0	97.51	0	30.1	
16/04/2024 23:00	46.17	0	97.69	0	29.6	
17/04/2024 00:00	46.16	0	97.7	0	29.3	
Minimum	25.57	0	93.03	0	29.3	
MnDate	16/04/2024 08:00	16/04/2024 00:00	16/04/2024 06:00	16/04/2024 00:00	17/04/2024 00:00	
Maximum	46.2	0.26	97.7	0	42.2	
MaxDate	16/04/2024 19:00	16/04/2024 11:00	17/04/2024 00:00	16/04/2024 00:00	16/04/2024 08:00	
Avg	39.04	0.07	95.56	0	36.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	9.4	0.1	1.9	0	4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/04/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 06:00	0	0.3	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 10:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 11:00	0	0.07	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 12:00	0	0.1	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 13:00	0	0.07	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 14:00	0	0.04	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 15:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 16:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 17:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 18:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 19:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 20:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 21:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 22:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
17/04/2024 23:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
18/04/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0	0	---	---	---	
MinDate	17/04/2024 00:00	17/04/2024 00:00	17/04/2024 00:00	17/04/2024 00:00	17/04/2024 00:00	
Maximum	0	0.3	---	---	---	
MaxDate	17/04/2024 00:00	17/04/2024 06:00	17/04/2024 00:00	17/04/2024 00:00	17/04/2024 00:00	
Avg	0	0.02	---	---	---	
Num	25	25	0	0	0	
Data[%]	100	100	---	---	---	
STD	0	0.1	---	---	---	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/04/2024 00:00	46.16	0	97.7	0	29.3	
17/04/2024 01:00	46.22	0	97.75	0	29.5	
17/04/2024 02:00	46.22	0	97.77	0	29.2	
17/04/2024 03:00	46.19	0.01	97.82	0	28.9	
17/04/2024 04:00	46.25	0	97.76	0	28.8	
17/04/2024 05:00	46.28	0	97.84	0	28.7	
17/04/2024 06:00	46.23	0	97.95	0	28.4	
17/04/2024 07:00	46.31	0	97.73	0	29.4	
17/04/2024 08:00	46.29	0	97.53	0	31.5	
17/04/2024 09:00	46.22	0.03	96.98	0	34.5	
17/04/2024 10:00	46.28	0.08	96.65	0	37.1	
17/04/2024 11:00	46.13	0.46	97.09	0	37.3	
17/04/2024 12:00	46.08	0.09	96.64	0	37.2	
17/04/2024 13:00	45.98	0.1	96.44	0	37	
17/04/2024 14:00	45.73	0.07	96.32	0	36.8	
17/04/2024 15:00	45.59	0.01	96.02	0	36.6	
17/04/2024 16:00	45.86	0	95.88	0	36.7	
17/04/2024 17:00	46.18	0	96.03	0	36.5	
17/04/2024 18:00	46.17	0	96.29	0	33.8	
17/04/2024 19:00	46.17	0	96.58	0	31.5	
17/04/2024 20:00	46.17	0	97.08	0	29.2	
17/04/2024 21:00	45.96	0	96.83	0	27.4	
17/04/2024 22:00	45.78	0	95.65	0	26.1	
17/04/2024 23:00	45.74	0	96.35	0	25.6	
18/04/2024 00:00	45.78	0	96.54	0	25.5	
Minimum	45.59	0	95.65	0	25.5	
MinDate	17/04/2024 15:00	17/04/2024 00:00	17/04/2024 22:00	17/04/2024 00:00	18/04/2024 00:00	
Maximum	46.31	0.46	97.95	0	37.3	
MaxDate	17/04/2024 07:00	17/04/2024 11:00	17/04/2024 06:00	17/04/2024 00:00	17/04/2024 11:00	
Avg	46.08	0.03	96.93	0	31.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	0.2	0.1	0.7	0	4.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/04/2024 00:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 06:00	0	0.23	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 07:00	3.16	0.11	ShutDown	ShutDown	ShutDown	GT11 S/D.
18/04/2024 08:00	29.15	0	90.05	0.7	41.3	
18/04/2024 09:00	32.7	0	94.44	0.7	28.1	
18/04/2024 10:00	32.55	0	94.86	0.7	27.5	
18/04/2024 11:00	32.62	0	95.03	0.7	27	
18/04/2024 12:00	21.9	0.01	91.84	0.7	50.2	
18/04/2024 13:00	32.72	0	92.28	0.6	33.4	
18/04/2024 14:00	32.62	0	93.86	0.6	28.7	
18/04/2024 15:00	32.62	0	93.82	0.7	26.2	
18/04/2024 16:00	32.63	0	93.76	0.7	26.2	
18/04/2024 17:00	32.62	0	93.44	0.7	26.6	
18/04/2024 18:00	32.61	0	93.21	0.7	27.5	
18/04/2024 19:00	32.48	0	93.24	0.7	28.5	
18/04/2024 20:00	32.38	0	93.16	0.7	29.3	
18/04/2024 21:00	32.36	0	93.55	0.7	29.8	
18/04/2024 22:00	32.33	0	93.66	0.7	30.2	
18/04/2024 23:00	32.33	0	93.63	0.7	30.2	
19/04/2024 00:00	32.19	0	93.42	0.8	35.2	
Minimum	0	0	90.05	0.6	26.2	
MinDate	18/04/2024 00:00	18/04/2024 00:00	18/04/2024 08:00	18/04/2024 13:00	18/04/2024 15:00	
Maximum	32.72	0.23	95.03	0.8	50.2	
MaxDate	18/04/2024 13:00	18/04/2024 06:00	18/04/2024 11:00	19/04/2024 00:00	18/04/2024 12:00	
Avg	21.68	0.01	93.37	0.7	30.9	
Num	25	25	17	17	17	
Data(%)	100	100	68	68	68	
STD	15.1	0.1	1.2	0	6.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/04/2024 00:00	45.78	0	96.54	0	25.5	
18/04/2024 01:00	45.8	0	96.54	0	25.4	
18/04/2024 02:00	45.78	0	96.55	0	25.2	
18/04/2024 03:00	45.78	0	96.54	0	25.1	
18/04/2024 04:00	45.77	0	96.6	0	25.1	
18/04/2024 05:00	45.97	0	97.05	0	25.7	
18/04/2024 06:00	46.19	0	96.88	0	26.1	
18/04/2024 07:00	43.83	0	96.19	0	24.7	
18/04/2024 08:00	29.34	0	93.32	0	30.7	
18/04/2024 09:00	32.63	0.01	94.58	0	18.9	
18/04/2024 10:00	32.48	0.08	94.74	0	18.4	
18/04/2024 11:00	32.56	0.36	95.01	0	18	
18/04/2024 12:00	21.85	0.34	92.04	0	45.4	
18/04/2024 13:00	32.64	<Samp	93.45	0	23.5	DUST waiting for spare part
18/04/2024 14:00	32.55	<Samp	93.77	0	19.3	DUST waiting for spare part
18/04/2024 15:00	32.56	<Samp	94.04	0	17.4	DUST waiting for spare part
18/04/2024 16:00	32.56	<Samp	93.94	0	17.4	DUST waiting for spare part
18/04/2024 17:00	32.56	<Samp	93.72	0	17.7	DUST waiting for spare part
18/04/2024 18:00	32.55	<Samp	93.37	0	18.5	DUST waiting for spare part
18/04/2024 19:00	32.42	<Samp	93.33	0	19.3	DUST waiting for spare part
18/04/2024 20:00	32.32	Maintenance	93.28	0	20.3	DUST waiting for spare part
18/04/2024 21:00	32.3	<Samp	93.74	0	20.9	DUST waiting for spare part
18/04/2024 22:00	32.27	Maintenance	93.72	0	21.1	DUST waiting for spare part
18/04/2024 23:00	32.27	Maintenance	93.72	0	21.1	DUST waiting for spare part
19/04/2024 00:00	23.16	Maintenance	93.05	0	26.6	DUST waiting for spare part
Minimum	21.85	0	92.04	0	17.4	
MinDate	18/04/2024 12:00	18/04/2024 00:00	18/04/2024 12:00	18/04/2024 00:00	18/04/2024 15:00	
Maximum	46.19	0.36	97.05	0	45.4	
MaxDate	18/04/2024 06:00	18/04/2024 11:00	18/04/2024 05:00	18/04/2024 00:00	18/04/2024 12:00	
Avg	35.76	0.06	94.59	0	23.2	
Num	25	13	25	25	25	
Data(%)	100	52	100	100	100	
STD	7.4	0.1	1.5	0	6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/04/2024 00:00	32.19	0	93.42	0.8	35.2	
19/04/2024 01:00	45.96	0	96.49	0.8	29.7	
19/04/2024 02:00	46.13	0	95.87	0.8	29.9	
19/04/2024 03:00	46.11	0	96.17	0.8	29.7	
19/04/2024 04:00	46.11	0	96.3	0.8	29.3	
19/04/2024 05:00	46.13	0	96.24	0.8	29.4	
19/04/2024 06:00	46.15	0.17	96.52	0.8	29.4	
19/04/2024 07:00	37.55	0	95.61	0.8	35.1	
19/04/2024 08:00	32.77	0	94.12	0.8	27.4	
19/04/2024 09:00	32.77	0	94.51	0.8	25.5	
19/04/2024 10:00	32.82	0	94.79	0.8	25	
19/04/2024 11:00	32.77	0	95.09	0.8	24.9	
19/04/2024 12:00	21.89	0	93.24	0.8	47.5	
19/04/2024 13:00	32.77	0	94.52	0.7	27.2	
19/04/2024 14:00	32.8	0	94.69	0.7	25.1	
19/04/2024 15:00	32.8	0	94.61	0.7	25	
19/04/2024 16:00	32.77	0	94.16	0.7	25.1	
19/04/2024 17:00	32.71	0	93.84	0.7	24.8	
19/04/2024 18:00	32.7	0	93.64	0.6	24.5	
19/04/2024 19:00	32.66	0	93.56	0.6	24.9	
19/04/2024 20:00	32.58	0	93.75	0.6	25.7	
19/04/2024 21:00	32.53	0	94.21	0.6	26.1	
19/04/2024 22:00	35.35	0	95.41	0.6	24.6	
19/04/2024 23:00	36.33	0	96.23	0.7	24.5	
20/04/2024 00:00	32.82	0	96.05	0.7	33.8	
Minimum	21.89	0	93.24	0.6	24.5	
MinDate	19/04/2024 12:00	19/04/2024 00:00	19/04/2024 12:00	19/04/2024 18:00	19/04/2024 18:00	
Maximum	46.15	0.17	96.52	0.8	47.5	
MaxDate	19/04/2024 06:00	19/04/2024 06:00	19/04/2024 06:00	19/04/2024 00:00	19/04/2024 12:00	
Avg	35.93	0.01	94.92	0.7	28.4	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.4	0	1.1	0.1	5.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/04/2024 00:00	23.16	Maintenance	93.05	0	28.6	DUST waiting for spare part
19/04/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/04/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/04/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/04/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/04/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/04/2024 06:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
19/04/2024 07:00	11.21	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/04/2024 08:00	32.7	Maintenance	94.7	0	24.9	DUST waiting for spare part
19/04/2024 09:00	32.71	0.33	94.33	0	22.9	
19/04/2024 10:00	32.75	0.2	94.45	0	21.9	
19/04/2024 11:00	32.71	0.21	94.75	0	21.8	
19/04/2024 12:00	21.89	0.21	93.06	0	46.1	
19/04/2024 13:00	32.72	0.2	94.5	0	23.8	
19/04/2024 14:00	32.75	0.17	94.31	0	21.5	
19/04/2024 15:00	32.73	0.12	94.22	0	21.4	
19/04/2024 16:00	32.71	0.1	93.94	0	21.5	
19/04/2024 17:00	32.64	0.08	93.51	0	21.2	
19/04/2024 18:00	32.64	0.03	93.28	0	21.3	
19/04/2024 19:00	32.6	0	93.16	0	22.3	
19/04/2024 20:00	32.52	0	93.38	0	23.3	
19/04/2024 21:00	32.47	0	93.74	0	23.8	
19/04/2024 22:00	35.29	0	94.87	0	21.7	DUST waiting for spare part
19/04/2024 23:00	36.26	<Samp	95.77	0	21.4	DUST waiting for spare part
20/04/2024 00:00	32.76	<Samp	95.78	0	30.8	
Minimum	0	0	93.05	0	21.2	
MinDate	19/04/2024 01:00	19/04/2024 19:00	19/04/2024 00:00	19/04/2024 00:00	19/04/2024 17:00	
Maximum	36.26	0.33	95.78	0	46.1	
MaxDate	19/04/2024 23:00	19/04/2024 09:00	20/04/2024 00:00	19/04/2024 00:00	19/04/2024 12:00	
Avg	23.41	0.12	94.16	0	24.5	
Num	25	14	19	18	18	
Data[%]	100	56	72	72	72	
STD	14.4	0.1	0.8	0	6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/04/2024 00:00	32.82	0	96.05	0.7	33.8	
20/04/2024 01:00	26.38	0	92.33	0.7	42.9	
20/04/2024 02:00	26.48	0	92.28	0.7	42.8	
20/04/2024 03:00	26.47	0	92.31	0.8	42.8	
20/04/2024 04:00	26.45	0	92.44	0.8	42.6	
20/04/2024 05:00	26.45	0	92.62	0.8	42.4	
20/04/2024 06:00	26.42	0.38	92.71	0.8	42.4	
20/04/2024 07:00	27.02	0	92.93	0.8	42.2	
20/04/2024 08:00	41.11	0	98.54	0.8	26.4	
20/04/2024 09:00	41.18	0	100.22	0.8	26.3	
20/04/2024 10:00	41.16	0	100.61	0.8	26.6	
20/04/2024 11:00	41.15	0	100.94	0.8	26.7	
20/04/2024 12:00	27.34	0	95.28	0.8	41.2	
20/04/2024 13:00	41.23	0	98.7	0.8	26.9	
20/04/2024 14:00	41.21	0	100.61	0.8	26.8	
20/04/2024 15:00	41.23	0	100	0.8	25.6	
20/04/2024 16:00	41.23	0	99.88	0.7	25.4	
20/04/2024 17:00	41.16	0	99.55	0.7	25.6	
20/04/2024 18:00	41.13	0	99.07	0.7	25.8	
20/04/2024 19:00	41.06	0	98.81	0.7	25.3	
20/04/2024 20:00	40.29	0	98.31	0.7	25	
20/04/2024 21:00	39.92	0	98.19	0.7	24.7	
20/04/2024 22:00	39.86	0	98.32	0.7	24.7	
20/04/2024 23:00	39.7	0	98.24	0.7	24.6	
21/04/2024 00:00	32.76	0	96.2	0.8	32.4	
Minimum	26.38	0	92.28	0.7	24.6	
MinDate	20/04/2024 01:00	20/04/2024 00:00	20/04/2024 02:00	20/04/2024 00:00	20/04/2024 23:00	
Maximum	41.23	0.38	100.94	0.8	42.9	
MaxDate	20/04/2024 13:00	20/04/2024 06:00	20/04/2024 11:00	20/04/2024 03:00	20/04/2024 01:00	
Avg	35.65	0.02	97.01	0.8	31.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.7	0.1	3.2	0.1	7.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/04/2024 00:00	32.76	<Samp	95.78	0	30.8	DUST waiting for spare part
20/04/2024 01:00	26.32	<Samp	92.81	0	39.7	DUST waiting for spare part
20/04/2024 02:00	26.42	Maintenance	92.53	0	39.4	DUST waiting for spare part
20/04/2024 03:00	26.41	Maintenance	92.53	0	39.4	DUST waiting for spare part
20/04/2024 04:00	26.39	Maintenance	92.65	0	39.3	DUST waiting for spare part
20/04/2024 05:00	26.4	Maintenance	92.81	0	39	DUST waiting for spare part
20/04/2024 06:00	26.36	Maintenance	92.92	0	39	DUST waiting for spare part
20/04/2024 07:00	26.96	Maintenance	93.08	0	37.6	DUST waiting for spare part
20/04/2024 08:00	41.05	<Samp	98.85	0	24.4	DUST waiting for spare part
20/04/2024 09:00	41.11	Maintenance	100.19	0	24.6	DUST waiting for spare part
20/04/2024 10:00	41.09	Maintenance	100.62	0	25.2	DUST waiting for spare part
20/04/2024 11:00	41.07	Maintenance	101	0	25.6	DUST waiting for spare part
20/04/2024 12:00	27.28	Maintenance	95.45	0	37.9	DUST waiting for spare part
20/04/2024 13:00	41.16	Maintenance	99.06	0	25.8	DUST waiting for spare part
20/04/2024 14:00	41.14	Maintenance	100.45	0	26.2	DUST waiting for spare part
20/04/2024 15:00	41.15	Maintenance	99.99	0	24.6	DUST waiting for spare part
20/04/2024 16:00	41.15	Maintenance	99.91	0	24.1	DUST waiting for spare part
20/04/2024 17:00	41.09	Maintenance	99.53	0	23.8	DUST waiting for spare part
20/04/2024 18:00	41.06	Maintenance	99.13	0	23.8	DUST waiting for spare part
20/04/2024 19:00	40.99	Maintenance	98.9	0	22.9	DUST waiting for spare part
20/04/2024 20:00	40.22	Maintenance	98.5	0	21.8	DUST waiting for spare part
20/04/2024 21:00	39.85	Maintenance	98.3	0	21.4	DUST waiting for spare part
20/04/2024 22:00	39.79	Maintenance	98.36	0	21.3	DUST waiting for spare part
20/04/2024 23:00	39.63	Maintenance	98.48	0	21.1	DUST waiting for spare part
21/04/2024 00:00	32.7	Maintenance	96.33	0	29.2	DUST waiting for spare part
Minimum	26.32	---	92.52	0	21.1	
MinDate	20/04/2024 01:00	20/04/2024 00:00	20/04/2024 02:00	20/04/2024 00:00	20/04/2024 23:00	
Maximum	41.16	---	101	0	39.7	
MaxDate	20/04/2024 13:00	20/04/2024 00:00	20/04/2024 11:00	20/04/2024 00:00	20/04/2024 01:00	
Avg	35.58	---	97.13	0	29.1	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	6.7	---	3.1	0	7.2	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG SO2@7%O2	11HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/04/2024 00:00	32.76	0	96.2	0.8	32.4	
21/04/2024 01:00	26.09	0	92.3	0.8	41.8	
21/04/2024 02:00	26.09	0	92.09	0.8	41.9	
21/04/2024 03:00	26.07	0	92.18	0.8	41.8	
21/04/2024 04:00	26.08	0	92.27	0.8	41.8	
21/04/2024 05:00	25.98	0	92.26	0.8	41.7	
21/04/2024 06:00	25.95	0.32	92.43	0.8	41.5	
21/04/2024 07:00	25.98	0	92.51	0.8	41.2	
21/04/2024 08:00	26.15	0	92.71	0.8	41.8	
21/04/2024 09:00	26.21	0	93.07	0.8	42.7	
21/04/2024 10:00	26.18	0	93.28	0.8	44.5	
21/04/2024 11:00	26.11	0	93.58	0.9	45.6	
21/04/2024 12:00	26.08	0	93.82	0.9	46	
21/04/2024 13:00	26.2	0	93.11	0.9	47.7	
21/04/2024 14:00	26.22	0	92.59	0.9	48.2	
21/04/2024 15:00	26.26	0	92.14	0.8	47.8	
21/04/2024 16:00	26.23	0	91.96	0.8	48.1	
21/04/2024 17:00	26.25	0	91.98	0.8	47.8	
21/04/2024 18:00	40.05	0	96.78	0.7	25.4	
21/04/2024 19:00	39.83	0	97.77	0.6	24.8	
21/04/2024 20:00	39.77	0	97.78	0.6	23.8	
21/04/2024 21:00	39.78	0	98.12	0.6	23.5	
21/04/2024 22:00	39.76	0	98.21	0.7	23.4	
21/04/2024 23:00	32.78	0	96.26	0.7	32	
22/04/2024 00:00	25.97	0	92.2	0.8	41.1	
Minimum	25.95	0	91.96	0.6	23.4	
MinDate	21/04/2024 06:00	21/04/2024 00:00	21/04/2024 16:00	21/04/2024 19:00	21/04/2024 22:00	
Maximum	40.05	0.32	98.21	0.9	48.2	
MaxDate	21/04/2024 18:00	21/04/2024 06:00	21/04/2024 22:00	21/04/2024 11:00	21/04/2024 14:00	
Avg	29.39	0.01	93.9	0.8	39.1	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	5.6	0.1	2.3	0.1	8.6	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG SO2@7%O2	12HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/04/2024 00:00	32.7	Maintenance	96.33	0	29.2	DUST waiting for spare part
21/04/2024 01:00	26.03	Maintenance	92.73	0	39	DUST waiting for spare part
21/04/2024 02:00	26.03	Maintenance	92.45	0	39.1	DUST waiting for spare part
21/04/2024 03:00	26.01	Maintenance	92.44	0	39.3	DUST waiting for spare part
21/04/2024 04:00	26.03	Maintenance	92.48	0	39.1	DUST waiting for spare part
21/04/2024 05:00	25.92	Maintenance	92.56	0	39.1	DUST waiting for spare part
21/04/2024 06:00	25.89	Maintenance	92.64	0	39	DUST waiting for spare part
21/04/2024 07:00	25.92	Maintenance	92.77	0	38.7	DUST waiting for spare part
21/04/2024 08:00	26.1	Maintenance	92.98	0	38.5	DUST waiting for spare part
21/04/2024 09:00	26.17	Maintenance	93.29	0	39.1	DUST waiting for spare part
21/04/2024 10:00	26.12	Maintenance	93.42	0	40.8	DUST waiting for spare part
21/04/2024 11:00	26.06	<Samp	93.87	0	41.6	DUST waiting for spare part
21/04/2024 12:00	26.03	<Samp	94.03	0	41.9	DUST waiting for spare part
21/04/2024 13:00	26.14	Maintenance	93.15	0	43.7	DUST waiting for spare part
21/04/2024 14:00	26.15	Maintenance	92.63	0	44.7	DUST waiting for spare part
21/04/2024 15:00	26.21	Maintenance	92.32	0	44.1	DUST waiting for spare part
21/04/2024 16:00	26.17	Maintenance	92.7	0	44.3	DUST waiting for spare part
21/04/2024 17:00	26.19	Maintenance	92.26	0	43.7	DUST waiting for spare part
21/04/2024 18:00	39.98	Maintenance	97.15	0	22.6	DUST waiting for spare part
21/04/2024 19:00	39.76	Maintenance	98	0	21.3	DUST waiting for spare part
21/04/2024 20:00	39.7	Maintenance	98.05	0	20.4	DUST waiting for spare part
21/04/2024 21:00	39.71	Maintenance	98.2	0	20.1	DUST waiting for spare part
21/04/2024 22:00	39.69	Maintenance	98.25	0	20.1	DUST waiting for spare part
21/04/2024 23:00	32.72	Maintenance	96.23	0	29.3	DUST waiting for spare part
22/04/2024 00:00	25.91	Maintenance	92.46	0	39.5	DUST waiting for spare part
Minimum	25.89	---	92.2	0	20.1	
MinDate	21/04/2024 06:00	21/04/2024 00:00	21/04/2024 16:00	21/04/2024 00:00	21/04/2024 21:00	
Maximum	39.98	---	98.25	0	44.7	
MaxDate	21/04/2024 18:00	21/04/2024 00:00	21/04/2024 22:00	21/04/2024 00:00	21/04/2024 14:00	
Avg	29.33	---	94.12	0	35.9	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	5.6	---	2.2	0	8.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/04/2024 00:00	25.97	0	92.2	0.8	41.1	
22/04/2024 01:00	26	0	92.29	0.8	40.8	
22/04/2024 02:00	26.03	0	92.38	0.8	40.7	
22/04/2024 03:00	26.01	0	92.24	0.8	40.7	
22/04/2024 04:00	25.99	0	92.15	0.8	40.6	
22/04/2024 05:00	26.06	0	92.19	0.9	40.5	
22/04/2024 06:00	26.08	0.23	92.2	0.9	40.5	
22/04/2024 07:00	26.26	0	92.51	0.9	40.5	
22/04/2024 08:00	39.35	0	97.68	0.8	23.8	
22/04/2024 09:00	33.9	0	95.32	0.8	22.1	
22/04/2024 10:00	33.95	0	95.32	0.8	22.2	
22/04/2024 11:00	33.98	0	96.03	0.8	22.2	
22/04/2024 12:00	21.52	0	93.05	0.9	45.6	
22/04/2024 13:00	34.26	0	95.13	0.8	23.6	
22/04/2024 14:00	34.21	0	95.35	0.8	22.2	
22/04/2024 15:00	34.2	0	95	0.8	22.1	
22/04/2024 16:00	34.11	0	94.7	0.7	22.1	
22/04/2024 17:00	33.9	0	94.32	0.7	22.1	
22/04/2024 18:00	33.82	0	93.83	0.7	21.9	
22/04/2024 19:00	33.87	0	93.84	0.7	21.5	
22/04/2024 20:00	34.03	0	94.03	0.7	21.3	
22/04/2024 21:00	34.15	0	94.58	0.7	21.3	
22/04/2024 22:00	34.07	0	94.8	0.7	21.3	
22/04/2024 23:00	34.05	0	94.72	0.7	21.2	
23/04/2024 00:00	25.68	0	93.88	0.8	29.6	
Minimum	21.52	0	92.15	0.7	21.2	
MinDate	22/04/2024 12:00	22/04/2024 00:00	22/04/2024 04:00	22/04/2024 16:00	22/04/2024 23:00	
Maximum	39.35	0.23	97.68	0.9	45.6	
MaxDate	22/04/2024 08:00	22/04/2024 06:00	22/04/2024 08:00	22/04/2024 05:00	22/04/2024 12:00	
Avg	30.86	0.01	93.99	0.8	29.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.6	0	1.5	0.1	9.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/04/2024 00:00	25.91	Maintenance	92.46	0	39.5	DUST waiting for spare part
22/04/2024 01:00	25.95	Maintenance	92.39	0	39.1	DUST waiting for spare part
22/04/2024 02:00	25.97	Maintenance	92.54	0	38.9	DUST waiting for spare part
22/04/2024 03:00	25.95	Maintenance	92.45	0	39.3	DUST waiting for spare part
22/04/2024 04:00	25.94	Maintenance	92.32	0	39.2	DUST waiting for spare part
22/04/2024 05:00	25.99	Maintenance	92.33	0	38.9	DUST waiting for spare part
22/04/2024 06:00	26.02	Maintenance	92.41	0	38.8	DUST waiting for spare part
22/04/2024 07:00	26.21	Maintenance	92.64	0	38	DUST waiting for spare part
22/04/2024 08:00	39.3	Maintenance	97.99	0	20.8	DUST waiting for spare part
22/04/2024 09:00	33.83	Maintenance	95.33	0	17.8	DUST waiting for spare part
22/04/2024 10:00	33.89	Maintenance	95.38	0	17.8	DUST waiting for spare part
22/04/2024 11:00	33.92	Maintenance	96.08	0	17.9	DUST waiting for spare part
22/04/2024 12:00	21.31	Maintenance	93.18	0	47	DUST waiting for spare part
22/04/2024 13:00	34.2	Maintenance	95.31	0	19.7	DUST waiting for spare part
22/04/2024 14:00	34.15	Maintenance	95.63	0	18	DUST waiting for spare part
22/04/2024 15:00	34.14	Maintenance	95.29	0	17.7	DUST waiting for spare part
22/04/2024 16:00	34.04	Maintenance	95.19	0	17.5	DUST waiting for spare part
22/04/2024 17:00	33.84	Maintenance	94.91	0	17.4	DUST waiting for spare part
22/04/2024 18:00	33.76	Maintenance	94.39	0	17.1	DUST waiting for spare part
22/04/2024 19:00	33.8	Maintenance	94.26	0	16.8	DUST waiting for spare part
22/04/2024 20:00	33.96	Maintenance	94.5	0	16.7	DUST waiting for spare part
22/04/2024 21:00	34.08	Maintenance	94.91	0	16.7	DUST waiting for spare part
22/04/2024 22:00	34.01	Maintenance	95.13	0	16.6	DUST waiting for spare part
22/04/2024 23:00	33.98	Maintenance	95.01	0	16.5	DUST waiting for spare part
23/04/2024 00:00	22.29	Maintenance	94.54	0	24.7	DUST waiting for spare part
Minimum	21.31	---	92.32	0	16.5	
MinDate	22/04/2024 12:00	22/04/2024 00:00	22/04/2024 04:00	22/04/2024 00:00	22/04/2024 23:00	
Maximum	39.3	---	97.99	0	47	
MaxDate	22/04/2024 08:00	22/04/2024 00:00	22/04/2024 08:00	22/04/2024 00:00	22/04/2024 12:00	
Avg	31.06	---	94.26	0	25.9	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.5	---	1.5	0	10.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/04/2024 00:00	25.68	0	93.88	0.8	29.6	
23/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
23/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
23/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
23/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
23/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
23/04/2024 06:00	0	0.17	ShutDown	ShutDown	ShutDown	GT11 SD
23/04/2024 07:00	10.69	0.04	ShutDown	ShutDown	ShutDown	GT11 SD
23/04/2024 08:00	34.05	0	95.28	0.8	28.6	
23/04/2024 09:00	34.29	0	95.57	0.8	27.7	
23/04/2024 10:00	34.3	0	95.78	0.9	27.8	
23/04/2024 11:00	34.32	0	96.54	0.9	28.1	
23/04/2024 12:00	21.97	0	93.69	0.9	50.7	
23/04/2024 13:00	34.45	0	95.5	0.9	29.5	
23/04/2024 14:00	34.4	0	95.8	0.8	28.1	
23/04/2024 15:00	34.38	0	95.39	0.8	27.7	
23/04/2024 16:00	34.37	0	95.12	0.8	27.4	
23/04/2024 17:00	34.06	0	94.65	0.8	27	
23/04/2024 18:00	34.09	0	94.36	0.7	26.6	
23/04/2024 19:00	33.9	0	94.07	0.7	26.2	
23/04/2024 20:00	34.08	0	94.22	0.7	26	
23/04/2024 21:00	34.12	0	94.77	0.8	26	
23/04/2024 22:00	34.09	0	95	0.8	25.8	
23/04/2024 23:00	33.96	0	94.83	0.8	25.6	
24/04/2024 00:00	32.89	0	94.38	0.8	32.9	
Minimum	0	0	93.69	0.7	25.6	
MinDate	23/04/2024 01:00	23/04/2024 00:00	23/04/2024 12:00	23/04/2024 18:00	23/04/2024 23:00	
Maximum	34.45	0.17	96.54	0.9	50.7	
MaxDate	23/04/2024 13:00	23/04/2024 06:00	23/04/2024 11:00	23/04/2024 10:00	23/04/2024 12:00	
Avg	24.16	0.01	94.93	0.8	29	
Num	25	25	18	18	18	
Data[%]	100	100	72	72	72	
STD	14.8	0	0.8	0.1	5.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/04/2024 00:00	32.29	Maintenance	94.54	0	24.7	DUST waiting for spare part
23/04/2024 01:00	47.75	Maintenance	96.37	0	32.2	DUST waiting for spare part
23/04/2024 02:00	47.85	Maintenance	94.9	0	32.2	DUST waiting for spare part
23/04/2024 03:00	48	Maintenance	95.1	0	32.4	DUST waiting for spare part
23/04/2024 04:00	48.06	Maintenance	95.28	0	32.4	DUST waiting for spare part
23/04/2024 05:00	48.08	Maintenance	95.42	0	32.4	DUST waiting for spare part
23/04/2024 06:00	48.1	Maintenance	95.49	0	32.4	DUST waiting for spare part
23/04/2024 07:00	39.15	Maintenance	95.27	0	31.3	DUST waiting for spare part
23/04/2024 08:00	33.99	Maintenance	95.25	0	18.3	DUST waiting for spare part
23/04/2024 09:00	34.23	Maintenance	95.13	0	17	DUST waiting for spare part
23/04/2024 10:00	34.24	Maintenance	95.27	0	17.1	DUST waiting for spare part
23/04/2024 11:00	34.25	< Samp	96.16	0	17.3	DUST waiting for spare part
23/04/2024 12:00	21.98	Maintenance	93.34	0	44	DUST waiting for spare part
23/04/2024 13:00	34.4	Maintenance	95.06	0	18.7	DUST waiting for spare part
23/04/2024 14:00	34.34	Maintenance	95.32	0	17	DUST waiting for spare part
23/04/2024 15:00	34.23	Maintenance	94.98	0	16.8	DUST waiting for spare part
23/04/2024 16:00	34.32	Maintenance	94.9	0	16.7	DUST waiting for spare part
23/04/2024 17:00	34.01	Maintenance	94.43	0	16.6	DUST waiting for spare part
23/04/2024 18:00	34.02	Maintenance	94.16	0	16.5	DUST waiting for spare part
23/04/2024 19:00	33.83	Maintenance	93.84	0	16.3	DUST waiting for spare part
23/04/2024 20:00	34.01	Maintenance	94.01	0	16.2	DUST waiting for spare part
23/04/2024 21:00	34.06	Maintenance	94.38	0	16.3	DUST waiting for spare part
23/04/2024 22:00	34.02	Maintenance	94.6	0	16.2	DUST waiting for spare part
23/04/2024 23:00	33.89	Maintenance	94.41	0	16.1	DUST waiting for spare part
24/04/2024 00:00	25.14	Maintenance	93.41	0	25.3	DUST waiting for spare part
Minimum	21.98	---	93.34	0	16.1	
MinDate	23/04/2024 12:00	23/04/2024 00:00	23/04/2024 12:00	23/04/2024 00:00	23/04/2024 23:00	
Maximum	48.1	---	96.37	0	44	
MaxDate	23/04/2024 06:00	23/04/2024 00:00	23/04/2024 01:00	23/04/2024 00:00	23/04/2024 12:00	
Avg	36.73	---	94.84	0	22.9	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	7.2	---	0.7	0	8.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/04/2024 00:00	32.89	0	94.38	0.8	32.9	
24/04/2024 01:00	48.15	0	96.04	0.8	36	
24/04/2024 02:00	48.24	0	94.81	0.9	36	
24/04/2024 03:00	48.29	0	95.08	0.9	35.9	
24/04/2024 04:00	48.32	0	95.22	0.9	35.7	
24/04/2024 05:00	48.34	0	95.59	0.9	35.5	
24/04/2024 06:00	48.29	0.36	95.5	0.9	35.4	
24/04/2024 07:00	39.57	0	95.67	0.9	36.6	
24/04/2024 08:00	34.1	0	94.76	0.9	27.6	
24/04/2024 09:00	34.39	0	95.22	0.9	25.8	
24/04/2024 10:00	34.38	0	95.35	0.9	26.3	
24/04/2024 11:00	34.37	0	95.97	0.9	26.2	
24/04/2024 12:00	21.59	0	93.2	1	50.4	
24/04/2024 13:00	34.4	0	95.03	0.9	27.6	
24/04/2024 14:00	34.36	0	95.43	0.9	26	
24/04/2024 15:00	34.44	0	95.09	0.8	25.8	
24/04/2024 16:00	34.24	0	94.71	0.8	25.6	
24/04/2024 17:00	34.07	0	94.29	0.8	25.2	
24/04/2024 18:00	34.02	0	93.97	0.7	24.8	
24/04/2024 19:00	33.91	0	93.84	0.7	24.4	
24/04/2024 20:00	33.98	0	93.9	0.7	24.1	
24/04/2024 21:00	34.18	0	94.49	0.8	24.1	
24/04/2024 22:00	34.1	0	94.62	0.8	24	
24/04/2024 23:00	33.99	0	94.49	0.8	23.8	
25/04/2024 00:00	25.34	0	93.62	0.8	32.1	
Minimum	21.59	0	93.2	0.7	23.8	
MinDate	24/04/2024 12:00	24/04/2024 00:00	24/04/2024 12:00	24/04/2024 18:00	24/04/2024 23:00	
Maximum	48.34	0.36	96.04	1	50.4	
MaxDate	24/04/2024 05:00	24/04/2024 06:00	24/04/2024 01:00	24/04/2024 12:00	24/04/2024 12:00	
Avg	36.88	0.01	94.81	0.8	29.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.3	0.1	0.7	0.1	6.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/04/2024 00:00	25.14	Maintenance	93.41	0	25.3	DUST waiting for spare part
24/04/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
24/04/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
24/04/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
24/04/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
24/04/2024 05:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
24/04/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
24/04/2024 07:00	10.42	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
24/04/2024 08:00	34.08	Maintenance	96.15	0	24.5	DUST waiting for spare part
24/04/2024 09:00	34.33	Maintenance	95.67	0	22.8	DUST waiting for spare part
24/04/2024 10:00	34.32	Maintenance	95.76	0	23.2	DUST waiting for spare part
24/04/2024 11:00	34.31	Maintenance	96.23	0	23.2	DUST waiting for spare part
24/04/2024 12:00	21.4	Maintenance	93.54	0	49.2	DUST waiting for spare part
24/04/2024 13:00	34.35	Maintenance	95.39	0	24.3	DUST waiting for spare part
24/04/2024 14:00	34.31	Maintenance	95.57	0	22.7	DUST waiting for spare part
24/04/2024 15:00	34.37	Maintenance	95.43	0	22.6	DUST waiting for spare part
24/04/2024 16:00	34.18	Maintenance	95.21	0	22.1	DUST waiting for spare part
24/04/2024 17:00	34.01	Maintenance	94.95	0	21.7	DUST waiting for spare part
24/04/2024 18:00	33.96	Maintenance	94.74	0	21.3	DUST waiting for spare part
24/04/2024 19:00	33.84	Maintenance	94.52	0	20.9	DUST waiting for spare part
24/04/2024 20:00	33.92	Maintenance	94.52	0	20.7	DUST waiting for spare part
24/04/2024 21:00	34.12	Maintenance	94.84	0	20.7	DUST waiting for spare part
24/04/2024 22:00	34.04	Maintenance	95	0	20.6	DUST waiting for spare part
24/04/2024 23:00	33.93	Maintenance	94.93	0	20.3	DUST waiting for spare part
25/04/2024 00:00	32.73	Maintenance	94.31	0	28.2	DUST waiting for spare part
Minimum	0	---	93.41	0	20.3	
MinDate	24/04/2024 01:00	24/04/2024 00:00	24/04/2024 00:00	24/04/2024 00:00	24/04/2024 23:00	
Maximum	34.37	---	96.23	0	49.2	
MaxDate	24/04/2024 15:00	24/04/2024 00:00	24/04/2024 11:00	24/04/2024 00:00	24/04/2024 12:00	
Avg	24.07	---	95.01	0	24.1	
Num	25	0	18	18	18	
Data[%]	100	---	72	72	72	
STD	14.8	---	0.8	0	6.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
25/04/2024 00:00	25.34	0	93.62	0.8	32.1	
25/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/04/2024 06:00	0	0.3	ShutDown	ShutDown	ShutDown	GT11 S/D
25/04/2024 07:00	11.89	0	ShutDown	ShutDown	ShutDown	GT11 S/D
25/04/2024 08:00	34.12	0	95.69	0.9	27.5	
25/04/2024 09:00	34.28	0	96.04	0.9	26.8	
25/04/2024 10:00	34.35	0	96.32	0.9	27.1	
25/04/2024 11:00	34.34	0	96.71	1	27.4	
25/04/2024 12:00	21.58	0	93.7	1	51.3	
25/04/2024 13:00	34.45	0	95.69	0.9	28.8	
25/04/2024 14:00	34.37	0	96.06	0.9	27.1	
25/04/2024 15:00	34.36	0	95.62	0.9	27	
25/04/2024 16:00	34.09	0	95.16	0.9	26.6	
25/04/2024 17:00	33.76	0	94.59	0.9	26.3	
25/04/2024 18:00	33.67	0	94.12	0.8	26.1	
25/04/2024 19:00	33.61	0	94.04	0.8	25.6	
25/04/2024 20:00	33.83	0	94.29	0.8	25.5	
25/04/2024 21:00	33.92	0	94.56	0.8	25.4	
25/04/2024 22:00	33.92	0	94.75	0.8	25.2	
25/04/2024 23:00	33.91	0	95.04	0.8	25	
26/04/2024 00:00	32.84	0	94.54	0.9	32.6	
Minimum	0	0	93.62	0.8	25	
MinDate	25/04/2024 01:00	25/04/2024 00:00	25/04/2024 00:00	25/04/2024 00:00	25/04/2024 23:00	
Maximum	34.45	0.3	96.71	1	51.3	
MaxDate	25/04/2024 13:00	25/04/2024 06:00	25/04/2024 11:00	25/04/2024 12:00	25/04/2024 12:00	
Avg	24.11	0.01	95.03	0.9	28.5	
Num	25	25	18	18	25	
Data[%]	100	100	72	72	100	
STD	14.7	0.1	0.9	0.1	6.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/h3	Degree C.	ppm	ppm	
25/04/2024 00:00	32.73	Maintenance	94.31	0	28.2	DUST waiting for spare part
25/04/2024 01:00	47.7	Maintenance	96.2	0	38.3	DUST waiting for spare part
25/04/2024 02:00	47.86	Maintenance	94.87	0	38.6	DUST waiting for spare part
25/04/2024 03:00	47.87	Maintenance	95.21	0	38.5	DUST waiting for spare part
25/04/2024 04:00	48	Maintenance	95.24	0	38.7	DUST waiting for spare part
25/04/2024 05:00	47.96	Maintenance	95.47	0	38.8	DUST waiting for spare part
25/04/2024 06:00	47.97	Maintenance	95.56	0	38.5	DUST waiting for spare part
25/04/2024 07:00	38.02	Maintenance	94.73	0	36.7	DUST waiting for spare part
25/04/2024 08:00	34.06	Maintenance	94.89	0	21.2	DUST waiting for spare part
25/04/2024 09:00	34.21	Maintenance	95.34	0	20.5	DUST waiting for spare part
25/04/2024 10:00	34.29	Maintenance	95.75	0	20.7	DUST waiting for spare part
25/04/2024 11:00	34.27	Maintenance	96.11	0	21	DUST waiting for spare part
25/04/2024 12:00	21.43	Maintenance	93.25	0	47.3	DUST waiting for spare part
25/04/2024 13:00	34.4	Maintenance	95.37	0	22.3	DUST waiting for spare part
25/04/2024 14:00	34.31	Maintenance	95.52	0	20.5	DUST waiting for spare part
25/04/2024 15:00	34.3	Maintenance	95.27	0	20.3	DUST waiting for spare part
25/04/2024 16:00	34.02	Maintenance	94.85	0	20	DUST waiting for spare part
25/04/2024 17:00	33.69	Maintenance	94.56	0	19.7	DUST waiting for spare part
25/04/2024 18:00	33.6	Maintenance	94.23	0	19.6	DUST waiting for spare part
25/04/2024 19:00	33.55	Maintenance	94.07	0	19.3	DUST waiting for spare part
25/04/2024 20:00	33.76	Maintenance	94.23	0	19.2	DUST waiting for spare part
25/04/2024 21:00	33.86	Maintenance	94.36	0	19.2	DUST waiting for spare part
25/04/2024 22:00	33.86	Maintenance	94.46	0	19	DUST waiting for spare part
25/04/2024 23:00	33.84	Maintenance	94.7	0	18.9	DUST waiting for spare part
26/04/2024 00:00	25.08	Maintenance	93.67	0	27.7	DUST waiting for spare part
Minimum	21.43	---	93.25	0	18.9	DUST waiting for spare part
MinDate	25/04/2024 12:00	25/04/2024 00:00	25/04/2024 12:00	25/04/2024 00:00	25/04/2024 23:00	
Maximum	48	---	96.2	0	47.3	
MaxDate	25/04/2024 04:00	25/04/2024 00:00	25/04/2024 01:00	25/04/2024 00:00	25/04/2024 12:00	
Avg	35.59	---	94.89	0	26.9	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	7.2	---	0.7	0	9.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/04/2024 00:00	32.84	0	94.54	0.9	32.6	
26/04/2024 01:00	48.14	0	96.03	0.9	36.6	
26/04/2024 02:00	48.21	0	94.88	0.9	36.5	
26/04/2024 03:00	48.25	0	95.28	0.9	36.3	
26/04/2024 04:00	48.36	0	95.42	0.9	36.1	
26/04/2024 05:00	48.32	0	95.51	0.9	35.4	
26/04/2024 06:00	48.39	0.26	96.09	1	35.5	
26/04/2024 07:00	38.89	0	95.67	1	36.6	
26/04/2024 08:00	34.06	0	94.85	0.9	26.5	
26/04/2024 09:00	34.21	0	95.35	0.9	25.2	
26/04/2024 10:00	34.24	0	95.58	0.9	25.5	
26/04/2024 11:00	34.14	0	96.27	0.9	25.7	
26/04/2024 12:00	21.94	0	93.6	1	50.7	
26/04/2024 13:00	34.28	0	95.23	0.9	27.8	
26/04/2024 14:00	34.18	0	95.46	0.9	25.7	
26/04/2024 15:00	34.18	0	94.97	0.9	25.2	
26/04/2024 16:00	34.02	0	94.77	0.8	25.2	
26/04/2024 17:00	33.85	0	94.37	0.8	25	
26/04/2024 18:00	33.88	0	94.14	0.8	24.2	
26/04/2024 19:00	33.68	0	93.84	0.8	23.8	
26/04/2024 20:00	33.76	0	93.89	0.8	23.3	
26/04/2024 21:00	33.91	0	94.29	0.8	23.1	
26/04/2024 22:00	36.94	0	95.92	0.8	24.2	
26/04/2024 23:00	37.22	0	96.95	0.8	24.5	
27/04/2024 00:00	34.01	0	96.65	0.9	32.9	
Minimum	21.94	0	93.6	0.8	23.1	
MinDate	26/04/2024 12:00	26/04/2024 00:00	26/04/2024 12:00	26/04/2024 16:00	26/04/2024 21:00	
Maximum	48.39	0.26	96.95	1	50.7	
MaxDate	26/04/2024 06:00	26/04/2024 06:00	26/04/2024 23:00	26/04/2024 06:00	26/04/2024 12:00	
Avg	37.38	0.01	95.18	0.9	29.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.9	0.1	0.9	0.1	6.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/04/2024 00:00	25.08	Maintenance	93.67	0	27.7	DUST waiting for spare part
26/04/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
26/04/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
26/04/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
26/04/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
26/04/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
26/04/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
26/04/2024 07:00	11.1	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
26/04/2024 08:00	33.99	Maintenance	95.6	0	23.4	DUST waiting for spare part
26/04/2024 09:00	34.15	Maintenance	95.4	0	22.3	DUST waiting for spare part
26/04/2024 10:00	34.18	<Samp	95.52	0	22.5	DUST waiting for spare part
26/04/2024 11:00	34.09	<Samp	96.28	0	22.8	DUST waiting for spare part
26/04/2024 12:00	21.95	Maintenance	93.77	0	48.8	DUST waiting for spare part
26/04/2024 13:00	34.22	Maintenance	95.43	0	25.7	DUST waiting for spare part
26/04/2024 14:00	34.1	Maintenance	95.32	0	22.7	DUST waiting for spare part
26/04/2024 15:00	34.12	Audit	94.92	0	22.1	DUST waiting for spare part
26/04/2024 16:00	33.96	Maintenance	94.67	0	22.2	DUST waiting for spare part
26/04/2024 17:00	33.79	Maintenance	94.3	0	21.9	DUST waiting for spare part
26/04/2024 18:00	33.82	Maintenance	94.12	0	21.1	DUST waiting for spare part
26/04/2024 19:00	33.62	Audit	93.78	0	20.8	DUST waiting for spare part
26/04/2024 20:00	33.7	<Samp	93.85	0	20.4	DUST waiting for spare part
26/04/2024 21:00	33.85	<Samp	94.96	0	20.2	DUST waiting for spare part
26/04/2024 22:00	36.88	<Samp	95.65	0	21.5	DUST waiting for spare part
26/04/2024 23:00	37.66	Maintenance	96.7	0	21.7	DUST waiting for spare part
27/04/2024 00:00	33.93	Maintenance	95.36	0	29.9	DUST waiting for spare part
Minimum	0	---	93.67	0	20.2	
MinDate	26/04/2024 01:00	26/04/2024 00:00	26/04/2024 00:00	26/04/2024 00:00	26/04/2024 21:00	
Maximum	37.66	---	96.7	0	48.8	
MaxDate	26/04/2024 23:00	26/04/2024 00:00	26/04/2024 23:00	26/04/2024 00:00	26/04/2024 12:00	
Avg	24.33	---	94.97	0	24.3	
Num	25	0	18	18	18	
Data[%]	100	---	72	72	72	
STD	15	---	1	0	6.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/04/2024 00:00	34.01	0	96.65	0.9	32.9	
27/04/2024 01:00	28.37	0	93.4	0.9	40.2	
27/04/2024 02:00	28.33	0	93.19	0.9	39.7	
27/04/2024 03:00	28.29	0	93.19	0.9	39.9	
27/04/2024 04:00	28.08	0	93.17	0.9	40.6	
27/04/2024 05:00	27.92	0	93.2	1	41.1	
27/04/2024 06:00	27.74	0.19	93.38	1	41.5	
27/04/2024 07:00	27.51	0	93.52	1	41.5	
27/04/2024 08:00	41.28	0	98.86	1	26.2	
27/04/2024 09:00	41.26	0	100.24	1	25.9	
27/04/2024 10:00	41.17	0	100.58	1	25.9	
27/04/2024 11:00	41.18	0	101.05	1	25.9	
27/04/2024 12:00	27.39	0	95.81	1	39.9	
27/04/2024 13:00	41.24	0	99.39	1	26.8	
27/04/2024 14:00	41.26	0	100.4	1	25.8	
27/04/2024 15:00	41.25	0	100.06	0.9	25.9	
27/04/2024 16:00	41.24	0	99.65	0.9	25.7	
27/04/2024 17:00	41.22	0	99.29	0.9	25.8	
27/04/2024 18:00	41.19	0	98.92	0.9	25.5	
27/04/2024 19:00	41.19	0	98.62	0.8	25	
27/04/2024 20:00	41.2	0	98.85	0.8	24.8	
27/04/2024 21:00	41.2	0	99.08	0.8	24.7	
27/04/2024 22:00	41.12	0	99.17	0.8	24.5	
27/04/2024 23:00	41.04	0	99.11	0.9	24.2	
28/04/2024 00:00	34.01	0	96.89	0.9	31.3	
Minimum	27.39	0	93.17	0.8	24.2	
MinDate	27/04/2024 12:00	27/04/2024 00:00	27/04/2024 04:00	27/04/2024 19:00	27/04/2024 23:00	
Maximum	41.28	0.19	101.05	1	41.5	
MaxDate	27/04/2024 08:00	27/04/2024 06:00	27/04/2024 11:00	27/04/2024 05:00	27/04/2024 06:00	
Avg	36.39	0.01	97.43	0.9	30.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.2	0	2.9	0.1	7.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/04/2024 00:00	33.93	Maintenance	96.36	0	29.9	DUST waiting for spare part
27/04/2024 01:00	28.3	Maintenance	93.35	0	35.9	DUST waiting for spare part
27/04/2024 02:00	28.27	Maintenance	93.17	0	35.6	DUST waiting for spare part
27/04/2024 03:00	28.23	<Samp	93.16	0	35.5	DUST waiting for spare part
27/04/2024 04:00	28.03	0	93.1	0	36	DUST waiting for spare part
27/04/2024 05:00	27.86	<Samp	93.07	0	36.5	DUST waiting for spare part
27/04/2024 06:00	27.67	Audit	93.21	0	36.7	DUST waiting for spare part
27/04/2024 07:00	27.45	Maintenance	93.35	0	36.7	DUST waiting for spare part
27/04/2024 08:00	41.23	Maintenance	99.2	0	24.6	DUST waiting for spare part
27/04/2024 09:00	41.19	Maintenance	100.69	0	24.2	DUST waiting for spare part
27/04/2024 10:00	41.1	Maintenance	100.96	0	24.7	DUST waiting for spare part
27/04/2024 11:00	41.11	Maintenance	101.47	0	24.9	DUST waiting for spare part
27/04/2024 12:00	27.34	Maintenance	96.22	0	36.4	DUST waiting for spare part
27/04/2024 13:00	41.18	Maintenance	99.95	0	26.7	DUST waiting for spare part
27/04/2024 14:00	41.19	Maintenance	100.69	0	25.4	DUST waiting for spare part
27/04/2024 15:00	41.17	Maintenance	100.57	0	25.4	DUST waiting for spare part
27/04/2024 16:00	41.16	Maintenance	100.32	0	24.8	DUST waiting for spare part
27/04/2024 17:00	41.15	Maintenance	99.9	0	24.6	DUST waiting for spare part
27/04/2024 18:00	41.12	Maintenance	99.48	0	23.7	DUST waiting for spare part
27/04/2024 19:00	41.11	Maintenance	99.3	0	22.7	DUST waiting for spare part
27/04/2024 20:00	41.13	Maintenance	99.64	0	22.4	DUST waiting for spare part
27/04/2024 21:00	41.12	Maintenance	99.7	0	22.1	DUST waiting for spare part
27/04/2024 22:00	41.04	Maintenance	99.71	0	21.7	DUST waiting for spare part
27/04/2024 23:00	40.97	Maintenance	99.74	0	21.3	DUST waiting for spare part
28/04/2024 00:00	33.95	Maintenance	97.49	0	27.9	DUST waiting for spare part
Minimum	27.34	0	93.07	0	21.3	
MinDate	27/04/2024 12:00	27/04/2024 04:00	27/04/2024 05:00	27/04/2024 00:00	27/04/2024 23:00	
Maximum	41.23	0	101.47	0	36.7	
MaxDate	27/04/2024 08:00	27/04/2024 04:00	27/04/2024 11:00	27/04/2024 00:00	27/04/2024 06:00	
Avg	36.32	0	97.75	0	28.3	
Num	25	1	25	25	25	
Data[%]	100	4	100	100	100	
STD	6.2	---	3.1	0	5.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/04/2024 00:00	34.01	0	96.89	0.9	31.3	
28/04/2024 01:00	27.28	0	92.64	0.9	40.6	
28/04/2024 02:00	27.32	0	92.52	0.9	40.9	
28/04/2024 03:00	27.32	0	92.54	0.9	41.1	
28/04/2024 04:00	27.19	0	92.61	0.9	41.5	
28/04/2024 05:00	27.14	0	92.52	1	41.5	
28/04/2024 06:00	27.1	0.38	92.74	1	41.4	
28/04/2024 07:00	27.13	0	93.05	1	41.1	
28/04/2024 08:00	27.12	0	92.93	1	41.4	
28/04/2024 09:00	27.13	0	93.05	1	41.6	
28/04/2024 10:00	27.17	0	93.08	1	41.5	
28/04/2024 11:00	27.15	0	93.93	1	41.9	
28/04/2024 12:00	27.21	0	94.17	1	41.5	
28/04/2024 13:00	27.29	0	93.33	1	40.8	
28/04/2024 14:00	27.3	0	92.86	0.9	39.5	
28/04/2024 15:00	27.34	0	92.64	0.9	39.8	
28/04/2024 16:00	27.32	0	92.47	0.9	39.5	
28/04/2024 17:00	27.33	0	92.33	0.9	39.8	
28/04/2024 18:00	41.07	0	97.54	0.9	24.8	
28/04/2024 19:00	40.98	0	98.79	0.9	23.7	
28/04/2024 20:00	41.01	0	98.84	0.8	23.5	
28/04/2024 21:00	41.02	0	99.26	0.8	23.5	
28/04/2024 22:00	41.06	0	99.3	0.9	23.4	
28/04/2024 23:00	33.9	0	97.15	0.9	30.7	
29/04/2024 00:00	27.21	0	92.62	0.9	39.5	
Minimum	27.1	0	92.33	0.8	23.4	
MinDate	28/04/2024 06:00	28/04/2024 00:00	28/04/2024 17:00	28/04/2024 20:00	28/04/2024 22:00	
Maximum	41.07	0.38	99.3	1	41.5	
MaxDate	28/04/2024 18:00	28/04/2024 06:00	28/04/2024 22:00	28/04/2024 05:00	28/04/2024 11:00	
Avg	30.52	0.02	94.39	0.9	36.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	5.7	0.1	2.5	0.1	7.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/04/2024 00:00	33.95	Maintenance	97.49	0	27.9	DUST waiting for spare part
28/04/2024 01:00	27.21	Maintenance	93.27	0	35.8	DUST waiting for spare part
28/04/2024 02:00	27.26	Audit	92.83	0	36.3	DUST waiting for spare part
28/04/2024 03:00	27.26	<Samp	92.84	0	36.6	DUST waiting for spare part
28/04/2024 04:00	27.13	<Samp	92.85	0	36.9	DUST waiting for spare part
28/04/2024 05:00	27.09	<Samp	92.75	0	36.9	DUST waiting for spare part
28/04/2024 06:00	27.04	<Samp	92.94	0	36.9	DUST waiting for spare part
28/04/2024 07:00	27.07	<Samp	93.23	0	36.6	DUST waiting for spare part
28/04/2024 08:00	27.07	<Samp	93.26	0	37.3	DUST waiting for spare part
28/04/2024 09:00	27.08	Audit	93.26	0	37.7	DUST waiting for spare part
28/04/2024 10:00	27.11	<Samp	93.31	0	37.9	DUST waiting for spare part
28/04/2024 11:00	27.09	<Samp	94.2	0	38.5	DUST waiting for spare part
28/04/2024 12:00	27.16	Maintenance	94.42	0	38.2	DUST waiting for spare part
28/04/2024 13:00	27.23	Maintenance	93.56	0	37.9	DUST waiting for spare part
28/04/2024 14:00	27.23	<Samp	93.11	0	36.4	DUST waiting for spare part
28/04/2024 15:00	27.28	<Samp	93.02	0	36.5	DUST waiting for spare part
28/04/2024 16:00	27.26	<Samp	92.94	0	36.2	DUST waiting for spare part
28/04/2024 17:00	27.27	<Samp	92.66	0	36.2	DUST waiting for spare part
28/04/2024 18:00	41	Maintenance	97.94	0	22.9	DUST waiting for spare part
28/04/2024 19:00	40.91	Maintenance	99.09	0	21	DUST waiting for spare part
28/04/2024 20:00	40.94	Maintenance	99.13	0	20.7	DUST waiting for spare part
28/04/2024 21:00	40.94	Maintenance	99.43	0	20.6	DUST waiting for spare part
28/04/2024 22:00	40.98	Maintenance	99.45	0	20.5	DUST waiting for spare part
28/04/2024 23:00	33.86	Maintenance	97.29	0	27.5	DUST waiting for spare part
29/04/2024 00:00	27.15	Maintenance	93.2	0	35	DUST waiting for spare part
Minimum	27.04		92.66	0	20.5	
MinDate	28/04/2024 06:00	28/04/2024 00:00	28/04/2024 17:00	28/04/2024 00:00	28/04/2024 22:00	
Maximum	41	---	99.45	0	38.5	
MaxDate	28/04/2024 18:00	28/04/2024 00:00	28/04/2024 22:00	28/04/2024 00:00	28/04/2024 11:00	
Avg	30.46		94.7	0	31	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	5.7	---	2.5	0	6.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/04/2024 00:00	27.21	0	92.62	0.9	39.5	
29/04/2024 01:00	27.23	0	92.5	0.9	39.2	
29/04/2024 02:00	27.27	0	92.62	1	39	
29/04/2024 03:00	27.25	0	92.57	1	38.8	
29/04/2024 04:00	27.21	0	92.67	1	39.1	
29/04/2024 05:00	27.24	0	92.66	1	39.3	
29/04/2024 06:00	27.25	0.3	92.84	1	39.5	
29/04/2024 07:00	27.48	0	93.05	1	38.7	
29/04/2024 08:00	40.71	0	98.86	1	23.5	
29/04/2024 09:00	34.12	0	95.72	0.9	21.3	
29/04/2024 10:00	34.16	0	95.51	1	21.6	
29/04/2024 11:00	34.24	0	96.42	1	21.6	
29/04/2024 12:00	21.98	0	93.92	1.1	45.5	
29/04/2024 13:00	34.49	0	95.43	1	22.5	
29/04/2024 14:00	34.43	0	95.71	1	21.4	
29/04/2024 15:00	34.44	0	95.29	0.9	21.4	
29/04/2024 16:00	34.3	0	95.03	0.9	21.4	
29/04/2024 17:00	34.09	0	94.5	0.9	21.2	
29/04/2024 18:00	33.98	0	94.16	0.8	21.1	
29/04/2024 19:00	33.91	0	94.01	0.8	20.8	
29/04/2024 20:00	34.03	0	94.18	0.8	20.6	
29/04/2024 21:00	34.24	0	94.65	0.8	20.5	
29/04/2024 22:00	34.25	0	94.93	0.8	20.5	
29/04/2024 23:00	34.15	0	94.71	0.8	20.5	
30/04/2024 00:00	24.81	0	93.75	0.9	28.8	
Minimum	21.98	0	92.5	0.8	20.5	
MinDate	29/04/2024 12:00	29/04/2024 00:00	29/04/2024 01:00	29/04/2024 18:00	29/04/2024 21:00	
Maximum	40.71	0.3	98.86	1.1	45.5	
MaxDate	29/04/2024 08:00	29/04/2024 06:00	29/04/2024 08:00	29/04/2024 12:00	29/04/2024 12:00	
Avg	31.38	0.01	94.33	0.9	28.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.4	0.1	1.5	0.1	9.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/04/2024 00:00	27.15	Maintenance	93.2	0	35	DUST waiting for spare part
29/04/2024 01:00	27.17	Maintenance	92.98	0	34.8	DUST waiting for spare part
29/04/2024 02:00	27.22	Maintenance	93.07	0	34.6	DUST waiting for spare part
29/04/2024 03:00	27.2	<Samp	92.95	0	34.5	DUST waiting for spare part
29/04/2024 04:00	27.16	<Samp	92.97	0	34.7	DUST waiting for spare part
29/04/2024 05:00	27.18	0	93	0	35	DUST waiting for spare part
29/04/2024 06:00	27.2	<Samp	93.07	0	35	DUST waiting for spare part
29/04/2024 07:00	27.42	<Samp	93.39	0	34.5	DUST waiting for spare part
29/04/2024 08:00	40.63	<Samp	99.27	0	22.1	DUST waiting for spare part
29/04/2024 09:00	34.06	<Samp	95.09	0	17.3	DUST waiting for spare part
29/04/2024 10:00	34.1	Maintenance	95.79	0	17.7	DUST waiting for spare part
29/04/2024 11:00	34.17	Maintenance	96.63	0	17.9	DUST waiting for spare part
29/04/2024 12:00	21.9	Maintenance	94.18	0	44.9	DUST waiting for spare part
29/04/2024 13:00	34.4	Maintenance	95.64	0	19.1	DUST waiting for spare part
29/04/2024 14:00	34.36	Maintenance	95.87	0	17.7	DUST waiting for spare part
29/04/2024 15:00	34.38	Maintenance	95.6	0	17.4	DUST waiting for spare part
29/04/2024 16:00	34.24	Maintenance	95.49	0	17.2	DUST waiting for spare part
29/04/2024 17:00	34.03	Maintenance	95.08	0	16.9	DUST waiting for spare part
29/04/2024 18:00	33.91	Maintenance	94.64	0	16.6	DUST waiting for spare part
29/04/2024 19:00	33.84	Maintenance	94.42	0	16.3	DUST waiting for spare part
29/04/2024 20:00	33.96	Maintenance	94.56	0	16.1	DUST waiting for spare part
29/04/2024 21:00	34.18	Maintenance	94.95	0	16	DUST waiting for spare part
29/04/2024 22:00	34.19	<Samp	95.23	0	16	DUST waiting for spare part
29/04/2024 23:00	34.09	<Samp	95.14	0	15.8	DUST waiting for spare part
30/04/2024 00:00	33.11	Maintenance	94.68	0	24.2	DUST waiting for spare part
Minimum	21.9	0	92.95	0	15.8	
MinDate	29/04/2024 12:00	29/04/2024 05:00	29/04/2024 03:00	29/04/2024 00:00	29/04/2024 23:00	
Maximum	40.63	0	99.27	0	44.9	
MaxDate	29/04/2024 08:00	29/04/2024 05:00	29/04/2024 08:00	29/04/2024 00:00	29/04/2024 12:00	
Avg	31.65	0	94.71	0	24.3	
Num	25	1	25	25	25	
Data[%]	100	4	100	100	100	
STD	4.2	---	1.5	0	9.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
30/04/2024 00:00	24.81	0	93.75	0.9	28.8	
30/04/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
30/04/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
30/04/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
30/04/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
30/04/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
30/04/2024 06:00	0	0.23	ShutDown	ShutDown	ShutDown	GT11 SD
30/04/2024 07:00	3.64	0.05	ShutDown	ShutDown	ShutDown	GT11 SD
30/04/2024 08:00	32.26	0	97	1	33.2	
30/04/2024 09:00	34.41	0	96.22	1	27.5	
30/04/2024 10:00	34.38	0	96.5	1	27.7	
30/04/2024 11:00	34.3	0	96.81	1	27.9	
30/04/2024 12:00	22.08	0	93.38	1.1	47.8	
30/04/2024 13:00	34.51	0	95.77	1	29.5	
30/04/2024 14:00	34.43	0	96.03	1	27.8	
30/04/2024 15:00	34.42	0	95.64	1	27.8	
30/04/2024 16:00	34.28	0	95.33	1	27.6	
30/04/2024 17:00	33.99	0	94.8	0.9	26.7	
30/04/2024 18:00	33.92	0	94.47	0.9	26.2	
30/04/2024 19:00	33.77	0	94.16	0.9	25.8	
30/04/2024 20:00	34.01	0	94.32	0.9	25.6	
30/04/2024 21:00	34.06	0	94.59	0.9	25.6	
30/04/2024 22:00	34.19	0	94.86	0.9	25.5	
30/04/2024 23:00	34.09	0	94.9	0.9	25.4	
01/05/2024 00:00	8.28	0	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	0	0	93.38	0.9	25.4	
MinDate	30/04/2024 01:00	30/04/2024 00:00	30/04/2024 12:00	30/04/2024 00:00	30/04/2024 23:00	
Maximum	34.51	0.23	97	1.1	47.8	
MaxDate	30/04/2024 13:00	30/04/2024 06:00	30/04/2024 08:00	30/04/2024 12:00	30/04/2024 12:00	
Avg	22.79	0.01	95.21	1	28.6	
Num	25	25	17	17	17	
Data[%]	100	100	68	68	68	
STD	15.3	0	1.1	0.1	5.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
30/04/2024 00:00	33.11	Maintenance	94.68	0	24.2	DUST waiting for spare part
30/04/2024 01:00	47.71	<Samp	96.18	0	31.4	DUST waiting for spare part
30/04/2024 02:00	47.84	Maintenance	94.97	0	31.4	DUST waiting for spare part
30/04/2024 03:00	47.89	<Samp	94.77	0	31.5	DUST waiting for spare part
30/04/2024 04:00	47.94	Maintenance	94.95	0	31.5	DUST waiting for spare part
30/04/2024 05:00	47.92	Maintenance	95.11	0	31.4	DUST waiting for spare part
30/04/2024 06:00	47.84	Maintenance	95.47	0	31.3	DUST waiting for spare part
30/04/2024 07:00	45.1	Maintenance	96.41	0	28.7	DUST waiting for spare part
30/04/2024 08:00	32.19	Maintenance	95.64	0	22.3	DUST waiting for spare part
30/04/2024 09:00	34.35	Maintenance	95.7	0	16	DUST waiting for spare part
30/04/2024 10:00	34.32	Audit	95.93	0	16.2	DUST waiting for spare part
30/04/2024 11:00	34.24	Maintenance	96.34	0	16.3	DUST waiting for spare part
30/04/2024 12:00	22.03	Maintenance	93.01	0	40.7	DUST waiting for spare part
30/04/2024 13:00	34.42	Maintenance	95.61	0	18.1	DUST waiting for spare part
30/04/2024 14:00	34.37	Maintenance	95.81	0	16.2	DUST waiting for spare part
30/04/2024 15:00	34.36	Maintenance	95.65	0	16.2	DUST waiting for spare part
30/04/2024 16:00	34.22	Maintenance	95.43	0	16	DUST waiting for spare part
30/04/2024 17:00	33.93	Maintenance	94.84	0	15.5	DUST waiting for spare part
30/04/2024 18:00	33.86	Maintenance	94.53	0	15.3	DUST waiting for spare part
30/04/2024 19:00	33.71	<Samp	94.2	0	15.2	DUST waiting for spare part
30/04/2024 20:00	33.95	Maintenance	94.37	0	15.2	DUST waiting for spare part
30/04/2024 21:00	34.01	Maintenance	94.5	0	15.2	DUST waiting for spare part
30/04/2024 22:00	34.12	Maintenance	94.75	0	15.2	DUST waiting for spare part
30/04/2024 23:00	34.03	Maintenance	94.88	0	15.2	DUST waiting for spare part
01/05/2024 00:00	39.53	Maintenance	95.51	0	30.5	DUST waiting for spare part
Minimum	22.03	---	93.01	0	15.2	
MinDate	30/04/2024 12:00	30/04/2024 00:00	30/04/2024 12:00	30/04/2024 00:00	30/04/2024 19:00	
Maximum	47.94	---	96.41	0	40.7	
MaxDate	30/04/2024 04:00	30/04/2024 00:00	30/04/2024 07:00	30/04/2024 00:00	30/04/2024 12:00	
Avg	37.48	---	95.17	0	22.3	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	6.9	---	0.8	0	8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
01/05/2024 00:00	8.28	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 06:00	0	0.17	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 08:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 09:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 10:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 11:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 12:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 13:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 14:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 15:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 16:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 17:00	1.86	0.1	ShutDown	ShutDown	ShutDown	GT11 SD
01/05/2024 18:00	28.45	0	92.69	1.1	40.4	
01/05/2024 19:00	32.61	0	93.7	1	26.8	
01/05/2024 20:00	32.6	0	93.81	1	27.2	
01/05/2024 21:00	32.57	0	94.09	1.1	27.4	
01/05/2024 22:00	31.64	0	93.94	1.1	33.3	
01/05/2024 23:00	46.1	0	96.55	1.1	32	
02/05/2024 00:00	46.26	0	95.35	1.1	32.1	
Minimum	0	0	92.69	1	26.8	
MinDate	01/05/2024 01:00	01/05/2024 00:00	01/05/2024 18:00	01/05/2024 19:00	01/05/2024 19:00	
Maximum	46.26	0.17	96.55	1.1	40.4	
MaxDate	02/05/2024 00:00	01/05/2024 06:00	01/05/2024 23:00	01/05/2024 18:00	01/05/2024 18:00	
Avg	10.41	0.01	94.3	1.1	31.3	
Num	25	25	7	7	7	
Data[%]	100	100	28	28	28	
STD	16.6	0	1.3	0	4.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
01/05/2024 00:00	39.53	Maintenance	95.51	0	30.5	DUST waiting for spare part
01/05/2024 01:00	47.47	Maintenance	95.02	0	30.2	DUST waiting for spare part
01/05/2024 02:00	47.56	Maintenance	94.77	0	30.1	DUST waiting for spare part
01/05/2024 03:00	47.57	Maintenance	94.89	0	30	DUST waiting for spare part
01/05/2024 04:00	47.56	Maintenance	94.84	0	30	DUST waiting for spare part
01/05/2024 05:00	47.62	Maintenance	94.98	0	29.9	DUST waiting for spare part
01/05/2024 06:00	47.71	Maintenance	95.14	0	29.8	DUST waiting for spare part
01/05/2024 07:00	47.4	Maintenance	95.08	0	29.2	DUST waiting for spare part
01/05/2024 08:00	46.32	Maintenance	95.05	0	26.8	DUST waiting for spare part
01/05/2024 09:00	45.85	Maintenance	94.89	0	27.8	DUST waiting for spare part
01/05/2024 10:00	45.55	Maintenance	94.55	0	29.6	DUST waiting for spare part
01/05/2024 11:00	45.27	<Samp	94.68	0	30.2	DUST waiting for spare part
01/05/2024 12:00	45.11	Maintenance	94.76	0	29.9	DUST waiting for spare part
01/05/2024 13:00	44.93	<Samp	94.48	0	29.9	DUST waiting for spare part
01/05/2024 14:00	44.96	Audit	94.36	0	29.7	DUST waiting for spare part
01/05/2024 15:00	45.05	<Samp	94.16	0	29.5	DUST waiting for spare part
01/05/2024 16:00	45.22	<Samp	94.55	0	29.9	DUST waiting for spare part
01/05/2024 17:00	44.4	Audit	94.61	0	26.1	DUST waiting for spare part
01/05/2024 18:00	29.76	Maintenance	92.53	0	24.9	DUST waiting for spare part
01/05/2024 19:00	32.54	Maintenance	93.43	0	14.6	DUST waiting for spare part
01/05/2024 20:00	32.53	Maintenance	93.6	0	14.8	DUST waiting for spare part
01/05/2024 21:00	32.5	Maintenance	93.81	0	14.9	DUST waiting for spare part
01/05/2024 22:00	24.32	Maintenance	93.32	0	22.8	DUST waiting for spare part
01/05/2024 23:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
02/05/2024 00:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
Minimum	0	---	92.53	0	14.6	
MinDate	01/05/2024 23:00	01/05/2024 00:00	01/05/2024 18:00	01/05/2024 00:00	01/05/2024 19:00	
Maximum	47.71	---	95.51	0	30.5	
MaxDate	01/05/2024 06:00	01/05/2024 00:00	01/05/2024 00:00	01/05/2024 00:00	01/05/2024 00:00	
Avg	39.07	---	94.48	0	27	
Num	25	0	23	23	23	
Data[%]	100	---	92	92	92	
STD	13.5	---	0.7	0	5.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/05/2024 00:00	46.26	0	95.35	1.1	32.1	
02/05/2024 01:00	46.29	0	95.28	1.1	32	
02/05/2024 02:00	46.28	0	95.37	1.2	32	
02/05/2024 03:00	46.29	0	95.44	1.2	31.7	
02/05/2024 04:00	46.31	0	95.57	1.2	31.5	
02/05/2024 05:00	46.38	0	95.55	1.2	31.9	
02/05/2024 06:00	46.5	0.38	95.73	1.2	32	
02/05/2024 07:00	46.89	0	95.91	1.2	33.9	
02/05/2024 08:00	44.09	0	95.66	1.2	35.4	
02/05/2024 09:00	32.05	0	94.46	1.2	33.2	
02/05/2024 10:00	34.17	0	95.29	1.2	26.3	
02/05/2024 11:00	34.24	0	95.64	1.2	26.5	
02/05/2024 12:00	24.68	0	93.68	1.2	43	
02/05/2024 13:00	31.2	0	94.08	1.2	34.3	
02/05/2024 14:00	34.16	0	95.33	1.1	27.1	
02/05/2024 15:00	34.3	0	94.93	1.1	26.9	
02/05/2024 16:00	34.14	0	94.65	1.1	26.4	
02/05/2024 17:00	33.99	0	94.39	1.1	26.3	
02/05/2024 18:00	33.9	0	94.02	1	25.6	
02/05/2024 19:00	33.84	0	94.09	1	24.9	
02/05/2024 20:00	34.02	0	94.18	1	24.7	
02/05/2024 21:00	34.08	0	94.51	1	24.6	
02/05/2024 22:00	34.06	0	94.62	1	24.5	
02/05/2024 23:00	34	0	94.71	1	24.5	
03/05/2024 00:00	39.82	0	95.44	1.1	36.7	
Minimum	24.68	0	93.68	1	24.5	
MinDate	02/05/2024 12:00	02/05/2024 00:00	02/05/2024 12:00	02/05/2024 18:00	02/05/2024 22:00	
Maximum	46.89	0.38	95.91	1.2	43	
MaxDate	02/05/2024 07:00	02/05/2024 06:00	02/05/2024 07:00	02/05/2024 02:00	02/05/2024 12:00	
Avg	38.08	0.02	94.96	1.1	29.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.6	0.1	0.6	0.1	4.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/05/2024 00:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 07:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 08:00	4.78	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
02/05/2024 09:00	31.98	<Samp	96.61	0	29	DUST waiting for spare part
02/05/2024 10:00	34.11	Audit	95.75	0	22.7	DUST waiting for spare part
02/05/2024 11:00	34.18	Maintenance	95.99	0	22.7	DUST waiting for spare part
02/05/2024 12:00	24.29	Maintenance	93.99	0	41.5	DUST waiting for spare part
02/05/2024 13:00	30.89	Maintenance	94.52	0	32.1	DUST waiting for spare part
02/05/2024 14:00	34.1	Maintenance	95.56	0	22.7	DUST waiting for spare part
02/05/2024 15:00	34.24	Maintenance	95.26	0	22.7	DUST waiting for spare part
02/05/2024 16:00	34.07	Maintenance	95.68	0	22.1	DUST waiting for spare part
02/05/2024 17:00	33.92	Maintenance	94.66	0	22	DUST waiting for spare part
02/05/2024 18:00	33.83	Audit	94.56	0	21.3	DUST waiting for spare part
02/05/2024 19:00	33.78	0.08	94.38	0	20.7	
02/05/2024 20:00	33.95	0.05	94.47	0	20.5	
02/05/2024 21:00	34.01	0.04	94.66	0	20.4	
02/05/2024 22:00	34	0.01	94.72	0	20.4	
02/05/2024 23:00	33.94	0	94.85	0	20.4	
03/05/2024 00:00	8.32	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	0	93.99	0	20.4	
MinDate	02/05/2024 00:00	02/05/2024 23:00	02/05/2024 12:00	02/05/2024 09:00	02/05/2024 21:00	
Maximum	34.24	0.08	96.61	0	41.5	
MaxDate	02/05/2024 15:00	02/05/2024 19:00	02/05/2024 09:00	02/05/2024 09:00	02/05/2024 12:00	
Num	20.34	0.03	95	0	24.1	
Avg	25	6	15	15	15	
Data[%]	100	24	60	60	60	
STD	16.1	0	0.7	0	5.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/05/2024 00:00	39.82	0	95.44	1.1	36.7	
03/05/2024 01:00	47.98	0	95.15	1.1	35.1	
03/05/2024 02:00	48.03	0	95.04	1.1	34.8	
03/05/2024 03:00	48.07	0	95.18	1.1	34.5	
03/05/2024 04:00	48.18	0	95.27	1.1	34.5	
03/05/2024 05:00	48.21	0	95.35	1.1	34.5	
03/05/2024 06:00	48.17	0.32	95.33	1.1	34.4	
03/05/2024 07:00	47.73	0	95.69	1.2	34.3	
03/05/2024 08:00	41.34	0	95.76	1.2	35.2	
03/05/2024 09:00	32.31	0	95.13	1.2	31.3	
03/05/2024 10:00	34.49	0	95.99	1.2	25.3	
03/05/2024 11:00	34.51	0	96.52	1.2	25.4	
03/05/2024 12:00	24.7	0	93.98	1.3	42.9	
03/05/2024 13:00	31.31	0	94.35	1.2	32.7	
03/05/2024 14:00	34.53	0	95.73	1.1	25	
03/05/2024 15:00	34.47	0	95.43	1.1	24.9	
03/05/2024 16:00	34.36	0	95.29	1.1	24.9	
03/05/2024 17:00	34.16	0	94.95	1.1	24.6	
03/05/2024 18:00	34.1	0	94.63	1.1	24.3	
03/05/2024 19:00	33.97	0	94.36	1	23.6	
03/05/2024 20:00	33.99	0	94.42	1	23.3	
03/05/2024 21:00	34.15	0	94.76	1	23.1	
03/05/2024 22:00	36.73	0	96.05	1.1	23.9	
03/05/2024 23:00	38.11	0	97.44	1.1	24.6	
04/05/2024 00:00	26.26	0	93.64	1.1	41.3	
Minimum	24.7	0	93.64	1	23.1	
MinDate	03/05/2024 12:00	03/05/2024 00:00	04/05/2024 00:00	03/05/2024 19:00	03/05/2024 21:00	
Maximum	48.21	0.32	97.44	1.3	42.9	
MaxDate	03/05/2024 05:00	03/05/2024 06:00	03/05/2024 23:00	03/05/2024 12:00	03/05/2024 12:00	
Avg	37.99	0.01	95.24	1.1	30.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.2	0.1	0.8	0.1	6.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/05/2024 00:00	8.32	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 02:00	0	0.01	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 03:00	0	0.04	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 04:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 05:00	0	0.06	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 06:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 07:00	0	0.07	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 08:00	8.11	0.14	ShutDown	ShutDown	ShutDown	GT12 S/D
03/05/2024 09:00	32.25	0.24	95.95	0	28.5	
03/05/2024 10:00	34.42	0.26	95.91	0	23.1	
03/05/2024 11:00	34.44	0.25	96.41	0	23.2	
03/05/2024 12:00	24.52	0.29	93.98	0	41.3	
03/05/2024 13:00	31.19	0.27	94.53	0	35.5	
03/05/2024 14:00	34.46	0.23	95.74	0	22.2	
03/05/2024 15:00	34.41	0.2	95.54	0	22	
03/05/2024 16:00	34.29	0.18	95.37	0	22	
03/05/2024 17:00	34.09	0.14	95.09	0	21.6	
03/05/2024 18:00	34.04	0.36	94.74	0	21.3	
03/05/2024 19:00	33.91	0.04	94.42	0	20.6	
03/05/2024 20:00	33.93	0	94.48	0	20.5	
03/05/2024 21:00	34.09	0	94.7	0	20.2	
03/05/2024 22:00	36.66	0	96	0	21.3	
03/05/2024 23:00	38.04	0	97.39	0	21.9	
04/05/2024 00:00	26.21	0	93.64	0	37.7	
Minimum	0	0	93.64	0	20.2	
MinDate	03/05/2024 01:00	03/05/2024 01:00	04/05/2024 00:00	03/05/2024 09:00	03/05/2024 21:00	
Maximum	38.04	0.36	97.39	0	41.3	
MaxDate	03/05/2024 23:00	03/05/2024 18:00	03/05/2024 23:00	03/05/2024 09:00	03/05/2024 12:00	
Avg	21.9	0.12	95.24	0	24.9	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.7	0.1	1	0	6.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/05/2024 00:00	26.26	0	93.64	1.1	41.3	
04/05/2024 01:00	28.7	0	93.34	1.1	38.7	
04/05/2024 02:00	28.92	0	93.57	1.2	37.8	
04/05/2024 03:00	28.62	0	93.45	1.2	38.2	
04/05/2024 04:00	28.77	0	93.41	1.2	38.3	
04/05/2024 05:00	28.69	0	93.56	1.2	38.7	
04/05/2024 06:00	28.68	0.26	93.59	1.2	38.7	
04/05/2024 07:00	28.59	0	93.77	1.2	38.4	
04/05/2024 08:00	28.71	0	93.85	1.2	37.5	
04/05/2024 09:00	39.44	0	98.34	1.2	29.4	
04/05/2024 10:00	42.95	0	102.03	1.2	26.1	
04/05/2024 11:00	43.06	0	101.41	1.2	26.1	
04/05/2024 12:00	32.4	0	97.62	1.2	33.2	
04/05/2024 13:00	39.5	0	97.96	1.2	29.3	
04/05/2024 14:00	43	0	100.97	1.2	25.6	
04/05/2024 15:00	43.02	0	101.63	1.2	25.3	
04/05/2024 16:00	42.91	0	101.32	1.2	25.5	
04/05/2024 17:00	42.77	0	100.9	1.2	25.8	
04/05/2024 18:00	42.61	0	100.38	1.2	25.5	
04/05/2024 19:00	42.37	0	100.08	1.1	24.9	
04/05/2024 20:00	42.63	0	100.11	1.1	24.8	
04/05/2024 21:00	42.81	0	100.63	1.1	24.9	
04/05/2024 22:00	42.88	0	100.92	1.2	24.9	
04/05/2024 23:00	42.78	0	100.9	1.2	24.7	
05/05/2024 00:00	28.77	0	94.81	1.2	35.5	
Minimum	26.26	0	93.34	1.1	24.7	
MinDate	04/05/2024 00:00	04/05/2024 00:00	04/05/2024 01:00	04/05/2024 00:00	04/05/2024 23:00	
Maximum	43.06	0.26	102.41	1.2	41.3	
MaxDate	04/05/2024 11:00	04/05/2024 06:00	04/05/2024 11:00	04/05/2024 02:00	04/05/2024 00:00	
Avg	36.4	0.01	97.73	1.2	31.2	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	7	0.1	3.5	0	6.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/05/2024 00:00	26.21	0	93.64	0	37.7	
04/05/2024 01:00	28.64	0.01	93.32	0	34.4	
04/05/2024 02:00	28.86	0.04	93.45	0	33.7	
04/05/2024 03:00	28.76	0.05	93.33	0	34	
04/05/2024 04:00	28.71	0.05	93.26	0	34.1	
04/05/2024 05:00	28.63	0.06	93.51	0	34.4	
04/05/2024 06:00	28.62	0.11	93.47	0	34.3	
04/05/2024 07:00	28.53	0.13	93.55	0	34	
04/05/2024 08:00	28.65	0.13	93.81	0	33.4	
04/05/2024 09:00	39.34	0.22	98.34	0	28.7	
04/05/2024 10:00	42.87	0.3	101.87	0	26.7	
04/05/2024 11:00	42.98	0.26	102.22	0	27.2	
04/05/2024 12:00	32.31	0.19	97.37	0	31.2	
04/05/2024 13:00	39.44	0.16	97.87	0	28.5	
04/05/2024 14:00	42.92	0.11	100.63	0	25.2	
04/05/2024 15:00	42.95	0.17	101.41	0	25.9	
04/05/2024 16:00	42.84	0.11	101.19	0	26.1	
04/05/2024 17:00	42.7	0.1	100.85	0	26.1	
04/05/2024 18:00	42.54	0.29	100.21	0	25.1	
04/05/2024 19:00	42.3	0.06	99.87	0	24	
04/05/2024 20:00	42.56	0.03	99.93	0	24	
04/05/2024 21:00	42.74	0.02	100.27	0	24.2	
04/05/2024 22:00	42.8	0.04	100.55	0	24.2	
04/05/2024 23:00	42.7	0.04	100.56	0	23.7	
05/05/2024 00:00	28.72	0.05	94.58	0	31.9	
Minimum	26.21	0	93.26	0	23.7	
MinDate	04/05/2024 00:00	04/05/2024 00:00	04/05/2024 04:00	04/05/2024 00:00	04/05/2024 23:00	
Maximum	42.98	0.3	102.22	0	37.7	
MaxDate	04/05/2024 11:00	04/05/2024 10:00	04/05/2024 11:00	04/05/2024 00:00	04/05/2024 00:00	
Avg	36.33	0.11	97.56	0	29.3	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	6.9	0.1	3.5	0	4.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/05/2024 00:00	28.77	0	94.81	1.2	35.5	
05/05/2024 01:00	28.9	0	93.32	1.2	35.7	
05/05/2024 02:00	28.82	0	93.37	1.2	35.8	
05/05/2024 03:00	28.65	0	93.34	1.2	36.2	
05/05/2024 04:00	28.33	0	93.45	1.2	37.2	
05/05/2024 05:00	28.09	0	93.34	1.2	37.9	
05/05/2024 06:00	27.83	0.19	93.34	1.3	38.4	
05/05/2024 07:00	27.6	0	93.41	1.2	38.5	
05/05/2024 08:00	27.54	0	93.42	1.2	38.7	
05/05/2024 09:00	27.55	0	93.79	1.2	38.9	
05/05/2024 10:00	27.53	0	93.87	1.2	38.9	
05/05/2024 11:00	27.49	0	94.22	1.3	39.8	
05/05/2024 12:00	27.51	0	93.92	1.3	39.3	
05/05/2024 13:00	27.6	0	93.33	1.2	39.3	
05/05/2024 14:00	27.47	0	92.93	1.2	39.6	
05/05/2024 15:00	27.5	0	92.67	1.2	38.9	
05/05/2024 16:00	27.54	0	92.82	1.2	37.7	
05/05/2024 17:00	27.58	0	92.92	1.2	36.8	
05/05/2024 18:00	34.51	0	94.99	1.2	39.9	
05/05/2024 19:00	41.37	0	99.51	1.1	23.2	
05/05/2024 20:00	41.32	0	99.51	1.1	23	
05/05/2024 21:00	41.3	0	99.89	1.1	23	
05/05/2024 22:00	34.29	0	97.65	1.1	29.4	
05/05/2024 23:00	27.47	0	93.15	1.2	37.7	
06/05/2024 00:00	27.46	0	93.13	1.2	37.8	
Minimum	27.46	0	92.67	1.1	23	
MinDate	06/05/2024 00:00	05/05/2024 00:00	05/05/2024 15:00	05/05/2024 19:00	05/05/2024 20:00	
Maximum	41.37	0.19	99.89	1.3	39.8	
MaxDate	05/05/2024 19:00	05/05/2024 06:00	05/05/2024 21:00	05/05/2024 06:00	05/05/2024 11:00	
Avg	30	0.01	94.4	1.2	35.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.7	0	2.2	0.1	5.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/05/2024 00:00	28.72	0.05	94.58	0	31.9	
05/05/2024 01:00	28.84	0.08	93.32	0	31.9	
05/05/2024 02:00	28.76	0.1	93.27	0	32	
05/05/2024 03:00	28.59	0.1	93.26	0	32.4	
05/05/2024 04:00	28.28	0.13	93.34	0	33	
05/05/2024 05:00	28.03	0.12	93.24	0	33.2	
05/05/2024 06:00	27.77	0.15	93.28	0	33.7	
05/05/2024 07:00	27.54	0.17	93.32	0	33.9	
05/05/2024 08:00	27.48	0.19	93.38	0	34	
05/05/2024 09:00	27.53	0.23	93.68	0	34.3	
05/05/2024 10:00	27.48	0.27	93.77	0	34.5	
05/05/2024 11:00	27.44	0.36	94.12	0	35.8	
05/05/2024 12:00	27.45	0.37	93.75	0	35.4	
05/05/2024 13:00	27.55	0.23	93.06	0	35.4	
05/05/2024 14:00	27.42	0.14	92.78	0	35.6	
05/05/2024 15:00	27.45	0.18	92.63	0	35.1	
05/05/2024 16:00	27.48	0.14	92.72	0	33.8	
05/05/2024 17:00	27.51	0.13	92.67	0	32.8	
05/05/2024 18:00	34.45	0.26	95.05	0	28.1	
05/05/2024 19:00	41.3	0.06	99.31	0	21.2	
05/05/2024 20:00	41.26	0.04	99.38	0	20.7	
05/05/2024 21:00	41.22	0.03	99.62	0	20.6	
05/05/2024 22:00	34.23	0.04	97.42	0	26.2	
05/05/2024 23:00	27.42	0.05	93.12	0	33	
06/05/2024 00:00	27.41	0.07	93.03	0	33.1	
Minimum	27.41	0.03	92.63	0	20.6	
MinDate	06/05/2024 00:00	05/05/2024 21:00	05/05/2024 15:00	05/05/2024 00:00	05/05/2024 21:00	
Maximum	41.3	0.37	99.62	0	35.8	
MaxDate	05/05/2024 19:00	05/05/2024 12:00	05/05/2024 21:00	05/05/2024 00:00	05/05/2024 11:00	
Avg	29.94	0.15	94.29	0	31.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.7	0.1	2.2	0	4.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/05/2024 00:00	27.46	0	93.13	1.2	37.8	
06/05/2024 01:00	27.48	0	93.12	1.2	37.9	
06/05/2024 02:00	27.47	0	93.12	1.2	38.2	
06/05/2024 03:00	27.44	0	93.25	1.2	38.1	
06/05/2024 04:00	27.45	0	93.09	1.2	38.2	
06/05/2024 05:00	27.46	0	93.24	1.3	38.3	
06/05/2024 06:00	27.47	0.36	93.27	1.3	38.2	
06/05/2024 07:00	27.7	0	93.61	1.3	37.3	
06/05/2024 08:00	27.5	0	93.85	1.2	35.3	
06/05/2024 09:00	31.4	0	94.81	1.2	28.2	
06/05/2024 10:00	34.27	0	96.11	1.2	21.2	
06/05/2024 11:00	34.38	0	96.68	1.2	21.2	
06/05/2024 12:00	25.07	0	93.43	1.2	39.8	
06/05/2024 13:00	31.3	0	93.13	1.2	29.1	
06/05/2024 14:00	34.35	0	93.24	1.1	21.5	
06/05/2024 15:00	34.4	0	94.52	1.1	21	
06/05/2024 16:00	34.37	0	94.83	1.2	20.8	
06/05/2024 17:00	34.2	0	94.95	1.2	20.9	
06/05/2024 18:00	34.21	0	94.86	1.2	21	
06/05/2024 19:00	34.02	0	94.78	1.2	20.5	
06/05/2024 20:00	34.08	0	94.63	1.2	20.6	
06/05/2024 21:00	34.24	0	95.27	1.2	20.3	
06/05/2024 22:00	34.34	0	95.38	1.2	20.3	
06/05/2024 23:00	34.23	0	95.19	1.2	20.2	
07/05/2024 00:00	7.98	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	7.98	0	93.09	1.1	20.2	
MinDate	07/05/2024 00:00	06/05/2024 00:00	06/05/2024 04:00	06/05/2024 14:00	06/05/2024 23:00	
Maximum	34.4	0.36	96.68	1.3	39.8	
MaxDate	06/05/2024 15:00	06/05/2024 06:00	06/05/2024 11:00	06/05/2024 05:00	06/05/2024 12:00	
Avg	30.17	0.01	94.23	1.2	28.6	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	5.7	0.1	1.1	0	8.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
06/05/2024 00:00	27.41	0.07	93.03	0	33.1	
06/05/2024 01:00	27.42	0.09	93.08	0	33.2	
06/05/2024 02:00	27.41	0.1	93.04	0	33.4	
06/05/2024 03:00	27.38	0.1	93.14	0	33.3	
06/05/2024 04:00	27.39	0.22	93.04	0	33.3	
06/05/2024 05:00	27.4	0.25	93.14	0	33.2	
06/05/2024 06:00	27.41	0.2	93.14	0	33	
06/05/2024 07:00	27.65	0.19	93.48	0	32.5	
06/05/2024 08:00	27.45	0.24	93.69	0	32	
06/05/2024 09:00	31.24	0.21	94.5	0	25	
06/05/2024 10:00	34.21	0.23	95.64	0	17.5	
06/05/2024 11:00	34.32	0.26	96.38	0	17.7	
06/05/2024 12:00	25.06	0.27	93.49	0	37.2	
06/05/2024 13:00	31.15	0.2	93.18	0	26	
06/05/2024 14:00	34.3	<Samp	93.32	0	17.8	Calibrate
06/05/2024 15:00	34.34	0.34	94.65	0	17.3	
06/05/2024 16:00	34.31	0.22	94.86	0	17	
06/05/2024 17:00	34.14	0.2	95.05	0	17	
06/05/2024 18:00	34.15	0.18	94.94	0	17	
06/05/2024 19:00	33.96	0.18	94.92	0	16.8	
06/05/2024 20:00	34.02	0.18	94.87	0	16.4	
06/05/2024 21:00	34.18	0.17	95.22	0	16.4	
06/05/2024 22:00	34.27	0.14	95.24	0	16.4	
06/05/2024 23:00	34.16	0.12	95.05	0	16.2	
07/05/2024 00:00	39.75	0.1	95.9	0	31.3	
Minimum	25.06	0.07	93.03	0	16.2	
MinDate	06/05/2024 12:00	06/05/2024 00:00	06/05/2024 00:00	06/05/2024 00:00	06/05/2024 23:00	
Maximum	39.75	0.34	96.38	0	37.2	
MaxDate	07/05/2024 00:00	06/05/2024 15:00	06/05/2024 11:00	06/05/2024 00:00	06/05/2024 12:00	
Avg	31.38	0.19	94.25	0	24.8	
Num	25	24	25	25	25	
Data[%]	100	99	100	100	100	
STD	3.8	0.1	1.1	0	8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
07/05/2024 00:00	7.98	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 06:00	0	0.3	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 08:00	6.29	0	ShutDown	ShutDown	ShutDown	GT11 S/D
07/05/2024 09:00	32.18	0	94.66	1.2	36.2	
07/05/2024 10:00	34.27	0	94.04	1.2	28.4	
07/05/2024 11:00	34.19	0	91.76	1.2	29.9	
07/05/2024 12:00	25.74	0	91.67	1.3	46.1	
07/05/2024 13:00	31.45	0	91.49	1.3	35.8	
07/05/2024 14:00	34.17	0	93.61	1.3	28.7	
07/05/2024 15:00	34.2	0	94.36	1.4	27.5	
07/05/2024 16:00	34.13	0	94.47	1.4	27.2	
07/05/2024 17:00	33.98	0	94.5	1.4	27.1	
07/05/2024 18:00	33.85	0	94.6	1.4	27.5	
07/05/2024 19:00	33.79	0	94.53	1.4	28	
07/05/2024 20:00	33.92	0	94.71	1.4	27.7	
07/05/2024 21:00	34.16	0	94.84	1.4	26.9	
07/05/2024 22:00	34.24	0	94.82	1.4	26.9	
07/05/2024 23:00	34.14	0	94.9	1.3	26.8	
08/05/2024 00:00	40.74	0	95.81	1.4	41.3	
Minimum	0	0	91.49	1.2	26.8	
MinDate	07/05/2024 01:00	07/05/2024 00:00	07/05/2024 13:00	07/05/2024 09:00	07/05/2024 23:00	
Maximum	40.74	0.3	95.81	1.4	46.1	
MaxDate	08/05/2024 00:00	07/05/2024 06:00	08/05/2024 00:00	07/05/2024 15:00	07/05/2024 12:00	
Avg	22.14	0.01	94.05	1.3	30.8	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16	0.1	1.3	0.1	5.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
07/05/2024 00:00	39.75	0.1	95.9	0	31.3	
07/05/2024 01:00	47.7	0.14	95.57	0	31.2	
07/05/2024 02:00	47.64	0.2	94.95	0	31.1	
07/05/2024 03:00	47.69	0.17	95.11	0	31.1	
07/05/2024 04:00	47.83	0.19	95.32	0	31	
07/05/2024 05:00	47.83	0.21	95.23	0	30.9	
07/05/2024 06:00	47.92	0.2	95.42	0	30.9	
07/05/2024 07:00	47.73	0.45	95.1	0	30.9	
07/05/2024 08:00	43.67	0.08	94.95	0	29.8	
07/05/2024 09:00	32.25	0.01	94.15	0	24.7	
07/05/2024 10:00	34.21	0.41	93.1	0	17.1	
07/05/2024 11:00	34.12	Audit	89.35	0	18.5	DUST waiting for spare part
07/05/2024 12:00	25.68	<Samp	90.88	0	37.5	DUST waiting for spare part
07/05/2024 13:00	31.32	<Samp	90.83	0	25.9	DUST waiting for spare part
07/05/2024 14:00	34.1	Maintenance	92.93	0	17.5	DUST waiting for spare part
07/05/2024 15:00	34.15	<Samp	93.79	0	16.8	DUST waiting for spare part
07/05/2024 16:00	34.07	Maintenance	93.99	0	16.5	DUST waiting for spare part
07/05/2024 17:00	33.91	Audit	94.06	0	16.5	DUST waiting for spare part
07/05/2024 18:00	33.79	<Samp	94.09	0	16.8	DUST waiting for spare part
07/05/2024 19:00	33.72	0.39	94.01	0	17.1	DUST waiting for spare part
07/05/2024 20:00	33.85	<Samp	94.17	0	16.9	DUST waiting for spare part
07/05/2024 21:00	34.09	0.1	94.28	0	16.3	DUST waiting for spare part
07/05/2024 22:00	34.17	0.07	94.18	0	16.4	
07/05/2024 23:00	34.08	0.06	94.22	0	16.3	
08/05/2024 00:00	7.79	0.11	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	7.79	0.01	89.35	0	16.3	
MinDate	08/05/2024 00:00	07/05/2024 09:00	07/05/2024 11:00	07/05/2024 00:00	07/05/2024 21:00	
Maximum	47.92	0.45	95.9	0	37.5	
MaxDate	07/05/2024 06:00	07/05/2024 07:00	07/05/2024 00:00	07/05/2024 00:00	07/05/2024 12:00	
Avg	36.93	0.18	93.98	0	23.7	
Num	25	16	24	24	24	
Data[%]	100	64	96	96	96	
STD	9.1	0.1	1.6	0	7.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/05/2024 00:00	40.74	0	95.81	1.4	41.3	
08/05/2024 01:00	49.03	0	95.73	1.4	37.8	
08/05/2024 02:00	49.03	0	95.66	1.4	38.6	
08/05/2024 03:00	49.02	0	95.86	1.4	38	
08/05/2024 04:00	48.89	0	96.07	1.4	37.2	
08/05/2024 05:00	48.7	0	96.17	1.4	35.6	
08/05/2024 06:00	48.82	0.26	96.44	1.4	36.1	
08/05/2024 07:00	48.55	0	96.52	1.4	36.7	
08/05/2024 08:00	43.79	0	96.72	1.4	37.9	
08/05/2024 09:00	32.29	0	94.45	1.4	35.2	
08/05/2024 10:00	34.35	0	94.9	1.4	27.3	
08/05/2024 11:00	34.41	0	95.93	1.4	27.1	
08/05/2024 12:00	25.26	0	94.44	1.4	45.2	
08/05/2024 13:00	31.43	0	94.1	1.4	35.5	
08/05/2024 14:00	34.52	0	95.15	1.3	26.7	
08/05/2024 15:00	34.5	0	94.78	1.3	26.6	
08/05/2024 16:00	34.3	0	94.24	1.3	26.7	
08/05/2024 17:00	33.99	0	93.9	1.2	26.2	
08/05/2024 18:00	33.89	0	93.95	1.2	26.1	
08/05/2024 19:00	33.83	0	93.83	1.2	26	
08/05/2024 20:00	33.98	0	93.94	1.2	25.6	
08/05/2024 21:00	34.08	0	94.28	1.2	25.3	
08/05/2024 22:00	34.21	0	94.33	1.2	25.2	
08/05/2024 23:00	34.18	0	94.36	1.2	24.9	
09/05/2024 00:00	8.38	0	ShutDown	ShutDown	ShutDown	
Minimum	8.38	0	93.83	1.2	24.9	
MinDate	09/05/2024 00:00	08/05/2024 00:00	08/05/2024 19:00	08/05/2024 17:00	08/05/2024 23:00	
Maximum	49.03	0.26	96.72	1.4	45.2	
MaxDate	08/05/2024 01:00	08/05/2024 06:00	08/05/2024 08:00	08/05/2024 00:00	08/05/2024 12:00	
Avg	37.37	0.01	95.07	1.3	32	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	9.5	0.1	1	0.1	6.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/05/2024 00:00	7.79	0.11	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 01:00	0	0.23	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 02:00	0	0.27	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 03:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 07:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 SD
08/05/2024 08:00	5.83	3.81	ShutDown	ShutDown	ShutDown	
08/05/2024 09:00	32.23	5.05	95.54	0	32	
08/05/2024 10:00	34.29	5.06	95.47	0	24.1	
08/05/2024 11:00	34.34	5.08	96.48	0	23.9	
08/05/2024 12:00	25.22	<Samp	95.04	0	42.4	Calibrate
08/05/2024 13:00	31.36	0.06	94.8	0	32.1	
08/05/2024 14:00	34.46	0.04	95.72	0	22.7	
08/05/2024 15:00	34.44	0.01	95.48	0	22.6	
08/05/2024 16:00	34.24	0	95.04	0	22.5	
08/05/2024 17:00	33.93	0	94.79	0	22	
08/05/2024 18:00	33.83	0	94.83	0	21.8	
08/05/2024 19:00	33.77	0	94.69	0	21.9	
08/05/2024 20:00	33.91	<Samp	94.79	0	21.5	DUST waiting for spare part
08/05/2024 21:00	34.03	Maintenance	94.99	0	21.3	DUST waiting for spare part
08/05/2024 22:00	34.16	<Samp	94.98	0	21.2	DUST waiting for spare part
08/05/2024 23:00	34.12	<Samp	94.95	0	20.9	DUST waiting for spare part
09/05/2024 00:00	39.75	<Samp	95.79	0	38.3	DUST waiting for spare part
Minimum	0	0	94.69	0	20.9	
MinDate	08/05/2024 01:00	08/05/2024 16:00	08/05/2024 19:00	08/05/2024 09:00	08/05/2024 23:00	
Maximum	39.75	5.08	96.48	0	32.4	
MaxDate	09/05/2024 00:00	08/05/2024 11:00	08/05/2024 11:00	08/05/2024 09:00	08/05/2024 12:00	
Avg	22.07	1.41	95.21	0	25.7	
Num	25	14	16	16	16	
Data[%]	100	56	64	64	64	
STD	16	2.2	0.5	0	6.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/05/2024 00:00	8.38	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 06:00	0	0.19	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 08:00	4.69	0.1	ShutDown	ShutDown	ShutDown	GT11 S/D
09/05/2024 09:00	32.35	0	96.3	1.3	34.6	
09/05/2024 10:00	34.41	0	95.78	1.3	27.8	
09/05/2024 11:00	34.43	0	95.71	1.3	27.9	
09/05/2024 12:00	25.23	0	93.12	1.4	43.6	
09/05/2024 13:00	31.4	0	93.78	1.3	34.9	
09/05/2024 14:00	34.38	0	95.15	1.3	27.3	
09/05/2024 15:00	34.4	0	93.98	1.3	27.3	
09/05/2024 16:00	34.18	0	91.05	1.3	27.3	
09/05/2024 17:00	33.95	0	92.45	1.3	27.7	
09/05/2024 18:00	33.92	0	92.85	1.3	27.1	
09/05/2024 19:00	33.8	0	92.43	1.3	27	
09/05/2024 20:00	33.9	0	92.39	1.3	27.2	
09/05/2024 21:00	34.06	0	93.58	1.3	26.9	
09/05/2024 22:00	36.81	0	95.29	1.4	27.7	
09/05/2024 23:00	37.83	0	96.69	1.4	28.5	
10/05/2024 00:00	27.54	0	93	1.4	47.4	
Minimum	0	0	91.05	1.3	26.9	
MinDate	09/05/2024 01:00	09/05/2024 00:00	09/05/2024 16:00	09/05/2024 09:00	09/05/2024 21:00	
Maximum	37.83	0.19	96.69	1.4	47.4	
MaxDate	09/05/2024 23:00	09/05/2024 06:00	09/05/2024 23:00	09/05/2024 12:00	10/05/2024 00:00	
Avg	21.83	0.01	93.98	1.3	30.6	
Num	25	25	16	16	16	
Data(%)	100	100	64	64	64	
STD	15.9	0	1.7	0	6.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/05/2024 00:00	39.75	<Samp	95.79	0	38.3	DUST waiting for spare part
09/05/2024 01:00	47.92	<Samp	95.21	0	39.6	DUST waiting for spare part
09/05/2024 02:00	47.94	0	95.19	0	39.2	
09/05/2024 03:00	47.85	0	95.44	0	38.9	
09/05/2024 04:00	47.83	0	95.4	0	39	
09/05/2024 05:00	48.06	0.04	95.37	0	38.9	
09/05/2024 06:00	48.1	<Samp	95.94	0	38.9	DUST waiting for spare part
09/05/2024 07:00	47.72	<Samp	95.55	0	38.4	DUST waiting for spare part
09/05/2024 08:00	44.43	0.43	96.05	0	35.8	
09/05/2024 09:00	32.34	0.03	95.5	0	27.1	
09/05/2024 10:00	34.35	<Samp	95.65	0	20.1	DUST waiting for spare part
09/05/2024 11:00	34.36	Maintenance	95.96	0	20	DUST waiting for spare part
09/05/2024 12:00	25.19	<Samp	93.59	0	37.3	DUST waiting for spare part
09/05/2024 13:00	31.32	Maintenance	94.21	0	28.1	DUST waiting for spare part
09/05/2024 14:00	34.32	<Samp	95.32	0	19.6	DUST waiting for spare part
09/05/2024 15:00	34.34	<Samp	94.4	0	19.7	DUST waiting for spare part
09/05/2024 16:00	34.12	Maintenance	91.7	0	20	DUST waiting for spare part
09/05/2024 17:00	33.89	Maintenance	92.86	0	20.5	DUST waiting for spare part
09/05/2024 18:00	33.87	Maintenance	93.42	0	19.8	DUST waiting for spare part
09/05/2024 19:00	33.73	Maintenance	93	0	19.6	DUST waiting for spare part
09/05/2024 20:00	33.84	Maintenance	92.88	0	19.8	DUST waiting for spare part
09/05/2024 21:00	33.99	Maintenance	93.88	0	19.5	DUST waiting for spare part
09/05/2024 22:00	36.74	<Samp	95.51	0	20.5	DUST waiting for spare part
09/05/2024 23:00	37.76	Maintenance	96.85	0	21.2	DUST waiting for spare part
10/05/2024 00:00	27.48	Maintenance	93.21	0	38.8	DUST waiting for spare part
Minimum	25.19	0	91.7	0	19.5	
MinDate	09/05/2024 12:00	09/05/2024 02:00	09/05/2024 16:00	09/05/2024 00:00	09/05/2024 21:00	
Maximum	48.1	0.43	96.85	0	39.6	
MaxDate	09/05/2024 06:00	09/05/2024 08:00	09/05/2024 23:00	09/05/2024 00:00	09/05/2024 01:00	
Avg	38.05	0.08	94.72	0	28.7	
Num	25	6	25	25	25	
Data(%)	100	24	100	100	100	
STD	7.2	0.2	1.3	0	9.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
10/05/2024 00:00	27.54	0	93	1.4	47.4	
10/05/2024 01:00	28.43	0	92.29	1.4	46.6	
10/05/2024 02:00	28.62	0	92.33	1.5	45.6	
10/05/2024 03:00	28.53	0	92.44	1.5	46	
10/05/2024 04:00	28.4	0	92.37	1.5	46.1	
10/05/2024 05:00	28.29	0	92.23	1.5	47	
10/05/2024 06:00	28.22	0.38	92.34	1.5	47.2	
10/05/2024 07:00	28.3	0	92.94	1.6	45.4	
10/05/2024 08:00	26.59	0	93.2	1.6	46.5	
10/05/2024 09:00	31.16	0	94.15	1.5	35.9	
10/05/2024 10:00	34.25	0	95.31	1.4	26.1	
10/05/2024 11:00	34.26	0	95.73	1.4	26.1	
10/05/2024 12:00	24.75	0	93.72	1.5	45.8	
10/05/2024 13:00	31.18	0	93.9	1.4	34.8	
10/05/2024 14:00	34.28	0	95.21	1.4	25.6	
10/05/2024 15:00	34.19	0	94.93	1.3	25.1	
10/05/2024 16:00	34.09	0	94.67	1.3	24.8	
10/05/2024 17:00	33.88	0	94.66	1.3	24.9	
10/05/2024 18:00	33.83	0	94.25	1.3	25.2	
10/05/2024 19:00	33.7	0	94.04	1.3	25	
10/05/2024 20:00	33.81	0	94.14	1.3	24.7	
10/05/2024 21:00	33.97	0	94.47	1.3	24.5	
10/05/2024 22:00	37.2	0	96.24	1.3	25.9	
10/05/2024 23:00	39.05	0	97.55	1.4	27	
11/05/2024 00:00	28.32	0	94.27	1.4	42.1	
Minimum	24.75	0	92.23	1.3	24.5	
MinDate	10/05/2024 12:00	10/05/2024 00:00	10/05/2024 05:00	10/05/2024 15:00	10/05/2024 21:00	
Maximum	39.05	0.38	97.55	1.6	47.4	
MaxDate	10/05/2024 23:00	10/05/2024 06:00	10/05/2024 23:00	10/05/2024 07:00	10/05/2024 00:00	
Avg	31.39	0.02	94.02	1.4	35.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	3.6	0.1	1.4	0.1	10.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
10/05/2024 00:00	27.48	Maintenance	93.21	0	38.8	DUST waiting for spare part
10/05/2024 01:00	28.38	<Samp	92.73	0	37.4	DUST waiting for spare part
10/05/2024 02:00	28.57	<Samp	92.8	0	36.5	DUST waiting for spare part
10/05/2024 03:00	28.47	<Samp	92.87	0	36.7	DUST waiting for spare part
10/05/2024 04:00	28.35	<Samp	92.82	0	36.6	DUST waiting for spare part
10/05/2024 05:00	28.24	Maintenance	92.75	0	37.6	DUST waiting for spare part
10/05/2024 06:00	28.16	Audit	92.9	0	38.1	DUST waiting for spare part
10/05/2024 07:00	28.25	0.15	93.34	0	36	DUST waiting for spare part
10/05/2024 08:00	26.5	<Samp	93.46	0	38.5	DUST waiting for spare part
10/05/2024 09:00	31.06	0.03	94.52	0	29.2	
10/05/2024 10:00	34.19	0	95.46	0	19	
10/05/2024 11:00	34.21	0	95.89	0	19	
10/05/2024 12:00	24.3	0	93.84	0	41.7	
10/05/2024 13:00	30.84	0	93.45	0	30.1	
10/05/2024 14:00	34.23	0	95.23	0	18.3	
10/05/2024 15:00	34.14	0	95.03	0	17.8	
10/05/2024 16:00	34.03	0	94.71	0	17.6	
10/05/2024 17:00	33.82	0	94.87	0	17.7	
10/05/2024 18:00	33.77	0	94.62	0	18.1	
10/05/2024 19:00	33.64	0	94.41	0	17.9	
10/05/2024 20:00	33.75	0	94.5	0	17.7	
10/05/2024 21:00	33.92	0	94.69	0	17.6	
10/05/2024 22:00	37.14	0	96.43	0	18.9	
10/05/2024 23:00	38.59	0	97.71	0	20	
11/05/2024 00:00	28.24	0	94.4	0	33.9	
Minimum	24.3	0	92.73	0	17.6	
MinDate	10/05/2024 12:00	10/05/2024 16:00	10/05/2024 01:00	10/05/2024 00:00	10/05/2024 16:00	
Maximum	38.59	0.15	97.71	0	41.7	
MaxDate	10/05/2024 23:00	10/05/2024 07:00	10/05/2024 23:00	10/05/2024 00:00	10/05/2024 12:00	
Avg	31.31	0.01	94.27	0	27.6	
Num	25	17	25	25	25	
Data[%]	100	68	100	100	100	
STD	3.7	0	1.3	0	9.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/05/2024 00:00	28.32	0	94.27	1.4	42.1	
11/05/2024 01:00	30.78	0	93.43	1.4	36	
11/05/2024 02:00	31.14	0	93.59	1.4	34.8	
11/05/2024 03:00	31.02	0	93.39	1.4	35.5	
11/05/2024 04:00	30.86	0	93.15	1.4	35.7	
11/05/2024 05:00	30.66	0	93.45	1.4	36.1	
11/05/2024 06:00	30.72	0.32	93.38	1.4	36.1	
11/05/2024 07:00	31.01	0	93.51	1.4	34.9	
11/05/2024 08:00	30.91	0	93.57	1.4	34.5	
11/05/2024 09:00	41.46	0	98.25	1.4	30.6	
11/05/2024 10:00	44.79	0	102.72	1.4	28.6	
11/05/2024 11:00	45.02	0	103.4	1.4	29	
11/05/2024 12:00	34.48	0	98.44	1.4	32.5	
11/05/2024 13:00	41.4	0	97.64	1.4	30.8	
11/05/2024 14:00	44.99	0	101.61	1.4	29.1	
11/05/2024 15:00	44.97	0	101.57	1.4	28.7	
11/05/2024 16:00	44.92	0	101.72	1.4	28.5	
11/05/2024 17:00	44.92	0	101.51	1.4	27.9	
11/05/2024 18:00	44.91	0	101.77	1.4	27.7	
11/05/2024 19:00	44.95	0	101.77	1.4	27.7	
11/05/2024 20:00	44.97	0	101.83	1.4	27.6	
11/05/2024 21:00	44.93	0	102.07	1.4	27.8	
11/05/2024 22:00	44.95	0	102.09	1.4	27.8	
11/05/2024 23:00	44.8	0	101.92	1.4	27.5	
12/05/2024 00:00	30.75	0	95.17	1.4	36	
Minimum	28.32	0	93.15	1.4	27.5	
MinDate	11/05/2024 00:00	11/05/2024 00:00	11/05/2024 04:00	11/05/2024 00:00	11/05/2024 23:00	
Maximum	45.02	0.32	103.4	1.4	42.1	
MaxDate	11/05/2024 11:00	11/05/2024 06:00	11/05/2024 11:00	11/05/2024 00:00	11/05/2024 00:00	
Avg	38.5	0.01	98.21	1.4	31.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.9	0.1	4	---	4.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/05/2024 00:00	28.24	0	94.4	0	33.9	
11/05/2024 01:00	30.72	0	93.58	0	27.9	
11/05/2024 02:00	31.08	0.27	93.6	0	26.7	
11/05/2024 03:00	30.96	Maintenance	93.44	0	27.4	DUST waiting for spare part
11/05/2024 04:00	30.8	Maintenance	93.17	0	27.6	DUST waiting for spare part
11/05/2024 05:00	30.6	Maintenance	93.45	0	28.2	DUST waiting for spare part
11/05/2024 06:00	30.65	Maintenance	93.42	0	28	DUST waiting for spare part
11/05/2024 07:00	30.95	Maintenance	93.57	0	26.7	DUST waiting for spare part
11/05/2024 08:00	30.85	Maintenance	93.65	0	26.1	DUST waiting for spare part
11/05/2024 09:00	41.33	Maintenance	98.41	0	25.9	DUST waiting for spare part
11/05/2024 10:00	44.72	Maintenance	102.75	0	25.2	DUST waiting for spare part
11/05/2024 11:00	44.94	Maintenance	103.2	0	26.2	DUST waiting for spare part
11/05/2024 12:00	34.4	Maintenance	98.21	0	26.2	DUST waiting for spare part
11/05/2024 13:00	41.32	Maintenance	98.2	0	25.8	DUST waiting for spare part
11/05/2024 14:00	44.91	Maintenance	101.54	0	24.6	DUST waiting for spare part
11/05/2024 15:00	44.99	Maintenance	101.63	0	24.3	DUST waiting for spare part
11/05/2024 16:00	44.84	Maintenance	101.85	0	24.4	DUST waiting for spare part
11/05/2024 17:00	44.84	<Samp	101.7	0	23.5	DUST waiting for spare part
11/05/2024 18:00	44.82	<Samp	101.89	0	23.3	DUST waiting for spare part
11/05/2024 19:00	44.87	<Samp	102.05	0	23.4	DUST waiting for spare part
11/05/2024 20:00	44.89	Maintenance	102	0	23.1	DUST waiting for spare part
11/05/2024 21:00	44.85	Maintenance	102	0	23	DUST waiting for spare part
11/05/2024 22:00	44.77	Maintenance	101.99	0	23	DUST waiting for spare part
11/05/2024 23:00	44.72	Maintenance	101.83	0	22.4	DUST waiting for spare part
12/05/2024 00:00	30.69	Maintenance	95.03	0	28.1	DUST waiting for spare part
Minimum	28.24	0	93.17	0	22.4	
MinDate	11/05/2024 00:00	11/05/2024 00:00	11/05/2024 04:00	11/05/2024 00:00	11/05/2024 23:00	
Maximum	44.94	0.27	103.2	0	33.9	
MaxDate	11/05/2024 11:00	11/05/2024 02:00	11/05/2024 11:00	11/05/2024 00:00	11/05/2024 00:00	
Avg	38.43	0.09	98.26	0	25.4	
Num	25	3	25	25	25	
Data[%]	100	12	100	100	100	
STD	6.9	0.2	4	0	2.5	

Date & Time	11CT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/05/2024 00:00	30.75	0	93.17	1.4	36	
12/05/2024 01:00	30.71	0	93.18	1.4	35.3	
12/05/2024 02:00	30.75	0	93.1	1.4	34.6	
12/05/2024 03:00	30.68	0	93.18	1.4	34.8	
12/05/2024 04:00	30.35	0	93.03	1.5	35.7	
12/05/2024 05:00	30.36	0	93.04	1.5	35.5	
12/05/2024 06:00	30.47	0.26	93.18	1.5	35.5	
12/05/2024 07:00	30.69	0	93.59	1.5	33.6	
12/05/2024 08:00	30.78	0	93.97	1.5	34.3	
12/05/2024 09:00	30.87	0	94.14	1.5	31.2	
12/05/2024 10:00	30.91	0	94.31	1.5	30.3	
12/05/2024 11:00	30.88	0	94.94	1.5	29.9	
12/05/2024 12:00	30.92	0	94.86	1.5	28.7	
12/05/2024 13:00	30.9	0	94.39	1.5	28.2	
12/05/2024 14:00	30.87	0	93.33	1.4	30.2	
12/05/2024 15:00	30.8	0	93.08	1.3	31.1	
12/05/2024 16:00	30.82	0	93.26	1.3	30	
12/05/2024 17:00	30.78	0	93.1	1.3	29.9	
12/05/2024 18:00	37.68	0	95.62	1.4	30.4	
12/05/2024 19:00	45.61	0	101.72	1.4	25.4	
12/05/2024 20:00	44.64	0	101.96	1.4	25.5	
12/05/2024 21:00	44.84	0	102.4	1.4	25.4	
12/05/2024 22:00	37.83	0	99.67	1.4	28.5	
12/05/2024 23:00	30.69	0	93.78	1.3	30.8	
13/05/2024 00:00	30.78	0	93.48	1.4	30.2	
Minimum	30.35	0	93.03	1.3	25.4	
MinDate	12/05/2024 04:00	12/05/2024 00:00	12/05/2024 04:00	12/05/2024 15:00	12/05/2024 19:00	
Maximum	44.84	0.26	102.4	1.5	36	
MaxDate	12/05/2024 21:00	12/05/2024 06:00	12/05/2024 21:00	12/05/2024 04:00	12/05/2024 00:00	
Avg	32.97	0.01	95.02	1.4	31.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.8	0.1	9	0.1	3.3	

Date & Time	12CT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/05/2024 00:00	30.69	Maintenance	93.03	0	28.1	DUST waiting for spare part
12/05/2024 01:00	30.65	Maintenance	93.11	0	27.2	DUST waiting for spare part
12/05/2024 02:00	30.69	Maintenance	93.07	0	26.7	DUST waiting for spare part
12/05/2024 03:00	30.62	Maintenance	93.22	0	26.8	DUST waiting for spare part
12/05/2024 04:00	30.29	Maintenance	93.1	0	27.9	DUST waiting for spare part
12/05/2024 05:00	30.3	Maintenance	93.11	0	27.8	DUST waiting for spare part
12/05/2024 06:00	30.41	Maintenance	93.16	0	28	DUST waiting for spare part
12/05/2024 07:00	30.63	<Samp	93.56	0	25.6	DUST waiting for spare part
12/05/2024 08:00	30.73	<Samp	93.87	0	26.4	DUST waiting for spare part
12/05/2024 09:00	30.81	Maintenance	94.15	0	23.5	DUST waiting for spare part
12/05/2024 10:00	30.85	Maintenance	94.2	0	22.9	DUST waiting for spare part
12/05/2024 11:00	30.82	Maintenance	94.88	0	22.5	DUST waiting for spare part
12/05/2024 12:00	30.85	Maintenance	94.79	0	21.6	DUST waiting for spare part
12/05/2024 13:00	30.83	Maintenance	94.28	0	21.3	DUST waiting for spare part
12/05/2024 14:00	30.81	Maintenance	93.38	0	23.3	DUST waiting for spare part
12/05/2024 15:00	30.74	Maintenance	93.23	0	24	DUST waiting for spare part
12/05/2024 16:00	30.76	Maintenance	93.46	0	23	DUST waiting for spare part
12/05/2024 17:00	30.71	Maintenance	93.37	0	23	DUST waiting for spare part
12/05/2024 18:00	37.57	Maintenance	96.06	0	25.5	DUST waiting for spare part
12/05/2024 19:00	44.53	Maintenance	102.18	0	22.5	DUST waiting for spare part
12/05/2024 20:00	44.55	Maintenance	102.29	0	22.7	DUST waiting for spare part
12/05/2024 21:00	44.76	Maintenance	102.54	0	22.5	DUST waiting for spare part
12/05/2024 22:00	37.77	Maintenance	99.68	0	24.4	DUST waiting for spare part
12/05/2024 23:00	30.64	Maintenance	93.93	0	25	DUST waiting for spare part
13/05/2024 00:00	30.73	Maintenance	93.64	0	24.5	DUST waiting for spare part
Minimum	30.29	---	93.07	0	21.3	
MinDate	12/05/2024 04:00	12/05/2024 00:00	12/05/2024 02:00	12/05/2024 00:00	12/05/2024 13:00	
Maximum	44.76	---	102.54	0	26.1	
MaxDate	12/05/2024 21:00	12/05/2024 00:00	12/05/2024 21:00	12/05/2024 00:00	12/05/2024 00:00	
Avg	32.91	---	95.09	0	24.7	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.8	---	3.1	0	2.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/05/2024 00:00	30.78	0	93.48	1.4	30.2	
13/05/2024 01:00	30.84	0	93.56	1.4	29.7	
13/05/2024 02:00	30.87	0	93.57	1.4	29.5	
13/05/2024 03:00	30.85	0	92.92	1.4	30.5	
13/05/2024 04:00	30.74	0	92.1	1.4	33.5	
13/05/2024 05:00	30.72	0	92.33	1.4	33.5	
13/05/2024 06:00	30.74	0.17	92.3	1.4	33.5	
13/05/2024 07:00	30.96	0	92.71	1.5	32.4	
13/05/2024 08:00	29.7	0	93.08	1.5	33.9	
13/05/2024 09:00	31.2	0	93.44	1.5	31.5	
13/05/2024 10:00	34.2	0	94.62	1.4	22.2	
13/05/2024 11:00	34.27	0.07	95.27	1.4	21.9	
13/05/2024 12:00	25.04	0.09	93.81	1.5	41.2	
13/05/2024 13:00	31.41	0.09	93.69	1.5	30.6	
13/05/2024 14:00	34.5	0	94.81	1.4	21.9	
13/05/2024 15:00	34.37	0	93.59	1.3	21.6	
13/05/2024 16:00	34.36	0	92.39	1.3	21.5	
13/05/2024 17:00	34.05	0	92.28	1.3	21.4	
13/05/2024 18:00	34.01	0	93.35	1.3	21.4	
13/05/2024 19:00	33.84	0	93.54	1.3	21.4	
13/05/2024 20:00	33.95	0	93.7	1.4	21.4	
13/05/2024 21:00	34.05	0	93.85	1.4	21.4	
13/05/2024 22:00	34.01	0	93.49	1.4	21.5	
13/05/2024 23:00	34.06	0	93.48	1.4	21.3	
14/05/2024 00:00	40.61	0	94.98	1.4	35.2	
Minimum	25.04	0	92.1	1.3	21.3	
MinDate	13/05/2024 12:00	13/05/2024 00:00	13/05/2024 04:00	13/05/2024 15:00	13/05/2024 23:00	
Maximum	40.61	0.17	95.27	1.5	41.2	
MaxDate	14/05/2024 00:00	13/05/2024 08:00	13/05/2024 11:00	13/05/2024 07:00	13/05/2024 12:00	
Avg	32.57	0.02	93.45	1.4	27.4	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	2.8	0	0.8	0.1	6.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/05/2024 00:00	30.73	Maintenance	93.64	0	24.5	DUST waiting for spare part
13/05/2024 01:00	30.77	Maintenance	93.72	0	24.1	DUST waiting for spare part
13/05/2024 02:00	30.81	Maintenance	93.73	0	23.6	DUST waiting for spare part
13/05/2024 03:00	30.79	<Samp	92.98	0	24.8	DUST waiting for spare part
13/05/2024 04:00	30.68	<Samp	92.71	0	28.1	DUST waiting for spare part
13/05/2024 05:00	30.66	0.03	92.46	0	28	DUST waiting for spare part
13/05/2024 06:00	30.67	<Samp	92.44	0	28.2	DUST waiting for spare part
13/05/2024 07:00	30.9	<Samp	92.87	0	27.2	DUST waiting for spare part
13/05/2024 08:00	29.68	<Samp	93.19	0	28	DUST waiting for spare part
13/05/2024 09:00	31.15	0.57	93.83	0	28.7	DUST waiting for spare part
13/05/2024 10:00	34.14	0.22	94.81	0	17.4	DUST waiting for spare part
13/05/2024 11:00	34.21	0.25	95.37	0	17	DUST waiting for spare part
13/05/2024 12:00	25.07	<Samp	93.95	0	38.7	DUST waiting for spare part
13/05/2024 13:00	31.45	<Samp	94.1	0	25.9	DUST waiting for spare part
13/05/2024 14:00	34.44	<Samp	95.02	0	16.8	DUST waiting for spare part
13/05/2024 15:00	34.31	<Samp	93.88	0	16.6	DUST waiting for spare part
13/05/2024 16:00	34.29	<Samp	92.79	0	16.6	DUST waiting for spare part
13/05/2024 17:00	33.99	<Samp	92.79	0	16.5	DUST waiting for spare part
13/05/2024 18:00	33.94	<Samp	93.51	0	16.5	DUST waiting for spare part
13/05/2024 19:00	33.77	<Samp	93.74	0	16.6	DUST waiting for spare part
13/05/2024 20:00	33.88	<Samp	93.95	0	16.5	DUST waiting for spare part
13/05/2024 21:00	34	1.08	93.92	0	16.5	DUST waiting for spare part
13/05/2024 22:00	33.95	0	93.86	0	16.7	DUST waiting for spare part
13/05/2024 23:00	34	<Samp	93.7	0	16.4	DUST waiting for spare part
14/05/2024 00:00	7.79	<Samp	ShutDown	ShutDown	ShutDown	GT12 shutdown.
Minimum	7.79	0	92.21	0	16.4	
MinDate	14/05/2024 00:00	13/05/2024 22:00	13/05/2024 04:00	13/05/2024 23:00		
Maximum	34.44	1.09	95.37	0	38.7	
MaxDate	13/05/2024 14:00	13/05/2024 21:00	13/05/2024 11:00	13/05/2024 00:00	13/05/2024 12:00	
Avg	31.2	0.36	93.59	0	21.9	
Num	25	6	24	24	24	
Data(%)	100	24	96	96	96	
STD	5.4	0.4	0.8	0	6.9	

Date & Time	11GT_LOAD MW	11HRSG_DUST mg/m3	11HRSG_TEMP Degree C	11HRSG_SO2@7%O2 ppm	11HRSG_NOx@7%O2 ppm	Remark
14/05/2024 00:00	40.61	0	94.98	1.4	35.2	
14/05/2024 01:00	48.85	0	95.4	1.4	30.8	
14/05/2024 02:00	48.96	0.01	95.61	1.4	30.9	
14/05/2024 03:00	49.03	0	95.64	1.4	30.3	
14/05/2024 04:00	48.96	0	95.76	1.4	29.6	
14/05/2024 05:00	48.75	0	96.01	1.5	28.5	
14/05/2024 06:00	48.89	0.38	96.28	1.5	29	
14/05/2024 07:00	48.77	0	96	1.5	29.9	
14/05/2024 08:00	44.62	0	96.69	1.5	29.2	
14/05/2024 09:00	32.29	0	94.53	1.5	28.2	
14/05/2024 10:00	34.44	0	95.31	1.5	21.5	
14/05/2024 11:00	34.47	0	96.08	1.4	21.4	
14/05/2024 12:00	25.21	0	94.21	1.5	38.9	
14/05/2024 13:00	31.43	0	94.3	1.5	28.5	
14/05/2024 14:00	34.55	0	95.84	1.4	21	
14/05/2024 15:00	34.59	0	95.49	1.4	21	
14/05/2024 16:00	34.41	0	95.18	1.4	21	
14/05/2024 17:00	34.2	0	95.07	1.3	21.3	
14/05/2024 18:00	34.16	0	94.94	1.3	21.6	
14/05/2024 19:00	34.01	0	94.6	1.3	21.3	
14/05/2024 20:00	34.1	0	94.68	1.2	21	
14/05/2024 21:00	34.22	0	95.22	1.3	21	
14/05/2024 22:00	34.29	0	95.15	1.3	21.2	
14/05/2024 23:00	34.18	0	95	1.3	21.2	
15/05/2024 00:00	7.94	0.01	Shutdown	Shutdown	Shutdown	GT11 S/D
Minimum	7.94	0	94.21	1.2	21	
MinDate	15/05/2024 00:00	14/05/2024 00:00	14/05/2024 12:00	14/05/2024 20:00	14/05/2024 14:00	
Maximum	49.03	0.38	96.69	1.5	38.9	
MaxDate	14/05/2024 03:00	14/05/2024 06:00	14/05/2024 08:00	14/05/2024 05:00	14/05/2024 12:00	
Avg	37.44	0.02	95.33	1.4	26	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	9.5	0.1	0.6	0.1	5.3	

Date & Time	12GT_LOAD MW	12HRSG_DUST mg/m3	12HRSG_TEMP Degree C	12HRSG_SO2@7%O2 ppm	12HRSG_NOx@7%O2 ppm	Remark
14/05/2024 00:00	7.79	<Samp	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 01:00	0	<Samp	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 02:00	0	<Samp	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 03:00	0	<Samp	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 04:00	0	<Samp	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 05:00	0	0.1	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 06:00	0	0.15	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 07:00	0	0.22	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 08:00	5.25	<Samp	Shutdown	Shutdown	Shutdown	GT12 S/D
14/05/2024 09:00	32.16	Maintenance	95.95	0	29.9	DUST waiting for spare part
14/05/2024 10:00	34.37	Maintenance	95.3	0	23.4	DUST waiting for spare part
14/05/2024 11:00	34.41	Maintenance	96.01	0	23.1	DUST waiting for spare part
14/05/2024 12:00	25.21	Maintenance	94.1	0	39.4	DUST waiting for spare part
14/05/2024 13:00	31.35	Maintenance	94.37	0	29.3	DUST waiting for spare part
14/05/2024 14:00	34.48	Maintenance	95.8	0	21.7	DUST waiting for spare part
14/05/2024 15:00	34.53	Maintenance	95.56	0	21.6	DUST waiting for spare part
14/05/2024 16:00	34.35	Maintenance	95.29	0	21.4	DUST waiting for spare part
14/05/2024 17:00	34.14	Maintenance	95.21	0	21.7	DUST waiting for spare part
14/05/2024 18:00	34.1	Maintenance	95.2	0	21.9	DUST waiting for spare part
14/05/2024 19:00	33.95	Maintenance	94.95	0	21.3	DUST waiting for spare part
14/05/2024 20:00	34.02	Maintenance	95.08	0	20.8	DUST waiting for spare part
14/05/2024 21:00	34.16	Maintenance	95.42	0	20.8	DUST waiting for spare part
14/05/2024 22:00	34.23	Maintenance	95.34	0	21	DUST waiting for spare part
14/05/2024 23:00	34.12	Maintenance	95.27	0	20.6	DUST waiting for spare part
15/05/2024 00:00	39.73	Maintenance	95.93	0	38.3	DUST waiting for spare part
Minimum	0	0.1	94.1	0	20.6	
MinDate	14/05/2024 01:00	14/05/2024 05:00	14/05/2024 12:00	14/05/2024 09:00	14/05/2024 23:00	
Maximum	39.73	0.22	96.01	0	39.4	
MaxDate	15/05/2024 00:00	14/05/2024 07:00	14/05/2024 11:00	14/05/2024 09:00	14/05/2024 12:00	
Avg	22.09	0.18	95.3	0	24.8	
Num	25	3	16	16	16	
Data[%]	100	12	64	64	64	
STD	16.1	0.1	0.5	0	6.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	HW	mg/m3	Degree C	ppm	ppm	
15/05/2024 00:00	7.94	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 06:00	0	0.32	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 08:00	6.25	0.08	ShutDown	ShutDown	ShutDown	GT11 S/D
15/05/2024 09:00	32.48	0	96.42	1.4	34.8	
15/05/2024 10:00	34.63	0	96.48	1.4	28.7	
15/05/2024 11:00	34.55	0	96.11	1.5	28.5	
15/05/2024 12:00	25.31	0	93.14	1.5	43.9	
15/05/2024 13:00	31.34	0	92.56	1.4	35.6	
15/05/2024 14:00	34.47	0	94.96	1.4	27.8	
15/05/2024 15:00	34.52	0	95.42	1.4	27.8	
15/05/2024 16:00	34.42	0	95.28	1.4	28.1	
15/05/2024 17:00	34.25	0	94.61	1.4	27.6	
15/05/2024 18:00	34.13	0	94.71	1.4	27.3	
15/05/2024 19:00	33.94	0	94.45	1.4	27	
15/05/2024 20:00	34.04	0	94.47	1.4	28.8	
15/05/2024 21:00	34.28	0	94.93	1.4	26.6	
15/05/2024 22:00	34.33	0	95	1.4	26.5	
15/05/2024 23:00	34.19	0	94.98	1.4	26.6	
16/05/2024 00:00	40.36	0	95.5	1.5	40.2	
Minimum	0	0	92.56	1.4	26.5	
MinDate	15/05/2024 01:00	15/05/2024 01:00	15/05/2024 13:00	15/05/2024 09:00	15/05/2024 22:00	
Maximum	40.36	0.32	96.48	1.5	43.9	
MaxDate	16/05/2024 00:00	15/05/2024 06:00	15/05/2024 10:00	15/05/2024 11:00	15/05/2024 12:00	
Avg	22.22	0.02	94.94	1.4	30.2	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16.1	0.1	1	0	5.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	HW	mg/m3	Degree C	ppm	ppm	
15/05/2024 00:00	39.73	Maintenance	95.93	0	38.3	DUST waiting for spare part
15/05/2024 01:00	47.63	Maintenance	95.12	0	39	DUST waiting for spare part
15/05/2024 02:00	47.96	Maintenance	95.05	0	38.8	DUST waiting for spare part
15/05/2024 03:00	47.88	Maintenance	95.33	0	38.6	DUST waiting for spare part
15/05/2024 04:00	47.99	Maintenance	95.48	0	38.6	DUST waiting for spare part
15/05/2024 05:00	48.11	Maintenance	95.49	0	38.6	DUST waiting for spare part
15/05/2024 06:00	48.11	Maintenance	96.02	0	38.5	DUST waiting for spare part
15/05/2024 07:00	47.58	Maintenance	95.56	0	38.2	DUST waiting for spare part
15/05/2024 08:00	43	Maintenance	96.07	0	36.8	DUST waiting for spare part
15/05/2024 09:00	32.4	Maintenance	96.03	0	26.8	DUST waiting for spare part
15/05/2024 10:00	34.56	Maintenance	96.34	0	20.5	DUST waiting for spare part
15/05/2024 11:00	34.49	Maintenance	96.05	0	20.2	DUST waiting for spare part
15/05/2024 12:00	25.17	Maintenance	93.14	0	38.8	DUST waiting for spare part
15/05/2024 13:00	31.16	Maintenance	92.74	0	29.2	DUST waiting for spare part
15/05/2024 14:00	34.41	Maintenance	94.7	0	19.9	DUST waiting for spare part
15/05/2024 15:00	34.46	Maintenance	95.29	0	19.9	DUST waiting for spare part
15/05/2024 16:00	34.36	<Samp	95.17	0	20	DUST waiting for spare part
15/05/2024 17:00	34.19	Maintenance	94.34	0	19.6	DUST waiting for spare part
15/05/2024 18:00	34.07	Maintenance	94.51	0	19.5	DUST waiting for spare part
15/05/2024 19:00	33.88	Maintenance	94.17	0	19.3	DUST waiting for spare part
15/05/2024 20:00	33.98	Maintenance	94.15	0	19.2	DUST waiting for spare part
15/05/2024 21:00	34.21	Maintenance	94.51	0	19.1	DUST waiting for spare part
15/05/2024 22:00	34.27	Maintenance	94.49	0	19	DUST waiting for spare part
15/05/2024 23:00	34.13	Maintenance	94.49	0	19	DUST waiting for spare part
16/05/2024 00:00	7.85	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	7.85	92.74	0	0	19	
MinDate	16/05/2024 00:00	15/05/2024 00:00	15/05/2024 13:00	15/05/2024 00:00	15/05/2024 22:00	
Maximum	48.11	---	96.34	0	39	
MaxDate	15/05/2024 05:00	15/05/2024 00:00	15/05/2024 10:00	15/05/2024 00:00	15/05/2024 01:00	
Avg	37.02	---	95.01	0	28.1	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	9.2	---	0.9	0	9.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/05/2024 00:00	40.36	0	95.5	1.5	40.2	
16/05/2024 01:00	48.35	0	95.23	1.4	38.2	
16/05/2024 02:00	48.45	0	95.49	1.5	37.8	
16/05/2024 03:00	48.38	0	95.54	1.5	37.6	
16/05/2024 04:00	48.51	0	95.57	1.5	37.3	
16/05/2024 05:00	48.44	0	95.65	1.5	37.3	
16/05/2024 06:00	48.32	0.26	95.7	1.5	36.9	
16/05/2024 07:00	48.2	0	95.77	1.5	36.5	
16/05/2024 08:00	43.85	0	96.27	1.5	35.4	
16/05/2024 09:00	32.43	0	95.13	1.5	31.6	
16/05/2024 10:00	34.48	0	95.75	1.5	25.6	
16/05/2024 11:00	34.43	0	95.11	1.4	25.9	
16/05/2024 12:00	25.26	0	92.92	1.5	44.5	
16/05/2024 13:00	31.33	0	93.73	1.5	34.7	
16/05/2024 14:00	34.32	0	93.79	1.4	25.8	
16/05/2024 15:00	34.13	0	94.41	1.4	25.3	
16/05/2024 16:00	34.2	0	94.62	1.5	25.1	
16/05/2024 17:00	34.12	0	94.61	1.5	24.9	
16/05/2024 18:00	34	0	94.54	1.5	26	
16/05/2024 19:00	33.91	0	94.45	1.5	24.9	
16/05/2024 20:00	34.06	0	94.51	1.5	24.8	
16/05/2024 21:00	34.28	0	94.83	1.5	24.6	
16/05/2024 22:00	34.26	0	94.84	1.5	24.5	
16/05/2024 23:00	34.11	0	94.78	1.5	24.4	
17/05/2024 00:00	8.43	0	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	8.43	0	92.92	1.4	24.4	
MinDate	17/05/2024 00:00	16/05/2024 00:00	16/05/2024 12:00	16/05/2024 01:00	16/05/2024 23:00	
Maximum	48.51	0.26	96.27	1.5	44.5	
MaxDate	16/05/2024 04:00	16/05/2024 06:00	16/05/2024 08:00	16/05/2024 00:00	16/05/2024 12:00	
Avg	37.22	0.01	94.96	1.5	31.2	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	9.3	0.1	0.8	0	6.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/05/2024 00:00	7.85	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 08:00	5.86	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
16/05/2024 09:00	32.34	Maintenance	96.45	0	26.9	DUST waiting for spare part
16/05/2024 10:00	34.42	Maintenance	95.6	0	21	DUST waiting for spare part
16/05/2024 11:00	34.36	Maintenance	95.12	0	21.2	DUST waiting for spare part
16/05/2024 12:00	25.24	Maintenance	92.68	0	39.7	DUST waiting for spare part
16/05/2024 13:00	31.24	Maintenance	93.55	0	29.9	DUST waiting for spare part
16/05/2024 14:00	34.26	<Samp	93.69	0	21.1	DUST waiting for spare part
16/05/2024 15:00	34.08	<Samp	94.23	0	20.7	DUST waiting for spare part
16/05/2024 16:00	34.14	<Samp	94.64	0	20.5	DUST waiting for spare part
16/05/2024 17:00	34.06	<Samp	94.66	0	20.1	DUST waiting for spare part
16/05/2024 18:00	33.93	<Samp	94.61	0	20.2	DUST waiting for spare part
16/05/2024 19:00	33.85	<Samp	94.48	0	20.3	DUST waiting for spare part
16/05/2024 20:00	33.99	<Samp	94.55	0	20.1	DUST waiting for spare part
16/05/2024 21:00	34.22	<Samp	94.71	0	19.8	DUST waiting for spare part
16/05/2024 22:00	34.2	<Samp	94.7	0	19.8	DUST waiting for spare part
16/05/2024 23:00	34.05	Audit	94.63	0	19.8	DUST waiting for spare part
17/05/2024 00:00	39.91	<Samp	95.45	0	37.2	DUST waiting for spare part
Minimum	0	---	92.68	0	19.8	
MinDate	16/05/2024 01:00	16/05/2024 00:00	16/05/2024 12:00	16/05/2024 09:00	16/05/2024 21:00	
Maximum	39.91	---	96.45	0	39.7	
MaxDate	17/05/2024 00:00	16/05/2024 00:00	16/05/2024 09:00	16/05/2024 09:00	16/05/2024 12:00	
Avg	22.08	---	94.61	0	23.6	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	16	---	0.9	0	6.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/05/2024 00:00	8.43	0	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
<17/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 06:00	0	0.19	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 08:00	4.56	0.01	ShutDown	ShutDown	ShutDown	GT11 SD
17/05/2024 09:00	32.42	0	95.82	1.6	34.7	
17/05/2024 10:00	34.48	0	95.88	1.6	28	
17/05/2024 11:00	34.35	0	96.05	1.6	27.7	
17/05/2024 12:00	25.25	0	93.8	1.7	42.6	
17/05/2024 13:00	31.33	0	94.27	1.6	34.8	
17/05/2024 14:00	34.4	0	95.06	1.6	27.3	
17/05/2024 15:00	34.33	0	94.65	1.5	26.8	
17/05/2024 16:00	34.23	0	95.05	1.5	26.7	
17/05/2024 17:00	34.12	0	95.11	1.5	26.6	
17/05/2024 18:00	34.03	0	94.98	1.5	26.5	
17/05/2024 19:00	33.96	0	94.84	1.5	26.3	
17/05/2024 20:00	34.01	0	94.87	1.5	26.2	
17/05/2024 21:00	34.31	0	95.36	1.5	26.2	
17/05/2024 22:00	37.24	0	96.81	1.5	27.3	
17/05/2024 23:00	38.25	0	97.75	1.5	27.9	
18/05/2024 00:00	28.06	0	94.39	1.6	42.4	
Minimum	0	0	93.8	1.5	26.2	
MnDate	17/05/2024 01:00	17/05/2024 00:00	17/05/2024 12:00	17/05/2024 15:00	17/05/2024 20:00	
Maximum	38.25	0.19	97.75	1.7	42.6	
MaxDate	17/05/2024 23:00	17/05/2024 06:00	17/05/2024 23:00	17/05/2024 12:00	17/05/2024 12:00	
Avg	21.91	0.01	95.29	1.6	29.9	
Num	25	25	16	16	16	
Data(%)	100	100	64	64	64	
STD	16	0	1	0.1	5.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/05/2024 00:00	39.91	<Samp	95.45	0	37.2	DUST waiting for spare part
17/05/2024 01:00	48.4	<Samp	94.84	0	38.9	DUST waiting for spare part
17/05/2024 02:00	48.81	0.66	94.89	0	40.1	DUST waiting for spare part
17/05/2024 03:00	48.82	<Samp	95.47	0	40	DUST waiting for spare part
17/05/2024 04:00	48.7	<Samp	95.65	0	39.2	DUST waiting for spare part
17/05/2024 05:00	48.55	0.36	95.81	0	38.1	DUST waiting for spare part
17/05/2024 06:00	48.48	0	95.93	0	37.6	
17/05/2024 07:00	48.11	0	95.56	0	37.9	
17/05/2024 08:00	44.84	<Samp	95.99	0	35.3	DUST waiting for spare part
17/05/2024 09:00	32.33	Maintenance	95.07	0	27	DUST waiting for spare part
17/05/2024 10:00	34.42	<Samp	95.54	0	19.7	DUST waiting for spare part
17/05/2024 11:00	34.29	Maintenance	95.83	0	19.6	DUST waiting for spare part
17/05/2024 12:00	25.22	Maintenance	93.66	0	36.1	DUST waiting for spare part
17/05/2024 13:00	31.25	Maintenance	94.38	0	27.4	DUST waiting for spare part
17/05/2024 14:00	34.33	Maintenance	95.1	0	19.1	DUST waiting for spare part
17/05/2024 15:00	34.27	Maintenance	94.66	0	18.7	DUST waiting for spare part
17/05/2024 16:00	34.18	Maintenance	95.05	0	18.5	DUST waiting for spare part
17/05/2024 17:00	34.05	Maintenance	95.13	0	18.3	DUST waiting for spare part
17/05/2024 18:00	33.98	Maintenance	95.09	0	18.4	DUST waiting for spare part
17/05/2024 19:00	33.89	Maintenance	95.02	0	18.3	DUST waiting for spare part
17/05/2024 20:00	33.95	Maintenance	94.87	0	18.3	DUST waiting for spare part
17/05/2024 21:00	34.26	Maintenance	95.1	0	18.3	DUST waiting for spare part
17/05/2024 22:00	37.17	Maintenance	96.6	0	19.8	DUST waiting for spare part
17/05/2024 23:00	38.19	Maintenance	97.53	0	20.4	DUST waiting for spare part
18/05/2024 00:00	28	Maintenance	94.12	0	34	DUST waiting for spare part
Minimum	25.22	0	93.66	0	18.3	
MnDate	17/05/2024 12:00	17/05/2024 06:00	17/05/2024 12:00	17/05/2024 00:00	17/05/2024 17:00	
Maximum	48.82	0.66	97.53	0	40.1	
MaxDate	17/05/2024 03:00	17/05/2024 02:00	17/05/2024 23:00	17/05/2024 00:00	17/05/2024 02:00	
Avg	38.34	0.26	95.29	0	27.8	
Num	25	4	25	25	25	
Data(%)	100	16	100	100	100	
STD	7.4	0.3	0.8	0	9.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/05/2024 00:00	28.06	0	94.39	1.6	42.4	
18/05/2024 01:00	30.78	0	93.82	1.6	36.2	
18/05/2024 02:00	31.94	0	93.82	1.6	32.5	
18/05/2024 03:00	32.37	0	93.99	1.6	30.7	
18/05/2024 04:00	32.25	0	94.06	1.6	31.3	
18/05/2024 05:00	32.05	0	93.88	1.6	32.9	
18/05/2024 06:00	32.03	0.38	94.08	1.6	32.9	
18/05/2024 07:00	32.09	0	94.47	1.6	31.4	
18/05/2024 08:00	32.34	0	94.92	1.6	29.1	
18/05/2024 09:00	42.47	0	99.16	1.6	32.4	
18/05/2024 10:00	46.24	0	101.59	1.6	32.3	
18/05/2024 11:00	46.31	0	101.82	1.6	31.5	
18/05/2024 12:00	35.74	0	97.58	1.6	30.5	
18/05/2024 13:00	42.65	0	98.53	1.6	30.9	
18/05/2024 14:00	46.27	0	102.37	1.6	31.6	
18/05/2024 15:00	46.28	0	102.12	1.6	31.3	
18/05/2024 16:00	46.18	0	102.06	1.6	31	
18/05/2024 17:00	46.13	0	102.17	1.6	30.9	
18/05/2024 18:00	45.97	0	102.1	1.6	30.2	
18/05/2024 19:00	46.42	0	101.97	1.6	30.6	
18/05/2024 20:00	46.44	0	101.69	1.6	30.5	
18/05/2024 21:00	46.31	0	102.2	1.6	30	
18/05/2024 22:00	46.26	0	102.43	1.6	29.4	
18/05/2024 23:00	46.18	0	102.56	1.6	28.9	
19/05/2024 00:00	32.13	0	95.58	1.6	30.7	
Minimum	28.06	0	93.82	1.6	28.9	
MinDate	18/05/2024 00:00	18/05/2024 00:00	18/05/2024 01:00	18/05/2024 00:00	18/05/2024 23:00	
Maximum	46.44	0.38	102.56	1.6	32.4	
MaxDate	18/05/2024 20:00	18/05/2024 06:00	18/05/2024 23:00	18/05/2024 00:00	18/05/2024 00:00	
Avg	39.67	0.02	98.53	1.6	31.7	
Num	25	25	25	25	25	
Data (%)	100	100	100	100	100	
STD	7.1	0.1	3.7		2.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/05/2024 00:00	28	Maintenance	94.12	0	34	DUST waiting for spare part
18/05/2024 01:00	30.72	Maintenance	93.64	0	27.9	DUST waiting for spare part
18/05/2024 02:00	31.88	Maintenance	93.81	0	24.5	DUST waiting for spare part
18/05/2024 03:00	32.31	Maintenance	93.98	0	22.9	DUST waiting for spare part
18/05/2024 04:00	32.19	Maintenance	94	0	23.7	DUST waiting for spare part
18/05/2024 05:00	31.99	Maintenance	93.84	0	25	DUST waiting for spare part
18/05/2024 06:00	31.97	Maintenance	93.97	0	25.2	DUST waiting for spare part
18/05/2024 07:00	32.03	Maintenance	94.36	0	23.4	DUST waiting for spare part
18/05/2024 08:00	32.18	Maintenance	94.72	0	21.4	DUST waiting for spare part
18/05/2024 09:00	42.35	Maintenance	99.03	0	28.9	DUST waiting for spare part
18/05/2024 10:00	46.16	<Samp	102.71	0	30.4	DUST waiting for spare part
18/05/2024 11:00	46.24	0.04	103.29	0	28.8	DUST waiting for spare part
18/05/2024 12:00	35.66	0.1	98.59	0	24.4	DUST waiting for spare part
18/05/2024 13:00	42.57	0.14	99.33	0	26.8	DUST waiting for spare part
18/05/2024 14:00	46.19	<Samp	102.96	0	28.8	DUST waiting for spare part
18/05/2024 15:00	46.22	Maintenance	102.86	0	29	DUST waiting for spare part
18/05/2024 16:00	46.1	Maintenance	102.78	0	29	DUST waiting for spare part
18/05/2024 17:00	46.04	Maintenance	102.93	0	28.6	DUST waiting for spare part
18/05/2024 18:00	45.9	Maintenance	102.87	0	28	DUST waiting for spare part
18/05/2024 19:00	45.44	Maintenance	102.72	0	26.2	DUST waiting for spare part
18/05/2024 20:00	45.81	Maintenance	102.62	0	27	DUST waiting for spare part
18/05/2024 21:00	46.23	Maintenance	102.69	0	28.2	DUST waiting for spare part
18/05/2024 22:00	46.19	Maintenance	102.82	0	27.6	DUST waiting for spare part
18/05/2024 23:00	46.11	Maintenance	102.89	0	27	DUST waiting for spare part
19/05/2024 00:00	32.07	Maintenance	96.1	0	23.6	DUST waiting for spare part
Minimum	28	0.04	93.64	0	21.4	
MinDate	18/05/2024 00:00	18/05/2024 11:00	18/05/2024 01:00	18/05/2024 00:00	18/05/2024 08:00	
Maximum	46.24	0.14	103.29	0	34	
MaxDate	18/05/2024 11:00	18/05/2024 13:00	18/05/2024 11:00	18/05/2024 00:00	18/05/2024 00:00	
Avg	39.54	0.09	98.95	0	26.8	
Num	25	3	25	25	25	
Data (%)	100	12	100	100	100	
STD	7.1	0.1	4.1	0	2.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/05/2024 00:00	32.13	0	95.58	1.6	30.7	
19/05/2024 01:00	32.14	0	93.71	1.6	28.8	
19/05/2024 02:00	32.05	0	93.43	1.6	28.4	
19/05/2024 03:00	31.95	0	93.4	1.6	28.7	
19/05/2024 04:00	31.62	0	93.33	1.6	30.5	
19/05/2024 05:00	31.47	0	93.22	1.6	31.6	
19/05/2024 06:00	31.26	0.32	93.23	1.6	32.1	
19/05/2024 07:00	31.07	0	93.66	1.6	33.6	
19/05/2024 08:00	30.98	0	93.75	1.6	30.9	
19/05/2024 09:00	30.89	0	93.62	1.6	30.7	
19/05/2024 10:00	30.87	0	93.41	1.6	31.2	
19/05/2024 11:00	30.82	0	93.45	1.6	31.7	
19/05/2024 12:00	30.93	0	93.92	1.6	29.6	
19/05/2024 13:00	30.86	0	92.26	1.6	31.9	
19/05/2024 14:00	30.87	0	92.29	1.6	31.9	
19/05/2024 15:00	30.95	0	93.18	1.6	29.4	
19/05/2024 16:00	30.96	0	93.59	1.6	28.5	
19/05/2024 17:00	30.98	0	93.1	1.6	28.5	
19/05/2024 18:00	37.83	0	95.45	1.6	30.7	
19/05/2024 19:00	44.88	0	101.48	1.6	26.7	
19/05/2024 20:00	44.87	0	101.6	1.6	26.6	
19/05/2024 21:00	44.89	0	101.98	1.6	26.4	
19/05/2024 22:00	37.91	0	99.64	1.6	29.5	
19/05/2024 23:00	30.92	0	93.68	1.6	31.1	
20/05/2024 00:00	30.73	0	92.45	1.6	34.7	
Minimum	30.73	0	92.26	1.6	26.4	
MinDate	20/05/2024 00:00	19/05/2024 00:00	19/05/2024 13:00	19/05/2024 00:00	19/05/2024 21:00	
Maximum	44.89	0.32	101.98	1.6	34.7	
MaxDate	19/05/2024 21:00	19/05/2024 06:00	19/05/2024 21:00	19/05/2024 00:00	20/05/2024 00:00	
Avg	33.39	0.01	94.74	1.6	30.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.7	0.1	3	0	2.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/05/2024 00:00	32.07	Maintenance	96.1	0	23.6	DUST waiting for spare part
19/05/2024 01:00	32.08	Maintenance	94.35	0	21.8	DUST waiting for spare part
19/05/2024 02:00	31.99	Maintenance	94.14	0	21.4	DUST waiting for spare part
19/05/2024 03:00	31.89	Maintenance	94.05	0	21.7	DUST waiting for spare part
19/05/2024 04:00	31.56	<Samp	93.86	0	23.3	DUST waiting for spare part
19/05/2024 05:00	31.41	Maintenance	93.77	0	24.3	DUST waiting for spare part
19/05/2024 06:00	31.2	Maintenance	93.77	0	24.6	DUST waiting for spare part
19/05/2024 07:00	31.02	Maintenance	94.07	0	26.3	DUST waiting for spare part
19/05/2024 08:00	30.92	Maintenance	94.27	0	24	DUST waiting for spare part
19/05/2024 09:00	30.83	<Samp	94.22	0	24.1	DUST waiting for spare part
19/05/2024 10:00	30.81	Maintenance	93.99	0	24.5	DUST waiting for spare part
19/05/2024 11:00	30.76	Maintenance	94	0	24.6	DUST waiting for spare part
19/05/2024 12:00	30.87	Maintenance	94.41	0	22.9	DUST waiting for spare part
19/05/2024 13:00	30.8	<Samp	92.75	0	24.7	DUST waiting for spare part
19/05/2024 14:00	30.82	<Samp	92.72	0	24.6	DUST waiting for spare part
19/05/2024 15:00	30.9	Maintenance	93.77	0	22.4	DUST waiting for spare part
19/05/2024 16:00	30.9	Maintenance	94.06	0	21.9	DUST waiting for spare part
19/05/2024 17:00	30.91	Maintenance	93.77	0	22.1	DUST waiting for spare part
19/05/2024 18:00	37.74	Maintenance	96.26	0	26.1	DUST waiting for spare part
19/05/2024 19:00	44.8	<Samp	102.38	0	24.4	DUST waiting for spare part
19/05/2024 20:00	44.8	Maintenance	102.58	0	24	DUST waiting for spare part
19/05/2024 21:00	44.82	Maintenance	102.7	0	23.9	DUST waiting for spare part
19/05/2024 22:00	37.84	Maintenance	100.15	0	25.3	DUST waiting for spare part
19/05/2024 23:00	30.86	Maintenance	94.33	0	24.9	DUST waiting for spare part
20/05/2024 00:00	30.66	Maintenance	92.82	0	28.5	DUST waiting for spare part
Minimum	30.66	---	92.72	0	21.4	
MinDate	20/05/2024 00:00	19/05/2024 00:00	19/05/2024 14:00	19/05/2024 00:00	19/05/2024 02:00	
Maximum	44.82	---	102.7	0	28.5	
MaxDate	19/05/2024 21:00	19/05/2024 00:00	19/05/2024 21:00	19/05/2024 00:00	20/05/2024 00:00	
Avg	33.33	---	96.33	0	24	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.7	---	3.1	0	1.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/05/2024 00:00	30.73	0	92.45	1.6	34.7	
20/05/2024 01:00	30.77	0	92.63	1.6	34.1	
20/05/2024 02:00	30.77	0	92.71	1.6	33.7	
20/05/2024 03:00	30.75	0	92.81	1.6	33.9	
20/05/2024 04:00	30.73	0	92.78	1.6	33.4	
20/05/2024 05:00	30.79	0	92.66	1.6	33	
20/05/2024 06:00	30.79	0.26	92.84	1.6	32.9	
20/05/2024 07:00	31.02	0	93.22	1.6	31.9	
20/05/2024 08:00	30.74	0	93.87	1.6	30	
20/05/2024 09:00	31.18	0	94.2	1.7	30.8	
20/05/2024 10:00	34.22	0	95.4	1.6	22.9	
20/05/2024 11:00	34.35	0	95.82	1.6	22.6	
20/05/2024 12:00	25.23	0.01	90.75	1.7	42.1	
20/05/2024 13:00	31.41	0	91.65	1.6	30.7	
20/05/2024 14:00	34.38	0	93.45	1.5	22.6	
20/05/2024 15:00	34.38	0	93.7	1.6	22.3	
20/05/2024 16:00	34.35	0	94.11	1.6	23.7	
20/05/2024 17:00	34.17	0	94.25	1.6	21.7	
20/05/2024 18:00	34.13	0	94.36	1.6	21.7	
20/05/2024 19:00	33.95	0	94.3	1.6	21.6	
20/05/2024 20:00	33.82	0	94.31	1.6	21.5	
20/05/2024 21:00	34.09	0	94.74	1.6	21.6	
20/05/2024 22:00	34.12	0	94.87	1.6	21.6	
20/05/2024 23:00	34.15	0	94.86	1.6	21.5	
21/05/2024 00:00	40.01	0	95.44	1.6	33.6	
Minimum	25.23	0	90.75	1.5	21.5	
MinDate	20/05/2024 12:00	20/05/2024 00:00	20/05/2024 12:00	20/05/2024 14:00	20/05/2024 20:00	
Maximum	40.01	0.26	95.82	1.7	42.1	
MaxDate	21/05/2024 00:00	20/05/2024 06:00	20/05/2024 11:00	20/05/2024 09:00	20/05/2024 12:00	
Avg	32.61	0.01	93.69	1.6	28	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	2.7	0.1	1.2	0	6.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
20/05/2024 00:00	30.66	Maintenance	92.82	0	28.5	DUST waiting for spare part
20/05/2024 01:00	30.71	Maintenance	93.13	0	27.5	DUST waiting for spare part
20/05/2024 02:00	30.71	Maintenance	93.26	0	27.3	DUST waiting for spare part
20/05/2024 03:00	30.69	Maintenance	93.36	0	27.7	DUST waiting for spare part
20/05/2024 04:00	30.67	Maintenance	93.31	0	26.8	DUST waiting for spare part
20/05/2024 05:00	30.74	Maintenance	93.27	0	26.4	DUST waiting for spare part
20/05/2024 06:00	30.72	Maintenance	93.36	0	26.3	DUST waiting for spare part
20/05/2024 07:00	30.96	Maintenance	93.74	0	25.3	DUST waiting for spare part
20/05/2024 08:00	30.69	Maintenance	94.29	0	23.9	DUST waiting for spare part
20/05/2024 09:00	31.13	Maintenance	94.75	0	25.5	DUST waiting for spare part
20/05/2024 10:00	34.16	Maintenance	95.69	0	17.4	DUST waiting for spare part
20/05/2024 11:00	34.3	Maintenance	96.17	0	17.1	DUST waiting for spare part
20/05/2024 12:00	25.21	Maintenance	91.56	0	36.8	DUST waiting for spare part
20/05/2024 13:00	31.38	Maintenance	92.3	0	25.3	DUST waiting for spare part
20/05/2024 14:00	34.33	Maintenance	93.77	0	17.2	DUST waiting for spare part
20/05/2024 15:00	34.32	Maintenance	94.18	0	17	DUST waiting for spare part
20/05/2024 16:00	34.29	Maintenance	94.59	0	18.4	DUST waiting for spare part
20/05/2024 17:00	34.11	Maintenance	94.68	0	16.6	DUST waiting for spare part
20/05/2024 18:00	34.06	Maintenance	94.87	0	16.6	DUST waiting for spare part
20/05/2024 19:00	33.88	Maintenance	94.79	0	16.5	DUST waiting for spare part
20/05/2024 20:00	33.86	Maintenance	94.84	0	16.4	DUST waiting for spare part
20/05/2024 21:00	34.03	Maintenance	95.17	0	16.4	DUST waiting for spare part
20/05/2024 22:00	34.06	<Samp	95.27	0	16.4	DUST waiting for spare part
20/05/2024 23:00	34.09	<Samp	95.29	0	16.3	DUST waiting for spare part
21/05/2024 00:00	8.39	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
Minimum	8.39	---	91.56	0	16.3	
MinDate	21/05/2024 00:00	20/05/2024 00:00	20/05/2024 12:00	20/05/2024 00:00	20/05/2024 23:00	
Maximum	34.33	---	96.17	0	36.8	
MaxDate	20/05/2024 14:00	20/05/2024 00:00	20/05/2024 11:00	20/05/2024 00:00	20/05/2024 12:00	
Avg	31.29	---	94.1	0	22.1	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	5.2	---	1.1	0	5.8	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG SO2@7%O2	11HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/05/2024 00:00	40.01	0	95.44	1.6	33.6	
21/05/2024 01:00	48.24	0	95.76	1.6	31	
21/05/2024 02:00	48.25	0	95.95	1.6	30.9	
21/05/2024 03:00	48.48	0	95.99	1.6	31	
21/05/2024 04:00	48.55	0	95.38	1.6	31.2	
21/05/2024 05:00	48.66	0	95.44	1.6	31.4	
21/05/2024 06:00	48.7	0.19	95.7	1.6	31.3	
21/05/2024 07:00	48.62	0	95.34	1.6	31.5	
21/05/2024 08:00	45.17	0	96.07	1.6	30	
21/05/2024 09:00	32.3	0	94.67	1.6	28.7	
21/05/2024 10:00	34.2	0	94.81	1.6	21.4	
21/05/2024 11:00	34.31	0	94.69	1.6	21.3	
21/05/2024 12:00	25.02	0	92.85	1.7	40.5	
21/05/2024 13:00	31.36	0	93.48	1.6	30.6	
21/05/2024 14:00	34.48	0	95.03	1.6	21.4	
21/05/2024 15:00	34.32	0	93.84	1.6	21.5	
21/05/2024 16:00	34.21	0	93.14	1.6	21.5	
21/05/2024 17:00	34.05	0	93.41	1.6	21.4	
21/05/2024 18:00	34.06	0	93.49	1.6	21.4	
21/05/2024 19:00	33.86	0	93.77	1.6	21.4	
21/05/2024 20:00	33.98	0	93.8	1.6	21.4	
21/05/2024 21:00	34.22	0	94.22	1.6	21.3	
21/05/2024 22:00	37.28	0	95.71	1.6	21.8	
21/05/2024 23:00	39.04	0	96.77	1.6	22.4	
22/05/2024 00:00	28.12	0	93.53	1.7	39.5	
Minimum	25.02	0	92.85	1.6	21.3	
MinDate	21/05/2024 12:00	21/05/2024 00:00	21/05/2024 12:00	21/05/2024 00:00	21/05/2024 11:00	
Maximum	48.7	0.19	96.77	1.7	40.5	
MaxDate	21/05/2024 06:00	21/05/2024 06:00	21/05/2024 23:00	21/05/2024 12:00	21/05/2024 12:00	
Avg	38.38	0.01	94.73	1.6	27.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.4	0	1.1	0	6.1	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG SO2@7%O2	12HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/05/2024 00:00	8.39	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 08:00	4.66	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/05/2024 09:00	32.11	Maintenance	95.36	0	28.9	DUST waiting for spare part
21/05/2024 10:00	34.14	Maintenance	95.24	0	21.3	DUST waiting for spare part
21/05/2024 11:00	34.25	0	95.13	0	21.1	
21/05/2024 12:00	25	0.31	93.31	0	37.4	
21/05/2024 13:00	31.36	0.05	94.12	0	29.3	
21/05/2024 14:00	34.3	0.07	95.43	0	21.2	
21/05/2024 15:00	34.26	0.08	94.53	0	21.1	
21/05/2024 16:00	34.15	0.01	93.83	0	21.1	
21/05/2024 17:00	33.99	<Samp	94.08	0	20.8	DUST waiting for spare part
21/05/2024 18:00	33.99	Maintenance	94.2	0	20.8	DUST waiting for spare part
21/05/2024 19:00	33.8	<Samp	94.47	0	20.9	DUST waiting for spare part
21/05/2024 20:00	33.92	<Samp	94.5	0	20.7	DUST waiting for spare part
21/05/2024 21:00	34.16	Maintenance	94.83	0	20.5	DUST waiting for spare part
21/05/2024 22:00	37.22	<Samp	96.35	0	21.9	DUST waiting for spare part
21/05/2024 23:00	38.98	0.04	97.46	0	22.9	DUST waiting for spare part
22/05/2024 00:00	28.05	0.82	94.06	0	37.2	DUST waiting for spare part
Minimum	0	0	93.31	0	20.5	
MinDate	21/05/2024 01:00	21/05/2024 11:00	21/05/2024 12:00	21/05/2024 09:00	21/05/2024 21:00	
Maximum	38.98	0.82	97.46	0	37.4	
MaxDate	21/05/2024 23:00	22/05/2024 00:00	21/05/2024 23:00	21/05/2024 09:00	21/05/2024 12:00	
Avg	21.87	0.17	94.87	0	24.2	
Num	25	8	16	16	16	
Data[%]	100	32	64	64	64	
STD	15.9	0.3	1.1	0	5.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/05/2024 00:00	28.12	0	93.53	1.7	39.5	
22/05/2024 01:00	30.51	0	92.52	1.6	32.9	
22/05/2024 02:00	31.64	0	92.79	1.6	28.2	
22/05/2024 03:00	31.91	0	93.14	1.6	27.2	
22/05/2024 04:00	31.91	0	92.94	1.6	26.9	
22/05/2024 05:00	31.9	0	93.2	1.6	27.2	
22/05/2024 06:00	31.83	0.38	93.44	1.6	27.5	
22/05/2024 07:00	31.86	0	93.63	1.6	26.6	
22/05/2024 08:00	32.11	0	94.01	1.6	24.5	
22/05/2024 09:00	42.73	0	98.45	1.6	25.3	
22/05/2024 10:00	46.37	0	102.51	1.6	26	
22/05/2024 11:00	46.36	0	102.67	1.6	25.8	
22/05/2024 12:00	35.91	0	98.65	1.5	23.7	
22/05/2024 13:00	42.68	0	98.49	1.5	25.1	
22/05/2024 14:00	46.35	0	101.93	1.5	26.7	
22/05/2024 15:00	46.28	0	101.76	1.5	27.3	
22/05/2024 16:00	46.11	0	101.54	1.5	26.2	
22/05/2024 17:00	46.08	0	101.38	1.5	25.6	
22/05/2024 18:00	46.16	0	101.35	1.5	24.9	
22/05/2024 19:00	46.08	0	101.58	1.5	23.8	
22/05/2024 20:00	46.17	0	101.85	1.5	23.6	
22/05/2024 21:00	46.36	0	102.44	1.5	23.7	
22/05/2024 22:00	46.31	0	102.65	1.5	23.4	
22/05/2024 23:00	46.19	0	102.71	1.5	23.2	
23/05/2024 00:00	32.18	0	95.54	1.5	24.2	
Minimum	28.12	0	92.52	1.5	23.2	
MinDate	22/05/2024 00:00	22/05/2024 00:00	22/05/2024 01:00	22/05/2024 12:00	22/05/2024 23:00	
Maximum	46.37	0.38	102.71	1.7	39.5	
MaxDate	22/05/2024 10:00	22/05/2024 06:00	22/05/2024 23:00	22/05/2024 00:00	22/05/2024 00:00	
Avg	39.6	0.02	98.19	1.6	26.4	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.2	0.1	4.1	0.1	3.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/05/2024 00:00	28.05	0.82	94.06	0	37.2	
22/05/2024 01:00	30.46	<Samp	93	0	32.5	DUST waiting for spare part
22/05/2024 02:00	31.58	0.38	93.32	0	29.4	
22/05/2024 03:00	31.86	0.11	93.65	0	28.4	
22/05/2024 04:00	31.86	0.16	93.51	0	28.2	
22/05/2024 05:00	31.84	0.18	93.72	0	28.7	
22/05/2024 06:00	31.76	0.23	93.89	0	28.9	
22/05/2024 07:00	31.82	0.26	93.97	0	27.7	
22/05/2024 08:00	32.05	<Samp	94.36	0	25.6	DUST waiting for spare part
22/05/2024 09:00	42.54	Maintenance	98.81	0	30.4	DUST waiting for spare part
22/05/2024 10:00	46.29	Maintenance	102.48	0	33.9	DUST waiting for spare part
22/05/2024 11:00	46.29	Maintenance	102.75	0	33.2	DUST waiting for spare part
22/05/2024 12:00	35.84	Maintenance	98.69	0	25.7	DUST waiting for spare part
22/05/2024 13:00	42.57	Maintenance	99.2	0	29.6	DUST waiting for spare part
22/05/2024 14:00	46.28	Maintenance	102.32	0	34.2	DUST waiting for spare part
22/05/2024 15:00	46.21	Maintenance	102.35	0	35.1	DUST waiting for spare part
22/05/2024 16:00	46.04	Maintenance	102.24	0	33.4	DUST waiting for spare part
22/05/2024 17:00	46	Maintenance	102.09	0	32.6	DUST waiting for spare part
22/05/2024 18:00	46.08	<Samp	102.16	0	31.5	DUST waiting for spare part
22/05/2024 19:00	46	<Samp	102.36	0	30.2	DUST waiting for spare part
22/05/2024 20:00	46.09	Maintenance	102.68	0	29.7	DUST waiting for spare part
22/05/2024 21:00	46.28	<Samp	103.23	0	29.6	DUST waiting for spare part
22/05/2024 22:00	46.23	<Samp	103.45	0	29.1	DUST waiting for spare part
22/05/2024 23:00	46.12	<Samp	103.41	0	29.1	DUST waiting for spare part
23/05/2024 00:00	32.1	<Samp	96.07	0	24.9	DUST waiting for spare part
Minimum	28.05	0.11	93	0	24.9	
MinDate	22/05/2024 00:00	22/05/2024 03:00	22/05/2024 01:00	22/05/2024 00:00	23/05/2024 00:00	
Maximum	46.29	0.82	103.45	0	37.2	
MaxDate	22/05/2024 10:00	22/05/2024 00:00	22/05/2024 22:00	22/05/2024 00:00	22/05/2024 00:00	
Avg	39.53	0.31	98.71	0	30.4	
Num	25	7	25	25	25	
Data[%]	100	28	100	100	100	
STD	7.2	0.2	4.2	0	3.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/05/2024 00:00	32.18	0	95.54	1.5	24.2	
23/05/2024 01:00	32.11	0	93.18	1.5	23.3	
23/05/2024 02:00	32.12	0	92.7	1.5	24.3	
23/05/2024 03:00	32.08	0	92.61	1.5	24.5	
23/05/2024 04:00	31.99	0	92.04	1.5	24.8	
23/05/2024 05:00	31.93	0	92.6	1.5	25.2	
23/05/2024 06:00	31.89	0.32	92.43	1.5	25.3	
23/05/2024 07:00	31.82	0	92.74	1.6	25.5	
23/05/2024 08:00	29.69	0	92.71	1.6	30.1	
23/05/2024 09:00	31.48	0	93.47	1.6	29.1	
23/05/2024 10:00	34.43	0	95	1.6	20.8	
23/05/2024 11:00	34.4	0	94.89	1.5	20.9	
23/05/2024 12:00	25.18	0	92.64	1.6	37	
23/05/2024 13:00	31.33	0	92.2	1.5	27.5	
23/05/2024 14:00	34.22	0	93.88	1.5	20.9	
23/05/2024 15:00	34.45	0	94.24	1.5	20.8	
23/05/2024 16:00	34.25	0	94.21	1.5	20.7	
23/05/2024 17:00	34.07	0	93.78	1.5	20.7	
23/05/2024 18:00	34.04	0	93.88	1.5	20.7	
23/05/2024 19:00	33.91	0	93.75	1.5	20.7	
23/05/2024 20:00	34.09	0	93.69	1.5	20.7	
23/05/2024 21:00	34.21	0	94.01	1.5	20.8	
23/05/2024 22:00	34.15	0	93.88	1.5	21	
23/05/2024 23:00	34.01	0	93.98	1.5	20.8	
24/05/2024 00:00	7.75	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	7.75	0	92.04	1.5	20.7	
MinDate	24/05/2024 00:00	23/05/2024 00:00	23/05/2024 04:00	23/05/2024 00:00	23/05/2024 16:00	
Maximum	34.45	0.32	95.54	1.6	37	
MaxDate	23/05/2024 15:00	23/05/2024 06:00	23/05/2024 00:00	23/05/2024 07:00	23/05/2024 12:00	
Avg	31.67	0.01	93.5	1.5	23.8	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	5.4	0.1	0.9	0	4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/05/2024 00:00	32.1	<Samp	96.07	0	24.9	DUST waiting for spare part
23/05/2024 01:00	32.04	<Samp	93.67	0	25.2	DUST waiting for spare part
23/05/2024 02:00	32.06	<Samp	93.17	0	26.2	DUST waiting for spare part
23/05/2024 03:00	32.02	0.4	93.03	0	26.2	
23/05/2024 04:00	31.93	0.27	92.45	0	26.5	
23/05/2024 05:00	31.86	0.03	92.93	0	26.5	
23/05/2024 06:00	31.82	0.33	92.71	0	26.8	
23/05/2024 07:00	31.76	0.09	93.08	0	26.7	
23/05/2024 08:00	29.63	0.11	92.98	0	30.2	
23/05/2024 09:00	31.36	0.21	93.79	0	26.6	
23/05/2024 10:00	34.37	0.32	95.2	0	18.2	
23/05/2024 11:00	34.34	0.32	95.12	0	18.2	
23/05/2024 12:00	25.18	0.31	92.9	0	34.8	
23/05/2024 13:00	31.22	0.27	92.84	0	25.4	
23/05/2024 14:00	34.14	0.18	94.47	0	18.1	
23/05/2024 15:00	34.39	0.21	94.98	0	17.8	
23/05/2024 16:00	34.18	0.29	95.08	0	17.6	
23/05/2024 17:00	34	0.29	94.6	0	17.6	
23/05/2024 18:00	33.97	0.25	94.73	0	17.5	
23/05/2024 19:00	33.85	0.25	94.61	0	17.5	
23/05/2024 20:00	34.03	0.23	94.54	0	17.6	
23/05/2024 21:00	34.15	0.21	94.73	0	17.7	
23/05/2024 22:00	34.09	0.18	94.6	0	17.8	
23/05/2024 23:00	33.94	0.19	94.63	0	17.6	
24/05/2024 00:00	40.52	0.18	95.22	0	35.4	
Minimum	25.18	0.03	92.45	0	17.5	
MinDate	23/05/2024 12:00	23/05/2024 05:00	23/05/2024 04:00	23/05/2024 00:00	23/05/2024 18:00	
Maximum	40.52	0.4	96.07	0	35.4	
MaxDate	24/05/2024 00:00	23/05/2024 03:00	23/05/2024 00:00	23/05/2024 00:00	24/05/2024 00:00	
Avg	32.92	0.23	94.09	0	23	
Num	25	22	25	25	25	
Data[%]	100	88	100	100	100	
STD	2.6	0.1	1	0	5.7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
24/05/2024 00:00	7.75	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 06:00	0	0.27	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 08:00	5.97	0	ShutDown	ShutDown	ShutDown	GT11 S/D
24/05/2024 09:00	32.21	0	94.36	1.7	34.4	
24/05/2024 10:00	34.26	0	95.01	1.6	28.1	
24/05/2024 11:00	34.33	0	95.44	1.6	27.8	
24/05/2024 12:00	25.19	0	93.93	1.7	44.7	
24/05/2024 13:00	31.32	0	94.54	1.7	35.7	
24/05/2024 14:00	34.36	0	95.97	1.6	28.3	
24/05/2024 15:00	34.35	0	95.53	1.6	28.2	
24/05/2024 16:00	34.25	0	95.15	1.6	27.5	
24/05/2024 17:00	34.15	0	94.67	1.5	27.1	
24/05/2024 18:00	34.12	0	94.41	1.5	27.2	
24/05/2024 19:00	33.86	0	94.59	1.5	27	
24/05/2024 20:00	33.93	0	94.61	1.5	26.9	
24/05/2024 21:00	34.17	0	95.07	1.5	26.8	
24/05/2024 22:00	37.01	0	96.75	1.6	27.9	
24/05/2024 23:00	38.88	0	97.99	1.6	28.7	
25/05/2024 00:00	28.3	0	94.12	1.6	43.2	
Minimum	0	0	93.93	1.5	26.8	
MinDate	24/05/2024 01:00	24/05/2024 00:00	24/05/2024 12:00	24/05/2024 17:00	24/05/2024 21:00	
Maximum	38.88	0.27	97.99	1.7	44.7	
MaxDate	24/05/2024 23:00	24/05/2024 06:00	24/05/2024 23:00	24/05/2024 09:00	24/05/2024 12:00	
Avg	21.94	0.01	95.13	1.6	30.6	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.9	0.1	1	0.1	5.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
24/05/2024 00:00	40.52	0.18	95.22	0	35.4	
24/05/2024 01:00	48.65	0.16	94.74	0	35.6	
24/05/2024 02:00	48.71	0.16	94.9	0	35.5	
24/05/2024 03:00	48.8	0.19	95.34	0	35.6	
24/05/2024 04:00	48.55	0.2	95.55	0	34.5	
24/05/2024 05:00	48.47	0.24	95.72	0	33.9	
24/05/2024 06:00	48.63	0.32	95.76	0	33.8	
24/05/2024 07:00	48.45	0.04	95.5	0	33.8	
24/05/2024 08:00	43.81	0	95.67	0	31.5	
24/05/2024 09:00	32.14	0.02	93.83	0	24.4	
24/05/2024 10:00	34.19	0.09	94.48	0	17.2	
24/05/2024 11:00	34.26	0.17	94.92	0	17.1	
24/05/2024 12:00	25.17	0.21	93.49	0	36.2	
24/05/2024 13:00	31.23	<Samp	94.26	0	26.1	DUST waiting for spare part
24/05/2024 14:00	34.3	Maintenance	95.65	0	17.3	DUST waiting for spare part
24/05/2024 15:00	34.29	Maintenance	95.35	0	17.2	DUST waiting for spare part
24/05/2024 16:00	34.19	Maintenance	95.04	0	16.6	DUST waiting for spare part
24/05/2024 17:00	34.09	Maintenance	94.73	0	16.4	DUST waiting for spare part
24/05/2024 18:00	34.06	Maintenance	94.39	0	16.5	DUST waiting for spare part
24/05/2024 19:00	33.8	<Samp	94.32	0	16.5	DUST waiting for spare part
24/05/2024 20:00	33.86	<Samp	94.27	0	16.5	DUST waiting for spare part
24/05/2024 21:00	34.11	<Samp	94.64	0	16.6	DUST waiting for spare part
24/05/2024 22:00	36.94	<Samp	96.2	0	17.6	DUST waiting for spare part
24/05/2024 23:00	38.82	<Samp	97.44	0	18.1	DUST waiting for spare part
25/05/2024 00:00	28.24	Maintenance	94.32	0	31.9	DUST waiting for spare part
Minimum	25.17	0	93.49	0	16.4	
MinDate	24/05/2024 12:00	24/05/2024 08:00	24/05/2024 12:00	24/05/2024 00:00	24/05/2024 17:00	
Maximum	48.8	0.32	97.44	0	36.2	
MaxDate	24/05/2024 03:00	24/05/2024 06:00	24/05/2024 23:00	24/05/2024 00:00	24/05/2024 12:00	
Avg	38.33	0.15	95.03	0	25.2	
Num	25	13	25	25	25	
Data[%]	100	52	100	100	100	
STD	7.4	0.1	0.8	0	8.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
25/05/2024 00:00	28.3	0	94.12	1.6	43.2	
25/05/2024 01:00	30.6	0	93.28	1.6	38.1	
25/05/2024 02:00	31.8	0	93.63	1.6	34.3	
25/05/2024 03:00	31.97	0	93.65	1.6	33.4	
25/05/2024 04:00	31.92	0	93.32	1.6	33.6	
25/05/2024 05:00	31.77	0	93.14	1.6	34.2	
25/05/2024 06:00	31.56	0.19	93.38	1.6	34.7	
25/05/2024 07:00	31.2	0	93.53	1.6	35.3	
25/05/2024 08:00	31.1	0	93.86	1.6	34.7	
25/05/2024 09:00	41.41	0	96.37	1.7	32.4	
25/05/2024 10:00	45.23	0	102.67	1.7	31.5	
25/05/2024 11:00	45.23	0	102.57	1.6	32.3	
25/05/2024 12:00	34.86	0	98.28	1.6	33	
25/05/2024 13:00	39.67	0.57	94.82	1.6	31.5	
25/05/2024 14:00	44.87	0.04	100.54	1.6	30.8	
25/05/2024 15:00	44.89	0	100.87	1.6	30.5	
25/05/2024 16:00	45.01	0	101.71	1.6	30	
25/05/2024 17:00	45.11	0	101.94	1.5	29.6	
25/05/2024 18:00	45.14	0	101.53	1.5	30.1	
25/05/2024 19:00	44.93	0	101.43	1.5	30.1	
25/05/2024 20:00	44.95	0	101.32	1.5	29.9	
25/05/2024 21:00	45.06	0	101.43	1.5	30	
25/05/2024 22:00	44.99	0	101.14	1.4	30.3	
25/05/2024 23:00	44.93	0	101.15	1.4	29.8	
26/05/2024 00:00	30.83	0	94.48	1.4	37.3	
Minimum	28.3	0	93.14	1.4	29.6	
MinDate	25/05/2024 00:00	25/05/2024 00:00	25/05/2024 05:00	25/05/2024 22:00	25/05/2024 17:00	
Maximum	45.23	0.57	102.67	1.7	43.2	
MaxDate	25/05/2024 10:00	25/05/2024 13:00	25/05/2024 10:00	25/05/2024 09:00	25/05/2024 00:00	
Avg	38.69	0.03	97.85	1.6	32.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.7	0.1	3.8	0.1	3.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/h3	Degree C	ppm	ppm	
25/05/2024 00:00	28.24	Maintenance	94.32	0	31.9	DUST waiting for spare part
25/05/2024 01:00	30.53	Maintenance	93.81	0	26.3	DUST waiting for spare part
25/05/2024 02:00	31.72	Maintenance	94.14	0	22.4	DUST waiting for spare part
25/05/2024 03:00	31.91	Maintenance	94.19	0	21.4	DUST waiting for spare part
25/05/2024 04:00	31.85	Maintenance	93.85	0	21.5	DUST waiting for spare part
25/05/2024 05:00	31.7	Maintenance	93.6	0	22.2	DUST waiting for spare part
25/05/2024 06:00	31.5	Maintenance	93.86	0	23	DUST waiting for spare part
25/05/2024 07:00	31.13	Maintenance	94.02	0	23.6	DUST waiting for spare part
25/05/2024 08:00	31.04	Maintenance	94.27	0	22.9	DUST waiting for spare part
25/05/2024 09:00	41.29	Maintenance	98.95	0	23.9	DUST waiting for spare part
25/05/2024 10:00	45.15	Maintenance	102.9	0	24.6	DUST waiting for spare part
25/05/2024 11:00	45.15	Maintenance	102.77	0	25.6	DUST waiting for spare part
25/05/2024 12:00	34.79	Maintenance	98.49	0	22.6	DUST waiting for spare part
25/05/2024 13:00	39.62	Maintenance	95.72	0	21.3	DUST waiting for spare part
25/05/2024 14:00	44.75	Maintenance	100.56	0	22.2	DUST waiting for spare part
25/05/2024 15:00	44.81	Maintenance	101.08	0	21.9	DUST waiting for spare part
25/05/2024 16:00	44.94	Maintenance	102.06	0	22.2	DUST waiting for spare part
25/05/2024 17:00	45.04	Maintenance	102.37	0	22	DUST waiting for spare part
25/05/2024 18:00	45.06	Maintenance	101.93	0	22	DUST waiting for spare part
25/05/2024 19:00	44.85	Maintenance	101.81	0	21.7	DUST waiting for spare part
25/05/2024 20:00	44.87	Maintenance	101.74	0	21.7	DUST waiting for spare part
25/05/2024 21:00	44.95	Maintenance	101.69	0	21.7	DUST waiting for spare part
25/05/2024 22:00	44.91	Maintenance	101.36	0	21.7	DUST waiting for spare part
25/05/2024 23:00	44.85	Maintenance	101.25	0	21.2	DUST waiting for spare part
26/05/2024 00:00	30.74	Maintenance	94.53	0	26.3	DUST waiting for spare part
Minimum	28.24	---	93.6	0	21.2	DUST waiting for spare part
MinDate	25/05/2024 00:00	25/05/2024 00:00	25/05/2024 05:00	25/05/2024 00:00	25/05/2024 23:00	
Maximum	45.15	---	102.9	0	31.9	
MaxDate	25/05/2024 10:00	25/05/2024 00:00	25/05/2024 10:00	25/05/2024 00:00	25/05/2024 00:00	
Avg	38.62	---	98.21	0	23.1	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	6.7	---	3.8	0	2.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/05/2024 00:00	30.83	0	94.46	1.4	37.3	
26/05/2024 01:00	30.8	0	92.76	1.4	37.6	
26/05/2024 02:00	30.81	0	92.78	1.4	37.3	
26/05/2024 03:00	30.85	0	92.78	1.5	36.8	
26/05/2024 04:00	30.73	0	92.73	1.5	36.8	
26/05/2024 05:00	30.75	0	92.64	1.5	36.7	
26/05/2024 06:00	30.68	0.4	92.63	1.5	37	
26/05/2024 07:00	30.62	0	92.92	1.5	36.9	
26/05/2024 08:00	30.68	0	93.14	1.5	35.7	
26/05/2024 09:00	30.89	0	93.52	1.5	33.6	
26/05/2024 10:00	31.02	0	93.77	1.5	32.4	
26/05/2024 11:00	31.08	0	94.06	1.5	31.8	
26/05/2024 12:00	31.01	0	94.12	1.4	31.8	
26/05/2024 13:00	30.99	0	93.7	1.4	31.6	
26/05/2024 14:00	31	0	93.61	1.4	31.4	
26/05/2024 15:00	31.06	0	93.28	1.4	31	
26/05/2024 16:00	31.06	0	93.05	1.4	31	
26/05/2024 17:00	31.03	0	92.72	1.4	31.2	
26/05/2024 18:00	37.91	0	95.4	1.3	30.5	
26/05/2024 19:00	44.83	0	101.48	1.4	27.7	
26/05/2024 20:00	44.83	0	101.71	1.4	27.5	
26/05/2024 21:00	44.91	0	101.03	1.4	28.5	
26/05/2024 22:00	37.7	0	98.68	1.3	32.7	
26/05/2024 23:00	30.7	0	93.15	1.3	36.1	
27/05/2024 00:00	30.73	0	92.98	1.4	35.6	
Minimum	30.62	0	92.63	1.3	27.5	
MinDate	26/05/2024 07:00	26/05/2024 00:00	26/05/2024 06:00	26/05/2024 18:00	26/05/2024 20:00	
Maximum	44.91	0.4	101.71	1.5	37.6	
MaxDate	26/05/2024 21:00	26/05/2024 06:00	26/05/2024 20:00	26/05/2024 03:00	26/05/2024 01:00	
Avg	33.1	0.02	94.52	1.4	33.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.8	0.1	2.9	0.1	3.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/05/2024 00:00	30.74	Maintenance	94.53	0	26.3	DUST waiting for spare part
26/05/2024 01:00	30.73	Maintenance	93.19	0	26.3	DUST waiting for spare part
26/05/2024 02:00	30.75	Maintenance	93.25	0	26.2	DUST waiting for spare part
26/05/2024 03:00	30.79	Maintenance	93.26	0	25.8	DUST waiting for spare part
26/05/2024 04:00	30.67	Maintenance	93.32	0	25.4	DUST waiting for spare part
26/05/2024 05:00	30.69	Maintenance	93.2	0	25.4	DUST waiting for spare part
26/05/2024 06:00	30.62	Maintenance	93.16	0	25.8	DUST waiting for spare part
26/05/2024 07:00	30.56	Maintenance	93.4	0	25.3	DUST waiting for spare part
26/05/2024 08:00	30.62	Maintenance	93.55	0	23.8	DUST waiting for spare part
26/05/2024 09:00	30.83	Maintenance	93.93	0	21.9	DUST waiting for spare part
26/05/2024 10:00	30.96	Maintenance	94.26	0	20.9	DUST waiting for spare part
26/05/2024 11:00	31.03	Maintenance	94.68	0	20.4	DUST waiting for spare part
26/05/2024 12:00	30.96	Maintenance	94.78	0	20.4	DUST waiting for spare part
26/05/2024 13:00	30.92	Maintenance	94.35	0	20.1	DUST waiting for spare part
26/05/2024 14:00	30.94	Maintenance	94.26	0	19.9	DUST waiting for spare part
26/05/2024 15:00	30.99	Maintenance	94.06	0	19.6	DUST waiting for spare part
26/05/2024 16:00	31	Maintenance	93.92	0	19.7	DUST waiting for spare part
26/05/2024 17:00	30.96	Maintenance	93.71	0	19.9	DUST waiting for spare part
26/05/2024 18:00	37.83	Maintenance	96.4	0	21.4	DUST waiting for spare part
26/05/2024 19:00	44.76	Maintenance	102.47	0	20.4	DUST waiting for spare part
26/05/2024 20:00	44.75	Maintenance	102.7	0	20.3	DUST waiting for spare part
26/05/2024 21:00	44.83	Maintenance	101.55	0	20.6	DUST waiting for spare part
26/05/2024 22:00	37.63	Maintenance	98.86	0	23.6	DUST waiting for spare part
26/05/2024 23:00	30.64	Maintenance	93.34	0	25.1	DUST waiting for spare part
27/05/2024 00:00	30.67	Maintenance	93.22	0	24.8	DUST waiting for spare part
Minimum	30.56	---	93.16	0	19.6	
MinDate	26/05/2024 07:00	26/05/2024 00:00	26/05/2024 06:00	26/05/2024 00:00	26/05/2024 15:00	
Maximum	44.83	---	102.7	0	26.3	
MaxDate	26/05/2024 21:00	26/05/2024 00:00	26/05/2024 20:00	26/05/2024 00:00	26/05/2024 00:00	
Avg	33.03	---	95.09	0	22.8	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.8	---	3	0	2.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/05/2024 00:00	30.73	0	92.98	1.4	35.6	
27/05/2024 01:00	30.77	0	93.1	1.4	35	
27/05/2024 02:00	30.79	0	93.23	1.4	34.5	
27/05/2024 03:00	30.79	0	93.27	1.4	34	
27/05/2024 04:00	30.72	0	93.3	1.4	33.7	
27/05/2024 05:00	30.82	0	93.38	1.4	33	
27/05/2024 06:00	30.87	0.32	93.63	1.4	32.7	
27/05/2024 07:00	31.02	0	94.03	1.4	31.6	
27/05/2024 08:00	29.88	0	94.3	1.5	31.8	
27/05/2024 09:00	31.11	0	94.29	1.5	32.1	
27/05/2024 10:00	34.1	0	95.34	1.4	23.8	
27/05/2024 11:00	34.29	0	96.02	1.4	23.9	
27/05/2024 12:00	24.64	0	94.63	1.5	44.7	
27/05/2024 13:00	31.35	0	94.25	1.5	33.7	
27/05/2024 14:00	34.5	0	95.64	1.4	24.7	
27/05/2024 15:00	34.46	0	95.28	1.4	24.5	
27/05/2024 16:00	34.45	0	95.33	1.3	24.2	
27/05/2024 17:00	34.27	0	95.25	1.3	24	
27/05/2024 18:00	34.2	0	94.81	1.3	23.8	
27/05/2024 19:00	33.96	0	94.44	1.3	23.2	
27/05/2024 20:00	34.05	0	94.37	1.3	23.1	
27/05/2024 21:00	34.28	0	94.97	1.3	23.1	
27/05/2024 22:00	34.28	0	94.96	1.3	23.1	
27/05/2024 23:00	34.14	0	95.03	1.3	22.8	
28/05/2024 00:00	39.79	0	95.83	1.3	35.3	
Minimum	24.64	0	92.98	1.3	22.8	
MinDate	27/05/2024 12:00	27/05/2024 00:00	27/05/2024 00:00	27/05/2024 16:00	27/05/2024 23:00	
Maximum	39.79	0.32	96.02	1.5	44.7	
MaxDate	28/05/2024 00:00	27/05/2024 06:00	27/05/2024 11:00	27/05/2024 08:00	27/05/2024 12:00	
Avg	32.57	0.01	94.47	1.4	29.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	2.8	0.1	0.9	0.1	6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/05/2024 00:00	30.67	Maintenance	93.22	0	24.8	DUST waiting for spare part
27/05/2024 01:00	30.72	Maintenance	93.32	0	24.1	DUST waiting for spare part
27/05/2024 02:00	30.73	Maintenance	93.49	0	23.6	DUST waiting for spare part
27/05/2024 03:00	30.73	Maintenance	93.57	0	22.9	DUST waiting for spare part
27/05/2024 04:00	30.65	Maintenance	93.58	0	22.6	DUST waiting for spare part
27/05/2024 05:00	30.75	Maintenance	93.62	0	21.7	DUST waiting for spare part
27/05/2024 06:00	30.81	Maintenance	93.83	0	21.5	DUST waiting for spare part
27/05/2024 07:00	30.96	Maintenance	94.21	0	20.4	DUST waiting for spare part
27/05/2024 08:00	29.82	Maintenance	94.45	0	21.8	DUST waiting for spare part
27/05/2024 09:00	30.63	Maintenance	94.85	0	24.3	DUST waiting for spare part
27/05/2024 10:00	34.04	Maintenance	95.37	0	15.4	DUST waiting for spare part
27/05/2024 11:00	34.23	Maintenance	96.1	0	15.5	DUST waiting for spare part
27/05/2024 12:00	24.3	Maintenance	94.69	0	39.9	DUST waiting for spare part
27/05/2024 13:00	31.19	Maintenance	94.39	0	26.6	DUST waiting for spare part
27/05/2024 14:00	34.44	<Samp	95.57	0	15.9	DUST waiting for spare part
27/05/2024 15:00	34.4	<Samp	95.35	0	15.8	DUST waiting for spare part
27/05/2024 16:00	34.38	Maintenance	95.39	0	15.7	DUST waiting for spare part
27/05/2024 17:00	34.2	Maintenance	95.28	0	15.5	DUST waiting for spare part
27/05/2024 18:00	34.14	Maintenance	94.96	0	15.5	DUST waiting for spare part
27/05/2024 19:00	33.89	Maintenance	94.7	0	15.1	DUST waiting for spare part
27/05/2024 20:00	33.99	Maintenance	94.63	0	15.1	DUST waiting for spare part
27/05/2024 21:00	34.21	Maintenance	95.02	0	15.1	DUST waiting for spare part
27/05/2024 22:00	34.21	Maintenance	94.96	0	15.1	DUST waiting for spare part
27/05/2024 23:00	34.08	Maintenance	95	0	15	DUST waiting for spare part
28/05/2024 00:00	8.37	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	8.37	---	93.22	0	15	
MinDate	28/05/2024 00:00	27/05/2024 00:00	27/05/2024 00:00	27/05/2024 00:00	27/05/2024 23:00	
Maximum	34.44	---	96.1	0	39.9	
MaxDate	27/05/2024 14:00	27/05/2024 00:00	27/05/2024 11:00	27/05/2024 00:00	27/05/2024 12:00	
Avg	31.23	---	94.56	0	20	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	5.3	---	0.8	0	5.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/05/2024 00:00	39.79	0	95.83	1.3	35.3	
28/05/2024 01:00	47.97	0	96.18	1.3	32.9	
28/05/2024 02:00	48.18	0	94.55	1.3	32.5	
28/05/2024 03:00	48.29	0	95.2	1.3	32.4	
28/05/2024 04:00	48.11	0	95.2	1.3	32.5	
28/05/2024 05:00	48.08	0	94.96	1.3	32.6	
28/05/2024 06:00	48.07	0.26	95.48	1.4	32.6	
28/05/2024 07:00	47.79	0	95.18	1.3	32.5	
28/05/2024 08:00	43.44	0	95.68	1.4	32	
28/05/2024 09:00	32.54	0	94.79	1.4	29.6	
28/05/2024 10:00	34.54	0	95.59	1.4	23.3	
28/05/2024 11:00	34.53	0	95.91	1.3	23.3	
28/05/2024 12:00	25.14	0	94.06	1.4	40.5	
28/05/2024 13:00	31.48	0	94.23	1.3	30.7	
28/05/2024 14:00	34.49	0	95.65	1.3	23.2	
28/05/2024 15:00	34.38	0	95.33	1.3	23.3	
28/05/2024 16:00	34.3	0	95.27	1.3	23	
28/05/2024 17:00	34.25	0	95.15	1.2	22.9	
28/05/2024 18:00	34.13	0	94.93	1.2	23	
28/05/2024 19:00	34.04	0	94.4	1.2	22.3	
28/05/2024 20:00	34.16	0	94.36	1.2	22.3	
28/05/2024 21:00	34.38	0	94.83	1.2	22.2	
28/05/2024 22:00	34.41	0	95.07	1.2	22.1	
28/05/2024 23:00	34.35	0	95.12	1.2	22.2	
29/05/2024 00:00	7.94	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	0		94.06	1.2	22.1	
MinDate	29/05/2024 00:00	28/05/2024 00:00	28/05/2024 12:00	28/05/2024 17:00	28/05/2024 22:00	
Maximum	48.29	0.26	96.18	1.4	40.5	
MaxDate	28/05/2024 03:00	28/05/2024 06:00	28/05/2024 01:00	28/05/2024 06:00	28/05/2024 12:00	
Avg	37.15	0.01	95.12	1.3	27.9	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	9.2	0.1	0.5	0.1	5.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/05/2024 00:00	8.37	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 08:00	5.91	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
28/05/2024 09:00	32.35	Maintenance	96.43	0	29.3	DUST waiting for spare part
28/05/2024 10:00	34.47	Maintenance	95.44	0	23	DUST waiting for spare part
28/05/2024 11:00	34.47	Maintenance	95.82	0	23	DUST waiting for spare part
28/05/2024 12:00	25.1	Maintenance	93.96	0	39.5	DUST waiting for spare part
28/05/2024 13:00	31.47	Maintenance	94.41	0	30	DUST waiting for spare part
28/05/2024 14:00	34.42	Maintenance	95.74	0	22.4	DUST waiting for spare part
28/05/2024 15:00	34.32	Maintenance	95.52	0	22.5	DUST waiting for spare part
28/05/2024 16:00	34.24	Maintenance	95.52	0	22.1	DUST waiting for spare part
28/05/2024 17:00	34.19	Maintenance	95.37	0	21.8	DUST waiting for spare part
28/05/2024 18:00	34.07	Maintenance	95.18	0	21.8	DUST waiting for spare part
28/05/2024 19:00	33.97	Maintenance	94.77	0	20.9	DUST waiting for spare part
28/05/2024 20:00	34.1	Maintenance	94.76	0	20.8	DUST waiting for spare part
28/05/2024 21:00	34.32	Maintenance	94.99	0	20.8	DUST waiting for spare part
28/05/2024 22:00	34.34	Maintenance	95.17	0	20.7	DUST waiting for spare part
28/05/2024 23:00	34.28	Maintenance	95.22	0	20.6	DUST waiting for spare part
29/05/2024 00:00	39.72	Maintenance	95.92	0	37.4	DUST waiting for spare part
Minimum	0		93.96	0	20.5	
MinDate	28/05/2024 01:00	28/05/2024 00:00	28/05/2024 12:00	28/05/2024 09:00	28/05/2024 23:00	
Maximum	39.72	---	96.43	0	39.5	
MaxDate	29/05/2024 00:00	28/05/2024 00:00	28/05/2024 09:00	28/05/2024 09:00	28/05/2024 12:00	
Avg	22.16		95.26	0	24.8	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	16	---	0.6	0	6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/05/2024 00:00	7.94	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 06:00	0	0.19	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 08:00	6.26	0.07	ShutDown	ShutDown	ShutDown	GT11 S/D
29/05/2024 09:00	32.48	0	95.19	1.4	36	
29/05/2024 10:00	34.83	0	95.81	1.4	29.6	
29/05/2024 11:00	34.62	0	95.97	1.4	29.3	
29/05/2024 12:00	25.14	0	93.88	1.4	44.9	
29/05/2024 13:00	31.52	0	94.29	1.4	35.7	
29/05/2024 14:00	34.63	0	95.98	1.4	28.5	
29/05/2024 15:00	34.54	0	95.76	1.3	28.5	
29/05/2024 16:00	34.78	0	95.47	1.3	28.6	
29/05/2024 17:00	34.35	0	95.09	1.3	28.5	
29/05/2024 18:00	34.29	0	94.96	1.3	28.3	
29/05/2024 19:00	34.11	0	94.87	1.3	27.9	
29/05/2024 20:00	34.21	0	94.6	1.3	27.5	
29/05/2024 21:00	34.45	0	95.03	1.3	27.1	
29/05/2024 22:00	34.46	0	95.12	1.3	27.1	
29/05/2024 23:00	34.27	0	95.16	1.3	26.7	
30/05/2024 00:00	40	0	95.71	1.3	38.9	
Minimum	0	0	93.88	1.3	26.7	
MinDate	29/05/2024 01:00	29/05/2024 00:00	29/05/2024 12:00	29/05/2024 15:00	29/05/2024 23:00	
Maximum	40	0.19	95.98	1.4	44.9	
MaxDate	30/05/2024 00:00	29/05/2024 06:00	29/05/2024 14:00	29/05/2024 09:00	29/05/2024 12:00	
Avg	22.28	0.01	95.18	1.3	30.8	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16.1	0	0.6	0.1	5.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/05/2024 00:00	39.72	Maintenance	95.92	0	37.4	DUST waiting for spare part
29/05/2024 01:00	47.39	Maintenance	95.22	0	38.4	DUST waiting for spare part
29/05/2024 02:00	47.44	Maintenance	94.81	0	39.1	DUST waiting for spare part
29/05/2024 03:00	47.56	Maintenance	95.09	0	39.6	DUST waiting for spare part
29/05/2024 04:00	47.52	Maintenance	95.24	0	39.8	DUST waiting for spare part
29/05/2024 05:00	47.62	Maintenance	95.24	0	39.8	DUST waiting for spare part
29/05/2024 06:00	47.72	Maintenance	95.81	0	39.8	DUST waiting for spare part
29/05/2024 07:00	47.4	Maintenance	94.81	0	39.4	DUST waiting for spare part
29/05/2024 08:00	42.69	Maintenance	95.43	0	37.4	DUST waiting for spare part
29/05/2024 09:00	32.39	Maintenance	94.91	0	28	DUST waiting for spare part
29/05/2024 10:00	34.26	Maintenance	95.47	0	21.1	DUST waiting for spare part
29/05/2024 11:00	34.55	Maintenance	95.83	0	21.1	DUST waiting for spare part
29/05/2024 12:00	25.11	Maintenance	93.91	0	38.3	DUST waiting for spare part
29/05/2024 13:00	31.5	Maintenance	94.59	0	28.2	DUST waiting for spare part
29/05/2024 14:00	34.57	Maintenance	95.74	0	20.3	DUST waiting for spare part
29/05/2024 15:00	34.48	Maintenance	95.68	0	20.3	DUST waiting for spare part
29/05/2024 16:00	34.28	Maintenance	95.3	0	20.3	DUST waiting for spare part
29/05/2024 17:00	34.29	Maintenance	95.03	0	20.3	DUST waiting for spare part
29/05/2024 18:00	34.23	Maintenance	94.99	0	20.1	DUST waiting for spare part
29/05/2024 19:00	34.05	Maintenance	94.88	0	19.8	DUST waiting for spare part
29/05/2024 20:00	34.15	Maintenance	94.71	0	19.5	DUST waiting for spare part
29/05/2024 21:00	34.30	Maintenance	95.02	0	19.1	DUST waiting for spare part
29/05/2024 22:00	34.39	Maintenance	95.07	0	19.2	DUST waiting for spare part
29/05/2024 23:00	34.22	Maintenance	95.12	0	18.9	DUST waiting for spare part
30/05/2024 00:00	7.84	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	7.84	---	93.91	0	18.9	
MinDate	30/05/2024 00:00	29/05/2024 00:00	29/05/2024 12:00	29/05/2024 00:00	29/05/2024 23:00	
Maximum	47.72	---	95.92	0	39.8	
MaxDate	29/05/2024 06:00	29/05/2024 00:00	29/05/2024 00:00	29/05/2024 00:00	29/05/2024 04:00	
Avg	36.95	---	95.16	0	28.6	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	9	---	0.5	0	9.2	

Date & Time	11GT_LOAD MW	11HRSG_DUST mg/m3	11HRSG_TEMP Degree C.	11HRSG_SO2@7%O2 ppm	11HRSG_NOx@7%O2 ppm	Remark
30/05/2024 00:00	40	0	95.71	1.3	38.9	
30/05/2024 01:00	47.79	0	95.08	1.3	37.8	
30/05/2024 02:00	47.87	0	95.02	1.3	37.9	
30/05/2024 03:00	47.96	0	95.18	1.3	37.5	
30/05/2024 04:00	47.95	0	95.2	1.4	37.5	
30/05/2024 05:00	47.96	0	95.15	1.4	37.6	
30/05/2024 06:00	48.02	0.38	95.34	1.4	37.7	
30/05/2024 07:00	47.59	0	95.22	1.4	37.9	
30/05/2024 08:00	43.87	0	95.55	1.4	37.6	
30/05/2024 09:00	32.46	0	94.54	1.5	34.4	
30/05/2024 10:00	34.6	0	95.45	1.4	27.7	
30/05/2024 11:00	34.55	0	96.03	1.4	28	
30/05/2024 12:00	25.59	0	94.71	1.5	43.9	
30/05/2024 13:00	31.57	0	94.2	1.4	34.3	
30/05/2024 14:00	34.6	0	95.6	1.4	27.3	
30/05/2024 15:00	34.49	0	95.14	1.4	27	
30/05/2024 16:00	34.42	0	95.05	1.3	26.3	
30/05/2024 17:00	34.35	0	94.77	1.3	26.2	
30/05/2024 18:00	34.31	0	94.41	1.3	25.8	
30/05/2024 19:00	34.11	0	94.29	1.3	25.7	
30/05/2024 20:00	34.25	0	94.29	1.3	25.8	
30/05/2024 21:00	34.48	0	94.76	1.3	25.6	
30/05/2024 22:00	34.39	0	95.11	1.3	25.5	
30/05/2024 23:00	34.28	0	95.04	1.3	25.6	
31/05/2024 00:00	8.32	0	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	8.32	0	94.2	1.3	25.5	
MinDate	31/05/2024 00:00	30/05/2024 00:00	30/05/2024 13:00	30/05/2024 00:00	30/05/2024 22:00	
Maximum	48.02	0.38	96.03	1.5	43.9	
MaxDate	30/05/2024 06:00	30/05/2024 06:00	30/05/2024 11:00	30/05/2024 09:00	30/05/2024 12:00	
Avg	37.19	0.02	95.04	1.4	32.1	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	9.1	0.1	0.5	0.1	6.1	

Date & Time	12GT_LOAD MW	12HRSG_DUST mg/m3	12HRSG_TEMP Degree C.	12HRSG_SO2@7%O2 ppm	12HRSG_NOx@7%O2 ppm	Remark
30/05/2024 00:00	7.84	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 03:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 05:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
30/05/2024 08:00	5.57	Maintenance	ShutDown	ShutDown	ShutDown	
30/05/2024 09:00	32.38	Maintenance	96.03	0	25.4	DUST waiting for spare part
30/05/2024 10:00	34.54	Maintenance	95.52	0	22.6	DUST waiting for spare part
30/05/2024 11:00	34.49	Maintenance	96.1	0	22.9	DUST waiting for spare part
30/05/2024 12:00	25.6	Maintenance	94.76	0	39.7	DUST waiting for spare part
30/05/2024 13:00	31.44	Maintenance	94.25	0	29.6	DUST waiting for spare part
30/05/2024 14:00	34.53	Maintenance	95.56	0	22.2	DUST waiting for spare part
30/05/2024 15:00	34.43	Maintenance	95.25	0	21.8	DUST waiting for spare part
30/05/2024 16:00	34.36	Maintenance	95.2	0	21.1	DUST waiting for spare part
30/05/2024 17:00	34.3	<Samp	94.97	0	21	DUST waiting for spare part
30/05/2024 18:00	34.24	Maintenance	94.73	0	20.7	DUST waiting for spare part
30/05/2024 19:00	34.05	Maintenance	94.59	0	20.5	DUST waiting for spare part
30/05/2024 20:00	34.19	Maintenance	94.53	0	20.7	DUST waiting for spare part
30/05/2024 21:00	34.41	Maintenance	94.8	0	20.6	DUST waiting for spare part
30/05/2024 22:00	34.32	Maintenance	95.11	0	20.5	DUST waiting for spare part
30/05/2024 23:00	34.21	Maintenance	95	0	20.6	DUST waiting for spare part
31/05/2024 00:00	39.65	Maintenance	95.57	0	37.8	DUST waiting for spare part
Minimum	0	---	94.25	0	20.5	
MinDate	30/05/2024 01:00	30/05/2024 00:00	30/05/2024 13:00	30/05/2024 09:00	30/05/2024 19:00	
Maximum	39.65	---	96.1	0	39.7	
MaxDate	31/05/2024 00:00	30/05/2024 00:00	30/05/2024 11:00	30/05/2024 09:00	30/05/2024 12:00	
Avg	22.18	---	95.12	0	24.5	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	16.1	---	0.5	0	6.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
31/05/2024 00:00	8.32	0	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 06:00	0	0.32	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 08:00	6.18	0.03	ShutDown	ShutDown	ShutDown	GT11 S/D
31/05/2024 09:00	32.39	0	95.34	1.4	35	
31/05/2024 10:00	34.52	0	95.14	1.3	28.4	
31/05/2024 11:00	34.5	0	95.37	1.3	28.3	
31/05/2024 12:00	25.34	0	93.92	1.4	44	
31/05/2024 13:00	31.54	0	93.75	1.4	34.9	
31/05/2024 14:00	34.56	0	95.23	1.3	28.1	
31/05/2024 15:00	34.51	0	94.8	1.4	27.9	
31/05/2024 16:00	34.41	0	94.42	1.3	27.9	
31/05/2024 17:00	34.29	0	94.01	1.3	27.2	
31/05/2024 18:00	34.23	0	93.92	1.3	27	
31/05/2024 19:00	34.05	0	93.63	1.2	26.7	
31/05/2024 20:00	34.04	0	93.8	1.3	26.3	
31/05/2024 21:00	34.26	0	94.35	1.3	26.2	
31/05/2024 22:00	37.3	0	96.11	1.3	27.6	
31/05/2024 23:00	38.02	0	96.98	1.3	28	
01/06/2024 00:00	27.56	0	93.2	1.3	43.7	
Minimum	0	0	93.2	1.2	26.2	
MinDate	31/05/2024 01:00	31/05/2024 00:00	01/06/2024 00:00	31/05/2024 19:00	31/05/2024 21:00	
Maximum	38.02	0.32	96.98	1.4	44	
MaxDate	31/05/2024 23:00	31/05/2024 06:00	31/05/2024 23:00	31/05/2024 09:00	31/05/2024 12:00	
Avg	22	0.01	94.62	1.3	30.5	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.9	0.1	1	0.1	5.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
31/05/2024 00:00	39.65	Maintenance	95.57	0	37.8	DUST waiting for spare part
31/05/2024 01:00	47.93	Maintenance	95.01	0	39.5	DUST waiting for spare part
31/05/2024 02:00	48.06	Maintenance	95.15	0	39.3	DUST waiting for spare part
31/05/2024 03:00	47.98	Maintenance	95.13	0	38.9	DUST waiting for spare part
31/05/2024 04:00	48.11	Maintenance	95.09	0	38.9	DUST waiting for spare part
31/05/2024 05:00	48.18	Maintenance	95.36	0	38.9	DUST waiting for spare part
31/05/2024 06:00	48.14	Maintenance	95.86	0	38.9	DUST waiting for spare part
31/05/2024 07:00	47.88	Maintenance	95.53	0	38.4	DUST waiting for spare part
31/05/2024 08:00	43.11	< Samp.	95.13	0	36.8	DUST waiting for spare part
31/05/2024 09:00	32.88	< Samp.	95.68	0	27.4	DUST waiting for spare part
31/05/2024 10:00	34.46	Maintenance	95.58	0	20.2	DUST waiting for spare part
31/05/2024 11:00	34.43	Maintenance	95.98	0	20	DUST waiting for spare part
31/05/2024 12:00	25.39	Maintenance	94.65	0	37.2	DUST waiting for spare part
31/05/2024 13:00	31.44	Maintenance	94.47	0	27.5	DUST waiting for spare part
31/05/2024 14:00	34.5	Maintenance	95.84	0	20	DUST waiting for spare part
31/05/2024 15:00	34.45	Maintenance	95.54	0	19.8	DUST waiting for spare part
31/05/2024 16:00	34.34	Maintenance	95.31	0	19.7	DUST waiting for spare part
31/05/2024 17:00	34.23	Maintenance	94.97	0	19.2	DUST waiting for spare part
31/05/2024 18:00	34.16	Maintenance	94.77	0	19	DUST waiting for spare part
31/05/2024 19:00	33.98	Maintenance	94.43	0	19	DUST waiting for spare part
31/05/2024 20:00	33.98	Maintenance	94.56	0	18.7	DUST waiting for spare part
31/05/2024 21:00	34.19	Maintenance	94.94	0	16.6	DUST waiting for spare part
31/05/2024 22:00	37.25	Maintenance	96.78	0	20	DUST waiting for spare part
31/05/2024 23:00	37.94	Maintenance	97.64	0	20.5	DUST waiting for spare part
01/06/2024 00:00	27.46	Audit	93.67	0	34.8	DUST waiting for spare part
Minimum	25.39		93.67	0	18.6	
MinDate	31/05/2024 12:00	31/05/2024 00:00	01/06/2024 00:00	31/05/2024 00:00	31/05/2024 21:00	
Maximum	48.18		97.64	0	39.5	
MaxDate	31/05/2024 05:00	31/05/2024 00:00	31/05/2024 23:00	31/05/2024 00:00	31/05/2024 01:00	
Avg	38.14		95.28	0	28.4	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	7.1	---	0.8	0	9.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
01/06/2024 00:00	27.56	0	93.2	1.3	43.7	
01/06/2024 01:00	28.8	0	92.89	1.3	42.2	
01/06/2024 02:00	28.81	0	92.84	1.3	42.5	
01/06/2024 03:00	28.76	0	92.91	1.4	42.9	
01/06/2024 04:00	28.56	0	92.89	1.4	43.7	
01/06/2024 05:00	28.48	0	92.66	1.4	44.5	
01/06/2024 06:00	28.4	0.28	92.86	1.4	44.3	
01/06/2024 07:00	28.19	0	93.07	1.4	44.2	
01/06/2024 08:00	31.75	0	93.87	1.4	41.5	
01/06/2024 09:00	42.18	0	99.8	1.4	29.6	
01/06/2024 10:00	42.33	0	100.43	1.4	30	
01/06/2024 11:00	42.31	0	100.4	1.4	30.2	
01/06/2024 12:00	28.3	0	94.56	1.4	43.2	
01/06/2024 13:00	42.29	0	98.86	1.4	31.4	
01/06/2024 14:00	42.41	0	100.56	1.4	30.1	
01/06/2024 15:00	42.37	0	100.25	1.4	29.9	
01/06/2024 16:00	42.27	0	100.05	1.3	29.7	
01/06/2024 17:00	42.08	0	99.83	1.3	29.5	
01/06/2024 18:00	41.97	0	99.45	1.3	29.3	
01/06/2024 19:00	41.85	0	99.45	1.3	29.2	
01/06/2024 20:00	42.1	0	99.5	1.3	29.2	
01/06/2024 21:00	42.25	0	99.98	1.3	29.1	
01/06/2024 22:00	42.26	0	100.02	1.3	28.9	
01/06/2024 23:00	38.69	0	99.52	1.3	31.2	
02/06/2024 00:00	28.27	0	93.51	1.3	43.5	
Minimum	27.56	0	92.66	1.3	28.9	
MinDate	01/06/2024 00:00	01/06/2024 00:00	01/06/2024 05:00	01/06/2024 00:00	01/06/2024 22:00	
Maximum	42.41	0.28	100.56	1.4	44.5	
MaxDate	01/06/2024 14:00	01/06/2024 06:00	01/06/2024 14:00	01/06/2024 03:00	01/06/2024 05:00	
Avg	36.13	0.01	96.93	1.4	35.7	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.8	0.1	3.4	0.1	6.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
01/06/2024 00:00	27.46	Audit	93.67	0	34.8	DUST waiting for spare part
01/06/2024 01:00	28.74	Maintenance	92.96	0	33.3	DUST waiting for spare part
01/06/2024 02:00	28.76	<Samp	92.83	0	33.7	DUST waiting for spare part
01/06/2024 03:00	28.69	<Samp	92.91	0	34	DUST waiting for spare part
01/06/2024 04:00	28.49	Maintenance	92.96	0	34.7	DUST waiting for spare part
01/06/2024 05:00	28.42	<Samp	92.68	0	35.3	DUST waiting for spare part
01/06/2024 06:00	28.35	Maintenance	92.95	0	35.2	DUST waiting for spare part
01/06/2024 07:00	28.13	Maintenance	93.14	0	35	DUST waiting for spare part
01/06/2024 08:00	31.67	Maintenance	94.17	0	33.5	DUST waiting for spare part
01/06/2024 09:00	42.1	Maintenance	100.09	0	23.6	DUST waiting for spare part
01/06/2024 10:00	42.26	Maintenance	100.75	0	24.2	DUST waiting for spare part
01/06/2024 11:00	42.23	Audit	100.78	0	24.4	DUST waiting for spare part
01/06/2024 12:00	28.24	Maintenance	94.87	0	34.8	DUST waiting for spare part
01/06/2024 13:00	42.19	<Samp	99.22	0	25.9	DUST waiting for spare part
01/06/2024 14:00	42.33	Maintenance	100.59	0	24.3	DUST waiting for spare part
01/06/2024 15:00	42.29	Maintenance	100.52	0	23.8	DUST waiting for spare part
01/06/2024 16:00	42.2	<Samp	100.3	0	23.5	DUST waiting for spare part
01/06/2024 17:00	41.99	Maintenance	100.06	0	22.9	DUST waiting for spare part
01/06/2024 18:00	41.9	Maintenance	99.73	0	22.7	DUST waiting for spare part
01/06/2024 19:00	41.78	Maintenance	99.65	0	22.4	DUST waiting for spare part
01/06/2024 20:00	42.03	Maintenance	99.74	0	22.6	DUST waiting for spare part
01/06/2024 21:00	42.18	Maintenance	100.01	0	22.7	DUST waiting for spare part
01/06/2024 22:00	42.18	Maintenance	100.01	0	22.5	DUST waiting for spare part
01/06/2024 23:00	38.77	Maintenance	99.35	0	24.8	DUST waiting for spare part
02/06/2024 00:00	28.23	Maintenance	93.79	0	34.6	DUST waiting for spare part
Minimum	27.46		92.68	0	22.4	
MinDate	01/06/2024 00:00	01/06/2024 00:00	01/06/2024 05:00	01/06/2024 00:00	01/06/2024 19:00	
Maximum	42.33	---	100.78	0	35.3	
MaxDate	01/06/2024 14:00	01/06/2024 00:00	01/06/2024 11:00	01/06/2024 00:00	01/06/2024 05:00	
Avg	36.06		97.11	0	26.4	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	6.8	---	3.4	0	5.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/06/2024 00:00	28.27	0	93.51	1.3	43.5	
02/06/2024 01:00	28.25	0	93.07	1.4	43.6	
02/06/2024 02:00	28.19	0	92.98	1.4	44.1	
02/06/2024 03:00	28.07	0	92.77	1.4	44.9	
02/06/2024 04:00	27.84	0	92.58	1.4	46.5	
02/06/2024 05:00	27.67	0	92.55	1.4	47.4	
02/06/2024 06:00	27.48	0.21	92.58	1.4	47.4	
02/06/2024 07:00	27.32	0	92.95	1.5	46.8	
02/06/2024 08:00	27.3	0	92.91	1.5	48.2	
02/06/2024 09:00	27.32	0	92.85	1.5	47.1	
02/06/2024 10:00	27.35	0	92.81	1.5	46.6	
02/06/2024 11:00	27.35	0	93.17	1.4	47.2	
02/06/2024 12:00	27.31	0	93.45	1.4	46.9	
02/06/2024 13:00	27.3	0	92.75	1.4	46.5	
02/06/2024 14:00	27.25	0	92.73	1.4	49.1	
02/06/2024 15:00	27.27	0	92.3	1.4	47	
02/06/2024 16:00	27.25	0	92.02	1.4	47	
02/06/2024 17:00	27.23	0	92.08	1.4	46.5	
02/06/2024 18:00	37.61	0	95.81	1.3	33.6	
02/06/2024 19:00	40.99	0	98.84	1.3	27.9	
02/06/2024 20:00	40.97	0	98.77	1.3	28.6	
02/06/2024 21:00	40.9	0	98.94	1.3	28.4	
02/06/2024 22:00	33.88	0	96.81	1.3	35.9	
02/06/2024 23:00	27.14	0	92.59	1.4	46.2	
03/06/2024 00:00	27.13	0	92.41	1.4	46	
Minimum	27.13	0	92.02	1.3	27.9	
MinDate	03/06/2024 00:00	02/06/2024 00:00	02/06/2024 16:00	02/06/2024 00:00	02/06/2024 19:00	
Maximum	40.99	0.21	98.94	1.5	49.1	
MaxDate	02/06/2024 19:00	02/06/2024 06:00	02/06/2024 21:00	02/06/2024 07:00	02/06/2024 14:00	
Avg	29.79	0.01	93.77	1.4	43.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.8	0	2.2	0.1	6.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
02/06/2024 00:00	28.23	Maintenance	93.79	0	34.6	DUST waiting for spare part
02/06/2024 01:00	28.19	Maintenance	93.39	0	34.5	DUST waiting for spare part
02/06/2024 02:00	28.12	<Samp	93.29	0	35.3	DUST waiting for spare part
02/06/2024 03:00	28.01	Maintenance	93.16	0	35.9	DUST waiting for spare part
02/06/2024 04:00	27.78	Maintenance	92.93	0	37.3	DUST waiting for spare part
02/06/2024 05:00	27.62	Maintenance	92.91	0	38.1	DUST waiting for spare part
02/06/2024 06:00	27.42	Maintenance	92.92	0	38	DUST waiting for spare part
02/06/2024 07:00	27.26	<Samp	93.26	0	37.3	DUST waiting for spare part
02/06/2024 08:00	27.24	Maintenance	93.11	0	38.9	DUST waiting for spare part
02/06/2024 09:00	27.27	Maintenance	93.23	0	38	DUST waiting for spare part
02/06/2024 10:00	27.29	Maintenance	93.25	0	37.6	DUST waiting for spare part
02/06/2024 11:00	27.28	Maintenance	93.64	0	38.2	DUST waiting for spare part
02/06/2024 12:00	27.25	Maintenance	93.86	0	37.8	DUST waiting for spare part
02/06/2024 13:00	27.24	Maintenance	93.15	0	37.4	DUST waiting for spare part
02/06/2024 14:00	27.19	Maintenance	93.1	0	39.8	DUST waiting for spare part
02/06/2024 15:00	27.21	Maintenance	92.77	0	38.1	DUST waiting for spare part
02/06/2024 16:00	27.19	Maintenance	92.57	0	37.9	DUST waiting for spare part
02/06/2024 17:00	27.16	Maintenance	92.68	0	37.3	DUST waiting for spare part
02/06/2024 18:00	37.54	Maintenance	96.43	0	27.4	DUST waiting for spare part
02/06/2024 19:00	40.91	Maintenance	99.31	0	21.8	DUST waiting for spare part
02/06/2024 20:00	40.91	Maintenance	99.23	0	22.4	DUST waiting for spare part
02/06/2024 21:00	40.83	Maintenance	99.29	0	22.1	DUST waiting for spare part
02/06/2024 22:00	33.83	Maintenance	97.1	0	29.5	DUST waiting for spare part
02/06/2024 23:00	27.08	Maintenance	93	0	38.1	DUST waiting for spare part
03/06/2024 00:00	27.08	Maintenance	92.88	0	38	DUST waiting for spare part
Minimum	27.08	---	92.57	0	21.8	
MinDate	02/06/2024 23:00	02/06/2024 00:00	02/06/2024 16:00	02/06/2024 00:00	02/06/2024 19:00	
Maximum	40.91	---	99.31	0	39.8	
MaxDate	02/06/2024 19:00	02/06/2024 00:00	02/06/2024 19:00	02/06/2024 00:00	02/06/2024 14:00	
Avg	29.72	0	94.18	0	34.9	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.8	---	2.2	0	5.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/06/2024 00:00	27.13	0	92.41	1.4	46	
03/06/2024 01:00	27.15	0	92.29	1.4	46.2	
03/06/2024 02:00	27.16	0	92.35	1.4	46.1	
03/06/2024 03:00	27.13	0	92.64	1.4	45.9	
03/06/2024 04:00	27.15	0	92.59	1.4	46.2	
03/06/2024 05:00	27.17	0	92.54	1.4	46.3	
03/06/2024 06:00	27.08	0.38	92.62	1.5	45.8	
03/06/2024 07:00	27.11	0	92.66	1.5	46.4	
03/06/2024 08:00	27.18	0	92.73	1.5	46.4	
03/06/2024 09:00	27.22	0	92.91	1.5	45.3	
03/06/2024 10:00	27.28	0	93.01	1.5	44.8	
03/06/2024 11:00	27.33	0	93.42	1.5	44.6	
03/06/2024 12:00	27.35	0	93.7	1.5	43.6	
03/06/2024 13:00	27.32	0	93.21	1.5	43.8	
03/06/2024 14:00	27.42	0	93.07	1.5	43.9	
03/06/2024 15:00	27.36	0	92.57	1.5	44.3	
03/06/2024 16:00	27.37	0	92.31	1.4	44.3	
03/06/2024 17:00	27.27	0	92.16	1.4	44.5	
03/06/2024 18:00	37.64	0	96.03	1.4	31.9	
03/06/2024 19:00	41.01	0	98.96	1.4	26.7	
03/06/2024 20:00	41.03	0	98.88	1.4	26.1	
03/06/2024 21:00	40.97	0	99.13	1.3	25.9	
03/06/2024 22:00	33.99	0	97.12	1.4	33.6	
03/06/2024 23:00	27.24	0	92.79	1.4	43	
04/06/2024 00:00	27.18	0	92.74	1.4	43	
Minimum	27.08	0	92.16	1.3	25.9	
MinDate	03/06/2024 06:00	03/06/2024 00:00	03/06/2024 17:00	03/06/2024 21:00	03/06/2024 21:00	
Maximum	41.03	0.38	99.13	1.5	46.4	
MaxDate	03/06/2024 20:00	03/06/2024 06:00	03/06/2024 21:00	03/06/2024 06:00	03/06/2024 07:00	
Avg	29.57	0.02	93.79	1.4	41.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.9	0.1	2.3	0.1	6.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
03/06/2024 00:00	27.08	Maintenance	92.88	0	38	
03/06/2024 01:00	27.09	Maintenance	92.68	0	38.2	
03/06/2024 02:00	27.1	Maintenance	92.68	0	38.1	
03/06/2024 03:00	27.08	Maintenance	92.99	0	38	
03/06/2024 04:00	27.09	Maintenance	92.95	0	38.1	
03/06/2024 05:00	27.11	Maintenance	92.87	0	38.3	
03/06/2024 06:00	27.01	Maintenance	92.99	0	38	
03/06/2024 07:00	27.04	Maintenance	92.99	0	38.4	
03/06/2024 08:00	27.11	Maintenance	93.09	0	38.5	
03/06/2024 09:00	27.16	Maintenance	93.31	0	37.6	
03/06/2024 10:00	27.22	Maintenance	93.42	0	37.2	
03/06/2024 11:00	27.27	Maintenance	93.83	0	37.2	
03/06/2024 12:00	27.29	Maintenance	94.13	0	36.3	
03/06/2024 13:00	27.26	Maintenance	93.59	0	36.5	
03/06/2024 14:00	27.35	Maintenance	93.42	0	36.8	
03/06/2024 15:00	27.3	Maintenance	93.06	0	37.1	
03/06/2024 16:00	27.31	Maintenance	92.94	0	37.1	
03/06/2024 17:00	27.22	Maintenance	92.76	0	37.2	
03/06/2024 18:00	37.57	Maintenance	96.62	0	26.4	
03/06/2024 19:00	40.93	Maintenance	99.41	0	21.2	
03/06/2024 20:00	40.96	Maintenance	99.42	0	20.3	
03/06/2024 21:00	40.89	Maintenance	99.57	0	19.9	
03/06/2024 22:00	33.92	Maintenance	97.44	0	27.5	
03/06/2024 23:00	27.18	Maintenance	93.22	0	35.5	
04/06/2024 00:00	27.12	Maintenance	93.13	0	35.6	
Minimum	27.01	---	92.68	0	19.9	
MinDate	03/06/2024 06:00	03/06/2024 00:00	03/06/2024 01:00	03/06/2024 00:00	03/06/2024 21:00	
Maximum	40.96	---	99.57	0	38.5	
MaxDate	03/06/2024 20:00	03/06/2024 00:00	03/06/2024 21:00	03/06/2024 00:00	03/06/2024 08:00	
Avg	29.51	---	94.21	0	34.5	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.9	---	2.3	0	6.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/06/2024 00:00	27.18	0	92.74	1.4	43	
04/06/2024 01:00	27.18	0	92.85	1.5	42.8	
04/06/2024 02:00	27.19	0	92.93	1.5	42.5	
04/06/2024 03:00	27.19	0	92.94	1.5	42.2	
04/06/2024 04:00	27.2	0	93	1.5	41.8	
04/06/2024 05:00	27.25	0	92.83	1.5	41.5	
04/06/2024 06:00	27.26	0.32	92.86	1.5	41.5	
04/06/2024 07:00	27.56	0	93.05	1.5	40.7	
04/06/2024 08:00	30.22	0	93.76	1.5	34.6	
04/06/2024 09:00	34.12	0	95.1	1.4	22.3	
04/06/2024 10:00	34.32	0	95.37	1.4	22.3	
04/06/2024 11:00	34.29	0	95.66	1.4	22.4	
04/06/2024 12:00	21.42	0.01	93.28	1.6	53.2	
04/06/2024 13:00	34.51	0	95.2	1.5	24.5	
04/06/2024 14:00	34.47	0	95.68	1.4	23	
04/06/2024 15:00	34.48	0	95.24	1.4	23.8	
04/06/2024 16:00	34.29	0	95.13	1.4	22.6	
04/06/2024 17:00	34	0	94.89	1.4	22.5	
04/06/2024 18:00	33.95	0	94.71	1.4	22.4	
04/06/2024 19:00	33.89	0	94.54	1.3	22.2	
04/06/2024 20:00	34.01	0	94.48	1.3	22	
04/06/2024 21:00	34.09	0	94.78	1.3	21.8	
04/06/2024 22:00	34.23	0	94.95	1.3	21.7	
04/06/2024 23:00	39.75	0	95.48	1.4	24.2	
05/06/2024 00:00	47.95	0	95.12	1.3	31.4	
Minimum	21.42	0	92.74	1.3	21.7	
MinDate	04/06/2024 12:00	04/06/2024 00:00	04/06/2024 00:00	04/06/2024 19:00	04/06/2024 22:00	
Maximum	47.95	0.32	95.68	1.6	53.2	
MaxDate	05/06/2024 00:00	04/06/2024 06:00	04/06/2024 14:00	04/06/2024 12:00	04/06/2024 12:00	
Avg	32.08	0.01	94.26	1.4	31.3	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	5.3	0.1	1.1	0.1	10.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MM	mg/m3	Degree C.	ppm	ppm	
04/06/2024 00:00	27.12	Maintenance	93.12	0	35.6	
04/06/2024 01:00	27.12	Maintenance	93.23	0	35.3	
04/06/2024 02:00	27.13	Maintenance	93.3	0	35.1	
04/06/2024 03:00	27.13	Maintenance	93.31	0	34.8	
04/06/2024 04:00	27.14	Maintenance	93.34	0	34.3	
04/06/2024 05:00	27.18	Maintenance	93.12	0	34.1	
04/06/2024 06:00	27.2	Maintenance	93.17	0	34	
04/06/2024 07:00	27.5	Maintenance	93.38	0	33.5	
04/06/2024 08:00	30.18	Maintenance	94.16	0	28.4	
04/06/2024 09:00	34.06	Maintenance	95.31	0	17.1	
04/06/2024 10:00	34.26	Maintenance	95.63	0	17	
04/06/2024 11:00	34.23	Maintenance	95.93	0	17.1	
04/06/2024 12:00	21	Maintenance	93.56	0	51.5	
04/06/2024 13:00	34.44	Maintenance	95.56	0	19.3	
04/06/2024 14:00	34.41	Maintenance	95.93	0	17.6	
04/06/2024 15:00	34.42	Maintenance	95.54	0	17.5	
04/06/2024 16:00	34.22	Maintenance	95.42	0	17.3	
04/06/2024 17:00	33.94	Maintenance	95.31	0	17.2	
04/06/2024 18:00	33.88	Maintenance	95.13	0	17.1	
04/06/2024 19:00	33.83	Maintenance	94.98	0	17	
04/06/2024 20:00	33.85	Maintenance	94.95	0	16.7	
04/06/2024 21:00	34.03	Maintenance	95.1	0	16.5	
04/06/2024 22:00	34.17	Maintenance	95.18	0	16.4	
04/06/2024 23:00	8.44	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 00:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	0	---	93.12	0	16.4	
MinDate	05/06/2024 00:00	04/06/2024 06:00	04/06/2024 00:00	04/06/2024 00:00	04/06/2024 22:00	
Maximum	34.44	---	95.93	0	51.5	
MaxDate	04/06/2024 13:00	04/06/2024 00:00	04/06/2024 11:00	04/06/2024 00:00	04/06/2024 12:00	
Avg	28.84	---	94.51	0	25.2	
Num	25	0	23	23	23	
Data(%)	100	---	92	0	92	
STD	8.4	---	1.1	0	10.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/06/2024 00:00	47.95	0	95.12	1.3	31.4	
05/06/2024 01:00	48	0	95.05	1.4	31.2	
05/06/2024 02:00	48.04	0	95.2	1.4	31.5	
05/06/2024 03:00	48.03	0	95.19	1.4	31.4	
05/06/2024 04:00	48.01	0	95.25	1.4	31.3	
05/06/2024 05:00	48.12	0	95.22	1.4	31.3	
05/06/2024 06:00	48.55	0.26	95.32	1.4	31.6	
05/06/2024 07:00	48.65	0	95.64	1.4	31.3	
05/06/2024 08:00	48.48	0	95.54	1.4	31.4	
05/06/2024 09:00	47.78	0	95.79	1.4	30.8	
05/06/2024 10:00	34.09	0	95.69	1.5	30.4	
05/06/2024 11:00	34.58	0	95.87	1.4	21.9	
05/06/2024 12:00	21.95	0	92.63	1.5	44.6	
05/06/2024 13:00	34.61	0	94.6	1.4	22.4	
05/06/2024 14:00	35.28	0	95.31	1.4	21.9	
05/06/2024 15:00	35.33	0	95.19	1.4	21.7	
05/06/2024 16:00	34.95	0	94.9	1.4	21.5	
05/06/2024 17:00	34.25	0	94.53	1.4	21.4	
05/06/2024 18:00	34.27	0	94.5	1.4	21.5	
05/06/2024 19:00	34.1	0	94.41	1.3	21.5	
05/06/2024 20:00	34.09	0	94.42	1.3	21.4	
05/06/2024 21:00	34.27	0	94.77	1.3	21.3	
05/06/2024 22:00	34.48	0	95.03	1.3	21.4	
05/06/2024 23:00	31.5	0	94.52	1.4	27.3	
06/06/2024 00:00	2.38	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	2.38	0	92.63	1.3	21.3	
MinDate	06/06/2024 00:00	05/06/2024 00:00	05/06/2024 12:00	05/06/2024 00:00	05/06/2024 21:00	
Maximum	48.65	0.26	95.87	1.5	44.6	
MaxDate	05/06/2024 07:00	05/06/2024 06:00	05/06/2024 11:00	05/06/2024 10:00	05/06/2024 12:00	
Avg	38.07	0.01	94.99	1.4	27.3	
Num	25	25	24	24	24	
Data(%)	100	100	96	96	96	
STD	10.7	0.1	0.7	0.1	6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
05/06/2024 00:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 08:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 09:00	0.59	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
05/06/2024 10:00	24.6	Maintenance	95.48	0	35.9	DUST waiting for spare part
05/06/2024 11:00	34.52	Maintenance	95.29	0	23.1	DUST waiting for spare part
05/06/2024 12:00	21.93	Maintenance	93	0	44.9	DUST waiting for spare part
05/06/2024 13:00	34.56	Maintenance	95.04	0	24.2	DUST waiting for spare part
05/06/2024 14:00	33.7	Maintenance	94.94	0	22.4	DUST waiting for spare part
05/06/2024 15:00	33.61	Maintenance	94.7	0	22	DUST waiting for spare part
05/06/2024 16:00	33.79	Maintenance	94.7	0	21.6	DUST waiting for spare part
05/06/2024 17:00	34.19	Maintenance	94.94	0	21.6	DUST waiting for spare part
05/06/2024 18:00	34.21	Maintenance	95.02	0	21.5	DUST waiting for spare part
05/06/2024 19:00	34.04	Maintenance	94.87	0	21.4	DUST waiting for spare part
05/06/2024 20:00	34.03	Maintenance	94.88	0	21.3	DUST waiting for spare part
05/06/2024 21:00	34.2	Maintenance	95.02	0	21.2	DUST waiting for spare part
05/06/2024 22:00	34.41	Maintenance	95.31	0	21.3	DUST waiting for spare part
05/06/2024 23:00	31.48	Maintenance	94.65	0	26.8	DUST waiting for spare part
06/06/2024 00:00	45	Maintenance	95.25	0	38.7	DUST waiting for spare part
Minimum	0	---	93	0	21.2	
MinDate	05/06/2024 00:00	05/06/2024 00:00	05/06/2024 12:00	05/06/2024 10:00	05/06/2024 21:00	
Maximum	45	---	95.48	0	44.9	
MaxDate	06/06/2024 00:00	05/06/2024 00:00	05/06/2024 10:00	05/06/2024 10:00	05/06/2024 12:00	
Avg	19.99	---	95.07	0	25.9	
Num	25	0	15	15	15	
Data(%)	100	---	60	60	60	
STD	17.1	---	0.8	0	7.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
06/06/2024 00:00	2.38	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 06:00	0	0.21	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
06/06/2024 08:00	21.49	0	<Samp	<Samp	<Samp	GT11 S/D
06/06/2024 09:00	34.63	0	95.64	1.4	29.4	
06/06/2024 10:00	34.28	0	95.64	1.4	29.2	
06/06/2024 11:00	34.55	0	95.86	1.5	29.3	
06/06/2024 12:00	21.92	0	93.09	1.6	51.8	
06/06/2024 13:00	34.55	0	95.26	1.5	30.9	
06/06/2024 14:00	34.59	0	95.98	1.5	29.5	
06/06/2024 15:00	34.55	0	95.42	1.5	29.4	
06/06/2024 16:00	34.52	0	95.11	1.4	29.3	
06/06/2024 17:00	34.4	0	94.87	1.4	28.8	
06/06/2024 18:00	34.35	0	94.73	1.4	28.2	
06/06/2024 19:00	34.11	0	94.38	1.4	28.1	
06/06/2024 20:00	34.1	0	94.3	1.4	27.9	
06/06/2024 21:00	34.23	0	94.65	1.4	27.7	
06/06/2024 22:00	34.29	0	94.74	1.4	28	
06/06/2024 23:00	31.4	0	94.29	1.4	33.7	
07/06/2024 00:00	46.49	0	95.98	1.4	38.9	
Minimum	0	0	93.09	1.4	27.7	
MinDate	06/06/2024 01:00	06/06/2024 01:00	06/06/2024 12:00	06/06/2024 09:00	06/06/2024 21:00	
Maximum	46.49	0.21	95.98	1.6	51.8	
MaxDate	07/06/2024 00:00	06/06/2024 06:00	06/06/2024 14:00	06/06/2024 12:00	06/06/2024 12:00	
Avg	22.83	0.01	95	1.4	31.3	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16.4	0	0.8	0.1	6.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
06/06/2024 00:00	46	Maintenance	96.25	0	38.7	DUST waiting for spare part
06/06/2024 01:00	47.89	Maintenance	95.14	0	40.8	DUST waiting for spare part
06/06/2024 02:00	47.98	Maintenance	95	0	40.8	DUST waiting for spare part
06/06/2024 03:00	47.97	Maintenance	95.35	0	40.9	DUST waiting for spare part
06/06/2024 04:00	48	Maintenance	95.38	0	40.9	DUST waiting for spare part
06/06/2024 05:00	48.36	Maintenance	95.58	0	40.6	DUST waiting for spare part
06/06/2024 06:00	48.25	Maintenance	96.01	0	40.5	DUST waiting for spare part
06/06/2024 07:00	47.82	Maintenance	95.53	0	40.1	DUST waiting for spare part
06/06/2024 08:00	34.4	Maintenance	94.37	0	35.3	DUST waiting for spare part
06/06/2024 09:00	34.58	Maintenance	95.02	0	21.5	DUST waiting for spare part
06/06/2024 10:00	34.81	Maintenance	95.48	0	21.5	DUST waiting for spare part
06/06/2024 11:00	34.48	Maintenance	95.46	0	21.3	DUST waiting for spare part
06/06/2024 12:00	21.91	<Samp	92.84	0	45.6	DUST waiting for spare part
06/06/2024 13:00	34.3	Maintenance	95.11	0	22.7	DUST waiting for spare part
06/06/2024 14:00	34.53	Maintenance	95.87	0	21.3	DUST waiting for spare part
06/06/2024 15:00	34.49	Maintenance	95.48	0	21.3	DUST waiting for spare part
06/06/2024 16:00	34.45	Maintenance	95.28	0	21.1	DUST waiting for spare part
06/06/2024 17:00	34.34	Maintenance	95.07	0	20.6	DUST waiting for spare part
06/06/2024 18:00	34.29	Maintenance	94.96	0	20.2	DUST waiting for spare part
06/06/2024 19:00	34.04	Maintenance	94.69	0	20.1	DUST waiting for spare part
06/06/2024 20:00	34.03	Maintenance	94.6	0	19.9	DUST waiting for spare part
06/06/2024 21:00	34.17	Maintenance	94.88	0	19.8	DUST waiting for spare part
06/06/2024 22:00	34.23	Maintenance	94.9	0	20.1	DUST waiting for spare part
06/06/2024 23:00	31.3	Maintenance	94.31	0	28	DUST waiting for spare part
07/06/2024 00:00	2.27	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	2.27	---	92.84	0	19.8	
MinDate	07/06/2024 00:00	06/06/2024 00:00	06/06/2024 12:00	06/06/2024 00:00	06/06/2024 21:00	
Maximum	48.36	---	96.25	0	45.6	
MaxDate	06/06/2024 05:00	06/06/2024 00:00	06/06/2024 00:00	06/06/2024 00:00	06/06/2024 12:00	
Avg	36.76	---	95.11	0	26.2	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	10.2	---	0.7	0	9.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
07/06/2024 00:00	46.49	0	95.98	1.4	38.9	
07/06/2024 01:00	48.23	0	95.19	1.4	39.5	
07/06/2024 02:00	48.26	0	95.53	1.4	39.4	
07/06/2024 03:00	48.32	0	95.52	1.4	39.3	
07/06/2024 04:00	48.29	0	95.57	1.4	39.2	
07/06/2024 05:00	48.57	0	95.78	1.5	39	
07/06/2024 06:00	48.52	0.4	96.02	1.5	38.9	
07/06/2024 07:00	48.26	0	96.06	1.5	38.8	
07/06/2024 08:00	34.94	0	95.09	1.5	38.6	
07/06/2024 09:00	34.45	0	94.87	1.5	27.3	
07/06/2024 10:00	34.56	0	95.34	1.5	27.3	
07/06/2024 11:00	34.5	0	95.73	1.5	27.4	
07/06/2024 12:00	22.14	0	92.64	1.6	50.2	
07/06/2024 13:00	34.5	0	94.78	1.5	29.8	
07/06/2024 14:00	34.55	0	95.36	1.5	27.3	
07/06/2024 15:00	34.53	0	94.84	1.4	27.1	
07/06/2024 16:00	34.37	0	94.73	1.4	26.8	
07/06/2024 17:00	34.33	0	94.7	1.4	26.8	
07/06/2024 18:00	34.23	0	94.54	1.4	26.7	
07/06/2024 19:00	34.12	0	94.28	1.4	26.4	
07/06/2024 20:00	34.23	0	94.24	1.4	26.1	
07/06/2024 21:00	34.41	0	94.8	1.4	26	
07/06/2024 22:00	37.56	0	96.41	1.4	27.6	
07/06/2024 23:00	34.98	0	96.15	1.4	32.8	
08/06/2024 00:00	28.4	0	93.07	1.5	45.2	
Minimum	22.14	0	92.64	1.4	26	
MinDate	07/06/2024 12:00	07/06/2024 00:00	07/06/2024 12:00	07/06/2024 00:00	07/06/2024 21:00	
Maximum	48.57	0.4	96.41	1.6	50.2	
MaxDate	07/06/2024 05:00	07/06/2024 06:00	07/06/2024 22:00	07/06/2024 12:00	07/06/2024 12:00	
Avg	38.23	0.02	95.09	1.4	33.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.5	0.1	0.9	0.1	7.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
07/06/2024 00:00	2.27	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
07/06/2024 08:00	20.84	Maintenance	<Samp	<Samp	<Samp	
07/06/2024 09:00	34.39	Maintenance	95.14	0	22.2	DUST waiting for spare part
07/06/2024 10:00	34.5	Audit	95.33	0	22.3	DUST waiting for spare part
07/06/2024 11:00	34.45	<Samp	95.71	0	22.3	DUST waiting for spare part
07/06/2024 12:00	22.11	<Samp	92.68	0	45.8	DUST waiting for spare part
07/06/2024 13:00	34.37	<Samp	95.2	0	24.6	DUST waiting for spare part
07/06/2024 14:00	34.49	Maintenance	95.66	0	22	DUST waiting for spare part
07/06/2024 15:00	34.46	Maintenance	95.38	0	21.7	DUST waiting for spare part
07/06/2024 16:00	34.3	Maintenance	95.21	0	21.5	DUST waiting for spare part
07/06/2024 17:00	34.25	Maintenance	95.22	0	21.4	DUST waiting for spare part
07/06/2024 18:00	34.16	Maintenance	95.11	0	21.3	DUST waiting for spare part
07/06/2024 19:00	34.06	Audit	94.85	0	21	DUST waiting for spare part
07/06/2024 20:00	34.16	Audit	94.84	0	20.8	DUST waiting for spare part
07/06/2024 21:00	34.34	<Samp	95.24	0	20.8	DUST waiting for spare part
07/06/2024 22:00	37.48	<Samp	96.82	0	22.6	DUST waiting for spare part
07/06/2024 23:00	34.93	<Samp	96.62	0	27.6	DUST waiting for spare part
08/06/2024 00:00	28.35	Maintenance	93.47	0	38.8	DUST waiting for spare part
Minimum	0	---	92.68	0	20.8	
MinDate	07/06/2024 01:00	07/06/2024 00:00	07/06/2024 12:00	07/06/2024 09:00	07/06/2024 20:00	
Maximum	37.48	---	96.82	0	45.8	
MaxDate	07/06/2024 22:00	07/06/2024 00:00	07/06/2024 22:00	07/06/2024 09:00	07/06/2024 12:00	
Avg	22.32	---	95.16	0	24.8	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	15.9	---	1	0	7.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/06/2024 00:00	28.4	0	93.07	1.5	45.2	
08/06/2024 01:00	28.99	0	92.9	1.5	42.7	
08/06/2024 02:00	29.05	0	92.95	1.5	42.1	
08/06/2024 03:00	28.94	0	93.13	1.5	42.5	
08/06/2024 04:00	28.83	0	93.21	1.5	42.7	
08/06/2024 05:00	28.77	0	93.01	1.5	43.1	
08/06/2024 06:00	28.78	0.37	92.96	1.5	42.8	
08/06/2024 07:00	28.68	0	93.18	1.5	42	
08/06/2024 08:00	32.3	0	94.03	1.5	38.9	
08/06/2024 09:00	42.75	0	100.36	1.5	29	
08/06/2024 10:00	42.92	0	101.08	1.5	29.3	
08/06/2024 11:00	42.85	0	101.49	1.6	29.5	
08/06/2024 12:00	28.82	0	95.67	1.5	41	
08/06/2024 13:00	42.81	0	99.51	1.5	30.3	
08/06/2024 14:00	42.9	0	101.04	1.5	29.2	
08/06/2024 15:00	42.92	0	100.77	1.5	29	
08/06/2024 16:00	42.81	0	100.58	1.5	29	
08/06/2024 17:00	42.66	0	100.4	1.5	28.8	
08/06/2024 18:00	42.67	0	100.29	1.4	28.6	
08/06/2024 19:00	42.52	0	99.88	1.4	27.9	
08/06/2024 20:00	42.64	0	99.97	1.4	27.7	
08/06/2024 21:00	42.83	0	100.56	1.4	28.2	
08/06/2024 22:00	42.86	0	100.46	1.5	28.3	
08/06/2024 23:00	39.24	0	99.57	1.5	31.1	
09/06/2024 00:00	28.8	0	93.29	1.5	41.5	
Minimum	28.4	0	92.9	1.4	27.7	
MinDate	08/06/2024 00:00	08/06/2024 00:00	08/06/2024 01:00	08/06/2024 18:00	08/06/2024 20:00	
Maximum	42.92	0.37	101.49	1.6	45.2	
MaxDate	08/06/2024 10:00	08/06/2024 06:00	08/06/2024 11:00	08/06/2024 11:00	08/06/2024 00:00	
Avg	36.63	0.01	97.33	1.5	34.8	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.9	0.1	3.6	0	6.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
08/06/2024 00:00	28.35	Maintenance	93.47	0	38.8	DUST waiting for spare part
08/06/2024 01:00	28.93	Maintenance	93.22	0	36.8	DUST waiting for spare part
08/06/2024 02:00	28.99	<Samp	93.35	0	36.6	DUST waiting for spare part
08/06/2024 03:00	28.88	<Samp	93.51	0	36.5	DUST waiting for spare part
08/06/2024 04:00	28.77	<Samp	93.61	0	36.7	DUST waiting for spare part
08/06/2024 05:00	28.71	<Samp	93.35	0	37.2	DUST waiting for spare part
08/06/2024 06:00	28.72	<Samp	93.33	0	36.8	DUST waiting for spare part
08/06/2024 07:00	28.62	<Samp	93.51	0	36	DUST waiting for spare part
08/06/2024 08:00	32.23	<Samp	94.51	0	34.1	DUST waiting for spare part
08/06/2024 09:00	42.68	<Samp	100.63	0	26.6	DUST waiting for spare part
08/06/2024 10:00	42.84	0	101.39	0	27.1	DUST waiting for spare part
08/06/2024 11:00	42.77	<Samp	101.73	0	27.5	DUST waiting for spare part
08/06/2024 12:00	28.74	Audit	95.74	0	35.4	DUST waiting for spare part
08/06/2024 13:00	42.69	Maintenance	99.86	0	28.6	DUST waiting for spare part
08/06/2024 14:00	42.82	Maintenance	101.29	0	27.3	DUST waiting for spare part
08/06/2024 15:00	42.84	Maintenance	101.22	0	26.9	DUST waiting for spare part
08/06/2024 16:00	42.73	Maintenance	101.01	0	26.9	DUST waiting for spare part
08/06/2024 17:00	42.58	Maintenance	100.87	0	26.4	DUST waiting for spare part
08/06/2024 18:00	42.6	Maintenance	100.83	0	25.9	DUST waiting for spare part
08/06/2024 19:00	42.45	Maintenance	100.5	0	24.7	DUST waiting for spare part
08/06/2024 20:00	42.57	Maintenance	100.54	0	24.4	DUST waiting for spare part
08/06/2024 21:00	42.76	Maintenance	100.84	0	25.3	DUST waiting for spare part
08/06/2024 22:00	42.79	Maintenance	100.73	0	25.5	DUST waiting for spare part
08/06/2024 23:00	39.15	Maintenance	99.71	0	27.7	DUST waiting for spare part
09/06/2024 00:00	28.74	Maintenance	93.62	0	35.4	DUST waiting for spare part
Minimum	28.35	0	93.22	0	24.4	
MinDate	08/06/2024 00:00	08/06/2024 10:00	08/06/2024 01:00	08/06/2024 00:00	08/06/2024 20:00	
Maximum	42.84	0	101.73	0	38.8	
MaxDate	08/06/2024 10:00	08/06/2024 10:00	08/06/2024 11:00	08/06/2024 00:00	08/06/2024 00:00	
Avg	36.56	0	97.69	0	30.8	
Num	25	1	25	25	25	
Data[%]	100	4	100	100	100	
STD	6.9	---	3.6	0	5.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/06/2024 00:00	28.8	0	93.29	1.5	41.5	
09/06/2024 01:00	28.85	0	92.72	1.5	41.6	
09/06/2024 02:00	28.91	0	92.67	1.5	41.1	
09/06/2024 03:00	28.86	0	92.56	1.5	41.2	
09/06/2024 04:00	28.73	0	92.44	1.5	41.6	
09/06/2024 05:00	28.59	0	92.5	1.5	41.9	
09/06/2024 06:00	28.51	0.28	91.87	1.5	42	
09/06/2024 07:00	28.28	0	91.84	1.5	43.9	
09/06/2024 08:00	28.22	0	92.33	1.5	44.6	
09/06/2024 09:00	28.38	0	92.67	1.5	43.1	
09/06/2024 10:00	28.42	0	92.88	1.5	41.8	
09/06/2024 11:00	28.45	0	93.34	1.6	41.2	
09/06/2024 12:00	28.4	0	93.57	1.5	41	
09/06/2024 13:00	28.42	0	93.06	1.5	40.6	
09/06/2024 14:00	28.42	0	93.06	1.5	40.6	
09/06/2024 15:00	28.41	0	93.04	1.5	39.7	
09/06/2024 16:00	28.38	0	92.82	1.5	39.9	
09/06/2024 17:00	28.31	0	92.39	1.5	40.4	
09/06/2024 18:00	38.75	0	96.1	1.4	30.8	
09/06/2024 19:00	42.15	0	99.53	1.4	26.2	
09/06/2024 20:00	42.09	0	99.52	1.4	26	
09/06/2024 21:00	42.14	0	99.86	1.4	26.2	
09/06/2024 22:00	35.16	0	97.48	1.5	32.7	
09/06/2024 23:00	28.29	0	92.9	1.5	40.7	
10/06/2024 00:00	28.22	0	92.52	1.5	41	
Minimum	28.22	0	91.84	1.4	26	
MinDate	09/06/2024 08:00	09/06/2024 00:00	09/06/2024 07:00	09/06/2024 18:00	09/06/2024 20:00	
Maximum	42.15	0.28	99.86	1.6	44.6	
MaxDate	09/06/2024 19:00	09/06/2024 06:00	09/06/2024 21:00	09/06/2024 11:00	09/06/2024 08:00	
Avg	30.81	0.01	93.87	1.5	38.9	
Num	25	25	25	25	25	
Data(%)	100	100	100	100	100	
STD	4.9	0.1	2.5	0	5.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
09/06/2024 00:00	28.74	Maintenance	93.62	0	35.4	DUST waiting for spare part
09/06/2024 01:00	28.79	Maintenance	93.08	0	35.6	DUST waiting for spare part
09/06/2024 02:00	28.85	Maintenance	93.02	0	35.4	DUST waiting for spare part
09/06/2024 03:00	28.8	Maintenance	92.91	0	35.4	DUST waiting for spare part
09/06/2024 04:00	28.67	Maintenance	92.84	0	35.8	DUST waiting for spare part
09/06/2024 05:00	28.53	Maintenance	92.84	0	35.9	DUST waiting for spare part
09/06/2024 06:00	28.45	Maintenance	92.7	0	35.9	DUST waiting for spare part
09/06/2024 07:00	28.22	Maintenance	92.18	0	37	DUST waiting for spare part
09/06/2024 08:00	28.16	Maintenance	92.63	0	37.8	DUST waiting for spare part
09/06/2024 09:00	28.32	Maintenance	93	0	37	DUST waiting for spare part
09/06/2024 10:00	28.35	Maintenance	93.24	0	35.8	DUST waiting for spare part
09/06/2024 11:00	28.39	Maintenance	93.6	0	35.4	DUST waiting for spare part
09/06/2024 12:00	28.33	Maintenance	93.81	0	35	DUST waiting for spare part
09/06/2024 13:00	28.36	Maintenance	93.33	0	34.7	DUST waiting for spare part
09/06/2024 14:00	28.36	Maintenance	93.29	0	34.7	DUST waiting for spare part
09/06/2024 15:00	28.34	Maintenance	93.28	0	33.9	DUST waiting for spare part
09/06/2024 16:00	28.32	Maintenance	93.19	0	34.1	DUST waiting for spare part
09/06/2024 17:00	28.24	Maintenance	92.94	0	34.6	DUST waiting for spare part
09/06/2024 18:00	38.65	Maintenance	96.69	0	28.8	DUST waiting for spare part
09/06/2024 19:00	42.07	Maintenance	99.92	0	22.3	DUST waiting for spare part
09/06/2024 20:00	42.02	Maintenance	99.93	0	22	DUST waiting for spare part
09/06/2024 21:00	42.07	Maintenance	100.06	0	22.1	DUST waiting for spare part
09/06/2024 22:00	35.09	Maintenance	97.63	0	27.8	DUST waiting for spare part
09/06/2024 23:00	28.23	Maintenance	93.98	0	34.4	DUST waiting for spare part
10/06/2024 00:00	28.16	Maintenance	92.77	0	34.8	DUST waiting for spare part
Minimum	28.16	---	92.18	0	22	
MinDate	09/06/2024 08:00	09/06/2024 00:00	09/06/2024 07:00	09/06/2024 00:00	09/06/2024 20:00	
Maximum	42.07	---	100.06	0	37.8	
MaxDate	09/06/2024 19:00	09/06/2024 00:00	09/06/2024 21:00	09/06/2024 00:00	09/06/2024 08:00	
Avg	30.74	---	94.2	0	33.2	
Num	25	0	25	25	25	
Data(%)	100	---	100	100	100	
STD	4.9	---	2.5	0	4.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	HW	mg/m3	Degree C.	ppm	ppm	
10/06/2024 00:00	28.22	0	92.52	1.5	41	
10/06/2024 01:00	28.21	0	92.32	1.5	41.2	
10/06/2024 02:00	28.22	0	92.54	1.5	41.2	
10/06/2024 03:00	28.16	0	92.52	1.5	41.2	
10/06/2024 04:00	28.18	0	92.59	1.5	41.3	
10/06/2024 05:00	28.19	0	92.64	1.5	41.2	
10/06/2024 06:00	28.23	0.19	92.6	1.5	41.3	
10/06/2024 07:00	28.39	0	92.58	1.5	40.5	
10/06/2024 08:00	31.07	0	93.29	1.5	36.1	
10/06/2024 09:00	34.5	0	94.42	1.5	23.3	
10/06/2024 10:00	34.57	0	94.3	1.5	23.2	
10/06/2024 11:00	34.42	0	94.29	1.5	23.3	
10/06/2024 12:00	22.1	0	91.51	1.6	49.4	
10/06/2024 13:00	34.64	0	93.69	1.5	25.4	
10/06/2024 14:00	34.42	0	94.02	1.4	23.1	
10/06/2024 15:00	34.5	0	94.06	1.5	23.1	
10/06/2024 16:00	34.32	0	93.9	1.5	23.1	
10/06/2024 17:00	34.13	0	93.75	1.4	23	
10/06/2024 18:00	34.12	0	93.69	1.4	22.9	
10/06/2024 19:00	33.94	0	93.63	1.4	22.8	
10/06/2024 20:00	33.99	0	93.7	1.4	22.8	
10/06/2024 21:00	34.25	0	94.28	1.4	22.7	
10/06/2024 22:00	34.3	0	94.55	1.4	22.7	
10/06/2024 23:00	31.59	0	94.02	1.5	28.4	
11/06/2024 00:00	2.56	0.03	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	2.56	0	91.51	1.4	22.7	
MinDate	11/06/2024 00:00	10/06/2024 00:00	10/06/2024 12:00	10/06/2024 14:00	10/06/2024 21:00	
Maximum	34.64	0.19	94.55	1.6	49.4	
MaxDate	10/06/2024 13:00	10/06/2024 06:00	10/06/2024 22:00	10/06/2024 12:00	10/06/2024 12:00	
Avg	30.37	0.01	93.39	1.5	31	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	6.7	0	0.8	0.1	9.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	HW	mg/m3	Degree C.	ppm	ppm	
10/06/2024 00:00	28.16	Maintenance	92.77	0	34.8	DUST waiting for spare part
10/06/2024 01:00	28.16	Maintenance	92.66	0	34.9	DUST waiting for spare part
10/06/2024 02:00	28.17	Maintenance	92.86	0	35	DUST waiting for spare part
10/06/2024 03:00	28.1	Maintenance	92.84	0	34.9	DUST waiting for spare part
10/06/2024 04:00	28.11	Maintenance	92.9	0	35	DUST waiting for spare part
10/06/2024 05:00	28.13	Maintenance	92.93	0	34.9	DUST waiting for spare part
10/06/2024 06:00	28.17	Maintenance	92.94	0	34.9	DUST waiting for spare part
10/06/2024 07:00	28.33	Maintenance	92.97	0	34.3	DUST waiting for spare part
10/06/2024 08:00	31	Maintenance	93.71	0	30.6	DUST waiting for spare part
10/06/2024 09:00	34.44	<Samp	95.25	0	17.7	DUST waiting for spare part
10/06/2024 10:00	34.51	Maintenance	95.23	0	17.6	DUST waiting for spare part
10/06/2024 11:00	34.36	Maintenance	95.24	0	17.6	DUST waiting for spare part
10/06/2024 12:00	22.06	Maintenance	92.34	0	45.2	DUST waiting for spare part
10/06/2024 13:00	34.57	<Samp	94.39	0	19.9	DUST waiting for spare part
10/06/2024 14:00	34.35	<Samp	94.67	0	17.5	DUST waiting for spare part
10/06/2024 15:00	34.43	Maintenance	94.76	0	17.5	DUST waiting for spare part
10/06/2024 16:00	34.26	Maintenance	94.66	0	17.3	DUST waiting for spare part
10/06/2024 17:00	34.07	Maintenance	94.55	0	17.1	DUST waiting for spare part
10/06/2024 18:00	34.06	Maintenance	94.48	0	17	DUST waiting for spare part
10/06/2024 19:00	33.87	Maintenance	94.39	0	17	DUST waiting for spare part
10/06/2024 20:00	33.83	Maintenance	94.38	0	16.9	DUST waiting for spare part
10/06/2024 21:00	34.19	Maintenance	94.78	0	16.9	DUST waiting for spare part
10/06/2024 22:00	34.23	Maintenance	95.01	0	16.9	DUST waiting for spare part
10/06/2024 23:00	31.5	<Samp	94.48	0	22.9	DUST waiting for spare part
11/06/2024 00:00	45.83	<Samp	95.94	0	32.7	DUST waiting for spare part
Minimum	22.06	---	92.34	0	16.9	
MinDate	10/06/2024 12:00	10/06/2024 06:00	10/06/2024 12:00	10/06/2024 00:00	10/06/2024 20:00	
Maximum	45.83	---	95.94	0	45.2	
MaxDate	11/06/2024 00:00	10/06/2024 00:00	11/06/2024 00:00	10/06/2024 00:00	10/06/2024 12:00	
Avg	32.04	---	94.05	0	25.5	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.5	---	1	0	9.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/06/2024 00:00	2.56	0.03	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 06:00	0	0.38	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 07:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
11/06/2024 08:00	21.41	0.06	<Samp	<Samp	<Samp	
11/06/2024 09:00	34.35	0	94.58	1.5	28.8	
11/06/2024 10:00	34.36	0	95.23	1.5	29.1	
11/06/2024 11:00	34.3	0	95.33	1.5	29.2	
11/06/2024 12:00	21.83	0.09	92.61	1.7	34.5	
11/06/2024 13:00	34.5	0	94.52	1.5	30.4	
11/06/2024 14:00	34.53	0	95.18	1.5	29	
11/06/2024 15:00	34.46	0	94.66	1.5	29	
11/06/2024 16:00	34.18	0	94.33	1.5	28.8	
11/06/2024 17:00	34.12	0	94.2	1.5	28	
11/06/2024 18:00	34.07	0	94.14	1.5	27.7	
11/06/2024 19:00	33.87	0	93.78	1.5	27.9	
11/06/2024 20:00	33.92	0	93.79	1.5	27.8	
11/06/2024 21:00	34.12	0	94.34	1.5	27.7	
11/06/2024 22:00	34.18	0	94.46	1.5	27.9	
11/06/2024 23:00	31.51	0	94.08	1.5	33.8	
12/06/2024 00:00	46.55	0	95.71	1.5	40.1	
Minimum	0	0	92.61	1.5	27.7	
MinDate	11/06/2024 01:00	11/06/2024 01:00	11/06/2024 12:00	11/06/2024 09:00	11/06/2024 18:00	
Maximum	46.55	0.38	95.71	1.7	44.5	
MaxDate	12/06/2024 00:00	11/06/2024 06:00	12/06/2024 00:00	11/06/2024 12:00	11/06/2024 12:00	
Avg	22.75	0.02	94.43	1.5	31.2	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16.3	0.1	0.7	0	7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
11/06/2024 00:00	45.83	<Samp	95.94	0	32.7	
11/06/2024 01:00	47.74	Maintenance	94.6	0	34	
11/06/2024 02:00	47.97	Maintenance	95.17	0	34.1	
11/06/2024 03:00	48.15	<Samp	95.4	0	34.1	
11/06/2024 04:00	48.26	Maintenance	95.41	0	34	
11/06/2024 05:00	48.34	Maintenance	95.4	0	33.5	
11/06/2024 06:00	48.35	<Samp	95.79	0	33.4	
11/06/2024 07:00	47.98	Maintenance	95.67	0	33	
11/06/2024 08:00	34.2	<Samp	94.28	0	29.6	
11/06/2024 09:00	34.28	<Samp	94.29	0	16.7	
11/06/2024 10:00	34.3	<Samp	94.98	0	16.8	
11/06/2024 11:00	34.22	<Samp	95.13	0	16.9	
11/06/2024 12:00	21.17	<Samp	93.27	0	51.6	
11/06/2024 13:00	34.39	Maintenance	94.39	0	18.4	
11/06/2024 14:00	34.47	Maintenance	94.9	0	16.7	
11/06/2024 15:00	34.39	Maintenance	94.49	0	16.7	
11/06/2024 16:00	34.12	Maintenance	94.27	0	16.5	
11/06/2024 17:00	34.06	Maintenance	94.18	0	16.2	
11/06/2024 18:00	34.01	Maintenance	94.09	0	16.1	
11/06/2024 19:00	33.8	Maintenance	93.75	0	16.4	
11/06/2024 20:00	33.85	Maintenance	93.74	0	16.3	
11/06/2024 21:00	34.06	Maintenance	94.18	0	16.3	
11/06/2024 22:00	34.12	Maintenance	94.27	0	16.4	
11/06/2024 23:00	31.44	Maintenance	93.79	0	22.7	
12/06/2024 00:00	2.51	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	2.51	---	92.27	0	16.1	
MinDate	12/06/2024 00:00	11/06/2024 00:00	11/06/2024 12:00	11/06/2024 00:00	11/06/2024 18:00	
Maximum	48.35	---	95.94	0	51.6	
MaxDate	11/06/2024 06:00	11/06/2024 00:00	11/06/2024 00:00	11/06/2024 00:00	11/06/2024 12:00	
Avg	35.64	---	94.6	0	24.5	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	10.3	---	0.8	0	9.9	

Date & Time	11CT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/06/2024 00:00	46.55	0	95.71	1.5	40.1	
12/06/2024 01:00	48.76	0	95.13	1.5	40.3	
12/06/2024 02:00	48.79	0	95.64	1.6	40	
12/06/2024 03:00	48.89	0	95.54	1.6	39.7	
12/06/2024 04:00	48.94	0	95.41	1.8	39.5	
12/06/2024 05:00	48.71	0	95.48	1.6	39.5	
12/06/2024 06:00	48.53	0.32	95.62	1.6	39.6	
12/06/2024 07:00	48.33	0	95.40	1.6	39.3	
12/06/2024 08:00	36.12	0	95.31	1.6	39.3	
12/06/2024 09:00	34.4	0	95.22	1.6	27.6	
12/06/2024 10:00	34.44	0	95.3	1.6	27.7	
12/06/2024 11:00	34.37	0	95.51	1.6	27.8	
12/06/2024 12:00	21.8	0	92.53	1.7	33.5	
12/06/2024 13:00	34.54	0	94.99	1.6	29.4	
12/06/2024 14:00	34.43	0	95.49	1.5	27.8	
12/06/2024 15:00	34.42	0	95.31	1.5	27.6	
12/06/2024 16:00	34.24	0	94.94	1.5	27.3	
12/06/2024 17:00	34.1	0	94.75	1.5	26.7	
12/06/2024 18:00	34.09	0	94.47	1.5	26.2	
12/06/2024 19:00	33.9	0	94.5	1.4	25.8	
12/06/2024 20:00	33.97	0	94.55	1.4	25.6	
12/06/2024 21:00	34.12	0	94.94	1.4	25.8	
12/06/2024 22:00	34.24	0	95.08	1.5	25.5	
12/06/2024 23:00	31.51	0	94.67	1.5	30.9	
13/06/2024 00:00	2.59	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	13/06/2024 00:00	0	92.53	1.4	25.3	
MinDate	13/06/2024 00:00	12/06/2024 00:00	12/06/2024 12:00	12/06/2024 19:00	12/06/2024 22:00	
Maximum	48.94	0.32	95.71	1.7	53.6	
MaxDate	12/06/2024 04:00	12/06/2024 06:00	12/06/2024 00:00	12/06/2024 12:00	12/06/2024 12:00	
Avg	36.99	0.01	95.68	1.5	33	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	10.4	0.1	0.7	0.1	7.6	

Date & Time	12CT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
12/06/2024 00:00	2.51	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 01:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
12/06/2024 08:00	19.36	Audit	<Samp	<Samp	<Samp	
12/06/2024 09:00	34.34	<Samp	95.45	0	23	
12/06/2024 10:00	34.38	<Samp	95.29	0	23.2	
12/06/2024 11:00	34.3	<Samp	95.47	0	23.4	
12/06/2024 12:00	21.36	<Samp	92.45	0	52.1	
12/06/2024 13:00	34.45	<Samp	94.95	0	24.6	
12/06/2024 14:00	34.36	<Samp	95.39	0	22.9	
12/06/2024 15:00	34.36	Maintenance	95.24	0	22.7	
12/06/2024 16:00	34.18	<Samp	94.93	0	22.3	
12/06/2024 17:00	34.04	Maintenance	94.85	0	21.9	
12/06/2024 18:00	34.02	Maintenance	94.57	0	21.4	
12/06/2024 19:00	33.84	Maintenance	94.55	0	21	
12/06/2024 20:00	33.91	Maintenance	94.61	0	20.9	
12/06/2024 21:00	34.05	Maintenance	94.8	0	20.8	
12/06/2024 22:00	34.17	Maintenance	94.98	0	20.8	
12/06/2024 23:00	31.45	Maintenance	94.53	0	25.9	
13/06/2024 00:00	45.99	Maintenance	95.34	0	38.2	
Minimum	0	---	92.45	0	20.8	
MinDate	12/06/2024 01:00	12/06/2024 00:00	12/06/2024 12:00	12/06/2024 09:00	12/06/2024 21:00	
Maximum	45.99	---	95.34	0	52.1	
MaxDate	13/06/2024 00:00	12/06/2024 00:00	13/06/2024 00:00	12/06/2024 09:00	12/06/2024 12:00	
Avg	22.6	---	94.91	0	25.3	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	16.3	---	0.8	0	8.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/06/2024 00:00	2.59	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 06:00	0	0.28	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 07:00	0	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
13/06/2024 08:00	21.32	0.09	<Samp	<Samp	<Samp	GT11 S/D
13/06/2024 09:00	34.45	0	95.69	1.6	28.9	
13/06/2024 10:00	34.49	0	95.71	1.6	29.4	
13/06/2024 11:00	34.36	0	95.83	1.6	29.5	
13/06/2024 12:00	22.75	0	93.62	1.7	53.5	
13/06/2024 13:00	34.53	0	94.92	1.6	31.3	
13/06/2024 14:00	34.93	0	95.66	1.6	29.5	
13/06/2024 15:00	34.93	0	95.67	1.6	29.4	
13/06/2024 16:00	34.31	0	95.43	1.6	28.7	
13/06/2024 17:00	34.19	0	95.17	1.5	28.6	
13/06/2024 18:00	34.12	0	94.99	1.5	28.4	
13/06/2024 19:00	33.9	0	94.84	1.5	28.2	
13/06/2024 20:00	34.05	0	94.54	1.5	27.6	
13/06/2024 21:00	34.19	0	94.59	1.5	26.9	
13/06/2024 22:00	34.21	0	95.1	1.5	26.7	
13/06/2024 23:00	31.37	0	94.89	1.5	31.8	
14/06/2024 00:00	46.47	0	96.29	1.5	37.4	
Minimum	0	0	93.62	1.5	26.7	
MinDate	13/06/2024 01:00	13/06/2024 00:00	13/06/2024 12:00	13/06/2024 17:00	13/06/2024 22:00	
Maximum	46.47	0.28	96.29	1.7	53.5	
MaxDate	14/06/2024 00:00	13/06/2024 06:00	14/06/2024 00:00	13/06/2024 12:00	13/06/2024 12:00	
Avg	22.85	0.02	95.18	1.6	31	
Num	25	25	16	16	16	
Data(%)	100	100	64	64	64	
STD	16.4	0.1	0.6	0.1	6.5	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
13/06/2024 00:00	45.99	Maintenance	96.34	0	38.2	DUST waiting for spare part
13/06/2024 01:00	48.05	Maintenance	95.18	0	40.1	DUST waiting for spare part
13/06/2024 02:00	48.15	Maintenance	95.1	0	40.1	DUST waiting for spare part
13/06/2024 03:00	48.18	Maintenance	95.36	0	40	DUST waiting for spare part
13/06/2024 04:00	48.14	Maintenance	95.34	0	40.1	DUST waiting for spare part
13/06/2024 05:00	48.09	Maintenance	95.37	0	40	DUST waiting for spare part
13/06/2024 06:00	48.09	Maintenance	95.56	0	39.6	DUST waiting for spare part
13/06/2024 07:00	47.73	<Samp	96.23	0	39.4	DUST waiting for spare part
13/06/2024 08:00	34.35	<Samp	94.92	0	34.1	DUST waiting for spare part
13/06/2024 09:00	34.37	Maintenance	95.28	0	20.8	DUST waiting for spare part
13/06/2024 10:00	34.43	Maintenance	95.44	0	21.3	DUST waiting for spare part
13/06/2024 11:00	34.31	Maintenance	95.68	0	21.5	DUST waiting for spare part
13/06/2024 12:00	21.88	Maintenance	93.27	0	48.4	DUST waiting for spare part
13/06/2024 13:00	34.42	Maintenance	94.74	0	23.3	DUST waiting for spare part
13/06/2024 14:00	34.08	Maintenance	95.16	0	21.1	DUST waiting for spare part
13/06/2024 15:00	33.99	Maintenance	94.62	0	20.7	DUST waiting for spare part
13/06/2024 16:00	34.25	Maintenance	95.18	0	20.6	DUST waiting for spare part
13/06/2024 17:00	34.12	Maintenance	94.97	0	20.5	DUST waiting for spare part
13/06/2024 18:00	34.06	Maintenance	94.9	0	20.4	DUST waiting for spare part
13/06/2024 19:00	33.83	Maintenance	94.74	0	20.2	DUST waiting for spare part
13/06/2024 20:00	33.97	Maintenance	94.5	0	19.8	DUST waiting for spare part
13/06/2024 21:00	34.12	Maintenance	94.54	0	19.2	DUST waiting for spare part
13/06/2024 22:00	35.15	Auto	94.87	0	19	DUST waiting for spare part
13/06/2024 23:00	31.23	Maintenance	94.54	0	24.5	DUST waiting for spare part
14/06/2024 00:00	2.13	Maintenance	ShutDown	ShutDown	ShutDown	GT12 shutdown.
Minimum	2.13	---	93.27	0	19	
MinDate	14/06/2024 00:00	13/06/2024 00:00	13/06/2024 12:00	13/06/2024 00:00	13/06/2024 22:00	
Maximum	48.18	---	96.34	0	48.4	
MaxDate	13/06/2024 03:00	13/06/2024 00:00	13/06/2024 00:00	13/06/2024 00:00	13/06/2024 12:00	
Avg	35.64	---	95.09	0	28.9	
Num	25	0	24	24	24	
Data(%)	100	---	96	96	96	
STD	10.3	---	0.6	0	6.9	

Date & Time	11GT_LOAD HW	11HRSG_DUST mg/m3	11HRSG_TEMP Degree C	11HRSG_SO2@7%O2 ppm	11HRSG_NOx@7%O2 ppm	Remark
14/06/2024 00:00	46.47	0	96.29	1.5	37.4	
14/06/2024 01:00	48.02	0	95.55	1.5	38.3	
14/06/2024 02:00	48.12	0	95.93	1.5	38.1	
14/06/2024 03:00	48.08	0	95.86	1.5	38	
14/06/2024 04:00	48.15	0	95.94	1.6	37.9	
14/06/2024 05:00	48.18	0	95.93	1.6	38.2	
14/06/2024 06:00	48.2	0.21	96.36	1.6	38.2	
14/06/2024 07:00	47.81	0	96.05	1.6	38.2	
14/06/2024 08:00	34.61	0	95.17	1.7	37.9	
14/06/2024 09:00	34.44	0	95.29	1.6	26.5	
14/06/2024 10:00	34.6	0	95.52	1.6	26.5	
14/06/2024 11:00	34.27	0	95.64	1.6	26.6	
14/06/2024 12:00	21.92	0	93.44	1.8	51.1	
14/06/2024 13:00	34.61	0	94.82	1.6	29	
14/06/2024 14:00	34.31	0	95.31	1.6	27.3	
14/06/2024 15:00	34.16	0	95.1	1.6	27.1	
14/06/2024 16:00	34.05	0	94.93	1.6	26.8	
14/06/2024 17:00	33.94	0	94.73	1.5	26.6	
14/06/2024 18:00	33.88	0	94.55	1.5	26.1	
14/06/2024 19:00	33.79	0	94.32	1.5	25.9	
14/06/2024 20:00	33.88	0	94.44	1.5	25.3	
14/06/2024 21:00	34.31	0	94.98	1.5	25.3	
14/06/2024 22:00	37.38	0	96.56	1.5	26.3	
14/06/2024 23:00	34.76	0	96.94	1.5	31.3	
15/06/2024 00:00	28.16	0	93.7	1.5	42.5	
Minimum	21.92	0	93.44	1.5	25.3	
MinDate	14/06/2024 12:00	14/06/2024 00:00	14/06/2024 12:00	14/06/2024 00:00	14/06/2024 20:00	
Maximum	48.2	0.21	96.94	1.8	51.1	
MaxDate	14/06/2024 06:00	14/06/2024 06:00	14/06/2024 23:00	14/06/2024 12:00	14/06/2024 12:00	
Avg	38.01	0.01	95.33	1.6	32.5	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.5	0	0.9	0.1	7	

Date & Time	12GT_LOAD HW	12HRSG_DUST mg/m3	12HRSG_TEMP Degree C	12HRSG_SO2@7%O2 ppm	12HRSG_NOx@7%O2 ppm	Remark
14/06/2024 00:00	2.13	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 01:00	0	<Samp	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
14/06/2024 08:00	20.89	Maintenance	<Samp	<Samp	<Samp	GT12 S/D
14/06/2024 09:00	34.37	Maintenance	95.65	0	22.2	DUST waiting for spare part
14/06/2024 10:00	34.14	Maintenance	95.39	0	22	DUST waiting for spare part
14/06/2024 11:00	34.2	Maintenance	95.71	0	22.1	DUST waiting for spare part
14/06/2024 12:00	21.87	<Samp	93.51	0	47.3	DUST waiting for spare part
14/06/2024 13:00	34.18	<Samp	94.79	0	24.3	DUST waiting for spare part
14/06/2024 14:00	34.24	<Samp	95.25	0	22.7	DUST waiting for spare part
14/06/2024 15:00	34.1	Maintenance	95.18	0	22.4	DUST waiting for spare part
14/06/2024 16:00	33.98	Maintenance	95.09	0	22.2	DUST waiting for spare part
14/06/2024 17:00	33.87	Maintenance	94.95	0	21.9	DUST waiting for spare part
14/06/2024 18:00	33.81	Maintenance	94.77	0	21.5	DUST waiting for spare part
14/06/2024 19:00	33.72	Maintenance	94.6	0	21.2	DUST waiting for spare part
14/06/2024 20:00	33.91	Maintenance	94.75	0	20.7	DUST waiting for spare part
14/06/2024 21:00	34.24	Maintenance	95.05	0	20.8	DUST waiting for spare part
14/06/2024 22:00	37.3	Maintenance	96.68	0	21.9	DUST waiting for spare part
14/06/2024 23:00	34.66	Maintenance	96.94	0	26.9	DUST waiting for spare part
15/06/2024 00:00	28.09	Maintenance	93.88	0	36.3	DUST waiting for spare part
Minimum	0		93.51	0	20.7	
MinDate	14/06/2024 01:00	14/06/2024 00:00	14/06/2024 12:00	14/06/2024 09:00	14/06/2024 20:00	
Maximum	37.3	---	96.94	0	47.3	
MaxDate	14/06/2024 22:00	14/06/2024 00:00	14/06/2024 23:00	14/06/2024 09:00	14/06/2024 12:00	
Avg	22.15		95.14	0	24.8	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	15.8	---	0.9	0	7.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
15/06/2024 00:00	28.16	0	93.7	1.5	42.5	
15/06/2024 01:00	28.76	0	93.52	1.5	41	
15/06/2024 02:00	28.82	0	93.23	1.6	41.5	
15/06/2024 03:00	28.7	0	93.19	1.6	42.1	
15/06/2024 04:00	28.56	0	93.05	1.6	42.6	
15/06/2024 05:00	28.5	0	93	1.6	43	
15/06/2024 06:00	28.48	0.15	93.13	1.6	42.7	
15/06/2024 07:00	28.41	0	93.52	1.6	42.5	
15/06/2024 08:00	31.81	0	94.39	1.6	39.4	
15/06/2024 09:00	42.45	0	100.68	1.6	28.6	
15/06/2024 10:00	42.55	0	101.41	1.6	28.9	
15/06/2024 11:00	42.53	0	101.69	1.6	29	
15/06/2024 12:00	28.5	0	96.09	1.6	41.1	
15/06/2024 13:00	42.34	0	99.75	1.7	29.5	
15/06/2024 14:00	42.48	0	101.28	1.6	28.6	
15/06/2024 15:00	42.49	0	101.04	1.6	28.9	
15/06/2024 16:00	42.34	0	100.83	1.6	29.3	
15/06/2024 17:00	42.3	0	100.75	1.6	28.9	
15/06/2024 18:00	42.29	0	100.52	1.6	28.6	
15/06/2024 19:00	42.14	0	100.25	1.5	28.8	
15/06/2024 20:00	42.13	0	99.95	1.5	28.2	
15/06/2024 21:00	42.22	0	100.12	1.5	27.5	
15/06/2024 22:00	42.25	0	100.51	1.5	27.2	
15/06/2024 23:00	36.64	0	99.85	1.5	29.8	
16/06/2024 00:00	28.3	0	93.85	1.5	40.1	
Minimum	28.16	0	93	1.5	27.2	
MinDate	15/06/2024 00:00	15/06/2024 00:00	15/06/2024 05:00	15/06/2024 00:00	15/06/2024 22:00	
Maximum	42.55	0.15	101.69	1.7	43	
MaxDate	15/06/2024 10:00	15/06/2024 06:00	15/06/2024 11:00	15/06/2024 13:00	15/06/2024 05:00	
Avg	36.25	0.01	97.57	1.6	34.4	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.8	0	3.6	0.1	6.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
15/06/2024 00:00	28.09	Maintenance	93.88	0	36.3	DUST waiting for spare part
15/06/2024 01:00	28.7	Maintenance	93.53	0	35.5	DUST waiting for spare part
15/06/2024 02:00	28.76	Maintenance	93.24	0	36.1	DUST waiting for spare part
15/06/2024 03:00	28.64	Maintenance	93.19	0	36.5	DUST waiting for spare part
15/06/2024 04:00	28.5	Maintenance	93	0	36.9	DUST waiting for spare part
15/06/2024 05:00	28.44	Maintenance	93.05	0	37.2	DUST waiting for spare part
15/06/2024 06:00	28.42	Maintenance	93.12	0	36.9	DUST waiting for spare part
15/06/2024 07:00	28.35	Maintenance	93.49	0	36.7	DUST waiting for spare part
15/06/2024 08:00	31.77	Maintenance	94.52	0	35	DUST waiting for spare part
15/06/2024 09:00	42.39	Maintenance	100.56	0	26.7	DUST waiting for spare part
15/06/2024 10:00	42.46	Maintenance	101.31	0	27.2	DUST waiting for spare part
15/06/2024 11:00	42.45	Maintenance	101.56	0	27.5	DUST waiting for spare part
15/06/2024 12:00	28.44	Maintenance	95.9	0	36.1	DUST waiting for spare part
15/06/2024 13:00	42.27	Maintenance	99.7	0	28.3	DUST waiting for spare part
15/06/2024 14:00	42.4	Maintenance	101.09	0	27.3	DUST waiting for spare part
15/06/2024 15:00	42.41	Maintenance	101.03	0	27.6	DUST waiting for spare part
15/06/2024 16:00	42.27	Maintenance	100.71	0	28.1	DUST waiting for spare part
15/06/2024 17:00	42.22	Maintenance	100.71	0	27.5	DUST waiting for spare part
15/06/2024 18:00	42.21	Maintenance	100.6	0	27	DUST waiting for spare part
15/06/2024 19:00	42.06	Maintenance	100.31	0	26.7	DUST waiting for spare part
15/06/2024 20:00	42.05	Maintenance	100	0	25.6	DUST waiting for spare part
15/06/2024 21:00	42.14	Maintenance	100.01	0	24.4	DUST waiting for spare part
15/06/2024 22:00	42.17	Maintenance	100.34	0	24.1	DUST waiting for spare part
15/06/2024 23:00	38.59	Maintenance	99.68	0	26.4	DUST waiting for spare part
16/06/2024 00:00	28.24	Maintenance	93.89	0	34.5	DUST waiting for spare part
Minimum	28.09	—	93	0	24.1	
MinDate	15/06/2024 00:00	15/06/2024 00:00	15/06/2024 04:00	15/06/2024 00:00	15/06/2024 22:00	
Maximum	42.46	—	101.56	0	37.2	
MaxDate	15/06/2024 10:00	15/06/2024 00:00	15/06/2024 11:00	15/06/2024 00:00	15/06/2024 05:00	
Avg	36.18	—	97.53	0	30.9	
Num	25	0	25	25	25	
Data[%]	100	—	100	100	100	
STD	6.8	—	3.5	0	4.9	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/06/2024 00:00	28.3	0	93.85	1.5	40.1	
16/06/2024 01:00	28.38	0	93.46	1.5	39.3	
16/06/2024 02:00	28.4	0	93.44	1.5	39	
16/06/2024 03:00	28.34	0	93.35	1.6	39.5	
16/06/2024 04:00	28.13	0	93.07	1.6	40.7	
16/06/2024 05:00	28.02	0	92.9	1.6	41.9	
16/06/2024 06:00	27.77	0.34	93	1.6	42.8	
16/06/2024 07:00	27.51	0	93.34	1.6	43.4	
16/06/2024 08:00	27.26	0	93.4	1.6	43.9	
16/06/2024 09:00	27.29	0	93.32	1.6	43.3	
16/06/2024 10:00	27.23	0	93.44	1.6	43.4	
16/06/2024 11:00	27.24	0	93.84	1.6	43.1	
16/06/2024 12:00	27.33	0	93.76	1.6	42	
16/06/2024 13:00	27.33	0	93.41	1.6	41.9	
16/06/2024 14:00	27.37	0	93.08	1.6	42	
16/06/2024 15:00	27.33	0	92.53	1.6	42.7	
16/06/2024 16:00	27.3	0	92.55	1.6	42.9	
16/06/2024 17:00	27.31	0	92.51	1.6	42.5	
16/06/2024 18:00	37.89	0	96.2	1.6	51.1	
16/06/2024 19:00	41.07	0	98.16	1.6	25.6	
16/06/2024 20:00	41.03	0	99.1	1.5	25.9	
16/06/2024 21:00	41.02	0	99.33	1.5	25.9	
16/06/2024 22:00	34.04	0	97.25	1.5	32.9	
16/06/2024 23:00	27.26	0	93.98	1.6	42.1	
17/06/2024 00:00	27.27	0	92.98	1.6	41.7	GT11 SD
Minimum	27.23	0	92.51	1.5	25.6	
MnDate	16/06/2024 10:00	16/06/2024 00:00	16/06/2024 17:00	16/06/2024 00:00	16/06/2024 19:00	
Maximum	41.07	0.34	99.33	1.6	43.9	
MaxDate	16/06/2024 19:00	16/06/2024 06:00	16/06/2024 21:00	16/06/2024 03:00	16/06/2024 08:00	
Avg	29.89	0.01	94.21	1.6	39.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	4.8	0.1	2.1	0	5.9	

Date & Time	11GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
16/06/2024 00:00	28.24	Maintenance	93.89	0	34.5	DUST waiting for spare part
16/06/2024 01:00	28.32	Maintenance	93.46	0	33.7	DUST waiting for spare part
16/06/2024 02:00	28.33	Maintenance	93.44	0	33.5	DUST waiting for spare part
16/06/2024 03:00	28.28	Maintenance	93.36	0	33.9	DUST waiting for spare part
16/06/2024 04:00	28.07	Maintenance	92.97	0	35.1	DUST waiting for spare part
16/06/2024 05:00	27.96	Maintenance	92.69	0	36.4	DUST waiting for spare part
16/06/2024 06:00	27.71	Maintenance	92.89	0	37.2	DUST waiting for spare part
16/06/2024 07:00	27.44	Maintenance	93.22	0	37.4	DUST waiting for spare part
16/06/2024 08:00	27.2	Maintenance	93.32	0	37.8	DUST waiting for spare part
16/06/2024 09:00	27.23	Maintenance	93.24	0	37.4	DUST waiting for spare part
16/06/2024 10:00	27.17	Maintenance	93.33	0	37.4	DUST waiting for spare part
16/06/2024 11:00	27.18	Maintenance	93.78	0	37.3	DUST waiting for spare part
16/06/2024 12:00	27.27	Maintenance	93.66	0	36.5	DUST waiting for spare part
16/06/2024 13:00	27.26	Maintenance	93.31	0	36.4	DUST waiting for spare part
16/06/2024 14:00	27.31	Maintenance	93.01	0	36.6	DUST waiting for spare part
16/06/2024 15:00	27.27	Maintenance	92.62	0	37.1	DUST waiting for spare part
16/06/2024 16:00	27.24	Maintenance	92.69	0	37.5	DUST waiting for spare part
16/06/2024 17:00	27.24	Maintenance	92.67	0	36.9	DUST waiting for spare part
16/06/2024 18:00	37.63	Maintenance	96.32	0	27.1	DUST waiting for spare part
16/06/2024 19:00	41	Maintenance	99.1	0	21.4	DUST waiting for spare part
16/06/2024 20:00	40.96	Maintenance	99.08	0	21.6	DUST waiting for spare part
16/06/2024 21:00	40.94	Maintenance	99.21	0	21.4	DUST waiting for spare part
16/06/2024 22:00	33.98	Maintenance	97.06	0	28.1	DUST waiting for spare part
16/06/2024 23:00	27.22	<Dump	93.05	0	35.7	DUST waiting for spare part
17/06/2024 00:00	27.22	Maintenance	92.67	0	35.4	DUST waiting for spare part
Minimum	27.17	---	92.62	0	21.4	
MnDate	16/06/2024 10:00	16/06/2024 00:00	16/06/2024 15:00	16/06/2024 00:00	16/06/2024 19:00	
Maximum	41	---	99.21	0	37.8	
MaxDate	16/06/2024 19:00	16/06/2024 00:00	16/06/2024 21:00	16/06/2024 00:00	16/06/2024 08:00	
Avg	29.83	---	94.17	0	33.7	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	4.8	---	2.1	0	5.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/06/2024 00:00	27.27	0	92.96	1.6	41.7	
17/06/2024 01:00	27.31	0	92.82	1.6	42.1	
17/06/2024 02:00	27.25	0	92.7	1.6	42.7	
17/06/2024 03:00	27.27	0	92.96	1.6	42.2	
17/06/2024 04:00	27.23	0	92.55	1.6	42.7	
17/06/2024 05:00	27.17	0	91.13	1.6	44.4	
17/06/2024 06:00	27.19	0.28	92.18	1.7	44.2	
17/06/2024 07:00	27.41	0	92.53	1.7	43.7	
17/06/2024 08:00	31.05	0	93.59	1.7	38	
17/06/2024 09:00	34.05	0	95.18	1.6	22.5	
17/06/2024 10:00	34.14	0	95.19	1.6	22.2	
17/06/2024 11:00	34.32	0	95.54	1.6	22.3	
17/06/2024 12:00	22.06	0	92.64	1.8	48.4	
17/06/2024 13:00	34.48	0	95.11	1.6	24.2	
17/06/2024 14:00	34.4	0	95.51	1.6	22.3	
17/06/2024 15:00	34.4	0	95.15	1.6	22.3	
17/06/2024 16:00	34.25	0.01	95.16	1.6	22.3	
17/06/2024 17:00	34.12	0.03	94.98	1.6	22.3	
17/06/2024 18:00	34.09	0	94.45	1.6	22.2	
17/06/2024 19:00	33.92	0	94.34	1.5	22.2	
17/06/2024 20:00	33.99	0	94.39	1.5	22.1	
17/06/2024 21:00	34.2	0	94.89	1.5	22	
17/06/2024 22:00	34.23	0	95.1	1.5	21.9	
17/06/2024 23:00	31.46	0	94.84	1.5	27.2	
19/06/2024 00:00	2.57	0.05	ShutDown	ShutDown	ShutDown	GT11 SD
Minimum	2.57	0	91.13	1.5	21.9	
MnDate	18/06/2024 00:00	17/06/2024 00:00	17/06/2024 05:00	17/06/2024 19:00	17/06/2024 22:00	
Maximum	34.48	0.28	95.54	1.8	48.4	
MaxDate	17/06/2024 13:00	17/06/2024 06:00	17/06/2024 11:00	17/06/2024 12:00	17/06/2024 12:00	
Avg	29.99	0.01	94	1.6	31.2	
Num	25	25	24	24	24	
Data(%)	100	100	96	96	96	
STD	6.8	0.1	1.3	0.1	10.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
17/06/2024 00:00	27.22	Maintenance	92.87	0	35.4	DUST waiting for spare part
17/06/2024 01:00	27.24	Maintenance	92.73	0	36	DUST waiting for spare part
17/06/2024 02:00	27.19	Maintenance	92.67	0	36.5	DUST waiting for spare part
17/06/2024 03:00	27.2	Maintenance	92.94	0	35.9	DUST waiting for spare part
17/06/2024 04:00	27.17	<Samp	92.4	0	36.7	DUST waiting for spare part
17/06/2024 05:00	27.11	<Samp	90.96	0	39.3	DUST waiting for spare part
17/06/2024 06:00	27.13	0.11	92.07	0	38.9	DUST waiting for spare part
17/06/2024 07:00	27.35	0.16	92.35	0	37.5	DUST waiting for spare part
17/06/2024 08:00	30.99	0.22	93.52	0	32.5	DUST waiting for spare part
17/06/2024 09:00	33.99	0.28	94.92	0	17.5	DUST waiting for spare part
17/06/2024 10:00	34.07	0.29	94.92	0	17.2	DUST waiting for spare part
17/06/2024 11:00	34.25	0.51	95.2	0	17.2	DUST waiting for spare part
17/06/2024 12:00	22.04	<Samp	92.45	0	43.6	DUST waiting for spare part
17/06/2024 13:00	34.42	<Samp	95.06	0	19.2	DUST waiting for spare part
17/06/2024 14:00	34.34	Maintenance	95.37	0	17.1	DUST waiting for spare part
17/06/2024 15:00	34.34	Maintenance	95.18	0	17	DUST waiting for spare part
17/06/2024 16:00	34.19	Maintenance	95.14	0	16.9	DUST waiting for spare part
17/06/2024 17:00	34.05	Maintenance	95.02	0	16.9	DUST waiting for spare part
17/06/2024 18:00	34.03	Maintenance	94.61	0	16.7	DUST waiting for spare part
17/06/2024 19:00	33.85	Maintenance	94.4	0	16.7	DUST waiting for spare part
17/06/2024 20:00	33.93	Maintenance	94.43	0	16.6	DUST waiting for spare part
17/06/2024 21:00	34.13	Maintenance	94.78	0	16.6	DUST waiting for spare part
17/06/2024 22:00	34.16	Maintenance	94.92	0	16.5	DUST waiting for spare part
17/06/2024 23:00	31.43	Maintenance	94.69	0	21.8	DUST waiting for spare part
18/06/2024 00:00	45.94	Maintenance	96.33	0	31.1	DUST waiting for spare part
Minimum	22.04	0.11	90.96	0	16.5	
MnDate	17/06/2024 12:00	17/06/2024 06:00	17/06/2024 05:00	17/06/2024 00:00	17/06/2024 22:00	
Maximum	45.94	0.51	96.33	0	43.6	
MaxDate	18/06/2024 00:00	17/06/2024 11:00	18/06/2024 00:00	17/06/2024 00:00	17/06/2024 12:00	
Avg	31.67	0.26	94	0	25.9	
Num	25	6	25	25	25	
Data(%)	100	24	100	100	100	
STD	4.7	0.1	1.4	0	10	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/06/2024 00:00	2.57	0.05	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 01:00	0	0.05	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 02:00	0	0.1	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 03:00	0	0.1	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 04:00	0	0.11	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 05:00	0	0.14	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 06:00	0	0.24	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
18/06/2024 08:00	20.81	0	<Samp	<Samp	<Samp	GT11 SD
18/06/2024 09:00	34.44	0	95.73	1.6	30.7	
18/06/2024 10:00	34.52	0	95.14	1.7	30.2	
18/06/2024 11:00	34.49	0	95.2	1.7	30.6	
18/06/2024 12:00	22.13	0	92.46	1.8	53	
18/06/2024 13:00	34.59	0	94.85	1.7	32.2	
18/06/2024 14:00	34.47	0	95.12	1.6	29.7	
18/06/2024 15:00	34.48	0	94.89	1.6	29.7	
18/06/2024 16:00	34.35	0	94.93	1.6	29.6	
18/06/2024 17:00	34.16	0	94.63	1.6	29.4	
18/06/2024 18:00	34.05	0	94.32	1.6	28.9	
18/06/2024 19:00	33.91	0	93.63	1.5	27.8	
18/06/2024 20:00	34.04	0	93.89	1.5	27.8	
18/06/2024 21:00	34.24	0	94.43	1.5	27.7	
18/06/2024 22:00	34.35	0	94.6	1.5	27.6	
18/06/2024 23:00	31.55	0	94.21	1.6	32.3	
19/06/2024 00:00	46.4	0	95.77	1.6	38.7	
Minimum	0	0	92.46	1.5	27.6	
MinDate	18/06/2024 01:00	18/06/2024 07:00	18/06/2024 12:00	18/06/2024 19:00	18/06/2024 22:00	
Maximum	46.4	0.24	95.77	1.8	53	
MaxDate	19/06/2024 00:00	18/06/2024 06:00	19/06/2024 00:00	18/06/2024 12:00	18/06/2024 12:00	
Avg	22.78	0.03	94.61	1.6	31.6	
Num	25	25	16	16	16	
Data(%)	100	100	64	64	64	
STD	16.3	0.1	0.8	0.1	6.3	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
18/06/2024 00:00	45.94	Maintenance	96.33	0	31.1	DUST waiting for spare part
18/06/2024 01:00	47.63	Maintenance	94.9	0	33.1	DUST waiting for spare part
18/06/2024 02:00	47.49	Maintenance	94.91	0	33.5	DUST waiting for spare part
18/06/2024 03:00	47.59	Maintenance	95.16	0	33.4	DUST waiting for spare part
18/06/2024 04:00	47.74	Maintenance	95.25	0	33.3	DUST waiting for spare part
18/06/2024 05:00	47.73	Maintenance	95.45	0	33.2	DUST waiting for spare part
18/06/2024 06:00	48	Maintenance	95.71	0	33	DUST waiting for spare part
18/06/2024 07:00	47.84	Maintenance	95.8	0	32.5	DUST waiting for spare part
18/06/2024 08:00	33.45	Maintenance	94.91	0	31.7	DUST waiting for spare part
18/06/2024 09:00	34.41	Maintenance	95.89	0	17.8	DUST waiting for spare part
18/06/2024 10:00	34.46	Maintenance	95.54	0	17	DUST waiting for spare part
18/06/2024 11:00	34.43	Maintenance	95.61	0	17.2	DUST waiting for spare part
18/06/2024 12:00	22.09	Maintenance	92.85	0	43.7	DUST waiting for spare part
18/06/2024 13:00	34.53	Maintenance	95.36	0	19.1	DUST waiting for spare part
18/06/2024 14:00	34.41	Maintenance	95.48	0	16.6	DUST waiting for spare part
18/06/2024 15:00	34.41	Maintenance	95.44	0	16.6	DUST waiting for spare part
18/06/2024 16:00	34.28	Maintenance	95.5	0	16.5	DUST waiting for spare part
18/06/2024 17:00	34.09	Maintenance	95.34	0	16.4	DUST waiting for spare part
18/06/2024 18:00	33.99	Maintenance	94.96	0	16.2	DUST waiting for spare part
18/06/2024 19:00	33.85	Maintenance	94.43	0	15.8	DUST waiting for spare part
18/06/2024 20:00	33.97	Maintenance	94.61	0	15.8	DUST waiting for spare part
18/06/2024 21:00	34.17	Maintenance	95.04	0	15.9	DUST waiting for spare part
18/06/2024 22:00	34.29	Maintenance	95.15	0	15.9	DUST waiting for spare part
18/06/2024 23:00	31.48	Maintenance	94.71	0	21.2	DUST waiting for spare part
19/06/2024 00:00	2.16	Maintenance	ShutDown	ShutDown	ShutDown	GT12 SD
Minimum	2.16	---	92.85	0	15.8	
MinDate	19/06/2024 00:00	18/06/2024 00:00	18/06/2024 12:00	18/06/2024 00:00	18/06/2024 19:00	
Maximum	48	---	96.33	0	43.7	
MaxDate	18/06/2024 06:00	18/06/2024 00:00	18/06/2024 00:00	18/06/2024 00:00	18/06/2024 12:00	
Avg	36.58	---	95.18	0	24	
Num	25	0	24	24	24	
Data(%)	100	---	96	96	96	
STD	10.1	---	0.7	0	8.8	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/06/2024 00:00	46.4	0	95.77	1.6	38.7	
19/06/2024 01:00	48.17	0	94.7	1.6	38.9	
19/06/2024 02:00	48.06	0	94.99	1.6	39.2	
19/06/2024 03:00	48.06	0	95.1	1.6	39.2	
19/06/2024 04:00	48.18	0	95.21	1.6	38.9	
19/06/2024 05:00	48.19	0	95.25	1.6	39.2	
19/06/2024 06:00	48.1	0.17	95.5	1.6	39.2	
19/06/2024 07:00	47.84	0	95.48	1.6	39	
19/06/2024 08:00	35.85	0	95.38	1.7	38.7	
19/06/2024 09:00	34.67	0	95.39	1.6	38	
19/06/2024 10:00	34.66	0	95.44	1.6	27.9	
19/06/2024 11:00	34.63	0	95.84	1.7	27.9	
19/06/2024 12:00	21.97	0	93.27	1.8	51.9	
19/06/2024 13:00	34.74	0	94.95	1.7	29.6	
19/06/2024 14:00	34.74	0	95.48	1.6	27.9	
19/06/2024 15:00	34.7	0	95.07	1.6	27.6	
19/06/2024 16:00	34.53	0	94.83	1.6	27.2	
19/06/2024 17:00	34.35	0	94.74	1.6	26.9	
19/06/2024 18:00	34.24	0	94.29	1.6	26.6	
19/06/2024 19:00	34.06	0	93.96	1.5	26.1	
19/06/2024 20:00	34.1	0	94.1	1.5	25.7	
19/06/2024 21:00	34.29	0	94.72	1.5	25.6	
19/06/2024 22:00	34.31	0	94.75	1.6	25.5	
19/06/2024 23:00	31.57	0	94.47	1.6	30.6	
20/06/2024 00:00	2.5	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	2.5	0	93.27	1.5	25.5	
MinDate	20/06/2024 00:00	19/06/2024 00:00	19/06/2024 12:00	19/06/2024 19:00	19/06/2024 22:00	
Maximum	48.19	0.17	95.84	1.8	51.9	
MaxDate	19/06/2024 05:00	19/06/2024 06:00	19/06/2024 11:00	19/06/2024 12:00	19/06/2024 12:00	
Avg	36.92	0.01	94.94	1.6	32.8	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	4.7	0.1	3	0	2.1	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
19/06/2024 00:00	2.16	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
19/06/2024 08:00	19.77	Maintenance	<Samp	<Samp	<Samp	GT12 S/D
19/06/2024 09:00	34.6	Maintenance	95.86	0	23.3	DUST waiting for spare part
19/06/2024 10:00	34.6	Maintenance	95.65	0	23.2	DUST waiting for spare part
19/06/2024 11:00	34.56	Maintenance	96.01	0	23.2	DUST waiting for spare part
19/06/2024 12:00	21.4	Maintenance	93.45	0	50.5	DUST waiting for spare part
19/06/2024 13:00	34.63	Maintenance	95.21	0	24.7	DUST waiting for spare part
19/06/2024 14:00	34.68	Maintenance	95.65	0	22.8	DUST waiting for spare part
19/06/2024 15:00	34.63	Maintenance	95.39	0	22.6	DUST waiting for spare part
19/06/2024 16:00	34.46	Maintenance	95.17	0	22.1	DUST waiting for spare part
19/06/2024 17:00	34.28	Maintenance	95.06	0	21.8	DUST waiting for spare part
19/06/2024 18:00	34.17	Maintenance	94.83	0	21.3	DUST waiting for spare part
19/06/2024 19:00	33.99	Maintenance	94.51	0	21	DUST waiting for spare part
19/06/2024 20:00	34.03	Maintenance	94.54	0	20.7	DUST waiting for spare part
19/06/2024 21:00	34.23	Maintenance	94.95	0	20.7	DUST waiting for spare part
19/06/2024 22:00	34.24	Maintenance	95.05	0	20.6	DUST waiting for spare part
19/06/2024 23:00	31.52	Maintenance	94.65	0	25.5	DUST waiting for spare part
20/06/2024 00:00	45.56	Maintenance	96.25	0	37.8	DUST waiting for spare part
Minimum	0	---	93.45	0	20.6	
MinDate	19/06/2024 01:00	19/06/2024 00:00	19/06/2024 12:00	19/06/2024 09:00	19/06/2024 22:00	
Maximum	45.56	---	96.25	0	50.5	
MaxDate	20/06/2024 00:00	19/06/2024 00:00	20/06/2024 00:00	19/06/2024 09:00	19/06/2024 12:00	
Avg	22.7	---	95.14	0	25.1	
Num	25	0	16	16	16	
Data[%]	100	---	64	64	64	
STD	16.4	---	0.7	0	7.9	

Date & Time	11GT_LOAD MW	11HRSG_DUST mg/m3	11HRSG_TEMP Degree C	11HRSG_SO2@7%O2 ppm	11HRSG_NOx@7%O2 ppm	Remark
20/06/2024 00:00	2.5	0	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 06:00	0	0.4	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 07:00	0	0.02	ShutDown	ShutDown	ShutDown	GT11 S/D
20/06/2024 08:00	21.28	0.1	<Samp	<Samp	<Samp	GT11 S/D
20/06/2024 09:00	34.46	0	95.45	1.7	29.4	
20/06/2024 10:00	34.65	0	95.65	1.7	29.7	
20/06/2024 11:00	34.25	0	95.68	1.7	29.4	
20/06/2024 12:00	21.71	0	93.75	1.9	53.6	
20/06/2024 13:00	34.77	0	95.35	1.7	31.4	
20/06/2024 14:00	34.7	0	96.01	1.7	29.5	
20/06/2024 15:00	34.73	0	95.55	1.7	29.6	
20/06/2024 16:00	34.57	0	95.32	1.7	29.4	
20/06/2024 17:00	34.39	0	95.36	1.7	29.1	
20/06/2024 18:00	34.32	0	94.85	1.6	28.9	
20/06/2024 19:00	34.13	0	94.48	1.6	28.6	
20/06/2024 20:00	34.19	0	96.3	1.6	28.1	
20/06/2024 21:00	34.4	0	95	1.6	27.7	
20/06/2024 22:00	34.37	0	95.2	1.6	27.6	
20/06/2024 23:00	31.56	0	94.7	1.6	32.9	
21/06/2024 00:00	45.89	0	95.78	1.6	40.1	
Minimum	0	0	93.75	1.6	27.6	
MinDate	20/06/2024 01:00	20/06/2024 00:00	20/06/2024 12:00	20/06/2024 18:00	20/06/2024 22:00	
Maximum	45.89	0.4	96.01	1.9	53.6	
MaxDate	21/06/2024 00:00	20/06/2024 06:00	20/06/2024 14:00	20/06/2024 12:00	20/06/2024 12:00	
Avg	22.83	0.02	95.15	1.7	31.6	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16.4	0.1	0.6	0.1	6.6	

Date & Time	12GT_LOAD MW	12HRSG_DUST mg/m3	12HRSG_TEMP Degree C	12HRSG_SO2@7%O2 ppm	12HRSG_NOx@7%O2 ppm	Remark
20/06/2024 00:00	45.56	Maintenance	96.25	0	37.8	DUST waiting for spare part
20/06/2024 01:00	47.36	Maintenance	94.46	0	40.5	DUST waiting for spare part
20/06/2024 02:00	47.35	Maintenance	94.85	0	40.5	DUST waiting for spare part
20/06/2024 03:00	47.49	Maintenance	95.1	0	40.7	DUST waiting for spare part
20/06/2024 04:00	47.68	Maintenance	95.21	0	41	DUST waiting for spare part
20/06/2024 05:00	47.77	Maintenance	95.29	0	40.9	DUST waiting for spare part
20/06/2024 06:00	47.75	<Samp	95.67	0	40.6	DUST waiting for spare part
20/06/2024 07:00	47.42	Maintenance	96.03	0	40	DUST waiting for spare part
20/06/2024 08:00	34.15	Maintenance	94.68	0	34.8	DUST waiting for spare part
20/06/2024 09:00	34.39	Maintenance	95.36	0	20.9	DUST waiting for spare part
20/06/2024 10:00	34.59	Maintenance	95.59	0	21.2	DUST waiting for spare part
20/06/2024 11:00	34.18	Maintenance	95.7	0	20.8	DUST waiting for spare part
20/06/2024 12:00	21.1	Maintenance	93.72	0	51.7	DUST waiting for spare part
20/06/2024 13:00	34.65	Maintenance	95.18	0	23.1	DUST waiting for spare part
20/06/2024 14:00	34.63	Maintenance	95.75	0	20.9	DUST waiting for spare part
20/06/2024 15:00	34.67	Maintenance	95.37	0	21	DUST waiting for spare part
20/06/2024 16:00	34.5	Maintenance	95.16	0	20.8	DUST waiting for spare part
20/06/2024 17:00	34.33	Maintenance	95.36	0	20.4	DUST waiting for spare part
20/06/2024 18:00	34.25	Maintenance	94.94	0	20.3	DUST waiting for spare part
20/06/2024 19:00	34.06	Maintenance	94.63	0	20	DUST waiting for spare part
20/06/2024 20:00	34.12	Maintenance	94.44	0	19.7	DUST waiting for spare part
20/06/2024 21:00	34.34	Maintenance	94.99	0	19.4	DUST waiting for spare part
20/06/2024 22:00	34.31	Maintenance	95.17	0	19.3	DUST waiting for spare part
20/06/2024 23:00	31.49	Maintenance	94.58	0	24.9	DUST waiting for spare part
21/06/2024 00:00	2.15	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	2.15	---	93.72	0	19.3	
MinDate	21/06/2024 00:00	20/06/2024 00:00	20/06/2024 12:00	20/06/2024 00:00	20/06/2024 22:00	
Maximum	47.77	---	96.25	0	51.7	
MaxDate	20/06/2024 05:00	20/06/2024 00:00	20/06/2024 00:00	20/06/2024 00:00	20/06/2024 12:00	
Avg	36.57	---	95.14	0	29.2	
Num	25	0	24	24	24	
Data[%]	100	---	96	96	96	
STD	10.1	---	0.6	0	10.5	

Date & Time	11GT LOAD	11HRSG DUST	11HRSG TEMP	11HRSG SO2@7%O2	11HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/06/2024 00:00	45.89	0	95.78	1.6	40.1	
21/06/2024 01:00	47.65	0	94.71	1.6	40.5	
21/06/2024 02:00	47.73	0	95.11	1.6	40.3	
21/06/2024 03:00	47.77	0	95.24	1.6	40.2	
21/06/2024 04:00	47.88	0	95.24	1.6	39.8	
21/06/2024 05:00	47.93	0	95.17	1.7	39.8	
21/06/2024 06:00	47.96	0.3	95.66	1.7	39.7	
21/06/2024 07:00	47.75	0	95.43	1.7	39.6	
21/06/2024 08:00	34.83	0	95.05	1.7	39.9	
21/06/2024 09:00	34.96	0	95.47	1.7	28	
21/06/2024 10:00	34.69	0	95.75	1.7	27.8	
21/06/2024 11:00	34.69	0	96.14	1.7	27.8	
21/06/2024 12:00	22.01	0	92.89	1.8	51.3	
21/06/2024 13:00	34.96	0	95.15	1.7	29.6	
21/06/2024 14:00	34.79	0	95.79	1.6	27.7	
21/06/2024 15:00	34.7	0	95.26	1.6	27.5	
21/06/2024 16:00	34.6	0	94.83	1.6	27.3	
21/06/2024 17:00	34.37	0	94.5	1.6	26.7	
21/06/2024 18:00	34.29	0	94.22	1.6	26.3	
21/06/2024 19:00	34.15	0	94.3	1.5	26	
21/06/2024 20:00	34.35	0	94.61	1.6	25.9	
21/06/2024 21:00	34.5	0	95.1	1.6	25.8	
21/06/2024 22:00	37.55	0	96.75	1.6	27.3	
21/06/2024 23:00	35.32	0	96.79	1.6	31.7	
22/06/2024 00:00	28.27	0	93.25	1.7	44.6	
Minimum	22.01	0	92.89	1.5	25.8	
MinDate	21/06/2024 12:00	21/06/2024 00:00	21/06/2024 12:00	21/06/2024 19:00	21/06/2024 21:00	
Maximum	47.96	0.3	96.79	1.8	51.3	
MaxDate	21/06/2024 06:00	21/06/2024 06:00	21/06/2024 23:00	21/06/2024 12:00	21/06/2024 12:00	
Avg	38.14	0.01	95.13	1.6	33.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.2	0.1	0.9	0.1	7.5	

Date & Time	12GT LOAD	12HRSG DUST	12HRSG TEMP	12HRSG SO2@7%O2	12HRSG NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
21/06/2024 00:00	2.15	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 01:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 02:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 03:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 04:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 05:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 06:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 07:00	0	Maintenance	ShutDown	ShutDown	ShutDown	GT12 S/D
21/06/2024 08:00	20.59	Maintenance	<Samp	<Samp	<Samp	GT12 S/D
21/06/2024 09:00	34.31	Maintenance	95.19	0	22.5	DUST waiting for spare part
21/06/2024 10:00	34.63	Maintenance	95.42	0	22.7	DUST waiting for spare part
21/06/2024 11:00	34.62	Maintenance	95.88	0	22.8	DUST waiting for spare part
21/06/2024 12:00	21.88	Maintenance	92.7	0	47	DUST waiting for spare part
21/06/2024 13:00	34.55	Maintenance	94.69	0	24	DUST waiting for spare part
21/06/2024 14:00	34.73	Maintenance	95.42	0	22.3	DUST waiting for spare part
21/06/2024 15:00	34.64	Maintenance	95.1	0	22.2	DUST waiting for spare part
21/06/2024 16:00	34.53	Maintenance	94.78	0	22	DUST waiting for spare part
21/06/2024 17:00	34.31	Maintenance	94.54	0	21.3	DUST waiting for spare part
21/06/2024 18:00	34.22	Maintenance	94.32	0	21	DUST waiting for spare part
21/06/2024 19:00	34.08	Maintenance	94.4	0	20.6	DUST waiting for spare part
21/06/2024 20:00	34.28	Maintenance	94.62	0	20.6	DUST waiting for spare part
21/06/2024 21:00	34.43	Maintenance	94.98	0	20.6	DUST waiting for spare part
21/06/2024 22:00	37.46	Maintenance	96.56	0	22.3	DUST waiting for spare part
21/06/2024 23:00	35.25	Maintenance	96.51	0	26.6	DUST waiting for spare part
22/06/2024 00:00	28.22	Maintenance	93.08	0	37.9	DUST waiting for spare part
Minimum	0	---	92.7	0	20.6	
MinDate	21/06/2024 01:00	21/06/2024 00:00	21/06/2024 12:00	21/06/2024 09:00	21/06/2024 19:00	
Maximum	37.46	---	96.56	0	47	
MaxDate	21/06/2024 22:00	21/06/2024 00:00	21/06/2024 22:00	21/06/2024 09:00	21/06/2024 12:00	
Avg	22.36	---	94.9	0	24.8	
Num	25	0	15	16	16	
Data[%]	100	---	64	64	64	
STD	15.9	---	1	0	7.2	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/06/2024 00:00	28.27	0	93.25	1.7	44.6	
22/06/2024 01:00	28.75	0	93.01	1.7	42.9	
22/06/2024 02:00	28.85	0	93.02	1.7	42.6	
22/06/2024 03:00	28.66	0	92.96	1.7	43	
22/06/2024 04:00	28.47	0	92.89	1.7	43.5	
22/06/2024 05:00	28.35	0	92.85	1.7	44.3	
22/06/2024 06:00	28.3	0.23	92.84	1.7	44.4	
22/06/2024 07:00	28.06	0	92.9	1.7	45	
22/06/2024 08:00	31.63	0	93.78	1.7	41.5	
22/06/2024 09:00	42.14	0	99.39	1.7	29.4	
22/06/2024 10:00	42.25	0	99.95	1.7	29.6	
22/06/2024 11:00	42.23	0	100.22	1.7	29.6	
22/06/2024 12:00	28.27	0	94.54	1.7	41.9	
22/06/2024 13:00	42.18	0	98.86	1.7	30.2	
22/06/2024 14:00	42.2	0	100.38	1.7	29.5	
22/06/2024 15:00	42.2	0	99.87	1.7	29.3	
22/06/2024 16:00	42.13	0	99.81	1.7	29.1	
22/06/2024 17:00	42.16	0	99.38	1.7	28.8	
22/06/2024 18:00	42.05	0	99.16	1.6	28.6	
22/06/2024 19:00	41.99	0	99.23	1.6	28.6	
22/06/2024 20:00	41.9	0	99.07	1.6	28.7	
22/06/2024 21:00	41.96	0	99.36	1.6	28.9	
22/06/2024 22:00	41.96	0	99.42	1.6	29	
22/06/2024 23:00	38.33	0	98.57	1.6	31.7	
23/06/2024 00:00	28.01	0	92.92	1.7	44.3	
Minimum	28.01	0	92.84	1.6	28.6	
MinDate	23/06/2024 00:00	22/06/2024 00:00	22/06/2024 06:00	22/06/2024 18:00	22/06/2024 18:00	
Maximum	42.25	0.23	100.38	1.7	45	
MaxDate	22/06/2024 10:00	22/06/2024 06:00	22/06/2024 14:00	22/06/2024 00:00	22/06/2024 07:00	
Avg	36.05	0.01	96.71	1.7	35.6	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	6.7	0	3.2	0	7.2	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
22/06/2024 00:00	28.22	Maintenance	93.08	0	37.9	DUST waiting for spare part
22/06/2024 01:00	28.68	Maintenance	92.88	0	36.8	DUST waiting for spare part
22/06/2024 02:00	28.78	Maintenance	92.87	0	36.5	DUST waiting for spare part
22/06/2024 03:00	28.59	Maintenance	92.83	0	36.8	DUST waiting for spare part
22/06/2024 04:00	28.42	Maintenance	92.8	0	37	DUST waiting for spare part
22/06/2024 05:00	28.28	Maintenance	92.71	0	37.6	DUST waiting for spare part
22/06/2024 06:00	28.24	Maintenance	92.71	0	37.7	DUST waiting for spare part
22/06/2024 07:00	28	Maintenance	92.72	0	38.1	DUST waiting for spare part
22/06/2024 08:00	31.55	<Samp	93.71	0	35.8	DUST waiting for spare part
22/06/2024 09:00	42.08	Maintenance	99.81	0	26.1	DUST waiting for spare part
22/06/2024 10:00	42.19	Maintenance	100.53	0	26.4	DUST waiting for spare part
22/06/2024 11:00	42.15	Maintenance	100.8	0	26.6	DUST waiting for spare part
22/06/2024 12:00	28.22	Maintenance	95.1	0	36.3	DUST waiting for spare part
22/06/2024 13:00	42.1	Maintenance	99.37	0	27.7	DUST waiting for spare part
22/06/2024 14:00	42.12	Maintenance	100.59	0	26.7	DUST waiting for spare part
22/06/2024 15:00	42.13	Maintenance	100.26	0	26.5	DUST waiting for spare part
22/06/2024 16:00	42.06	Maintenance	100.23	0	26.2	DUST waiting for spare part
22/06/2024 17:00	42.08	Maintenance	99.89	0	25.6	DUST waiting for spare part
22/06/2024 18:00	41.97	Maintenance	99.69	0	25.5	DUST waiting for spare part
22/06/2024 19:00	41.92	Maintenance	99.68	0	25	DUST waiting for spare part
22/06/2024 20:00	41.83	Maintenance	99.51	0	25	DUST waiting for spare part
22/06/2024 21:00	41.89	Maintenance	99.6	0	25.2	DUST waiting for spare part
22/06/2024 22:00	41.89	Maintenance	99.61	0	25.2	DUST waiting for spare part
22/06/2024 23:00	38.27	Maintenance	98.65	0	27.5	DUST waiting for spare part
23/06/2024 00:00	27.96	Maintenance	93.34	0	37.6	DUST waiting for spare part
Minimum	27.96	---	92.71	0	25	
MinDate	23/06/2024 00:00	22/06/2024 00:00	22/06/2024 05:00	22/06/2024 00:00	22/06/2024 19:00	
Maximum	42.19	---	100.8	0	38.1	
MaxDate	22/06/2024 10:00	22/06/2024 00:00	22/06/2024 11:00	22/06/2024 00:00	22/06/2024 07:00	
Avg	35.98	---	96.92	0	30.9	
Num	25	0	25	25	25	
Data[%]	100	---	100	100	100	
STD	6.7	---	3.5	0	5.6	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/06/2024 00:00	28.01	0	92.92	1.7	44.3	
23/06/2024 01:00	28.04	0	92.26	1.7	44.6	
23/06/2024 02:00	28.06	0	92.04	1.7	44.9	
23/06/2024 03:00	28.09	0	92.02	1.7	44.7	
23/06/2024 04:00	27.97	0	91.93	1.7	44.4	
23/06/2024 05:00	28	0	92.07	1.7	44	
23/06/2024 06:00	27.89	0.17	92.19	1.7	44.3	
23/06/2024 07:00	27.71	0	92.23	1.7	45	
23/06/2024 08:00	28.03	0	92.16	1.7	44.1	
23/06/2024 09:00	28.12	0	92.38	1.7	43.4	
23/06/2024 10:00	28.23	0	92.47	1.7	42.6	
23/06/2024 11:00	28.2	0	92.49	1.7	42.3	
23/06/2024 12:00	28.17	0	92.56	1.7	42.6	
23/06/2024 13:00	28.32	0	92.42	1.7	41.1	
23/06/2024 14:00	28.34	0	92.4	1.7	40.9	
23/06/2024 15:00	28.33	0	92.11	1.7	40.9	
23/06/2024 16:00	28.26	0	91.9	1.7	41.3	
23/06/2024 17:00	28.21	0	91.83	1.7	41.5	
23/06/2024 18:00	38.57	0	95.82	1.7	31	
23/06/2024 19:00	41.98	0	99.21	1.7	26.9	
23/06/2024 20:00	41.88	0	99.19	1.7	26.9	
23/06/2024 21:00	41.99	0	99.5	1.7	26.9	
23/06/2024 22:00	35.04	0	97.22	1.7	33.8	
23/06/2024 23:00	28.17	0	92.32	1.7	42.1	
24/06/2024 00:00	28.09	0	92.19	1.7	42.7	
Minimum	27.71	0	91.83	1.7	26.9	
MinDate	23/06/2024 07:00	23/06/2024 00:00	23/06/2024 17:00	23/06/2024 00:00	23/06/2024 19:00	
Maximum	41.99	0.17	99.5	1.7	45	
MaxDate	23/06/2024 21:00	23/06/2024 06:00	23/06/2024 21:00	23/06/2024 00:00	23/06/2024 07:00	
Avg	30.47	0.01	93.43	1.7	40.3	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	5	0	2.5	---	6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
23/06/2024 00:00	27.96	Maintenance	93.34	0	37.6	DUST waiting for spare part
23/06/2024 01:00	27.98	Maintenance	92.65	0	38	DUST waiting for spare part
23/06/2024 02:00	27.99	Maintenance	92.45	0	38.4	DUST waiting for spare part
23/06/2024 03:00	28.03	Maintenance	92.46	0	38.2	DUST waiting for spare part
23/06/2024 04:00	27.91	Maintenance	92.48	0	37.7	DUST waiting for spare part
23/06/2024 05:00	27.94	<Samp	92.53	0	37.3	DUST waiting for spare part
23/06/2024 06:00	27.83	0.2	92.63	0	37.6	
23/06/2024 07:00	27.66	0.25	92.64	0	38.3	
23/06/2024 08:00	27.96	0.26	92.58	0	37.6	
23/06/2024 09:00	28.06	0.27	92.81	0	37.2	
23/06/2024 10:00	28.17	0.31	92.89	0	36.6	
23/06/2024 11:00	28.14	0.31	92.94	0	36.5	
23/06/2024 12:00	28.1	0.31	92.94	0	36.8	
23/06/2024 13:00	28.26	0.31	92.83	0	35.5	
23/06/2024 14:00	28.27	0.27	92.79	0	35.3	
23/06/2024 15:00	28.27	0.27	92.69	0	35.3	
23/06/2024 16:00	28.2	0.26	92.55	0	35.7	
23/06/2024 17:00	28.15	0.25	92.48	0	35.8	
23/06/2024 18:00	38.51	0.25	96.49	0	27	
23/06/2024 19:00	41.91	0.25	99.66	0	23	
23/06/2024 20:00	41.81	0.25	99.64	0	23	
23/06/2024 21:00	41.92	0.25	99.76	0	23	
23/06/2024 22:00	34.98	0.25	97.37	0	29.4	
23/06/2024 23:00	28.11	0.24	93.11	0	36.1	
24/06/2024 00:00	28.03	0.25	93.05	0	36.6	
Minimum	27.66	0.2	92.45	0	23	
MinDate	23/06/2024 07:00	23/06/2024 06:00	23/06/2024 02:00	23/06/2024 00:00	23/06/2024 19:00	
Maximum	41.92	0.31	99.76	0	38.4	
MaxDate	23/06/2024 21:00	23/06/2024 10:00	23/06/2024 21:00	23/06/2024 00:00	23/06/2024 02:00	
Avg	30.41	0.26	93.91	0	34.5	
Num	25	19	25	25	25	
Data[%]	100	76	100	100	100	
STD	5	0	2.5	0	5.1	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/06/2024 00:00	28.09	0	92.19	1.7	42.7	
24/06/2024 01:00	28.09	0	92.22	1.7	42.8	
24/06/2024 02:00	28.15	0	92.15	1.7	42.4	
24/06/2024 03:00	28.13	0	92.08	1.7	42.6	
24/06/2024 04:00	28.12	0	92.1	1.7	42.3	
24/06/2024 05:00	28.12	0	92.1	1.7	41.9	
24/06/2024 06:00	28.21	0.32	92.19	1.7	41.6	
24/06/2024 07:00	28.35	0	92.35	1.7	40.6	
24/06/2024 08:00	31.67	0	93.3	1.7	36.6	
24/06/2024 09:00	34.61	0	94.63	1.7	24.2	
24/06/2024 10:00	34.6	0	94.66	1.7	23.7	
24/06/2024 11:00	34.61	0	94.85	1.7	23.8	
24/06/2024 12:00	22.32	0	92.12	1.8	48.9	
24/06/2024 13:00	34.75	0	94.19	1.7	25.2	
24/06/2024 14:00	34.74	0	94.67	1.7	23.5	
24/06/2024 15:00	34.7	0	94.18	1.6	23.4	
24/06/2024 16:00	34.59	0	93.98	1.6	23.4	
24/06/2024 17:00	34.43	0	93.73	1.6	23.2	
24/06/2024 18:00	34.38	0	93.73	1.6	23.1	
24/06/2024 19:00	34.14	0	93.52	1.6	23.3	
24/06/2024 20:00	34.19	0	93.45	1.6	23.4	
24/06/2024 21:00	34.39	0	93.86	1.6	23.4	
24/06/2024 22:00	34.32	0	93.88	1.6	23.5	
24/06/2024 23:00	31.35	0	93.4	1.6	29.8	
25/06/2024 00:00	2.09	0.01	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	2.09	0	92.08	1.6	23.1	
MinDate	25/06/2024 00:00	24/06/2024 00:00	24/06/2024 03:00	24/06/2024 15:00	24/06/2024 18:00	
Maximum	34.75	0.32	94.85	1.8	48.9	
MaxDate	24/06/2024 13:00	24/06/2024 06:00	24/06/2024 11:00	24/06/2024 12:00	24/06/2024 12:00	
Avg	30.45	0.01	93.31	1.7	31.6	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	6.9	0.1	1	0.1	9.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
24/06/2024 00:00	28.03	0.25	93.05	0	36.6	
24/06/2024 01:00	28.03	0.25	93.16	0	36.7	
24/06/2024 02:00	28.09	0.25	93.14	0	36.4	
24/06/2024 03:00	28.07	0.15	93.08	0	36.4	
24/06/2024 04:00	28.06	0.06	93.09	0	36.1	
24/06/2024 05:00	28.06	0.25	93.16	0	35.7	
24/06/2024 06:00	28.15	0.19	93.2	0	35.4	
24/06/2024 07:00	28.29	0.22	93.41	0	34.5	
24/06/2024 08:00	31.65	0.26	94.41	0	31.8	
24/06/2024 09:00	34.52	0.32	95.12	0	18.7	
24/06/2024 10:00	34.54	0.36	95.01	0	18.2	
24/06/2024 11:00	34.56	0.37	95.22	0	18.3	
24/06/2024 12:00	22.31	0.36	92.58	0	45.5	
24/06/2024 13:00	34.74	0.36	94.67	0	19.6	
24/06/2024 14:00	34.67	0.36	94.91	0	17.8	
24/06/2024 15:00	34.63	0.3	94.59	0	17.7	
24/06/2024 16:00	34.53	<Samp	94.39	0	17.6	DUST waiting for spare part
24/06/2024 17:00	34.36	Maintenance	94.21	0	17.2	DUST waiting for spare part
24/06/2024 18:00	34.31	<Samp	94.22	0	17.1	DUST waiting for spare part
24/06/2024 19:00	34.07	0.1	94.04	0	17.2	
24/06/2024 20:00	34.13	0.1	93.96	0	17.3	
24/06/2024 21:00	34.32	0.1	94.26	0	17.4	
24/06/2024 22:00	34.26	0.11	94.19	0	17.5	
24/06/2024 23:00	31.39	0.13	93.66	0	24	
25/06/2024 00:00	46.51	0.14	95.73	0	33.4	
Minimum	22.31	0.06	92.58	0	17.1	
MinDate	24/06/2024 12:00	24/06/2024 04:00	24/06/2024 12:00	24/06/2024 00:00	24/06/2024 18:00	
Maximum	46.51	0.37	95.73	0	45.5	
MaxDate	25/06/2024 00:00	24/06/2024 11:00	25/06/2024 00:00	24/06/2024 00:00	24/06/2024 12:00	
Avg	32.17	0.23	94.02	0	26.2	
Num	25	22	25	25	25	
Data[%]	100	88	100	100	100	
STD	4.6	0.1	0.8	0	9.5	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
25/06/2024 00:00	2.09	0.01	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 06:00	0	0.28	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 SD
25/06/2024 08:00	20.4	0.06	<Samp	<Samp	<Samp	GT11 SD
25/06/2024 09:00	34.7	0	95.3	1.7	29.6	
25/06/2024 10:00	34.74	0	95.53	1.7	29.7	
25/06/2024 11:00	34.7	0	95.53	1.7	29.8	
25/06/2024 12:00	22.15	0	92.11	1.9	52.6	
25/06/2024 13:00	34.82	0	94.23	1.7	31.7	
25/06/2024 14:00	34.71	0	94.48	1.7	29.5	
25/06/2024 15:00	34.7	0	94.19	1.7	29	
25/06/2024 16:00	34.49	0	93.92	1.6	28.6	
25/06/2024 17:00	34.32	0	93.61	1.6	28.2	
25/06/2024 18:00	34.28	0	93.48	1.6	27.9	
25/06/2024 19:00	34.08	0	93.47	1.6	27.8	
25/06/2024 20:00	34.11	0.02	92.51	1.6	28.2	
25/06/2024 21:00	34.28	0	93.54	1.7	27.9	
25/06/2024 22:00	34.26	0	93.69	1.7	28.3	
25/06/2024 23:00	31.41	0	93.29	1.7	34.1	
26/06/2024 00:00	46.86	0	95.42	1.7	39.6	
Minimum	0	0	92.11	1.6	27.8	
MinDate	25/06/2024 01:00	25/06/2024 01:00	25/06/2024 12:00	25/06/2024 16:00	25/06/2024 19:00	
Maximum	46.86	0.28	95.53	1.9	52.6	
MaxDate	26/06/2024 00:00	25/06/2024 06:00	25/06/2024 10:00	25/06/2024 12:00	25/06/2024 12:00	
Avg	22.94	0.01	94.02	1.7	31.4	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16.5	0.1	1	0.1	6.4	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
25/06/2024 00:00	46.51	0.14	95.73	0	33.4	
25/06/2024 01:00	47.98	0.14	94.62	0	35.1	
25/06/2024 02:00	48.09	0.15	95.19	0	35.1	
25/06/2024 03:00	48.26	0.12	95.47	0	35.1	
25/06/2024 04:00	48.14	0.07	95.46	0	34.8	
25/06/2024 05:00	48.25	0.05	95.4	0	34.8	
25/06/2024 06:00	48.27	0.03	95.8	0	34.7	
25/06/2024 07:00	47.97	0.05	95.28	0	34.1	
25/06/2024 08:00	35.23	0.12	94.61	0	30.6	
25/06/2024 09:00	34.63	0.23	94.64	0	16.9	
25/06/2024 10:00	34.68	0.29	94.9	0	16.9	
25/06/2024 11:00	34.63	0.31	94.95	0	16.8	
25/06/2024 12:00	22.15	0.28	91.72	0	43.8	
25/06/2024 13:00	34.75	0.24	94.68	0	19	
25/06/2024 14:00	34.63	0.23	94.95	0	16.7	
25/06/2024 15:00	34.64	0.21	94.76	0	16.4	
25/06/2024 16:00	34.42	0.2	94.6	0	16.3	
25/06/2024 17:00	34.25	0.09	94.34	0	16.1	
25/06/2024 18:00	34.21	0.25	94.29	0	16	
25/06/2024 19:00	34.02	0.07	94.28	0	16	
25/06/2024 20:00	34.05	0.18	92.92	0	16.4	
25/06/2024 21:00	34.21	0.16	94.07	0	16.3	
25/06/2024 22:00	34.2	0.2	94.27	0	16.3	
25/06/2024 23:00	31.34	0.21	93.79	0	22.9	
26/06/2024 00:00	2.44	0.25	ShutDown	ShutDown	ShutDown	GT12 SD
Minimum	2.44	0.03	91.72	0	16	
MinDate	26/06/2024 00:00	25/06/2024 06:00	25/06/2024 12:00	25/06/2024 00:00	25/06/2024 18:00	
Maximum	48.27	0.31	95.8	0	43.8	
MaxDate	25/06/2024 06:00	25/06/2024 11:00	25/06/2024 06:00	25/06/2024 00:00	25/06/2024 12:00	
Avg	35.88	0.17	94.61	0	24.6	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	10.2	0.1	0.9	0	9.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/06/2024 00:00	46.86	0	95.42	1.7	39.6	
26/06/2024 01:00	48.98	0	95.24	1.7	39.9	
26/06/2024 02:00	49.05	0	95.73	1.7	39.8	
26/06/2024 03:00	49	0	95.68	1.7	39.7	
26/06/2024 04:00	48.94	0	95.55	1.7	39.4	
26/06/2024 05:00	48.93	0	95.65	1.7	39.2	
26/06/2024 06:00	48.92	0.21	95.8	1.8	39	
26/06/2024 07:00	48.71	0	95.78	1.8	39.1	
26/06/2024 08:00	34.98	0	95.01	1.9	38.4	
26/06/2024 09:00	34.58	0	94.83	1.8	28	
26/06/2024 10:00	34.64	0	94.96	1.8	28.3	
26/06/2024 11:00	34.59	0	94.89	1.8	28.2	
26/06/2024 12:00	22.24	0	91.98	1.9	51	
26/06/2024 13:00	34.67	0	94.4	1.8	30.1	
26/06/2024 14:00	34.63	0	94.85	1.7	27.9	
26/06/2024 15:00	34.59	0	94.7	1.7	27.7	
26/06/2024 16:00	34.39	0	94.73	1.7	27.4	
26/06/2024 17:00	34.24	0	94.55	1.7	27.2	
26/06/2024 18:00	34.22	0	94.4	1.6	27.3	
26/06/2024 19:00	34.08	0	94.31	1.6	27	
26/06/2024 20:00	34.14	0	94.41	1.6	26.4	
26/06/2024 21:00	34.41	0	94.92	1.6	26.3	
26/06/2024 22:00	34.39	0	94.96	1.6	26.1	
26/06/2024 23:00	31.61	0	94.51	1.7	31	
27/06/2024 00:00	2.5	0	ShutDown	ShutDown	ShutDown	GT11 S/D
Minimum	2.5	0	91.98	1.6	26.1	
MinDate	27/06/2024 00:00	26/06/2024 00:00	26/06/2024 12:00	26/06/2024 18:00	26/06/2024 22:00	
Maximum	49.05	0.21	95.8	1.9	51	
MaxDate	26/06/2024 02:00	26/06/2024 06:00	26/06/2024 06:00	26/06/2024 08:00	26/06/2024 12:00	
Avg	37.13	0.01	94.89	1.7	33.1	
Num	25	25	24	24	24	
Data[%]	100	100	96	96	96	
STD	10.5	0	0.8	0.1	6.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
26/06/2024 00:00	2.44	0.25	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 01:00	0	0.17	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 02:00	0	0.1	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 03:00	0	0.1	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 04:00	0	0.11	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 05:00	0	0.12	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 06:00	0	0.16	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 07:00	0	0.18	ShutDown	ShutDown	ShutDown	GT12 SD
26/06/2024 08:00	20.72	0.21	<Samp	<Samp	<Samp	GT12 SD
26/06/2024 09:00	34.52	0.33	95.09	0	22.5	DUST waiting for spare part
26/06/2024 10:00	34.57	0.42	94.92	0	22.8	DUST waiting for spare part
26/06/2024 11:00	34.51	0.43	94.81	0	22.7	DUST waiting for spare part
26/06/2024 12:00	22.17	0.43	91.88	0	46.7	DUST waiting for spare part
26/06/2024 13:00	34.6	0.43	94.11	0	25.8	DUST waiting for spare part
26/06/2024 14:00	34.56	0.41	94.66	0	22.5	DUST waiting for spare part
26/06/2024 15:00	34.52	0.39	94.62	0	22.5	DUST waiting for spare part
26/06/2024 16:00	34.32	0.39	94.69	0	22.1	DUST waiting for spare part
26/06/2024 17:00	34.17	0.41	94.51	0	21.9	DUST waiting for spare part
26/06/2024 18:00	34.16	0.38	94.4	0	21.9	DUST waiting for spare part
26/06/2024 19:00	34.01	0.05	94.29	0	21.6	DUST waiting for spare part
26/06/2024 20:00	34.07	0	94.34	0	21.3	DUST waiting for spare part
26/06/2024 21:00	34.34	0	94.69	0	21.2	DUST waiting for spare part
26/06/2024 22:00	34.32	0	94.63	0	21	DUST waiting for spare part
26/06/2024 23:00	31.57	0	94.06	0	25.8	DUST waiting for spare part
27/06/2024 00:00	46.25	0	95.05	0	37.4	DUST waiting for spare part
Minimum	0	0	91.88	0	21	
MinDate	26/06/2024 01:00	26/06/2024 20:00	26/06/2024 12:00	26/06/2024 09:00	26/06/2024 22:00	
Maximum	46.23	0.43	96.09	0	46.7	
MaxDate	27/06/2024 00:00	26/06/2024 11:00	27/06/2024 00:00	26/06/2024 09:00	26/06/2024 12:00	
Avg	22.79	0.22	94.5	0	24.9	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	16.4	0.2	0.8	0	7	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/06/2024 00:00	2.5	0	ShutDown	ShutDown	ShutDown	
27/06/2024 01:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
27/06/2024 02:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
27/06/2024 03:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
27/06/2024 04:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
27/06/2024 05:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
27/06/2024 06:00	0	0.15	ShutDown	ShutDown	ShutDown	GT11 S/D
27/06/2024 07:00	0	0	ShutDown	ShutDown	ShutDown	GT11 S/D
27/06/2024 08:00	21.49	0	<Samp	<Samp	<Samp	GT11 S/D
27/06/2024 09:00	34.73	0	95.45	1.8	28.5	
27/06/2024 10:00	34.76	0	95.93	1.8	29.2	
27/06/2024 11:00	34.73	0	95.96	1.8	29.2	
27/06/2024 12:00	21.7	0	92.43	1.9	57.7	
27/06/2024 13:00	34.86	0	95.07	1.8	31.5	
27/06/2024 14:00	34.77	0	95.99	1.8	29.3	
27/06/2024 15:00	34.74	0	95.14	1.7	28.7	
27/06/2024 16:00	34.54	0	94.99	1.7	28.5	
27/06/2024 17:00	34.28	0	95.18	1.7	28.5	
27/06/2024 18:00	34.22	0	94.59	1.7	27.9	
27/06/2024 19:00	34.16	0	94.35	1.6	27.7	
27/06/2024 20:00	34.26	0	94.34	1.6	27.4	
27/06/2024 21:00	34.48	0	94.98	1.6	27.4	
27/06/2024 22:00	34.43	0	95.13	1.7	27.3	
27/06/2024 23:00	31.67	0	94.55	1.7	32.5	
28/06/2024 00:00	46.32	0	96.09	1.7	39	
Minimum	0	0	92.43	1.6	27.3	
MinDate	27/06/2024 01:00	27/06/2024 00:00	27/06/2024 12:00	27/06/2024 19:00	27/06/2024 22:00	
Maximum	46.32	0.15	96.09	1.9	57.7	
MaxDate	28/06/2024 00:00	27/06/2024 06:00	28/06/2024 00:00	27/06/2024 12:00	27/06/2024 12:00	
Avg	22.91	0.01	95.01	1.7	31.3	
Num	25	25	16	16	16	
Data(%)	100	100	64	64	64	
STD	16.4	0	0.9	0.1	7.6	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
27/06/2024 00:00	46.23	0	96.05	0	37.4	
27/06/2024 01:00	48.24	0	94.96	0	39.2	
27/06/2024 02:00	48.27	0	95.07	0	39.2	
27/06/2024 03:00	48.29	0	95.35	0	39.2	
27/06/2024 04:00	48.28	0	95.35	0	39.1	
27/06/2024 05:00	48.38	0	95.34	0	39.3	
27/06/2024 06:00	48.53	0	95.68	0	39.4	
27/06/2024 07:00	48.72	0	95.76	0	40.7	
27/06/2024 08:00	34.31	0	94.73	0	33.7	
27/06/2024 09:00	34.67	0	95.1	0	20.2	
27/06/2024 10:00	34.69	0.08	95.5	0	20.7	
27/06/2024 11:00	34.67	0.18	95.52	0	20.7	
27/06/2024 12:00	21.39	0.19	92.09	0	52.5	
27/06/2024 13:00	34.77	0.16	94.79	0	23	
27/06/2024 14:00	34.7	0.15	95.52	0	20.6	
27/06/2024 15:00	34.67	0.04	94.91	0	20	
27/06/2024 16:00	34.47	0	94.76	0	19.9	
27/06/2024 17:00	34.25	0	94.9	0	19.9	
27/06/2024 18:00	34.15	0.37	94.56	0	19.5	
27/06/2024 19:00	34.09	0.04	94.41	0	19.3	
27/06/2024 20:00	34.19	0.03	94.34	0	19.2	
27/06/2024 21:00	34.41	0	94.72	0	19.3	
27/06/2024 22:00	34.36	0.03	94.76	0	19.2	
27/06/2024 23:00	31.61	0.03	94.17	0	24.6	
28/06/2024 00:00	2.58	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
Minimum	2.58	0	92.09	0	19.2	
MinDate	28/06/2024 00:00	27/06/2024 00:00	27/06/2024 12:00	27/06/2024 00:00	27/06/2024 20:00	
Maximum	48.72	0.37	96.05	0	52.5	
MaxDate	27/06/2024 07:00	27/06/2024 18:00	27/06/2024 00:00	27/06/2024 00:00	27/06/2024 12:00	
Avg	36.92	0.05	94.93	0	28.6	
Num	25	25	24	24	24	
Data(%)	100	100	96	96	96	
STD	10.3	0.1	0.8	0	10.4	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/06/2024 00:00	46.32	0	96.09	1.7	39	
28/06/2024 01:00	48.38	0	95.18	1.7	39.1	
28/06/2024 02:00	48.48	0	95.39	1.7	39.1	
28/06/2024 03:00	48.6	0	95.68	1.7	39.1	
28/06/2024 04:00	48.53	0	95.73	1.7	39	
28/06/2024 05:00	48.52	0	95.88	1.7	38.7	
28/06/2024 06:00	48.58	0.34	96.27	1.7	38.6	
28/06/2024 07:00	48.15	0	96.03	1.7	38.5	
28/06/2024 08:00	35.02	0	95.68	1.8	38.5	
28/06/2024 09:00	34.63	0	95.9	1.8	27.1	
28/06/2024 10:00	34.68	0	96.13	1.8	27.4	
28/06/2024 11:00	34.62	0	95.27	1.7	27.1	
28/06/2024 12:00	21.68	0	91.86	1.9	55.3	
28/06/2024 13:00	34.73	0	94.02	1.7	28.4	
28/06/2024 14:00	34.63	0	95.39	1.7	25.9	
28/06/2024 15:00	34.66	0	95.51	1.7	25.9	
28/06/2024 16:00	34.55	0	95.32	1.7	25.7	
28/06/2024 17:00	34.44	0	95.04	1.7	27.7	
28/06/2024 18:00	34.39	0	94.74	1.7	26	
28/06/2024 19:00	34.35	0	94.53	1.7	25.7	
28/06/2024 20:00	34.28	0	94.71	1.7	25.4	
28/06/2024 21:00	34.43	0	95.15	1.7	25.3	
28/06/2024 22:00	37.64	0	96.79	1.7	26.8	
28/06/2024 23:00	35.82	0	97.28	1.7	30.3	
29/06/2024 00:00	28.79	0	93.58	1.8	42.3	
Minimum	21.68	0	91.86	1.7	25.3	
MinDate	28/06/2024 12:00	28/06/2024 00:00	28/06/2024 12:00	28/06/2024 00:00	28/06/2024 21:00	
Maximum	48.6	0.34	97.28	1.9	55.3	
MaxDate	28/06/2024 03:00	28/06/2024 06:00	28/06/2024 23:00	28/06/2024 12:00	28/06/2024 12:00	
Avg	38.36	0.01	95.33	1.7	32.9	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.5	0.1	1.1	0.1	7.8	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
28/06/2024 00:00	2.58	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 01:00	0	0.05	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 02:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 03:00	0	0.03	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 04:00	0	0.08	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 05:00	0	0.16	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 06:00	0	0.17	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 07:00	0	0.21	ShutDown	ShutDown	ShutDown	GT12 S/D
28/06/2024 08:00	20.64	0.26	<Samp	<Samp	<Samp	GT12 S/D
28/06/2024 09:00	34.56	0.34	96.03	0	22.1	
28/06/2024 10:00	34.61	0.4	96.06	0	22.5	
28/06/2024 11:00	34.55	0.36	95.21	0	22.1	
28/06/2024 12:00	21.19	0.09	91.72	0	51.9	
28/06/2024 13:00	34.6	0	94.15	0	23.4	
28/06/2024 14:00	34.56	0.01	95.35	0	20.7	
28/06/2024 15:00	34.6	0.11	95.6	0	20.7	
28/06/2024 16:00	34.49	0.22	95.46	0	20.5	
28/06/2024 17:00	34.38	0.14	95.13	0	22.6	
28/06/2024 18:00	34.33	0.35	94.96	0	21.1	
28/06/2024 19:00	34.29	0.05	94.75	0	20.8	
28/06/2024 20:00	34.22	0.04	94.87	0	20.6	
28/06/2024 21:00	34.36	0.05	95.22	0	20.5	
28/06/2024 22:00	37.57	0.07	96.84	0	22	
28/06/2024 23:00	35.75	0.09	97.2	0	25.4	
29/06/2024 00:00	28.73	0.1	93.57	0	35.4	
Minimum	0	0	91.72	0	20.5	
MinDate	28/06/2024 01:00	28/06/2024 13:00	28/06/2024 12:00	28/06/2024 09:00	28/06/2024 16:00	
Maximum	37.57	0.4	97.2	0	51.9	
MaxDate	28/06/2024 22:00	28/06/2024 10:00	28/06/2024 23:00	28/06/2024 09:00	28/06/2024 12:00	
Avg	22.4	0.14	95.13	0	24.5	
Num	25	25	16	16	16	
Data[%]	100	100	64	64	64	
STD	15.9	0.1	1.3	0	8.2	



Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C.	ppm	ppm	
29/06/2024 00:00	28.79	0	93.58	1.8	42.3	
29/06/2024 01:00	31.64	0	93.83	1.7	33.2	
29/06/2024 02:00	31.77	0	94.02	1.7	32.7	
29/06/2024 03:00	32.09	0	94.2	1.7	31.1	
29/06/2024 04:00	31.96	0	94.11	1.7	31.4	
29/06/2024 05:00	31.93	0	94.04	1.7	31.7	
29/06/2024 06:00	32.11	0.28	94.14	1.7	30.7	
29/06/2024 07:00	32.09	0	94.48	1.7	30.2	
29/06/2024 08:00	35.75	0	95.35	1.7	30.3	
29/06/2024 09:00	46.38	0	101.46	1.7	30.2	
29/06/2024 10:00	46.39	0	102.03	1.7	30.3	
29/06/2024 11:00	46.27	0	102.55	1.7	30.4	
29/06/2024 12:00	31.98	0	95.44	1.7	34.6	
29/06/2024 13:00	46.04	0	101.03	1.8	30.5	
29/06/2024 14:00	46.2	0	103.05	1.8	31	
29/06/2024 15:00	46.25	0	102.32	1.8	31.2	
29/06/2024 16:00	46.07	0	102.21	1.8	30.7	
29/06/2024 17:00	45.96	0	102.26	1.8	30.1	
29/06/2024 18:00	45.89	0	102.11	1.8	29.6	
29/06/2024 19:00	45.91	0	102.15	1.8	29.3	
29/06/2024 20:00	46.04	0	102.19	1.8	29.2	
29/06/2024 21:00	46.14	0	102.66	1.8	29	
29/06/2024 22:00	46.18	0	102.92	1.8	28.9	
29/06/2024 23:00	42.61	0	101.93	1.8	30.3	
30/06/2024 00:00	31.96	0	94.53	1.7	31.4	
Minimum	28.79	0	93.58	1.7	28.9	
MinDate	29/06/2024 00:00	29/06/2024 00:00	29/06/2024 00:00	29/06/2024 01:00	29/06/2024 22:00	
Maximum	46.39	0.28	103.05	1.8	42.3	
MaxDate	29/06/2024 10:00	29/06/2024 06:00	29/06/2024 14:00	29/06/2024 00:00	29/06/2024 00:00	
Avg	39.78	0.01	98.74	1.7	31.2	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.1	0.1	4	0.1	2.7	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree C	ppm	ppm	
29/06/2024 00:00	28.73	0.1	93.57	0	35.4	
29/06/2024 01:00	31.59	0.06	93.77	0	28.5	
29/06/2024 02:00	31.71	0.05	93.98	0	28.1	
29/06/2024 03:00	32.02	0.09	94.19	0	26.8	
29/06/2024 04:00	31.9	0.15	94.11	0	26.8	
29/06/2024 05:00	31.87	0.16	94.07	0	27.2	
29/06/2024 06:00	32.04	0.15	94.1	0	26.2	
29/06/2024 07:00	32.03	0.18	94.36	0	25.7	
29/06/2024 08:00	35.65	0.2	95.29	0	27	
29/06/2024 09:00	46.3	0.16	101.67	0	31.1	
29/06/2024 10:00	46.31	0.06	101.98	0	30.7	
29/06/2024 11:00	46.2	0	102.49	0	30.5	
29/06/2024 12:00	31.92	0	95.19	0	30.2	
29/06/2024 13:00	46.01	0.08	101.03	0	31.2	
29/06/2024 14:00	46.12	0.23	102.77	0	32.3	
29/06/2024 15:00	46.16	0.3	102.32	0	32.5	
29/06/2024 16:00	45.98	0.24	102.26	0	31.8	
29/06/2024 17:00	45.87	0.18	102.22	0	31.1	
29/06/2024 18:00	45.82	0.32	102.2	0	30.2	
29/06/2024 19:00	45.84	0.02	102.41	0	29.1	
29/06/2024 20:00	45.97	0	102.54	0	28.1	
29/06/2024 21:00	46.05	0.01	102.7	0	28.9	
29/06/2024 22:00	46.1	0.01	102.9	0	28.6	
29/06/2024 23:00	42.54	0.02	101.76	0	28.9	
30/06/2024 00:00	31.9	0.03	94.49	0	26.7	
Minimum	28.73	0	93.57	0	25.7	
MinDate	29/06/2024 00:00	29/06/2024 11:00	29/06/2024 00:00	29/06/2024 00:00	29/06/2024 07:00	
Maximum	46.31	0.32	102.9	0	35.4	
MaxDate	29/06/2024 10:00	29/06/2024 18:00	29/06/2024 22:00	29/06/2024 00:00	29/06/2024 00:00	
Avg	39.71	0.11	98.73	0	29.4	
Num	25	25	25	25	25	
Data[%]	100	100	100	100	100	
STD	7.1	0.1	4.1	0	2.3	

Date & Time	11GT_LOAD	11HRSG_DUST	11HRSG_TEMP	11HRSG_SO2@7%O2	11HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree.C	ppm	ppm	
30/06/2024 00:00	31.96	0	94.53	1.7	31.4	
30/06/2024 01:00	31.96	0	93.6	1.8	31.4	
30/06/2024 02:00	31.94	0	93.56	1.8	31.1	
30/06/2024 03:00	31.78	0	93.56	1.8	31.5	
30/06/2024 04:00	31.43	0	93.53	1.7	32.6	
30/06/2024 05:00	31.25	0	93.41	1.7	33.2	
30/06/2024 06:00	31.01	0.21	92.8	1.7	35.9	
30/06/2024 07:00	30.86	0	92.9	1.7	36.1	
30/06/2024 08:00	30.74	0	93.05	1.7	36	
30/06/2024 09:00	30.72	0	93.43	1.7	35.3	
30/06/2024 10:00	30.77	0	93.97	1.7	33.3	
30/06/2024 11:00	30.75	0	94.04	1.7	32.6	
30/06/2024 12:00	30.79	0	94.15	1.7	32.3	
30/06/2024 13:00	30.77	0	93.43	1.7	33.9	
30/06/2024 14:00	30.58	0	92.49	1.7	36.9	
30/06/2024 15:00	30.66	0	92.72	1.7	35.6	
30/06/2024 16:00	30.74	0	93.02	1.7	33.7	
30/06/2024 17:00	30.81	0	92.97	1.7	32.6	
30/06/2024 18:00	41.23	0	97.26	1.7	29.2	
30/06/2024 19:00	44.79	0	101.31	1.7	27.1	
30/06/2024 20:00	44.79	0	101	1.7	27.2	
30/06/2024 21:00	44.72	0	101.37	1.7	27.1	
30/06/2024 22:00	37.06	0	98.98	1.7	31.3	
30/06/2024 23:00	30.6	0	93.33	1.7	36	
01/07/2024 00:00	30.61	0	93.83	1.7	35.6	
Minimum	30.58	0	92.49	1.7	27.1	
MinDate	30/06/2024 14:00	30/06/2024 00:00	30/06/2024 14:00	30/06/2024 00:00	30/06/2024 19:00	
Maximum	44.79	0.21	101.37	1.8	36.9	
MaxDate	30/06/2024 19:00	30/06/2024 06:00	30/06/2024 21:00	30/06/2024 01:00	30/06/2024 14:00	
Avg	33.36	0.01	94.7	1.7	32.8	
High	25	25	25	25	25	
Datal[%]	100	100	100	100	100	
STD	4.9	0	2.8	0	2.9	

Date & Time	12GT_LOAD	12HRSG_DUST	12HRSG_TEMP	12HRSG_SO2@7%O2	12HRSG_NOx@7%O2	Remark
	MW	mg/m3	Degree.C	ppm	ppm	
30/06/2024 00:00	31.9	0.03	94.49	0	26.7	
30/06/2024 01:00	31.89	0.04	93.69	0	26.4	
30/06/2024 02:00	31.87	0.03	93.64	0	26.3	
30/06/2024 03:00	31.71	0.03	93.64	0	26.6	
30/06/2024 04:00	31.36	0.04	93.59	0	27.7	
30/06/2024 05:00	31.19	0.05	93.47	0	28.3	
30/06/2024 06:00	30.95	0.03	92.87	0	30.9	
30/06/2024 07:00	30.8	0	93.61	0	30.9	
30/06/2024 08:00	30.68	0.02	93.18	0	30.7	
30/06/2024 09:00	30.65	0.04	93.42	0	30.1	
30/06/2024 10:00	30.71	0.13	93.99	0	28.7	
30/06/2024 11:00	30.69	0.27	94.17	0	28.1	
30/06/2024 12:00	30.72	0.31	94.73	0	27.8	
30/06/2024 13:00	30.71	0.33	93.43	0	29.4	
30/06/2024 14:00	30.51	0.09	92.98	0	31.8	
30/06/2024 15:00	30.6	0.05	92.93	0	30.6	
30/06/2024 16:00	30.68	0.12	93.73	0	28.7	
30/06/2024 17:00	30.74	0.09	93.38	0	27.8	
30/06/2024 18:00	41.13	0.22	97.78	0	27.2	
30/06/2024 19:00	44.71	0.06	101.51	0	25.7	
30/06/2024 20:00	44.71	0.08	101.21	0	25.4	
30/06/2024 21:00	44.65	0.1	101.36	0	25	
30/06/2024 22:00	37.68	0.12	98.73	0	28	
30/06/2024 23:00	30.54	0.1	93.31	0	31.1	
01/07/2024 00:00	30.55	0.08	93.06	0	30.7	
Minimum	30.51	0	92.98	0	25	
MinDate	30/06/2024 14:00	30/06/2024 07:00	30/06/2024 14:00	30/06/2024 00:00	30/06/2024 21:00	
Maximum	44.71	0.33	101.51	0	31.8	
MaxDate	30/06/2024 19:00	30/06/2024 13:00	30/06/2024 19:00	30/06/2024 00:00	30/06/2024 14:00	
Avg	33.29	0.1	94.8	0	28.4	
High	25	25	25	25	25	
Datal[%]	100	100	100	100	100	
STD	4.9	0.1	2.8	0	2	

B.GRIMM SINCE 1878		Plan to replace the opacity of the source power supply in stack #12.													
No	ขั้นตอน	ผู้รับผิดชอบ	2024												Remark
			มกราคม	กุมภาพันธ์	มีนาคม	เมษายน	พฤษภาคม	มิถุนายน	กรกฎาคม	สิงหาคม	กันยายน	ตุลาคม	พฤศจิกายน	ธันวาคม	
1	อุปกรณ์ตรวจวัดฝุ่น (Opacity_Stack#12) มีสัญญาณแจ้งเตือนอ่านค่าผิดปกติ	นายฤทธิกร ชำนาญศิริเวช		↔											
2	ทีมงานเข้าตรวจสอบอุปกรณ์ตรวจวัดฝุ่น (Opacity_Stack#12) ตรวจพบว่ามี Error Code : ** LIGHT CHECK**	นายฤทธิกร ชำนาญศิริเวช		↔											
3	ทีมงานขึ้นตรวจสอบอุปกรณ์ตรวจวัดที่บริเวณปลายปล่อง Main Stack#12 พบว่าอุปกรณ์ชุดจ่ายไฟเสียหาย (Power supply source DC/Voltage)	นายฤทธิกร ชำนาญศิริเวช		↔											
4	ทีมงานตรวจสอบอะไหล่คลัง Store ไม่มีสินค้าเนื่องจาก Part ดังกล่าวไม่ได้อยู่ในชุดของการทำตรวจสอบและซ่อมบำรุงประจำปีทุกๆ 6 เดือน	นายฤทธิกร ชำนาญศิริเวช		↔											
5	ทีมงานทำการติดต่อกับ Service ที่ได้มีการว่าจ้างตามสัญญาดูแลรักษาประจำปีของทางโรงไฟฟ้าเพื่อทำการขอสั่งซื้อชุดเสียหายดังกล่าว	นายฤทธิกร ชำนาญศิริเวช		↔											
6	ทีมงานแจ้งให้ผู้เกี่ยวข้องรับทราบถึงข้อมูลและเหตุการณ์ดังกล่าวจำเป็นต้องรออะไหล่เนื่องจากสินค้าต้องนำเข้าจากต่างประเทศทำให้ต้องใช้ระยะเวลาค่อนข้างนานกว่าปกติ	นายฤทธิกร ชำนาญศิริเวช		↔										เนื่องจากอุปกรณ์ดังกล่าวต้องนำเข้าจากต่างประเทศและขั้นตอนการดำเนินการระบบงานแล้วเสร็จทำให้สินค้าจากต่างประเทศใช้เวลาค่อนข้างนานกว่าปกติ ซึ่งภาคอุตสาหกรรมได้รับผลกระทบดังกล่าว.	
7	เจ้าหน้าที่โรงไฟฟ้าทำการแจ้งออกคำสั่งซื้อไปยังบริษัท PICO ผู้ให้บริการ	นายฤทธิกร ชำนาญศิริเวช			↔										
8	ชุดอุปกรณ์ที่สั่งซื้อถูกส่งมายังโรงไฟฟ้า BPWHA1	นายฤทธิกร ชำนาญศิริเวช					↔								
9	ทีมงานวางแผนงานและแจ้งทีม Service นัดเข้าทำการเปลี่ยนพร้อมทั้งตรวจสอบระบบ	นายฤทธิกร ชำนาญศิริเวช						↔							

 (นายฤทธิกร ชำนาญศิริเวช) ผู้จัดทำ วันที่ 15 ก.พ 2567	 (นายพันเทพ เหล่าสูงเนิน) ผู้ทบทวน วันที่ 15 ก.พ 2567
--	--