

ภาคผนวก ข-15

เอกสารตรวจสอบสภาพอุปกรณ์ตอบสนองเหตุฉุกเฉิน

รายการอุปกรณ์ตอบโต้เหตุฉุกเฉิน

Oil Spill Equipment (Inventory) - JAN 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
1	3 M Petroleum Sorbent Sheet Type, Model HP-255 (Size 12' x 12' 3 x Bag & 10 sheets/bag)	100 SHts.	Oil spill	90/ pcs.	300 SHts.	800 SHts.	CON02	JO.M0.00.00.000.4	By Condition
2	Marker Buoy (Size Dia 10" - 18 x EA)	10 Ea.	Oil spill	2,980/ pcs.	4 Ea.	10 Ea.	CON01	JO.M0.00.00.000.9	By Condition
3	Yellow bag	0 Packs	Spill response	90/Kgs	5 Packs	20 Packs	CON02	JO.M0.00.00.001.1	By Condition
4	3M Dust Mask # 9003	40 Ea	Oil spill	33 / Ea	20 Ea	40 Ea	CON02	JO.M0.00.00.000.2	By Condition
5	Nitrile Gloves, L,13" x Thk.2.8mm,Size L	0 Ea	Spill response	58 / Ea	25 Ea	30 Ea	IT OFFICE	JO.M0.00.00.001.0	By Condition
6	3M Safety Goggles Model 1821	20 Ea	Spill response	90 /Ea.	20 Ea	25 Ea	IT OFFICE	JO.M0.00.00.000.5	By Condition
7	3M Disposable Model 4310 size L	20 Ea	Spill response	110 / Ea.	20 Ea	25 Ea	Com 02	JO.M0.00.00.000.1	By Condition
8	3M Petroleum Sorbent Boom T-270 (3m /pc., 4pc/ pack)	28 Pcs.	Oil spill	3,1685 / pcs.	20 Pcs.	35 Pcs.	CON03	JO.M0.00.00.000.3	By Condition
9	Petroleum sorbent Boom Type, Model SEU-9 (3m /pc)	3 Pcs.	Oil spill	2,375 / pcs.	0 Pcs.	4 Pcs.	CON02	JO.M0.00.00.001.4	By Condition
10	Clear/Tec Rubberize/Particulate (75lbs/Drum)	2 Drums	Oil spill	899.3 USD/Box	0 Box	3 Box	CON01	JO.M0.00.00.001.5	N/M
11	Clear/Tec Rubberize/Classic Particulate (150lbs/pail)	2 Pail	Oil spill	219.99 USD/Pail	0 Pail	2 Pail	CON02	JO.M0.00.00.001.6	N/M
12	3M-6200 Half Facepiece Respirator	20 Pcs.	Spill response	837 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.7	By Condition
13	3M-6009 Mercury Vapor / Chlorine Gas	11 Pcs.	Chemical	599 / Pcs.	11 Pcs	15 Pcs	IT OFFICE	JO.M0.00.00.001.2	Lot# 1 (6 Ea) : 10/2023 Lot# 2 (5 Ea) : 08/2024
14	3M-6006 Multi Acid Gas	20Pcs.	Oil spill	5995 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.3	Lot# 1 (6 Ea) : 01/2024 Lot# 2 (5 Ea) : 09/2023 Lot# 3 (9 Ea) : 12/2026
	3M 6007 Mercury vapor / Chemical filter cartridge								Lot# 1 (9 Ea) : 06/2026

















Oil Spill Equipment (Inventory) - JAN 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
15		9 Pcs.	Chemical	599 / Pcs.	9 Pcs	10 Pcs	IT OFFICE	JO.M0.00.00.002.9	
16	Cotton Rag	2 Sec	Oil spill	535 / Ea.	1 Sec	3 Sec	CON01	JO.M0.00.00.001.8	By Condition
17	Red Bag	4 Pac	Spill response	67 / Pac	10 Pac	20 Pac	CON02	JO.M0.00.00.001.9	By Condition
18	Teapool Pure	9 Gal	Oil spill	159 / Gal	5 Gal	10 Gal	CON01	JO.M0.00.00.002.0	N/M
19	3M HIGH PERFORMANCE CHEMICAL ROLL C-RL 13	4 Roll	Chemical	7,340 / Roll	2 Roll	4 Roll	CON01	JO.M0.00.00.002.1	By Condition
20	3M CHEMICAL SORBENT MINI-BOOM P200	30 Pcs.	Chemical	760 / Pcs	15 Pcs.	40 Pcs.	CON02	JO.M0.00.00.002.2	By Condition
21	3M CHEMICAL & UNIVERSAL FOLDED SORBENT	3 Box	Chemical	6,050 / Box	1 Box	4 Box	CON01	JO.M0.00.00.002.3	By Condition
22	BARRICADE TAPE WHITE/RED 3"x100m	4 Roll	Spill response	90 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.4	By Condition
23	AVON WATERPROOF CLOTH TAPE	4 Roll	Spill response	120 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.5	By Condition
24	OILER-1 35L	2 Gal	Oil spill	1,140 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.6	N/M
25	SIMPLE GREEN CLEANER / DEGREASER	2 Gal	Spill response	1,130 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.7	N/M
26	See Clean Oil Spill Dispensant P050, 25LTR/PAIL	40 Gal	Spill response	2,959 / Gal	40 Gal	45 Gal	CON01	JO.M0.00.00.002.8	Lot# 1 (40Gal): 12/2026










Checked by: Chawalit
Y.

Date :29 Jan 24

Oil Spill Equipment Inventory 1- JAN 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
1	Oil containment Boom, Fence Boom : Model SK-F45 Set 1 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
2	Oil containment Boom, Fence Boom : Model SK-F45 Set 2 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
3	Oil containment Boom, Fence Boom : Model SK-F45 Set 3 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
4	Permanet Boom "SK-Boom" Model: SK-P70 	220 m.	6,200/m.	Berth # 1	Ready to use	
5	Permanet Boom "SK-Boom" Model: SK-P70 	80 m.	6,200/m.	Berth # 1	Stand by	
6	Permanet Boom "TAKARA" Model: FB-700 	50 m.	5,850/m.	Oil spill Container	Stand by	
7	Permanet Boom: ZHEJIANG JIANZHONG 	150 m.	4,750/m.	Oil spill Container	Stand by	
8	Fence Boom # 1 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Raining	
9	Fence Boom # 2 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Raining	
10	Fence Boom # 3 (4 Roll) 	100 m.	N/M	Berth # 1 draft	Ready to use	
11	Shengqian PUM Boom size 400 mm X 25 mtr section c/w ASTM connector 	25 m.	251,900	Oil spill Container	Ready to use	
12	WELDT Water Pump assembly c/w Hose 	1 set.	118, 000	IT Generator Room	Ready to use	
13	PS180 Potable Air Blower c/w P/Prop X3 	1 set.	95,000	IT Generator Room	Ready to use	
14	Brush Skimmer: LAMOR® Model: Minimax 12 with Powerpack Pump 	1 set.	1,180,000/ Set	Oil spill Container	Ready to use	
15	Portable Dispersant Sprayer System # 1 	2 set.	49,000/ Set	IT Generator Room	Ready to use	
16	Sand and Sawdust drum # 1 	1 set.	N/M	Berth # 1	Ready to use - Sand : 40Kg , Sawdust : 10kg	
	Sand and Sawdust drum # 2					

Oil Spill Equipment Inventory 1- JAN 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
17		1 set.	N/M	Berth # 3 (Red container)	Ready to use - Sand : 60Kg ,Sawdust : 10kg	
18	Sand and Sawdust drum # 3 	1 set.	N/M	Berth # 4	Ready to use - Sand : 20Kg ,Sawdust : 5kg	
19	Sand and Sawdust drum # 4 	1 set.	N/M	Berth # 6 (Chevron container)	Ready to use - Sand : 40Kg ,Sawdust : 7kg	
20	Sand and Sawdust drum # 5 	1 set.	N/M	Marshalling Yard	Ready to use - Sand : 20Kg ,Sawdust : 10kg	
21	500 Lts Empty tank 	1 Tank	N/M	Berth # 1	Ready to use	
22	Canvas Oil hose 	2 set.	N/M	Berth # 1	Ready to use	
23	Floating frame 	1 set.	N/M	Berth # 1	Ready to use	
24	Electric oil boom winder 	1 set.	N/M	Berth # 1	Ready to use	
25	Leaf Net Skimmer 	1 set.	N/M	Oil spill Container	Ready to use	
26	Floor Squeegee 30" 	3 EA.	N/M	Oil spill Container	Ready to use	

Checked by Chawalit
Y.

Date: 29 Jan 2024

Oil Spill Equipment (Inventory) - FEB 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
1	3 M Petroleum Sorbent Sheet Type Model HP-115 (Size 12" x 18" 3 x Bag & 11 Sheets/Bag)	100 Shks.	Oil spill	60/ pcs.	100 Shks.	800 Shks.	CON02	JO.M0.00.00.005.4	By Condition
2	Marker Buoy (Size Dia 10" : 18 x EA)	10 Ea.	Oil spill	2,980/ pcs.	4 Ea.	10 Ea.	CON01	JO.M0.00.00.000.9	By Condition
3	Yellow bag	0 Packs	Spill response	90/Xgs	5 Packs	20 Packs	CON02	JO.M0.00.00.001.1	By Condition
4	3M Dust Mask # 9043	40 Ea	Oil spill	33 / Ea	20 Ea	40 Ea	CON02	JO.M0.00.00.000.2	By Condition
5	Nitrile Gloves, L13" x Thk.10mm,Size L	0 Ea	Spill response	59 / Ea	25 Ea	30 Ea	IT OFFICE	JO.M0.00.00.001.0	By Condition
6	3M Safety Goggles Model 1821	20 Ea	Spill response	90 /Ea.	20 Ea	25 Ea	IT OFFICE	JO.M0.00.00.000.5	By Condition
7	3M Disposable Model 4310 size L	20 Ea	Spill response	110 / Ea.	20 Ea	25 Ea	Con 02	JO.M0.00.00.000.1	By Condition
8	3M Petroleum Sorbent Boom T-275 (3m /pc., 4pc/ pack)	28 Pcs.	Oil spill	3,185 / pcs.	20 Pcs.	35 Pcs.	CON03	JO.M0.00.00.000.3	By Condition
9	Petroleum sorbent Boom Type, Model SEL-8 (3m /pc)	3 Pcs.	Oil spill	2,375 / pcs.	0 Pcs.	4 Pcs.	CON02	JO.M0.00.00.001.4	By Condition
10	ClearTec Rubberizer/Particulate (75Lbs/Drum)	2 Drums	Oil spill	699.5 USD/Box	0 Box	3 Box	CON01	JO.M0.00.00.001.5	N/M
11	ClearTec Rubberizer/Class Particulate (13Lbs/pail)	2 Pail	Oil spill	219.99 USD/Pail	0 Pail	2 Pail	CON02	JO.M0.00.00.001.6	N/M
12	3M-6200 Half Facepiece Respirator	20 Pcs.	Spill response	637 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.7	By Condition
13	3M-6009 Mercury Vapor / Chlorine Gas	11 Pcs.	Chemical	599 / Pcs.	11 Pcs	15 Pcs	IT OFFICE	JO.M0.00.00.001.2	Lot# 1 (6 Ea) : 12/2023 Lot# 2 (5 Ea) : 08/2024
14	3M-6009 Multi Acid Gas	20Pcs.	Oil spill	5995 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.3	Lot# 1 (6 Ea) : 05/2024 Lot# 2 (5 Ea) : 08/2023 Lot# 3 (9 Ea) : 12/2024
	3M 8007 Mercury vapor / Chemical filter cartridge								Lot# 1 (9 Ea) : 06/2026

















Oil Spill Equipment (Inventory) - FEB 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
15		9 Pcs.	Chemical	599 / Pcs.	9 Pcs	10 Pcs	IT OFFICE	JO.M0.00.00.002.9	
16	Cotton Rag	2 Sac	Oil spill	535 / Ea.	1 Sac	3 Sac	CON01	JO.M0.00.00.001.8	By Condition
17	Red Bag	4 Pac	Spill response	67 / Pac	10 Pac	20 Pac	CON02	JO.M0.00.00.001.9	By Condition
18	Terpol Pure	9 Gal	Oil spill	159 / Gal	5 Gal	10 Gal	CON01	JO.M0.00.00.002.0	N/M
19	3M HIGH PERFORMANCE CHEMICAL ROLL C-RL 15	4 Roll	Chemical	7,540 / Roll	2 Roll	4 Roll	CON01	JO.M0.00.00.002.1	By Condition
20	3M CHEMICAL SORBENT MINI-BOOM P200	30 Pcs.	Chemical	760 / Pcs	15 Pcs.	40 Pcs.	CON02	JO.M0.00.00.002.2	By Condition
21	3M CHEMICAL & UNIVERSAL FOLDED SORBENT	3 Box	Chemical	4,050 / Box	1 Box	4 Box	CON01	JO.M0.00.00.002.3	By Condition
22	BARRICADE TAPE WHITE/RED 3"x100m	4 Roll	Spill response	90 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.4	By Condition
23	AVON WATERPROOF CLOTH TAPE	4 Roll	Spill response	120 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.5	By Condition
24	OILER-1 20L	2 Gal	Oil spill	1,140 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.6	N/M
25	SAMPLE GREEN CLEANER / DEGREASER	2 Gal	Spill response	2,150 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.7	N/M
26	Sea Clean Oil Spill Dispersant PGSD, 25LTS/PAIL	40 Gal	Spill response	2,959 / Gal	40 Gal	45 Gal	CON01	JO.M0.00.00.002.8	Lot# 1 (40Gal): 12/2024











Checked by : Chawalit
Y.

Date :29 FEB 24

Oil Spill Equipment Inventory - FEB 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
1	Oil containment Boom, Fence Boom : Model SK-F45 Set 1 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
2	Oil containment Boom, Fence Boom : Model SK-F45 Set 2 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
3	Oil containment Boom, Fence Boom : Model SK-F45 Set 3 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
4	Permanent Boom, "SK-Boom" Model: SK-P20 	220 m.	6,200/m.	Berth # 1	Ready to use	
5	Permanent Boom, "SK-Boom" Model: SK-P20 	80 m.	6,200/m.	Berth # 1	Stand by	
6	Permanent Boom, "TACASAT" Model: FB-200 	50 m.	5,800/m.	Oil spill Container	Stand by	
7	Permanent Boom, ZHEJIANG HANZHONG 	150 m.	4,750/m.	Oil spill Container	Stand by	
8	Fence Boom # 1 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Ramping	
9	Fence Boom # 2 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Ramping	
10	Fence Boom # 3 (4 Roll) 	100 m.	N/M	Berth # 1 strait	Ready to use	
11	Shoreguardian PUA Boom size 400 mm X 25 mtr section c/w ASTM connector 	25 m.	251,900	Oil spill Container	Ready to use	
12	WEGONET Water Pump assembly c/w Hose 	1 set.	110,000	IT Generator Room	Ready to use	
13	PE380 Potable Air Blower c/w P/Prop XII 	1 set.	95,000	IT Generator Room	Ready to use	
14	Brush Skimmer LAMORC Model: Minimax 12 with Powerpack Pump 	1 set.	1,180,000/ Set	Oil spill Container	Ready to use	
15	Portable Dispersant Sprayer System # 1 	2 set.	49,000/ Set	IT Generator Room	Ready to use	
16	Sand and Sawdust drum # 1 	1 set.	N/M	Berth # 1	Ready to use - Sand : 40kg , Sawdust : 10kg	
	Sand and Sawdust drum # 2					

Oil Spill Equipment Inventory - FEB 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
17		1 set.	N/M	Berth # 3 (Red container)	Ready to use - Sand : 60kg ,Sawdust : 10kg	
18	Sand and Sawdust drum # 3 	1 set.	N/M	Berth # 4	Ready to use - Sand : 20kg ,Sawdust : 5kg	
19	Sand and Sawdust drum # 4 	1 set.	N/M	Berth # 6 (Chevron container)	Ready to use - Sand : 40kg ,Sawdust : 7kg	
20	Sand and Sawdust drum # 5 	1 set.	N/M	Marshalling Yard	Ready to use - Sand : 20kg ,Sawdust : 10kg	
21	500 Lts Empty tank 	1 Tank	N/M	Berth # 1	Ready to use	
22	Canvas Oil hose 	2 set.	N/M	Berth # 1	Ready to use	
23	Floating frame 	1 set.	N/M	Berth # 1	Ready to use	
24	Electric oil boom wincher 	1 set.	N/M	Berth # 1	Ready to use	
25	Leaf Net Skimmer 	1 set.	N/M	Oil spill Container	Ready to use	
26	Floor Squeegee 30" 	3 EA.	N/M	Oil spill Container	Ready to use	

Checked by: Chawalit
Y.

Date: 29 FEB 2024

Oil Spill Equipment (Inventory) - MAR 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
1	3M Petroleum Sorbent Sheet Type, Model HP-333 (Size 12" x 12" x 3.5 Bag 10 Sheets/Bag)	100 Shls.	Oil spill	60/ pcs.	300 Shls.	800 Shls.	CON02	JO.M0.00.00.000.4	By Condition
2	Marker Buoy (Size Dia 10" : 18 x EA)	10 Ea.	Oil spill	2,980/ pcs.	4 Ea.	10 Ea.	CON01	JO.M0.00.00.000.9	By Condition
3	Yellow bag	0 Pcs	Spill response	90/Kgs	3 Pcs	20 Pcs	CON02	JO.M0.00.00.001.1	By Condition
4	3M Dust Mask # 9043	40 Ea	Oil spill	33 / Ea	20 Ea	40 Ea	CON02	JO.M0.00.00.000.2	By Condition
5	Nitrile Gloves, L,13" x 7 1/2", 1.5mm, Size L	0 Ea	Spill response	39 / Ea	25 Ea	30 Ea	IT OFFICE	JO.M0.00.00.001.0	By Condition
6	3M Safety Goggles Model 1821	20 Ea	Spill response	90 /Ea.	20 Ea	25 Ea	IT OFFICE	JO.M0.00.00.000.5	By Condition
7	3M Disposable Model 4510 size L	20 Ea	Spill response	110 / Ea.	20 Ea	25 Ea	Con 02	JO.M0.00.00.000.1	By Condition
8	3M Petroleum Sorbent Boom T-270 (3m/pc, 4pc/ pack)	20 Pcs.	Oil spill	3,1485 / pcs.	20 Pcs.	35 Pcs.	CON03	JO.M0.00.00.000.3	By Condition
9	Petroleum sorbent Boom Type, Model SEL-B (3m /pc)	3 Pcs.	Oil spill	2,375 / pcs.	0 Pcs.	4 Pcs.	CON02	JO.M0.00.00.001.4	By Condition
10	ClearTec Rubberizer/Particulate (75lbs/Drum)	2 Drums	Oil spill	699.5 USD/Box	0 Box	3 Box	CON01	JO.M0.00.00.001.5	N/A
11	ClearTec Rubberizer Classic Particulate (15Lbs/pail)	2 PaIl	Oil spill	219.99 USD/PaIl	0 PaIl	2 PaIl	CON02	JO.M0.00.00.001.6	N/A
12	3M-6200 Half Facepiece Respirator	20 Pcs.	Spill response	637 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.7	By Condition
13	3M-6009 Mercury Vapor / Chlorine Gas	11 Pcs.	Chemical	399 / Pcs.	11 Pcs	15 Pcs	IT OFFICE	JO.M0.00.00.001.2	Lot# 1 (4 Ea) : 10/2023 Lot# 2 (5 Ea) : 06/2024
14	3M-6006 Multi Acid Gas	20Pcs.	Oil spill	5995 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.3	Lot# 1 (4 Ea) : 02/2024 Lot# 2 (5 Ea) : 05/2023 Lot# 3 (9 Ea) : 12/2026
15	3M 6007 Mercury vapor / Chemical filter cartridge								Lot# 1 (9 Ea) : 06/2024

















Oil Spill Equipment (Inventory) - MAR 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
15		9 Pcs.	Chemical	599 / Pcs.	9 Pcs	10 Pcs	IT OFFICE	JO.M0.00.00.001.9	
16	Cotton Bag	2 Sac	Oil spill	535 / Ea.	1 Sac	3 Sac	CON01	JO.M0.00.00.001.8	By Condition
17	Red Bag	4 Pac	Spill response	67 / Pac	10 Pac	20 Pac	CON02	JO.M0.00.00.001.9	By Condition
18	Teepee Pure	9 Gal	Oil spill	159 / Gal	5 Gal	10 Gal	CON01	JO.M0.00.00.001.0	N/A
19	3M HIGH PERFORMANCE CHEMICAL ROLL C-RL 15	4 Roll	Chemical	7,540 / Roll	2 Roll	4 Roll	CON01	JO.M0.00.00.001.1	By Condition
20	3M CHEMICAL SORBENT MINI-BOOM P200	30 Pcs.	Chemical	760 / Pcs	15 Pcs.	40 Pcs.	CON02	JO.M0.00.00.001.2	By Condition
21	3M CHEMICAL & UNIVERSAL FOLDED SORBENT	3 Box	Chemical	4,050 / Box	1 Box	4 Box	CON01	JO.M0.00.00.001.3	By Condition
22	BARRICADE TAPE WHITE/RED 3"x100m	4 Roll	Spill response	90 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.001.4	By Condition
23	AVON WATERPROOF CLOTH TAPE	4 Roll	Spill response	120 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.001.5	By Condition
24	OILER-1 20L	2 Gal	Oil spill	1,140 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.001.6	N/A
25	SIMPLE GREEN CLEANER / DEGREASER	2 Gal	Spill response	1,150 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.001.7	N/A
26	See Clean Oil Spill Dispersant #050, 25LTS/PAIL	40 Gal	Spill response	2,959 / Gal	40 Gal	45 Gal	CON01	JO.M0.00.00.001.8	Lot# 1 (40Gal): 12/2026










Checked by : Chawalit Y.

Date :29 MAR 24

Oil Spill Equipment (Inventory 1) - MAR 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
1	Oil containment Boom, Fence Boom : Model SK-F43 Set 1 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
2	Oil containment Boom, Fence Boom : Model SK-F43 Set 2 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
3	Oil containment Boom, Fence Boom : Model SK-F43 Set 3 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
4	Permanet Boom; "SK-Boom" Model: SK-P70 	220 m.	6,200/m.	Berth # 1	Ready to use	
5	Permanet Boom; "SK-Boom" Model: SK-P70 	80 m.	6,200/m.	Berth # 1	Stand by	
6	Permanet Boom; "YAMABA" Model: FB-700 	50 m.	5,850/m.	Oil spill Container	Stand by	
7	Permanet Boom; ZHEJIANG HANCHONG 	150 m.	4,750/m.	Oil spill Container	Stand by	
8	Fence Boom # 1 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Rancing	
9	Fence Boom # 2 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Rancing	
10	Fence Boom # 3 (4 Roll) 	100 m.	N/M	Berth # 1 strait	Ready to use	
11	Shoreguardian PUA Boom size 400 mm X 25 mtr section c/w ASTM connector 	25 m.	251,900	Oil spill Container	Ready to use	
12	WQJINT Water Pump assembly c/w Hose 	1 set.	110, 000	IT Generator Room	Ready to use	
13	PS180 Portable Air Blower c/w P/Prop Kit 	1 set.	95,000	IT Generator Room	Ready to use	
14	Brush Skimmer LAMOCY Model: Minimax 12 with Powerpack Pump 	1 set.	1,180,000/ Set	Oil spill Container	Ready to use	
15	Portable Dispensant Sprayer System # 1 	2 set.	49,000/ Set	IT Generator Room	Ready to use	
16	Sand and Sawdust drum # 1 	1 set.	N/M	Berth # 1	Ready to use - Sand : 60kg , Sawdust : 10kg	
	Sand and Sawdust drum # 2					

Oil Spill Equipment (Inventory 1) - MAR 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
17		1 set.	N/M	Berth # 3 (Red container)	Ready to use - Sand : 60kg ,Sawdust : 10kg	
18	Sand and Sawdust drum # 3 	1 set.	N/M	Berth # 8	Ready to use - Sand : 20kg ,Sawdust : 5kg	
19	Sand and Sawdust drum # 4 	1 set.	N/M	Berth # 6 (Chevron container)	Ready to use - Sand : 40kg ,Sawdust : 7kg	
20	Sand and Sawdust drum # 5 	1 set.	N/M	Marshalling Yard	Ready to use - Sand : 20kg ,Sawdust : 10kg	
21	500 Lts Empty tank 	1 Tank	N/M	Berth # 1	Ready to use	
22	Canvas Oil hose 	2 set.	N/M	Berth # 1	Ready to use	
23	Floating frame 	1 set.	N/M	Berth # 1	Ready to use	
24	Electric oil boom winch 	1 set.	N/M	Berth # 1	Ready to use	
25	Leaf Net Skimmer 	1 set.	N/M	Oil spill Container	Ready to use	
26	Floor Squeegee 30" 	3 EA.	N/M	Oil spill Container	Ready to use	

Checked by Chawalit
Y.

Date :29 MAR 2024

Oil Spill Equipment (Inventory) - APR 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
1	3 M Petroleum Sorbent Sheet Type, Model HP-155 (200 12" x 13", 3 x Bag & 30 Sheets/Bag)	100 Shts.	Oil spill	60/ pcs.	300 Shts.	800 Shts.	CON02	JO.M0.00.00.000.4	By Condition
2	Marlex Buoy (Size Dia 10" - 18 x EA)	10 Ea.	Oil spill	2,980/ pcs.	4 Ea.	10 Ea.	CON01	JO.M0.00.00.000.9	By Condition
3	Yellow bag	0 Pcs	Spill response	90/Kgs	5 Pcs	20 Pcs	CON02	JO.M0.00.00.002.1	By Condition
4	3M Dust Mask # 9003	40 Ea	Oil spill	35 / Ea	20 Ea	40 Ea	CON02	JO.M0.00.00.000.2	By Condition
5	Nitrile Gloves, L.13" x 7 1/2".18mm.Size L	0 Ea	Spill response	59 / Ea	25 Ea	30 Ea	IT OFFICE	JO.M0.00.00.001.0	By Condition
6	3M Safety Goggles Model 1621	20 Ea	Spill response	90 /Ea.	20 Ea	25 Ea	IT OFFICE	JO.M0.00.00.000.5	By Condition
7	3M Disposable Model 4510 size L	20 Ea	Spill response	110 / Ea.	20 Ea	25 Ea	Con 02	JO.M0.00.00.000.1	By Condition
8	3M Petroleum Sorbent Boom T-370 (3m /pc, 4pc/ pack)	28 Pcs.	Oil spill	3,1485 / pcs.	20 Pcs.	35 Pcs.	CON03	JO.M0.00.00.000.3	By Condition
9	Petroleum sorbent Boom Type, Model SEL-B (3m /pc)	3 Pcs.	Oil spill	2,375 / pcs.	0 Pcs.	4 Pcs.	CON02	JO.M0.00.00.001.4	By Condition
10	ClearTex Rubberizer/Particulate (75Lbs/Drum)	2 Drums	Oil spill	695.5 USD/Box	0 Box	3 Box	CON01	JO.M0.00.00.001.5	N/M
11	ClearTex Rubberizer/Particulate (15Lbs/pail)	2 Pail	Oil spill	219.99 USD/Pail	0 Pail	2 Pail	CON02	JO.M0.00.00.001.6	N/M
12	3M-6200 Half Facepiece Respirator	20 Pcs.	Spill response	637 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.7	By Condition
13	3M-6009 Mercury Vapor / Chlorine Gas	11 Pcs.	Chemical	599 / Pcs.	11 Pcs	15 Pcs	IT OFFICE	JO.M0.00.00.001.2	Lot# 1 (4 Ea) : 10/2023 Lot# 2 (3 Ea) : 06/2024
14	3M-6008 Muhl Acid Gas	20Pcs.	Oil spill	5995 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.3	Lot# 1 (4 Ea) : 02/2024 Lot# 2 (5 Ea) : 05/2023 Lot# 3 (9 Ea) : 12/2026
	3M 6007 Mercury vapor / Chemical filter cartridge								Lot# 1 (9 Ea) : 06/2026

















Oil Spill Equipment (Inventory) - APR 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
15		9 Pcs.	Chemical	599 / Pcs.	9 Pcs	10 Pcs	IT OFFICE	JO.M0.00.00.002.9	
16	Cotton Bag	2 Sec	Oil spill	535 / Ea.	1 Sec	3 Sec	CON01	JO.M0.00.00.001.8	By Condition
17	Red Bag	4 Pac	Spill response	67 / Pac	10 Pac	20 Pac	CON02	JO.M0.00.00.001.9	By Condition
18	Tecpol Pure	9 Gal	Oil spill	159 / Gal	5 Gal	10 Gal	CON01	JO.M0.00.00.002.0	N/M
19	3M HIGH PERFORMANCE CHEMICAL ROLL C-RL 15	4 Roll	Chemical	7,540 / Roll	2 Roll	4 Roll	CON01	JO.M0.00.00.002.1	By Condition
20	3M CHEMICAL SORBENT MINI-ROOM P200	30 Pcs.	Chemical	760 / Pcs	15 Pcs.	40 Pcs.	CON02	JO.M0.00.00.002.2	By Condition
21	3M CHEMICAL & UNIVERSAL FOLDED SORBENT	3 Box	Chemical	4,050 / Box	1 Box	4 Box	CON01	JO.M0.00.00.002.3	By Condition
22	BARRICADE TAPE WHITE/RED 3"x100m	4 Roll	Spill response	90 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.4	By Condition
23	AVON WATERPROOF CLOTH TAPE	4 Roll	Spill response	120 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.5	By Condition
24	OILER-1 20L	2 Gal	Oil spill	1,140 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.6	N/M
25	SIMPLE GREEN CLEANER / DEGREASER	2 Gal	Spill response	1,150 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.7	N/M
26	See Clean Oil Spill Dispensam #050, 25LTR/PAIL	40 Gal	Spill response	2,959 / Gal	40 Gal	45 Gal	CON01	JO.M0.00.00.002.8	Lot# 1 (40Gal) : 12/2026










Checked by : Chawalit
Y.

Date :29 APR 24

Oil Spill Equipment (Inventory 1) - APR 2024

No.	Description	Qty	Unit Price	Location	Condition check	Remark
1	Oil containment Boom, Fence Boom : Model SK-F45 Set 1 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
2	Oil containment Boom, Fence Boom : Model SK-F45 Set 2 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
3	Oil containment Boom, Fence Boom : Model SK-F45 Set 3 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
4	Permanent Boom: "SG-Boom" Model: SK-P70 	220 m.	6,200/m.	Berth # 1	Ready to use	
5	Permanent Boom: "SG-Boom" Model: SK-P70 	80 m.	6,200/m.	Berth # 1	Stand by	
6	Permanent Boom: "TAKARA" Model: FB-700 	50 m.	5,850/m.	Oil spill Container	Stand by	
7	Permanent Boom: ZHEJIANG HANZHONG 	150 m.	4,750/m.	Oil spill Container	Stand by	
8	Fence Boom # 1 (8 Roll) 	100 m.	N/M	Berth # 1	Moved to Ramping	
9	Fence Boom # 2 (8 Roll) 	100 m.	N/M	Berth # 1	Moved to Ramping	
10	Fence Boom # 3 (8 Roll) 	100 m.	N/M	Berth # 1 (vitrail)	Ready to use	
11	Shoreguardian PUA Boom size 400 mm X 25 mtr section c/w ASTM connector 	25 m.	251,800	Oil spill Container	Ready to use	
12	WSDOT Water Pump assembly c/w Hose 	1 set.	110, 000	IT Generator Room	Ready to use	
13	PS300 Portable Air Blower c/w P/Prop Kit 	1 set.	95,000	IT Generator Room	Ready to use	
14	Brush Skimmer: LAMOR® Model: Minimax 12 with Powerpack Pump 	1 set.	1,180,000/ Set	Oil spill Container	Ready to use	
15	Portable Dissipant Sprayer System # 1 	2 set.	49,000/ Set	IT Generator Room	Ready to use	
16	Sand and Sawdust drum # 1 	1 set.	N/M	Berth # 1	Ready to use - Sand : 80Kg , Sawdust : 10kg	
	Sand and Sawdust drum # 2					

Oil Spill Equipment (Inventory 1) - APR 2024

No.	Description	Qty	Unit Price	Location	Condition check	Remark
17		1 set.	N/M	Berth # 3 (Red container)	Ready to use - Sand : 60Kg ,Sawdust : 10kg	
18	Sand and Sawdust drum # 3 	1 set.	N/M	Berth #4	Ready to use - Sand : 20Kg ,Sawdust : 5kg	
19	Sand and Sawdust drum # 4 	1 set.	N/M	Berth # 6 (Chevron container)	Ready to use - Sand : 40Kg ,Sawdust : 7kg	
20	Sand and Sawdust drum # 5 	1 set.	N/M	Marshalling Yard	Ready to use - Sand : 20Kg ,Sawdust : 10kg	
21	500 Ltrs Empty tank 	1 Tank	N/M	Berth # 1	Ready to use	
22	Canvas Oil hose 	2 set.	N/M	Berth # 1	Ready to use	
23	Floating frame 	1 set.	N/M	Berth # 1	Ready to use	
24	Electric oil boom whaler 	1 set.	N/M	Berth # 1	Ready to use	
25	Leaf Net Skimmer 	1 set.	N/M	Oil spill Container	Ready to use	
26	Floor Squeegee 30" 	3 EA.	N/M	Oil spill Container	Ready to use	

Checked by: Chawalit
Y.

Date :29 APR 2024

Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
1	3M Petroleum Sorbent Sheet Type, Model HP-235 (Size 12" x 12" - 3 x 6 Bag 3 M Sheets/Bag)	100 Shets.	Oil spill	60/ pcs.	300 Shets.	800 Shets.	CON02	JO.M0.00.00.000.4	By Condition
2	Marker Buoy (Size Dia 15" - 18 x EA)	10 Ea.	Oil spill	2,980/ pcs.	4 Ea.	10 Ea.	CON01	JO.M0.00.00.000.9	By Condition
3	Yellow bag	0 Packs	Spill response	90/kg	5 Packs	20 Packs	CON02	JO.M0.00.00.001.1	By Condition
4	3M Dust Mask # 9003	40 Ea	Oil spill	33 / Ea	20 Ea	40 Ea	CON02	JO.M0.00.00.000.2	By Condition
5	Nitrile Gloves, L13" x 7 1/2" 10mm Size L	0 Ea	Spill response	59 / Ea	25 Ea	30 Ea	IT OFFICE	JO.M0.00.00.001.0	By Condition
6	3M Safety Goggles Model 1811	20 Ea	Spill response	90 /Ea.	20 Ea	25 Ea	IT OFFICE	JO.M0.00.00.000.5	By Condition
7	3M Disposable Model 4510 size L	20 Ea	Spill response	110 / Ea.	20 Ea	25 Ea	Con 02	JO.M0.00.00.000.1	By Condition
8	3M Petroleum Sorbent Boom T-270 (3m/pc., 4pc/ pack)	28 Pcs.	Oil spill	3,1445 / pcs.	20 Pcs.	35 Pcs.	CON03	JO.M0.00.00.000.3	By Condition
9	Petroleum sorbent Boom Type, Model SEL-B (3m /pc)	3 Pcs.	Oil spill	2,375 / pcs.	0 Pcs.	4 Pcs.	CON02	JO.M0.00.00.001.4	By Condition
10	ClearTex Rubberbar Particulate (75Lbs/Drum)	2 Drums	Oil spill	699.5 USD/Box	0 Box	3 Box	CON01	JO.M0.00.00.001.5	N/M
11	ClearTex Rubberbar Classic Particulate (15Lbs/pail)	2 Pail	Oil spill	219.99 USD/Pail	0 Pail	2 Pail	CON02	JO.M0.00.00.001.6	N/M
12	3M-6200 Half Facepiece Respirator	20 Pcs.	Spill response	637 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.7	By Condition
13	3M-6009 Mercury Vapor / Chlorine Gas	11 Pcs.	Chemical	599 / Pcs.	11 Pcs	15 Pcs	IT OFFICE	JO.M0.00.00.001.2	Lot# 1 (4 Ea) : 10/2023 Lot# 2 (5 Ea) : 06/2024
14	3M-6006 Multi Acid Gas	20Pcs.	Oil spill	5995 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.001.3	Lot# 1 (4 Ea) : 01/2024 Lot# 2 (5 Ea) : 05/2025 Lot# 3 (9 Ea) : 12/2026
	3M 800F Mercury vapor / Chemical filter cartridge								Lot# 1 (9 Ea) : 06/2028
















Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
15		9 Pcs.	Chemical	599 / Pcs.	9 Pcs	10 Pcs	IT OFFICE	JO.M0.00.00.002.9	
16	Cotton Bag	2 Sac	Oil spill	535 / Ea.	1 Sac	3 Sac	CON01	JO.M0.00.00.001.8	By Condition
17	Red Bag	4 Pac	Spill response	67 / Pac	10 Pac	20 Pac	CON02	JO.M0.00.00.001.9	By Condition
18	Teepol Pure	9 Gal	Oil spill	159 / Gal	5 Gal	10 Gal	CON01	JO.M0.00.00.002.0	N/M
19	3M HIGH PERFORMANCE CHEMICAL ROLL C-RL 15	4 Roll	Chemical	7,340 / Roll	2 Roll	4 Roll	CON01	JO.M0.00.00.002.1	By Condition
20	3M CHEMICAL SORBENT MINI-BOOM P200	30 Pcs.	Chemical	780 / Pcs	15 Pcs.	40 Pcs.	CON02	JO.M0.00.00.002.2	By Condition
21	3M CHEMICAL & UNIVERSAL FOLDED SORBENT	3 Box	Chemical	4,050 / Box	1 Box	4 Box	CON01	JO.M0.00.00.002.3	By Condition
22	BARRICADE TAPE WHITE/RED 3"x100m	4 Roll	Spill response	90 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.4	By Condition
23	AVON WATERPROOF CLOTH TAPE	4 Roll	Spill response	120 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.002.5	By Condition
24	OILER-1 20L	2 Gal	Oil spill	1,140 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.6	N/M
25	SIMPLE GREEN CLEANER / DEGREASER	2 Gal	Spill response	1,150 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.002.7	N/M
26	See Clean Oil Spill Dispenser #050, 25LTR/PAIL	40 Gal	Spill response	2,959 / Gal	40 Gal	45 Gal	CON01	JO.M0.00.00.002.8	Lot# 1 (40Gal) : 12/2026











Checked by : Chawalit
Y.

Date :13 MAY 24

Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
1	Oil containment Boom, Fence Boom : Model SK-F45 Set 1 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
2	Oil containment Boom, Fence Boom : Model SK-F45 Set 2 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
3	Oil containment Boom, Fence Boom : Model SK-F45 Set 3 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
4	Permanent Boom, "SK Boom" Model: SK-P70 	220 m.	6,200/m.	Berth # 1	Ready to use	
5	Permanent Boom, "SK Boom" Model: SK-P70 	80 m.	6,200/m.	Berth # 1	Stand by	
6	Permanent Boom, "TAKARA" Model: FB-700 	50 m.	5,850/m.	Oil spill Container	Stand by	
7	Permanent Boom, ZHEJIANG HANZHONG 	150 m.	4,750/m.	Oil spill Container	Stand by	
8	Fence Boom # 1 (8 Roll) 	100 m.	N/M	Berth # 1	Moved to Ramping	
9	Fence Boom # 2 (8 Roll) 	100 m.	N/M	Berth # 1	Moved to Ramping	
10	Fence Boom # 3 (8 Roll) 	100 m.	N/M	Berth # 1 vtrak	Ready to use	
11	Shoreguardian PUA Boom, size 400 mm X 25 mtr section c/w ASTM connector 	25 m.	251,800	Oil spill Container	Ready to use	
12	W202KT Water Pump assem belt c/w Hose 	1 set.	110, 000	IT Generator Room	Ready to use	
13	P8180 Portable Air Blower c/w P/Prop XII 	1 set.	95,000	IT Generator Room	Ready to use	
14	Brush Skimmer: LAMOR", Model: Minimax 12 with Powerack Pump 	1 set.	1,180,000/ Set	Oil spill Container	Ready to use	
15	Portable Dispensant Sprayer System # 1 	2 set.	49,000/ Set	IT Generator Room	Ready to use	
16	Sand and Sawdust drum # 1 	1 set.	N/M	Berth # 1	Ready to use - Sand : 40Kg ,Sawdust : 10kg	
	Sand and Sawdust drum # 2					

Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Unit Price	Location	Condition check	Remark
17		1 set.	N/M	Berth # 3 (Red container)	Ready to use - Sand : 60Kg ,Sawdust : 10kg	
18	Sand and Sawdust drum # 3 	1 set.	N/M	Berth # 4	Ready to use - Sand : 20Kg ,Sawdust : 5kg	
19	Sand and Sawdust drum # 4 	1 set.	N/M	Berth # 6 (Chevron container)	Ready to use - Sand : 40Kg ,Sawdust : 7kg	
20	Sand and Sawdust drum # 5 	1 set.	N/M	Marshalling Yard	Ready to use - Sand : 20Kg ,Sawdust : 10kg	
21	500 Ltr Empty tank 	1 Tank	N/M	Berth # 1	Ready to use	
22	Canvas Oil hose 	2 set.	N/M	Berth # 1	Ready to use	
23	Floating frame 	1 set.	N/M	Berth # 1	Ready to use	
24	Electric oil boom wincher 	1 set.	N/M	Berth # 1	Ready to use	
25	Leaf Net Skimmer 	1 set.	N/M	Oil spill Container	Ready to use	
26	Floor Squeegee 30" 	3 EA.	N/M	Oil spill Container	Ready to use	

Checked by : Chawalit
Y.

Date :13 MAY 2024

Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
1	3M Petroleum Sorbent Sheet Type, Model HP-255 (Size 37" x 17" 3.5kg & 10 Sheets/Bag)	100 Shks.	Oil spill	60/ pcs.	300 Shks.	800 Shks.	CON02	JO.M0.00.00.000.4	By Condition
2	Marlex Bury (Size 18" : 18 x 5A)	10 Ea.	Oil spill	2,980/ pcs.	4 Ea.	10 Ea.	CON01	JO.M0.00.00.000.9	By Condition
3	Yellow bag	0 Packs	Spill response	90/Kgs	5 Packs	20 Packs	CON02	JO.M0.00.00.000.1	By Condition
4	3M Dust Mask # 8063	40 Ea	Oil spill	33 / Ea	20 Ea	40 Ea	CON02	JO.M0.00.00.000.2	By Condition
5	Nitrile Gloves, L.17" x 7.5x.18mm.Size L	0 Ea	Spill response	59 / Ea	25 Ea	30 Ea	IT OFFICE	JO.M0.00.00.000.0	By Condition
6	3M Safety Goggles Model 1421	20 Ea	Spill response	90 /Ea.	20 Ea	25 Ea	IT OFFICE	JO.M0.00.00.000.5	By Condition
7	3M Disposable Model 4510 size L	20 Ea	Spill response	110 / Ea.	20 Ea	25 Ea	Con 02	JO.M0.00.00.000.1	By Condition
8	3M Petroleum Sorbent Boom T-270 (3m/pc, 4pc/ pack)	28 Pcs.	Oil spill	3,1683 / pcs.	20 Pcs.	33 Pcs.	CON03	JO.M0.00.00.000.3	By Condition
9	Petroleum sorbent Boom Type, Model SEL-B (3m /pc)	9 Pcs.	Oil spill	2,375 / pcs.	0 Pcs.	4 Pcs.	CON02	JO.M0.00.00.000.4	By Condition
10	ClearTex Rubberizer/Particulate (75kg/Drum)	2 Drums	Oil spill	699.5 USD/Box	0 Box	3 Box	CON01	JO.M0.00.00.000.5	N/M
11	ClearTex Rubberizer/Particulate (15Lbs/pail)	2 Pail	Oil spill	219.99 USD/Pail	0 Pail	2 Pail	CON02	JO.M0.00.00.000.6	N/M
12	3M-6200 Half Facepiece Respirator	20 Pcs.	Spill response	637 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.000.7	By Condition
13	3M-6029 Mercury Vapor / Chlorine Gas	11 Pcs.	Chemical	599 / Pcs.	11 Pcs	15 Pcs	IT OFFICE	JO.M0.00.00.000.2	Lot# 1 (4 Ea) : 10/2023 Lot# 2 (5 Ea) : 06/2024
14	3M-6006 Multi Acid Gas	20Pcs.	Oil spill	5995 / Pcs.	20 Pcs	25 Pcs	IT OFFICE	JO.M0.00.00.000.3	Lot# 1 (4 Ea) : 01/2024 Lot# 2 (5 Ea) : 05/2023 Lot# 3 (9 Ea) : 12/2026
	3M 600P Mercury vapor / Chemical filter cartridge								Lot# 1 (9 Ea) : 06/2026

















Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Type of use	Unit Price	Minimum Requirement	Maximum Stock	Store Location	Material Code	Expiry Date
15		9 Pcs.	Chemical	599 / Pcs.	9 Pcs	10 Pcs	IT OFFICE	JO.M0.00.00.000.8	
16	Cotton Rag	2 Sac	Oil spill	535 / Ea.	1 Sac	3 Sac	CON01	JO.M0.00.00.000.8	By Condition
17	Red Bag	4 Pac	Spill response	67 / Pac	10 Pac	20 Pac	CON02	JO.M0.00.00.000.9	By Condition
18	Teepol Pure	9 Gal	Oil spill	159 / Gal	5 Gal	10 Gal	CON01	JO.M0.00.00.000.0	N/M
19	3M HIGH PERFORMANCE CHEMICAL ROLL C-RL 13	4 Roll	Chemical	7,540 / Roll	2 Roll	4 Roll	CON01	JO.M0.00.00.000.1	By Condition
20	3M CHEMICAL SORBENT MINI-BOOM P200	30 Pcs.	Chemical	760 / Pcs	15 Pcs.	40 Pcs.	CON02	JO.M0.00.00.000.2	By Condition
21	3M CHEMICAL & UNIVERSAL FOLDED SORBENT	3 Box	Chemical	4,050 / Box	1 Box	4 Box	CON01	JO.M0.00.00.000.3	By Condition
22	BARRICADE TAPE WHITE/RED 3"x100m	4 Roll	Spill response	90 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.000.4	By Condition
23	AVON WATERPROOF CLOTH TAPE	4 Roll	Spill response	120 / Roll	2 Roll	6 Roll	CON02	JO.M0.00.00.000.5	By Condition
24	OILER-1 20L	2 Gal	Oil spill	1,140 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.000.6	N/M
25	SMPL GREEN CLEANER / DREGREASER	2 Gal	Spill response	1,150 / Gal	1 Gal	4 Gal	CON01	JO.M0.00.00.000.7	N/M
26	Sea Clean Oil Spill Dispensant #050, 35LTR/PAIL	40 Gal	Spill response	2,999 / Gal	40 Gal	45 Gal	CON01	JO.M0.00.00.000.8	Lot# 1 (40Gal): 12/2026








Checked by: Chawalit
Y.

Date: 25 JUNE 24

Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Unit Price	Location	Condition check	Remarks
1	Oil containment Boom, Fence Boom : Model SK-F45 Set 1 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
2	Oil containment Boom, Fence Boom : Model SK-F45 Set 2 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
3	Oil containment Boom, Fence Boom : Model SK-F45 Set 3 (8 Roll) 	200 m.	2,300/m.	Berth # 1	Ready to use	
4	Permanent Boom: "Sk-Boom" Model: SK-P70 	220 m.	6,200/m.	Berth # 1	Ready to use	
5	Permanent Boom: "Sk-Boom" Model: SK-P70 	80 m.	6,200/m.	Berth # 1	Stand by	
6	Permanent Boom: "TAKARA" Model: FB-700 	50 m.	5,850/m.	Oil spill Container	Stand by	
7	Permanent Boom: ZHEJIANG HANDONG 	150 m.	4,750/m.	Oil spill Container	Stand by	
8	Fence Boom # 1 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Raming	
9	Fence Boom # 2 (4 Roll) 	100 m.	N/M	Berth # 1	Moved to Raming	
10	Fence Boom # 3 (4 Roll) 	100 m.	N/M	Berth # 1 vtralt	Ready to use	
11	Shoreguardian PMA Boom: size 400 mm X 25 mtr section c/w ASTM connector 	25 m.	251,800	Oil spill Container	Ready to use	
12	W200MT Water Pump assembly c/w Hose 	1 set.	110, 000	IT Generator Room	Ready to use	
13	PS180 Potable Air Blower c/w P/Prop Kit 	1 set.	95,000	IT Generator Room	Ready to use	
14	Beach Skimmer: LAMOR", Model: Minimax 12 with Powerpack Pump 	1 set.	1,180,000/ Set	Oil spill Container	Ready to use	
15	Portable Dispersant Sprayer System # 1 	2 set.	49,000/ Set	IT Generator Room	Ready to use	
16	Sand and Sawdust drum # 1 	1 set.	N/M	Berth # 1	Ready to use - Sand : 40kg , Sawdust : 10kg	
	Sand and Sawdust drum # 2					


Oil Spill Equipment (Inventory) - MAY 2024

No	Description	Qty	Unit Price	Location	Condition check	Remarks
17		1 set.	N/M	Berth # 3 (Red container)	Ready to use - Sand : 60kg ,Sawdust : 10kg	
18	Sand and Sawdust drum # 3 	1 set.	N/M	Berth # 4	Ready to use - Sand : 20kg ,Sawdust : 5kg	
19	Sand and Sawdust drum # 4 	1 set.	N/M	Berth # 6 (Chevron container)	Ready to use - Sand : 40kg ,Sawdust : 7kg	
20	Sand and Sawdust drum # 5 	1 set.	N/M	Marshalling Yard	Ready to use - Sand : 20kg ,Sawdust : 10kg	
21	500 Lts Empty tank 	1 Tank	N/M	Berth # 1	Ready to use	
22	Canvas Oil hose 	2 set.	N/M	Berth # 1	Ready to use	
23	Floating frame 	1 set.	N/M	Berth # 1	Ready to use	
24	Electric oil boom whaler 	1 set.	N/M	Berth # 1	Ready to use	
25	Lead Net Skimmer 	1 set.	N/M	Oil spill Container	Ready to use	
26	Floor Squeegee 30" 	3 EA.	N/M	Oil spill Container	Ready to use	

Checked by : Chawalit
Y.

Date : 25 JUNE 2024

ตัวอย่างเอกสารตรวจสอบสภาพอุปกรณ์ตอบโต้ภาวะฉุกเฉิน
และอุปกรณ์ดับเพลิง




PTTEP
PSB

PSB

FIRE FIGHTING EQUIPMENT

YEARLY CHECK LIST



PSB SONGKHLA


OPERATION UNIT

		ISSUED	RETURN	COMPLETED
1	FIRE HYDRANT	31/01/24	31/01/24	100 %
2	FIRE HOSE REEL	31/01/24	31/01/24	100 %
3	FIRE HOSE	31/01/24	31/01/24	100 %
4	EXTINGUISHER	31/01/24	31/01/24	100 %
5	FIRE MAN EDP.	31/01/24	31/01/24	100 %
6	LIFEBUOY	31/01/24	31/01/24	100 %
7	STRETCHER	31/01/24	31/01/24	100 %
8	SAFETY SHOWER	31/01/24	31/01/24	100 %
9	EYEWASH STATION	31/01/24	31/01/24	100 %
10	TROCH	31/01/24	31/01/24	100 %
11	FIRE ALARM	31/01/24	31/01/24	100 %
12	EMERGENCY PHONE	31/01/24	31/01/24	100 %
13	FIRE HOSE TROLLEY	31/01/24	31/01/24	100 %
14	EMERGENCY FIRE EXIT DOOR	31/01/24	31/01/24	100 %
TASK COMPLETED				100 %

TIME SPENDING: 31 MAN HRS

REMARK:

CHECK BY: PM team DATE: 31/01/2024




PTTEP
PSB

FIRE HYDRANT

MAINTENANCE SHEET

YEARLY



PSB SONGKHLA

OPERATION UNIT LOCATION: PSB DATE: 31/01/24

SAFETY SERVICE PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. HYDRANTS ARE ACCESSIBLE & FREE OF OBSTRUCTION

B. TOP OF HYDRANT IS NOT LEAKING WHEN HYDRANT IS ON


C. RUBBER SEAL UNDER CAPS ARE NOT LEAKING

D. CONNECT FIRE HOSE TO FLUSH WATER (OPEN / CLOSE SERVICE VALVE SLOWLY SEVERAL TIMES)

E. HYDRANT BARREL IS IN GOOD CONDITION WITHOUT CRACKS OR CORROSION

F. OUTLET CAPS SECURE


G. CLEAN AND GREASE OF MOVING PARTS



A	B	C	D	E	F	G	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓	✓	✓		HD1	SECURITY BOX2
✓	✓	✓	✓	✓	✓	✓		HD2	SECURITY BOX3
✓	✓	✓	✓	✓	✓	✓	Receiver water	HD3	SECURITY BOX3
✓	✓	✓	✓	✓	✓	✓		HD4	SECURITY BOX4
✓	✓	✓	✓	✓	✓	✓		HD5	JETTY STREET WAY
✓	✓	✓	✓	✓	✓	✓		HD6	JETTY STREET WAY
✓	✓	✓	✓	✓	✓	✓		HD7	JETTY STREET WAY
✓	✓	✓	✓	✓	✓	✓		HD8	JETTY BERTH1
✓	✓	✓	✓	✓	✓	✓		HD9	JETTY BERTH2
✓	✓	✓	✓	✓	✓	✓		HD10	JETTY BERTH3
✓	✓	✓	✓	✓	✓	✓		HD11	JETTY BERTH4
✓	✓	✓	✓	✓	✓	✓		HD12	JETTY BERTH5
✓	✓	✓	✓	✓	✓	✓		HD13	JETTY BERTH6
✓	✓	✓	✓	✓	✓	✓		HD14	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓	✓	Receiver water	HD15	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓	✓		HD16	PSB BUILDING-B / West
✓	✓	✓	✓	✓	✓	✓	Receiver water	AHD-01	PSB WHI - 04

REMARKS:

LEADER: PM team




PTTEP
PSB

FIRE HOSE REEL

MAINTENANCE SHEET

YEARLY



PSB SONGKHLA

OPERATION UNIT LOCATION: PSB DATE: 31/01/24

SAFETY SERVICE PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. THE HOSE REEL IS READILY ACCESSIBLE WITH NO OBSTACLES RESTRICTING ITS ACCESS


B. ANY DAMAGE OR CORROSION OF THE HOSE REEL - GOOD, 2= POOR, 3= BAD, 4= VERY BAD

C. THE NOZZLE IS RETAINED IN THE NOZZLE INTERLOCK

D. CHECK NOZZLE AND HOSE BY FILL WATER INTO THE HOSE FULLY

E. THE HOSE REEL CAN BE UNWOUND FREELY IN ITS INTENDED DIRECTION


F. CLEAN AND GREASE AS NECESSARY



A	B	C	D	E	F	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓	✓		FH10	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓	✓		FH01	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓	✓		FH02	PSB BUILDING-B / OFFICE FLOOR2
✓	✓	✓	✓	✓	✓		FH03	PSB BUILDING-B / OFFICE FLOOR3
✓	✓	✓	✓	✓	✓		FR4	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓	✓		FR5	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓	✓		FR6	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓	✓		FR7	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓	✓		FR8	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓	✓		FR9	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓	✓		AFR 01	PSB WHI 04
✓	✓	✓	✓	✓	✓		FH-11	Free Zone-Chemical Room

REMARKS:

LEADER: PM team




PTTEP
PSB

FIRE HOSE BOX

MAINTENANCE SHEET

YEARLY



PSB SONGKHLA

OPERATION UNIT LOCATION: PSB DATE: 31/01/24

SAFETY SERVICE PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. HOSE BOX IN GOOD CONDITION WITHOUT CRACKS

B. SECURING STRAP & DOOR PACKING IN A GOOD CONDITION


C. NOZZLE OF APPROPRIATE SIZE & TYPE

D. FIRE HOSE OF APPROPRIATE LENGTH

E. APPROPRIATE SPANNER

F. HOSE COUPLING IS PROPERLY CONNECTED

G. FIRE HOSE CONNECT WITH FIRE HYDRANT, NOZZLE AND FULL FILL WATER FOR TEST LEAK OPERATION



A	B	C	D	E	F	G	REMARKS	LOCATION
✓	✓	✓	✓	✓	✓	✓	FH 38 mm - 1 Pc / FH 64 mm - 1 Pc / NOZZLE - 1	JETTY BERTH - 1 (FH 01)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 / FH 38 mm - 1 Pc / FH 64 mm - 1 Pc / NOZZLE - 1	JETTY BERTH - 2 (FH 02)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 / FH 38 mm - 1 Pc / FH 64 mm - 1 Pc / NOZZLE - 1	JETTY BERTH - 4 (FH 03)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 / FH 38 mm - 1 Pc / FH 64 mm - 1 Pc / NOZZLE - 1	JETTY BERTH - 5 (FH 04)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 / FH 38 mm - 1 Pc / FH 64 mm - 1 Pc / NOZZLE - 1	JETTY BERTH - 6 (FH 05)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 / FH 38 mm - 1 Pc / FH 64 mm - 1 Pc / NOZZLE - 1	PSB JETTY/HD 07 (FH 06)
✓	✓	✓	✓	✓	✓	✓	NOZZLE - 2 / Y-VALVE - 1 / HAND TOOL - 1	BEHIND PSB BUILDING-A

REMARKS:

LEADER: PM team

PTTEP PSB EXTINGUISHER MAINTENANCE SHEET YEARLY PSB SONGKHLA SAFETY SERVICE DATE: 09/11/24 PAGE 1 OF 6

WORK DETAILS FOR EACH UNIT:

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL

D. TURN UP SIDE DOWN TO DECOMPACT POWDER. HIT SIDE CAREFULLY AGAINST METAL SURFACE TO ASSIST (P).

E. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD

F. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

G. WHEN CO2 TO SEE IF IT STILL WORKS NORMALLY OR NOT every 6 month

WAGON CO2 ที่ต้องดูให้แน่ใจว่าไม่หมดสภาพใช้ไม่ได้ 3 ข้างรถบรรทุก

ID No.	TYPE	LOCATION	DEPARTMENT
PP-01	Dry powder 6.8 kg	Security box 4	PSB BUILDING-A
PC-01	CO2 4.5 kg	PSB OFFICE 1st FLOOR/ Room 108	PSB BUILDING-A
PP-02	Dry powder 6.8 kg	PSB 1st floor/infront off medical	PSB BUILDING-A
PC-02	CO2 4.5 kg	PSB OFFICE 1st FLOOR/ fire hose box (S)	PSB BUILDING-A
PP-03	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (N)	PSB BUILDING-A
PP-04	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 211	PSB BUILDING-A
PP-05	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (N)	PSB BUILDING-A
PP-06	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ CPOC office	PSB BUILDING-A
PP-07	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (S)	PSB BUILDING-A
PP-08	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (N)	PSB BUILDING-A
PP-09	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (S)	PSB BUILDING-A
PP-10	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (N)	PSB BUILDING-A
PP-11	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (S)	PSB BUILDING-A
PP-12	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (N)	PSB BUILDING-A
PC-03	CO2 4.5 kg	PSB office floor/ infront off radio room	PSB BUILDING-A
PC-04	CO2 4.5 kg	PSB office floor/ TY room	PSB BUILDING-A
PC-05	CO2 4.5 kg	PSB Fire pump	PSB BUILDING-A
PP-14	Dry powder 6.8 kg	Driver seat room	PSB BUILDING-A
PP-15	Dry powder 6.8 kg	Security box 2	PSB BUILDING-A
PP-16	Dry powder 6.8 kg	Security box 3	PSB BUILDING-A
PP-17	Dry powder 6.8 kg	Fire service shop	PSB BUILDING-A
PC-05	CO2 4.5 kg	Electrical room	PSB BUILDING-A
PC-06	CO2 4.5 kg	Electrical room	PSB BUILDING-A
PP-01	Foam 9 liter	Generator room	PSB BUILDING-A
PP-02	Foam 9 liter	Generator room	PSB BUILDING-A
NP-01	Dry powder 6.8 kg	PSB FLOOR1 - E.S	PSB BUILDING-B
NP-02	Dry powder 6.8 kg	PSB FLOOR1	PSB BUILDING-B
NP-03	Dry powder 6.8 kg	PSB FLOOR1	PSB BUILDING-B
NP-04	Dry powder 6.8 kg	PSB FLOOR1	PSB BUILDING-B
NP-05	Dry powder 6.8 kg	PSB FLOOR1	PSB BUILDING-B
NP-06	Dry powder 6.8 kg	PSB FLOOR1	PSB BUILDING-B
NP-07	Dry powder 6.8 kg	PSB FLOOR2	PSB BUILDING-B
NP-08	Dry powder 6.8 kg	PSB FLOOR2	PSB BUILDING-B
NP-09	Dry powder 6.8 kg	PSB FLOOR2	PSB BUILDING-B
NP-10	Dry powder 6.8 kg	PSB FLOOR2	PSB BUILDING-B
NP-11	Dry powder 6.8 kg	PSB FLOOR3	PSB BUILDING-B
NP-12	Dry powder 6.8 kg	PSB FLOOR3	PSB BUILDING-B

PTTEP PSB EXTINGUISHER MAINTENANCE SHEET YEARLY PSB SONGKHLA SAFETY SERVICE DATE: 09/11/24 PAGE 2 OF 6

WORK DETAILS FOR EACH UNIT:

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL

D. TURN UP SIDE DOWN TO DECOMPACT POWDER. HIT SIDE CAREFULLY AGAINST METAL SURFACE TO ASSIST (P).

E. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD

F. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

G. WHEN CO2 TO SEE IF IT STILL WORKS NORMALLY OR NOT every 6 month

WAGON CO2 ที่ต้องดูให้แน่ใจว่าไม่หมดสภาพใช้ไม่ได้ 3 ข้างรถบรรทุก

ID No.	TYPE	LOCATION	DEPARTMENT
NP-13	Dry powder 6.8 kg	PSB FLOOR3	PSB BUILDING-B
NP-14	Dry powder 6.8 kg	PSB FLOOR3	PSB BUILDING-B
JP 01	Dry powder 6.8 kg	Security box 6	JETTY
JP 02	Dry powder 6.8 kg	Fire hose reel box No.1	JETTY
JP 03	Dry powder 6.8 kg	Fire hose reel box No.2	JETTY
JP 04	Dry powder 6.8 kg	Fire hose reel box No.3	JETTY
JP 05	Dry powder 6.8 kg	Fire hose reel box No.4	JETTY
JP 06	Dry powder 6.8 kg	Fire hose reel box No.5	JETTY
JP 07	Dry powder 6.8 kg	Infront off office	JETTY
JP 08	Dry powder 6.8 kg	Infront off Electrical room	JETTY
JP 09	Dry powder 6.8 kg	Security box 5	JETTY
JP 10	Dry powder 6.8 kg	Contrainer of CPOC	JETTY
JP 11	Dry powder 6.8 kg	Generator Room 02	JETTY
JP 12	Dry powder 6.8 kg	On the boat	JETTY
JP 13	Dry powder 6.8 kg	Electrical room	PSB
PP 22	Dry powder 6.8 kg	Maintenance work shop	PSB
PP 23	Dry powder 6.8 kg	Maintenance work shop	PSB
PP 18	Dry powder 6.8 kg	Maintenance work shop	PSB
PP 19	Dry powder 6.8 kg	Maintenance work shop	PSB
PP 20	Dry powder 6.8 kg	Maintenance work shop	PSB
PC 08	CO2 4.5 kg	Canteen	PSB
MF 01	Foam 10 LTR	Security box 3	PSB
AP 01	Dry powder 6.8 kg	PSB warehouse#1-office	PSB W/001
AC 01	CO2 4.5 kg	PSB warehouse#1-office	PSB W/001
AP 02	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W/001
AP 03	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W/001
AP 04	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W/001
AP 05	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W/001
AP 06	Dry powder 6.8 kg	Inside warehouse#1(East)	PSB W/001
AP 07	Dry powder 6.8 kg	Inside PSB warehouse#1(East)	PSB W/001
AP 08	Dry powder 6.8 kg	Inside PSB warehouse#1(East)	PSB W/001
AP 09	Dry powder 6.8 kg	Inside PSB warehouse#1(East)	PSB W/001
AP 10	Dry powder 6.8 kg	PSB warehouse#1-infront off cool room	PSB W/001
AC 02	CO2 4.5 kg	Inside PSB warehouse#1(N)	PSB W/001
AP 11	Dry powder 6.8 kg	Inside PSB W/H#1-roof shade	PSB W/001
AP 12	Dry powder 6.8 kg	Inside PSB W/H#1-roof shade	PSB W/001
AP 13	Dry powder 6.8 kg	PSB-waste transit	PSB W/001
AP 14	Dry powder 6.8 kg	PSB-waste transit	PSB W/001

PTTEP PSB EXTINGUISHER MAINTENANCE SHEET YEARLY PSB SONGKHLA SAFETY SERVICE DATE: 09/11/24 PAGE 3 OF 6

WORK DETAILS FOR EACH UNIT:

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL

D. TURN UP SIDE DOWN TO DECOMPACT POWDER. HIT SIDE CAREFULLY AGAINST METAL SURFACE TO ASSIST (P).

E. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD

F. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

G. WHEN CO2 TO SEE IF IT STILL WORKS NORMALLY OR NOT every 6 month

WAGON CO2 ที่ต้องดูให้แน่ใจว่าไม่หมดสภาพใช้ไม่ได้ 3 ข้างรถบรรทุก

ID No.	TYPE	LOCATION	DEPARTMENT
AP 15	Dry powder 6.8 kg	Infront off chemical room	PSB W/001
AP 16	Dry powder 6.8 kg	Chemical room	PSB W/001
AP 17	Dry powder 6.8 kg	Chemical room	PSB W/001
AC 03	CO2 4.5 kg	Electrical room	PSB W/001
AP 18	Dry powder 6.8 kg	Plant store	PSB W/001
AF 01	Foam 9 Liter	Plant store	PSB W/001
AF 02	Foam 9 Liter	Chemical room	PSB W/001
AP 19	Dry powder 6.8 kg	Inside Warehouse (W)	PSB W/004
AP 20	Dry powder 6.8 kg	Inside Warehouse Mezzanine Deck/E	PSB W/004
AP 21	Dry powder 6.8 kg	Inside Warehouse(S)	PSB W/004
AP 22	Dry powder 6.8 kg	Office Warehouse(E)	PSB W/004
AP 23	Dry powder 6.8 kg	Inside Warehouse(E)	PSB W/004
AP 24	Dry powder 6.8 kg	Inside Warehouse(N)	PSB W/004
AP 25	Dry powder 6.8 kg	Warehouse(S)	PSB W/004
AP 26	Dry powder 6.8 kg	Inside Warehouse	PSB W/004
AP 27	Dry powder 6.8 kg	Office Warehouse(E)	PSB W/004
AP 28	Dry powder 6.8 kg	PSB Warehouse#1 - Cool Room	PSB W/004
AP 29	Dry powder 6.8 kg	PSB Warehouse#1 - Cool Room	PSB W/004
AP 30	Dry powder 6.8 kg	PSB Warehouse#1 - Electrical Room	PSB W/004
AC 04	CO2 4.5 kg	Office Warehouse(E)	PSB W/004
AC 05	CO2 4.5 kg	PSB Warehouse#1 - Cool Room	PSB W/004
AC 06	CO2 4.5 kg	PSB Warehouse#1 - Cool Room	PSB W/004
AC 07	CO2 4.5 kg	PSB Warehouse#1 - Electrical Room	PSB W/004
AC 08	CO2 4.5 kg	PSB Warehouse#1 - Forklift battery charger	PSB W/004
BP 01	Dry powder 6.8 kg	Security box 8	PSB W/006
BP 02	Dry powder 6.8 kg	Infront off generator room WH	PSB W/006
BC 01	CO2 4.5 kg	Infront off generator room WH	PSB W/006
BP 03	Dry powder 6.8 kg	Inside Warehouse (N)	PSB W/006
BP 04	Dry powder 6.8 kg	Inside Warehouse (E)	PSB W/006
BP 05	Dry powder 6.8 kg	Infront off Warehouse	PSB W/006
BP 06	Dry powder 6.8 kg	Infront off pipe room office (N)	PSB W/006
BP 07	Dry powder 6.8 kg	Infront off pipe room office (E)	PSB W/006
BP 08	Dry powder 6.8 kg	Infront off Warehouse	PSB W/006
BP 09	Dry powder 6.8 kg	Infront off Warehouse (Door 2)	PSB W/006
BP 10	Dry powder 6.8 kg	Inside Warehouse (Door 2)	PSB W/006
BP 11	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 12	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 13	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 14	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 15	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 16	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 17	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 18	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 19	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 20	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 21	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 22	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 23	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 24	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 25	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 26	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 27	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 28	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 29	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 30	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 31	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 32	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 33	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 34	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 35	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 36	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 37	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 38	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 39	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 40	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 41	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 42	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 43	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 44	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 45	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 46	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 47	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 48	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 49	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 50	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 51	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 52	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 53	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 54	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 55	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 56	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 57	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 58	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 59	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 60	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 61	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 62	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 63	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 64	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 65	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 66	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 67	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 68	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 69	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 70	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 71	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 72	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 73	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 74	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 75	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 76	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 77	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 78	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 79	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 80	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 81	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 82	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 83	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 84	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 85	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 86	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 87	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 88	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 89	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 90	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 91	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 92	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 93	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 94	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 95	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 96	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 97	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 98	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 99	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006
BP 100	Dry powder 6.8 kg	Infront off Warehouse (E)	PSB W/006

PTTEP PSB EXTINGUISHER MAINTENANCE SHEET YEARLY PSB SONGKHLA SAFETY SERVICE DATE: 09/11/24 PAGE 4 OF 6

WORK DETAILS FOR EACH UNIT:

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL

D. TURN UP SIDE DOWN TO DECOMPACT POWDER. HIT SIDE CAREFULLY AGAINST METAL SURFACE TO ASSIST (P).

E. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD

F. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

G. WHEN CO2 TO SEE IF IT STILL WORKS NORMALLY OR NOT every 6 month

WAGON CO2 ที่ต้องดูให้แน่ใจว่าไม่หมดสภาพใช้ไม่ได้ 3 ข้างรถบรรทุก

ID No.	TYPE	LOCATION	DEPARTMENT
BP 15	Dry powder 6.8 kg	Zone M 1st floor	PSB W/006
BP 16	Dry powder 6.8 kg	Zone M 1st floor	PSB W/006
BP 17	Dry powder 6.8 kg	Zone M 1st floor	PSB W/006
BP 18	Dry powder 6.8 kg	Zone M 1st floor	PSB W/006
BP 19	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 20	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 21	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 22	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 23	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 24	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 25	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 26	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 27	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 28	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 29	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 30	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 31	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 32	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 33	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 34	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 35	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 36	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 37	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 38	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 39	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 40	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 41	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 42	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 43	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 44	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 45	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 46	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 47	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 48	Dry powder 6.8 kg	Zone M 2nd floor	PSB W/006
BP 49	Dry powder 6.8 kg	Zone M	

EXTINGUISHER

MAINTENANCE SHEET

YEARLY

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT

LOCATION: PSB

DATE: 09/01/24

PAGE 5 OF 6

WORK DETAILS FOR EACH UNIT

THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED

ถังดับเพลิงสามารถมองเห็นได้และไม่เป็นอุปสรรค

THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE OR CLOGGED NOZZLE)

สลักกุญแจล็อกไม่เสียหายและซีลลิ้นชักไม่แตก (ไม่มีการเสียหาย รั่วซึม หรืออุดตันหัวฉีด)

INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL

ตัวบ่งชี้สถานะของถังอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่าถังยังเต็มอยู่

TURN UP SIDE DOWN TO DECOMPACT POWDER. HIT SIDE CAREFULLY AGAINST METAL SURFACE TO ASSIST (P.)

พลิกถังขึ้นด้านข้างลงเพื่ออัดผงดับเพลิง. ใช้นิ้วข้างข้างอย่างระมัดระวังกับพื้นผิวโลหะเพื่อช่วย (P.)

THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD

คำแนะนำการใช้งานบนป้ายชื่อถังอ่านได้และหันออกด้านนอก

A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

ช่างซ่อมถังดับเพลิงที่ได้รับอนุญาตต้องตรวจสอบถังดับเพลิง

W/DOH C-2 TO SEE IF IT STILL WORKS NORMALLY OR NOT EVERY 6 MONTH

ช่างซ่อมถังดับเพลิงต้องตรวจสอบว่าถังยังทำงานได้ตามปกติหรือไม่ ทุกๆ 6 เดือน

A	B	C	D	E	F	G	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓	✓	✓		EP 05	Dry powder 6.8 kg	EMH1-2nd floor	EMH 1
✓	✓	✓	✓	✓	✓	✓		EP 06	Dry powder 6.8 kg	EMH1-Container office	EMH 1
✓	✓	✓	✓	✓	✓	✓		EP 07	Dry powder 6.8 kg	EMH2-1st floor (S/E)	EMH 2
✓	✓	✓	✓	✓	✓	✓		EP 08	Dry powder 6.8 kg	EMH2-1st floor (N/W)	EMH 2
✓	✓	✓	✓	✓	✓	✓		EC 01	C-2 4.54 kg	EMH2-1st floor (S/W)	EMH 2
✓	✓	✓	✓	✓	✓	✓		EP 09	Dry powder 6.8 kg	EMH2 2nd floor (O)	EMH 2
✓	✓	✓	✓	✓	✓	✓		EP 10	Dry powder 6.8 kg	EMH2 2nd floor (S)	EMH 2
✓	✓	✓	✓	✓	✓	✓		EC 02	C-2 4.54 kg	EMH2-2nd floor inside room	EMH 2
✓	✓	✓	✓	✓	✓	✓		EP 11	Dry powder 6.8 kg	Well service office 2nd floor	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 12	Dry powder 6.8 kg	1st floor labview off Meeting room	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 13	Dry powder 6.8 kg	1st floor labview off Cool room	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 14	Dry powder 6.8 kg	Container office	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 15	Dry powder 6.8 kg	Roof shade tent	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 16	Dry powder 6.8 kg	Stone room and yard	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 17	Dry powder 6.8 kg	Stone room and yard	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 18	Dry powder 6.8 kg	Stone room and yard	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 19	Dry powder 6.8 kg	Work shop (N-E)	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 20	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EC 03	C-2 4.54 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 21	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓	✓	✓		EP 22	Dry powder 6.8 kg	EMI W540 workshop - NW	EMI W540
✓	✓	✓	✓	✓	✓	✓		EP 23	Dry powder 6.8 kg	EMI W540 workshop - SW	EMI W540
✓	✓	✓	✓	✓	✓	✓		EP 24	Dry powder 6.8 kg	EMI W540 workshop - SE	EMI W540
✓	✓	✓	✓	✓	✓	✓		EP 25	Dry powder 6.8 kg	EMI W540 workshop - NE	EMI W540
✓	✓	✓	✓	✓	✓	✓		EP 26	Dry powder 6.8 kg	EMI W540 Warehouse - E	EMI W540
✓	✓	✓	✓	✓	✓	✓		EP 27	Dry powder 6.8 kg	EMI W540 Warehouse - W	EMI W540
✓	✓	✓	✓	✓	✓	✓		EP 28	Dry powder 6.8 kg	EMI W540 Office floor#1 - E	EMI W540
✓	✓	✓	✓	✓	✓	✓		EP 29	Dry powder 6.8 kg	EMI W540 Office floor#1 - W	EMI W540
✓	✓	✓	✓	✓	✓	✓		EC 04	C-2 4.54 kg	EMI W540 Warehouse - W/Electrical room	EMI W540
✓	✓	✓	✓	✓	✓	✓		EC 05	C-2 4.54 kg	EMI W540 Warehouse - W/Electrical room	EMI W540
✓	✓	✓	✓	✓	✓	✓		CP 01	Dry powder 6.8 kg	Cyroc waste house (N-E)	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 02	Dry powder 6.8 kg	Cyroc waste house (S-E)	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 03	Dry powder 6.8 kg	Cyroc waste house (S-W)	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 04	Dry powder 6.8 kg	Cyroc waste house (N-W)	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 05	Dry powder 6.8 kg	Cyroc roof shade	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 06	Dry powder 6.8 kg	Cyroc roof shade	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 07	Dry powder 6.8 kg	Influent off cool room	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 08	Dry powder 6.8 kg	Influent off cool room	CP0C
✓	✓	✓	✓	✓	✓	✓		CP 09	Dry powder 6.8 kg	Container office	CP0C

REMARKS

LEADER: PM Team

EXTINGUISHER

MAINTENANCE SHEET

YEARLY

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT

LOCATION: PSB

DATE: 09/01/24

PAGE 6 OF 6

WORK DETAILS FOR EACH UNIT

THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED

ถังดับเพลิงสามารถมองเห็นได้และไม่เป็นอุปสรรค

THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE OR CLOGGED NOZZLE)

สลักกุญแจล็อกไม่เสียหายและซีลลิ้นชักไม่แตก (ไม่มีการเสียหาย รั่วซึม หรืออุดตันหัวฉีด)

INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL

ตัวบ่งชี้สถานะของถังอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่าถังยังเต็มอยู่

TURN UP SIDE DOWN TO DECOMPACT POWDER. HIT SIDE CAREFULLY AGAINST METAL SURFACE TO ASSIST (P.)

พลิกถังขึ้นด้านข้างลงเพื่ออัดผงดับเพลิง. ใช้นิ้วข้างข้างอย่างระมัดระวังกับพื้นผิวโลหะเพื่อช่วย (P.)

THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD

คำแนะนำการใช้งานบนป้ายชื่อถังอ่านได้และหันออกด้านนอก

A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

ช่างซ่อมถังดับเพลิงที่ได้รับอนุญาตต้องตรวจสอบถังดับเพลิง

W/DOH C-2 TO SEE IF IT STILL WORKS NORMALLY OR NOT EVERY 6 MONTH

ช่างซ่อมถังดับเพลิงต้องตรวจสอบว่าถังยังทำงานได้ตามปกติหรือไม่ ทุกๆ 6 เดือน

A	B	C	D	E	F	G	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓	✓	✓		CP 10	Dry powder 6.8 kg	Container office	CP0C
✓	✓	✓	✓	✓	✓	✓		LP 127	Dry powder 6.8 kg	COOL ROOM	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 128	Dry powder 6.8 kg	COOL ROOM	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 129	Dry powder 6.8 kg	WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 05	Dry powder 6.8 kg	WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 131	Dry powder 6.8 kg	WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 54	Dry powder 6.8 kg	WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 130	Dry powder 6.8 kg	WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 133	Dry powder 6.8 kg	WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 136	Dry powder 6.8 kg	WARE HOUSE/CHEMICAL ROOM	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 137	Dry powder 6.8 kg	WARE HOUSE/CHEMICAL ROOM	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LF 08	Form 9 LTR	CHEMICAL ROOM	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 147	Dry powder 6.8 kg	SECURITY YARD 1	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 05	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 06	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 07	Dry powder 6.8 kg	CUSTOMS OFFICE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 32	Dry powder 6.8 kg	PSB-W540 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 35	Dry powder 6.8 kg	PSB-W540 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 146	Dry powder 6.8 kg	IN FRONT OF ROOF SHADE	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 80	Dry powder 6.8 kg	SECURITY BOX No.9	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LC 01	C-2 4.54 kg	INSIDE CONTAINER	FREE ZONE CONT
✓	✓	✓	✓	✓	✓	✓		LF 09	Form 9 LTR	CHEMICAL ROOM	FREE ZONE
✓	✓	✓	✓	✓	✓	✓		LP 45	Dry powder 6.8 kg	TERMINAL CHECK IN / WEST	TERMINAL
✓	✓	✓	✓	✓	✓	✓		LP 46	Dry powder 6.8 kg	TERMINAL CHECK IN / EAST	TERMINAL
✓	✓	✓	✓	✓	✓	✓		AP 27	Dry powder 6.8 kg	PSB Warehouse-SW	PSB Warehouse
✓	✓	✓	✓	✓	✓	✓		AP 28	Dry powder 6.8 kg	PSB Warehouse-SW	PSB Warehouse
✓	✓	✓	✓	✓	✓	✓		AP 29	Dry powder 6.8 kg	PSB Warehouse-SW	PSB Warehouse
✓	✓	✓	✓	✓	✓	✓		AP 30	Dry powder 6.8 kg	PSB Warehouse-SW	PSB Warehouse

REMARKS

LEADER: PM Team

FIRE MAN BOX

MAINTENANCE SHEET

YEARLY

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT

LOCATION: PSB

DATE: 09/01/24

PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

CHECK FIRE SUIT, FIRE HELMET, BOOTS, GLOVES & OTHER EQUIPMENT AVAILABLE

ตรวจสอบชุดดับเพลิง, หมวกกันน็อก, รองเท้าบูต, ถุงมือและอุปกรณ์อื่น ๆ

SECURING STRAP, DOOR PACKING AND LOCK FUNCTIONS IN A GOOD CONDITION

สายรัด, ฟองน้ำประตูและฟังก์ชันการล็อกอยู่ในสภาพที่ดี

CLEAN & READY TO USE

ทำความสะอาดและพร้อมใช้งาน

A	B	C	REMARKS	LOCATION
✓	✓	✓	✓ FIRE SUIT - 4 Pcs. ✓ FIRE HELMET - 4 Pcs. ✓ BOOTS - 4 Pcs.	JETTY
✓	✓	✓	✓ GLOVES - 4 Pcs. ✓ FOAM INJECTION - 1 Pcs. ✓ V-VALVE - 1 Pcs.	JETTY
✓	✓	✓	✓ FIRE SUIT - 4 Pcs. ✓ FIRE HELMET - 4 Pcs. ✓ BOOTS - 4 Pcs.	FIRE SERVICE WORKSHOP
✓	✓	✓	✓ GLOVES - 4 Pcs.	FIRE SERVICE WORKSHOP
✓	✓	✓	✓ FIRE SUIT - 4 Pcs. ✓ FIRE HELMET - 4 Pcs. ✓ BOOTS - 4 Pcs.	BEHIND PSB BUILDING-A
✓	✓	✓	✓ GLOVES - 4 Pcs.	BEHIND PSB BUILDING-A

REMARKS

LEADER: PM Team

LIFEBOUY

MAINTENANCE SHEET

YEARLY

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT

LOCATION: PSB

DATE: 09/01/24

PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

LIFEBOUY IS ACCESSIBLE & EASILY REMOVED FOR USE

ห่วงชูชีพสามารถเข้าถึงได้ง่ายและถอดออกเพื่อใช้งานได้

VISUALLY INSPECT THE LIFEBOUY FOR DAMAGE

ตรวจสอบห่วงชูชีพเพื่อหาความเสียหาย

LIFEBOUY IS SEALED WITH A PLUG

ห่วงชูชีพถูกปิดผนึกด้วยตะกั่ว

THE GRAB LINE AROUND THE CIRCUMFERENCE IS NOT DAMAGED

สายรัดรอบ ๆ ขอบไม่มีความเสียหาย



REPLACE PAINTER LINE AND REFLEXIVE TAPE IF POOR CONDITION

เปลี่ยนริ้วสี และแถบสะท้อนแสง เมื่อมีสภาพไม่ดี

A	B	C	D	E	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓		LBV-1	JETTY NE
✓	✓	✓	✓	✓		LBV-2	JETTY BERTH - 1
✓	✓	✓	✓	✓		LBV-3	JETTY BERTH - 2
✓	✓	✓	✓	✓		LBV-4	JETTY BERTH - 3
✓	✓	✓	✓	✓		LBV-5	JETTY BERTH - 4
✓	✓	✓	✓	✓		LBV-6	JETTY BERTH - 5
✓	✓	✓	✓	✓		LBV-7	JETTY BERTH - 6
✓	✓	✓	✓	✓		LBV-8	JETTY S/W
✓	✓	✓	✓	✓		LBV-9	JETTY N/W
✓	✓	✓	✓	✓		LBV-10	JETTY BOAT
✓	✓	✓	✓	✓		LBV-11	JETTY BOAT

REMARKS

LEADER: PM Team

 PTTEP PSB	SAFETY SHOWER MAINTENANCE SHEET YEARLY	PSB SONGKHLA  SAFETY SERVICE
OPERATION UNIT	LOCATION : PSB	DATE: 29/1/24
		PAGE 1 OF 1


WORK DETAILS FOR EACH UNIT

A. EASILY LOCATED & ACCESSIBLE ACTUATOR
 ติดตั้งให้มองเห็นและเข้าถึงได้ง่าย

B. GOOD CENTER OF WATER PATTERN
 จุดศูนย์กลางน้ำที่พ่นออกมา

C. COVERS ARE REMOVED BY WATER FLOW
 ที่ครอบบนชุดน้ำจะหลุดออกโดยน้ำที่ไหล

D. VALVE ACTUATOR IS EASY TO LOCATE
 ตัวลิ้นวาล์วจะง่ายต่อการมองเห็น



A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		CHEMICAL ROOM PSB W/SH2
✓	✓	✓	✓		WASTE AREA BONGKOT
✓	✓	✓	✓		CHEMICAL ROOM PSB W/SH6 (BK7)
✓	✓	✓	✓		FREE ZONE
✓	✓	✓	✓		CPOC ROOF SHEDS

REMARKS _____

LEADER PM Jeam.

 PTSP PSB	TORCH MAINTENANCE SHEET YEARLY	PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1
OPERATION UNIT	LOCATION : PSB	DATE: 30/11/24

WORK DETAILS FOR EACH UNIT

CHECK FUNTIONS AND CONDITIONS OF TORCH

A. ตรวจตอนที่ยังขึ้นและเงื่อนไขของไฟฉาย
CHECK THE BRIGHTNESS OF THE LIGHT

B. ตรวจตอนความสว่างของแสง
WALL BRACKET SECURE FOR USING

C. กรณียึดที่ปลอดภัยสำหรับการใช้งาน
ABLE TO BE USED OR OBTAINED

D. สามารถนำมาใช้หรือการใช้งานได้อย่างดี
APPLY INSPECTION STICKER AND RECORD ON TASK SHEET



E. ใช้ติดก๊อรัตรวจตอนและบันทึกบนแผ่นงาน







A	B	C	D	E	REMARKS	LOCATION
✓	✓	✓	✓	✓		PSB WH#6 - Cool room C1(BKT)
✓	✓	✓	✓	✓		PSB WH#6 - Cool room C2 (BKT)
✓	✓	✓	✓	✓		PSB WH#6 - Cool room AB 1 in (BKT)
✓	✓	✓	✓	✓		PSB WH#6 - Cool room AB 2 in(BKT)
✓	✓	✓	✓	✓		PSB WH#6 - Inside door2 (BKT)
✓	✓	✓	✓	✓		PSB BUILDING-A/ELECTRICAL ROOM
✓	✓	✓	✓	✓		PSB BUILDING-A GENERATOR ROOM
✓	✓	✓	✓	✓		FREE ZONE COOL ROOM
✓	✓	✓	✓	✓		PSB WH#6 COOL ROOM
✓	✓	✓	✓	✓		SH#1 FLOOR 1st
✓	✓	✓	✓	✓		SH#1 FLOOR 2nd
✓	✓	✓	✓	✓		WELL SERVICE OFFICE/FLOOR 2 nd
✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP
✓	✓	✓	✓	✓		CPOC WH
✓	✓	✓	✓	✓		CPOC COOL ROOM



REMARKS _____



LEADER: 

		FIRE ALARM MAINTENANCE SHEET YEARLY		PSB SONGKHLA  SAFETY SERVICE	
OPERATION UNIT	LOCATION : PSB	DATE : 29/11/24	PAGE 1 OF 4		
WORK DETAILS FOR EACH UNIT					
A. GOOD ALARM SENSOR MODE เช็กการทำงานของเครื่องแจ้งเตือน CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบสภาพตัวอุปกรณ์ กระดาษรีด หรือแตก CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	A101	PSB BUILDING-A / 1ST FLOOR SHEYRON OFFICE
✓	✓	✓	✓	A102	PSB BUILDING-A / 1ST FLOOR WEST DOOR
✓	✓	✓	✓	A103	PSB BUILDING-A / 1ST FLOOR MEDIC ROOM
✓	✓	✓	✓	A104	PSB BUILDING-A / SECURITY BOX-4
✓	✓	✓	✓	A105	PSB BUILDING-A / 2nd FLOOR AT STAIR
✓	✓	✓	✓	A106	PSB BUILDING-A / 2nd FLOOR CPOC OFFICE
✓	✓	✓	✓	A107	PSB BUILDING-A 2nd FLOOR EMERGENCY DOOR
✓	✓	✓	✓	A108	PSB BUILDING-A 3th FLOOR AT STAIR
✓	✓	✓	✓	A109	PSB BUILDING-A / 3th FLOOR RADIO ROOM
✓	✓	✓	✓	A111	PSB BUILDING-A / 3th FLOOR ROOM 304
✓	✓	✓	✓	A112	PSB BUILDING-A / 3th FLOOR ROOM 310
✓	✓	✓	✓	A113	PSB BUILDING-A / IN SIDE ELECTRICAL ROOM
✓	✓	✓	✓	N0.01	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.02	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.03	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.04	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.05	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.06	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.07	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.08	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.09	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.10	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.11	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.12	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.13	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.14	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.15	PSB BUILDING-B / 3-4 FLOOR
✓	✓	✓	✓	J101	IN SIDE JETTY ELECTRICAL ROOM
✓	✓	✓	✓	J102	JETTY BERTH 1
✓	✓	✓	✓	J103	JETTY BERTH 2
✓	✓	✓	✓	J104	JETTY BERTH 6
✓	✓	✓	✓	J105	JETTY BULK TANK 1

		FIRE ALARM MAINTENANCE SHEET YEARLY		PSB SONGKHLA  SAFETY SERVICE	
OPERATION UNIT	LOCATION : PSB	DATE : 29/11/24	PAGE 2 OF 4		
WORK DETAILS FOR EACH UNIT					
A. GOOD ALARM SENSOR MODE เช็กการทำงานของเครื่องแจ้งเตือน CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบสภาพตัวอุปกรณ์ กระดาษรีด หรือแตก CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	J106	JETTY BULK TANK 2
✓	✓	✓	✓	J107	JETTY OFFICE
✓	✓	✓	✓	J108	SECURITY BOX 6 JETTY
✓	✓	✓	✓	B119	CREW CHANGE AREA
✓	✓	✓	✓	ST-01	SPECIAL TOOL S-E
✓	✓	✓	✓	ST-02	SPECIAL TOOL S-E
✓	✓	✓	✓	ST-03	SPECIAL TOOL S-W
✓	✓	✓	✓	B120	WASTE AREA ROW 8
✓	✓	✓	✓	B121	WASTE AREA ROW 20
✓	✓	✓	✓	B122	TERMINAT CHECK-IN West
✓	✓	✓	✓	B123	TERMINAT CHECK-IN South
✓	✓	✓	✓	B109	PSB WHM6-COOM ROOM CA-B
✓	✓	✓	✓	B108	PSB WHM6-COOM ROOM CE
✓	✓	✓	✓	B111	INFRONT OF PSB WHM6-N
✓	✓	✓	✓	B107	INFRONT OF PSB WHM6-W
✓	✓	✓	✓	B110	Inside PSB WHM6-West
✓	✓	✓	✓	B112	PSB WAREHOUSE#6-B32
✓	✓	✓	✓	B106	PSB WHM6-STOCK CONTROL-S/E
✓	✓	✓	✓	B103	PSB WHM6-CHEMICAL ROOM
✓	✓	✓	✓	B104	PSB WHM6-PAINTING STORAGE
✓	✓	✓	✓	B117	PSB WHM6-OFFICE
✓	✓	✓	✓	B116	PSB WHM6-OFFICE
✓	✓	✓	✓	B115	PSB WHM6-OFFICE
✓	✓	✓	✓	B113	WAREHOUSE#1 - B 33
✓	✓	✓	✓	B114	WAREHOUSE#1 - B 33
✓	✓	✓	✓	B101	PSB WHM6-GBS WORKSHOP
✓	✓	✓	✓	B103	PSB WHM6-GBN WORKSHOP
✓	✓	✓	✓	B102	PSB WHM6-GBN WORKSHOP
✓	✓	✓	✓	F103	FREE ZONE COOL ROOM
✓	✓	✓	✓	F104	FREE ZONE COOL ROOM
✓	✓	✓	✓	F105	FREE ZONE WH STAIR
✓	✓	✓	✓	F106	FREE ZONE WH WEST
✓	✓	✓	✓	F107	FREE ZONE WH S/W

		FIRE ALARM MAINTENANCE SHEET YEARLY		PSB SONGKHLA  SAFETY SERVICE	
OPERATION UNIT	LOCATION : PSB	DATE : 29/11/24	PAGE 3 OF 4		
WORK DETAILS FOR EACH UNIT					
A. GOOD ALARM SENSOR MODE เช็กการทำงานของเครื่องแจ้งเตือน CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบสภาพตัวอุปกรณ์ กระดาษรีด หรือแตก CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	F108	FREE ZONE WH SE
✓	✓	✓	✓	F101	FREE ZONE CHEMICAL
✓	✓	✓	✓	F102	FREE ZONE CHEMICAL
✓	✓	✓	✓	F109	FREE ZONE NEW WH
✓	✓	✓	✓	J101	EMI WORKSHOP#1 / N
✓	✓	✓	✓	J102	EMI WORKSHOP#1 / NW
✓	✓	✓	✓	J103	EMI WORKSHOP#1 / SW
✓	✓	✓	✓	J104	EMI WORKSHOP#1 / SW
✓	✓	✓	✓	E101	EMI WORKSHOP#2 / STAIRS
✓	✓	✓	✓	E102	EMI WORKSHOP#2 / STAIRS
✓	✓	✓	✓	E103	EMI WORKSHOP#2 / STAIRS
✓	✓	✓	✓	E104	EMI WORKSHOP#2 / STAIRS
✓	✓	✓	✓	E105	EMI WORKSHOP#2 DOORS
✓	✓	✓	✓	E106	EMI WORKSHOP#2 DOORS
✓	✓	✓	✓	E107	EMI WORKSHOP#2 LEVEL2
✓	✓	✓	✓	E108	EMI WORKSHOP#2 LEVEL2
✓	✓	✓	✓	E109	EMI WORKSHOP - NW
✓	✓	✓	✓	E110	EMI WORKSHOP - SW
✓	✓	✓	✓	E111	EMI WORKSHOP - NE
✓	✓	✓	✓	E112	EMI Warehouse - E
✓	✓	✓	✓	E113	EMI Warehouse - W
✓	✓	✓	✓	E114	EMI Office floor1 - E
✓	✓	✓	✓	E115	EMI Office floor1 - W
✓	✓	✓	✓	E116	EMI Office floor2 - E
✓	✓	✓	✓	E117	EMI Office floor2 - W
✓	✓	✓	✓	H101	WELL SERVICE OFFICE LEVEL 1
✓	✓	✓	✓	H102	WELL SERVICE OFFICE LEVEL 2
✓	✓	✓	✓	H103	WELL SERVICE WORKSHOP
✓	✓	✓	✓	H104	WELL SERVICE WORKSHOP
✓	✓	✓	✓	C101	CPOC WH
✓	✓	✓	✓	C102	CPOC WH
✓	✓	✓	✓	C103	CPOC WH
✓	✓	✓	✓	C104	CPOC WH
✓	✓	✓	✓	C105	CPOC COOL ROOM
✓	✓	✓	✓	C106	CPOC COOL ROOM

		FIRE ALARM MAINTENANCE SHEET YEARLY		PSB SONGKHLA  SAFETY SERVICE	
OPERATION UNIT	LOCATION : PSB	DATE : 29/11/24	PAGE 4 OF 4		
WORK DETAILS FOR EACH UNIT					
A. GOOD ALARM SENSOR MODE เช็กการทำงานของเครื่องแจ้งเตือน CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบสภาพตัวอุปกรณ์ กระดาษรีด หรือแตก CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	F001	PSB FIRE SERVICE WORKSHOP
✓	✓	✓	✓	M01	PSB WHM1 OFFICE N
✓	✓	✓	✓	M02	PSB WHM1 OFFICE SE
✓	✓	✓	✓	M03	PSB WHM1 WH COOL ROOM S
✓	✓	✓	✓	M04	PSB WHM1 CHEMICAL ROOM W/N
✓	✓	✓	✓	M05	PSB WHM1 CHEMICAL ROOM S
✓	✓	✓	✓	M 06	PSB CHEMICAL WASTE TRANSIT
✓	✓	✓	✓	M07	PSB CHEMICAL WASTE TRANSIT
✓	✓	✓	✓	M08	PSB GAS STORE SW
✓	✓	✓	✓	M-10	PSB WHM1
✓	✓	✓	✓	M-11	PSB WHM1
✓	✓	✓	✓	MA4-01	PSB WHM4
✓	✓	✓	✓	MA4-02	PSB WHM4
✓	✓	✓	✓	MA4-03	PSB WHM4
✓	✓	✓	✓	MA4-04	PSB WHM4
✓	✓	✓	✓	MA4-05	PSB WHM4
✓	✓	✓	✓	MA4-06	PSB WHM4
✓	✓	✓	✓	MA4-07	PSB WHM4
✓	✓	✓	✓	MA5-01	PSB WHM5
✓	✓	✓	✓	MA5-02	PSB WHM5
✓	✓	✓	✓	MA5-03	PSB WHM5
✓	✓	✓	✓	MA5-04	PSB WHM5
✓	✓	✓	✓	S-01	SERVICE MAINTENANCE WORKSHOP
REMARKS:					
LEADER <i>Ph Jarm</i>					

 PTTEP PSB OPERATION UNIT	EMERGENCY PHONE MAINTENANCE SHEET YEARLY LOCATION : PSB DATE : 25/11/24	PSB SONGKHLA  SAFETY SERVICE
		PAGE 1 OF 1


WORK DETAILS FOR EACH UNIT

A. PHONE ACCESSIBLE
การเข้าถึงโทรศัพท์

B. EMERGENCY PHONE NUMBERS AND PROCEDURES POSTED AT OR NEAR TELEPHONE
หมายเลขโทรศัพท์ที่ฉุกเฉินและวิธีการติดต่อที่ใกล้โทรศัพท์

C. SAFETY BOARD DISPLAYING EMERGENCY PHONE NUMBER
ป้ายแสดงจำนวนเบอร์โทรศัพท์ฉุกเฉิน

D. FUNCTIONALITY SUITABLE
ฟังก์ชันที่เหมาะสม



A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		FREE ZONE
✓	✓	✓	✓		CREW CHANGE AREA
✓	✓	✓	✓		JETTY
✓	✓	✓	✓		PSB WH#6-MUSTER POINT
✓	✓	✓	✓		EMI MUSTER POINT

REMARKS

LEADER *PH Jeany*

 PTTEP PSB OPERATION UNIT	FIRE HOSE TROLLEY MAINTENANCE SHEET YEARLY LOCATION : PSB DATE : 25/11/24	PSB SONGKHLA  SAFETY SERVICE
		PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. All equipment complete as specified
อุปกรณ์ครบตามที่ระบุไว้

B. All equipment is in working condition. All equipment is in working condition.
ทุกอย่างเป็นสภาพพร้อมใช้งาน

C. NON-OBSTRUCTED
ไม่กีดขวาง

D. The Trolley is in good working condition, easy to move.
รถเข็นเป็นสภาพพร้อมใช้งาน เคลื่อนย้ายได้สะดวก

E. LUBRICATE AND GREASE COUPLINGS AS NECESSARY
หล่อลื่นและทาสีที่ข้อต่อตามจำเป็น

F. Check for leaks and cracks by holding down the pressure for about 5 minutes.
ตรวจสอบรอยรั่ว รอยแตก โดยการกดความดันไว้ประมาณ 5 นาที



A	B	C	D	E	F	REMARKS	LOCATION
✓	✓	✓	✓	✓	✓	TH SIZE-43 MM - 4 Ft. ✓ FH SIZE-64 MM - 4 Ft. ✓ Y-VALVE-1P. ✓ NOZZLE-2 Ft. ✓ HAND TOOL-1 Ft.	BEHIND OF PSB BUILDING-A
✓	✓	✓	✓	✓	✓	TH SIZE-43 MM - 3 Ft. ✓ FH SIZE-64 MM - 2 Ft. ✓ Y-VALVE-2 Ft. ✓ NOZZLE-2 Ft.	BEHIND SECURITY BOX-2

REMARKS

LEADER *PH Jeany*

 PTTEP PSB OPERATION UNIT	EMERGENCY FIRE EXIT DOOR MAINTENANCE SHEET YEARLY PM LOCATION : PSB DATE : 25/11/24	PSB SONGKHLA  SAFETY SERVICE
		PAGE 1 OF 2

WORK DETAILS FOR EACH UNIT

A. NON OBSTRUCTION
ไม่มีสิ่งกีดขวาง


B. CHECK PAINC HANDLE BY PRESS AND RELEASE THE DOOR HANDLE. TO TEST WHETHER IT WORKS NORMALLY OR NOT / ตรวจสอบโดยการกดและปล่อยมือที่ประตู เพื่อทดสอบว่าทำงานปกติหรือไม่

C. CHECK SELF CLOSING DEVICE-BY OPEN THE DOOR FULLY AND RELEASE YOUR HAND. THE DOOR MUST COMPLETELY CLOSE BY ITSELF.
ตรวจสอบ Self closing device โดยการเปิดประตูให้สุด แล้วปล่อยมือ ประตูต้องปิดโดยอัตโนมัติ

D. CLEAN UP AND LUBRICATE AS NECESSARY
ทำความสะอาดและหล่อลื่นตามความเหมาะสม



A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓		PSB BUILDING-B / Floor#1 North-East
✓	✓	✓	✓		PSB BUILDING-B / Floor#2 East
✓	✓	✓	✓		PSB BUILDING-B / Floor#2 North-East
✓	✓	✓	✓		PSB BUILDING-B / Floor#3 East
✓	✓	✓	✓		PSB BUILDING-B / Floor#3 North-East
✓	✓	✓	✓		PSB BUILDING-A / Floor#1 North
✓	✓	✓	✓		PSB BUILDING-A / Floor#1 North
✓	✓	✓	✓		PSB BUILDING-A / Floor#1 South-West
✓	✓	✓	✓		PSB BUILDING-A / Floor#1 South-West
✓	✓	✓	✓		PSB BUILDING-A / Floor#2 South-West
✓	✓	✓	✓		PSB BUILDING-A / Floor#2 North
✓	✓	✓	✓		PSB BUILDING-A / Floor#3 South-West
✓	✓	✓	✓		PSB BUILDING-A / Floor#3 North
✓	✓	✓	✓		PSB-WH#5 / North-West
✓	✓	✓	✓		PSB-WH#5 / North-East
✓	✓	✓	✓		PSB-WH#5 / South-East
✓	✓	✓	✓		PSB-WH#5 / South-West
✓	✓	✓	✓		CPOC-WH / North-West
✓	✓	✓	✓		CPOC-WH / South-West(M37)
✓	✓	✓	✓		CPOC-WH / South-East
✓	✓	✓	✓		CPOC-WH / North-East
✓	✓	✓	✓		CPOC-WH/Cool Room / South-East
✓	✓	✓	✓		PSB-Chemical Room / North-West
✓	✓	✓	✓		PSB-WH#4 / North-East
✓	✓	✓	✓		PSB-WH#4 / Cool Room / North-East
✓	✓	✓	✓		PSB-WH#1 / North-West
✓	✓	✓	✓		PSB-WH#1 / Cool Room / North-East
✓	✓	✓	✓		EMI-Work shop#1/Floor#1/North
✓	✓	✓	✓		EMI-Work shop#1/Floor#1/South
✓	✓	✓	✓		EMI-Work shop#2/Floor#1/North-West
✓	✓	✓	✓		EMI-Work shop#2/Floor#1/south-West
✓	✓	✓	✓		WELL SERVICE OFFICE/Floor#2/SE
✓	✓	✓	✓		WELL SERVICE OFFICE/Floor#2/E

 PTTEP PSB OPERATION UNIT	EMERGENCY FIRE EXIT DOOR MAINTENANCE SHEET YEARLY PM LOCATION : PSB DATE : 25/11/24	PSB SONGKHLA  SAFETY SERVICE
		PAGE 2 OF 2

WORK DETAILS FOR EACH UNIT

A. NON OBSTRUCTION
ไม่มีสิ่งกีดขวาง

B. CHECK PAINC HANDLE BY PRESS AND RELEASE THE DOOR HANDLE. TO TEST WHETHER IT WORKS NORMALLY OR NOT / ตรวจสอบโดยการกดและปล่อยมือที่ประตู เพื่อทดสอบว่าทำงานปกติหรือไม่

C. CHECK SELF CLOSING DEVICE-BY OPEN THE DOOR FULLY AND RELEASE YOUR HAND. THE DOOR MUST COMPLETELY CLOSE BY ITSELF.
ตรวจสอบ Self closing device โดยการเปิดประตูให้สุด แล้วปล่อยมือ ประตูต้องปิดโดยอัตโนมัติ


D. CLEAN UP AND LUBRICATE AS NECESSARY
ทำความสะอาดและหล่อลื่นตามความเหมาะสม



A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓		WEL SERVICE WORKSHOP / North-West
✓	✓	✓	✓		PSB WH6 / South-East
✓	✓	✓	✓		WH#2(Special Tool) / North-West
✓	✓	✓	✓		PSB FREE ZONE-WH / North-East
✓	✓	✓	✓		PSB FREE ZONE-WH / South-East
✓	✓	✓	✓		PSB FREE ZONE-CHEMICAL ROOM / North-West
✓	✓	✓	✓		PSB FREE ZONE-COOLROOM / North-East
✓	✓	✓	✓		TERMINAL CHECK-IN / North-East
✓	✓	✓	✓		EMI WS#3 Workshop-N
✓	✓	✓	✓		EMI WS#3 Workshop-S
✓	✓	✓	✓		EMI WS#3 Warehouse-NE
✓	✓	✓	✓		EMI WS#3 Warehouse-Electrical room
✓	✓	✓	✓		EMI WS#3 Office floor#1-S
✓	✓	✓	✓		EMI WS#3 Office floor#2-S

Remark:

LEADER *PH Jeany*




PTTEP
PSB

PSB

FIRE FIGHTING EQUIPMENT

MONTHLY CHECK LIST



PSB SSGE

OPERATION UNIT

	ISSUED	RETURN	COMPLETED
1 FIRE HYDRANT	29/08/24	29/08/24	100 %
2 FIRE HOSE REEL	29/08/24	29/08/24	100 %
3 FIRE HOSE	29/08/24	29/08/24	100 %
4 EXTINGUISHER	29/08/24	29/08/24	100 %
5 FIRE MAN EQP.	29/08/24	29/08/24	100 %
6 LIFEBUOY	29/08/24	29/08/24	100 %
7 STRETCHER	29/08/24	29/08/24	100 %
8 SAFETY SHOWER	29/08/24	29/08/24	100 %
9 EYEWASH STATION	29/08/24	29/08/24	100 %
10 TROCH	29/08/24	29/08/24	100 %
11 FIRE ALARM	29/08/24	29/08/24	100 %
12 EMERGENCY PHONE	29/08/24	29/08/24	100 %
13 FIRE HOSE TROLLEY	29/08/24	29/08/24	100 %
TASK COMPLETED			100 %

TIME SPENDING: 16.50 MANHRS

REMARK:

CHECK BY: PM team DATE: 29/08/2024



PTTEP
PSB

FIRE HYDRANT

MAINTENANCE SHEET

MONTHLY

PSB SONGKHLA

SAFETY SERVICE

PAGE 1 OF 1

OPERATION UNIT LOCATION: PSB DATE: 29/08/24

WORK DETAILS FOR EACH UNIT

A. HYDRANTS ARE ACCESSIBLE & FREE OF OBSTRUCTION

B. หัวจ่ายบนชั้นวางของไม่ได้มีสิ่งกีดขวาง

C. TOP OF HYDRANT IS NOT LEAKING WHEN HYDRANT IS ON

D. ด้านบนของหัวจ่ายบนชั้นวางไม่ได้มีสิ่งกีดขวาง

E. RUBBER SEAL UNDER CAPS ARE NOT LEAKING

F. ซีลยางภายใต้ฝาครอบไม่รั่วซึม

G. HYDRANT BARREL IS IN GOOD CONDITION WITHOUT CRACKS OR CORROSION

H. สายหัวจ่ายบนชั้นวางของอยู่ในสภาพที่ดีไม่มีรอยร้าวหรือการกัดกร่อน

I. OUTLET CAPS SECURE

J. ฝาครอบน๊อตอยู่อย่างแน่นหนา

K. CLEAN AND GREASE OF MOVING PARTS


L. ทำความสะอาดและหล่อลื่นชิ้นส่วนที่เคลื่อนที่



A	B	C	D	E	F	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓	✓		HD1	SECURITY BOX2
✓	✓	✓	✓	✓	✓		HD2	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD3	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD4	SECURITY BOX4
✓	✓	✓	✓	✓	✓		HD5	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD6	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD7	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD8	JETTY BERTH1
✓	✓	✓	✓	✓	✓		HD9	JETTY BERTH2
✓	✓	✓	✓	✓	✓		HD10	JETTY BERTH3
✓	✓	✓	✓	✓	✓		HD11	JETTY BERTH4
✓	✓	✓	✓	✓	✓		HD12	JETTY BERTH5
✓	✓	✓	✓	✓	✓		HD13	JETTY BERTH6
✓	✓	✓	✓	✓	✓		HD14	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD15	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD16	PSB BUILDING-B / West
✓	✓	✓	✓	✓	✓		AJHD-01	PSB W/H - 04
✓	✓	✓	✓	✓	✓		FHD-01	FREE ZONE-CHEMICAL ROOM

REMARKS:

LEADER: PM team



PTTEP
PSB

FIRE HOSE REEL

MAINTENANCE SHEET

MONTHLY

PSB SONGKHLA

SAFETY SERVICE

PAGE 1 OF 1

OPERATION UNIT LOCATION: PSB DATE: 29/08/24

WORK DETAILS FOR EACH UNIT

A. THE HOSE REEL IS READILY ACCESSIBLE WITH NO OBSTACLES RESTRICTING ITS ACCESS

B. หัวจ่ายบนชั้นวางของไม่ได้มีสิ่งกีดขวาง

C. ANY DAMAGE OR CORROSION OF THE HOSE REEL (1 = GOOD, 2 = POOR, 3 = BAD, 4 = VERY BAD)

D. ความเสียหายใดๆ หรือการกัดกร่อนของสายหัวจ่าย (1 = ดี, 2 = พอใช้, 3 = ไม่ดี, 4 = ไม่ดีนัก)

E. THE NOZZLE IS RETAINED IN THE NOZZLE INTERLOCK


F. หัวฉีดถูกรักษาไว้ในหัวฉีดล็อก

G. THE HOSE REEL CAN BE UNWOUND FREELY IN ITS INTENDED DIRECTION

H. สายหัวจ่ายสามารถคลายออกในทิศทางที่ต้องการ

I. CLEAN AND GREASE AS NECESSARY

J. ทำความสะอาดและหล่อลื่นชิ้นส่วนที่จำเป็น



A	B	C	D	E	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓		FH10	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH01	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH02	PSB BUILDING-B / OFFICE FLOOR2
✓	✓	✓	✓	✓		FH03	PSB BUILDING-B / OFFICE FLOOR3
✓	✓	✓	✓	✓		FR4	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR5	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR6	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		FR7	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR8	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR9	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		AFR 01	PSB W/H 04
✓	✓	✓	✓	✓		PH-11	FREE ZONE CHEMICAL ROOM

REMARKS:

LEADER: PM team



PTTEP
PSB

FIRE HOSE BOX

MAINTENANCE SHEET

MONTHLY

PSB SONGKHLA

SAFETY SERVICE

PAGE 1 OF 1

OPERATION UNIT LOCATION: PSB DATE: 29/08/24

WORK DETAILS FOR EACH UNIT

A. HOSE BOX IN GOOD CONDITION WITHOUT CRACKS

B. กล่องหัวจ่ายอยู่ในสภาพที่ดีไม่มีรอยร้าว

C. SECURING STRAP & DOOR PACKING IN A GOOD CONDITION

D. สายรัดและประตูบรรจุอยู่ในสภาพที่ดี

E. NOZZLE OF APPROPRIATE SIZE & TYPE

F. หัวฉีดขนาดและประเภทที่เหมาะสม

G. FIRE HOSE OF APPROPRIATE LENGTH

H. สายหัวจ่ายมีความยาวที่เหมาะสม

I. APPROPRIATE SPANNER

J. หัวฉีดที่เหมาะสม

K. HOSE COUPLING IS PROPERLY CONNECTED

L. การเชื่อมต่อสายหัวจ่ายเชื่อมต่ออย่างถูกต้อง

M. NOZZLE IS FREELY MOVING


N. หัวฉีดเคลื่อนที่อย่างอิสระ



A	B	C	D	E	F	G	REMARKS	LOCATION
✓	✓	✓	✓	✓	✓	✓	✓ (FH 38 mm = 1 Pc) ✓ (FH 64 mm = 1 Pc) ✓ NOZZLE = 1 ✓ HAND TOOL = 1	JETTY BERTH - 1 (FH 01)
✓	✓	✓	✓	✓	✓	✓	✓ (FH 38 mm = 1 Pc) ✓ (FH 64 mm = 1 Pc) ✓ NOZZLE = 1 ✓ HAND TOOL = 1	JETTY BERTH - 2 (FH 02)
✓	✓	✓	✓	✓	✓	✓	✓ (FH 38 mm = 1 Pc) ✓ (FH 64 mm = 1 Pc) ✓ NOZZLE = 1 ✓ HAND TOOL = 1	JETTY BERTH - 3 (FH 03)
✓	✓	✓	✓	✓	✓	✓	✓ (FH 38 mm = 1 Pc) ✓ (FH 64 mm = 1 Pc) ✓ NOZZLE = 1 ✓ HAND TOOL = 1	JETTY BERTH - 4 (FH 04)
✓	✓	✓	✓	✓	✓	✓	✓ (FH 38 mm = 1 Pc) ✓ (FH 64 mm = 1 Pc) ✓ NOZZLE = 1 ✓ HAND TOOL = 1	JETTY BERTH - 5 (FH 05)
✓	✓	✓	✓	✓	✓	✓	✓ (FH 38 mm = 1 Pc) ✓ (FH 64 mm = 1 Pc) ✓ NOZZLE = 1 ✓ HAND TOOL = 1	PSB JETTY/HD 07 (FH 03)
✓	✓	✓	✓	✓	✓	✓	✓ NOZZLE-2 ✓ Y-VALVE-1 ✓ HAND TOOL-1	ROUND PSB BUILDING-A


REMARKS:

LEADER: PM team



**EXTINGUISHER
MAINTENANCE SHEET
MONTHLY**

SFS SONGKHLA




SAFETY SERVICE

OPERATION UNIT: **LOCATION: PSB**




DATE: **27/2/24**

WORK DETAILS FOR EACH UNIT

- A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
ถังดับเพลิงสามารถมองเห็นได้โดยไม่มีสิ่งกีดขวาง
- B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
สลักติดล็อกไม่เสียหายและซีลลิ้นชัก (ไม่เสียหาย ไม่กัดกร่อน ไม่รั่วซึม ไม่อุดตันหัวฉีด)
- C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่ใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีน้ำมันเต็ม
- D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำบนป้ายชื่ออ่านได้และหันหน้าออก
- E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
การตรวจสอบโดยช่างเทคนิคดับเพลิงที่ได้รับอนุญาต



A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		PP-01	Dry powder 6.8 kg	Security box 4	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-01	Co2 4.5 kg		
✓	✓	✓	✓	✓		PP-02	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ Room 108	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-02	Co2 4.5 kg	PSB 1st floor/Infant oil medical	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-03	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-04	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-05	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 221	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-06	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 211	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-07	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-08	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ CPDC office	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-09	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-10	Dry powder 6.8 kg	PSB office 3rd fl infanta oil radio room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-11	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-12	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-03	Co2 4.5 kg	PSB office 3rd fl infanta oil radio room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-04	Co2 4.5 kg	PSB office 3rd fl IT room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-07	Co2 4.5 kg	PSB Fire pump	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-14	Dry powder 6.8 kg	Driver corridor	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-15	Dry powder 6.8 kg	Security box 2	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-16	Dry powder 6.8 kg	Security box 3	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-17	Dry powder 6.8 kg	Fire service shop	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-05	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-06	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-01	Press 9 liter	Generators PSB08	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-02	Press 9 liter	Generator room	PSB BUILDING-A
✓	✓	✓	✓	✓		NP-01	Dry powder 6.8 kg	NEW PSB FLOOR1/ ES	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-02	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-03	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-04	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-05	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-06	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-07	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-08	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-09	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-10	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-11	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP12	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B

		EXTINGUISHER MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE					
OPERATION UNIT		LOCATION: PSB		DATE: 29/09/24					
WORK DETAILS FOR EACH UNIT.									
A.	THE EXTINGUISHER IS VISIBLE & UNOBSCTURED เครื่องดับเพลิงสามารถมองเห็นได้และไม่มีการกีดขวาง								
B.	THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE) สลักเกลียวล็อกไม่ได้รับความเสียหาย (ไม่มีการชำรุด, ไม่มีการกัดกร่อน, ไม่มีการรั่วซึม, หรือหัวฉีดอุดตัน)								
C.	INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL ตัวชี้ระดับเชื้อเพลิงอยู่ในตำแหน่งที่สามารถใช้งานได้ และมั่นใจว่าตัวชี้ยังเต็ม								
									
THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD ข้อชี้แจงบนป้ายชื่อเครื่องดับเพลิงสามารถอ่านได้และหันหน้าออก									
E.	A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED อุปกรณ์ดับเพลิงต้องได้รับการตรวจสอบโดยช่างเทคนิคที่มีใบอนุญาต								
A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		NP-13	Dry powder 6.8 kg	NEW PSB FLOORJ	PSB BUILDING-01
✓	✓	✓	✓	✓		NP-14	Dry powder 6.8 kg	NEW PSB FLOORJ	PSB BUILDING-02
✓	✓	✓	✓	✓		JP 01	Dry powder 6.8 kg	Security box 6	JETTY
✓	✓	✓	✓	✓		JP 02	Dry powder 6.8 kg	Fire hose reel box No.1	JETTY
✓	✓	✓	✓	✓		JP 03	Dry powder 6.8 kg	Fire hose reel box No.2	JETTY
✓	✓	✓	✓	✓		JP 04	Dry powder 6.8 kg	Fire hose reel box No.3	JETTY
✓	✓	✓	✓	✓		JP 05	Dry powder 6.8 kg	Fire hose reel box No.4	JETTY
✓	✓	✓	✓	✓		JP 08	Dry powder 6.8 kg	Fire hose reel box No.5	JETTY
✓	✓	✓	✓	✓		JP 07	Dry powder 6.8 kg	Infront off office	JETTY
✓	✓	✓	✓	✓		JP 06	Dry powder 8.9 kg	Infront off Electrical room	JETTY
✓	✓	✓	✓	✓		JP 09	Dry powder 6.8 kg	Security box 5	JETTY
✓	✓	✓	✓	✓		JP 11	Dry powder 7.5 kg	Container of CPCC	JETTY
✓	✓	✓	✓	✓		JP 07	Foam 9 Liter	Generator Room 02	JETTY
✓	✓	✓	✓	✓		JP10	Dry powder 2.3 kg	On the boat	JETTY
✓	✓	✓	✓	✓		JC 01	Cold 4.54 kg	Electrical room	JETTY
✓	✓	✓	✓	✓		PP 22	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 21	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 18	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 19	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 20	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PC 08	Cold 4.54 kg	Cantoon	PSB
✓	✓	✓	✓	✓		MF 01	Foam 9 Liter	Security box 3	PSB
✓	✓	✓	✓	✓		AF 01	Dry powder 6.8 kg	PSB WAREHOUSE#1-office	PSB W#001
✓	✓	✓	✓	✓		AC 01	Cold 4.54 kg	PSB Warehouse#1-office	PSB W#001
✓	✓	✓	✓	✓		AP 02	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W#001
✓	✓	✓	✓	✓		AP 03	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W#001
✓	✓	✓	✓	✓		AP 04	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W#001
✓	✓	✓	✓	✓		AP 05	Dry powder 6.8 kg	Inside PSB warehouse#1(W)	PSB W#001
✓	✓	✓	✓	✓		AP 06	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB W#001
✓	✓	✓	✓	✓		AP 07	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB W#001
✓	✓	✓	✓	✓		AP 08	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB W#001
✓	✓	✓	✓	✓		AP 09	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB W#001
✓	✓	✓	✓	✓		AP 10	Dry powder 6.8 kg	Artibit waste waste infront off cool room	PSB W#001
✓	✓	✓	✓	✓		AC 02	Cold 4.54 kg	Inside Artibit waste house(N)	PSB W#001
✓	✓	✓	✓	✓		AP 11	Dry powder 6.8 kg	Inside PSB W/H#1-roof shade	PSB W#001
✓	✓	✓	✓	✓		AP 12	Dry powder 6.8 kg	Inside PSB W/H#1-roof shade	PSB W#001
✓	✓								



**EXTINGUISHER
MAINTENANCE SHEET**
MONTHLY

PSB SONGKHLA



SAFETY SERVICE

OPERATION UNIT: _____

LOCATION: PSB _____

DATE: 20/04/24

PAGE 3 OF 6

WORK DETAILS FOR EACH UNIT.

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
 เครื่องดับเพลิงสามารถมองเห็นได้โดยไม่มีสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN OR DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE
 ฝักบัวล็อกที่ปิดอยู่อย่างมั่นคงและซีลฝากระโปรงไม่แตกหักหรือเสียหาย, สึกกร่อน, รั่วซึม, หรืออุดตันหัวฉีด

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
 ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้และตรวจสอบให้แน่ใจว่าตัวชี้วัดยังเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
 ข้อแนะนำการใช้งานบนป้ายกำกับอ่านได้ชัดเจนและหันออกด้านนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE SIGNED
 วิศวกรที่ได้รับการอนุญาตให้ตรวจสอบและบำรุงรักษาเครื่องดับเพลิงต้องลงนาม



A	B	C	D	E	REMARKS	ID NO.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		AP 15	Dry powder 6.8 kg.	Infront off chemical room	PSB W001
✓	✓	✓	✓	✓		AP 16	Dry powder 6.8 kg.	Chemical room	PSB W001
✓	✓	✓	✓	✓		AP 17	Dry powder 6.8 kg.	Chemical room	PSB W001
✓	✓	✓	✓	✓		AC 03	Cod 4.54 kg.	Electrical room	PSB W004
✓	✓	✓	✓	✓		AP 18	Dry powder 6.8 kg.	Plant store	PSB W004
✓	✓	✓	✓	✓		AF 01	Fume 9 Liter	Plant store	PSB W001
✓	✓	✓	✓	✓		AF 02	Fume 9 Liter	Chemical room	PSB W001
✓	✓	✓	✓	✓		AP 19	Dry powder 9 kg.	Inside PSB warehouse#4(W)	PSB W004
✓	✓	✓	✓	✓		AP 20	Dry powder 9 kg.	Inside PSB warehouse#4-Mezanine Deck/E	PSB W004
✓	✓	✓	✓	✓		AP 21	Dry powder 9 kg.	Inside PSB warehouse#4(E)	PSB W004
✓	✓	✓	✓	✓		AP 22	Dry powder 9 kg.	Office PSB warehouse#4(E)	PSB W004
✓	✓	✓	✓	✓		AP 23	Dry powder 9 kg.	Inside PSB warehouse#4(E)	PSB W004
✓	✓	✓	✓	✓		AP 24	Dry powder 9 kg.	Inside PSB warehouse#4(N)	PSB W004
✓	✓	✓	✓	✓		AP 25	Dry powder 9 kg.	PSB warehouse#4(E)	PSB W004
✓	✓	✓	✓	✓		AP 26	Dry powder 9 kg.	Inside PSB warehouse#4	PSB W004
✓	✓	✓	✓	✓		AC 04	Cod 5 kg.	Office PSB warehouse#4(E)	PSB W004
✓	✓	✓	✓	✓		AC 05	Cod 5 kg.	PSB Warehouse#4 - Cool Room	PSB W004
✓	✓	✓	✓	✓		AC 06	Cod 5 kg.	PSB Warehouse#4 - Cool Room	PSB W004
✓	✓	✓	✓	✓		AC 07	Cod 5 kg.	PSB Warehouse#4 - Electrical Room	PSB W004
✓	✓	✓	✓	✓		AC 08	Cod 5 kg.	PSB Warehouse#4- Forklift battery charger	PSB W004
✓	✓	✓	✓	✓		BP 01	Dry powder 6.8 kg.	Security box B	PSB W006
✓	✓	✓	✓	✓		BP 02	Dry powder 6.8 kg.	Infront off generator room	PSB W006
✓	✓	✓	✓	✓		BP 03	Cod 4.54 kg.	Infront off generator room	PSB W006
✓	✓	✓	✓	✓		BP 03	Fume 9 Liter	Infront off generator room	PSB W006
✓	✓	✓	✓	✓		BP 03	Dry powder 6.8 kg.	Inside Ware house (N)	PSB W006
✓	✓	✓	✓	✓		BP 04	Dry powder 6.8 kg.	Inside Ware house (N)	PSB W006
✓	✓	✓	✓	✓		BP 05	Dry powder 6.8 kg.	Infront Warehouse	PSB W006
✓	✓	✓	✓	✓		BP 05	Dry powder 6.8 kg.	Infront off pipe cam offset (N)	PSB W006
✓	✓	✓	✓	✓		BP 07	Dry powder 6.8 kg.	Infront off pipe turn offset (E)	PSB W006
✓	✓	✓	✓	✓		BP 47	Dry powder 6.8 kg.	Infront off Ware house	PSB W006
✓	✓	✓	✓	✓		BP 47	Dry powder 6.8 kg.	Infront off Ware house (Door 2)	PSB W006
✓	✓	✓	✓	✓		BP 48	Dry powder 23 kg.	Infront off Ware house (Door 2)	PSB W006
✓	✓	✓	✓	✓		BP 23	Dry powder 23 kg.	Inside Ware house (Door2)	PSB W006
✓	✓	✓	✓	✓		BP 09	Dry powder 23 kg.	Infront off Ware house (E)	PSB W006
✓	✓	✓	✓	✓		BP 10	Dry powder 6.8 kg.	Office Ware house	PSB W006
✓	✓	✓	✓	✓		BP 11	Dry powder 6.8 kg.	Infront off coolroom ABH (w)	PSB W006
✓	✓	✓	✓	✓		BP 02	Cod 4.54 kg.	Infront off coolroom ABH (E)	PSB W006
✓	✓	✓	✓	✓		BP 12	Dry powder 6.8 kg.	Infront off coolroom C2	PSB W006
✓	✓	✓	✓	✓		BP 13	Dry powder 6.8 kg.	Inside coolroom C2	PSB W006
✓	✓	✓	✓	✓		BP 14	Dry powder 6.8 kg.	Inside coolroom AB 2nd floor	PSB W006
✓	✓	✓	✓	✓		BP 03	Cod 4.54 kg.	Inside coolroom AB 2nd floor	PSB W006
✓	✓	✓	✓	✓		BP 15	Dry powder 6.8 kg.	Zone M 1st floor	PSB W006

PSB SONGKHLA

EXTINGUISHER

MAINTENANCE SHEET

MONTHLY

SAFETY SERVICE

OPERATION UNIT LOCATION: PSB

DATE: 27/01/24

PAGE 4 OF 6

WORK DETAILS FOR EACH UNIT.

A. THE EXTINGUISHER IS VISIBLE & UNOBTURED

ถังดับเพลิงสามารถมองเห็นได้และไม่มีสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)

สลักเกลียวล็อกและซีลแอมเปอร์ไม่ชำรุด (ไม่เสียหาย ไม่กัดกร่อน ไม่รั่วซึม ไม่อุดตันหัวฉีด)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL

ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และมั่นใจว่ายังมีของเหลวอยู่

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD

คำแนะนำการใช้งานบนป้ายกำกับสามารถอ่านได้และชี้ไปทางด้านนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

ช่างซ่อมบำรุงถังดับเพลิงที่ได้รับอนุญาตต้องตรวจสอบ

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		BP 19	Dry powder 6.8 kg	Zone M 2nd floor	PSB W1806
✓	✓	✓	✓	✓		BP 20	Dry powder 6.8 kg	Inside Ware house	PSB W1803
✓	✓	✓	✓	✓		BP 21	Dry powder 6.8 kg	Inside Ware house	PSB W1806
✓	✓	✓	✓	✓		BP 22	Dry powder 6.8 kg	Inside Ware house	PSB W1806
✓	✓	✓	✓	✓		BP 24	Dry powder 6.8 kg	Infront off Stock control(W)	PSB W1806
✓	✓	✓	✓	✓		BP 25	Dry powder 6.8 kg	Infront off Stock control(W)	PSB W1806
✓	✓	✓	✓	✓		BP 26	Dry powder 6.8 kg	Infront off Stock control(W)	PSB W1806
✓	✓	✓	✓	✓		BP 27	Dry powder 6.8 kg	Infront off Stock control(W)	PSB W1806
✓	✓	✓	✓	✓		BC 04	Co2 4.5 kg	Infront off Stock control Office	PSB W1806
✓	✓	✓	✓	✓		BC 05	Co2 4.5 kg	Inside chemical room	PSB W1806
✓	✓	✓	✓	✓		BP 28	Dry powder 6.8 kg	Inside chemical room	PSB W1806
✓	✓	✓	✓	✓		BP 29	Dry powder 23 kg	Infront off chemical room	PSB W1806
✓	✓	✓	✓	✓		BP 30	Dry powder 23 kg	Infront off chemical room	PSB W1806
✓	✓	✓	✓	✓		BP 45	Dry powder 6.8 kg	Paint store	PSB W1806
✓	✓	✓	✓	✓		BP 51	Dry powder 6.8 kg	Maintenance work shop	PSB W1806
✓	✓	✓	✓	✓		BP 32	Dry powder 6.8 kg	Maintenance work shop	PSB W1806
✓	✓	✓	✓	✓		BP 33	Dry powder 6.8 kg	Inside maintenance work shop	PSB W1806
✓	✓	✓	✓	✓		BP 34	Dry powder 6.8 kg	Infront off maintenance work shop	PSB W1806
✓	✓	✓	✓	✓		BP 46	Dry powder 6.8 kg	Infront off maintenance work shop	PSB W1806
✓	✓	✓	✓	✓		BP 35	Dry powder 6.8 kg	Office W	PSB W1806
✓	✓	✓	✓	✓		BP 36	Dry powder 6.8 kg	Office E	PSB W1806
✓	✓	✓	✓	✓		BC 06	Co2 4.5 kg	Office (Lobby)	PSB W1806
✓	✓	✓	✓	✓		BP 04	Flame 9 liter	Inside chemical room	PSB W1806
✓	✓	✓	✓	✓		BP 37	Dry powder 6.8 kg	Infront off waste area office	WASTE AREA
✓	✓	✓	✓	✓		BP 38	Dry powder 23 kg	Infront off waste area office	WASTE AREA
✓	✓	✓	✓	✓		BP 39	Dry powder 6.8 kg	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BF 01	Flame 9 liter	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BF 02	Flame 9 liter	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BP 05	Flame 9 liter	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BP 40	Dry powder 6.8 kg	Waste area (W)	WASTE AREA
✓	✓	✓	✓	✓		BP 41	Dry powder 6.8 kg	Infront off EMI warehouse	EMI WH
✓	✓	✓	✓	✓		BP 42	Dry powder 6.8 kg	Infront off EMI warehouse	EMI WH
✓	✓	✓	✓	✓		BP 44	Dry powder 6.8 kg	Visitor area	PSB Visitor area
✓	✓	✓	✓	✓		EP 01	Dry powder 6.8 kg	Security box 1	EMI 1.
✓	✓	✓	✓	✓		EP 02	Dry powder 6.8 kg	EMI 1st floor (N)	EMI 1.
✓	✓	✓	✓	✓		EP 03	Dry powder 6.8 kg	EMI 1st floor (E)	EMI 1.
✓	✓	✓	✓	✓		EP 04	Dry powder 6.8 kg	EMI 2nd floor	EMI 1.
✓	✓	✓	✓	✓		EP 05	Dry powder 6.8 kg	EMI 2nd floor	EMI 1.
✓	✓	✓	✓	✓		EP 06	Dry powder 6.		

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE
PAGE 5 OF 6

OPERATION UNIT: PSB LOCATION: PSB DATE: 27/02/24

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
 B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
 C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
 D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
 E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

A	B	C	D	E	REMARKS	ID NO.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		EP 08	Dry powder 6.8 kg	EMI 1st floor (N-W)	EMI 2
✓	✓	✓	✓	✓		EC 01	CO2 4.54 kg	EMI 1st floor (S-W)	EMI 2
✓	✓	✓	✓	✓		EP 09	Dry powder 6.8 kg	EMI 2nd floor (N)	EMI 2
✓	✓	✓	✓	✓		EP 10	Dry powder 6.8 kg	EMI 2nd floor (S)	EMI 2
✓	✓	✓	✓	✓		EC 02	CO2 4.54 kg	EMI 2nd floor inside room	EMI 2
✓	✓	✓	✓	✓		EP 11	Dry powder 6.8 kg	Wall partition office 2nd floor	WELL SERVICE
✓	✓	✓	✓	✓		EP 12	Dry powder 6.8 kg	1st floor in front of Meeting room	WELL SERVICE
✓	✓	✓	✓	✓		EP 13	Dry powder 6.8 kg	1st floor in front of Cool room	WELL SERVICE
✓	✓	✓	✓	✓		EP 14	Dry powder 6.8 kg	Container office	WELL SERVICE
✓	✓	✓	✓	✓		EP 15	Dry powder 6.8 kg	Roof shade roof	WELL SERVICE
✓	✓	✓	✓	✓		EP 16	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP 17	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP 18	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP 19	Dry powder 6.8 kg	Work shop (N-E)	WELL SERVICE
✓	✓	✓	✓	✓		EP 20	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EC 03	CO2 4.54 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EP 21	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EP 22	Dry powder 6.8 kg	EMI W343 workshop - NW	EMI W343
✓	✓	✓	✓	✓		EP 23	Dry powder 6.8 kg	EMI W343 workshop - SW	EMI W343
✓	✓	✓	✓	✓		EP 24	Dry powder 6.8 kg	EMI W343 workshop - SE	EMI W343
✓	✓	✓	✓	✓		EP 25	Dry powder 6.8 kg	EMI W343 workshop - NE	EMI W343
✓	✓	✓	✓	✓		EP 26	Dry powder 6.8 kg	EMI W343 Warehouse - E	EMI W343
✓	✓	✓	✓	✓		EP 27	Dry powder 6.8 kg	EMI W343 Warehouse - W	EMI W343
✓	✓	✓	✓	✓		EP 28	Dry powder 6.8 kg	EMI W343 Office floor#1 - E	EMI W343
✓	✓	✓	✓	✓		EP 29	Dry powder 6.8 kg	EMI W343 Office floor#1 - W	EMI W343
✓	✓	✓	✓	✓		EC 04	CO2 4.54 kg	EMI W343 Warehouse - W/Electrical room	EMI W343
✓	✓	✓	✓	✓		EC 05	CO2 4.54 kg	EMI W343 Warehouse - W/Electrical room	EMI W343
✓	✓	✓	✓	✓		CP 01	Dry powder 6.8 kg	Cpoc ware houses (N-E)	CP0C
✓	✓	✓	✓	✓		CP 02	Dry powder 6.8 kg	Cpoc ware houses (S-E)	CP0C
✓	✓	✓	✓	✓		CP 03	Dry powder 6.8 kg	Cpoc ware houses (S-W)	CP0C
✓	✓	✓	✓	✓		CP 04	Dry powder 6.8 kg	Cpoc ware houses (N-W)	CP0C
✓	✓	✓	✓	✓		CP 05	Dry powder 6.8 kg	Cpoc ware houses (N-E)	CP0C
✓	✓	✓	✓	✓		CP 06	Dry powder 6.8 kg	Cpoc roof shade	CP0C
✓	✓	✓	✓	✓		CP 07	Dry powder 6.8 kg	Infant off cool room	CP0C
✓	✓	✓	✓	✓		CP 08	Dry powder 6.8 kg	Infant off cool room	CP0C
✓	✓	✓	✓	✓		CP 09	Dry powder 6.8 kg	Container office	CP0C
✓	✓	✓	✓	✓		CP 10	Dry powder 6.8 kg	Container office	CP0C
✓	✓	✓	✓	✓		LP 127	Dry powder 6.8 kg	COOL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 128	Dry powder 6.8 kg	COOL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 129	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE
PAGE 6 OF 6

OPERATION UNIT: PSB LOCATION: PSB DATE: 27/02/24

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
 B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
 C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
 D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
 E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED

A	B	C	D	E	REMARKS	ID NO.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		LP 65	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 131	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 54	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 130	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 133	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 136	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 137	Dry powder 6.8 kg	CHEMICAL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 08	Flame 9 LTR	CHEMICAL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 147	Dry powder 6.8 kg	SECURITY YARD 1	FREE ZONE
✓	✓	✓	✓	✓		LP 05	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 06	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 07	Dry powder 6.8 kg	CUSTOMS OFFICE	FREE ZONE
✓	✓	✓	✓	✓		LP 32	Dry powder 6.8 kg	PSB-W343 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓		LP 35	Dry powder 6.8 kg	PSB-W343 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓		LP 146	Dry powder 6.8 kg	IN FRONT OF ROOF SHADE	FREE ZONE
✓	✓	✓	✓	✓		LP 80	Dry powder 6.8 kg	SECURITY BOX No.9	FREE ZONE
✓	✓	✓	✓	✓		LC 01	CO2 6.8 kg	INSIDE CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 09	Flame 9 LTR	CHEMICAL ROOM	FREE ZONE
✓	✓	✓	✓	✓		LP 45	Dry powder 6.8 kg	TERMINAL CHECK IN / WEST	TERMINAL
✓	✓	✓	✓	✓		LP 46	Dry powder 6.8 kg	TERMINAL CHECK IN / EAST	TERMINAL
✓	✓	✓	✓	✓		AP 27	Dry powder 6.8 kg	PSB Warehouse#1-NW	PSB Warehouse#1
✓	✓	✓	✓	✓		AP 28	Dry powder 6.8 kg	PSB Warehouse#1-SW	PSB Warehouse#1
✓	✓	✓	✓	✓		AP 29	Dry powder 6.8 kg	PSB Warehouse#1-SE	PSB Warehouse#1
✓	✓	✓	✓	✓		AP 30	Dry powder 6.8 kg	PSB Warehouse#1-NE	PSB Warehouse#1

REMARKS:

LEADER: PM team

PTTEP
PSB

FIRE MAN BOX
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE
PAGE 1 OF 1

OPERATION UNIT: PSB LOCATION: PSB DATE: 27/02/24

WORK DETAILS FOR EACH UNIT

A. CHECK FIRE SUIT, FIRE HELMET, BOOTS, GLOVES & OTHER EQUIPMENT AVAILABLE
 B. SECURING STRAP, DOOR PACKING AND LOCK FUNCTIONS IN A GOOD CONDITION
 C. CLEAN & READY TO USE

A	B	C	REMARKS	LOCATION
✓	✓	✓	FIRE SUIT - 4 Pcs. FIRE HELMET - 4 Pcs. BOOTS - 4 Pcs.	JETTY
✓	✓	✓	GLOVES - 4 Pcs. FOAM INJECTION - 1 Pcs. VALVE - 1 Pcs.	FIRE SERVICE WORKSHOP
✓	✓	✓	FIRE SUIT - 4 Pcs. FIRE HELMET - 4 Pcs. BOOTS - 4 Pcs.	BEHIND PSB BUILDING-A
✓	✓	✓	GLOVES - 4 Pcs.	
✓	✓	✓	FIRE SUIT - 4 Pcs. FIRE HELMET - 4 Pcs. BOOTS - 4 Pcs.	
✓	✓	✓	GLOVES - 4 Pcs.	

REMARKS:

LEADER: PM team

PTTEP
PSB

LIFEBUOY
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE
PAGE 1 OF 1

OPERATION UNIT: PSB LOCATION: PSB DATE: 27/02/24



WORK DETAILS FOR EACH UNIT

A. LIFEBUOY IS ACCESSIBLE & EASILY REMOVED FOR USE
 B. VISUALLY INSPECT THE LIFEBUOY FOR DAMAGE
 C. LIFEBUOY IS SEALED WITH A PLUG
 D. THE GRAB LINE AROUND THE CIRCUMFERENCE IS NOT DAMAGED

A	B	C	D	REMARKS	ID NO.	LOCATION
✓	✓	✓	✓		LBV - 1	JETTY-NE
✓	✓	✓	✓		LBV - 2	JETTY BERTH - 1
✓	✓	✓	✓		LBV - 3	JETTY BERTH - 2
✓	✓	✓	✓		LBV - 4	JETTY BERTH - 3
✓	✓	✓	✓		LBV - 5	JETTY BERTH - 4
✓	✓	✓	✓		LBV - 6	JETTY BERTH - 5
✓	✓	✓	✓		LBV - 7	JETTY BERTH - 6
✓	✓	✓	✓		LBV - 8	JETTY SW
✓	✓	✓	✓		LBV - 9	JETTY NW
✓	✓	✓	✓		LBV - 10	JETTY BOAT
✓	✓	✓	✓		LBV - 11	JETTY BOAT


REMARKS:

LEADER: PM team

 PTTEP PSB	STRETCHER MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE
	OPERATION UNIT LOCATION: PSB	DATE: 29/08/24	PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT



A. THE STRETCHER FREE OF EXCESSIVE WEAR
 B. ALL MOVING PART (COUPLING, LEVERS, HINGES, AND SLIDING FRAMES) OPERATE PROPERLY
 C. THE COUPLING PINS ARE SECURELY IN PLACE
 D. THE FOOT SECTION LOCK PROPERLY INTO EACH POSITION
 E. THE HEAD-AND FOOT-END COUPLING REQUIRE LUBRICATION



A	B	C	D	E	REMARKS	LOCATION
✓	✓	✓	✓	✓		PSB WAREHOUSE#4
✓	✓	✓	✓	✓		JETTY
✓	✓	✓	✓	✓		PSB WAREHOUSE#1 / OFFICE
✓	✓	✓	✓	✓		PSB BUILDING-A/MEDIC ROOM
✓	✓	✓	✓	✓		PSB BUILDING-A/MEDIC ROOM


REMARKS:

LEADER: PM team

 PTTEP PSB	SAFETY SHOWER MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE
	OPERATION UNIT LOCATION: PSB	DATE: 29/08/24	PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT



A. EASILY LOCATED & ACCESSIBLE ACTUATOR
 B. GOOD CENTER OF WATER PATTERN
 C. COVERS ARE REMOVED BY WATER FLOW
 D. VALVE ACTUATOR IS EASY TO LOCATE



A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		CHEMICAL ROOM - PSB W/H#2
✓	✓	✓	✓		WASTE AREA
✓	✓	✓	✓		CHEMICAL ROOM - PSB W/H#6
✓	✓	✓	✓		FREE ZONE
✓	✓	✓	✓		CPOC ROOF SHED


REMARKS:

LEADER: PM team

 PTTEP PSB	EYE WASH STATION MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE
	OPERATION UNIT LOCATION: PSB	DATE: 29/08/24	PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT



A. NON OBSTRUCTION
 B. WATER IS AT THE PROPER FILL LINE & NO LEAKING
 C. NO DAMAGE OR CRACK TO THE UNIT
 D. ADEQUATE WATER PRESSURE AND FLOW



A	B	C	D	E	REMARKS	LOCATION
✓	✓	✓	✓	✓		CPOC W/H - COOL ROOM
✓	✓	✓	✓	✓		WASTE AREA OFFICE
✓	✓	✓	✓	✓		WASTE CHEMICAL TRANSIT
✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP - NE
✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP - NW
✓	✓	✓	✓	✓		PSB BUILDING-A-GENERATOR
✓	✓	✓	✓	✓		EMI WS#3 workshop


REMARKS:

LEADER: PM team

 PTTEP PSB	TORCH MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE
	OPERATION UNIT LOCATION: PSB	DATE: 29/08/24	PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. CHECK FUNCTIONS AND CONDITIONS OF TORCH
 B. CHECK THE BRIGHTNESS OF THE LIGHT
 C. WALL BRACKET SECURE FOR USING
 D. APPLY INSPECTION STICKER AND RECORD ON TASK SHEET



A	B	C	D	E	REMARKS	LOCATION
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room CUBRT
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room C2 (BKT)
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room AB 1st (BKT)
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room AB 2nd (BKT)
✓	✓	✓	✓	✓		PSB W/H#6 - Inside door2 (BKT)
✓	✓	✓	✓	✓		PSB BUILDING-A/ELECTRICAL ROOM
✓	✓	✓	✓	✓		PSB BUILDING-A-GENERATOR ROOM
✓	✓	✓	✓	✓		FREE ZONE COOL ROOM
✓	✓	✓	✓	✓		PSB W/H#1 COOL ROOM
✓	✓	✓	✓	✓		EMI#1 FLOOR 1st
✓	✓	✓	✓	✓		EMI#1 FLOOR 2nd
✓	✓	✓	✓	✓		WELL SERVICE OFFICE-FLOOR 2nd
✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP
✓	✓	✓	✓	✓		CPOC W/H
✓	✓	✓	✓	✓		CPOC COOL ROOM

REMARKS:



LEADER: PM team

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION : PSB		SAFETY SERVICE	
		DATE: 27/08/24		PAGE 1 OF 4	
WORK DETAILS FOR EACH UNIT					
GOOD ALARM SENSOR MODE					
A. ตรวจเช็คการแจ้งเตือนด้วยมือ CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด หัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบอุปกรณ์หัวอุปกรณ์ กระดาษรีด หรือตะกั่ว CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	A101	PSB BUILDING-A / 1ST FLOOR SHEYRON OFFICE
✓	✓	✓	✓	A102	PSB BUILDING-A / 1ST FLOOR WEST DOOR
✓	✓	✓	✓	A103	PSB BUILDING-A / 1ST FLOOR MEDIC ROOM
✓	✓	✓	✓	A104	PSB BUILDING-A / SECURITY BOX 4
✓	✓	✓	✓	A105	PSB BUILDING-A / 2nd FLOOR AT STAIR
✓	✓	✓	✓	A106	PSB BUILDING-A / 2nd FLOOR CPOC OFFICE
✓	✓	✓	✓	A107	PSB BUILDING-A / 2nd FLOOR EMERGENCY DOOR
✓	✓	✓	✓	A108	PSB BUILDING-A / 3rd FLOOR AT STAIR
✓	✓	✓	✓	A110	PSB BUILDING-A / 3rd FLOOR RADIO ROOM
✓	✓	✓	✓	A109	PSB BUILDING-A / 3rd FLOOR ROOM 304
✓	✓	✓	✓	A111	PSB BUILDING-A / 3rd FLOOR ROOM 310
✓	✓	✓	✓	A112	PSB BUILDING-A / IN SIDE ELECTRICAL ROOM
✓	✓	✓	✓	A113	PSB BUILDING-A / IN FONT OFF FIRE PUMP
✓	✓	✓	✓	N0.01	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.02	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.03	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.04	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.05	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.06	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.07	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.08	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.09	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.10	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.11	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.12	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.13	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.14	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.15	PSB BUILDING-B / 3rd FLOOR
✓	✓	✓	✓	J101	IN SIDE JETTY ELECTRICAL ROOM
✓	✓	✓	✓	J102	JETTY BERTH 1
✓	✓	✓	✓	J103	JETTY BERTH 2
✓	✓	✓	✓	J104	JETTY BERTH 6
✓	✓	✓	✓	J105	JETTY BULK TANK 1

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION : PSB		SAFETY SERVICE	
		DATE: 27/08/24		PAGE 2 OF 4	
WORK DETAILS FOR EACH UNIT					
GOOD ALARM SENSOR MODE					
A. ตรวจเช็คการแจ้งเตือนด้วยมือ CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด หัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบอุปกรณ์หัวอุปกรณ์ กระดาษรีด หรือตะกั่ว CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	J106	JETTY BULK TANK 2
✓	✓	✓	✓	J107	JETTY OFFICE
✓	✓	✓	✓	J108	SECURITY BOX 6 JETTY
✓	✓	✓	✓	B119	CREW CHANGE AREA
✓	✓	✓	✓	ST-01	EMI SPECIAL TOOL S-E W/H
✓	✓	✓	✓	ST-02	EMI SPECIAL TOOL S-E W/H
✓	✓	✓	✓	ST-03	EMI SPECIAL TOOL S-W W/H
✓	✓	✓	✓	B120	WASTE AREA ROW 8
✓	✓	✓	✓	B121	WASTE AREA ROW 20
✓	✓	✓	✓	B122	TERMINAT CHECK-IN/Out
✓	✓	✓	✓	B123	TERMINAT CHECK-IN/Out
✓	✓	✓	✓	B109	PSB W/H#6-COOM ROOM CA-B
✓	✓	✓	✓	B108	PSB W/H#6-COOM ROOM CE
✓	✓	✓	✓	B111	INFRONT OF PSB W/H#6-N
✓	✓	✓	✓	B107	INFRONT OF PSB W/H#6-W
✓	✓	✓	✓	B110	INSIDE PSB W/H#6-West
✓	✓	✓	✓	B112	PSB WAREHOUSE#6-B32
✓	✓	✓	✓	B106	PSB W/H#6-STOCK CONTROL-S/E
✓	✓	✓	✓	B105	PSB W/H#6-CHEMICAL ROOM
✓	✓	✓	✓	B104	PSB W/H#6-PAINTING STORAGE
✓	✓	✓	✓	B117	PSB W/H#6-OFFICE
✓	✓	✓	✓	B116	PSB W/H#6-OFFICE
✓	✓	✓	✓	B115	PSB W/H#6-OFFICE
✓	✓	✓	✓	B113	PSB W/H#6-OFFICE
✓	✓	✓	✓	B114	GBS WAREHOUSE#1 - B 33
✓	✓	✓	✓	B101	GBS WAREHOUSE#1 - B 33
✓	✓	✓	✓	B103	PSB W/H#6-GBS WORKSHOP
✓	✓	✓	✓	B102	PSB W/H#6-GBS WORKSHOP
✓	✓	✓	✓	F103	FREE ZONE COOL ROOM
✓	✓	✓	✓	F104	FREE ZONE COOL ROOM
✓	✓	✓	✓	F105	FREE ZONE W/H STAIR
✓	✓	✓	✓	F106	FREE ZONE W/H WEST
✓	✓	✓	✓	F107	FREE ZONE W/H SW

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION : PSB		SAFETY SERVICE	
		DATE: 27/08/24		PAGE 3 OF 4	
WORK DETAILS FOR EACH UNIT					
GOOD ALARM SENSOR MODE					
A. ตรวจเช็คการแจ้งเตือนด้วยมือ CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด หัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบอุปกรณ์หัวอุปกรณ์ กระดาษรีด หรือตะกั่ว CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	F108	FREE ZONE W/H S/E
✓	✓	✓	✓	F101	FREE ZONE CHEMICAL
✓	✓	✓	✓	F102	FREE ZONE CHEMICAL
✓	✓	✓	✓	F109	FREE ZONE NEW W/H
✓	✓	✓	✓	I101	EMI WORKSHOP1 / N
✓	✓	✓	✓	I102	EMI WORKSHOP1 / NW
✓	✓	✓	✓	I103	EMI WORKSHOP1 / SW
✓	✓	✓	✓	I104	EMI WORKSHOP1 / SW
✓	✓	✓	✓	E101	EMI WORKSHOP2 / STAIRS
✓	✓	✓	✓	E102	EMI WORKSHOP2 / STAIRS
✓	✓	✓	✓	E103	EMI WORKSHOP2
✓	✓	✓	✓	E104	EMI WORKSHOP2 DOORS
✓	✓	✓	✓	E105	EMI WORKSHOP2 DOORS
✓	✓	✓	✓	E106	EMI WORKSHOP2 LEVEL2
✓	✓	✓	✓	E107	EMI WORKSHOP2 LEVEL2
✓	✓	✓	✓	E108	EMI WORKSHOP - NW
✓	✓	✓	✓	E109	EMI WORKSHOP - SW
✓	✓	✓	✓	E110	EMI WORKSHOP - NE
✓	✓	✓	✓	E111	EMI WORKSHOP - E
✓	✓	✓	✓	E112	EMI WORKSHOP - W
✓	✓	✓	✓	E113	EMI WORKSHOP - E
✓	✓	✓	✓	E114	EMI WORKSHOP - W
✓	✓	✓	✓	E115	EMI WORKSHOP - E
✓	✓	✓	✓	E116	EMI WORKSHOP - W
✓	✓	✓	✓	H101	WELL SERVICE OFFICE LEVEL 1
✓	✓	✓	✓	H102	WELL SERVICE OFFICE LEVEL 2
✓	✓	✓	✓	H103	WELL SERVICE WORKSHOP
✓	✓	✓	✓	H104	WELL SERVICE WORKSHOP
✓	✓	✓	✓	C101	CPOC W/H
✓	✓	✓	✓	C102	CPOC W/H
✓	✓	✓	✓	C103	CPOC W/H
✓	✓	✓	✓	C104	CPOC W/H
✓	✓	✓	✓	C105	CPOC COOL ROOM
✓	✓	✓	✓	C106	CPOC COOL ROOM

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION : PSB		SAFETY SERVICE	
		DATE: 27/08/24		PAGE 4 OF 4	
WORK DETAILS FOR EACH UNIT					
GOOD ALARM SENSOR MODE					
A. ตรวจเช็คการแจ้งเตือนด้วยมือ CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. การทำความสะอาด หัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ให้ตรวจสอบอุปกรณ์หัวอุปกรณ์ กระดาษรีด หรือตะกั่ว CHECK ID. NO					
D. ตรวจสอบอุปกรณ์ประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	F001	PSB FIRE SERVICE WORKSHOP
✓	✓	✓	✓	M01	PSB W/H#1 OFFICE N
✓	✓	✓	✓	M02	PSB W/H#1 OFFICE S/E
✓	✓	✓	✓	M03	PSB W/H#1 W/H COOL ROOM S
✓	✓	✓	✓	M04	PSB W/H#1 CHEMICAL ROOM W/H
✓	✓	✓	✓	M05	PSB W/H#1 CHEMICAL ROOM S
✓	✓	✓	✓	M06	PSB CHEMICAL WASTE TRANSIT
✓	✓	✓	✓	M07	PSB CHEMICAL WASTE TRANSIT
✓	✓	✓	✓	M08	PSB GAS STORE S/W
✓	✓	✓	✓	M-10	PSB W/H#1
✓	✓	✓	✓	M-11	PSB W/H#1
✓	✓	✓	✓	MAA-01	PSB W/H#4
✓	✓	✓	✓	MAA-02	PSB W/H#4
✓	✓	✓	✓	MAA-03	PSB W/H#4
✓	✓	✓	✓	MAA-04	PSB W/H#4
✓	✓	✓	✓	MAA-05	PSB W/H#4
✓	✓	✓	✓	MAA-06	PSB W/H#4
✓	✓	✓	✓	MAA-07	PSB W/H#4
✓	✓	✓	✓	MAA-08	PSB W/H#4
✓	✓	✓	✓	MAA-09	PSB W/H#4
✓	✓	✓	✓	MAA-10	PSB W/H#4
✓	✓	✓	✓	MAA-11	PSB W/H#4
✓	✓	✓	✓	MAA-12	PSB W/H#4
✓	✓	✓	✓	MAA-13	PSB W/H#4
✓	✓	✓	✓	MAA-14	PSB W/H#4
✓	✓	✓	✓	MAA-15	PSB W/H#4
✓	✓	✓	✓	MAA-16	PSB W/H#4
✓	✓	✓	✓	MAA-17	PSB W/H#4
✓	✓	✓	✓	MAA-18	PSB W/H#4
✓	✓	✓	✓	MAA-19	PSB W/H#4
✓	✓	✓	✓	MAA-20	PSB W/H#4
✓	✓	✓	✓	MAA-21	PSB W/H#4
✓	✓	✓	✓	MAA-22	PSB W/H#4
✓	✓	✓	✓	MAA-23	PSB W/H#4
✓	✓	✓	✓	MAA-24	PSB W/H#4
✓	✓	✓	✓	MAA-25	PSB W/H#4
✓	✓	✓	✓	MAA-26	PSB W/H#4
✓	✓	✓	✓	MAA-27	PSB W/H#4
✓	✓	✓	✓	MAA-28	PSB W/H#4
✓	✓	✓	✓	MAA-29	PSB W/H#4
✓	✓	✓	✓	MAA-30	PSB W/H#4
✓	✓	✓	✓	MAA-31	PSB W/H#4
✓	✓	✓	✓	MAA-32	PSB W/H#4
✓	✓	✓	✓	MAA-33	PSB W/H#4
✓	✓	✓	✓	MAA-34	PSB W/H#4
✓	✓	✓	✓	MAA-35	PSB W/H#4
✓	✓	✓	✓	MAA-36	PSB W/H#4
✓	✓	✓	✓	MAA-37	PSB W/H#4
✓	✓	✓	✓	MAA-38	PSB W/H#4
✓	✓	✓	✓	MAA-39	PSB W/H#4
✓	✓	✓	✓	MAA-40	PSB W/H#4
✓	✓	✓	✓	MAA-41	PSB W/H#4
✓	✓	✓	✓	MAA-42	PSB W/H#4
✓	✓	✓	✓	MAA-43	PSB W/H#4
✓	✓	✓	✓	MAA-44	PSB W/H#4
✓	✓	✓	✓	MAA-45	PSB W/H#4
✓	✓	✓	✓	MAA-46	PSB W/H#4
✓	✓	✓	✓	MAA-47	PSB W/H#4
✓	✓	✓	✓	MAA-48	PSB W/H#4
✓	✓	✓	✓	MAA-49	PSB W/H#4
✓	✓	✓	✓	MAA-50	PSB W/H#4
✓	✓	✓	✓	MAA-51	PSB W/H#4
✓	✓	✓	✓	MAA-52	PSB W/H#4
✓	✓	✓	✓	MAA-53	PSB W/H#4
✓	✓	✓	✓	MAA-54	PSB W/H#4
✓	✓	✓	✓	MAA-55	PSB W/H#4
✓	✓	✓	✓	MAA-56	PSB W/H#4
✓	✓	✓	✓	MAA-57	PSB W/H#4
✓	✓	✓	✓	MAA-58	PSB W/H#4
✓	✓	✓	✓	MAA-59	PSB W/H#4
✓	✓	✓	✓	MAA-60	PSB W/H#4
✓	✓	✓	✓	MAA-61	PSB W/H#4
✓	✓	✓	✓	MAA-62	PSB W/H#4
✓	✓	✓	✓	MAA-63	PSB W/H#4
✓	✓	✓	✓	MAA-64	PSB W/H#4
✓	✓	✓	✓	MAA-65	PSB W/H#4
✓	✓	✓	✓	MAA-66	PSB W/H#4
✓	✓	✓	✓	MAA-67	PSB W/H#4
✓	✓	✓	✓	MAA-68	PSB W/H#4
✓	✓	✓	✓	MAA-69	PSB W/H#4
✓	✓	✓	✓	MAA-70	PSB W/H#4
✓	✓	✓	✓	MAA-71	PSB W/H#4
✓	✓	✓	✓	MAA-72	PSB W/H#4
✓	✓	✓	✓	MAA-73	PSB W/H#4
✓	✓	✓	✓	MAA-74	PSB W/H#4
✓	✓	✓	✓	MAA-75	PSB W/H#4
✓	✓	✓	✓	MAA-76	PSB W/H#4
✓	✓	✓	✓	MAA-77	PSB W/H#4
✓	✓	✓	✓	MAA-78	PSB W/H#4
✓	✓	✓	✓	MAA-79	PSB W/H#4
✓	✓	✓	✓	MAA-80	PSB W/H#4
✓	✓	✓	✓	MAA-81	PSB W/H#4
✓	✓	✓	✓	MAA-82	PSB W/H#4
✓	✓	✓	✓	MAA-83	PSB W/H#4
✓	✓	✓	✓	MAA-84	PSB W/H#4
✓	✓	✓	✓	MAA-85	PSB W/H#4
✓	✓	✓	✓	MAA-86	PSB W/H#4
✓	✓	✓	✓	MAA-87	PSB W/H#4
✓	✓	✓	✓	MAA-88	PSB W/H#4
✓	✓	✓	✓	MAA-89	PSB W/H#4
✓	✓	✓	✓	MAA-90	PSB W/H#4
✓	✓	✓	✓	MAA-91	PSB W/H#4
✓	✓	✓	✓	MAA-92	PSB W/H#4
✓	✓	✓	✓	MAA-93	PSB W/H#4
✓	✓	✓	✓	MAA-94	PSB W/H#4
✓	✓	✓	✓	MAA-95	PSB W/H#4
✓	✓	✓	✓	MAA-96	PSB W/H#4
✓	✓	✓	✓	MAA-97	PSB W/H#4
✓	✓	✓	✓	MAA-98	PSB W/H#4
✓	✓	✓	✓	MAA-99	PSB W/H#4
✓	✓	✓	✓		

 PTTEP PSB OPERATION UNIT		EMERGENCY PHONE MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE	
LOCATION : PSB		DATE : 29/06/24		PAGE 1 OF 1	


WORK DETAILS FOR EACH UNIT

A. PHONE ACCESSIBLE
การให้ใช้งานโทรศัพท์

B. EMERGENCY PHONE NUMBERS AND PROCEDURES POSTED AT OR NEAR TELEPHONE
หมายเลขโทรศัพท์ฉุกเฉินและวิธีการโดยติดใกล้กับโทรศัพท์

C. SAFETY BOARD DISPLAYING EMERGENCY PHONE NUMBER
ป้ายความปลอดภัยแสดงหมายเลขโทรศัพท์ฉุกเฉิน



D. FUNCTIONALITY SUITABLE
ฟังก์ชันที่เหมาะสม



A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		FREE ZONE CONTAINER
✓	✓	✓	✓		CREW CHANGE AREA
✓	✓	✓	✓		JETTY
✓	✓	✓	✓		PSB W/16- MUSTER POINT
✓	✓	✓	✓		EMI MUSTER POINT.

REMARKS:

LEADER: PM team

 PTTEP PSB OPERATION UNIT		FIRE HOSE TROLLEY MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE	
LOCATION : PSB		DATE : 29/06/24		PAGE 1 OF 1	


WORK DETAILS FOR EACH UNIT

A. All equipment complete as specified
อุปกรณ์ครบถ้วนตามที่ระบุไว้

B. All equipment is in working condition. All equipment is in working condition.
อุปกรณ์ทุกอย่างอยู่ในสภาพพร้อมใช้งาน

C. NON-OBSTRUCTED
ไม่สิ่งกีดขวาง



D. The Trolley is in good working condition, easy to move.
รถเข็นอยู่ในสภาพพร้อมใช้งาน เคลื่อนย้ายได้สะดวก



A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓	PS SIZE 45 MM - 4 Ft. PS SIZE 64 MM - 4 Ft. VALVE- 1P. NOZZLE- 2 Ft. HAND TOOL- 1 Ft.	BEHIND OF PSB BUILDING-A
✓	✓	✓	✓	PS SIZE 45 MM - 3 Ft. PS SIZE 64 MM - 2 Ft. VALVE- 2 Ft. NOZZLE- 2 Ft.	BESIDE SECURITY BOX- 2

REMARKS:

LEADER: PM team

 PTTEP PSB OPERATION UNIT		PSB FIRE FIGHTING EQUIPMENT MONTHLY CHECK LIST		 PSB SONGKHLA	
---	--	---	--	---	--

		ISSUED	RETURN	COMPLETED
1	FIRE HYDRANT	29/06/24	29/06/24	100%
2	FIRE HOSE REEL	29/06/24	29/06/24	100%
3	FIRE HOSE	29/06/24	29/06/24	100%
4	EXTINGUISHER	29/06/24	29/06/24	100%
5	FIRE MAN Eqp.	29/06/24	29/06/24	100%
6	LIFEBUOY	29/06/24	29/06/24	100%
7	STRETCHER	29/06/24	29/06/24	100%
8	SAFETY SHOWER	29/06/24	29/06/24	100%
9	EYEWASH STATION	29/06/24	29/06/24	100%
10	TROCH	29/06/24	29/06/24	100%
11	FIRE ALARM	29/06/24	29/06/24	100%
12	EMERGENCY PHONE	29/06/24	29/06/24	100%
13	FIRE HOSE TROLLEY	29/06/24	29/06/24	100%

TASK COMPLETED: 100%

TIME SPENDING: 10.55 HOURS

REMARK:

CHECK BY: PM team DATE: 29/06/24

 PTTEP PSB OPERATION UNIT		FIRE HYDRANT MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE	
LOCATION : PSB		DATE : _____		PAGE 1 OF 1	

WORK DETAILS FOR EACH UNIT

A. HYDRANTS ARE ACCESSIBLE & FREE OF OBSTRUCTION
จำนวนและตำแหน่งของตู้ดับเพลิงอยู่ในที่ที่เข้าถึงได้และไม่มีสิ่งกีดขวาง

B. TOP OF HYDRANT IS NOT LEAKING WHEN HYDRANT IS ON
ด้านบนของหัวจ่ายดับเพลิงไม่รั่วไหลเมื่อมีการเปิดหัวจ่ายดับเพลิง

C. RUBBER SEAL UNDER CAPS ARE NOT LEAKING
ซีลยางภายใต้ฝาครอบไม่รั่วไหล

D. HYDRANT BARREL IS IN GOOD CONDITION WITHOUT CRACKS OR CORROSION
สายหัวจ่ายดับเพลิงอยู่ในสภาพที่ดี โดยไม่มีรอยร้าวหรือการกัดกร่อน

E. OUTLET CAPS SECURE
ฝาครอบหัวจ่ายดับเพลิงแน่น

F. CLEAN AND GREASE OF MOVING PARTS
ทำความสะอาดและหล่อลื่นชิ้นส่วนที่เคลื่อนที่



A	B	C	D	E	F	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓	✓		HD1	SECURITY BOX2
✓	✓	✓	✓	✓	✓		HD2	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD3	SECURITY BOX4
✓	✓	✓	✓	✓	✓		HD4	SECURITY BOX4
✓	✓	✓	✓	✓	✓		HD5	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD6	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD7	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD8	JETTY BERTH1
✓	✓	✓	✓	✓	✓		HD9	JETTY BERTH2
✓	✓	✓	✓	✓	✓		HD10	JETTY BERTH3
✓	✓	✓	✓	✓	✓		HD11	JETTY BERTH4
✓	✓	✓	✓	✓	✓		HD12	JETTY BERTH5
✓	✓	✓	✓	✓	✓		HD13	JETTY BERTH6
✓	✓	✓	✓	✓	✓		HD14	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD15	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD16	PSB BUILDING-B / West
✓	✓	✓	✓	✓	✓		AHD-01	PSB W/1 - 04
✓	✓	✓	✓	✓	✓		FHD-01	FREE ZONE-CHEMICAL ROOM

REMARKS:

LEADER: PM team

PTTEP
PSB

**FIRE HOSE REEL
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT LOCATION: PSB DATE: _____

PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. THE HOSE REEL IS READILY ACCESSIBLE WITH NO OBSTACLES RESTRICTING ITS ACCESS
 (หัวฉีดหรือสายพานสามารถใช้งานได้โดยไม่ต้องขจัดสิ่งกีดขวาง การเข้าถึงสะดวก)

B. ANY DAMAGE OR CORROSION OF THE HOSE REEL(1= GOOD, 2= POOR, 3= BAD, 4= VERY BAD)
 ความเสียหายหรือการกัดกร่อนของสายฉีด (1 - ดี, 2 - พอใช้, 3 - ไม่ดี, 4 - ไม่ดีนัก)

C. THE NOZZLE IS RETAINED IN THE NOZZLE INTERLOCK
 หัวฉีดถูกขังรวมไว้ในหัวฉีดล็อกอัตโนมัติ

D. THE HOSE REEL CAN BE UNWOUND FREELY IN ITS INTENDED DIRECTION
 สายฉีดสามารถคลายออกได้อย่างอิสระในทิศทางที่กำหนด

E. CLEAN AND GREASE AS NECESSARY.
 ทำความสะอาดและหล่อลื่นตามจำเป็น

A	B	C	D	E	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓		FH10	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH01	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH02	PSB BUILDING-B / OFFICE FLOOR2
✓	✓	✓	✓	✓		FH03	PSB BUILDING-B / OFFICE FLOOR3
✓	✓	✓	✓	✓		FR4	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR5	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR6	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		FR7	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR8	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR9	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		AFR 01	PSB W/H 04
✓	✓	✓	✓	✓		FH-11	FREE ZONE CHEMICAL ROOM

REMARKS:

LEADER: *PM team*

PTTEP
PSB

**FIRE HOSE BOX
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT LOCATION: PSB DATE: 27/12/24

PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

HOSE BOX IN GOOD CONDITION WITHOUT CRACKS
 กล่องสายฉีดอยู่ในสภาพที่ดี ไม่มีรอยร้าว

A. SECURING STRAP & DOOR PACKING IN A GOOD CONDITION
 สายรัดและประตูบรรจุอยู่ในสภาพที่ดี

B. NOZZLE OF APPROPRIATE SIZE & TYPE
 หัวฉีดขนาดและประเภทที่เหมาะสม

C. FIRE HOSE OF APPROPRIATE LENGTH
 สายฉีดมีความยาวเหมาะสม

D. APPROPRIATE SPANNER
 ป้อนที่เหมาะสม

E. HOSE COUPLING IS PROPERLY CONNECTED
 การเชื่อมต่อสายฉีดเชื่อมต่อย่างถูกต้อง

F. NOZZLE IS FREELY MOVING
 หัวฉีดเคลื่อนที่อย่างอิสระ

G. หัวฉีดเคลื่อนที่อย่างอิสระ

A	B	C	D	E	F	G	REMARKS	LOCATION
✓	✓	✓	✓	✓	✓	✓	(FH 38 mm = 1 Pc) (FH 64 mm = 1 Pc) NOZZLE = 1 HAND TOOL = 1	JETTY BERTH - 1 (FH 01)
✓	✓	✓	✓	✓	✓	✓	(FH 38 mm = 1 Pc) (FH 64 mm = 1 Pc) NOZZLE = 1 HAND TOOL = 1	JETTY BERTH - 2 (FH 02)
✓	✓	✓	✓	✓	✓	✓	(FH 38 mm = 1 Pc) (FH 64 mm = 1 Pc) NOZZLE = 1 HAND TOOL = 1	JETTY BERTH - 4 (FH 03)
✓	✓	✓	✓	✓	✓	✓	(FH 38 mm = 1 Pc) (FH 64 mm = 1 Pc) NOZZLE = 1 HAND TOOL = 1	JETTY BERTH - 5 (FH 04)
✓	✓	✓	✓	✓	✓	✓	(FH 38 mm = 1 Pc) (FH 64 mm = 1 Pc) NOZZLE = 1 HAND TOOL = 1	JETTY BERTH - 6 (FH 05)
✓	✓	✓	✓	✓	✓	✓	(FH 38 mm = 1 Pc) (FH 64 mm = 1 Pc) NOZZLE = 1 HAND TOOL = 1	PSB JETTY RD 07 (FH 06)
✓	✓	✓	✓	✓	✓	✓	NOZZLE = 2 Y-VALVE = 1 HAND TOOL = 1	BEHIND PSB BUILDING-A

REMARKS:

LEADER: *PM team*

PTTEP
PSB

**EXTINGUISHER
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT LOCATION: PSB DATE: 27/12/24

PAGE 1 OF 6

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
 หัวฉีดดับเพลิงสามารถมองเห็นได้/ไม่มีสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE OR CLOGGED NOZZLE)
 ปินล็อกอยู่ในที่และซีลประตูไม่แตก (ไม่เสียหาย, ไม่กัดกร่อน, ไม่รั่วซึม, หัวฉีดไม่อุดตัน)

C. INDICATOR IS IN THE OPERABLE PORTION & ENSURE IT IS STILL FULL
 ตัวชี้วัดอยู่ในส่วนที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
 ข้อความบนป้ายชื่ออ่านได้และหันออกด้านนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
 วิศวกรที่ได้รับอนุญาตต้องตรวจสอบหัวฉีดดับเพลิงตามกำหนด

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		PP-01	Dry powder 6.8 kg	Security box 4	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-01	Cu2 4.5 kg	PSB OFFICE 1st FLOOR/ Room 108	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-02	Dry powder 6.8 kg	PSB 1st floor/Infront off medical	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-02	Cu2 4.5 kg	PSB OFFICE 1st FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-03	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-04	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 211	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-05	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-06	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ CPQC office	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-07	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-08	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ CPQC office	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-09	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-10	Dry powder 6.8 kg	PSB OFFICE 3rd floor/ Infront off media room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-11	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-12	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ Infront off media room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-03	Cu2 4.5 kg	PSB OFFICE floor/ Infront off media room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-04	Cu2 4.5 kg	PSB OFFICE floor/ IT room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-07	Cu2 4.5 kg	PSB Fire pump	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-14	Dry powder 6.8 kg	Security box 2	PSB BUILDING-B
✓	✓	✓	✓	✓		PP-15	Dry powder 6.8 kg	Security box 3	PSB BUILDING-B
✓	✓	✓	✓	✓		PP-16	Dry powder 6.8 kg	Security box 3	PSB BUILDING-B
✓	✓	✓	✓	✓		PP-17	Dry powder 6.8 kg	Fire service shop	PSB BUILDING-B
✓	✓	✓	✓	✓		PC-05	Cu2 4.5 kg	Electrical room	PSB BUILDING-B
✓	✓	✓	✓	✓		PC-06	Cu2 4.5 kg	Electrical room	PSB BUILDING-B
✓	✓	✓	✓	✓		PP-01	From 9 lines	Generator room	PSB BUILDING-B
✓	✓	✓	✓	✓		PP-02	From 9 lines	Generator room	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-01	Dry powder 6.8 kg	NEW PSB FLOOR1 E-S	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-02	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-03	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-04	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-05	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-06	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-07	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-08	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-09	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-10	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-11	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-12	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B

PTTEP
PSB

**EXTINGUISHER
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT LOCATION: PSB DATE: 27/12/24

PAGE 2 OF 6

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
 หัวฉีดดับเพลิงสามารถมองเห็นได้/ไม่มีสิ่งกีดขวาง


B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE OR CLOGGED NOZZLE)
 ปินล็อกอยู่ในที่และซีลประตูไม่แตก (ไม่เสียหาย, ไม่กัดกร่อน, ไม่รั่วซึม, หัวฉีดไม่อุดตัน)

C. INDICATOR IS IN THE OPERABLE PORTION & ENSURE IT IS STILL FULL
 ตัวชี้วัดอยู่ในส่วนที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
 ข้อความบนป้ายชื่ออ่านได้และหันออกด้านนอก


E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
 วิศวกรที่ได้รับอนุญาตต้องตรวจสอบหัวฉีดดับเพลิงตามกำหนด

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		NP-13	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-14	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		JP 01	Dry powder 6.8 kg	Security box 6	JETTY
✓	✓	✓	✓	✓		JP 02	Dry powder 6.8 kg	Fire hose reel box No.1	JETTY
✓	✓	✓	✓	✓		JP 03	Dry powder 6.8 kg	Fire hose reel box No.2	JETTY
✓	✓	✓	✓	✓		JP 04	Dry powder 6.8 kg	Fire hose reel box No.3	JETTY
✓	✓	✓	✓	✓		JP 05	Dry powder 6.8 kg	Fire hose reel box No.4	JETTY
✓	✓	✓	✓	✓		JP 06	Dry powder 6.8 kg	Fire hose reel box No.5	JETTY
✓	✓	✓	✓	✓		JP 07	Dry powder 6.8 kg	Infront off office	JETTY
✓	✓	✓	✓	✓		JP 08	Dry powder 6.8 kg	Infront off Electrical room	JETTY
✓	✓	✓	✓	✓		JP 09	Dry powder 6.8 kg	Security box 5	JETTY
✓	✓	✓	✓	✓		JP 10	Dry powder 6.8 kg	Container of CPQC	JETTY
✓	✓	✓	✓	✓		JP 11	Dry powder 6.8 kg	Generator Room 02	JETTY
✓	✓	✓	✓	✓		JP 12	Dry powder 6.8 kg	On the boat	JETTY
✓	✓	✓	✓	✓		JP 13	Dry powder 6.8 kg	Electrical room	JETTY
✓	✓	✓	✓	✓		JP 14	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 15	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 16	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 17	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 18	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 19	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 20	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 21	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 22	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 23	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 24	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 25	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 26	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 27	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 28	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 29	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 30	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 31	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 32	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 33	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 34	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 35	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 36	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 37	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 38	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 39	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 40	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 41	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 42	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 43	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 44	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 45	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 46	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 47	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 48	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 49	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 50	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 51	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 52	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓		JP 53	Dry powder 6.8 kg	Security box 3	JETTY
✓	✓	✓	✓	✓					



**EXTINGUISHER
MAINTENANCE SHEET
MONTHLY**

PSB SINGHA



SAFETY SERVICE

OPERATION UNIT LOCATION: PSB

DATE: 28/10/26

WORK DETAILS FOR EACH UNIT:


A. THE EXTINGUISHER IS VISIBLE & UNOBTSTRUCTED
 a. วัตถุถังดับเพลิงสามารถมองเห็นได้โดยไม่มีสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT, AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLES)
 b. สลักเกลียวที่ล็อกถังดับเพลิงยังใช้งานได้ (ไม่มีรอยแตก รอยกัดกร่อน รอยรั่ว หรือหัวฉีดอุดตัน)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
 c. ไม้ชี้ที่ถังดับเพลิงยังอยู่ในตำแหน่งที่ใช้งานได้ และตรวจสอบให้แน่ใจว่าถังดับเพลิงยังเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
 d. ข้อความคำแนะนำบนป้ายชื่อถังดับเพลิงสามารถมองเห็นได้และหันหน้าออก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
 e. ถังดับเพลิงต้องได้รับการตรวจสอบและบำรุงรักษาโดยช่างเทคนิคที่ได้รับอนุญาต






					REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		AP 15	Dry powder 6.8 kg	Infront off chemical room	PSB W0004
✓	✓	✓	✓	✓		AP 16	Dry powder 6.8 kg	Chemical room	PSB W0004
✓	✓	✓	✓	✓		AP 17	Dry powder 6.8 kg	Chemical room	PSB W0001
✓	✓	✓	✓	✓		AC 03	Cut 4.54 kg	Electrical room	PSB W0001
✓	✓	✓	✓	✓		AP 18	Dry powder 6.8 kg	Plant store	PSB W0001
✓	✓	✓	✓	✓		AF 01	From 9 Liter	Plant store	PSB W0001
✓	✓	✓	✓	✓		AF 02	From 9 Liter	Chemical room	PSB W0001
✓	✓	✓	✓	✓		AP 19	Dry powder 7.1 kg	Inside PSB Warehouse#4-Measurement	PSB W0004
✓	✓	✓	✓	✓		AP 20	Dry powder 9 kg	Inside PSB Warehouse#4-Measurement Deck E	PSB W0004
✓	✓	✓	✓	✓		AP 21	Dry powder 9 kg	Inside PSB Warehouse#4E3	PSB W0004
✓	✓	✓	✓	✓		AP 22	Dry powder 9 kg	Office PSB Warehouse#4E3	PSB W0004
✓	✓	✓	✓	✓		AP 23	Dry powder 9 kg	Inside PSB Warehouse#4E3	PSB W0004
✓	✓	✓	✓	✓		AP 24	Dry powder 9 kg	Inside PSB Warehouse#4N	PSB W0004
✓	✓	✓	✓	✓		AP 25	Dry powder 9 kg	PSB Warehouse#4E3	PSB W0004
✓	✓	✓	✓	✓		AP 26	Dry powder 6.8 kg	Inside PSB Warehouse#4	PSB W0004
✓	✓	✓	✓	✓		AC 04	Cut 4.54 kg	Office PSB Warehouse#4E3	PSB W0004
✓	✓	✓	✓	✓		AC 05	Cut 4.54 kg	PSB Warehouse#4 - Cool Room	PSB W0004
✓	✓	✓	✓	✓		AC 06	Cut 4.54 kg	PSB Warehouse#4 - Cool Room	PSB W0004
✓	✓	✓	✓	✓		AC 07	Cut 4.54 kg	PSB Warehouse#4 - Electrical Room	PSB W0004
✓	✓	✓	✓	✓		AC 08	Cut 4.54 kg	PSB Warehouse#4-Forklift battery charger	PSB W0004
✓	✓	✓	✓	✓		BP 01	Dry powder 6.8 kg	Security house 8	PSB W0004
✓	✓	✓	✓	✓		BP 02	Dry powder 6.8 kg	Infront off generator room	PSB W0004
✓	✓	✓	✓	✓		BC 01	Cut 4.54 kg	Infront off generator room	PSB W0004
✓	✓	✓	✓	✓		BF 03	From 9 Liter	Infront off generator room	PSB W0004
✓	✓	✓	✓	✓		BP 04	Dry powder 6.8 kg	Inside Ware house (N)	PSB W0004
✓	✓	✓	✓	✓		BP 05	Dry powder 6.8 kg	Inside Ware house (S)	PSB W0004
✓	✓	✓	✓	✓		BP 06	Dry powder 6.8 kg	Inside Ware house	PSB W0004
✓	✓	✓	✓	✓		BP 07	Dry powder 6.8 kg	Infront off pipe room office (N)	PSB W0004
✓	✓	✓	✓	✓		BP 08	Dry powder 6.8 kg	Infront off pipe room office (E)	PSB W0004
✓	✓	✓	✓	✓		BP 09	Dry powder 6.8 kg	Infront off Ware house (D)	PSB W0004
✓	✓	✓	✓	✓		BP 47	Dry powder 6.8 kg	Infront off Ware house (Door 2)	PSB W0004
✓	✓	✓	✓	✓		BP 48	Dry powder 23 kg	Infront off Ware house (Door 2)	PSB W0004
✓	✓	✓	✓	✓		BP 23	Dry powder 23 kg	Inside Ware house (Door2)	PSB W0004
✓	✓	✓	✓	✓		BP 09	Dry powder 23 kg	Infront off Ware house (E)	PSB W0004
✓	✓	✓	✓	✓		BP 10	Dry powder 6.8 kg	Office Ware house	PSB W0004
✓	✓	✓	✓	✓		BP 11	Dry powder 6.8 kg	Infront off coolroom AB1 w)	PSB W0004
✓	✓	✓	✓	✓		BC 02	Cut 4.54 kg	Infront off coolroom AB1 E)	PSB W0004
✓	✓	✓	✓	✓		BP 12	Dry powder 6.8 kg	Infront off coolroom C2	PSB W0004
✓	✓	✓	✓	✓		BP 13	Dry powder 6.8 kg	Inside coolroom C2	PSB W0004



 PTTEP PSB		EXTINGUISHER MAINTENANCE SHEET MONTHLY		DATE: <u>18/09/24</u>		PSB SONGKHLA  SAFETY SERVICE PAGE 4 OF 6			
OPERATION UNIT		LOCATION: PSB							
WORK DETAILS FOR EACH UNIT:									
A. THE EXTINGUISHER IS VISIBLE & UNOBSSTRUCTED หน่วยดับเพลิงสามารถเข้าถึงได้โดยไม่มีสิ่งกีดขวาง									
B. THE LOCKING PIN IS INTACT AND THE RAISER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE) ตัวล็อกและซีลลิฟต์ยังใช้งานได้ปกติ (ไม่มีรอยแตกเสียหาย รั่วซึม หรือหัวฉีดอุดตัน)									
C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL ตัวชี้วัดยังอยู่ในตำแหน่งที่ใช้งานได้และตรวจสอบให้แน่ใจว่ายังมีน้ำมันเต็ม									
D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD ข้อความบนป้ายชื่ออ่านได้และหันออกด้านนอก									
E. A LICENSED PSB EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED พนักงานที่ได้รับอนุญาตต้องตรวจสอบและบันทึกผลการตรวจสอบ									
									
A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		BP 19	Dry powder 6.8 kg	Zone M 2nd floor	PSB W1046
✓	✓	✓	✓	✓		BP 20	Dry powder 6.8 kg	Inside Ware house	PSB W1014
✓	✓	✓	✓	✓		BP 21	Dry powder 6.8 kg	Inside Ware house	PSB W1014
✓	✓	✓	✓	✓		BP 22	Dry powder 6.8 kg	Inside Ware house	PSB W1014
✓	✓	✓	✓	✓		BP 24	Dry powder 6.8 kg	Infront off Stock control(W)	PSB W1014
✓	✓	✓	✓	✓		BP 25	Dry powder 6.8 kg	Infront off Stock control(W)	PSB W1014
✓	✓	✓	✓	✓		BP 26	Dry powder 6.8 kg	Infront off Stock control(E)	PSB W1014
✓	✓	✓	✓	✓		BP 27	Dry powder 6.8 kg	Infront off Stock control(E)	PSB W1014
✓	✓	✓	✓	✓		BC 04	Co2 4.5kg	Infront off Stock control Office	PSB W1014
✓	✓	✓	✓	✓		BC 05	Co2 4.5kg	Inside chemical room	PSB W1014
✓	✓	✓	✓	✓		BP 28	Dry powder 6.8 kg	Inside chemical room	PSB W1014
✓	✓	✓	✓	✓		BP 29	Dry powder 23 kg	Infront off chemical room	PSB W1014
✓	✓	✓	✓	✓		BP 30	Dry powder 23 kg	Infront off chemical room	PSB W1014
✓	✓	✓	✓	✓		BP 45	Dry powder 6.8 kg	Paint store	PSB W1014
✓	✓	✓	✓	✓		BP 31	Dry powder 6.8 kg	Maintenance work shop	PSB W1014
✓	✓	✓	✓	✓		BP 32	Dry powder 6.8 kg	Maintenance work shop	PSB W1014
✓	✓	✓	✓	✓		BP 33	Dry powder 6.8 kg	Inside maintenance work shop	PSB W1014
✓	✓	✓	✓	✓		BP 34	Dry powder 6.8 kg	Infront off maintenance work shop	PSB W1014
✓	✓	✓	✓	✓		BP 46	Dry powder 6.8 kg	Infront off maintenance work shop	PSB W1014
✓	✓	✓	✓	✓		BP 35	Dry powder 6.8 kg	Office W	PSB W1014
✓	✓	✓	✓	✓		BP 36	Dry powder 6.8 kg	Office E	PSB W1014
✓	✓	✓	✓	✓		BC 06	Co2 4.5kg	Office (Lobby)	PSB W1014
✓	✓	✓	✓	✓		BF 04	Foam 9 litres	Inside chemical room	PSB W1014
✓	✓	✓	✓	✓		BP 27	Dry powder 6.8 kg	Infront off waste area office	WASTE AREA
✓	✓	✓	✓	✓		BP 38	Dry powder 23 kg	Infront off waste area office	WASTE AREA
✓	✓	✓	✓	✓		BP 39	Dry powder 6.8 kg	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BF 01	Foam 9 litres	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BF 02	Foam 9 litres	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BP 05	Foam 9 litres	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BP 40	Dry powder 23 kg	Waste area (F1)	WASTE AREA
✓	✓	✓	✓	✓		BP 41	Dry powder 6.8 kg	Infront off EMI warehouse	EMI WH
✓	✓	✓	✓	✓		BP 42	Dry powder 6.8 kg	Infront off EMI warehouse	EMI WH
✓	✓	✓	✓	✓		BP 44	Dry powder 6.8 kg	Valitor area	PSB Valitor Area
✓	✓	✓	✓	✓		EP 01	Dry powder 6.8 kg	Security box 1	EMI 1
✓	✓	✓	✓	✓		EP 02	Dry powder 6.8 kg	EMI 1st floor (N)	EMI 1
✓	✓	✓	✓	✓		EP 03	Dry powder 6.8 kg	EMI 1st floor (E)	EMI 1
✓	✓								




 P.T.T.E.P PSB					EXTINGUISHER MAINTENANCE SHEET MONTHLY		P.S.B SONGKHLA SAFETY SERVICE		
OPERATION UNIT		LOCATION: PSB			DATE: 19/12/24		PAGE 5 OF 6		
WORK DETAILS FOR EACH UNIT:									
A. THE EXTINGUISHER IS VISIBLE, & UNOBSTRUCTED ถังดับเพลิงสามารถมองเห็นได้โดยไม่มีสิ่งกีดขวาง									
B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE ปินล็อกที่ติดกับถังดับเพลิงยังใช้งานได้ และซีลประตูไม่มีชำรุดเสียหาย, ไม่มีการกัดกร่อน, ไม่รั่วซึม, หรือหัวฉีดอุดตัน									
INDICATOR IS IN THE OPERABLE POSITION & INSURE IT IS STILL FULL ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และมั่นใจว่าถังดับเพลิงยังเต็ม									
THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD คำสั่งการใช้งานบนป้ายระบุข้อมูลถังดับเพลิงสามารถอ่านได้ และหันออกด้านนอก									
A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED ถังดับเพลิงต้องได้รับการตรวจสอบโดยช่างเทคนิคที่ได้รับการรับรอง									
A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		EP-08	Dry powder 6.8 kg	EMI 1st floor (N-W)	EMI-2
✓	✓	✓	✓	✓		EC-01	Co2 4.5 kg	EMI 1st floor (S-W)	EMI-2
✓	✓	✓	✓	✓		EP-09	Dry powder 6.8 kg	EMI 2nd floor (N)	EMI-2
✓	✓	✓	✓	✓		EP-10	Dry powder 6.8 kg	EMI 2nd floor (S)	EMI-2
✓	✓	✓	✓	✓		EC-02	Co2 4.5 kg	EMI 2nd floor inside room	EMI-2
✓	✓	✓	✓	✓		EP-11	Dry powder 6.8 kg	Well service office 2nd floor	WELL SERVICE
✓	✓	✓	✓	✓		EP-12	Dry powder 6.8 kg	1st floor Infront off Meeting room	WELL SERVICE
✓	✓	✓	✓	✓		EP-13	Dry powder 6.8 kg	1st floor In front off Ciel room	WELL SERVICE
✓	✓	✓	✓	✓		EP-14	Dry powder 6.8 kg	Container office	WELL SERVICE
✓	✓	✓	✓	✓		EP-15	Dry powder 6.8 kg	Roof shade steel	WELL SERVICE
✓	✓	✓	✓	✓		EP-16	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP-17	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP-18	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP-19	Dry powder 6.8 kg	Work shop (N-E)	WELL SERVICE
✓	✓	✓	✓	✓		EP-20	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EC-03	Co2 4.5 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EP-21	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EP-22	Dry powder 6.8 kg	EMI W503 workshop - NW	EMI W503
✓	✓	✓	✓	✓		EP-23	Dry powder 6.8 kg	EMI W503 workshop - SW	EMI W503
✓	✓	✓	✓	✓		EP-24	Dry powder 6.8 kg	EMI W503 workshop - SE	EMI W503
✓	✓	✓	✓	✓		EP-25	Dry powder 6.8 kg	EMI W503 workshop - NE	EMI W503
✓	✓	✓	✓	✓		EP-26	Dry powder 6.8 kg	EMI W503 Warehouse - E	EMI W503
✓	✓	✓	✓	✓		EP-27	Dry powder 6.8 kg	EMI W503 Warehouse - W	EMI W503
✓	✓	✓	✓	✓		EP-28	Dry powder 6.8 kg	EMI W503 Office flooroff - E	EMI W503
✓	✓	✓	✓	✓		EP-29	Dry powder 6.8 kg	EMI W503 Office flooroff - W	EMI W503
✓	✓	✓	✓	✓		EC-04	Co2 4.5 kg	EMI W503 Warehouse - W/Electrical room	EMI W503
✓	✓	✓	✓	✓		EC-05	Co2 4.5 kg	EMI W503 Warehouse - W/Electrical room	EMI W503
✓	✓	✓	✓	✓		CP-01	Dry powder 6.8 kg	Cpec waste house (S-E)	CP0C
✓	✓	✓	✓	✓		CP-02	Dry powder 6.8 kg	Cpec waste house (S-E)	CP0C
✓	✓	✓	✓	✓		CP-03	Dry powder 6.8 kg	Cpec waste house (S-W)	CP0C
✓	✓	✓	✓	✓		CP-04	Dry powder 6.8 kg	Cpec waste house (N-W)	CP0C
✓	✓	✓	✓	✓		CP-05	Dry powder 6.8 kg	Cpec roof shade	CP0C
✓	✓	✓	✓	✓		CP-06	Dry powder 6.8 kg	Cpec roof shade	CP0C
✓	✓	✓	✓	✓		CP-07	Dry powder 6.8 kg	Infront off cool room	CP0C
✓	✓	✓	✓	✓		CP-08	Dry powder 6.8 kg	Infront off cool room	CP0C
✓	✓	✓	✓	✓					


 PTTEP PSB EXTINGUISHER MAINTENANCE SHEET MONTHLY					PSB SONGKHLA SAFETY SERVICE PAGE 6 OF 6				
OPERATION UNIT		LOCATION: PSB		DATE: 10/19/24					
WORK DETAILS FOR EACH UNIT. A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED เครื่องดับเพลิงสามารถมองเห็นได้โดยสะดวก B. THE LOCKING PIN IS EXTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE) ตัวล็อกและซีลที่ป้องกันการรั่วซึม (ไม่มีความเสียหาย ร้าวฉีก หรืออุดตัน) C. INDICATOR IS IN THE OPERABLE PORTION & ENSURE IT IS STILL FULL ตัวชี้วัดอยู่ในส่วนที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีของเหลว D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD ข้อแนะนำบนฉลากต้องสามารถมองเห็นได้ชัดเจนและหันออก E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED ได้รับการตรวจสอบจากผู้ชำนาญการ (มีใบอนุญาต) และผ่านการตรวจสอบ									
A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		LP 65	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 131	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 54	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 130	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 133	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 137	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 136	Dry powder 6.8 kg	CHEMICAL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 137	Dry powder 6.8 kg	CHEMICAL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LF 08	From 9 LTR	CHEMICAL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 147	Dry powder 6.8 kg	SECURITY YARD 1	FREE ZONE
✓	✓	✓	✓	✓		LP 05	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 06	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 07	Dry powder 6.8 kg	CUSTOMS OFFICE	FREE ZONE
✓	✓	✓	✓	✓		LP 32	Dry powder 6.8 kg	PSB-WH01 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓		LP 35	Dry powder 6.8 kg	PSB-WH03 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓		LP 146	Dry powder 6.8 kg	IN FRONT OF ROOF SHADE	FREE ZONE
✓	✓	✓	✓	✓		LP 80	Dry powder 6.8 kg	SECURITY BOX No.9	FREE ZONE
✓	✓	✓	✓	✓		LC 01	5.0 6.8 kg	INSIDE CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 09	From 9 LTR	CHEMICAL ROOM	FREE ZONE
✓	✓	✓	✓	✓		LP 45	Dry powder 6.8 kg	TERMINAL CHECK IN / WEST	TERMINAL
✓	✓	✓	✓	✓		LP 46	Dry powder 6.8 kg	TERMINAL CHECK IN / EAST	TERMINAL
✓	✓	✓	✓	✓		AP 27	Dry powder 6.8 kg	PSB Warehouse#5-NW	PSB Warehouse#5
✓	✓	✓	✓	✓		AP 28	Dry powder 6.8 kg	PSB Warehouse#5-SW	PSB Warehouse#5
✓	✓	✓	✓	✓		AP 29	Dry powder 6.8 kg	PSB Warehouse#5-SE	PSB Warehouse#5
✓	✓	✓	✓	✓		AP 30	Dry powder 6.8 kg	PSB Warehouse#5-NE	PSB Warehouse#5
REMARK:									

 PTTEP PSB OPERATION UNIT		FIRE MAN BOX MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION : PSB		DATE : 18/12/24			
WORK DETAILS FOR EACH UNIT A. CHECK FIRE SUIT, FIRE HELMET, BOOTS, GLOVES & OTHER EQUIPMENT AVAILABLE ตรวจสอบชุดดับเพลิงพร้อม อุปกรณ์ดับเพลิงอื่น ๆ B. SECURING STRAP, DOOR, PACKING AND LOCK FUNCTIONS IN A GOOD CONDITION ยึดสายรัดประตู อุปกรณ์บรรจุ และ ฟังก์ชันการล็อกให้อยู่ในสภาพที่ดี C. CLEAN & READY TO USE ทำความสะอาดพร้อมใช้งาน					
					
A	B	C	REMARKS		LOCATION
✓	✓	✓	<input checked="" type="checkbox"/> FIRE SUIT - 4 Pcs. <input checked="" type="checkbox"/> FIRE HELMET - 4 Pcs. <input checked="" type="checkbox"/> BOOTS - 4 Pcs. <input checked="" type="checkbox"/> GLOVES - 4 Pcs. <input checked="" type="checkbox"/> FOAM INJECTION - 1 Pcs. <input checked="" type="checkbox"/> VALVE - 1 Pcs.		JETTY
✓	✓	✓	<input checked="" type="checkbox"/> FIRE SUIT - 4 Pcs. <input checked="" type="checkbox"/> FIRE HELMET - 4 Pcs. <input checked="" type="checkbox"/> BOOTS - 4 Pcs. <input checked="" type="checkbox"/> GLOVES - 4 Pcs.		FIRE SERVICE WORKSHOP
✓	✓	✓	<input checked="" type="checkbox"/> FIRE SUIT - 4 Pcs. <input checked="" type="checkbox"/> FIRE HELMET - 4 Pcs. <input checked="" type="checkbox"/> BOOTS - 4 Pcs. <input checked="" type="checkbox"/> GLOVES - 4 Pcs.		BEHIND PSB BUILDING-A
REMARKS					
LEADER: PM Team					


 PTTEP PSB OPERATION UNIT		LIFEBOUY MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION : PSB		DATE : 18/12/24			
WORK DETAILS FOR EACH UNIT A. LIFEBOUY IS ACCESSIBLE & EASILY REMOVED FOR USE ทุ่นชูชีพสามารถใช้งานได้สะดวกโดยไม่มีสิ่งกีดขวางการใช้งาน B. VISUALLY INSPECT THE LIFEBOUY FOR DAMAGE ตรวจสอบทุ่นชูชีพเพื่อหาความเสียหาย C. LIFEBOUY IS SEALED WITH A PLUG ทุ่นชูชีพถูกปิดผนึกด้วยจุกอุดรู D. THE GRAB LINE AROUND THE CIRCUMFERENCE IS NOT DAMAGED สายจับรอบ ๆ ทุ่นไม่มีความเสียหาย					
					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		LBV-1 JETTY-N/E
✓	✓	✓	✓		LBV-2 JETTY BERTH - 1
✓	✓	✓	✓		LBV-3 JETTY BERTH - 2
✓	✓	✓	✓		LBV-4 JETTY BERTH - 3
✓	✓	✓	✓		LBV-5 JETTY BERTH - 4
✓	✓	✓	✓		LBV-6 JETTY BERTH - 5
✓	✓	✓	✓		LBV-7 JETTY BERTH - 6
✓	✓	✓	✓		LBV-8 JETTY S/W
✓	✓	✓	✓		LBV-9 JETTY N/W
✓	✓	✓	✓		LBV-10 JETTY BOAT
✓	✓	✓	✓		LBV-11 JETTY BOAT
REMARKS					
LEADER: PM Team					

 PTTEP PSB OPERATION UNIT		STRETCHER MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION : PSB		DATE : 18/12/24			
WORK DETAILS FOR EACH UNIT A. THE STRETCHER FREE OF EXCESSIVE WEAR เสาขาที่เกี่ยวของที่สะอาด B. ALL MOVING PART (COUPLING, LEVERS, HINGES, AND SLIDING FRAMES) OPERATE PROPERLY องค์ประกอบที่เคลื่อนไหว (การเชื่อมต่อ, คันโยก,บานพับ และ โครงเลื่อน) ทำงานได้อย่างถูกต้อง C. THE COUPLING PINS ARE SECURELY IN PLACE 销釘ที่เชื่อมอยู่ในที่อย่างถาวร D. THE FOOT SECTION LOCK PROPERLY INTO EACH POSITION ส่วนล็อกที่เท้าถูกใส่ในตำแหน่งที่ถูกต้อง E. THE HEAD-AND FOOT-END COUPLING REQUIRE LUBRICATION ส่วนหัวและส่วนท้ายต้องมีการหล่อลื่น					
					
A	B	C	D	E	REMARKS
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
REMARKS					
LEADER: PM Team					

 PTTEP PSB OPERATION UNIT		SAFETY SHOWER MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION : PSB		DATE : 18/12/24			
WORK DETAILS FOR EACH UNIT A. EASILY LOCATED & ACCESSIBLE ACTUATOR ติดตั้งไว้ได้ง่ายและเข้าถึงได้ง่าย B. GOOD CENTER OF WATER PATTERN จุดศูนย์กลางน้ำที่พ่น C. COVERS ARE REMOVED BY WATER FLOW ที่ครอบจะถูกลบออกโดยน้ำที่ไหล D. VALVE ACTUATOR IS EASY TO LOCATE ตัวหัววาล์วจะง่ายต่อการติดตั้ง					
					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		CHEMICAL ROOM - PSB W382
✓	✓	✓	✓		WASTE AREA
✓	✓	✓	✓		CHEMICAL ROOM - PSB W386
✓	✓	✓	✓		FREE ZONE
✓	✓	✓	✓		CPOC ROOF SHED
REMARKS					
LEADER: PM Team					



PSB
FIRE FIGHTING EQUIPMENT
MONTHLY CHECK LIST




OPERATION UNIT

	ISSUED	RETURN	COMPLETED
1. FIRE HYDRANT	30/04/24	30/04/24	100%
2. FIRE HOSE REEL	30/04/24	30/04/24	100%
3. FIRE HOSE	30/04/24	30/04/24	100%
4. EXTINGUISHER	30/04/24	30/04/24	100%
5. FIRE MAN TQP.	30/04/24	30/04/24	100%
6. LIFEBOUY	30/04/24	30/04/24	100%
7. STRETCHER	30/04/24	30/04/24	100%
8. SAFETY SHOWER	30/04/24	30/04/24	100%
9. EYE WASH STATION	30/04/24	30/04/24	100%
10. TROCH	30/04/24	30/04/24	100%
11. FIRE ALARM	30/04/24	30/04/24	100%
12. EMERGENCY PHONE	30/04/24	30/04/24	100%
13. FIRE HOSE TROLLEY	30/04/24	30/04/24	100%
TASK COMPLETED			100%

TIME SPENDING: 20.45 MAN/HR


REMARK:

CHECK BY: PM Jorm DATE: 30/04/2024



PTTEP
PSB
FIRE HYDRANT
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA



SAFETY SERVICE

OPERATION UNIT LOCATION: PSB DATE: 30/04/24 PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. HYDRANTS ARE ACCESSIBLE & FREE OF OBSTRUCTION
หัวจ่ายดับเพลิงสามารถใช้งานได้สะดวก ไม่มีสิ่งกีดขวาง


B. TOP OF HYDRANT IS NOT LEAKING WHEN HYDRANT IS ON
ด้านบนของหัวจ่ายดับเพลิงไม่รั่วไหลเมื่อมีการเปิดหัวจ่าย

C. RUBBER SEAL UNDER CAPS ARE NOT LEAKING
ซีลยางภายใต้ฝาครอบไม่รั่วไหล

D. HYDRANT BARREL IS IN GOOD CONDITION WITHOUT CRACKS OR CORROSION
เสาหัวจ่ายดับเพลิงอยู่ในสภาพที่ดี โดยไม่มีรอยร้าวหรือการกัดกร่อน

E. OUTLET CAPS SECURE
ฝักการเชื่อมต่อปลอดภัย


F. CLEAN AND GREASE OF MOVING PARTS
ทำความสะอาดและหล่อลื่นชิ้นส่วนที่เคลื่อนไหว



A	B	C	D	E	F	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓	✓		HD1	SECURITY BOX2
✓	✓	✓	✓	✓	✓		HD2	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD3	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD4	SECURITY BOX4
✓	✓	✓	✓	✓	✓		HD5	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD6	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD7	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD8	JETTY BERTH1
✓	✓	✓	✓	✓	✓		HD9	JETTY BERTH2
✓	✓	✓	✓	✓	✓		HD10	JETTY BERTH3
✓	✓	✓	✓	✓	✓		HD11	JETTY BERTH4
✓	✓	✓	✓	✓	✓		HD12	JETTY BERTH5
✓	✓	✓	✓	✓	✓		HD13	JETTY BERTH6
✓	✓	✓	✓	✓	✓		HD14	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD15	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD16	PSB BUILDING-B / West
✓	✓	✓	✓	✓	✓		AJID-01	PSB WH - 04
✓	✓	✓	✓	✓	✓		FHD-01	FREE ZONE-CHEMICAL ROOM


REMARKS:

LEADER: PM Jorm



PTTEP
PSB
FIRE HOSE REEL
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA



SAFETY SERVICE

OPERATION UNIT LOCATION: PSB DATE: 30/04/24 PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT


A. THE HOSE REEL IS READILY ACCESSIBLE WITH NO OBSTACLES RESTRICTING ITS ACCESS
ตู้หัวรีลสามารถใช้งานได้สะดวก ไม่มีสิ่งกีดขวาง การเข้าถึงการเข้าถึง

B. ANY DAMAGE OR CORROSION OF THE HOSE REEL (1= GOOD, 2= POOR, 3= BAD, 4= VERY BAD)
ความเสียหายใด ๆ หรือการกัดกร่อนของรีล (1 = ดี, 2 = พอใช้, 3 = ไม่ดี, 4 = ไม่ดีเลย)

C. THE NOZZLE IS RETAINED IN THE NOZZLE INTERLOCK
หัวฉีดถูกรักษาไว้ในหัวฉีดอินเทอร์ล็อก

D. THE HOSE REEL CAN BE UNWOUND FREELY IN ITS INTENDED DIRECTION
การปล่อยรีลสามารถปล่อยออกได้อย่างอิสระในทิศทางที่ตั้งใจ

E. CLEAN AND GREASE AS NECESSARY.
การทำความสะอาดและหล่อลื่นตามจำเป็น



A	B	C	D	E	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓		FH10	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH01	PSB BUILDING-B / OFFICE FLOOR2
✓	✓	✓	✓	✓		FH02	PSB BUILDING-B / OFFICE FLOOR2
✓	✓	✓	✓	✓		FH03	PSB BUILDING-B / OFFICE FLOOR3
✓	✓	✓	✓	✓		FR4	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR5	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR6	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		FR7	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR8	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR9	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		AFR 01	PSB WH 04
✓	✓	✓	✓	✓		FH-11	FREE ZONE CHEMICAL ROOM

REMARKS:

LEADER: PM Jorm



PTTEP
PSB
FIRE HOSE BOX
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA



SAFETY SERVICE

OPERATION UNIT LOCATION: PSB DATE: 30/04/24 PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. HOSE BOX IN GOOD CONDITION WITHOUT CRACKS
กล่องเก็บรีลอยู่ในสภาพที่ดี ไม่มีรอยร้าว

B. SECURING STRAP & DOOR PACKING IN A GOOD CONDITION
สายรัดและประตูบรรจุอยู่ในสภาพที่ดี

C. NOZZLE OF APPROPRIATE SIZE & TYPE
หัวฉีดขนาดและประเภทที่เหมาะสม

D. FIRE HOSE OF APPROPRIATE LENGTH
สายฉีดน้ำหัวฉีดมีความยาวที่เหมาะสม

E. APPROPRIATE SPANNER
ประแจที่เหมาะสม

F. HOSE COUPLING IS PROPERLY CONNECTED
การเชื่อมต่อท่อถูกเชื่อมต่ออย่างถูกต้อง

G. NOZZLE IS FREELY MOVING
หัวฉีดเคลื่อนที่อย่างอิสระ



A	B	C	D	E	F	G	REMARKS	LOCATION
✓	✓	✓	✓	✓	✓	✓	<input checked="" type="checkbox"/> (FH 38 mm = 1 Pc) <input checked="" type="checkbox"/> (FH 64 mm = 1 Pc) <input checked="" type="checkbox"/> NOZZLE = 1 <input checked="" type="checkbox"/> HAND TOOL = 1	JETTY BERTH - 1 (FH 01)
✓	✓	✓	✓	✓	✓	✓	<input checked="" type="checkbox"/> (FH 38 mm = 1 Pc) <input checked="" type="checkbox"/> (FH 64 mm = 1 Pc) <input checked="" type="checkbox"/> NOZZLE = 1 <input checked="" type="checkbox"/> HAND TOOL = 1	JETTY BERTH - 2 (FH 02)
✓	✓	✓	✓	✓	✓	✓	<input checked="" type="checkbox"/> (FH 38 mm = 1 Pc) <input checked="" type="checkbox"/> (FH 64 mm = 1 Pc) <input checked="" type="checkbox"/> NOZZLE = 1 <input checked="" type="checkbox"/> HAND TOOL = 1	JETTY BERTH - 4 (FH 03)
✓	✓	✓	✓	✓	✓	✓	<input checked="" type="checkbox"/> (FH 38 mm = 1 Pc) <input checked="" type="checkbox"/> (FH 64 mm = 1 Pc) <input checked="" type="checkbox"/> NOZZLE = 1 <input checked="" type="checkbox"/> HAND TOOL = 1	JETTY BERTH - 5 (FH 04)
✓	✓	✓	✓	✓	✓	✓	<input checked="" type="checkbox"/> (FH 38 mm = 1 Pc) <input checked="" type="checkbox"/> (FH 64 mm = 1 Pc) <input checked="" type="checkbox"/> NOZZLE = 1 <input checked="" type="checkbox"/> HAND TOOL = 1	JETTY BERTH - 6 (FH 05)
✓	✓	✓	✓	✓	✓	✓	<input checked="" type="checkbox"/> (FH 38 mm = 1 Pc) <input checked="" type="checkbox"/> (FH 64 mm = 1 Pc) <input checked="" type="checkbox"/> NOZZLE = 1 <input checked="" type="checkbox"/> HAND TOOL = 1	PSB JETTY HD 07 (FH 08)
✓	✓	✓	✓	✓	✓	✓	<input checked="" type="checkbox"/> NOZZLE = 2 <input checked="" type="checkbox"/> Y-VALVE = 1 <input checked="" type="checkbox"/> HAND TOOL = 1	BEHIND PSB BUILDING-A

REMARKS:

LEADER: PM Jorm

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE

OPERATION UNIT


LOCATION: PSB

DATE: 30/04/24

PAGE 1 OF 6

WORK DETAILS FOR EACH UNIT

- A. THE EXTINGUISHER IS VISIBLE & UNOBSERVED
ดับเพลิงสามารถมองเห็นได้และไม่มีการกีดขวาง
- B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
สลักเกลียวล็อกไม่เสียหายและไม่แตก (ไม่มีการฉีกขาด รั่วซึม หรืออุดตันหัวฉีด)
- C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีของเหลวเต็ม
- D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
ข้อความบนป้ายชื่ออ่านได้และหันหน้าออก
- E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ช่างซ่อมบำรุงถังดับเพลิงที่ได้รับอนุญาตต้องตรวจสอบแล้ว



A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		PP-01	Dry powder 6.8 kg	Security box 4	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-02	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ Room 108	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-03	Co2 4.5 kg	PSB 1st floor/entrance off medical	PSB BUILDING-B
✓	✓	✓	✓	✓		PP-04	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-05	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-06	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 211	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-07	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-08	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ CPOC office	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-09	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-10	Dry powder 6.8 kg	PSB office 3th floor / fire hose box	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-11	Dry powder 6.8 kg	PSB OFFICE 3th FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-12	Dry powder 6.8 kg	PSB OFFICE 3th FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-03	Co2 4.5 kg	PSB office floor3 /entrance off radio room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-04	Co2 4.5 kg	PSB office floor3 / IT room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-07	Co2 4.5 kg	PSB Fire pump	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-14	Dry powder 6.8 kg	Driver room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-15	Dry powder 6.8 kg	Security box 2	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-16	Dry powder 6.8 kg	Security box 3	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-17	Dry powder 6.8 kg	Fire service shop	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-05	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-06	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-01	Power 9 Liter	Generator room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-02	Power 9 Liter	Generator room	PSB BUILDING-A
✓	✓	✓	✓	✓		NP-01	Dry powder 6.8 kg	NEW PSB FLOOR1 E/S	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-02	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-03	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-04	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-05	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-06	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-07	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-08	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-09	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-10	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-11	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-12	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE

OPERATION UNIT

LOCATION: PSB

DATE: 30/04/24

PAGE 2 OF 6

WORK DETAILS FOR EACH UNIT

- A. THE EXTINGUISHER IS VISIBLE & UNOBSERVED
ดับเพลิงสามารถมองเห็นได้และไม่มีการกีดขวาง
- B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
สลักเกลียวล็อกไม่เสียหายและไม่แตก (ไม่มีการฉีกขาด รั่วซึม หรืออุดตันหัวฉีด)
- C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีของเหลวเต็ม
- D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
ข้อความบนป้ายชื่ออ่านได้และหันหน้าออก
- E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ช่างซ่อมบำรุงถังดับเพลิงที่ได้รับอนุญาตต้องตรวจสอบแล้ว



A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		NP-13	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-14	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		JP 01	Dry powder 6.8 kg	Security box 6	JETTY
✓	✓	✓	✓	✓		JP 02	Dry powder 6.8 kg	Fire hose reel box No.1	JETTY
✓	✓	✓	✓	✓		JP 03	Dry powder 6.8 kg	Fire hose reel box No.2	JETTY
✓	✓	✓	✓	✓		JP 04	Dry powder 6.8 kg	Fire hose reel box No.3	JETTY
✓	✓	✓	✓	✓		JP 05	Dry powder 6.8 kg	Fire hose reel box No.4	JETTY
✓	✓	✓	✓	✓		JP 06	Dry powder 6.8 kg	Fire hose reel box No.5	JETTY
✓	✓	✓	✓	✓		JP 07	Dry powder 6.8 kg	Infront off office	JETTY
✓	✓	✓	✓	✓		JP 08	Dry powder 6.8 kg	Infront off Electrical room	JETTY
✓	✓	✓	✓	✓		JP 09	Dry powder 6.8 kg	Security box 5	JETTY
✓	✓	✓	✓	✓		JP 11	Dry powder 2.5 kg	Container of CPOC	JETTY
✓	✓	✓	✓	✓		JP 07	Power 9 Liter	Generator Room 02	JETTY
✓	✓	✓	✓	✓		JP10	Dry powder 2.5 kg	On the boat	JETTY
✓	✓	✓	✓	✓		JP10	Dry powder 2.5 kg	Electrical room	JETTY
✓	✓	✓	✓	✓		JP 22	Co2 4.54 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 21	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 18	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 19	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 20	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PC 08	Co2 4.5 kg	Canteen	PSB
✓	✓	✓	✓	✓		MF 01	Power 50 Liter	Security box 3	PSB
✓	✓	✓	✓	✓		AP 01	Dry powder 6.8 kg	PSB WAREHOUSE#1-office	PSB WARE
✓	✓	✓	✓	✓		AC 01	Co2 4.54 kg	PSB Warehouse#1-office	PSB WARE
✓	✓	✓	✓	✓		AP 02	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WARE
✓	✓	✓	✓	✓		AP 03	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WARE
✓	✓	✓	✓	✓		AP 04	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WARE
✓	✓	✓	✓	✓		AP 05	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WARE
✓	✓	✓	✓	✓		AP 06	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WARE
✓	✓	✓	✓	✓		AP 07	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WARE
✓	✓	✓	✓	✓		AP 08	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WARE
✓	✓	✓	✓	✓		AP 09	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WARE
✓	✓	✓	✓	✓		AC 02	Co2 4.54 kg	Arbit waste house/entrance off cool room	PSB WARE
✓	✓	✓	✓	✓		AP 10	Dry powder 6.8 kg	Inside Arbit waste house(N)	PSB WARE
✓	✓	✓	✓	✓		AP 11	Dry powder 6.8 kg	Inside PSB W/H#1-roof shade	PSB WARE
✓	✓	✓	✓	✓		AP 12	Dry powder 6.8 kg	Inside PSB W/H#1-roof shade	PSB WARE
✓	✓	✓	✓	✓		AP 13	Dry powder 6.8 kg	PSB W/H#2-waste transit	PSB WARE
✓	✓	✓	✓	✓		AP 14	Dry powder 6.8 kg	PSB W/H#2-waste transit	PSB WARE

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE

OPERATION UNIT


LOCATION: PSB

DATE: 30/04/24

PAGE 3 OF 6

WORK DETAILS FOR EACH UNIT

- A. THE EXTINGUISHER IS VISIBLE & UNOBSERVED
ดับเพลิงสามารถมองเห็นได้และไม่มีการกีดขวาง
- B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
สลักเกลียวล็อกไม่เสียหายและไม่แตก (ไม่มีการฉีกขาด รั่วซึม หรืออุดตันหัวฉีด)
- C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีของเหลวเต็ม
- D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
ข้อความบนป้ายชื่ออ่านได้และหันหน้าออก
- E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ช่างซ่อมบำรุงถังดับเพลิงที่ได้รับอนุญาตต้องตรวจสอบแล้ว



A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		AP 15	Dry powder 6.8 kg	Infront off chemical room	PSB WARE
✓	✓	✓	✓	✓		AP 16	Dry powder 6.8 kg	Chemical room	PSB WARE
✓	✓	✓	✓	✓		AP 17	Dry powder 6.8 kg	Chemical room	PSB WARE
✓	✓	✓	✓	✓		AC 03	Co2 4.54 kg	Electrical room	PSB WARE
✓	✓	✓	✓	✓		AP 18	Dry powder 6.8 kg	Paint store	PSB WARE
✓	✓	✓	✓	✓		AP 01	Power 9 Liter	Paint store	PSB WARE
✓	✓	✓	✓	✓		AP 02	Power 9 Liter	Chemical room	PSB WARE
✓	✓	✓	✓	✓		AP 19	Dry powder 9 kg	Inside PSB warehouse#4(W)	PSB WARE
✓	✓	✓	✓	✓		AP 20	Dry powder 9 kg	Inside PSB warehouse#4-Mezanine Dock/E	PSB WARE
✓	✓	✓	✓	✓		AP 21	Dry powder 9 kg	Inside PSB warehouse#4(S)	PSB WARE
✓	✓	✓	✓	✓		AP 22	Dry powder 9 kg	Office PSB warehouse#4(E)	PSB WARE
✓	✓	✓	✓	✓		AP 23	Dry powder 9 kg	Inside PSB warehouse#4(E)	PSB WARE
✓	✓	✓	✓	✓		AP 24	Dry powder 9 kg	Inside PSB warehouse#4(N)	PSB WARE
✓	✓	✓	✓	✓		AP 25	Dry powder 9 kg	Inside PSB warehouse#4(S)	PSB WARE
✓	✓	✓	✓	✓		AP 26	Dry powder 6.8 kg	Inside PSB warehouse#4	PSB WARE
✓	✓	✓	✓	✓		AC 04	Co2 4.5 kg	Office PSB warehouse#4(E)	PSB WARE
✓	✓	✓	✓	✓		AC 05	Co2 4.5 kg	PSB Warehouse#4 - Cool Room	PSB WARE
✓	✓	✓	✓	✓		AC 06	Co2 4.5 kg	PSB Warehouse#4 - Cool Room	PSB WARE
✓	✓	✓	✓	✓		AC 07	Co2 4.5 kg	PSB Warehouse#4 - Electrical Room	PSB WARE
✓	✓	✓	✓	✓		AC 08	Co2 4.5 kg	PSB Warehouse#4- Forklift battery charger	PSB WARE
✓	✓	✓	✓	✓		AC 09	Co2 4.5 kg	PSB Warehouse#4- Forklift battery charger	PSB WARE
✓	✓	✓	✓	✓		BP 01	Dry powder 6.8 kg	Security box 8	PSB WARE
✓	✓	✓	✓	✓		BP 02	Dry powder 6.8 kg	Infront off generator room	PSB WARE
✓	✓	✓	✓	✓		BP 03	Co2 4.54 kg	Infront off generator room	PSB WARE
✓	✓	✓	✓	✓		BP 04	Power 9 Liter	Infront off generator room	PSB WARE
✓	✓	✓	✓	✓		BP 05	Dry powder 6.8 kg	Inside Ware house (N)	PSB WARE
✓	✓	✓	✓	✓		BP 06	Dry powder 6.8 kg	Inside Ware house (S)	PSB WARE
✓	✓	✓	✓	✓		BP 07	Dry powder 6.8 kg	Infront Warehouse	PSB WARE
✓	✓	✓	✓	✓		BP 08	Dry powder 6.8 kg	Infront off pipe steam office (N)	PSB WARE
✓	✓	✓	✓	✓		BP 09	Dry powder 6.8 kg	Infront off pipe steam office (E)	PSB WARE
✓	✓	✓	✓	✓		BP 10	Dry powder 6.8 kg	Infront off Ware house (Door 2)	PSB WARE
✓	✓	✓	✓	✓		BP 11	Dry powder 6.8 kg	Infront off Ware house (Door 3)	PSB WARE
✓	✓	✓	✓	✓		BP 12	Dry powder 6.8 kg	Infront off Ware house (Door 4)	PSB WARE
✓	✓	✓	✓	✓		BP 13	Dry powder 6.8 kg	Infront off Ware house (Door 5)	PSB WARE
✓	✓	✓	✓	✓		BP 14	Dry powder 6.8 kg	Infront off Ware house (Door 6)	PSB WARE
✓	✓	✓	✓	✓		BP 15	Dry powder 6.8 kg	Infront off Ware house (Door 7)	PSB WARE
✓	✓	✓	✓	✓		BP 16	Dry powder 6.8 kg	Infront off Ware house (Door 8)	PSB WARE
✓	✓	✓	✓	✓		BP 17	Dry powder 6.8 kg	Infront off Ware house (Door 9)	PSB WARE
✓	✓	✓	✓	✓		BP 18	Dry powder 6.8 kg	Infront off Ware house (Door 10)	PSB WARE

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE

OPERATION UNIT

LOCATION: PSB

DATE: 30/04/24



PAGE 4 OF 6

WORK DETAILS FOR EACH UNIT

- A. THE EXTINGUISHER IS VISIBLE & UNOBSERVED
ดับเพลิงสามารถมองเห็นได้และไม่มีการกีดขวาง
- B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
สลักเกลียวล็อกไม่เสียหายและไม่แตก (ไม่มีการฉีกขาด รั่วซึม หรืออุดตันหัวฉีด)
- C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีของเหลวเต็ม
- D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
ข้อความบนป้ายชื่ออ่านได้และหันหน้าออก
- E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ช่างซ่อมบำรุงถังดับเพลิงที่ได้รับอนุญาตต้องตรวจสอบแล้ว




A	B	C	D	E	*REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		BP 19	Dry powder 6.8 kg	Zone M 2nd floor	PSB WARE
✓	✓	✓	✓	✓		BP 20	Dry powder 6.8 kg	Inside Ware house	PSB WARE
✓	✓	✓	✓	✓		BP 21	Dry powder 6.8 kg	Inside Ware house	PSB WARE
✓	✓	✓	✓	✓		BP 22	Dry powder 6.8 kg	Inside Ware house	PSB WARE
✓	✓	✓	✓	✓		BP 24	Dry powder 6.8 kg	Infront off Stock control(W)	PSB WARE
✓	✓	✓	✓	✓		BP 25	Dry powder 6.8 kg	Infront off Stock control(W)	PSB WARE
✓	✓	✓	✓	✓		BP 26	Dry powder 6.8 kg	Infront off Stock control(E)	PSB WARE
✓	✓	✓	✓	✓		BP 27	Dry powder 6.8 kg	Infront off Stock control(E)	PSB WARE
✓	✓	✓	✓	✓		BC 04	Cat 4.54 kg	Infront off Stock control Office	PSB WARE
✓	✓	✓	✓	✓		BC 05	Cat 4.54 kg	Inside chemical room	PSB WARE
✓	✓	✓	✓	✓		BP 28	Dry powder 6.8 kg	Inside chemical room	PSB WARE
✓	✓	✓	✓	✓		BP 29	Dry powder 23 kg	Infront off chemical room	PSB WARE
✓	✓	✓	✓	✓		BP 30	Dry powder 23 kg	Infront off chemical room	PSB WARE
✓	✓	✓	✓	✓		BP 45	Dry powder 6.8 kg	Paint store	PSB WARE
✓	✓	✓	✓	✓		BP 31	Dry powder 6.8 kg	Maintenance work shop	PSB WARE
✓	✓	✓	✓	✓		BP 32	Dry powder 6.8 kg	Maintenance work shop	PSB WARE
✓	✓	✓	✓	✓		BP 33	Dry powder 6.8 kg	Inside maintenance work shop	PSB WARE
✓	✓	✓	✓	✓		BP 34	Dry powder 6.8 kg	Infront off maintenance work shop	PSB WARE
✓	✓	✓	✓	✓		BP 46	Dry powder 6.8 kg	Infront off maintenance work shop	PSB WARE
✓	✓	✓	✓	✓		BP 35	Dry powder 6.8 kg	Office W	PSB WARE
✓	✓	✓	✓	✓		BP 36	Dry powder 6.8 kg	Office E	PSB WARE
✓	✓	✓	✓	✓		BC 06	Cat 4.54 kg	Office (Lobby)	PSB WARE
✓	✓	✓	✓	✓		BF 04	Foam 9 litres	Inside chemical room	PSB WARE
✓	✓	✓	✓	✓		BP 37	Dry powder 6.8 kg	Infront off waste area office	WASTE AREA
✓	✓	✓	✓	✓		BP 38	Dry powder 23 kg	Infront off waste area office	WASTE AREA
✓	✓	✓	✓	✓		BP 39	Dry powder 6.8 kg	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BF 01	Foam 9 litres	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BF 02	Foam 9 litres	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BF 05	Foam 9 litres	Waste area	WASTE AREA
✓	✓	✓	✓	✓		BP 40	Dry powder 23 kg	Waste area (W)	WASTE AREA
✓	✓	✓	✓	✓		BP 41	Dry powder 6.8 kg	Infront off EMI warehouse	EMI WARE
✓	✓	✓	✓	✓		BP 42	Dry powder 6.8 kg	Infront off EMI warehouse	EMI WARE
✓	✓	✓	✓	✓		BP 43	Dry powder 6.8 kg	Visitor area	PSB WARE
✓	✓	✓	✓	✓		EP 01	Dry powder 6.8 kg	Security box 1	EMI 1
✓	✓	✓	✓	✓		EP 02	Dry powder 6.8 kg	EMI 1st floor (S)	EMI 1
✓	✓	✓	✓	✓		EP 03	Dry powder 6.8 kg	EMI 1st floor (E)	EMI 1
✓	✓	✓	✓	✓		EP 04	Dry powder 6.8 kg	EMI 2nd floor	EMI 1
✓	✓	✓	✓	✓		EP 05	Dry powder 6.8 kg	EMI 2nd floor	EMI 1
✓	✓	✓	✓	✓		EP 06	Dry powder 6.8 kg	Container office	EMI 1
✓	✓	✓	✓	✓		EP 07	Dry powder 6.8 kg	EMI 1st floor (S/E)	EMI 2

 PTTEP PSB	EXTINGUISHER MAINTENANCE SHEET MONTHLY	PSB SONGKHLA  SAFETY SERVICE
OPERATION UNIT	LOCATION: PSB	DATE: 30/04/24
		PAGE 6 OF 6

WORK INSTRUCTIONS FOR EACH UNIT.


- THE EXTINGUISHER IS VISIBLE & UNOBSCTURED
เครื่องดับเพลิงสามารถมองเห็นได้ตลอดเวลา
- THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE OR CLOGGED NOZZLE)
สลักเกลียวล็อกไม่ชำรุดเสียหาย และซีลกันรั่วไม่แตกหัก (ไม่พบความเสียหาย รอยกัดกร่อน หรือการอุดตันที่หัวฉีด)
- INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้ระดับเชื้อเพลิงอยู่ในตำแหน่งที่ใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีเชื้อเพลิง
- THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำการใช้งานที่ปรากฏบนป้ายข้อมูลสามารถอ่านได้ และหันออกด้านนอก
- A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
พนักงานซ่อมบำรุงรถดับเพลิงที่มีใบอนุญาตต้องตรวจสอบ







A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT	
✓	✓	✓	✓	✓		LP 65	Dry powder 6.8 kg	INSIDE WARE HOUSE	FIRE ZONE	
✓	✓	✓	✓	✓		LP 131	Dry powder 6.8 kg	INSIDE WARE HOUSE	FIRE ZONE	
✓	✓	✓	✓	✓		LP 54	Dry powder 6.8 kg	INSIDE WARE HOUSE	FIRE ZONE	
✓	✓	✓	✓	✓		LP 130	Dry powder 6.8 kg	INSIDE WARE HOUSE	FIRE ZONE	
✓	✓	✓	✓	✓		LP 132	Dry powder 6.8 kg	INSIDE WARE HOUSE	FIRE ZONE	
✓	✓	✓	✓	✓		LP 136	Dry powder 6.8 kg	CHEMICAL ROOM W/H	FIRE ZONE	
✓	✓	✓	✓	✓		LP 137	Dry powder 6.8 kg	CHEMICAL ROOM W/H	FIRE ZONE	
✓	✓	✓	✓	✓		LF 08	Foam 9 LTR	CHEMICAL ROOM W/H	FIRE ZONE	
✓	✓	✓	✓	✓		LP 147	Dry powder 6.8 kg	SECURITY YARD 1	FIRE ZONE	
✓	✓	✓	✓	✓		LP 05	Dry powder 6.8 kg	CONTAINER	FIRE ZONE	
✓	✓	✓	✓	✓		LP 06	Dry powder 6.8 kg	CONTAINER	FIRE ZONE	
✓	✓	✓	✓	✓		LP 07	Dry powder 6.8 kg	CUSTOMS OFFICE	FIRE ZONE	
✓	✓	✓	✓	✓		LP 32	Dry powder 6.8 kg	PSB-WHD (Fire zone)	FIRE ZONE	
✓	✓	✓	✓	✓		LP 33	PSB-WHD (Fire zone)	PSB-WHD (Fire zone)	FIRE ZONE	
✓	✓	✓	✓	✓		LP 146	Dry powder 6.8 kg	IN FRONT OF ROOF SHADE	FIRE ZONE	
✓	✓	✓	✓	✓		LP 80	Dry powder 6.8 kg	SECURITY BOX No.9	FIRE ZONE	
✓	✓	✓	✓	✓		LC 01	Cub 6.8 kg	INSIDE CONTAINER	FIRE ZONE	
✓	✓	✓	✓	✓		LP 09	Foam 9 LTR	CHEMICAL ROOM	FIRE ZONE	
✓	✓	✓	✓	✓		LP 45	Dry powder 6.8 kg	TERMINAL CHECK IN / WEST	TERMINAL	
✓	✓	✓	✓	✓		LP 46	Dry powder 6.8 kg	TERMINAL CHECK IN / EAST	TERMINAL	
✓	✓	✓	✓	✓		AP 27	PSB Warehouse#5-NW	PSB Warehouse#5		
✓	✓	✓	✓	✓		AP 28	Dry powder 6.8 kg	PSB Warehouse#5-SW	PSB Warehouse#5	
✓	✓	✓	✓	✓		AP 29	Dry powder 6.8 kg	PSB Warehouse#5-SE	PSB Warehouse#5	
✓	✓	✓	✓	✓		AP 30	Dry powder 6.8 kg	PSB Warehouse#5-NE	PSB Warehouse#5	


REMARKS:

LEADER: PM team

 PSB OPERATION UNIT	LIFEBOY MAINTENANCE SHEET MONTHLY DATE: <u>28/06/21</u>	PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1																																																																																				
WORK DETAILS FOR EACH UNIT <div style="display: flex; justify-content: space-between; align-items: flex-start;"> <div style="width: 60%;"> <p>A. LIFEBOY IS ACCESSIBLE & EASILY REMOVED FOR USE หน่วยกู้ชีพสามารถดึงได้ไม่ยากหรือนำออกได้โดยง่ายตามหลักการใช้งาน</p> <p>B. VISUALLY INSPECT THE LIFEBOY FOR DAMAGE ตรวจสอบหน่วยกู้ชีพที่เก็บหากพบความเสียหาย</p> <p>C. LIFEBOY IS SEALED WITH A PLUG หน่วยกู้ชีพถูกปิดผนึกด้วยลูกตุ้ม</p> <p>D. THE GRAB LINE AROUND THE CIRCUMFERENCE IS NOT DAMAGED สายชักวนรอบ ๆ รอบไม่มีความเสียหาย</p> </div> <div style="width: 35%; text-align: center;">  </div> </div>																																																																																						
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 5%;">A</th> <th style="width: 5%;">B</th> <th style="width: 5%;">C</th> <th style="width: 5%;">D</th> <th style="width: 35%;">REMARKS</th> <th style="width: 15%;">ID.NO</th> <th style="width: 30%;">LOCATION</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 1</td> <td>JETTY-WE</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 2</td> <td>JETTY BERTH - 1</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 3</td> <td>JETTY BERTH - 2</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 4</td> <td>JETTY BERTH - 3</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 5</td> <td>JETTY BERTH - 4</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 6</td> <td>JETTY BERTH - 5</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 7</td> <td>JETTY BERTH - 6</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 8</td> <td>JETTY S/W</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 9</td> <td>JETTY N/W</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 10</td> <td>JETTY BOAT</td> </tr> <tr> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td style="text-align: center;">✓</td> <td></td> <td>LBV - 11</td> <td>JETTY BOAT</td> </tr> </tbody> </table>			A	B	C	D	REMARKS	ID.NO	LOCATION	✓	✓	✓	✓		LBV - 1	JETTY-WE	✓	✓	✓	✓		LBV - 2	JETTY BERTH - 1	✓	✓	✓	✓		LBV - 3	JETTY BERTH - 2	✓	✓	✓	✓		LBV - 4	JETTY BERTH - 3	✓	✓	✓	✓		LBV - 5	JETTY BERTH - 4	✓	✓	✓	✓		LBV - 6	JETTY BERTH - 5	✓	✓	✓	✓		LBV - 7	JETTY BERTH - 6	✓	✓	✓	✓		LBV - 8	JETTY S/W	✓	✓	✓	✓		LBV - 9	JETTY N/W	✓	✓	✓	✓		LBV - 10	JETTY BOAT	✓	✓	✓	✓		LBV - 11	JETTY BOAT
A	B	C	D	REMARKS	ID.NO	LOCATION																																																																																
✓	✓	✓	✓		LBV - 1	JETTY-WE																																																																																
✓	✓	✓	✓		LBV - 2	JETTY BERTH - 1																																																																																
✓	✓	✓	✓		LBV - 3	JETTY BERTH - 2																																																																																
✓	✓	✓	✓		LBV - 4	JETTY BERTH - 3																																																																																
✓	✓	✓	✓		LBV - 5	JETTY BERTH - 4																																																																																
✓	✓	✓	✓		LBV - 6	JETTY BERTH - 5																																																																																
✓	✓	✓	✓		LBV - 7	JETTY BERTH - 6																																																																																
✓	✓	✓	✓		LBV - 8	JETTY S/W																																																																																
✓	✓	✓	✓		LBV - 9	JETTY N/W																																																																																
✓	✓	✓	✓		LBV - 10	JETTY BOAT																																																																																
✓	✓	✓	✓		LBV - 11	JETTY BOAT																																																																																
REMARKS: <div style="border-bottom: 1px solid black; height: 15px; margin-bottom: 5px;"></div> <div style="border-bottom: 1px solid black; height: 15px; margin-bottom: 5px;"></div> <div style="border-bottom: 1px solid black; height: 15px; margin-bottom: 5px;"></div> <div style="border-bottom: 1px solid black; height: 15px; margin-bottom: 5px;"></div>																																																																																						
LEADER <u>PH Team</u>																																																																																						

 PTPSB PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PAB SONGKHLA  SAFETY SERVICE	
OPERATION UNIT		LOCATION : PSB		DATE: 30/04/2564	
PAGE 1 OF 4					


WORK DETAILS FOR EACH UNIT					
A.	GOOD ALARM SENSOR MODE				
B.	ตรวจเช็คการแจ้งเตือนที่ CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH				
C.	ตรวจสอบกระจก ตัวอุปกรณ์แจ้งเตือนที่แตก หรือร้าว CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT				
D.	ตรวจสอบอุปกรณ์ตัวระบุ CHECK ID. NO				
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	A101		PSB BUILDING-A / 1ST FLOOR SHEVRON OFFICE
✓	✓	✓	A102		PSB BUILDING-A / 1ST FLOOR WEST DOOR
✓	✓	✓	A103		PSB BUILDING-A / 1ST FLOOR MEDIC ROOM
✓	✓	✓	A104		PSB BUILDING-A / SECURITY BOX 4
✓	✓	✓	A105		PSB BUILDING-A / 2nd FLOOR AT STAIR
✓	✓	✓	A106		PSB BUILDING-A / 2nd FLOOR CPCC OFFICE
✓	✓	✓	A107		PSB BUILDING-A/2nd FLOOR EMERGENCY DOOR
✓	✓	✓	A108		PSB BUILDING-A-3th FLOOR AT STAIR
✓	✓	✓	A110		PSB BUILDING-A / 3th FLOOR REDIO ROOM
✓	✓	✓	A109		PSB BUILDING-A / 3th FLOOR ROOM 304
✓	✓	✓	A111		PSB BUILDING-A / 3th FLOOR ROOM 310
✓	✓	✓	A112		PSB BUILDING-A / IN SIDE ELECTRICAL ROOM
✓	✓	✓	A113		PSB BUILDING-A / IN FONT OFF FIRE PUMP
✓	✓	✓	N0.01		PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	N0.02		PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	N0.03		PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	N0.04		PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	N0.05		PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	N0.06		PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	N0.07		PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	N0.08		PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	N0.09		PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	N0.10		PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	N0.11		PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	N0.12		PSB BUILDING-B / 3rd FLOOR
✓	✓	✓	N0.13		PSB BUILDING-B / 3rd FLOOR
✓	✓	✓	N0.14		PSB BUILDING-B / 3rd FLOOR
✓	✓	✓	N0.15		PSB BUILDING-B / 3rd FLOOR
✓	✓	✓	J101		IN SIDE JETTY ELECTRICAL ROOM
✓	✓	✓	J102		JETTY BERTH 1
✓	✓	✓	J103		JETTY BERTH 2
✓	✓	✓	J104		JETTY BERTH 6
✓	✓	✓	J105		JETTY BULK TANK 1



PTTEP
PSB

**FIRE ALARM
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA



SAFETY SERVICE

PAGE 2 OF 4

OPERATION UNIT

LOCATION : PSB

DATE 29/06/2564

WORK DETAILS FOR EACH UNIT

A. GOOD ALARM SENSOR MODE

ตรวจสอบการทำงานของเซ็นเซอร์

CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH

ทำความสะอาด หัวอุปกรณ์แจ้งเตือนด้วยแปรงฝุ่น



CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT

ตรวจสอบสภาพการทำงานของกระจกที่แตกหรือร้าว

D. CHECK ID. NO

ตรวจสอบเลขประจำตัว




A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	J106		JETTY BULK TANK 2
✓	✓	✓	J107		JETTY OFFICE
✓	✓	✓	J108		SECURITY BOX 4 JETTY
✓	✓	✓	B119		CREW CHANGE AREA
✓	✓	✓	ST-01		EMI SPECIAL TOOL S-E WH
✓	✓	✓	ST-02		EMI SPECIAL TOOL S-E WH
✓	✓	✓	ST-03		EMI SPECIAL TOOL S-W WH
✓	✓	✓	B120		WASTE AREA ROW 5
✓	✓	✓	B121		WASTE AREA ROW 2
✓	✓	✓	B122		TERMINAT CHECK-IN West
✓	✓	✓	B123		TERMINAT CHECK-IN South
✓	✓	✓	B109		PSB WH16-COOM ROOM CA-B
✓	✓	✓	B108		PSB WH16-COOM ROOM CE
✓	✓	✓	B111		INFRONT OF PSB WH16-N
✓	✓	✓	B107		INFRONT OF PSB WH16-W
✓	✓	✓	B110		INSIDE PSB WH16-West
✓	✓	✓	B112		PSB WAREHOUSE#- B32
✓	✓	✓	B106		PSB WH16- STOCK CONTROL-S/E
✓	✓	✓	B105		PSB WH16-CHEMICAL ROOM
✓	✓	✓	B104		PSB WH16- PAINTING STORAGE
✓	✓	✓	B117		PSB WH16-OFFICE
✓	✓	✓	B116		PSB WH16-OFFICE
✓	✓	✓	B115		PSB WH16-OFFICE
✓	✓	✓	B113		GBS WAREHOUSE#1 - B 33
✓	✓	✓	B114		GBS WAREHOUSE#1 - B 33
✓	✓	✓	B101		PSB WH16-GBS WORKSHOP
✓	✓	✓	B103		PSB WH16-GBN WORKSHOP
✓	✓	✓	B102		PSB WH16-GBN WORKSHOP
✓	✓	✓	F103		FREE ZONE COOL ROOM
✓	✓	✓	F104		FREE ZONE COOL ROOM
✓	✓	✓	F105		FREE ZONE WH STAIR
✓	✓	✓	F106		FREE ZONE WH WEST
✓	✓	✓	F107		FREE ZONE WH S/W

 PTPSB OPERATION UNIT	FIRE ALARM MAINTENANCE SHEET MONTHLY LOCATION : PSB	DATE: 29/6/64	PSB SONGKHLA  SAFETY SERVICE PAGE 3 OF 4
---	---	---------------	--

WORK DETAILS FOR EACH UNIT

- GOOD ALARM SENSOR MODE
เชาฆออการแจ้งเตือนที่ดี
CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH
- การทำความสะอาด หัวอุปกรณ์แจ้งเหตุด้วยมือ ด้วยแปรงขี้ฝุ่น
CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT
- ให้ตรวจสอบคุณภาพหัวอุปกรณ์ กระดกไว้ หรือแตก
CHECK ID. NO
- ตรวจสอบเลขประจำตัว

A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	P108		FREE ZONE W1 S/E
✓	✓	✓	P101		FREE ZONE CHEMICAL
✓	✓	✓	E102		FREE ZONE CHEMICAL
✓	✓	✓	P109		FREE ZONE NEW W/H
✓	✓	✓	I101		EMI WORKSHOP#1 / N
✓	✓	✓	I102		EMI WORKSHOP#1 / NW
✓	✓	✓	I103		EMI WORKSHOP#1 / SW
✓	✓	✓	I104		EMI WORKSHOP#1 / SW
✓	✓	✓	E109		EMI WORKSHOP#2 / STAIRS
✓	✓	✓	E102		EMI WORKSHOP#2 / STAIRN
✓	✓	✓	E103		EMI WORKSHOP#2
✓	✓	✓	E104		EMI WORKSHOP#2 DOORS
✓	✓	✓	E105		EMI WORKSHOP#2 DOORN
✓	✓	✓	E106		EMI WORKSHOP#2 LEVEL2
✓	✓	✓	E107		EMI WORKSHOP#2 LEVEL2
✓	✓	✓	E108		EMI#3 WORKSHOP - NW
✓	✓	✓	E109		EMI#3 WORKSHOP - SW
✓	✓	✓	E110		EMI#3 WORKSHOP - NE
✓	✓	✓	E111		EMI#3 Warehouse - E
✓	✓	✓	E112		EMI#3 Warehouse - W
✓	✓	✓	E113		EMI#3 Office floor1 - E
✓	✓	✓	E114		EMI#3 Office floor1 - W
✓	✓	✓	E115		EMI#3 Office floor2 - E
✓	✓	✓	E116		EMI#3 Office floor2 - W
✓	✓	✓	H101		WELL SERVICE OFFICE LEVEL 1
✓	✓	✓	H102		WELL SERVICE OFFICE LEVEL 2
✓	✓	✓	H103		WELL SERVICE WORKSHOP
✓	✓	✓	H104		WELL SERVICE WORKSHOP
✓	✓	✓	C101		CPQC W/H
✓	✓	✓	C102		CPQC W/H
✓	✓	✓	C103		CPQC W/H
✓	✓	✓	C104		CPQC W/H
✓	✓	✓	C105		CPQC CDOL ROOM
✓	✓	✓	C106		CPQC COOL ROOM

 PSB OPERATION UNIT		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA  SAFETY SERVICE PAGE 4 OF 4	
		LOCATION : PSB		DATE: 29/11/24	
WORK DETAILS FOR EACH UNIT					
A. GOOD ALARM SENSOR MODE ตรวจเช็คอุปกรณ์แจ้งเตือนที่มี CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH					
B. สภาพการทำงานของตู้ อุปกรณ์แจ้งเตือนกระจกแตก ตรวจสอบสัญญาณ CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT					
C. ใช้กระดาษติดเลขที่อุปกรณ์ ตรวจสอบรหัส หรือเลข CHECK ID, NO					
D. ตรวจสอบอุปกรณ์ประจำตู้					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓		P001	PSB FIRE SERVICE WORKSHOP
✓	✓	✓		M01	PSB WH#1 OFFICE N
✓	✓	✓		M02	PSB WH#1 OFFICE S/E
✓	✓	✓		M03	PSB WH#1 WH/ COOL ROOM S
✓	✓	✓		M04	PSB WH#1 CHEMICAL ROOM W/N
✓	✓	✓		M05	PSB WH#1 CHEMICAL ROOM S
✓	✓	✓		M106	PSB CHEMICAL WASTE TRANSIT
✓	✓	✓		M07	PSB CHEMICAL WASTE TRANSIT
✓	✓	✓		M08	PSB GAS STORE S/W
✓	✓	✓		M-10	PSB WH#1
✓	✓	✓		M-11	PSB WH#1
✓	✓	✓		MA4-01	PSB WH#4
✓	✓	✓		MA4-02	PSB WH#4
✓	✓	✓		MA4-03	PSB WH#4
✓	✓	✓		MA4-04	PSB WH#4
✓	✓	✓		MA4-05	PSB WH#4
✓	✓	✓		MA4-06	PSB WH#4
✓	✓	✓		MA4-07	PSB WH#4
✓	✓	✓		MA5-01	PSB WH#5
✓	✓	✓		MA5-02	PSB WH#5
✓	✓	✓		MA5-03	PSB WH#5
✓	✓	✓		MA5-04	PSB WH#5
✓	✓	✓		S-01	PSB SERVICE MAINTENANCE WORKSHOP
REMARKS:					
LEADER					

PSB
OPERATION UNIT

EMERGENCY PHONE
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE
PAGE 1 OF 1

LOCATION : PSB DATE : 29/06/24

WORK DETAILS FOR EACH UNIT

A. PHONE ACCESSIBLE
การให้แจ้งโทรศัพท์

B. EMERGENCY PHONE NUMBERS AND PROCEDURES POSTED AT OR NEAR TELEPHONE
หมายเลขโทรศัพท์ฉุกเฉินและวิธีการโดยติดใกล้กับโทรศัพท์

C. SAFETY BOARD DISPLAYING EMERGENCY PHONE NUMBER
ป้ายสำหรับแสดงหมายเลขโทรศัพท์ฉุกเฉิน

D. FUNCTIONALITY SUITABLE
ฟังก์ชันที่เหมาะสม

A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		FREE ZONE CONTAINER
✓	✓	✓	✓		CREW CHANGE AREA
✓	✓	✓	✓		JETTY
✓	✓	✓	✓		PSB WH16- MUSTER POINT
✓	✓	✓	✓		EM MUSTER POINT

REMARKS

LEADER PM Team

PSB
OPERATION UNIT

FIRE HOSE TROLLEY
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE
PAGE 1 OF 1

LOCATION : PSB DATE : 30/06/24

WORK DETAILS FOR EACH UNIT

A. All equipment complete as specified
อุปกรณ์ครบตามที่ระบุไว้

B. All equipment is in working condition. All equipment is in working condition.
อุปกรณ์ทุกอย่างเป็นสภาพพร้อมใช้งาน

C. NON-OBSTRUCTED
ไม่มีสิ่งกีดขวาง

D. The Trolley is in good working condition, easy to move.
รถเข็นอยู่ในสภาพพร้อมใช้งาน เคลื่อนย้ายได้สะดวก

A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓	PH SIZE 45 MM - 4 Ft. PH SIZE 64 MM - 4 Ft. PH VALVE - 1N. HOSE 1/2 IN. HOSE TUBE - 1 Ft.	BEHIND OF PSB BUILDING-A
✓	✓	✓	✓	PH SIZE 45 MM - 3 Ft. PH SIZE 64 MM - 3 Ft. PH VALVE - 3 Ft. HOSE 1/2 IN.	BESIDE SECURITY BOX-2

REMARKS

LEADER PM Team

PSB
OPERATION UNIT

FIRE FIGHTING EQUIPMENT
MONTHLY CHECK LIST

PSB SONGKHLA
SAFETY SERVICE
PAGE 1 OF 1

ISSUED RETURN COMPLETED

1	FIRE HYDRANT	29/06/24	29/06/24	100%
2	FIRE HOSE REEL	29/06/24	29/06/24	100%
3	FIRE HOSE	29/06/24	29/06/24	100%
4	EXTINGUISHER	29/06/24	29/06/24	100%
5	FIRE MAN EQP.	29/06/24	29/06/24	100%
6	LIFEBUOY	29/06/24	29/06/24	100%
7	STRETCHER	29/06/24	29/06/24	100%
8	SAFETY SHOWER	29/06/24	29/06/24	100%
9	EYEWASH STATION	29/06/24	29/06/24	100%
10	TROCH	29/06/24	29/06/24	100%
11	FIRE ALARM	29/06/24	29/06/24	100%
12	EMERGENCY PHONE	29/06/24	29/06/24	100%
13	FIRE HOSE TROLLEY	29/06/24	29/06/24	100%

TASK COMPLETED 100%

TIME SPENDING: 15.45 MAN HRS

REMARK:

CHECK BY: PM Team DATE: 29/06/2024

PSB
OPERATION UNIT

FIRE HYDRANT
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA
SAFETY SERVICE
PAGE 1 OF 1

LOCATION : PSB DATE : 29/05/24

WORK DETAILS FOR EACH UNIT

A. HYDRANTS ARE ACCESSIBLE & FREE OF OBSTRUCTION
หัวจ่ายสามารถใช้งานได้สะดวก ไม่มีสิ่งกีดขวาง

B. TOP OF HYDRANT IS NOT LEAKING WHEN HYDRANT IS ON
ด้านบนของหัวจ่ายไม่มีการรั่วซึมเมื่อเปิดใช้งาน

C. RUBBER SEAL UNDER CAPS ARE NOT LEAKING
ซีลยางภายใต้ฝาครอบไม่รั่วซึม

D. HYDRANT BARKEL IS IN GOOD CONDITION WITHOUT CRACKS OR CORROSION
สายหัวจ่ายอยู่ในสภาพดี ไม่พบรอยร้าวหรือการกัดกร่อน

E. OUTLET CAPS SECURE
ฝาครอบที่ออกยึดแน่น

F. CLEAN AND GREASE OF MOVING PARTS
ทำความสะอาดและหล่อลื่นชิ้นส่วนที่เคลื่อนที่

A	B	C	D	E	F	REMARKS	ID.NO	LOCATION
✓	✓	✓	✓	✓	✓		HD1	SECURITY BOX2
✓	✓	✓	✓	✓	✓		HD2	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD3	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD4	SECURITY BOX4
✓	✓	✓	✓	✓	✓		HD5	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD6	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD7	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD8	JETTY BERTH1
✓	✓	✓	✓	✓	✓		HD9	JETTY BERTH2
✓	✓	✓	✓	✓	✓		HD10	JETTY BERTH3
✓	✓	✓	✓	✓	✓		HD11	JETTY BERTH4
✓	✓	✓	✓	✓	✓		HD12	JETTY BERTH5
✓	✓	✓	✓	✓	✓		HD13	JETTY BERTH6
✓	✓	✓	✓	✓	✓		HD14	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD15	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD16	PSB BUILDING-B / West
✓	✓	✓	✓	✓	✓		AHD-01	PSB WH - 04
✓	✓	✓	✓	✓	✓		FHD-01	FREE ZONE-CHEMICAL ROOM

REMARKS:

LEADER PM Team

PTTEP
PSB

**FIRE HOSE REEL
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT: PSB

LOCATION: PSB

DATE: 09/05/24

PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. THE HOSE REEL IS READILY ACCESSIBLE WITH NO OBSTACLES RESTRICTING ITS ACCESS
ตู้ไฟพร้อมสายยางใช้ได้อย่างสะดวกไม่มีสิ่งกีดขวาง การจำกัดการเข้าถึง

B. ANY DAMAGE OR CORROSION OF THE HOSE REEL: 1- GOOD, 2- POOR, 3- BAD, 4- VERY BAD
ความเสียหายใด ๆ หรือการกัดกร่อนของตู้ไฟหรือสาย (1 - ดี, 2 - พอใช้, 3 - ไม่ดี, 4 - ไม่ดีนัก)

C. THE NOZZLE IS RETAINED IN THE NOZZLE INTERLOCK
หัวฉีดถูกตรึงไว้ในที่ล็อกหัวฉีด

D. THE HOSE REEL CAN BE UNWOUND FREELY IN ITS INTENDED DIRECTION
สายยางสามารถคลายออกได้อย่างอิสระในทิศทางที่กำหนด

E. CLEAN AND GREASE AS NECESSARY.
ทำความสะอาดและหล่อลื่นตามจำเป็น

A	B	C	D	E	REMARKS	ID NO	LOCATION
✓	✓	✓	✓	✓		FH10	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH01	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH02	PSB BUILDING-B / OFFICE FLOOR2
✓	✓	✓	✓	✓		FH03	PSB BUILDING-B / OFFICE FLOOR3
✓	✓	✓	✓	✓		FR4	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR5	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR6	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		FR7	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR8	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR9	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		AFR 01	PSB W/H 04
✓	✓	✓	✓	✓		FH-11	FREE ZONE CHEMICAL ROOM

REMARKS:

LEADER: PM Team

PTTEP
PSB

**FIRE HOSE BOX
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT: PSB

LOCATION: PSB

DATE: 09/05/24

PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. HOSE BOX IN GOOD CONDITION WITHOUT CRACKS
กล่องถังน้ำดับเพลิงอยู่ในสภาพที่ดีไม่มีรอยร้าว

B. SECURING STRAP & DOOR PACKING IN A GOOD CONDITION
สายรัดและประตูบรรจุในสภาพที่ดี

C. NOZZLE OF APPROPRIATE SIZE & TYPE
หัวฉีดขนาดและประเภทที่เหมาะสม

D. FIRE HOSE OF APPROPRIATE LENGTH
สายฉีดน้ำดับเพลิงมีความยาวที่เหมาะสม

E. APPROPRIATE SPANNER
ประแจที่เหมาะสม

F. HOSE COUPLING IS PROPERLY CONNECTED
การเชื่อมต่อของสายยางกับหัวฉีดถูกต้อง

G. NOZZLE IS FREELY MOVING
หัวฉีดเคลื่อนที่อย่างอิสระ

A	B	C	D	E	F	G	REMARKS	LOCATION
✓	✓	✓	✓	✓	✓	✓	(FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	JETTY BERTH - 1 (FH 01)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 (FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	JETTY BERTH - 2 (FH 02)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 (FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	JETTY BERTH - 3 (FH 03)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 (FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	JETTY BERTH - 4 (FH 04)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 (FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	JETTY BERTH - 5 (FH 05)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 (FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	JETTY BERTH - 6 (FH 06)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 (FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	PSB JETTY/HID 07 (FH 07)
✓	✓	✓	✓	✓	✓	✓	HAND TOOL - 1 (FH 38 mm - 1 Pc) (FH 64 mm - 1 Pc) NOZZLE - 1	BEHIND PSB BUILDING-A

REMARKS:

LEADER: PM Team

PTTEP
PSB

**EXTINGUISHER
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT: PSB

LOCATION: PSB

DATE: 09/05/24

PAGE 1 OF 6

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
ถังดับเพลิงสามารถมองเห็นได้อย่างชัดเจนไม่มีสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
สลักเกลียวล็อกไม่เสียหายและซีลประตูไม่แตก (ไม่มีความเสียหาย รั่วไหล หัวฉีดอุดตัน)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวบ่งชี้ระดับน้ำอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีน้ำเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
ข้อมูลคำแนะนำบนป้ายชื่อถังดับเพลิงสามารถอ่านได้และหันออกด้านนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงต้องได้รับการตรวจสอบและบำรุงรักษาโดยช่างเทคนิคที่มีใบอนุญาต

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		PP-01	Dry powder 6.8 kg	Society box 4	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-01	Co2 4.5 kg	PSB BUILDING-A	
✓	✓	✓	✓	✓		PP-02	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ Room 108	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-02	Co2 4.5 kg	PSB 1st floor/infirmary off medical	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-03	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-04	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-05	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 221	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-06	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 221	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-07	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-08	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ CPOC office	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-09	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-10	Dry powder 6.8 kg	PSB office 3rd fl / infirmary off radio room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-11	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-12	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-03	Co2 4.5 kg	PSB office floor/ infirmary off radio room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-04	Co2 4.5 kg	PSB office floor/ IT room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-07	Co2 4.5 kg	PSB office floor/ IT room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-14	Dry powder 6.8 kg	PSB Fire pump	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-15	Dry powder 6.8 kg	Driver's office	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-16	Dry powder 6.8 kg	Security box 2	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-17	Dry powder 6.8 kg	Security box 3	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-17	Dry powder 6.8 kg	Fire service shop	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-05	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-06	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-01	Power 9 liter	Generator room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-02	Power 9 liter	Generator room	PSB BUILDING-A
✓	✓	✓	✓	✓		NP-01	Dry powder 6.8 kg	NEW PSB FLOOR1 E/S	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-02	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-03	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-04	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-05	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-06	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-07	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-08	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-09	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-10	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-11	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-12	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B

PTTEP
PSB

**EXTINGUISHER
MAINTENANCE SHEET
MONTHLY**

PSB SONGKHLA

SAFETY SERVICE

OPERATION UNIT: PSB

LOCATION: PSB

DATE: 09/05/24

PAGE 2 OF 6

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
ถังดับเพลิงสามารถมองเห็นได้อย่างชัดเจนไม่มีสิ่งกีดขวาง




B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLE)
สลักเกลียวล็อกไม่เสียหายและซีลประตูไม่แตก (ไม่มีความเสียหาย รั่วไหล หัวฉีดอุดตัน)




C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวบ่งชี้ระดับน้ำอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีน้ำเต็ม




D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
ข้อมูลคำแนะนำบนป้ายชื่อถังดับเพลิงสามารถอ่านได้และหันออกด้านนอก




E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงต้องได้รับการตรวจสอบและบำรุงรักษาโดยช่างเทคนิคที่มีใบอนุญาต


A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		NP-13	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-14	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		JP 01	Dry powder 6.8 kg	Security box 6	JETTY
✓	✓	✓	✓	✓		JP 02	Dry powder 6.8 kg	Fire hose reel box No.1	JETTY
✓	✓	✓	✓	✓		JP 03	Dry powder 6.8 kg	Fire hose reel box No.2	JETTY
✓	✓	✓	✓	✓		JP 04	Dry powder 6.8 kg	Fire hose reel box No.3	JETTY
✓	✓	✓	✓	✓		JP 05	Dry powder 6.8 kg	Fire hose reel box No.4	JETTY
✓	✓	✓	✓	✓		JP 06	Dry powder 6.8 kg	Fire hose reel box No.5	JETTY
✓	✓	✓	✓	✓		JP 07	Dry powder 6.8 kg	Infront off office	JETTY
✓	✓	✓	✓	✓		JP 08	Dry powder 6.8 kg	Infront off Electrical room	JETTY
✓	✓	✓	✓	✓		JP 09	Dry powder 2.5 kg	Security box 5	JETTY
✓	✓	✓	✓	✓		JP 10	Dry powder 2.5 kg	Container of CPOC	JETTY
✓	✓	✓	✓	✓		JP 11	Dry powder 2.5 kg	Generator Room 02	JETTY
✓	✓	✓	✓	✓		JP 12	Dry powder 2.5 kg	On the boat	JETTY
✓	✓	✓	✓	✓		JP 13	Dry powder 2.5 kg	Electrical room	JETTY
✓	✓	✓	✓	✓		JP 14	Dry powder 2.5 kg	Electrical room	JETTY
✓	✓	✓	✓	✓		JP 15	Dry powder 2.5 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		JP 16	Dry powder 2.5 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		JP 17	Dry powder 2.5 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		JP 18	Dry powder 2.5 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		JP 19	Dry powder 2.5 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		JP 20	Dry powder 2.5 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PC 08	Co2 4.5 kg	Canteen	PSB
✓	✓	✓	✓	✓		MF 01	Power 9 liter	Security box 3	PSB
✓	✓	✓	✓	✓		AP 01	Dry powder 6.8 kg	PSB WAREHOUSE#1-office	PSB W/H#1
✓	✓	✓	✓	✓		AP 02	Dry powder 6.8 kg	PSB Warehouse#1-office	PSB W/H#1
✓	✓	✓	✓	✓		AP 03	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB W/H#1
✓	✓	✓	✓	✓		AP 04	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB W/H#1
✓	✓	✓	✓	✓		AP 05	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB W/H#1
✓	✓	✓	✓	✓		AP 06	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB W/H#1
✓	✓	✓	✓	✓		AP 07	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB W/H#1
✓	✓	✓	✓	✓		AP 08	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB W/H#1
✓	✓	✓	✓	✓		AP 09	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB W/H#1
✓	✓	✓	✓	✓		AP 10	Dry powder 6.8 kg	Arbit ware house/infront off cool room	PSB W/H#1
✓	✓	✓	✓	✓		AP 11	Dry powder 6.8 kg	Inside Arthit ware house(N)	PSB W/H#1
✓	✓	✓	✓	✓		AP 12	Dry powder 6.8 kg	Inside PSB W/H#1- roof shade	PSB W/H#1
✓	✓	✓	✓	✓		AP 13	Dry powder 6.8 kg	Inside PSB W/H#1- roof shade	PSB W/H#1
✓	✓	✓	✓	✓		AP 14	Dry powder 6.8 kg	PSBW W/H#2-waste transit	PSB W/H#1
✓	✓	✓	✓	✓		AP 15	Dry powder 6.8 kg	PSBW W/H#2-waste transit	PSB W/H#1


 PTTEP PSB OPERATION UNIT		FIRE MAN BOX MAINTENANCE SHEET MONTHLY DATE: 25/05/24		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION: PSB					
WORK DETAILS FOR EACH UNIT					
A. CHECK FIRE SUIT, FIRE HELMET, BOOTS, GLOVES & OTHER EQUIPMENT AVAILABLE ตรวจสอบชุดป้องกันภัย พกมาพร้อมอุปกรณ์ที่จำเป็น มีอยู่ และพร้อมใช้งาน					
B. SECURING STRAP, DOOR PACKING AND LOCK FUNCTIONS IN A GOOD CONDITION สายรัด ประตูบรรจุ และฟังก์ชันการล็อกประตูที่ดี					
C. CLEAN & READY TO USE ภาชนะพร้อมใช้งานและพร้อมใช้งาน					
					
A	B	C	REMARKS		LOCATION
✓	✓	✓	<input checked="" type="checkbox"/> FIRE SUIT - 4 Pcs. <input checked="" type="checkbox"/> FIRE HELMET - 4 Pcs. <input checked="" type="checkbox"/> BOOTS - 4 Pcs. <input checked="" type="checkbox"/> GLOVES - 4 Pcs. <input checked="" type="checkbox"/> FOAM DIRECTION - 1 Pcs. <input checked="" type="checkbox"/> VALVE - 1 Pcs.		JETTY
✓	✓	✓	<input checked="" type="checkbox"/> FIRE SUIT - 4 Pcs. <input checked="" type="checkbox"/> FIRE HELMET - 4 Pcs. <input checked="" type="checkbox"/> BOOTS - 4 Pcs. <input checked="" type="checkbox"/> GLOVES - 4 Pcs.		FIRE SERVICE WORKSHOP
✓	✓	✓	<input checked="" type="checkbox"/> FIRE SUIT - 4 Pcs. <input checked="" type="checkbox"/> FIRE HELMET - 4 Pcs. <input checked="" type="checkbox"/> BOOTS - 4 Pcs. <input checked="" type="checkbox"/> GLOVES - 4 Pcs.		BEHIND PSB BUILDING-A
REMARKS:					
LEADER: PH LEAM					


 PTTEP PSB OPERATION UNIT		LIFEBOUY MAINTENANCE SHEET MONTHLY DATE: 25/05/24		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION: PSB					
WORK DETAILS FOR EACH UNIT					
A. LIFEBOUY IS ACCESSIBLE & EASILY REMOVED FOR USE ภาชนะสามารถใช้งานได้ และพร้อมใช้งาน					
B. VISUALLY INSPECT THE LIFEBOUY FOR DAMAGE ตรวจสอบภาชนะที่ความเสียหาย					
C. LIFEBOUY IS SEALED WITH A PLUG ภาชนะถูกปิดผนึกด้วยตะกั่ว					
D. THE GRAB LINE AROUND THE CIRCUMFERENCE IS NOT DAMAGED สายจับรอบ ๆ ภาชนะไม่มีความเสียหาย					
					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		LBV - 1 JETTY-NE
✓	✓	✓	✓		LBV - 2 JETTY BERTH - 1
✓	✓	✓	✓		LBV - 3 JETTY BERTH - 2
✓	✓	✓	✓		LBV - 4 JETTY BERTH - 3
✓	✓	✓	✓		LBV - 5 JETTY BERTH - 4
✓	✓	✓	✓		LBV - 6 JETTY BERTH - 5
✓	✓	✓	✓		LBV - 7 JETTY BERTH - 6
✓	✓	✓	✓		LBV - 8 JETTY S/W
✓	✓	✓	✓		LBV - 9 JETTY N/W
✓	✓	✓	✓		LBV - 10 JETTY BOAT
✓	✓	✓	✓		LBV - 11 JETTY BOAT
REMARKS:					
LEADER: PH LEAM					


 PTTEP PSB OPERATION UNIT		STRETCHER MAINTENANCE SHEET MONTHLY DATE: 25/05/24		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION: PSB					
WORK DETAILS FOR EACH UNIT					
A. THE STRETCHER FREE OF EXCESSIVE WEAR ภาชนะที่รองรับน้ำหนักไม่สึกหรอ					
B. ALL MOVING PART (COUPLING, LEVERS, HINGES, AND SLIDING FRAMES) OPERATE PROPERLY ส่วนที่เคลื่อนไหวทั้งหมด (การเชื่อมต่อ, หัก, บานพับ และ โครงสร้าง) ทำงานได้อย่างถูกต้อง					
C. THE COUPLING PINS ARE SECURELY IN PLACE สลักที่เชื่อมอยู่ในที่อย่างมั่นคง					
D. THE FOOT SECTION LOCK PROPERLY INTO EACH POSITION ส่วนที่ล็อกที่ขาอยู่อย่างมั่นคง					
E. THE HEAD-AND FOOT-END COUPLING REQUIRE LUBRICATION ส่วนหัวและส่วนท้ายต้องการการหล่อลื่น					
					
A	B	C	D	E	REMARKS
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
✓	✓	✓	✓	✓	
REMARKS:					
LEADER: PH LEAM					

 PTTEP PSB OPERATION UNIT		SAFETY SHOWER MAINTENANCE SHEET MONTHLY DATE: 25/05/24		PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1	
LOCATION: PSB					
WORK DETAILS FOR EACH UNIT					
A. EASILY LOCATED & ACCESSIBLE ACTUATOR ตัวกดน้ำสามารถใช้งานได้					
B. GOOD CENTER OF WATER PATTERN จุดศูนย์กลางของน้ำ					
C. COVERS ARE REMOVED BY WATER FLOW ฝักบัวถูกถอดออกโดยน้ำที่ไหล					
D. VALVE ACTUATOR IS EASY TO LOCATE หัวจับวาล์วสามารถใช้งานได้					
					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		CHEMICAL ROOM - PSB-WH02
✓	✓	✓	✓		WASTE AREA
✓	✓	✓	✓		CHEMICAL ROOM - PSB-WH06
✓	✓	✓	✓		FREE ZONE
✓	✓	✓	✓		CPOC ROOF SHED
REMARKS:					
LEADER: PH LEAM					

PTTEP PSB		EYE WASH STATION MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION: PSB		SAFETY SERVICE PAGE 1 OF 1	
<p>WORK DETAILS FOR EACH UNIT</p> <p>A. NON OBSTRUCTION ไม่มีสิ่งกีดขวาง การใช้งานไม่สะดวก</p> <p>B. DUST CAPS OR DUST COVER ARE IN PLACE วัสดุปิดบังหรือฝาครอบบนถังดับเพลิงต้องอยู่ในที่ถูกต้องและสมบูรณ์</p> <p>C. WATER IS AT THE PROPER FILL LINE & NO LEAKING ระดับน้ำอยู่ในที่ที่กำหนดและไม่มีน้ำรั่ว</p> <p>D. NO DAMAGE OR CRACK TO THE UNIT ถัง-ขวด อยู่ในสภาพที่สมบูรณ์ ไม่มีความเสียหาย</p> <p>E. ADEQUATE WATER PRESSURE AND FLOW แรงดันน้ำที่เพียงพอ</p>					
					
A	B	C	D	E	REMARKS
✓	✓	✓	✓	✓	CPOC WH - COOL ROOM
✓	✓	✓	✓	✓	WASTE AREA OFFICE
✓	✓	✓	✓	✓	WASTE CHEMICAL TRANSIT
✓	✓	✓	✓	✓	WELL SERVICE WORKSHOP - NE
✓	✓	✓	✓	✓	WELL SERVICE WORKSHOP - NW
✓	✓	✓	✓	✓	PSB BUILDING-A-GENERATOR
✓	✓	✓	✓	✓	EMI WSK3 workshop
<p>REMARKS:</p>					
<p>LEADER: <u>PM Jearm</u></p>					

PTTEP PSB		TORCH MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION: PSB		SAFETY SERVICE PAGE 1 OF 1	
<p>WORK DETAILS FOR EACH UNIT</p> <p>A. CHECK FUNTIONS AND CONDITIONS OF TORCH ตรวจสอบฟังก์ชันและเงื่อนไขของไฟฉาย</p> <p>B. CHECK THE BRIGHTNESS OF THE LIGHT ตรวจสอบความสว่างของแสง</p> <p>C. WALL BRACKET SECURE FOR USING ผนังยึดที่ปลอดภัยสำหรับการใช้งาน</p> <p>D. ABLE TO BE USED OR OBTAINED สามารถนำมาใช้หรือการใช้งานได้</p> <p>E. APPLY INSPECTION STICKER AND RECORD ON TASK SHEET ใช้ติดฉลากตรวจสอบและบันทึกบนแผ่นงาน</p>					
					
A	B	C	D	E	REMARKS
✓	✓	✓	✓	✓	PSB WH16 - Cool room C1(BKT)
✓	✓	✓	✓	✓	PSB WH16 - Cool room C2 (BKT)
✓	✓	✓	✓	✓	PSB WH16 - Cool room AB 1 st (BKT)
✓	✓	✓	✓	✓	PSB WH16 - Cool room AB 2 nd(BKT)
✓	✓	✓	✓	✓	PSB WH16 - Inside door2 (BKT)
✓	✓	✓	✓	✓	PSB BUILDING-A-ELECTRICAL ROOM
✓	✓	✓	✓	✓	PSB BUILDING-A-GENERATOR ROOM
✓	✓	✓	✓	✓	FREE ZONE COOL ROOM
✓	✓	✓	✓	✓	PSB WH11 COOL ROOM
✓	✓	✓	✓	✓	EMI1 FLOOR 1st
✓	✓	✓	✓	✓	EMI1 FLOOR 2nd
✓	✓	✓	✓	✓	WELL SERVICE OFFICE/FLOOR 2nd
✓	✓	✓	✓	✓	WELL SERVICE WORKSHOP
✓	✓	✓	✓	✓	CPOC WH
✓	✓	✓	✓	✓	CPOC COOL ROOM
<p>REMARKS:</p>					
<p>LEADER: <u>PM Jearm</u></p>					

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION: PSB		SAFETY SERVICE PAGE 1 OF 4	
<p>WORK DETAILS FOR EACH UNIT</p> <p>A. GOOD ALARM SENSOR MODE โหมดการแจ้งเตือนที่ดี</p> <p>B. CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยแปรงฝุ่น</p> <p>C. CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT ให้ตรวจสอบสภาพตัวอุปกรณ์ กระดาษหรือกระจก</p> <p>D. CHECK ID. NO ตรวจสอบหมายเลขตัว</p>					
					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	A101	PSB BUILDING-A / 1ST FLOOR SHEYRON OFFICE
✓	✓	✓	✓	A102	PSB BUILDING-A / 1ST FLOOR WEST DOOR
✓	✓	✓	✓	A103	PSB BUILDING-A / 1ST FLOOR MEDIC ROOM
✓	✓	✓	✓	A104	PSB BUILDING-A / SECURITY BOX 4
✓	✓	✓	✓	A105	PSB BUILDING-A / 2nd FLOOR AT STAIR
✓	✓	✓	✓	A106	PSB BUILDING-A / 2nd FLOOR CPOC OFFICE
✓	✓	✓	✓	A107	PSB BUILDING-A-2nd FLOOR EMERGENCY DOOR
✓	✓	✓	✓	A108	PSB BUILDING-A-3rd FLOOR AT STAIR
✓	✓	✓	✓	A109	PSB BUILDING-A / 3rd FLOOR RADIO ROOM
✓	✓	✓	✓	A110	PSB BUILDING-A / 3rd FLOOR ROOM 304
✓	✓	✓	✓	A111	PSB BUILDING-A / 3rd FLOOR ROOM 310
✓	✓	✓	✓	A112	PSB BUILDING-A / IN SIDE ELECTRICAL ROOM
✓	✓	✓	✓	A113	PSB BUILDING-A / IN FRONT OFF FIRE PUMP
✓	✓	✓	✓	N0.01	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.02	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.03	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.04	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.05	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.06	PSB BUILDING-B / 1ST FLOOR
✓	✓	✓	✓	N0.07	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.08	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.09	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.10	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.11	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.12	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.13	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.14	PSB BUILDING-B / 2nd FLOOR
✓	✓	✓	✓	N0.15	PSB BUILDING-B / 3-4 FLOOR
✓	✓	✓	✓	J101	IN SIDE JETTY ELECTRICAL ROOM
✓	✓	✓	✓	J102	JETTY BERTH 1
✓	✓	✓	✓	J103	JETTY BERTH 2
✓	✓	✓	✓	J104	JETTY BERTH 6
✓	✓	✓	✓	J105	JETTY BULK TANK 1

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT		LOCATION: PSB		SAFETY SERVICE PAGE 2 OF 4	
<p>WORK DETAILS FOR EACH UNIT</p> <p>A. GOOD ALARM SENSOR MODE โหมดการแจ้งเตือนที่ดี</p> <p>B. CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยแปรงฝุ่น</p> <p>C. CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT ให้ตรวจสอบสภาพตัวอุปกรณ์ กระดาษหรือกระจก</p> <p>D. CHECK ID. NO ตรวจสอบหมายเลขตัว</p>					
					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓	J106	JETTY BULK TANK 2
✓	✓	✓	✓	J107	JETTY OFFICE
✓	✓	✓	✓	J108	SECURITY BOX 6 JETTY
✓	✓	✓	✓	B119	CREW CHANGE AREA
✓	✓	✓	✓	ST-01	EMI SPECIAL TOOL S-E W/H
✓	✓	✓	✓	ST-02	EMI SPECIAL TOOL S-E W/H
✓	✓	✓	✓	ST-03	EMI SPECIAL TOOL S-W W/H
✓	✓	✓	✓	B120	WASTE AREA ROW 8
✓	✓	✓	✓	B121	WASTE AREA ROW 20
✓	✓	✓	✓	B122	TERMINAT CHECK-IN/Out
✓	✓	✓	✓	B123	TERMINAT CHECK-IN/Out
✓	✓	✓	✓	B109	PSB WH16-COOM ROOM CA-B
✓	✓	✓	✓	B108	PSB WH16-COOM ROOM CE
✓	✓	✓	✓	B111	INFRONT OF PSB WH16-N
✓	✓	✓	✓	B107	INFRONT OF PSB WH16-W
✓	✓	✓	✓	B110	INSIDE PSB WH16-West
✓	✓	✓	✓	B112	PSB WAREHOUSE-B- B32
✓	✓	✓	✓	B106	PSB WH16-STOCK CONTROL-S-E
✓	✓	✓	✓	B105	PSB WH16-CHEMICAL ROOM
✓	✓	✓	✓	B104	PSB WH16- PAINTING STORAGE
✓	✓	✓	✓	B117	PSB WH16-OFFICE
✓	✓	✓	✓	B116	PSB WH16-OFFICE
✓	✓	✓	✓	B115	PSB WH16-OFFICE
✓	✓	✓	✓	B113	GBS WAREHOUSE1 - B 33
✓	✓	✓	✓	B114	GBS WAREHOUSE1 - B 33
✓	✓	✓	✓	B101	PSB WH16-GBS WORKSHOP
✓	✓	✓	✓	B103	PSB WH16-GBN WORKSHOP
✓	✓	✓	✓	B102	PSB WH16-GBN WORKSHOP
✓	✓	✓	✓	F103	FREE ZONE COOL ROOM
✓	✓	✓	✓	F104	FREE ZONE COOL ROOM
✓	✓	✓	✓	F105	FREE ZONE WH STAIR
✓	✓	✓	✓	F106	FREE ZONE WH WEST
✓	✓	✓	✓	F107	FREE ZONE WH SAW

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT	LOCATION : PSB	DATE: 29/05/24	SAFETY SERVICE PAGE 3 OF 4		
WORK DETAILS FOR EACH UNIT A. GOOD ALARM SENSOR MODE ตรวจเช็คการแจ้งเตือนที่ติดตั้ง B. CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน C. CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT ให้ตรวจสอบสภาพการชำรุดแตกหัก กระจกตู้รับสัญญาณ D. CHECK ID. NO. ตรวจสอบหมายเลขประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓		FREE ZONE WH S/E
✓	✓	✓	✓		FREE ZONE CHEMICAL
✓	✓	✓	✓		FREE ZONE CHEMICAL
✓	✓	✓	✓		FREE ZONE NEW WH
✓	✓	✓	✓		EMI WORKSHOP#1 / N
✓	✓	✓	✓		EMI WORKSHOP#1 / NW
✓	✓	✓	✓		EMI WORKSHOP#1 / SW
✓	✓	✓	✓		EMI WORKSHOP#1 / SW
✓	✓	✓	✓		EMI WORKSHOP#2 / STAIRS
✓	✓	✓	✓		EMI WORKSHOP#2 / STAIR/N
✓	✓	✓	✓		EMI WORKSHOP#2
✓	✓	✓	✓		EMI WORKSHOP#2 DOORS
✓	✓	✓	✓		EMI WORKSHOP#2 DOOR/N
✓	✓	✓	✓		EMI WORKSHOP#2 LEVEL2
✓	✓	✓	✓		EMI WORKSHOP#2 LEVEL2
✓	✓	✓	✓		EMI#3 WORKSHOP - NW
✓	✓	✓	✓		EMI#3 WORKSHOP - SW
✓	✓	✓	✓		EMI#3 WORKSHOP - NE
✓	✓	✓	✓		EMI#3 Warehouse - E
✓	✓	✓	✓		EMI#3 Warehouse - W
✓	✓	✓	✓		EMI#3 Office floor1 - E
✓	✓	✓	✓		EMI#3 Office floor1 - W
✓	✓	✓	✓		EMI#3 Office floor2 - E
✓	✓	✓	✓		EMI#3 Office floor2 - W
✓	✓	✓	✓		WELL SERVICE OFFICE LEVEL 1
✓	✓	✓	✓		WELL SERVICE OFFICE LEVEL 2
✓	✓	✓	✓		WELL SERVICE WORKSHOP
✓	✓	✓	✓		WELL SERVICE WORKSHOP
✓	✓	✓	✓		CPOC W/H
✓	✓	✓	✓		CPOC W/H
✓	✓	✓	✓		CPOC W/H
✓	✓	✓	✓		CPOC W/H
✓	✓	✓	✓		CPOC COOL ROOM
✓	✓	✓	✓		CPOC COOL ROOM

PTTEP PSB		FIRE ALARM MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT	LOCATION : PSB	DATE: 29/05/24	SAFETY SERVICE PAGE 4 OF 4		
WORK DETAILS FOR EACH UNIT A. GOOD ALARM SENSOR MODE ตรวจเช็คการแจ้งเตือนที่ติดตั้ง B. CLEANING MANUAL NOTIFICATION DEVICE WITH A DUST BRUSH การทำความสะอาด ตัวอุปกรณ์แจ้งเตือนด้วยมือ ด้วยแปรงสีฟัน C. CHECK THE CONDITION OF THE BROKEN OR CRACKED GLASS EQUIPMENT ให้ตรวจสอบสภาพการชำรุดแตกหัก กระจกตู้รับสัญญาณ D. CHECK ID. NO. ตรวจสอบหมายเลขประจำตัว					
A	B	C	D	REMARKS	AREA-LOCATION
✓	✓	✓	✓		PSB FIRE SERVICE WORKSHOP
✓	✓	✓	✓		PSB W/H#1 OFFICE - N
✓	✓	✓	✓		PSB W/H#1 OFFICE - S/E
✓	✓	✓	✓		PSB W/H#1 W/H COOL ROOM - S
✓	✓	✓	✓		PSB W/H#1 CHEMICAL ROOM - W/N
✓	✓	✓	✓		PSB W/H#1 CHEMICAL ROOM - S
✓	✓	✓	✓		PSB CHEMICAL WASTE TRANSIT
✓	✓	✓	✓		PSB CHEMICAL WASTE TRANSIT
✓	✓	✓	✓		PSB GAS STORE S/W
✓	✓	✓	✓		PSB W/H#1
✓	✓	✓	✓		PSB W/H#1
✓	✓	✓	✓		PSB W/H#4
✓	✓	✓	✓		PSB W/H#4
✓	✓	✓	✓		PSB W/H#4
✓	✓	✓	✓		PSB W/H#4
✓	✓	✓	✓		PSB W/H#4
✓	✓	✓	✓		PSB W/H#4
✓	✓	✓	✓		PSB W/H#4
✓	✓	✓	✓		PSB W/H#5
✓	✓	✓	✓		PSB W/H#5
✓	✓	✓	✓		PSB W/H#5
✓	✓	✓	✓		PSB W/H#5
✓	✓	✓	✓		PSB SERVICE MAINTENANCE WORKSHOP

REMARKS:

LEADER *PH LEAM*

PTTEP PSB		EMERGENCY PHONE MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT	LOCATION : PSB	DATE: 29/05/24	SAFETY SERVICE PAGE 1 OF 1		
WORK DETAILS FOR EACH UNIT A. PHONE ACCESSIBLE การใช้โทรศัพท์ B. EMERGENCY PHONE NUMBERS AND PROCEDURES POSTED AT OR NEAR TELEPHONE หมายเลขโทรศัพท์ฉุกเฉินและวิธีการโดยติดใกล้โทรศัพท์ C. SAFETY BOARD DISPLAYING EMERGENCY PHONE NUMBER บอร์ดความปลอดภัยแสดงหมายเลขโทรศัพท์ฉุกเฉิน D. FUNCTIONALITY SUITABLE ใช้งานได้เหมาะสม					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		FREE ZONE CONTAINER
✓	✓	✓	✓		CREW CHANGE AREA
✓	✓	✓	✓		JETTY
✓	✓	✓	✓		PSB W/H#6- MUSTER POINT
✓	✓	✓	✓		EMI MUSTER POINT


REMARKS:

LEADER *PH LEAM*


PTTEP PSB		FIRE HOSE TROLLEY MAINTENANCE SHEET MONTHLY		PSB SONGKHLA	
OPERATION UNIT	LOCATION : PSB	DATE: 29/05/24	SAFETY SERVICE PAGE 1 OF 1		
WORK DETAILS FOR EACH UNIT All equipment complete as specified อุปกรณ์ครบตามจำนวนที่ระบุไว้ All equipment is in working condition. All equipment is in working condition. อุปกรณ์ถูกต้องและอยู่ในสภาพพร้อมใช้งาน NON-OBSTRUCTED ไม่มีสิ่งกีดขวาง The Trolley is in good working condition, easy to move. รถเข็นอยู่ในสภาพพร้อมใช้งาน และใช้งานได้ง่าย					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		BEHIND OF PSB BUILDING-A
✓	✓	✓	✓		RESIDE SECURITY BOX-2

REMARKS:

LEADER *PH LEAM*



PTTEP
PSB
FIRE FIGHTING EQUIPMENT
MONTHLY CHECK LIST



OPERATION UNIT

	ISSUED	RETURN	COMPLETED
1. FIRE HYDRANT	28/06/24	28/06/24	100%
2. FIRE HOSE REEL	28/06/24	28/06/24	100%
3. FIRE HOSE	28/06/24	28/06/24	100%
4. EXTINGUISHER	28/06/24	28/06/24	100%
5. FIRE MAN EOP	28/06/24	28/06/24	100%
6. LIFE BUOY	28/06/24	28/06/24	100%
7. STRETCHER	28/06/24	28/06/24	100%
8. SAFETY SHOWER	28/06/24	28/06/24	100%
9. EYE WASH STATION	28/06/24	28/06/24	100%
10. TROCH	28/06/24	28/06/24	100%
11. FIRE ALARM	28/06/24	28/06/24	100%
12. EMERGENCY PHONE	28/06/24	28/06/24	100%
13. FIRE HOSE TROLLEY	28/06/24	28/06/24	100%
TASK COMPLETED			100%

TIME SPENDING: 19.45 MIN/HR

REMARK:

CHECK BY: PM team DATE: 28/06/2024



PTTEP
PSB
FIRE HYDRANT
MAINTENANCE SHEET
MONTHLY



OPERATION UNIT LOCATION: PSB DATE: 28/06/24 PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT


A. HYDRANTS ARE ACCESSIBLE & FREE OF OBSTRUCTION
 B. TOP OF HYDRANT IS NOT LEAKING WHEN HYDRANT IS ON
 C. RUBBER SEAL UNDER CAPS ARE NOT LEAKING
 D. HYDRANT BARREL IS IN GOOD CONDITION WITHOUT CRACKS OR CORROSION
 E. OUTLET CAPS SECURE
 F. CLEAN AND GREASE OF MOVING PARTS




A	B	C	D	E	F	REMARKS	ID NO	LOCATION
✓	✓	✓	✓	✓	✓		HD1	SECURITY BOX2
✓	✓	✓	✓	✓	✓		HD2	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD3	SECURITY BOX3
✓	✓	✓	✓	✓	✓		HD4	SECURITY BOX4
✓	✓	✓	✓	✓	✓		HD5	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD6	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD7	JETTY STREET WAY
✓	✓	✓	✓	✓	✓		HD8	JETTY BERTH1
✓	✓	✓	✓	✓	✓		HD9	JETTY BERTH2
✓	✓	✓	✓	✓	✓		HD10	JETTY BERTH3
✓	✓	✓	✓	✓	✓		HD11	JETTY BERTH4
✓	✓	✓	✓	✓	✓		HD12	JETTY BERTH5
✓	✓	✓	✓	✓	✓		HD13	JETTY BERTH6
✓	✓	✓	✓	✓	✓		HD14	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD15	WATER PUMP CONTROLLER
✓	✓	✓	✓	✓	✓		HD16	PSB BUILDING-B / West
✓	✓	✓	✓	✓	✓		AHD-01	PSB WH - 04
✓	✓	✓	✓	✓	✓		FHD-01	FREE ZONE-CHEMICAL ROOM

REMARKS:

LEADER: PM team




PTTEP
PSB
FIRE HOSE REEL
MAINTENANCE SHEET
MONTHLY



OPERATION UNIT LOCATION: PSB DATE: 28/06/24 PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT


A. THE HOSE REEL IS READILY ACCESSIBLE WITH NO OBSTACLES RESTRICTING ITS ACCESS
 B. ANY DAMAGE OR CORROSION OF THE HOSE REEL (1= GOOD, 2= POOR, 3= BAD, 4= VERY BAD)
 C. THE NOZZLE IS RETAINED IN THE NOZZLE INTERLOCK
 D. THE HOSE REEL CAN BE UNWOUND FREELY IN ITS INTENDED DIRECTION
 E. CLEAN AND GREASE AS NECESSARY




A	B	C	D	E	REMARKS	ID NO	LOCATION
✓	✓	✓	✓	✓		FH10	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH01	PSB BUILDING-B / OFFICE FLOOR1
✓	✓	✓	✓	✓		FH02	PSB BUILDING-B / OFFICE FLOOR2
✓	✓	✓	✓	✓		FH03	PSB BUILDING-B / OFFICE FLOOR3
✓	✓	✓	✓	✓		FR4	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR5	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR6	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		FR7	PSB BUILDING-A / FLOOR1
✓	✓	✓	✓	✓		FR8	PSB BUILDING-A / FLOOR2
✓	✓	✓	✓	✓		FR9	PSB BUILDING-A / FLOOR3
✓	✓	✓	✓	✓		AFR 01	PSB WH 04
✓	✓	✓	✓	✓		FH-11	FREE ZONE CHEMICAL ROOM

REMARKS:

LEADER: PM team




PTTEP
PSB
FIRE HOSE BOX
MAINTENANCE SHEET
MONTHLY



OPERATION UNIT LOCATION: PSB DATE: 28/06/24 PAGE 1 OF 1

WORK DETAILS FOR EACH UNIT

A. HOSE BOX IN GOOD CONDITION WITHOUT CRACKS
 B. SECURING STRAP & DOOR PACKING IN A GOOD CONDITION
 C. NOZZLE OF APPROPRIATE SIZE & TYPE
 D. FIRE HOSE OF APPROPRIATE LENGTH
 E. APPROPRIATE SPANNER
 F. HOSE COUPLING IS PROPERLY CONNECTED
 G. NOZZLE IS FREELY MOVING



A	B	C	D	E	F	G	REMARKS	LOCATION
✓	✓	✓	✓	✓	✓	✓	[FH 38 mm - 1 Pc] [FH 64 mm - 1 Pc] NOZZLE - 1	JETTY BERTH - 1 (FH 01)
✓	✓	✓	✓	✓	✓	✓	[FH 38 mm - 1 Pc] [FH 64 mm - 1 Pc] NOZZLE - 1	JETTY BERTH - 2 (FH 02)
✓	✓	✓	✓	✓	✓	✓	[FH 38 mm - 1 Pc] [FH 64 mm - 1 Pc] NOZZLE - 1	JETTY BERTH - 4 (FH 03)
✓	✓	✓	✓	✓	✓	✓	[FH 38 mm - 1 Pc] [FH 64 mm - 1 Pc] NOZZLE - 1	JETTY BERTH - 5 (FH 04)
✓	✓	✓	✓	✓	✓	✓	[FH 38 mm - 1 Pc] [FH 64 mm - 1 Pc] NOZZLE - 1	JETTY BERTH - 6 (FH 05)
✓	✓	✓	✓	✓	✓	✓	[FH 38 mm - 1 Pc] [FH 64 mm - 1 Pc] NOZZLE - 1	PSB JETTY HD 07 (FH 03)
✓	✓	✓	✓	✓	✓	✓	NOZZLE-2 Y-VALVE-1 HAND TOOL-1	BEHIND PSB BUILDING-A

REMARKS:

LEADER: PM team

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

OPERATION UNIT LOCATION: PSB

DATE: 28/06/24

SAFETY SERVICE

PAGE 1 OF 6

WORK DETAILS FOR EACH UNIT.

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
การมองเห็นถังดับเพลิงไม่ถูกสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLES)
ตัวล็อกและซีลประตูยังใช้งานได้ (ไม่มีการเสียหาย ร้าวซึม หรืออุดตัน)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่ใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีน้ำมันเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำการใช้งานบนป้ายระบุถังดับเพลิงสามารถอ่านได้และชี้ให้เห็นภายนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงต้องได้รับการตรวจสอบโดยช่างเทคนิคที่ได้รับการรับรอง

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		PP-01	Dry powder 6.8 kg	Security box 4	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-01	Co2 4.5 kg		
✓	✓	✓	✓	✓		PC-02	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ Room 108	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-03	Co2 4.5 kg		
✓	✓	✓	✓	✓		PP-04	Dry powder 6.8 kg	PSB OFFICE 1st FLOOR/ Fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-05	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 221	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-06	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Room 217	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-07	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-08	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ CPOC office	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-09	Dry powder 6.8 kg	PSB OFFICE 2nd FLOOR/ Fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-10	Dry powder 6.8 kg	PSB office 3rd R / Infront off radio room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-11	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ Fire hose box (N)	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-12	Dry powder 6.8 kg	PSB OFFICE 3rd FLOOR/ Fire hose box (S)	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-03	Co2 4.5 kg	PSB office floor/ Infront off radio room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-04	Co2 4.5 kg		
✓	✓	✓	✓	✓		PC-07	Co2 4.5 kg	PSB Fire pump	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-14	Dry powder 6.8 kg	Driver container	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-16	Dry powder 6.8 kg	Security box 2	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-17	Dry powder 6.8 kg	Fire service shop	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-05	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PC-06	Co2 4.5 kg	Electrical room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-01	From 9 Line	Generator room	PSB BUILDING-A
✓	✓	✓	✓	✓		PP-02	From 9 Line	Generator room	PSB BUILDING-A
✓	✓	✓	✓	✓		NP-01	Dry powder 6.8 kg	NEW PSB FLOOR1 E/S	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-02	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-03	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-04	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-05	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-06	Dry powder 6.8 kg	NEW PSB FLOOR1	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-07	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-08	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-09	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-10	Dry powder 6.8 kg	NEW PSB FLOOR2	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-11	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-12	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

OPERATION UNIT LOCATION: PSB

DATE: 28/06/24

SAFETY SERVICE

PAGE 2 OF 6

WORK DETAILS FOR EACH UNIT.

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
การมองเห็นถังดับเพลิงไม่ถูกสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLES)
ตัวล็อกและซีลประตูยังใช้งานได้ (ไม่มีการเสียหาย ร้าวซึม หรืออุดตัน)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่ใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีน้ำมันเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำการใช้งานบนป้ายระบุถังดับเพลิงสามารถอ่านได้และชี้ให้เห็นภายนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงต้องได้รับการตรวจสอบโดยช่างเทคนิคที่ได้รับการรับรอง

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		NP-13	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		NP-14	Dry powder 6.8 kg	NEW PSB FLOOR3	PSB BUILDING-B
✓	✓	✓	✓	✓		JP 01	Dry powder 6.8 kg	Security box 6	JETTY
✓	✓	✓	✓	✓		JP 02	Dry powder 6.8 kg	Fire hose reel box No.1	JETTY
✓	✓	✓	✓	✓		JP 03	Dry powder 6.8 kg	Fire hose reel box No.2	JETTY
✓	✓	✓	✓	✓		JP 04	Dry powder 6.8 kg	Fire hose reel box No.3	JETTY
✓	✓	✓	✓	✓		JP 05	Dry powder 6.8 kg	Fire hose reel box No.4	JETTY
✓	✓	✓	✓	✓		JP 06	Dry powder 6.8 kg	Fire hose reel box No.5	JETTY
✓	✓	✓	✓	✓		JP 07	Dry powder 6.8 kg	Infront off office	JETTY
✓	✓	✓	✓	✓		JP 08	Dry powder 6.8 kg	Infront off Electrical room	JETTY
✓	✓	✓	✓	✓		JP 09	Dry powder 6.8 kg	Security box 5	JETTY
✓	✓	✓	✓	✓		JP 10	Dry powder 6.8 kg	Container of CPOC	JETTY
✓	✓	✓	✓	✓		JP 11	Dry powder 6.8 kg	On the boat # 04	JETTY
✓	✓	✓	✓	✓		JP 12	Dry powder 2.5 kg	Generator Room 02	JETTY
✓	✓	✓	✓	✓		JP 13	Dry powder 2.5 kg	On the boat # 02	JETTY
✓	✓	✓	✓	✓		JP 14	Dry powder 2.5 kg	Electrical room	JETTY
✓	✓	✓	✓	✓		PP 21	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 22	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 18	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 19	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PP 20	Dry powder 6.8 kg	Maintenance work shop	PSB
✓	✓	✓	✓	✓		PC 08	Co2 4.5 kg	Canteen	PSB
✓	✓	✓	✓	✓		MF 01	From 9 Line	Security box 3	PSB
✓	✓	✓	✓	✓		AP 01	Dry powder 6.8 kg	PSB WAREHOUSE#1-office	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 01	Co2 4.5 kg	PSB Warehouse#1-office	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 02	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 03	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 04	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 05	Dry powder 6.8 kg	Inside PSB warehouse#1-(W)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 06	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 07	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 08	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 09	Dry powder 6.8 kg	Inside PSB warehouse#1-(East)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 10	Dry powder 6.8 kg	Arbitr warehouse/infront off cool room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 02	Co2 4.5 kg	Inside Arbitr warehouse(N)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 11	Dry powder 6.8 kg	Inside PSB W/H#1- roof shade	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 12	Dry powder 6.8 kg	Inside PSB W/H#1- roof shade	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 13	Dry powder 6.8 kg	PSB W/H#2-waste transit	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 14	Dry powder 6.8 kg	PSB W/H#2-waste transit	PSB WAREHOUSE

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

OPERATION UNIT LOCATION: PSB

DATE: 28/06/24

SAFETY SERVICE

PAGE 3 OF 6

WORK DETAILS FOR EACH UNIT.

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
การมองเห็นถังดับเพลิงไม่ถูกสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLES)
ตัวล็อกและซีลประตูยังใช้งานได้ (ไม่มีการเสียหาย ร้าวซึม หรืออุดตัน)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่ใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีน้ำมันเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำการใช้งานบนป้ายระบุถังดับเพลิงสามารถอ่านได้และชี้ให้เห็นภายนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงต้องได้รับการตรวจสอบโดยช่างเทคนิคที่ได้รับการรับรอง

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		AP 15	Dry powder 6.8 kg	Infront off chemical room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 16	Dry powder 6.8 kg	Chemical room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 17	Dry powder 6.8 kg	Chemical room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 03	Co2 4.5 kg	Electrical room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 18	Dry powder 6.8 kg	Paint store	PSB WAREHOUSE
✓	✓	✓	✓	✓		AF 01	From 9 Line	Plant store	PSB WAREHOUSE
✓	✓	✓	✓	✓		AF 02	From 9 Line	Chemical room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 19	Dry powder 9 kg	Inside PSB warehouse#4-(W)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 20	Dry powder 9 kg	Inside PSB warehouse#4-Mezzanine Deck/E	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 21	Dry powder 9 kg	Inside PSB warehouse#4(S)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 22	Dry powder 9 kg	Office PSB warehouse#4(E)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 23	Dry powder 9 kg	Inside PSB warehouse#4(E)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 24	Dry powder 9 kg	Inside PSB warehouse#4(N)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 25	Dry powder 9 kg	PSB warehouse#4(S)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AP 26	Dry powder 6.8 kg	Inside PSB warehouse#4	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 04	Co2 5 kg	Office PSB warehouse#4(E)	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 05	Co2 5 kg	PSB Warehouse#4 - Cool Room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 06	Co2 5 kg	PSB Warehouse#4 - Cool Room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 07	Co2 5 kg	PSB Warehouse#4 - Electrical Room	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 08	Co2 5 kg	PSB Warehouse#4 - Forklift battery charger	PSB WAREHOUSE
✓	✓	✓	✓	✓		AC 09	Co2 5 kg	PSB Warehouse#4 - Forklift battery charger	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 01	Dry powder 6.8 kg	Security box 8	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 02	Dry powder 6.8 kg	Infront off generator room	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 03	Co2 4.5 kg	Infront off generator room	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 04	From 9 Line	Infront off generator room	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 05	Dry powder 6.8 kg	Inside Ware house (N)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 06	Dry powder 6.8 kg	Inside Ware house (S)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 07	Dry powder 6.8 kg	Infront Warehouse	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 08	Dry powder 6.8 kg	Infront off pipe team office (N)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 09	Dry powder 6.8 kg	Infront off pipe team office (E)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 10	Dry powder 6.8 kg	Infront off Ware house (Door 2)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 11	Dry powder 6.8 kg	Infront off Ware house (Door 3)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 12	Dry powder 23 kg	Inside Ware house (Door2)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 13	Dry powder 23 kg	Inside Ware house (Door3)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 14	Dry powder 23 kg	Infront off Ware house (E)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 15	Dry powder 6.8 kg	Office Ware house	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 16	Dry powder 6.8 kg	Infront off coolroom (ADI w)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 17	Dry powder 6.8 kg	Infront off coolroom (ADI E)	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 18	Dry powder 6.8 kg	Infront off coolroom C2	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 19	Dry powder 6.8 kg	Infront off coolroom C2	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 20	Dry powder 6.8 kg	Inside coolroom A/B 2nd floor	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 21	Dry powder 6.8 kg	Inside coolroom A/B 2nd floor	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 22	Dry powder 6.8 kg	Zone M 1st floor	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 23	Dry powder 6.8 kg	Zone M 1st floor	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 24	Dry powder 6.8 kg	Zone M 1st floor	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 25	Dry powder 6.8 kg	Zone M 2nd floor	PSB WAREHOUSE

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

OPERATION UNIT LOCATION: PSB

DATE: 28/06/24

SAFETY SERVICE

PAGE 4 OF 6

WORK DETAILS FOR EACH UNIT.

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
การมองเห็นถังดับเพลิงไม่ถูกสิ่งกีดขวาง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLES)
ตัวล็อกและซีลประตูยังใช้งานได้ (ไม่มีการเสียหาย ร้าวซึม หรืออุดตัน)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่ใช้งานได้ และตรวจสอบให้แน่ใจว่ายังมีน้ำมันเต็ม

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำการใช้งานบนป้ายระบุถังดับเพลิงสามารถอ่านได้และชี้ให้เห็นภายนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงต้องได้รับการตรวจสอบโดยช่างเทคนิคที่ได้รับการรับรอง

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		BP 19	Dry powder 6.8 kg	Zone M 2nd floor	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 20	Dry powder 6.8 kg	Inside Ware house	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 21	Dry powder 6.8 kg	Inside Ware house	PSB WAREHOUSE
✓	✓	✓	✓	✓		BP 22	Dry powder 6.8 kg	Inside Ware house	PSB W

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

SAFETY SERVICE

PAGE 5 OF 6

OPERATION UNIT LOCATION: PSB DATE: 28/06/24

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
การมองเห็นถังดับเพลิงไม่ถูกสิ่งกีดขวางบัง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLES)
สลักเกลียวล็อกถังดับเพลิงอยู่ในสภาพดี และซีลถังดับเพลิงไม่แตก (ไม่พบความเสียหาย รั่วไหล หรือสิ่งอุดตันที่หัวฉีด)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่าถังดับเพลิงยังเต็มอยู่

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำบนป้ายชื่อถังดับเพลิงอ่านได้ และหันออกด้านนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงที่ได้รับการบำรุงรักษาตามข้อกำหนดต้องมีใบรับรองการตรวจสอบ

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		EP 08	Dry powder 6.8 kg	EMI 1st floor (N-W)	EMI 2
✓	✓	✓	✓	✓		EC 01	Co2 4.5 kg	EMI 1st floor (S-W)	EMI 2
✓	✓	✓	✓	✓		EP 09	Dry powder 6.8 kg	EMI 2nd floor (N)	EMI 2
✓	✓	✓	✓	✓		EP 10	Dry powder 6.8 kg	EMI 2nd floor (S)	EMI 2
✓	✓	✓	✓	✓		EC 02	Co2 4.5 kg	EMI 2nd floor inside room	EMI 2
✓	✓	✓	✓	✓		EP 11	Dry powder 6.8 kg	Well service office 2nd floor	WELL SERVICE
✓	✓	✓	✓	✓		EP 12	Dry powder 6.8 kg	1st floor In front of Meeting room	WELL SERVICE
✓	✓	✓	✓	✓		EP 13	Dry powder 6.8 kg	1st floor In front of Cost room	WELL SERVICE
✓	✓	✓	✓	✓		EP 14	Dry powder 6.8 kg	Container office	WELL SERVICE
✓	✓	✓	✓	✓		EP 15	Dry powder 6.8 kg	Roof shade knot	WELL SERVICE
✓	✓	✓	✓	✓		EP 16	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP 17	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP 18	Dry powder 6.8 kg	store room and yard	WELL SERVICE
✓	✓	✓	✓	✓		EP 19	Dry powder 6.8 kg	Work shop (N-E)	WELL SERVICE
✓	✓	✓	✓	✓		EP 20	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EC 03	Co2 4.5 kg	Work shop (N)	WELL SERVICE
✓	✓	✓	✓	✓		EP 21	Dry powder 6.8 kg	Work shop (W)	WELL SERVICE
✓	✓	✓	✓	✓		EP 22	Dry powder 6.8 kg	EMI W543 workshop - NW	EMI W543
✓	✓	✓	✓	✓		EP 23	Dry powder 6.8 kg	EMI W543 workshop - SW	EMI W543
✓	✓	✓	✓	✓		EP 24	Dry powder 6.8 kg	EMI W543 workshop - SE	EMI W543
✓	✓	✓	✓	✓		EP 25	Dry powder 6.8 kg	EMI W543 workshop - NE	EMI W543
✓	✓	✓	✓	✓		EP 26	Dry powder 6.8 kg	EMI W543 Warehouse - E	EMI W543
✓	✓	✓	✓	✓		EP 27	Dry powder 6.8 kg	EMI W543 Warehouse - W	EMI W543
✓	✓	✓	✓	✓		EP 28	Dry powder 6.8 kg	EMI W543 Warehouse - E	EMI W543
✓	✓	✓	✓	✓		EP 29	Dry powder 6.8 kg	EMI W543 Warehouse - W	EMI W543
✓	✓	✓	✓	✓		EC 04	Co2 4.5 kg	EMI W543 Warehouse - W/Electrical room	EMI W543
✓	✓	✓	✓	✓		EC 05	Co2 4.5 kg	EMI W543 Warehouse - W/Electrical room	EMI W543
✓	✓	✓	✓	✓		CP 01	Dry powder 6.8 kg	Cpoc waste house (N-E)	CP0C
✓	✓	✓	✓	✓		CP 02	Dry powder 6.8 kg	Cpoc waste house (S-E)	CP0C
✓	✓	✓	✓	✓		CP 03	Dry powder 6.8 kg	Cpoc waste house (S-W)	CP0C
✓	✓	✓	✓	✓		CP 04	Dry powder 6.8 kg	Cpoc waste house (N-W)	CP0C
✓	✓	✓	✓	✓		CP 05	Dry powder 6.8 kg	Cpoc roof shade	CP0C
✓	✓	✓	✓	✓		CP 06	Dry powder 6.8 kg	Cpoc roof shade	CP0C
✓	✓	✓	✓	✓		CP 07	Dry powder 6.8 kg	Cpoc roof shade	CP0C
✓	✓	✓	✓	✓		CP 08	Dry powder 6.8 kg	Infront off cool room	CP0C
✓	✓	✓	✓	✓		CP 09	Dry powder 6.8 kg	Container office	CP0C
✓	✓	✓	✓	✓		CP 10	Dry powder 6.8 kg	Container office	CP0C
✓	✓	✓	✓	✓		LP 127	Dry powder 6.8 kg	COOL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 128	Dry powder 6.8 kg	COOL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 129	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE

PTTEP
PSB

EXTINGUISHER
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

SAFETY SERVICE

PAGE 6 OF 6

OPERATION UNIT LOCATION: PSB DATE: 28/06/24

WORK DETAILS FOR EACH UNIT

A. THE EXTINGUISHER IS VISIBLE & UNOBSTRUCTED
การมองเห็นถังดับเพลิงไม่ถูกสิ่งกีดขวางบัง

B. THE LOCKING PIN IS INTACT AND THE RAMPER SEAL IS UNBROKEN (NO DAMAGE, CORROSION, LEAKAGE, OR CLOGGED NOZZLES)
สลักเกลียวล็อกถังดับเพลิงอยู่ในสภาพดี และซีลถังดับเพลิงไม่แตก (ไม่พบความเสียหาย รั่วไหล หรือสิ่งอุดตันที่หัวฉีด)

C. INDICATOR IS IN THE OPERABLE POSITION & ENSURE IT IS STILL FULL
ตัวชี้วัดอยู่ในตำแหน่งที่สามารถใช้งานได้ และตรวจสอบให้แน่ใจว่าถังดับเพลิงยังเต็มอยู่

D. THE INSTRUCTIONS ON THE NAMEPLATE ARE LEGIBLE & FACING OUTWARD
คำแนะนำบนป้ายชื่อถังดับเพลิงอ่านได้ และหันออกด้านนอก

E. A LICENSED FIRE EXTINGUISHER MAINTENANCE MUST HAVE INSPECTED
ถังดับเพลิงที่ได้รับการบำรุงรักษาตามข้อกำหนดต้องมีใบรับรองการตรวจสอบ

A	B	C	D	E	REMARKS	ID No.	TYPE	LOCATION	DEPARTMENT
✓	✓	✓	✓	✓		LP 65	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 131	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 54	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 130	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 133	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 136	Dry powder 6.8 kg	INSIDE WARE HOUSE	FREE ZONE
✓	✓	✓	✓	✓		LP 137	Dry powder 6.8 kg	CHEMICAL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 08	From 9 LTR	CHEMICAL ROOM W/H	FREE ZONE
✓	✓	✓	✓	✓		LP 147	Dry powder 6.8 kg	SECURITY YARD 1	FREE ZONE
✓	✓	✓	✓	✓		LP 05	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 06	Dry powder 6.8 kg	CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LP 07	Dry powder 6.8 kg	CUSTOMS OFFICE	FREE ZONE
✓	✓	✓	✓	✓		LP 32	Dry powder 6.8 kg	PSB-W189 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓		LP 35	Dry powder 6.8 kg	PSB-W189 (Free zone)	FREE ZONE
✓	✓	✓	✓	✓		LP 146	Dry powder 6.8 kg	IN FRONT OF ROOF SHADE	FREE ZONE
✓	✓	✓	✓	✓		LP 80	Dry powder 6.8 kg	INSIDE CONTAINER	FREE ZONE
✓	✓	✓	✓	✓		LC 01	Co2 6.8 kg	SECURITY BOX No.9	FREE ZONE
✓	✓	✓	✓	✓		LP 09	From 9 LTR	CHEMICAL ROOM	FREE ZONE
✓	✓	✓	✓	✓		LP 45	Dry powder 6.8 kg	TERMINAL CHECK IN / WEST	TERMINAL
✓	✓	✓	✓	✓		LP 46	Dry powder 6.8 kg	TERMINAL CHECK IN / EAST	TERMINAL
✓	✓	✓	✓	✓		AP 27	Dry powder 6.8 kg	PSB Warehouse#5-NW	PSB Warehouse#5
✓	✓	✓	✓	✓		AP 28	Dry powder 6.8 kg	PSB Warehouse#5-SW	PSB Warehouse#5
✓	✓	✓	✓	✓		AP 29	Dry powder 6.8 kg	PSB Warehouse#5-SE	PSB Warehouse#5
✓	✓	✓	✓	✓		AP 30	Dry powder 6.8 kg	PSB Warehouse#5-NE	PSB Warehouse#5

REMARKS:

LEADER: PM Leam

PTTEP
PSB

FIRE MAN BOX
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

SAFETY SERVICE

PAGE 1 OF 1

OPERATION UNIT LOCATION: PSB DATE: 28/06/24

WORK DETAILS FOR EACH UNIT

A. CHECK FIRE SUIT, FIRE HELMET, BOOTS, GLOVES & OTHER EQUIPMENT AVAILABLE
ตรวจสอบชุดดับเพลิง, หมวกกันน็อค, รองเท้า, ถุงมือ และอุปกรณ์อื่นๆ ที่พร้อมใช้งาน

B. SECURING STRAP, DOOR PACKING AND LOCK FUNCTIONS IN A GOOD CONDITION
สายรัด, ฟองน้ำประตู และฟังก์ชันการล็อกอยู่ในสภาพดี

C. CLEAN & READY TO USE
สะอาดและพร้อมใช้งาน

A	B	C	REMARKS	LOCATION
✓	✓	✓	FIRE SUIT - 4 Pcs. ✓ FIRE HELMET - 4 Pcs. ✓ BOOTS - 4 Pcs. ✓	JETTY
✓	✓	✓	GLOVES - 4 Pcs. ✓ FOAM INJECTION - 1 Pc. ✓ VALVE - 1 Pc. ✓	FIRE SERVICE WORKSHOP
✓	✓	✓	FIRE SUIT - 4 Pcs. ✓ FIRE HELMET - 4 Pcs. ✓ BOOTS - 4 Pcs. ✓	BEHIND PSB BUILDING-A
✓	✓	✓	GLOVES - 4 Pcs. ✓ FIRE HELMET - 4 Pcs. ✓ BOOTS - 4 Pcs. ✓	
✓	✓	✓	FIRE SUIT - 4 Pcs. ✓ FIRE HELMET - 4 Pcs. ✓ BOOTS - 4 Pcs. ✓	
✓	✓	✓	GLOVES - 4 Pcs. ✓	

REMARKS:

LEADER: PM Leam

PTTEP
PSB

LIFEBUOY
MAINTENANCE SHEET
MONTHLY

PSB SONGKHLA

SAFETY SERVICE

PAGE 1 OF 1

OPERATION UNIT LOCATION: PSB DATE: 28/06/24

WORK DETAILS FOR EACH UNIT

A. LIFEBUOY IS ACCESSIBLE & EASILY REMOVED FOR USE
ห่วงยางสามารถเข้าถึงและถอดออกได้ง่าย

B. VUALLY INSPECT THE LIFEBUOY FOR DAMAGE
ตรวจสอบห่วงยางเพื่อหาความเสียหาย

C. LIFEBUOY IS SEALED WITH A PLUG
ห่วงยางถูกปิดผนึกด้วยตะกั่ว

D. THE GRAB LINE AROUND THE CIRCUMFERENCE IS NOT DAMAGED
สายรัดรอบห่วงยางไม่มีความเสียหาย

A	B	C	D	REMARKS	ID NO	LOCATION
✓	✓	✓	✓		LBY - 1	JETTY-NE
✓	✓	✓	✓		LBY - 2	JETTY BERTH - 1
✓	✓	✓	✓		LBY - 3	JETTY BERTH - 2
✓	✓	✓	✓		LBY - 4	JETTY BERTH - 3
✓	✓	✓	✓		LBY - 5	JETTY BERTH - 4
✓	✓	✓	✓		LBY - 6	JETTY BERTH - 5
✓	✓	✓	✓		LBY - 7	JETTY BERTH - 6
✓	✓	✓	✓		LBY - 8	JETTY S/W
✓	✓	✓	✓		LBY - 9	JETTY N/W
✓	✓	✓	✓		LBY - 10	JETTY BOAT
✓	✓	✓	✓		LBY - 11	JETTY BOAT

REMARKS:




LEADER: PM Leam




	STRETCHER MAINTENANCE SHEET MONTHLY		PSB SONGKHLA																																										
	OPERATION UNIT	LOCATION : PSB	SAFETY SERVICE																																										
DATE: 28/06/24		PAGE 1 OF 1																																											
WORK DETAILS FOR EACH UNIT																																													
A. THE STRETCHER FREE OF EXCESSIVE WEAR อุปกรณ์ที่เกี่ยวของต้องสะอาด ALL MOVING PART (COUPLING, LEVERS, HINGES, AND SLIDING FRAMES) OPERATE PROPERLY B. ส่วนที่เชื่อมกับหัวรถเข็น (การเชื่อมตัว, ตัวล็อก, ขาพับ และ โครงเชื่อม) ทำงานได้อย่างถูกต้อง THE COUPLING PINS ARE SECURELY IN PLACE C. เข็มล็อกอยู่ในที่ปลอดภัย THE FOOT SECTION LOCK PROPERLY INTO EACH POSITION D. ส่วนล็อกที่ถูกต้องต้องขันและทำความสะอาด THE HEAD-AND FOOT-END COUPLING REQUIRE LUBRICATION E. ส่วนหัวและส่วนท้ายต้องมีการหล่อลื่น																																													
<table border="1"> <tr> <th>A</th> <th>B</th> <th>C</th> <th>D</th> <th>E</th> <th>REMARKS</th> <th>LOCATION</th> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB WAREHOUSE#6</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>JETTY</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB WAREHOUSE#1 / OFFICE</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB BUILDING-A-MEDIC ROOM</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB BUILDING-A-MEDIC ROOM</td> </tr> </table>	A	B	C	D	E	REMARKS	LOCATION	✓	✓	✓	✓	✓		PSB WAREHOUSE#6	✓	✓	✓	✓	✓		JETTY	✓	✓	✓	✓	✓		PSB WAREHOUSE#1 / OFFICE	✓	✓	✓	✓	✓		PSB BUILDING-A-MEDIC ROOM	✓	✓	✓	✓	✓		PSB BUILDING-A-MEDIC ROOM	REMARKS:		
A	B	C	D	E	REMARKS	LOCATION																																							
✓	✓	✓	✓	✓		PSB WAREHOUSE#6																																							
✓	✓	✓	✓	✓		JETTY																																							
✓	✓	✓	✓	✓		PSB WAREHOUSE#1 / OFFICE																																							
✓	✓	✓	✓	✓		PSB BUILDING-A-MEDIC ROOM																																							
✓	✓	✓	✓	✓		PSB BUILDING-A-MEDIC ROOM																																							
LEADER: PM Team																																													

	SAFETY SHOWER MAINTENANCE SHEET MONTHLY		PSB SONGKHLA																																				
	OPERATION UNIT	LOCATION : PSB	SAFETY SERVICE																																				
DATE: 29/06/24		PAGE 1 OF 1																																					
WORK DETAILS FOR EACH UNIT																																							
A. EASILY LOCATED & ACCESSIBLE ACTUATOR ติดตั้งได้ง่ายและเข้าถึงได้ง่าย B. GOOD CENTER OF WATER PATTERN จุดศูนย์กลางของน้ำ C. COVERS ARE REMOVED BY WATER FLOW ฝักครอบจะถูกลบออกโดยน้ำที่ไหล D. VALVE ACTUATOR IS EASY TO LOCATE หัวตัววาล์วต้องอยู่ตำแหน่งที่มองเห็น																																							
<table border="1"> <tr> <th>A</th> <th>B</th> <th>C</th> <th>D</th> <th>REMARKS</th> <th>LOCATION</th> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>CHEMICAL ROOM - PSB W/H#2</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>WASTE AREA</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>CHEMICAL ROOM - PSB W/H#6</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>FREE ZONE</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>CPOC ROOF SHED</td> </tr> </table>	A	B	C	D	REMARKS	LOCATION	✓	✓	✓	✓		CHEMICAL ROOM - PSB W/H#2	✓	✓	✓	✓		WASTE AREA	✓	✓	✓	✓		CHEMICAL ROOM - PSB W/H#6	✓	✓	✓	✓		FREE ZONE	✓	✓	✓	✓		CPOC ROOF SHED	REMARKS:		
A	B	C	D	REMARKS	LOCATION																																		
✓	✓	✓	✓		CHEMICAL ROOM - PSB W/H#2																																		
✓	✓	✓	✓		WASTE AREA																																		
✓	✓	✓	✓		CHEMICAL ROOM - PSB W/H#6																																		
✓	✓	✓	✓		FREE ZONE																																		
✓	✓	✓	✓		CPOC ROOF SHED																																		
LEADER: PM Team																																							

	EYE WASH STATION MAINTENANCE SHEET MONTHLY		PSB SONGKHLA																																																								
	OPERATION UNIT	LOCATION : PSB	SAFETY SERVICE																																																								
DATE: 28/06/24		PAGE 1 OF 1																																																									
WORK DETAILS FOR EACH UNIT																																																											
A. NON OBSTRUCTION ไม่มีสิ่งกีดขวาง การเข้าถึงได้สะดวก B. DUST CAPS OR DUST COVER ARE IN PLACE ฝาครอบฝุ่นหรือฝาปิดฝุ่นอยู่ในตำแหน่งที่ถูกต้องและสมบูรณ์ C. WATER IS AT THE PROPER FILL LINE & NO LEAKING ระดับน้ำอยู่ในเกณฑ์ที่กำหนดและไม่มีน้ำรั่ว D. NO DAMAGE OR CRACK TO THE UNIT ตัวถัง อุปกรณ์ภายนอกไม่มีความเสียหาย E. ADEQUATE WATER PRESSURE AND FLOW แรงดันน้ำที่ไหลเพียงพอ																																																											
<table border="1"> <tr> <th>A</th> <th>B</th> <th>C</th> <th>D</th> <th>E</th> <th>REMARKS</th> <th>LOCATION</th> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>CPOC W/H - COOL ROOM</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>WASTE AREA OFFICE</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>WASTE CHEMICAL TRANSIT</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>WELL SERVICE WORKSHOP - NE</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>WELL SERVICE WORKSHOP - NW</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB BUILDING-A-GENERATOR</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>EMI WS#3 workshop</td> </tr> </table>	A	B	C	D	E	REMARKS	LOCATION	✓	✓	✓	✓	✓		CPOC W/H - COOL ROOM	✓	✓	✓	✓	✓		WASTE AREA OFFICE	✓	✓	✓	✓	✓		WASTE CHEMICAL TRANSIT	✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP - NE	✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP - NW	✓	✓	✓	✓	✓		PSB BUILDING-A-GENERATOR	✓	✓	✓	✓	✓		EMI WS#3 workshop	REMARKS:		
A	B	C	D	E	REMARKS	LOCATION																																																					
✓	✓	✓	✓	✓		CPOC W/H - COOL ROOM																																																					
✓	✓	✓	✓	✓		WASTE AREA OFFICE																																																					
✓	✓	✓	✓	✓		WASTE CHEMICAL TRANSIT																																																					
✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP - NE																																																					
✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP - NW																																																					
✓	✓	✓	✓	✓		PSB BUILDING-A-GENERATOR																																																					
✓	✓	✓	✓	✓		EMI WS#3 workshop																																																					
LEADER: PM Team																																																											

	TORCH MAINTENANCE SHEET MONTHLY		PSB SONGKHLA																																																																																																																
	OPERATION UNIT	LOCATION : PSB	SAFETY SERVICE																																																																																																																
DATE: 28/06/24		PAGE 1 OF 1																																																																																																																	
WORK DETAILS FOR EACH UNIT																																																																																																																			
A. CHECK FUNCTIONS AND CONDITIONS OF TORCH ตรวจสอบการทำงานของไฟฉาย B. CHECK THE BRIGHTNESS OF THE LIGHT ตรวจสอบความสว่างของแสง C. WALL BRACKET SECURE FOR USING ผนังยึดที่ปลอดภัยสำหรับการใช้งาน D. ABLE TO BE USED OR OBTAINED สามารถนำมาใช้หรือการใช้งานได้ E. APPLY INSPECTION STICKER AND RECORD ON TASK SHEET ใช้สติ๊กเกอร์ตรวจสอบและบันทึกบนแผ่นงาน																																																																																																																			
<table border="1"> <tr> <th>A</th> <th>B</th> <th>C</th> <th>D</th> <th>E</th> <th>REMARKS</th> <th>LOCATION</th> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB W/H#6 - Cool room C1 (BCT)</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB W/H#6 - Cool room C2 (BCT)</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB W/H#6 - Cool room AB 1a (BCT)</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB W/H#6 - Cool room AB 2a (BCT)</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB W/H#6 - Inside duct#2 (BCT)</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB BUILDING-A-ELECTRICAL ROOM</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB BUILDING-A-GENERATOR ROOM</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>FREE ZONE COOL ROOM</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>PSB W/H#1 COOL ROOM</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>EMI#1 FLOOR 1st</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>EMI#1 FLOOR 2nd</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>WELL SERVICE OFFICE/FLOOR 2nd</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>WELL SERVICE WORKSHOP</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>CPOC W/H</td> </tr> <tr> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td>✓</td> <td></td> <td>CPOC COOL ROOM</td> </tr> </table>	A	B	C	D	E	REMARKS	LOCATION	✓	✓	✓	✓	✓		PSB W/H#6 - Cool room C1 (BCT)	✓	✓	✓	✓	✓		PSB W/H#6 - Cool room C2 (BCT)	✓	✓	✓	✓	✓		PSB W/H#6 - Cool room AB 1a (BCT)	✓	✓	✓	✓	✓		PSB W/H#6 - Cool room AB 2a (BCT)	✓	✓	✓	✓	✓		PSB W/H#6 - Inside duct#2 (BCT)	✓	✓	✓	✓	✓		PSB BUILDING-A-ELECTRICAL ROOM	✓	✓	✓	✓	✓		PSB BUILDING-A-GENERATOR ROOM	✓	✓	✓	✓	✓		FREE ZONE COOL ROOM	✓	✓	✓	✓	✓		PSB W/H#1 COOL ROOM	✓	✓	✓	✓	✓		EMI#1 FLOOR 1st	✓	✓	✓	✓	✓		EMI#1 FLOOR 2nd	✓	✓	✓	✓	✓		WELL SERVICE OFFICE/FLOOR 2nd	✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP	✓	✓	✓	✓	✓		CPOC W/H	✓	✓	✓	✓	✓		CPOC COOL ROOM	REMARKS:		
A	B	C	D	E	REMARKS	LOCATION																																																																																																													
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room C1 (BCT)																																																																																																													
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room C2 (BCT)																																																																																																													
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room AB 1a (BCT)																																																																																																													
✓	✓	✓	✓	✓		PSB W/H#6 - Cool room AB 2a (BCT)																																																																																																													
✓	✓	✓	✓	✓		PSB W/H#6 - Inside duct#2 (BCT)																																																																																																													
✓	✓	✓	✓	✓		PSB BUILDING-A-ELECTRICAL ROOM																																																																																																													
✓	✓	✓	✓	✓		PSB BUILDING-A-GENERATOR ROOM																																																																																																													
✓	✓	✓	✓	✓		FREE ZONE COOL ROOM																																																																																																													
✓	✓	✓	✓	✓		PSB W/H#1 COOL ROOM																																																																																																													
✓	✓	✓	✓	✓		EMI#1 FLOOR 1st																																																																																																													
✓	✓	✓	✓	✓		EMI#1 FLOOR 2nd																																																																																																													
✓	✓	✓	✓	✓		WELL SERVICE OFFICE/FLOOR 2nd																																																																																																													
✓	✓	✓	✓	✓		WELL SERVICE WORKSHOP																																																																																																													
✓	✓	✓	✓	✓		CPOC W/H																																																																																																													
✓	✓	✓	✓	✓		CPOC COOL ROOM																																																																																																													
LEADER: PM Team																																																																																																																			

 PTTEP PSB OPERATION UNIT	EMERGENCY PHONE MAINTENANCE SHEET MONTHLY DATE: 08/04/25	PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1			
LOCATION: PSB					
WORK DETAILS FOR EACH UNIT					
A. PHONE ACCESSIBLE การใช้โทรศัพท์ B. EMERGENCY PHONE NUMBERS AND PROCEDURES POSTED AT OR NEAR TELEPHONE หมายเลขโทรศัพท์ฉุกเฉินและวิธีการโดยทั่วไปที่โทรศัพท์ C. SAFETY BOARD DISPLAYING EMERGENCY PHONE NUMBER ป้ายสำหรับแสดงหมายเลขโทรศัพท์ฉุกเฉิน D. FUNCTIONALITY SUITABLE ใช้งานได้เหมาะสม					
					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓		FREE ZONE CONTAINER
✓	✓	✓	✓		CREW CHANGE AREA
✓	✓	✓	✓		JETTY
✓	✓	✓	✓		PSB W/H#6- MUSTER POINT
✓	✓	✓	✓		EMI MUSTER POINT.
REMARKS <div style="text-align: right;"> LEADER <i>PM team</i> </div>					

 PTTEP PSB OPERATION UNIT	FIRE HOSE TROLLEY MAINTENANCE SHEET MONTHLY DATE: 08/04/25	PSB SONGKHLA  SAFETY SERVICE PAGE 1 OF 1			
LOCATION: PSB					
WORK DETAILS FOR EACH UNIT					
A. All equipment complete as specified อุปกรณ์ครบตามจำนวนที่ได้ระบุไว้ B. All equipment is in working condition. All equipment is in working condition. อุปกรณ์ทุกตัวอยู่ในสภาพพร้อมใช้งาน NON-OBSTRUCTED C. ไม่กีดขวาง The Trolley is in good working condition, easy to move. รถเข็นอยู่ในสภาพพร้อมใช้งาน เคลื่อนย้ายได้สะดวก					
					
A	B	C	D	REMARKS	LOCATION
✓	✓	✓	✓	<input checked="" type="checkbox"/> FH SIZE 45 MM - 4 Ft. <input checked="" type="checkbox"/> FH SIZE 64 MM - 4 Ft. <input checked="" type="checkbox"/> V-VALVE-12V <input checked="" type="checkbox"/> NOZZLE-2 Ft. <input checked="" type="checkbox"/> HAND TOOL-1 Pz.	BEHIND OF PSB BUILDING-A
✓	✓	✓	✓	<input checked="" type="checkbox"/> FH SIZE 45 MM - 3 Ft. <input checked="" type="checkbox"/> FH SIZE 64 MM - 2 Ft. <input checked="" type="checkbox"/> V-VALVE-2 Ft. <input checked="" type="checkbox"/> NOZZLE-2 Ft.	BESIDE SECURITY BOX-2
REMARKS: <div style="text-align: right;"> LEADER <i>PM team</i> </div>					

ภาคผนวก ข-16

หนังสือประสานงานโยธาธิการและผังเมือง จังหวัดสงขลา



บริษัท ปตท.สผ. อินเตอร์เนชั่นแนล จำกัด
PTTEP International Limited

บริษัทในกลุ่ม ปตท.สผ.
A Company of PTTEP Group

ที่ ปตท.สผ.อ.13153/00-7247/2556

25 มิถุนายน 2556

เรื่อง ขอแก้ไขข้อกำหนดการใช้ประโยชน์ที่ดินประเภทที่สี่เพื่อการรักษาคุณภาพสิ่งแวดล้อม(สี่ฟ้า)
บริเวณหมายเลข 7.2

เรียน โยธาธิการและผังเมือง จังหวัดสงขลา

สำนักงานโยธาธิการและผังเมือง

สิ่งที่ส่งมาด้วย หนังสือสำนักงานโยธาธิการและผังเมืองเลขที่ สข 0020/024 ลงวันที่ 5 มกราคม 2551

ตามที่ บริษัท ปตท.สผ.อินเตอร์เนชั่นแนล จำกัด ได้ขอแก้ไขข้อกำหนดกฎกระทรวงผังเมืองรวมชุมชนท่าเรือน้ำลึกสงขลา และคณะกรรมการผังเมืองได้มีมติเห็นชอบเมื่อการประชุมครั้งที่ 11/2550 วันที่ 15 พฤศจิกายน 2550 ให้นำเรื่องการขอแก้ไขข้อกำหนดการใช้ประโยชน์ที่ดินประเภทที่สี่เพื่อการรักษาคุณภาพสิ่งแวดล้อม(สี่ฟ้า) บริเวณหมายเลข 7.2 ของกฎกระทรวงผังเมืองรวมชุมชนท่าเรือน้ำลึกสงขลา จังหวัดสงขลา พ.ศ. 2548 ไปแก้ไขในการปรับปรุงผังเมืองรวมดังกล่าวในครั้งต่อไป ตามรายละเอียดในสิ่งที่ส่งมาด้วยนั้น บริษัทฯ ได้รับทราบขอทราบความคืบหน้าในการพิจารณาเรื่องการขอแก้ไขข้อกำหนดที่บริษัทร้องขอไปดังกล่าว และขอทราบขั้นตอนการดำเนินงานในลำดับต่อไป

จึงเรียนมาเพื่อโปรดพิจารณา และขอขอบพระคุณสำนักงานโยธาธิการและผังเมือง จังหวัดสงขลา ณ โอกาสนี้

ขอแสดงความนับถือ

(นางงามเกียรติ วงศ์พิฑารวณ)

ผู้จัดการฐานสนับสนุนการพัฒนาปิโตรเลียม (สงขลา)

ฐานสนับสนุนการพัฒนาปิโตรเลียม ปตท.สผ.(สงขลา)

โทรศัพท์ 0-7433-8888

โทรสาร 0-7433-8890-1

ที่ สข 0020/ 024

สำนักงานโยธาธิการและผังเมืองจังหวัดสงขลา
ถนอมราษฎร์บำรุง สข 90000

5 มกราคม 2551

เรื่อง ขอส่งรายงานการประชุมคณะกรรมการผังเมือง ครั้งที่ 11/2550

เรียน ผู้จัดการฐานสนับสนุนการพัฒนาปิโตรเลียม

สิ่งที่ส่งมาด้วย รายงานการประชุม

สำนักงานโยธาธิการและผังเมืองจังหวัดสงขลา ขอส่งรายงานการประชุม เรื่อง
ขอแก้ไขข้อกำหนดกฎกระทรวงผังเมืองรวมชุมชนท่าเรือน้ำลึกสงขลา มาพร้อมนี้

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายณัฏฐ์ วงศ์พิฑารวณ)
วิศวกรโยธาชำนาญพิเศษ
โยธาธิการและผังเมืองจังหวัดสงขลา

กลุ่มงานวิชาการผังเมือง

โทร/โทรสาร. (074) 322057,327247

รับ ๖ ส.ค. 2551
รับ ๖ ส.ค. 2551
๖ ก.ค. ๖๖

ฉบับปรับปรุงแล้ว
รายงานการประเมินผลโครงการ
ครั้งที่ 11 / 2550
วันที่ 25 พฤศจิกายน 2550
เวลา 13.30 น.

ณ ห้องประชุม 1201 ชั้น 2 อาคาร 1 กรมโยธาธิการและผังเมือง ถนนพระราม 9

รายงานผลการประเมินผลโครงการ

1. นายวิวัฒน์ งามวิจิตร	รองปลัดกระทรวงมหาดไทย	ประธาน
2. นายสมคิด ธรรมสาร	ผู้ตรวจราชการกระทรวงมหาดไทย	กรรมการ
3. นายศักดิ์ ธรรมสาร	ผู้อำนวยการกองการช่าง	กรรมการ
4. นายวิบูลย์ งามวิจิตร	รองปลัดกระทรวงมหาดไทย	กรรมการ
5. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
6. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
7. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
8. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
9. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
10. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
11. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
12. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
13. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
14. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
15. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ
16. นายวิบูลย์ งามวิจิตร	ผู้อำนวยการกองการช่าง	กรรมการ

ฯ-รายงาน.....

-2-

รายงานผลการประเมินผลโครงการ

1. นายวิวัฒน์ งามวิจิตร
2. นายสมคิด ธรรมสาร
3. นายศักดิ์ ธรรมสาร
4. นายวิบูลย์ งามวิจิตร
5. นายวิบูลย์ งามวิจิตร

คณะกรรมการ
คณะกรรมการ
คณะกรรมการ
คณะกรรมการ
คณะกรรมการ

รายงานผลการประเมินผลโครงการ

1. นายวิวัฒน์ งามวิจิตร
2. นายสมคิด ธรรมสาร
3. นายศักดิ์ ธรรมสาร
4. นายวิบูลย์ งามวิจิตร
5. นายวิบูลย์ งามวิจิตร

กรมโยธาธิการและผังเมือง

1. นายวิวัฒน์ งามวิจิตร
2. นายสมคิด ธรรมสาร
3. นายศักดิ์ ธรรมสาร
4. นายวิบูลย์ งามวิจิตร
5. นายวิบูลย์ งามวิจิตร
6. นายวิบูลย์ งามวิจิตร
7. นายวิบูลย์ งามวิจิตร
8. นายวิบูลย์ งามวิจิตร
9. นายวิบูลย์ งามวิจิตร

ฯ-10.นาย.....

1. นายอุบลศักดิ์ วัชรปกร โสภณบริหารและผังเมืองจังหวัดสระบุรี
2. นางสาวกัญญา ทรัพย์พิทย เข้าหน้าพิทักษ์และผังเมือง 82
3. นายทศพร นภาพงษ์ สำนักบริหารและผังเมืองจังหวัดสระบุรี
4. นายวุฒิพงษ์ เก่งอุดมศรีวิทย์ ศึกษาโธสา 87ว
5. นายไธยม ชำนาญเขต แผนกโยธาธิการและผังเมืองจังหวัดสงขลา
6. นายพิชญ์ 72
7. สำนักบริหารและผังเมืองจังหวัดสงขลา
8. เข้ามหน้าพิทักษ์และผังเมือง 72
9. แผนกโยธาธิการและผังเมืองจังหวัดนครปฐม

๑-ก่อนเริ่มประชุม.....

รายงานว่า

1. ตั้งเมืองรวมขุนหาญท่าเรือท่าลี้กึ่งตงจลา จังหวัดสงขลา ประกาศใช้บังคับครั้งแรกตามกฎกระทรวง ฉบับที่ 34 (พ.ศ. 2530) และให้ดำเนินการปรับปรุงผัง ที่ตั้งที่ 1 โดยพระอภัยมณีและคณะพระนาง ฉบับที่ 255 (พ.ศ. 2539) และให้พิจารณาขอพระมหากษัตริย์ใช้บังคับต่อไปอีก 1 ปี 2 ครั้ง หากตลอดการใช้บังคับในวันที 25 เมษายน 2546
2. กระทรวงตั้งงานได้มีหนังสือ ส่วน ที่ พท 0202/699 ลงวันที่ 26 กุมภาพันธ์ 2546 ข. การสนับสนุนให้วิสาหกิจ ปตท.ชน.อินทรีเข้าร่วมผล จัดทำ แผนรวมดำเนินการและประกอบกิจการที่เพื่อเชื่อมโยงพื้นที่ที่ด้านทิวเขา ด้านตงจลา จังหวัดสงขลา เพื่อเป็นประโยชน์ต่อจังหวัดและประเทศโดยรวม
3. คณะที่ปรึกษามติของรวมขุนหาญท่าเรือท่าลี้กึ่งตงจลา จังหวัดสงขลา และคณะกรรมการพิจารณาพื้นที่เมืองรวมขุนหาญ ให้พิจารณาเรื่องดังกล่าวเมื่อวันที่ 13 มีนาคม 2546 และ 8 เมษายน 2546 ตามลำดับ มีมติเห็นชอบไปให้เปลี่ยนแปลงชื่อจากพื้นที่ในกฎกระทรวงฉบับที่ 255 (พ.ศ.2539) ให้ว่ากฎกระทรวงผังเมืองรวมขุนหาญท่าเรือท่าลี้กึ่งตงจลา (ปรับปรุงครั้งที่ 2)
4. จังหวัดสงขลา มีหนังสือที่ สข 0023/9206 ลงวันที่ 27 พฤษภาคม 2546 แจ้งขอแก้ไขชื่อตามร่างกฎกระทรวงผังเมืองรวมขุนหาญท่าเรือท่าลี้กึ่งตงจลา จังหวัดสงขลา (ปรับปรุงครั้งที่ 2) โดยขอปรับปรุงชื่อพื้นที่ตามของที่ขึ้นประเภทที่โล่งเพื่อการรักษาคุณภาพสิ่งแวดล้อม (สีเขียว) ขว้างขามเขต 7.2 ให้ใช้ประโยชน์ที่ดินเพื่อการรักษาคุณภาพสิ่งแวดล้อม การก่อสร้าง หรือที่เกี่ยวข้องกับการท่องเที่ยว การเกษตรอื่นว่า โดยระบบของที่ดิน หรือสามารถประโยชน์แก่พื้นที่ และขอทราบการส่งทางขึ้นและพาณิชยกรรม มีภาพที่ถือที่ กท 0321/002157 ลงวันที่ 30 พฤษภาคม 2546 ขอให้กรมโยธาธิการและผังเมืองเห็นชอบการไประบุประโยชน์ที่ดินในเขตพื้นที่สีเขียว ซึ่งให้ใช้ประโยชน์เพื่อการรักษาคุณภาพสิ่งแวดล้อมให้เป็นพื้นที่ประเภทอุตสาหกรรมและที่ดินทั่วไป
5. คณะกรรมการผังเมืองเพื่อพิจารณาพื้นที่เมือง ให้รวบรวมพิจารณาเรื่องดังกล่าว เมื่อวันที่ 8 กรกฎาคม 2546 ที่ประชุมมีมติเห็นว่า กรณีดังกล่าวนี้ให้ทำเรื่องขึ้นจะต้องพิจารณาตามกฎ 24 และไม่สามารถพิจารณาได้ตามมาตรา 26 ระวชนา แบ่ง พ.ร.บ.การผังเมือง พ.ศ. 2518 จึงเห็นควรให้กรมโยธาธิการและผังเมืองแจ้งองค์การบริหารส่วนตำบลขุนหาญให้ผู้เกี่ยวข้องทราบต่อไป
6. กรมโยธาธิการและผังเมืองได้มีหนังสือแจ้งจังหวัดสงขลา ที่ นท 07126/6410 ลงวันที่ 8 กันยายน 2546 แจ้งทราบการดำเนินการว่า เมื่อพิจารณาโยธาธิการและผังเมืองได้ดำเนินการวางแผนและจัดทำผังเมืองรวมขุนหาญท่าเรือท่าลี้กึ่งตงจลา จังหวัดสงขลา (ปรับปรุงครั้งที่ 2) ตามที่เห็นชอบแล้วจึงมีมติเห็นชอบร่างกฎหมายเพื่อ
- /-ประกาศแทน...

ประกาศเป็นกฎกระทรวงไว้บังคับ หากกรณีเห็นสมควรตั้งข้อหาใดๆ ในขณะนั้น จะทำให้เกิดภาระของการดำเนินการแก่ข้อหาที่มีความผิดเบา เนื่องจากจะเสียของเรื่องกว่าดำเนินการไปพอให้เกิดความเสียหายในการประกาศใช้บังคับถึงเมื่อรวม จึงเห็นควรให้ส่งเมื่อรวมของทุกข้อหาเพื่อไม่เกิดขงขาด จึงทรงลงนาม (ปรับปรุงครั้งที่ ๒) ทำให้มีการลงนามเห็นชอบตรากฎกระทรวงไว้ และเมื่อประกาศใช้บังคับเป็นกฎกระทรวงแล้วจึงดำเนินการตราแก้ไขปรับปรุงเพิ่มเติมไว้บังคับแก่ข้อหาต่อไป

[illegible]

๓. บริษัท ปตท. จำกัด (มหาชน) ขอเปลี่ยนแปลงชื่อกิจการการได้ระ โยชน์
 ที่ผลประโยชน์ บริษัทขอจดทะเบียน ๗.๒ ให้ได้ประโยชน์ได้เต็มที่กับทุกภาคส่วนที่เกี่ยวข้อง การท่องเที่ยวหรือสิ่งแวดล้อม
 ที่มีการท่องเที่ยว การพัฒนาชุมชน หรือการสาธารณสุขได้ประโยชน์ร่วมกัน

9. คณะที่ปรึกษาฯ มีมติเห็นชอบให้บรรจุบทพิจารณาเรื่องดังกล่าวเมื่อ วันที่ 8 สิงหาคม 2549 ที่ประชุมมีมติเห็นชอบให้เปิดตลาดแปลงข้อกำหนดในกฎกระทรวงฯ ตามที่บริษัท วิธัช

10. คณะกรรมการพิจารณาพัฒนาเมืองของกรมฯ ได้ประชุมพิจารณาเรื่องดังกล่าว เมื่อวันที่ 16
พฤษภาคม 2550 ที่ประชุมได้มีมติลงนามแนะนำ การดำเนินการสร้างท่าเรือบริเวณของ บริษัท ปตท.สส.อเนกประสงค์
ส่วนหนึ่งตาม จ.พัทลุง มีคณะกรรมการจัดตั้งกิจกรมตามท่าเรือนี้เกิดขึ้นจาก จังหวัดสงขลา เนื่องจากบริเวณที่ตั้งท่า
เรือบริเวณนี้ไม่ใช่บริเวณที่ถูกจัดเป็นที่ดิน และบริเวณ ปตท.สส.อเนกประสงค์ส่วนหนึ่งตาม จ.พัทลุง ต้องการให้ดินในพื้นเมือง
รวมให้เป็นที่ปลายสุดทางปัจจุบัน หรือพื้นที่ใหม่ใช้จัดทำท่าเรือบริเวณที่ตั้งแล้ว จึงเห็นสมควรให้ทำเรื่องขออนุญาต
ดำเนินการตามกรมฯ ให้ทำไปให้เป็นที่ดำเนินการปรับปรุงท่าเรือดังกล่าว

11. คณะอนุกรรมการผังเมืองเพื่อพิจารณาด้านผังเมือง ได้ประชุมพิจารณาเรื่องดังกล่าว
จำนวน 3 ครั้ง

- ครั้งที่ 1 เมื่อวันที่ 28 กุมภาพันธ์ 2550 ที่ประชุมมูลนิธิฯ ได้พิจารณาโครงการและ
ผังเมืองจังหวัดสงขลาจากข้อมูลการขออนุญาตการก่อสร้างท่าเทียบเรือว่าได้รับการอนุญาตหรือไม่ มีขั้นตอนการ
พิจารณาอนุญาตจากใดบ้าง และให้กองจัดการวางผังเมืองการขออนุญาตก่อสร้างท่าเทียบเรือว่าดำเนินการตาม
ขนาดตามหรือไม่ แล้วนำแบบขอเสนอการวางผังเมือง อื่นครั้งต่อไป

-ครั้งที่ 2 เมื่อวันที่ 21 มีนาคม 2550 ที่ประชุมมีมติให้ฝ่ายเลขานุการฯ ตรวจสอบ
ข้อมูลเบื้องต้น

(1) จากข้อมูล กรมเจ้าท่าออกใบอนุญาตให้ปล่อยช้างลงอ่างล้างน้ำ ๗ วันที่ 13 มกราคม 2544 ถึงวันที่ 12 มกราคม 2545 แต่การออกใบอนุญาตให้ปล่อยช้างทำที่สวนเรื่อของพนักงานท้องถิ่น

1-(ເກສບາດນຶ່ງ...)

(เทศบาลเมืองสิงหนคร) ออกให้ ณ วันที่ 7 พฤษภาคม 2546 ซึ่งเป็นวันที่ทั้งเมืองรวมขบวนพาเหรบ์ไปฉลองสงกรานต์
หาดทรายขาวถึงกับน้ำท่วมถึงบริเวณที่ 25 ถนนสาย 2546 เพิ่งมีรถบัสวิ่งหลังจากใบอนุญาตก่อสร้างอาคารออกให้ ก็
ถือว่าเป็นการก่อสร้างถึงขนาดตั้งเขตอาชญาไปเสีย

(2) กลไกการพิจารณาเรื่องดังกล่าวข้างต้น จะต้องหลีกเลี่ยงมิให้เกิดกระบวนการทราดซึ่งส่วนนี้สำคัญยิ่งว่ กรมการขนส่งทางบกและพาณิชย์นาวี (กรมเจ้าท่าเดิม) จะพิจารณาอนุญาต ต้องมีการเสนอให้ คณะกรรมการฯ ชุดดังกล่าวตรวจสอบก่อน ดังนัน้ความมีผลของคณะกรรมการชุดนี้ด้วย

(3) ให้ฝ่ายเอกสารจังหวัดพิจิตรแก้ไขเอกสารการพิจารณาอนุญาตให้ก่อสร้างกำแพงคอนกรีตของวิทยาลัยการอาชีพพิจิตรตามแบบที่แนบมา และให้ฝ่ายเอกสารจังหวัดพิจิตรแจ้งให้หน่วยงานที่เกี่ยวข้องได้รับทราบการพิจารณาแล้ว ให้ฝ่ายเอกสารจังหวัดพิจิตรแจ้งให้หน่วยงานที่เกี่ยวข้องได้รับทราบการพิจารณาแล้ว

12. ครั้งที่ 3 เมื่อวันที่ 29 พฤษภาคม 2550 ที่ประชุมคณะกรรมการทั้งเจ็ดองค์ ที่มีที่ประชุม
กรมศิลปากรและกรมการศึกษาด้านวัฒนธรรมของกรมฯ เมื่อวันที่ 16 มกราคม 2550 ได้พิจารณาและแก้ไขข้อถกเถียง
โดยที่ทางสำนักพิมพ์ ไททานีกรมและทั้งองค์การบริหารสงฆ์จากเรื่องดังกล่าวเป็นข้อถกเถียงเกี่ยวกับความจำเป็นที่จะต้อง
บูรณาการเรื่องศักดิ์สิทธิ์จาก จักรวรรดิสงฆ์จากทั้ง ๒

จึงแยกคณะกรรมการฯ เพื่อไปรุดพิจารณา

เป็นหน้าที่สำนักงานโสตศึกษาและศูนย์เพื่อส่งเสริมสังคม (นสวต) แห่งนี้ ที่ต้องทำร่วมกับ กักตักใจอง 72) จึงจะประกอบกรการขยาย Power Point ทั้งเป็นวงร่วมนำมาเสริมที่อีกสงขลา จัดทำสงขลา และบริเวณทางเหนือที่อีกสงขลาที่มีอยู่เดิม และบริเวณที่ก่อสร้างใหม่ โดยสรุปข้อมูลในการดำเนินการ ดังนี้

[illegible]

1-កងកេរ្តិ៍ឈ្មោះ...

2. ในคราวประชุมดังกล่าวที่หอประชุมของมหาวิทยาลัยสุโขทัยธรรมาธิราช กรุงเทพมหานคร ได้มีมติว่า คณะกรรมการฯ จะพิจารณาให้เป็นไปตามมติของคณะกรรมการฯ ที่ประชุมเมื่อวันที่ ๑๖ กรกฎาคม ๒๕๖๑ เรื่อง "สิทธิมนุษยชน" หากสามารถลงมติได้ก็ให้ดำเนินการต่อไป

3. คณะกรรมการตั้งเมืองจึงพิจารณาแล้ว เห็นชอบให้ทำกรณีนี้ บริษัท ปตท. สม. อินสเตอร์แอนด์เนต จำกัด ขอแก้ไขข้อกำหนดการให้บริการโดยให้เพิ่มประเภทที่ ส่งเพื่อบริการลูกค้าตามหลังละติจูด (สี่ปี) บริเวณมาตราข 7.2 ของกฎกระทรวงส่งมอบมอบหมายเพื่อให้บริการจาก จังหวัดจันทรา พ.ศ. 2548 ให้แก้ไขในกฎวิธีปฏิบัติตั้งเมืองรวมทั้งตัวบทข้อ 6) ตามมติคณะกรรมการตั้งเมืองเพื่อพิจารณาด้วยตั้งเมือง และกรมโยธาธิการและผังเมืองเสนอ และให้พร้อมชี้แจงเหตุผลและเงื่อนไขของคณะกรรมการตั้งเมืองไปพิจารณาตามขั้นตอนต่อไป

143 ထို...

ภาคผนวก ข-17

บันทึกปริมาณยานพาหนะเข้า-ออกพื้นที่โครงการ

IN-OUT Your company									
IN ตั้งแต่ 01/01/2024@00:00 ถึง 31/01/2024@23:59									
ลำดับ #	รายละเอียด Details		ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
1	031	MM 71-2531สข	JT	รถเช่าเลอร์	๙. 01/01/2024 07:21	๙. 01/01/2024 07:46	0.24	6-1	
2	040	GT 71-7857สข	JT	รถเช่าเลอร์	๙. 01/01/2024 07:22	๙. 01/01/2024 08:25	1.03	6-1	
3	045	GT 71-8962สข	JETTY	รถเช่าเลอร์	๙. 01/01/2024 07:24	๙. 01/01/2024 08:37	1.13	6-1	
4	555	GT 71-8392สข	JETTY	รถกระบะ รถหกล้อ	๙. 01/01/2024 07:27	๙. 01/01/2024 08:09	0.41	6-1	
5	046	AAL 77-3737กทม	JETTY	รถเช่าเลอร์	๙. 01/01/2024 07:32	๙. 01/01/2024 09:17	1.45	6-1	
6	023	GT 71-7398สข	JETTY	รถเช่าเลอร์	๙. 01/01/2024 07:34	๙. 01/01/2024 08:45	1.11	6-1	
7	888	GT 71-7904สข	JETTY	รถเช่าเลอร์	๙. 01/01/2024 07:52	๙. 01/01/2024 08:53	1.01	6-1	
8	039	MML 63-1798กทม	JETTY	รถเช่าเลอร์	๙. 01/01/2024 08:04	๙. 01/01/2024 08:25	0.21	6-1	
9	C00	BP 82-4614สข	CHEVRON	รถกระบะ รถหกล้อ	๙. 01/01/2024 08:06	๙. 01/01/2024 09:40	1.35	6-1	
10	C44	STT 71-6877สข	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:07	๙. 01/01/2024 09:17	1.10	6-1	
11	C77	AAL 77-3740กทม	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:09		0.00	6-7	
12	038	GT 71-8704สข	JETTY	รถกระบะ รถหกล้อ	๙. 01/01/2024 08:16	๙. 01/01/2024 08:37	0.21	6-1	
13	C11	AAL 62-9248กทม	CHEVRON	รถสิบล้อ	๙. 01/01/2024 08:17	๙. 01/01/2024 09:17	0.60	6-1	
14	022	AAL 79-6735กทม	JETTY	รถเช่าเลอร์	๙. 01/01/2024 08:20	๙. 01/01/2024 12:17	3.58	6-1	
15	C66	AAL 76-8997กทม	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:21		0.00	6-7	
16	C69	AAL 77-0554กทม	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:23	๙. 01/01/2024 09:39	1.16	6-1	
17	048	SAP 71-8958สข	JETTY	รถเช่าเลอร์	๙. 01/01/2024 08:24	๙. 01/01/2024 15:04	6.40	6-6	
18	C99	GT 71-6346สข	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:25	๙. 01/01/2024 08:59	0.34	6-1	
19	C22	SK 81-4321สข	CHEVRON	รถสิบล้อ	๙. 01/01/2024 08:30	๙. 01/01/2024 08:45	0.15	6-1	
20	C58	AAL 1090344PP17Z1R012... 76-8810กทม	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:37	๙. 01/01/2024 09:40	1.03	6-1	
21	036	AAL 77-0553กทม	JETTY	รถเช่าเลอร์	๙. 01/01/2024 08:39	๙. 01/01/2024 08:53	0.14	6-1	
22	044	AAL 79-6733กทม	JETTY	รถเช่าเลอร์	๙. 01/01/2024 08:41	๙. 01/01/2024 09:17	0.36	6-1	
23	C55	MM 71-7654สข	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:41	๙. 01/01/2024 09:16	0.35	6-1	
24	C85	AAL สุวรรณ สีดำ 39001... 77-3738กทม	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:42	๙. 01/01/2024 10:43	2.01	6-1	
25	C90	AAL 76-8809กทม	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 08:53	๙. 01/01/2024 09:39	0.46	6-1	
26	C88	GT 71-8392สข	CHEVRON	รถกระบะ รถหกล้อ	๙. 01/01/2024 08:53	๙. 01/01/2024 09:40	0.47	6-1	
27	034	WMS 72-8833ชบ	JETTY	รถเช่าเลอร์	๙. 01/01/2024 08:59	๙. 01/01/2024 09:40	0.41	6-1	
๒๘	C๐๐	AAL 7๗ ๐75๕๖กทม	CHEVRON	รถเช่าเลอร์	๙. 01/01/2024 0๙:๐๐	๙. 01/01/2024 10:๔2	๑.42	๕-๑	

IN-OUT Your company									
IN ตั้งแต่ 01/01/2024@00:00 ถึง 31/01/2024@23:59									
ลำดับ #	รายละเอียด Details		ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
898	333	MML 71-2531สข	JETTY	รถกระบะ รถหกล้อ	๙. 06/01/2024 10:35	๙. 06/01/2024 12:45	2.11	6-1	
899	000	SAP T0BR7917111A3B063... 71-8859สข	JETTY	รถเช่าเลอร์	๙. 06/01/2024 10:36	๙. 06/01/2024 11:59	1.24	6-1	
900	777	AAL 64-2295กทม	JETTY	รถเช่าเลอร์	๙. 06/01/2024 10:40	๙. 06/01/2024 11:59	1.19	6-1	
901	444	GT 71-7398สข	JETTY	รถเช่าเลอร์	๙. 06/01/2024 10:45	๙. 06/01/2024 12:00	1.15	6-1	
902	C47	GT 71-8704สข	JETTY	รถกระบะ รถหกล้อ	๙. 06/01/2024 10:48	๙. 06/01/2024 11:31	0.43	6-1	
903	632	SK 81-4321สข	JETTY	รถสิบล้อ	๙. 06/01/2024 10:49	๙. 06/01/2024 11:30	0.41	6-1	
904	521	TXP 71-7598สข	JETTY	รถน้ำมัน รถป่วน	๙. 06/01/2024 10:50	๙. 06/01/2024 12:00	1.11	6-1	
905	C31	MM 71-5065สข	CHEVRON	รถเช่าเลอร์	๙. 06/01/2024 10:52	๙. 06/01/2024 11:31	0.39	6-1	
906	C36	AAL 77-4787กทม	CHEVRON	รถเช่าเลอร์	๙. 06/01/2024 10:58	๙. 06/01/2024 11:30	0.33	6-1	
907	C41	GT 71-6346สข	CHEVRON	รถเช่าเลอร์	๙. 06/01/2024 11:01	๙. 06/01/2024 11:30	0.29	6-1	
908	635	TNP พล76147สข	JETTY	รถกระบะ รถหกล้อ	๙. 06/01/2024 11:02	๙. 06/01/2024 11:31	0.29	6-1	
909	999	GT 71-8704สข	JETTY	รถกระบะ รถหกล้อ	๙. 06/01/2024 11:05	๙. 06/01/2024 12:00	0.55	6-1	
910	58	GT 71-8802สข	JETTY	รถเช่าเลอร์	๙. 06/01/2024 11:09	๙. 06/01/2024 12:46	1.37	6-1	
911	56	AAL ปิยะพงศ์ หวังบุรี... 72-8796กทม	JETTY	รถเช่าเลอร์	๙. 06/01/2024 11:26	๙. 06/01/2024 12:00	0.34	6-1	
912	59	GT 71-7317สข	JETTY	รถเช่าเลอร์	๙. 06/01/2024 11:30	๙. 06/01/2024 12:00	0.30	6-1	
913	C57	AAL 77-1976กทม	CHEVRON	รถเช่าเลอร์	๙. 06/01/2024 11:32	๙. 06/01/2024 14:02	2.30	6-1	
914	025	KSN พน4547สข	JETTY	รถกระบะ รถหกล้อ	๙. 06/01/2024 11:37	๙. 06/01/2024 12:46	1.08	6-1	
915	022	STP 71-3917สข	JETTY	รถน้ำมัน รถป่วน	๙. 06/01/2024 11:39	๙. 06/01/2024 13:35	1.56	6-1	
916	050	TNP บข-6600สข	JETTY	รถกระบะ รถหกล้อ	๙. 06/01/2024 12:29	๙. 06/01/2024 13:33	1.05	6-1	
917	023	GTE 79-3983กทม	JETTY	รถน้ำมัน รถป่วน	๙. 06/01/2024 12:37	๙. 06/01/2024 14:02	1.25	6-1	
918	044	TXP 71-7598สข	JETTY	รถน้ำมัน รถป่วน	๙. 06/01/2024 12:38	๙. 06/01/2024 14:49	2.10	6-1	
919	040	BJ 70-1628พล	JETTY	รถน้ำมัน รถป่วน	๙. 06/01/2024 12:40	๙. 06/01/2024 16:06	3.27	6-1	
920	C11	GT 71-8704สข	CHEVRON	รถกระบะ รถหกล้อ	๙. 06/01/2024 12:45	๙. 06/01/2024 13:34	0.50	6-1	
921	012	GTE 79-3985กทม	JETTY	รถน้ำมัน รถป่วน	๙. 06/01/2024 12:46	๙. 06/01/2024 14:02	1.16	6-1	
922	032	GT 71-5727สข	JETTY	รถเช่าเลอร์	๙. 06/01/2024 12:48	๙. 06/01/2024 13:35	0.47	6-1	
923	C58	GT เต็ม ศรีทอง 39609... 71-8392สข	CHEVRON	รถเช่าเลอร์	๙. 06/01/2024 12:56	๙. 06/01/2024 14:02	1.07	6-1	
924	030	STP จำเนียร ฤกษ์มงคล 3... 71-5047สข	JETTY	รถน้ำมัน รถป่วน	๙. 06/01/2024 12:56	๙. 06/01/2024 14:48	1.52	6-1	

IN-OUT Your company

IN ตั้งแต่ 01/01/2024@00:00 ถึง 31/01/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ให้เข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate
4205	034 ST 71-4414สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:07	จ. 29/01/2024 16:47	1.40	6-1
4206	028 GT 71-7902สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:08	จ. 29/01/2024 16:16	1.09	6-1
4207	021 BES Somboon Kruathong... 2บด7001กทท 0897021026	EMI	รถกระบะ รถหกล้อ	จ. 29/01/2024 15:09	จ. 29/01/2024 15:39	0.31	6-1
4208	001 AAL สมปอง สุขะปานะ 39... 77-1976กทท	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:09	จ. 29/01/2024 15:39	0.30	6-1
4209	030 MM 72-0871สข	JETTY	รถสิบล้อ	จ. 29/01/2024 15:15	จ. 29/01/2024 16:17	1.02	6-1
4210	009 AAL 77-1977กทท	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:18	จ. 29/01/2024 15:39	0.21	6-1
4211	022 OPF พพ-6859สข	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 15:38	จ. 29/01/2024 16:47	1.09	6-1
4212	556 STP 71-3917สข	JETTY	รถน้ำมัน รถป่วน	จ. 29/01/2024 15:44	จ. 29/01/2024 16:53	1.08	6-1
4213	555 GT 71-6346สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:47	จ. 29/01/2024 16:16	0.29	6-1
4214	777 AAL 78-0974กทท	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:47	จ. 29/01/2024 16:16	0.29	6-1
4215	788 GT 71-5727สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:48	จ. 29/01/2024 16:16	0.28	6-1
4216	693 MM 70-6222สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:49	จ. 29/01/2024 16:15	0.26	6-1
4217	333 AAL 77-4786กทท	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:50	จ. 29/01/2024 16:15	0.25	6-1
4218	000 GT 71-7904สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 15:58	จ. 29/01/2024 16:23	0.25	6-1
4219	999 GT 72-1452สข	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:06	จ. 29/01/2024 16:23	0.17	6-1
4220	222 SAP 72-1086สข	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:07	จ. 29/01/2024 16:23	0.16	6-1
4221	009 OGEO ชก-59นศ	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:10	จ. 29/01/2024 16:48	0.39	6-1
4222	111 WTW 72-2606สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 16:13	จ. 29/01/2024 16:49	0.36	6-1
4223	587 MML 71-3101สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 16:14	จ. 29/01/2024 16:49	0.35	6-1
4224	424 SAP 71-8839สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 16:15	จ. 29/01/2024 21:30	5.15	6-1
4225	030 BES Suppanut Chakoch... ชด-6953กทท	OTF	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:20	จ. 29/01/2024 16:48	0.28	6-1
4226	045 GT 71-8392สข	JETTY	รถเช่าเลอร์	จ. 29/01/2024 16:22	จ. 29/01/2024 16:47	0.25	6-1
4227	042 MML 71-4432สข	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:23	จ. 29/01/2024 16:48	0.25	6-1
4228	006 OTF 82-4246สข	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:24	จ. 29/01/2024 19:36	3.13	6-1
4229	031 งด-8139กทท	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:25	จ. 29/01/2024 16:48	0.22	6-1
4230	021 OWU พล-7514สข	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:38	จ. 29/01/2024 19:36	2.58	6-1
4231	001 OTF 2บด-4063กทท	JETTY	รถกระบะ รถหกล้อ	จ. 29/01/2024 16:41	จ. 29/01/2024 19:20	2.40	6-1

IN-OUT Your company


IN ตั้งแต่ 01/01/2024@00:00 ถึง 31/01/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ให้เข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate
4515	4 AAL 77.4789กทท รถเช่า...	JETTY	รถเช่าเลอร์	ท. 31/01/2024 21:33	ท. 01/02/2024 00:51	3.18	6-1
4516	5 GTE มนชัย สันสาธา 390... ชง909ส.ข รถกระบะ	JETTY	รถกระบะ รถหกล้อ	ท. 31/01/2024 21:35	ท. 31/01/2024 23:27	1.52	6-1
4517	6 MM ประจักษ์ ประสานสง... 63.1794กทท รถเช่า...	JETTY	รถเช่าเลอร์	ท. 31/01/2024 21:36	ท. 31/01/2024 23:53	2.17	6-1
4518	7 AAL .780231กทท รถเช่า...	JETTY	รถเช่าเลอร์	ท. 31/01/2024 21:37	ท. 01/02/2024 00:51	3.14	6-1
4519	8 AAL กอเต หัดหมัด 3900... 72.8756กทท รถเช่า...	JETTY	รถเช่าเลอร์	ท. 31/01/2024 21:39	ท. 01/02/2024 00:50	3.11	6-1
4520	9 NOP กฤษณิด นพสุวรรณ 3... กช1958ส.ข รถกระบะ	JETTY	รถกระบะ รถหกล้อ	ท. 31/01/2024 21:44	ท. 31/01/2024 23:27	1.43	6-1
4521	10 MML อนิรุทธิ์ อมลังษ์ ... 71.2532ส.ข รถเช่า...	JETTY	รถเช่าเลอร์	ท. 31/01/2024 21:46	ท. 31/01/2024 23:27	1.41	6-1
4522	11 AAL 774786กทท รถเช่าเลอร์	JETTY	รถเช่าเลอร์	ท. 31/01/2024 22:07	ท. 01/02/2024 03:00	4.53	6-1
4523	12 AAL สุพรรณิย์ อินสระโร 1... 79.6734กทท รถเช่า...	JETTY	รถเช่าเลอร์	ท. 31/01/2024 22:09	ท. 01/02/2024 02:59	4.50	6-1
4524	13 AAL สุวรรณ สีดำ 39001... 773738กทท รถเช่าเลอร์	JETTY	รถเช่าเลอร์	ท. 31/01/2024 22:34	ท. 31/01/2024 23:53	1.19	6-1

สรุป

Visitor ที่เข้ามา	4,524
กลับไปแล้ว	4,517
ยังไม่กลับ	7
อยู่สั้นสุด (h.mm)	0.00
อยู่นานสุด (h.mm)	18.00
เฉลี่ย (h.mm)	1.39

Visitor by type



IN-OUT Your company

IN ตั้งแต่ 01/02/2024@00:00 ถึง 28/02/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ปร G
710	036 ST อาฟัส หลีเห็ด 19... 71-4323สข	JETTY	รถน้ำมัน รถปูน	จ. 05/02/2024 20:48	จ. 05/02/2024 22:34	1.45	6-
711	023 นท7858สข	JETTY	รถกระบะ รถหนักล้อ	จ. 05/02/2024 21:30	จ. 05/02/2024 22:34	1.03	6-
712	032 DJ 72-0469สข	JETTY	รถแทรกเลอร์	จ. 05/02/2024 21:35	จ. 05/02/2024 22:33	0.58	6-
713	030 CONN ไร่ศักดิ์ การ์ดน... 71-6118สข	JETTY	รถแทรกเลอร์	จ. 05/02/2024 21:59	อ. 06/02/2024 04:52	6.54	6-
714	028 BJ 70-1581พล	JETTY	รถน้ำมัน รถปูน	อ. 06/02/2024 07:07	อ. 06/02/2024 09:15	2.07	6-
715	020 GT 71-7398สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:02	อ. 06/02/2024 08:57	0.56	6-
716	046 SK 82-7263สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:04	อ. 06/02/2024 08:58	0.54	6-
717	027 SK หวานลาด บินหลี่ 29... 70-7838สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:20	อ. 06/02/2024 08:58	0.38	6-
718	002 AAL 79-6502กทม	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:21	อ. 06/02/2024 08:58	0.37	6-
719	042 GT P0GN5395D18955052... 71-8962สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:27	อ. 06/02/2024 09:15	0.48	6-
720	022 TCS พรสวรรค์ เรือคำ ... 72-2970รย	JETTY	รถสิบล้อ	อ. 06/02/2024 08:28	อ. 06/02/2024 10:14	1.46	6-
721	084 OK 71-7969สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:32	อ. 06/02/2024 10:22	1.50	6-
722	006 PSW 71-5563สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:47	อ. 06/02/2024 09:55	1.08	6-
723	021 SC 1๗๗-7513กทม	JETTY	รถกระบะ รถหนักล้อ	อ. 06/02/2024 08:48	อ. 06/02/2024 09:55	1.07	6-
724	009 GT 72-1452สข	JETTY	รถสิบล้อ	อ. 06/02/2024 08:49	อ. 06/02/2024 09:15	0.26	6-
725	C44 AAL 76-8810กทม	CHEVRON	รถแทรกเลอร์	อ. 06/02/2024 08:49	อ. 06/02/2024 09:14	0.25	6-
726	000 GT 71-7857สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:51	อ. 06/02/2024 09:14	0.23	6-
727	555 SK 82-7249สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:56	อ. 06/02/2024 09:36	0.40	6-
728	038 SK 82-7263สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 08:57	อ. 06/02/2024 09:14	0.17	6-
729	222 AAL 79-6735กทม	JETTY	รถแทรกเลอร์	อ. 06/02/2024 09:01	อ. 06/02/2024 09:35	0.34	6-
730	040 BJ 70-3106พล	JETTY	รถน้ำมัน รถปูน	อ. 06/02/2024 09:03	อ. 06/02/2024 10:22	1.19	6-
731	666 AAL 77-3739กทม	JETTY	รถแทรกเลอร์	อ. 06/02/2024 09:04	อ. 06/02/2024 09:36	0.31	6-
732	031 MM 70-6222สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 09:06	อ. 06/02/2024 10:22	1.16	6-
733	039 GT นรินทร์ อินทสระ 59... 71-5727สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 09:08	อ. 06/02/2024 09:35	0.28	6-
734	029 GT 71-8802สข	JETTY	รถแทรกเลอร์	อ. 06/02/2024 09:08	อ. 06/02/2024 10:09	1.01	6-
735	020 AAL 67-7863กทม	JETTY	รถเครน นอก	อ. 06/02/2024 09:10	อ. 06/02/2024 22:32	13.22	6-
736	036 MPC 98-1460กทม	JETTY	รถแทรกเลอร์	อ. 06/02/2024 09:11	อ. 06/02/2024 09:35	0.24	6-

IN-OUT Your company

IN ตั้งแต่ 01/02/2024@00:00 ถึง 28/02/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ปร G
1453	034 AAL 79-6735กทม	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:20	ท. 09/02/2024 16:04	0.44	6-
1454	021 STP 71-3916สข	JETTY	รถน้ำมัน รถปูน	ท. 09/02/2024 15:21	ท. 09/02/2024 17:05	1.45	6-
1455	005 KIA 2๗๗-6032กทม	JETTY	รถกระบะ รถหนักล้อ	ท. 09/02/2024 15:21	ท. 09/02/2024 16:22	1.00	6-
1456	022 LE 72-7180สร	JETTY	รถน้ำมัน รถปูน	ท. 09/02/2024 15:25	ท. 09/02/2024 17:05	1.40	6-
1457	874 SAP 71-9239สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:28	ท. 09/02/2024 18:52	3.24	6-
1458	C77 AAL 62-9248กทม	CHEVRON	รถสิบล้อ	ท. 09/02/2024 15:29	ท. 09/02/2024 16:04	0.35	6-
1459	031 PSW 71-5563สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:29	ท. 09/02/2024 16:41	1.12	6-
1460	045 MML 71-3101สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:30	ท. 09/02/2024 16:03	0.33	6-
1461	042 GT 71-8965สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:32	ท. 09/02/2024 16:36	1.04	6-
1462	889 AAL 64-2295กทม	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:33	ท. 09/02/2024 18:53	3.20	6-
1463	020 GTE 79-3983กทม	JETTY	รถน้ำมัน รถปูน	ท. 09/02/2024 15:34	ท. 09/02/2024 20:47	5.14	6-
1464	009 DJ 72-0469สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:40	ท. 09/02/2024 16:04	0.24	6-
1465	222 GT 71-5727สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:40	ท. 09/02/2024 16:21	0.41	6-
1466	666 GT 71-6346สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:41	ท. 09/02/2024 16:21	0.40	6-
1467	287 AAL 63-9069กทม	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:43	ท. 09/02/2024 16:03	0.21	6-
1468	564 TXP 71-7600สข	JETTY	รถน้ำมัน รถปูน	ท. 09/02/2024 15:47	ท. 09/02/2024 16:36	0.49	6-
1469	89 AAL U0N5184P91694X073... 79-6730กทม	JETTY	รถแทรกเลอร์	ท. 09/02/2024 15:54	ท. 09/02/2024 18:55	3.01	6-
1470	333 GT 71-8392สข	JETTY	รถแทรกเลอร์	ท. 09/02/2024 16:03	ท. 09/02/2024 16:41	0.38	6-
1471	444 AAL 64-2296กทม	JETTY	รถแทรกเลอร์	ท. 09/02/2024 16:04	ท. 09/02/2024 20:49	4.45	6-
1472	551 ADISORN Nontawat Sukhakho... ๒๗๑-7059กทม	OMI	รถกระบะ รถหนักล้อ	ท. 09/02/2024 16:05	ท. 09/02/2024 16:21	0.16	6-
1473	000 MML 65-7421กทม	JETTY	รถแทรกเลอร์	ท. 09/02/2024 16:06	ท. 09/02/2024 16:30	0.23	6-
1474	06 SGMS ๓๖-4272กทม	JETTY	รถกระบะ รถหนักล้อ	ท. 09/02/2024 16:14	ท. 09/02/2024 16:42	0.27	6-
1475	C88 AAL 77-0554กทม	CHEVRON	รถแทรกเลอร์	ท. 09/02/2024 16:28	ท. 09/02/2024 16:49	0.21	6-
1476	029 KPS 68-3229กทม	JETTY	รถน้ำมัน รถปูน	ท. 09/02/2024 16:30	ท. 09/02/2024 18:55	2.25	6-

IN-OUT Your company

IN ตั้งแต่ 01/02/2024@00:00 ถึง 28/02/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm
2785	027 SW มพ-3996สข	JETTY	รถกระบะ รถหกล้อ	สา. 18/02/2024 09:56	สา. 18/02/2024 16:35	6.39
2786	123 SW 81-2691สข	JETTY	รถกระบะ รถหกล้อ	สา. 18/02/2024 09:56	สา. 18/02/2024 16:11	6.15
2787	369 มท-7858สข	JETTY	รถกระบะ รถหกล้อ	สา. 18/02/2024 09:57	สา. 18/02/2024 10:27	0.30
2788	111 AAL 69-6416กทม	JETZY	รถเทรลเลอร์	สา. 18/02/2024 10:02	สา. 18/02/2024 11:12	1.10
2789	742 MM 71-2532สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:04	สา. 18/02/2024 11:52	1.48
2790	555 SM มพ-2238สข	JETTY	รถกระบะ รถหกล้อ	สา. 18/02/2024 10:05	สา. 18/02/2024 11:11	1.07
2791	C51 SAP 71-8523สข	CHEVRON	รถเทรลเลอร์	สา. 18/02/2024 10:07	สา. 18/02/2024 10:33	0.26
2792	669 GT 71-7857สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:09	สา. 18/02/2024 10:33	0.24
2793	456 AAL 77-3740กทม	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:11	สา. 18/02/2024 10:33	0.22
2794	368 WMS 72-7373ขบ	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:14	สา. 18/02/2024 10:33	0.19
2795	C36 AAL 72-8762กทม	CHEVRON	รถเทรลเลอร์	สา. 18/02/2024 10:14	สา. 18/02/2024 10:33	0.19
2796	654 SCOMI ณรงค์ฤทธิ์ โพธิ์ท... 9กค-7603กทม	JETTY	รถกระบะ รถหกล้อ	สา. 18/02/2024 10:15	สา. 18/02/2024 10:33	0.18
2797	C72 GT 71-5727สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:17	สา. 18/02/2024 11:11	0.54
2798	C73 GT 71-7902สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:17	สา. 18/02/2024 11:12	0.54
2799	652 AAL 79-6731กทม	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:20	สา. 18/02/2024 11:12	0.52
2800	651 GT ไปรษณีย์ 1900... 71-8704สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:20	สา. 18/02/2024 13:23	3.03
2801	351 SAP 71-8533สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:24	สา. 18/02/2024 11:52	1.27
2802	856 ... มท-7858สข	JETTY	รถกระบะ รถหกล้อ	สา. 18/02/2024 10:26	สา. 18/02/2024 11:12	0.46
2803	C69 AAL 77-4786กทม	CHEVRON	รถเทรลเลอร์	สา. 18/02/2024 10:36	สา. 18/02/2024 11:11	0.36
2804	725 AAL 79-6733กทม	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:36	สา. 18/02/2024 11:11	0.35
2805	545 AAL 69-6422กทม	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:37	สา. 18/02/2024 11:11	0.34
2806	543 AAL 77-4788กทม	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:38	สา. 18/02/2024 11:11	0.32
2807	031 GT 71-8962สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:43	สา. 18/02/2024 13:24	2.41
2808	854 SAP 72-1087สข	JETTY	รถกระบะ รถหกล้อ	สา. 18/02/2024 10:44	สา. 18/02/2024 11:11	0.27
2809	523 STP 71-4323สข	JETTY	รถน้ำมัน รถป่วน	สา. 18/02/2024 10:46	สา. 18/02/2024 11:52	1.05
2810	364 GT 71-7904สข	JETTY	รถเทรลเลอร์	สา. 18/02/2024 10:49	สา. 18/02/2024 13:23	2.34
2811	535 STP 71-5047สข	JETTY	รถน้ำมัน รถป่วน	สา. 18/02/2024 10:57	สา. 18/02/2024 13:49	2.51

IN-OUT Your company


IN ตั้งแต่ 01/02/2024@00:00 ถึง 28/02/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ปร Gt
4611	045 AAL ถศ1897กทม	JTTEY	รถกระบะ รถหกล้อ	พ. 28/02/2024 17:03	พ. 28/02/2024 18:27	1.24	6-
4612	0029 MM อุดสะณี นิลราห์ม... 71.3101ส.ข รถเทร...	JETY	รถเทรลเลอร์	พ. 28/02/2024 17:55	พ. 28/02/2024 18:32	0.37	6-
4613	023 GT ไปรษณีย์ 1900... 71.8704ส.ข รถยนต์	JETY	รถกระบะ รถหกล้อ	พ. 28/02/2024 18:02	พ. 28/02/2024 18:27	0.25	6-
4614	050 PSW นพดล แก้วมุข 3900... 71.5563ส.ข รถเทร...	JETY	รถเทรลเลอร์	พ. 28/02/2024 18:03	พ. 28/02/2024 18:48	0.45	6-
4615	009 SAP คุณานนท์ ตามปานท... 71.9239ส.ค รถเทร...	JETY	รถเทรลเลอร์	พ. 28/02/2024 18:05	พ. 28/02/2024 21:00	2.55	6-
4616	012 KPS 683229กม รถบรรทุกป่วน		รถน้ำมัน รถป่วน	พ. 28/02/2024 18:12	พ. 28/02/2024 21:00	2.48	6-
4617	046 AAL 796731 รถเทรลเลอร์		รถเทรลเลอร์	พ. 28/02/2024 18:14	พ. 28/02/2024 21:01	2.48	6-
4618	034 9893 รถกระบะ		รถกระบะ รถหกล้อ	พ. 28/02/2024 18:15	พ. 28/02/2024 18:47	0.32	6-
4619	006 STP 715334 รถบรรทุกป่วน		รถน้ำมัน รถป่วน	พ. 28/02/2024 19:41	พ. 28/02/2024 21:39	1.58	6-
4620	005 909 รถกระบะ		รถกระบะ รถหกล้อ	พ. 28/02/2024 20:52	พ. 28/02/2024 21:46	0.54	6-

สรุป

Visitor ที่เข้ามา	4,620
กลับไปแล้ว	4,600
ยังไม่กลับ	20
อยู่สั้นสุด (h.mm)	0.00
อยู่ยาวนานสุด (h.mm)	30.51
เฉลี่ย (h.mm)	1.44

Visitor by type



รถกระบะ รถหกล้อ = 885
รถน้ำมัน รถป่วน = 643
รถสิบล้อ = 364
รถส่งอาหาร รถบรรทุก = 1
รถเข็น นอก = 14
รถเทรลเลอร์ = 2693
รถเข็น = 20

IN-OUT Your company

IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าพัก Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ปี G
1	96 AAL 77-0552กทม	JETTY	รถเช่า	จ. 01/04/2024 06:41	จ. 01/04/2024 09:33	2.52	6-
2	259 SAP 71-9239สข	JT	รถเช่า	จ. 01/04/2024 07:21	จ. 01/04/2024 08:00	0.39	6-
3	888 PSW 71-6120สข	JETTY	รถเช่า	จ. 01/04/2024 07:47	จ. 01/04/2024 08:40	0.53	6-
4	298 GT 71-8704สข	JETTY	รถกระบะ รถยก	จ. 01/04/2024 07:48	จ. 01/04/2024 09:20	1.31	6-
5	043 GT 71-7857สข	JT	รถเช่า	จ. 01/04/2024 08:01	จ. 01/04/2024 08:58	0.57	6-
6	021 GT 71-7858สข	JT	รถเช่า	จ. 01/04/2024 08:02	จ. 01/04/2024 09:45	1.43	6-
7	040 MM 70-6222สข	JT	รถเช่า	จ. 01/04/2024 08:09	จ. 01/04/2024 08:40	0.31	6-
8	034 PTTEP 2พด6994กทม	JT	รถกระบะ รถยก	จ. 01/04/2024 08:09	จ. 01/04/2024 08:39	0.30	6-
9	018 SIAMRAJ APICHAART THUENG... 4ขท2520กทม 086-7496155	Jetty CVX	รถกระบะ รถยก	จ. 01/04/2024 08:11	จ. 01/04/2024 08:40	0.29	6-
10	035 AAL 79-6735กทม	JT	รถกระบะ รถยก	จ. 01/04/2024 08:12	จ. 01/04/2024 10:39	2.27	6-
11	006 AAL 79-6502กทม	JT	รถเช่า	จ. 01/04/2024 08:14	จ. 01/04/2024 10:27	2.13	6-
12	039 AAL 77-0554กทม	JT	รถเช่า	จ. 01/04/2024 08:20	จ. 01/04/2024 08:40	0.20	6-
13	030 GT 71-6346สข	JT	รถเช่า	จ. 01/04/2024 08:25	จ. 01/04/2024 08:41	0.16	6-
14	028 SAP ส่วนจ นวลละมุด 39... 71-7614สข	JETTY	รถเช่า	จ. 01/04/2024 08:28	จ. 01/04/2024 09:21	0.53	6-
15	025 GT 71-7398สข	JETTY	รถเช่า	จ. 01/04/2024 08:30	จ. 01/04/2024 08:58	0.28	6-
16	005 AAL กอเต หัดนัด 3900... 72-8756กทม	JETTY	รถเช่า	จ. 01/04/2024 08:32	จ. 01/04/2024 10:11	1.39	6-
17	045 GT 71-8802สข	JT	รถเช่า	จ. 01/04/2024 08:37	จ. 01/04/2024 09:20	0.44	6-
18	038 PAE 91-5500กทม	JT	รถสิบล้อ	จ. 01/04/2024 08:42	จ. 01/04/2024 08:58	0.16	6-
19	046 AAL 68-0708กทม	AAL	รถกระบะ รถยก	จ. 01/04/2024 08:43	จ. 01/04/2024 09:21	0.38	6-
20	009 AAL 79-6733กทม	JT	รถเช่า	จ. 01/04/2024 08:45	จ. 01/04/2024 09:45	0.59	6-
21	048 SPA 71-9239สข	JT	รถเช่า	จ. 01/04/2024 08:56	จ. 01/04/2024 09:20	0.24	6-
22	027 WMS 51-3329กทม	JT	รถเช่า	จ. 01/04/2024 09:03	จ. 01/04/2024 09:33	0.31	6-
23	023 BES Somboon Kruathong... 2ขท7001กทม 0897021026	EMI	รถกระบะ รถยก	จ. 01/04/2024 09:06	จ. 01/04/2024 09:20	0.14	6-
24	35 WMS 72-7575ขม	JT	รถเช่า	จ. 01/04/2024 09:14	จ. 01/04/2024 09:33	0.20	6-
25	248 AAL 96-5154กทม	JT	รถเช่า	จ. 01/04/2024 09:19	จ. 01/04/2024 09:45	0.26	6-
26	121 CTK มล6147สข	JT	รถกระบะ รถยก	จ. 01/04/2024 09:20	จ. 01/04/2024 09:25	0.05	6-
27	276 TNA 77-6141กทม	JT	รถกระบะ รถยก	จ. 01/04/2024 09:27	จ. 01/04/2024 09:28	0.12	6-

IN-OUT Your company

IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าพัก Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ปี G
248	53 SK 81-0226สข	JETTY	รถสิบล้อ	จ. 02/04/2024 11:04	จ. 02/04/2024 11:27	0.23	6-
249	69 MMT มท4776สข	CHEVRON	รถกระบะ รถยก	จ. 02/04/2024 11:06	จ. 02/04/2024 11:35	0.29	6-
250	96 SAP 71-8797สข	JETTY	รถสิบล้อ	จ. 02/04/2024 11:08	จ. 02/04/2024 11:23	0.14	6-
251	71 PCN 71-9052สข	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 11:12	จ. 02/04/2024 12:42	1.30	6-
252	85 GTE 61-2613กทม	JETTY	รถเช่า	จ. 02/04/2024 11:19	จ. 02/04/2024 13:23	2.03	6-
253	80 GTE โกซิดย โสฬวง 59... 79-3985กทม	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 11:20	จ. 02/04/2024 13:23	2.02	6-
254	55 71-8839 63	JETTY	รถสิบล้อ	จ. 02/04/2024 11:23	จ. 02/04/2024 13:38	2.15	6-
255	63 SAP ขาแฟฉัน คีอราแฉ 1... 71-9029สข	JETTY	รถกระบะ รถยก	จ. 02/04/2024 11:25	จ. 02/04/2024 11:35	0.10	6-
256	88 CPOP E0QL8125R19944032... 3ขท7681กทม	JETTY	รถกระบะ รถยก	จ. 02/04/2024 11:26	จ. 02/04/2024 11:36	0.10	6-
257	028 AAL 77-4788กทม	JETTY	รถเช่า	จ. 02/04/2024 11:28	จ. 02/04/2024 13:38	2.10	6-
258	86 STS กท9397สข	JETTY	รถกระบะ รถยก	จ. 02/04/2024 11:30	จ. 02/04/2024 21:11	9.41	6-
259	034 GT 034	JETTY	รถเช่า	จ. 02/04/2024 11:34	จ. 02/04/2024 12:42	1.08	6-
260	009 SAP F0I33789D1752M0X2... 71-8533สข	JETTY	รถเช่า	จ. 02/04/2024 11:35	จ. 02/04/2024 12:42	1.07	6-
261	035 GTE ศิริคค รัตนโมณเฒ ... 79-3983กทม	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 11:36	จ. 02/04/2024 13:52	2.16	6-
262	63 STP 71-3916สข	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 11:40	จ. 02/04/2024 12:42	1.02	6-
263	030 GTE 79-4754กทม	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 11:42	จ. 02/04/2024 14:30	2.48	6-
264	51 SK สมยงคค สร้งแกว ... 82-5738สข	PTTEP	รถสิบล้อ	จ. 02/04/2024 11:44	จ. 02/04/2024 12:02	0.18	6-
265	027 GTE 60-0474กทม	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 11:52	จ. 02/04/2024 14:47	2.55	6-
266	87 SK 80-6162สข	PTTEP	รถสิบล้อ	จ. 02/04/2024 12:01	จ. 02/04/2024 12:22	0.20	6-
267	023 PCN 72-2441สข	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 12:04	จ. 02/04/2024 13:43	1.39	6-
268	005 STP 71-4323สข	JETTY	รถน้ำมัน รถปูน	จ. 02/04/2024 12:08	จ. 02/04/2024 13:52	1.44	6-
269	69 OK กรรชญ์ สุชะวาท ... 82-8938สข	JETTY	รถกระบะ รถยก	จ. 02/04/2024 12:09	จ. 02/04/2024 13:22	1.13	6-
270	82 SK 81-3485สข	PTTEP	รถสิบล้อ	จ. 02/04/2024 12:21	จ. 02/04/2024 13:37	1.17	6-

IN-OUT Your company

IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประ G
496	249 AAL 64-2295กทท	JT	รถมอเตอร์	พ. 03/04/2024 14:03	พ. 03/04/2024 14:53	0.49	6-
497	136 MM JT 78-1986สข	JT	รถมอเตอร์	พ. 03/04/2024 14:06	พ. 03/04/2024 14:53	0.47	6-
498	156 SK 81-3475สข	JT	รถลิ้นล้อ	พ. 03/04/2024 14:08	พ. 03/04/2024 14:23	0.15	6-
499	248 AAL 72-0871สข	JT	รถลิ้นล้อ	พ. 03/04/2024 14:17	พ. 03/04/2024 14:53	0.36	6-
500	142 STM พพ2238สข	JT	รถกระบะ รถหกล้อ	พ. 03/04/2024 14:18	พ. 03/04/2024 15:02	0.44	6-
501	134 MM 71-0487สข	JT	รถมอเตอร์	พ. 03/04/2024 14:26	พ. 03/04/2024 15:41	1.15	6-
502	359 GTE 79-4754กทท	JT	รถน้ำมัน รถป่วน	พ. 03/04/2024 14:27	พ. 03/04/2024 16:23	1.56	6-
503	25 SK 82-8966สข	JT	รถลิ้นล้อ	พ. 03/04/2024 14:30	พ. 03/04/2024 14:46	0.16	6-
504	198 JT 71-2531สข	JT	รถมอเตอร์	พ. 03/04/2024 14:30	พ. 03/04/2024 15:41	1.11	6-
505	245 SP 72-2570สข	JT	รถน้ำมัน รถป่วน	พ. 03/04/2024 14:39	พ. 03/04/2024 16:23	1.43	6-
506	154 NDT งข6263สข	JT	รถกระบะ รถหกล้อ	พ. 03/04/2024 14:42	พ. 03/04/2024 15:03	0.21	6-
507	213 SP 72-2468สข	JT	รถน้ำมัน รถป่วน	พ. 03/04/2024 14:48		0.00	6-
508	215 ADS 71-5654สข	JT	รถลิ้นล้อ	พ. 03/04/2024 14:52	พ. 03/04/2024 15:18	0.26	6-
509	145 AP กข7885สข	JT	รถกระบะ รถหกล้อ	พ. 03/04/2024 14:54	พ. 03/04/2024 15:18	0.24	6-
510	156 MM พพ4775สข	JT	รถกระบะ รถหกล้อ	พ. 03/04/2024 14:55	พ. 03/04/2024 16:08	1.13	6-
511	167 EXT 95-9900สข	JT	รถลิ้นล้อ	พ. 03/04/2024 14:56	พ. 03/04/2024 19:21	4.26	6-
512	146 TXP 71-7600สข	JT	รถน้ำมัน รถป่วน	พ. 03/04/2024 14:57	พ. 03/04/2024 16:08	1.11	6-
513	248 KPS 68-3229กทท	JT	รถน้ำมัน รถป่วน	พ. 03/04/2024 14:59	พ. 03/04/2024 16:23	1.24	6-
514	132 MM 71-0331สข	JT	รถมอเตอร์	พ. 03/04/2024 15:02	พ. 03/04/2024 15:40	0.38	6-
515	25 SK 80-5763สข	PTEP	รถลิ้นล้อ	พ. 03/04/2024 15:03	พ. 03/04/2024 15:19	0.17	6-
516	219 GT 71-7398สข	JT	รถมอเตอร์	พ. 03/04/2024 15:04	พ. 03/04/2024 15:40	0.37	6-
517	164 STM 1ขก9993กทท	JT	รถกระบะ รถหกล้อ	พ. 03/04/2024 15:08	พ. 03/04/2024 15:26	0.18	6-
518	14 AAL 79-6503สข	JT	รถมอเตอร์	พ. 03/04/2024 15:14	พ. 03/04/2024 15:25	0.12	6-
519	155 PSW 71-6503สข	JT	รถมอเตอร์	พ. 03/04/2024 15:14	พ. 03/04/2024 16:08	0.54	6-
520	165 SAP 71-9239สข	JT	รถมอเตอร์	พ. 03/04/2024 15:16	พ. 03/04/2024 15:41	0.25	6-
521	124 SPM 7กข8174กทท	JT	รถกระบะ รถหกล้อ	พ. 03/04/2024 15:20	พ. 03/04/2024 15:41	0.21	6-
522	121 MM 71-6532สข	JT	รถมอเตอร์	พ. 03/04/2024 15:21	พ. 03/04/2024 15:41	0.19	6-
523	750 GT 71-8704สข	JT	รถลิ้นล้อ	พ. 03/04/2024 15:25	พ. 03/04/2024 15:40	0.15	6-

IN-OUT Your company


IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประ G
548	2 SK 815169สข	PTTEP	รถกระบะ รถหกล้อ	พ. 03/04/2024 18:09	พ. 04/04/2024 12:03	17.55	6

สรุป

Visitor ที่เข้ามา	548
กลับไปแล้ว	536
ยังไม่กลับ	12
อยู่สั้นสุด (h.mm)	0.00
อยู่นานสุด (h.mm)	17.55
เฉลี่ย (h.mm)	1.28

Visitor by type



IN-OUT Your company

IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ปร Gr
1	96 AAL 77-0552กทท	JETTY	รถเช่า	จ. 01/04/2024 06:41	จ. 01/04/2024 09:33	2.52	6-
2	259 SAP 71-9239สข	JT	รถเช่า	จ. 01/04/2024 07:21	จ. 01/04/2024 08:00	0.39	6-
3	888 PSW 71-6120สข	JETTY	รถเช่า	จ. 01/04/2024 07:47	จ. 01/04/2024 08:40	0.53	6-
4	298 GT 71-8704สข	JETTY	รถเช่า รถบรรทุก	จ. 01/04/2024 07:48	จ. 01/04/2024 09:20	1.31	6-
5	043 GT 71-7857สข	JT	รถเช่า	จ. 01/04/2024 08:01	จ. 01/04/2024 08:58	0.57	6-
6	021 GT 71-7858สข	JT	รถเช่า	จ. 01/04/2024 08:02	จ. 01/04/2024 09:45	1.43	6-
7	040 MM 70-6222สข	JT	รถเช่า	จ. 01/04/2024 08:09	จ. 01/04/2024 08:40	0.31	6-
8	034 PTTEP 2กทท6994กทท	JT	รถเช่า รถบรรทุก	จ. 01/04/2024 08:09	จ. 01/04/2024 08:39	0.30	6-
9	018 SIAMRAJ APICHAART THUENG... 4กทท2520กทท 086-7496155	Jetty CVX	รถเช่า รถบรรทุก	จ. 01/04/2024 08:11	จ. 01/04/2024 08:40	0.29	6-
10	035 AAL 79-6735กทท	JT	รถเช่า รถบรรทุก	จ. 01/04/2024 08:12	จ. 01/04/2024 10:39	2.27	6-
11	006 AAL 79-6502กทท	JT	รถเช่า	จ. 01/04/2024 08:14	จ. 01/04/2024 10:27	2.13	6-
12	039 AAL 77-0554กทท	JT	รถเช่า	จ. 01/04/2024 08:20	จ. 01/04/2024 08:40	0.20	6-
13	030 GT 71-6346สข	JT	รถเช่า	จ. 01/04/2024 08:25	จ. 01/04/2024 08:41	0.16	6-
14	028 SAP สำนักงาน นวคตเขต 39... 71-7614สข	JETTY	รถเช่า	จ. 01/04/2024 08:28	จ. 01/04/2024 09:21	0.53	6-
15	025 GT 71-7398สข	JETTY	รถเช่า	จ. 01/04/2024 08:30	จ. 01/04/2024 08:58	0.28	6-
16	005 AAL กอศ. หักหนี้ 3900... 72-8756กทท	JETTY	รถเช่า	จ. 01/04/2024 08:32	จ. 01/04/2024 10:11	1.39	6-
17	045 GT 71-8802สข	JT	รถเช่า	จ. 01/04/2024 08:37	จ. 01/04/2024 09:20	0.44	6-
18	038 PAE 91-5500กทท	JT	รถเช่า	จ. 01/04/2024 08:42	จ. 01/04/2024 08:58	0.16	6-
19	046 AAL 68-0708กทท	AAL	รถเช่า รถบรรทุก	จ. 01/04/2024 08:43	จ. 01/04/2024 09:21	0.38	6-
20	009 AAL 79-6733กทท	JT	รถเช่า	จ. 01/04/2024 08:45	จ. 01/04/2024 09:45	0.59	6-
21	048 SPA 71-9239สข	JT	รถเช่า	จ. 01/04/2024 08:56	จ. 01/04/2024 09:20	0.24	6-
22	027 WMS 51-3329กทท	JT	รถเช่า	จ. 01/04/2024 09:03	จ. 01/04/2024 09:33	0.31	6-
23	023 BES Somboon Kruathong... 2กทท7001กทท 0897021026	EMI	รถเช่า รถบรรทุก	จ. 01/04/2024 09:06	จ. 01/04/2024 09:20	0.14	6-
24	35 WMS 72-7575สข	JT	รถเช่า	จ. 01/04/2024 09:14	จ. 01/04/2024 09:33	0.20	6-
25	248 AAL 96-5154กทท	JT	รถเช่า	จ. 01/04/2024 09:19	จ. 01/04/2024 09:45	0.26	6-
26	121 CTK 6กทท6147สข	JT	รถเช่า รถบรรทุก	จ. 01/04/2024 09:20	จ. 01/04/2024 09:25	0.05	6-
27	226 TNA 6กทท6141สข	JT	รถเช่า รถบรรทุก	จ. 01/04/2024 09:22	จ. 01/04/2024 09:24	0.12	6-

IN-OUT Your company

IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ปร Gr
248	53 SK 81-0226สข	JETTY	รถเช่า	จ. 02/04/2024 11:04	จ. 02/04/2024 11:27	0.23	6-
249	69 MMT 6กทท4776สข	CHEVRON	รถเช่า รถบรรทุก	จ. 02/04/2024 11:06	จ. 02/04/2024 11:35	0.29	6-
250	96 SAP 71-8797สข	JETTY	รถเช่า	จ. 02/04/2024 11:08	จ. 02/04/2024 11:23	0.14	6-
251	71 PCN 71-9052สข	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:12	จ. 02/04/2024 12:42	1.30	6-
252	85 GTE 61-2613กทท	JETTY	รถเช่า	จ. 02/04/2024 11:19	จ. 02/04/2024 13:23	2.03	6-
253	80 GTE โกดัง 59... 79-3985กทท	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:20	จ. 02/04/2024 13:23	2.02	6-
254	55 71-8839 63	JETTY	รถเช่า	จ. 02/04/2024 11:23	จ. 02/04/2024 13:38	2.15	6-
255	63 SAP ขาเหล็ก คือราเม 1... 71-9029สข	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:25	จ. 02/04/2024 11:35	0.10	6-
256	88 CPOP E0QL8125R19944032... 3กทท7681กทท	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:26	จ. 02/04/2024 11:36	0.10	6-
257	028 AAL 77-4788กทท	JETTY	รถเช่า	จ. 02/04/2024 11:28	จ. 02/04/2024 13:38	2.10	6-
258	86 STS 6กทท9397สข	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:30	จ. 02/04/2024 21:11	9.41	6-
259	034 GT 034	JETTY	รถเช่า	จ. 02/04/2024 11:34	จ. 02/04/2024 12:42	1.08	6-
260	009 SAP F0I33789D1752M0X2... 71-8533สข	JETTY	รถเช่า	จ. 02/04/2024 11:35	จ. 02/04/2024 12:42	1.07	6-
261	035 GTE 6กทท33 รันโม... 79-3983กทท	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:36	จ. 02/04/2024 13:52	2.16	6-
262	63 STP 71-3916สข	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:40	จ. 02/04/2024 12:42	1.02	6-
263	030 GTE 79-4754กทท	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:42	จ. 02/04/2024 14:30	2.48	6-
264	51 SK สมยศ สร้างแก้ว ... 82-5738สข	PTTEP	รถเช่า	จ. 02/04/2024 11:44	จ. 02/04/2024 12:02	0.18	6-
265	027 GTE 60-0474กทท	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 11:52	จ. 02/04/2024 14:47	2.55	6-
266	87 SK 80-6162สข	PTTEP	รถเช่า	จ. 02/04/2024 12:01	จ. 02/04/2024 12:22	0.20	6-
267	023 PCN 72-2441สข	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 12:04	จ. 02/04/2024 13:43	1.39	6-
268	005 STP 71-4323สข	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 12:08	จ. 02/04/2024 13:52	1.44	6-
269	69 OK 6กทท9397 สขจวท ... 82-8938สข	JETTY	รถเช่า รถบรรทุก	จ. 02/04/2024 12:09	จ. 02/04/2024 13:22	1.13	6-
270	82 SK 81-3485สข	PTTEP	รถเช่า	จ. 02/04/2024 12:21	จ. 02/04/2024 13:37	1.17	6-

IN-OUT Your company

IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
3000 63	AAL ตลขุโสบ หวังนุรัก... 69-6416กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 13:34	๙. 22/04/2024 15:01	1.27	8-8	0
3001 69	WMS 72-8833ชม	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 13:38	๙. 22/04/2024 14:59	1.21	8-8	0
3002 863	AAL 79-6731กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 13:41	๙. 22/04/2024 15:00	1.19	8-8	0
3003 040	GTE นิวัติ รัตนโมฬี ... 61-2611กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 13:50	๙. 22/04/2024 20:31	6.41	8-8	0
3004 043	MS รบ5571กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 13:53	๙. 22/04/2024 17:07	3.15	8-8	0
3005 621	GTE ณฐกานต์ สุวรรณภูมิ... 79-3983กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 13:59	๙. 22/04/2024 17:03	3.04	8-8	0
3006 025	BJ สามารก ขุนนาทุม ... 70-1581พล	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 14:03	๙. 22/04/2024 17:05	3.02	8-8	0
3007 698	AAL 64-2295กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 14:07	๙. 22/04/2024 17:07	2.60	8-8	0
3008 034	BREKER ณรงค์ เรืองยิม 3... กค2223สข 0863670410	Jetty	ส่ง สิ้นค้า	๙. 22/04/2024 14:10	๙. 22/04/2024 17:05	2.55	8-8	0
3009 359	BES Somboon Kruathong... 2ขค7063กทท 0897021026	EMI	ส่ง สิ้นค้า	๙. 22/04/2024 14:11	๙. 22/04/2024 14:59	0.49	8-8	0
3010 691	MPC 98-1460กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 14:19	๙. 22/04/2024 17:07	2.48	8-8	0
3011 018	KIA ณฤตฤทธิ์ ตูลาพอง... 2คพ6032กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 14:29	๙. 22/04/2024 17:06	2.36	8-8	0
3012 596	MML ประจักษ์ ประสานสง... 71-2857สข	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 14:33	๙. 22/04/2024 17:06	2.33	8-8	0
3013 752	GT 71-8965สข	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 14:35	๙. 22/04/2024 17:07	2.33	8-8	0
3014 888	GT LOYS323RL112770B3... 71-7858สข	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 14:47	๙. 22/04/2024 17:05	2.19	8-8	0
3015 587	AAL ตลขุโสบ หวังนุรัก... 69-6416กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:01	๙. 22/04/2024 17:05	2.04	8-8	0
3016 593	GT 71-7857สข	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:06	๙. 22/04/2024 17:05	1.59	8-8	0
3017 222	AAL 96-5154กทท	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:28	๙. 22/04/2024 17:05	1.36	8-8	0
3018 333	TXP ชาศิ จันทริยัง ... 71-7598สร	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:34	๙. 22/04/2024 20:31	4.57	8-8	0
3019 113	AAL รถเทรลเลอร์-79-6...	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:38	๙. 22/04/2024 20:31	4.53	8-8	0
3020 132	BES Suppanut Chakoch... รถกระบะ-2ขค-6951กทท	OTF	ส่ง สิ้นค้า	๙. 22/04/2024 15:46	๙. 22/04/2024 17:04	1.18	8-8	0
3021 284	PCS พรสวรรค์ เรืองคำ ... 72-2970รย	JETTY	รับ สิ้นค้า	๙. 22/04/2024 15:47	๙. 22/04/2024 17:03	1.16	8-8	0
3022 192	SAP รถเทรลเลอร์-71-8...	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:51	๙. 22/04/2024 20:31	4.41	8-8	0
3023 000	GT รถเทรลเลอร์-71-7...	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:53	๙. 22/04/2024 17:02	1.09	8-8	0
3024 236 ศรีชัย เพชรบุรี 38... รถกระบะ-บค-7858สข	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:55	๙. 22/04/2024 17:02	1.08	8-8	0
3025 231	AAL รถเทรลเลอร์-79-6...	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:57	๙. 22/04/2024 20:31	4.34	8-8	0
3026 514	GT รถเทรลเลอร์-71-8...	JETTY	ส่ง สิ้นค้า	๙. 22/04/2024 15:59	๙. 22/04/2024 17:02	1.02	8-8	0

IN-OUT Your company


IN ตั้งแต่ 01/04/2024@00:00 ถึง 30/04/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
4466 36	GT 71 8962สข	JETTY	ส่ง สิ้นค้า	๙. 30/04/2024 22:23	๙. 01/05/2024 04:48	6.25	8-8	0

สรุป

Visitor ที่เข้ามา	4,466
กลับไปแล้ว	4,463
ยังไม่กลับ	3
อยู่สั้นสุด (h.mm)	0.00
อยู่นานสุด (h.mm)	21.39
เฉลี่ย (h.mm)	2.48

Visitor by type



- ติดค้างงาน = 12
- ประชุม อบรม = 1
- ผู้รับเหมา = 13
- รับ สิ้นค้า = 917
- วางบิล = 22
- ส่ง สิ้นค้า = 3440
- อื่นๆ = 60
- เยี่ยมชม-ตรวจงาน = 1

IN-OUT Your company

IN ตั้งแต่ 01/05/2024@00:00 ถึง 31/05/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ให้เข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
810	257 SAP 72-1080สข	SAP	รับ สินค้า	๙. 06/05/2024 09:29	๙. 06/05/2024 10:09	0.40	8-8	0
811	358 SKL ขค335สข	JEETY	ส่ง สินค้า	๙. 06/05/2024 09:30	๙. 06/05/2024 11:58	2.29	8-8	0
812	C5555 OK 71-7863สข	CHR	ส่ง สินค้า	๙. 06/05/2024 09:31	๙. 06/05/2024 10:10	0.39	8-8	0
813	C55555 AAL 76-8809กทม	CHR	รับ สินค้า	๙. 06/05/2024 09:32	๙. 06/05/2024 10:07	0.35	8-8	0
814	573 AAL 77-0581กทม	JETTY	รับ สินค้า	๙. 06/05/2024 09:33	๙. 06/05/2024 11:57	2.24	8-8	0
815	24 GT 71-5727สข	JETTY	รับ สินค้า	๙. 06/05/2024 09:34	๙. 06/05/2024 15:14	5.40	8-8	0
816	254 PSW 71-5563สข	JETTY	รับ สินค้า	๙. 06/05/2024 09:35	๙. 06/05/2024 11:53	2.18	8-8	0
817	C63 GT 71-7398สข	JETTY	ส่ง สินค้า	๙. 06/05/2024 09:38	๙. 06/05/2024 10:08	0.31	8-8	0
818	C88 72-7575ขบ	CHR	รับ สินค้า	๙. 06/05/2024 09:43	๙. 06/05/2024 11:59	2.15	8-8	0
819	C12 AAL CHR 68-0708กทม		ส่ง สินค้า	๙. 06/05/2024 09:47	๙. 06/05/2024 12:03	2.16	8-8	0
820	C23 AAL 62-9248กทม	CHR	รับ สินค้า	๙. 06/05/2024 09:48	๙. 06/05/2024 10:06	0.19	8-8	0
821	C556 ST 72-2875สข	CHR	ส่ง สินค้า	๙. 06/05/2024 09:49	๙. 06/05/2024 12:01	2.12	8-8	0
822	563 AAL 69-4405	JETTY	รับ สินค้า	๙. 06/05/2024 09:50	๙. 06/05/2024 12:02	2.12	8-8	0
823	231 GT 71-7902สข	CHR	ส่ง สินค้า	๙. 06/05/2024 09:51	๙. 06/05/2024 11:52	2.02	8-8	0
824	624 MM 71-4547สข	JETTY	รับ สินค้า	๙. 06/05/2024 09:51	๙. 06/05/2024 11:50	1.59	8-8	0
825	C65 GT 61-6346สข	CHR	ส่ง สินค้า	๙. 06/05/2024 09:52	๙. 06/05/2024 11:52	1.60	8-8	0
826	265 MM 71-3004สข	JETTY	รับ สินค้า	๙. 06/05/2024 09:59	๙. 06/05/2024 12:02	2.03	8-8	0
827	167 AAL 79-6502กทม	JETTY	รับ สินค้า	๙. 06/05/2024 10:01	๙. 06/05/2024 13:29	3.28	8-8	0
828	78 MM 63-1794กทม	JETTY	รับ สินค้า	๙. 06/05/2024 10:03	๙. 06/05/2024 11:50	1.46	8-8	0
829	23 MM 71-5154สข	JETY	รับ สินค้า	๙. 06/05/2024 10:07	๙. 06/05/2024 15:15	5.07	8-8	0
830	14 MM 72-0871สข	JETY	รับ สินค้า	๙. 06/05/2024 10:14	๙. 06/05/2024 11:52	1.38	8-8	0
831	312 KPS 72-7180สข	JETZ	ส่ง สินค้า	๙. 06/05/2024 10:15	๙. 06/05/2024 11:51	1.37	8-8	0
832	513 AAL 79-650กทม	JETY	ส่ง สินค้า	๙. 06/05/2024 10:16	๙. 06/05/2024 11:58	1.42	8-8	0
833	257 GTE 61-2608กทม	JETTTY	ส่ง สินค้า	๙. 06/05/2024 10:18	๙. 06/05/2024 15:12	4.55	8-8	0
834	82 GTE 79-4754กทม	JETTY	ส่ง สินค้า	๙. 06/05/2024 10:18	๙. 06/05/2024 15:12	4.54	8-8	0
835	555 ST 71-4323สข	JETTY	ส่ง สินค้า	๙. 06/05/2024 10:19	๙. 06/05/2024 15:12	4.53	8-8	0
836	987 AAL 77-4789กทม	JETTY	ส่ง สินค้า	๙. 06/05/2024 10:21	๙. 06/05/2024 11:58	1.37	8-8	0
837	035 GTE กข5956กทม	JETTY	ส่ง สินค้า	๙. 06/05/2024 10:23	๙. 06/05/2024 17:35	7.12	8-8	0

IN-OUT Your company

IN ตั้งแต่ 01/05/2024@00:00 ถึง 31/05/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ให้เข้าพบ Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
2156	021 GT เติม ศรีทอง 39609... 71-8392สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:10	๙. 14/05/2024 13:25	2.16	8-8	0
2157	045 MM หม-4776สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:10	๙. 14/05/2024 13:27	2.16	8-8	0
2158	025 STS วิจารณ์ หุ่นน้อย 3... มข-8420สข	JETTY	รับ สินค้า	๙. 14/05/2024 11:19	๙. 14/05/2024 13:26	2.07	8-8	0
2159	048 PCN 72-2188สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:21	๙. 14/05/2024 15:04	3.43	8-8	0
2160	323 SAP วิจารณ์ เพชรเจีย ... 71-7875สข	JETTY	รับ สินค้า	๙. 14/05/2024 11:22	๙. 14/05/2024 15:06	3.43	8-8	0
2161	035 PCN 71-9835สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:23	๙. 14/05/2024 13:23	1.60	8-8	0
2162	034 STP สะมะแอ นันทจิต 59... 71-3916สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:26	๙. 14/05/2024 13:23	1.57	8-8	0
2163	456 GT 71-8802สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:31	๙. 14/05/2024 15:05	3.34	8-8	0
2164	005 SSSP ชีรวัฒน์ มณีล้ำ 1... นร-8338สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:31	๙. 14/05/2024 13:25	1.54	8-8	0
2165	C63 AAL 76-8809กทม	CHEVRON	ส่ง สินค้า	๙. 14/05/2024 11:33	๙. 14/05/2024 13:24	1.51	8-8	0
2166	C13 WMS 72-8998ขบ	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:37	๙. 14/05/2024 15:06	3.29	8-8	0
2167	665 GT 71-8962สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:38	๙. 14/05/2024 13:24	1.46	8-8	0
2168	112 KPS สัมผัส หล้าหมัด 39... 68-6370กทม	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:52	๙. 14/05/2024 18:24	6.32	8-8	0
2169	332 GT 71-7902สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:57	๙. 14/05/2024 13:22	1.25	8-8	0
2170	040 SM หมพ-2238สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 11:57	๙. 14/05/2024 13:24	1.26	8-8	0
2171	635 BOA ปราโมทย์ แก้วมณี ... ขล-1570สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:04	๙. 14/05/2024 15:02	2.58	8-8	0
2172	544 GT 7-5727สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:21	๙. 14/05/2024 15:06	2.45	8-8	0
2173	654 SPP 72-1187สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:30	๙. 14/05/2024 14:57	2.27	8-8	0
2174	367 STP 72-4326สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:33	๙. 14/05/2024 14:56	2.23	8-8	0
2175	657 SPP 72-2468สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:36	๙. 14/05/2024 18:24	5.48	8-8	0
2176	663 GT 71-8704สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:38	๙. 14/05/2024 18:26	5.48	8-8	0
2177	652 GT 71-7858สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:45	๙. 14/05/2024 13:23	0.37	8-8	0
2178	C42 AAL 77-3739กทม	CHEVRON	ส่ง สินค้า	๙. 14/05/2024 12:50	๙. 14/05/2024 15:06	2.16	8-8	0
2179	52 GT 71-7857สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 12:54	๙. 14/05/2024 15:04	2.10	8-8	0
2180	964 GT 71-8965สข	JETTY	ส่ง สินค้า	๙. 14/05/2024 13:00	๙. 14/05/2024 15:02	2.02	8-8	0
2181	338 AAL 78-0231กทม	JETTY	ส่ง สินค้า	๙. 14/05/2024 13:01	๙. 14/05/2024 14:56	1.54	8-8	0
2182	042 AAL 77-4789กทม	JETTY	ส่ง สินค้า	๙. 14/05/2024 13:06	๙. 14/05/2024 15:01	1.55	8-8	0
2183	582 AAL 77-4787กทม	JETTY	ส่ง สินค้า	๙. 14/05/2024 13:06	๙. 14/05/2024 15:03	1.56	8-8	0

IN-OUT Your company

IN ตั้งแต่ 01/05/2024@00:00 ถึง 31/05/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
4045	265 WMS 51-3329ชม	JT	รับ สินค้า	๒๖. 26/05/2024 09:02	๒๖. 26/05/2024 10:28	1.26	8-8	0
4046	356 AAL 77-4789กทม	JT	รับ สินค้า	๒๖. 26/05/2024 09:11	๒๖. 26/05/2024 10:28	1.17	8-8	0
4047	396 KPS 63-6370กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:21	๒๖. 26/05/2024 11:53	2.32	8-8	0
4048	352 GTE 60-0474กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:22	๒๖. 26/05/2024 11:38	2.17	8-8	0
4049	673 GTE 79-0754กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:22	๒๖. 26/05/2024 11:39	2.16	8-8	0
4050	675 SN ชน2203สช	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:25	๒๖. 26/05/2024 10:28	1.03	8-8	0
4051	148 CTK 71-6118สช	JT	รับ สินค้า	๒๖. 26/05/2024 09:26	๒๖. 26/05/2024 10:28	1.02	8-8	0
4052	566 GTE 79-3983กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:27	๒๖. 26/05/2024 16:15	6.48	8-8	0
4053	866 WMS 72-7575ชม	JT	รับ สินค้า	๒๖. 26/05/2024 09:28	๒๖. 26/05/2024 12:06	2.38	8-8	0
4054	849 WMS 72-8877ชม	JT	รับ สินค้า	๒๖. 26/05/2024 09:28	๒๖. 26/05/2024 11:53	2.25	8-8	0
4055	254 GTE 71-8962สช	JT	รับ สินค้า	๒๖. 26/05/2024 09:29	๒๖. 26/05/2024 12:05	2.36	8-8	0
4056	379 GTE ถข5956กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:31	๒๖. 26/05/2024 17:43	8.12	8-8	0
4057	846 GTE 61-2605กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:34	๒๖. 26/05/2024 16:15	6.41	8-8	0
4058	088 GT 71-8965สช	JT	รับ สินค้า	๒๖. 26/05/2024 09:36	๒๖. 26/05/2024 12:05	2.29	8-8	0
4059	099 MOP ปรากร เพชรทอง 39... ผจ2456สช	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:37	๒๖. 26/05/2024 10:28	0.51	8-8	0
4060	0663 KSN มนัส สุวรรณโณ 390... ผก8347สช	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:39	๒๖. 26/05/2024 12:03	2.24	8-8	0
4061	049 CCO อนุชาติ ศรีมาก 19... 7กภ618กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:40	๒๖. 26/05/2024 10:27	0.47	8-8	0
4062	546 AAL 79-6733กทม	JT	รับ สินค้า	๒๖. 26/05/2024 09:47	๒๖. 26/05/2024 12:06	2.19	8-8	0
4063	65 AAL 72-8758กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 09:49	๒๖. 26/05/2024 11:39	1.50	8-8	0
4064	576 NDT ชน7798สช	JT	รับ สินค้า	๒๖. 26/05/2024 10:02	๒๖. 26/05/2024 12:09	2.07	8-8	0
4065	976 AAL 77-0554กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 10:05	๒๖. 26/05/2024 11:36	1.32	8-8	0
4066	666 STS กม9397สช	JT	ผู้รับเหมา	๒๖. 26/05/2024 10:07	๒๖. 26/05/2024 17:43	7.36	8-8	0
4067	886 MPT สห2704กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 10:09	๒๖. 26/05/2024 12:05	1.56	8-8	0
4068	048 EES ชร5962สช	JT	ส่ง สินค้า	๒๖. 26/05/2024 10:13	๒๖. 26/05/2024 15:57	5.44	8-8	0
4069	845 AAL 77-7888กทม	JT	ส่ง สินค้า	๒๖. 26/05/2024 10:14	๒๖. 26/05/2024 16:14	5.59	8-8	0
4070	67 JT 72-7280สช	JT	ส่ง สินค้า	๒๖. 26/05/2024 10:33	๒๖. 26/05/2024 11:31	0.59	8-8	0
4071	645 MM 71-3991สช	JT	ส่ง สินค้า	๒๖. 26/05/2024 10:34	๒๖. 26/05/2024 11:48	1.14	8-8	0

IN-OUT Your company


IN ตั้งแต่ 01/05/2024@00:00 ถึง 31/05/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
5034	567 TWT 72-0445สช	JETTY	ส่ง สินค้า	๓. 31/05/2024 16:20	๓. 01/06/2024 04:34	12.14	8-8	0
5035	95 TXP 71-7600สช	JT	ส่ง สินค้า	๓. 31/05/2024 16:48	๓. 01/06/2024 04:34	11.46	8-8	0
5036	564 AMARIT Supat Sangkaew 39... รกกระบะ-กต-6928กทม MHE		ส่ง สินค้า	๓. 31/05/2024 17:11	๓. 01/06/2024 04:34	11.23	8-8	0
5037	021 SAP คุณานนต์ ตามภานท... 71 9239สช	JETTY	ส่ง สินค้า	๓. 31/05/2024 17:53	๓. 01/06/2024 04:34	10.42	8-8	0
5038	045 TXP สมชาย สุขเกษม 319... 71 7600สร	JETTY	ส่ง สินค้า	๓. 31/05/2024 18:24	๓. 01/06/2024 04:35	10.11	8-8	0
5039	1 GT 71.8704.ช รกยนต์	JETY	ส่ง สินค้า	๓. 31/05/2024 18:52	๓. 01/06/2024 04:35	9.43	8-8	0
5040	048 SK 81.4321.สช รกยนต์	JETY	รับ สินค้า	๓. 31/05/2024 19:10	๓. 01/06/2024 04:35	9.25	8-8	0
5041	043 EXPT 95.9900กทม รกยนต์	JETY	รับ สินค้า	๓. 31/05/2024 19:39	๓. 01/06/2024 04:35	8.56	8-8	0
5042	005 AAL 72.8760กท รกเทร...	JETY	รับ สินค้า	๓. 31/05/2024 19:41	๓. 01/06/2024 04:35	8.54	8-8	0
5043	025 GT 71.8704.สช รกยนต์	JETY	ส่ง สินค้า	๓. 31/05/2024 20:03	๓. 01/06/2024 04:35	8.32	8-8	0

สรุป

Visitor ที่เข้ามา	5,043
กลับไปแล้ว	5,042
ค้างไว้มากลับ	1
อยู่สั้นสุด (h.mm)	0.00
อยู่นานสุด (h.mm)	32.38
เฉลี่ย (h.mm)	3.07

Visitor by type



สีแดง	ติดค้างงาน = 19
สีเขียว	ผู้รับเหมา = 20
สีน้ำเงิน	รับ สินค้า = 1188
สีเหลือง	วางบิล = 28
สีฟ้า	ส่ง สินค้า = 3787
สีชมพู	อื่นๆ = 1

IN-OUT Your company

IN ตั้งแต่ 01/06/2024@00:00 ถึง 28/06/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type		เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
1	6 AAL กำพล อิศสระ 19099... 77.3644กท รถเทร...	JETY	ส่ง สิ้นค้า	๙.	10/06/2024 18:29	๙. 12/06/2024 00:11	29.41	6-1	1
2	7 GT ชีระวุฒิ พาสี 390... 71.7398ส.ข รถเทร...	JETY	ส่ง สิ้นค้า	๙.	10/06/2024 18:32		0.00	6-?	1
3	1 ศรชัย เพชรบุรี 38... นท7858สข	JETTY	ส่ง สิ้นค้า	๙.	10/06/2024 18:56		0.00	6-?	1
4	2 สข นท7858	JETTY	ส่ง สิ้นค้า	๙.	10/06/2024 19:54		0.00	6-?	1
5	1 ST ยงยุทธ พิมพ์ะโร ... 71 8571สข	JETTY	ส่ง สิ้นค้า	๙.	10/06/2024 21:22	๙. 11/06/2024 17:32	20.11	6-1	1
6	639 MSTs 2ฉบับ5453กทม	JETTY	ส่ง สิ้นค้า	๙.	11/06/2024 06:47	๙. 12/06/2024 04:45	21.58	6-1	1
7	86 5 3		ส่ง สิ้นค้า	๙.	11/06/2024 16:51	๙. 12/06/2024 04:46	11.54	6-1	0
8	541 บุญณ 54 53	54	ส่ง สิ้นค้า	๙.	11/06/2024 17:00	๙. 12/06/2024 04:46	11.46	6-1	1
9	4125 AMARIT Supat Sangkaew 39... 65782	MHE	ติดต่องาน	๙.	11/06/2024 17:07	๙. 12/06/2024 04:43	11.36	6-1	1
10	1 GT สิทธิประเสริฐ หน้... 72.3092ส.ข รถเทร...	JETY	ส่ง สิ้นค้า	๙.	11/06/2024 17:52		0.00	6-?	1
11	11 888 55 88	55	ส่ง สิ้นค้า	๙.	11/06/2024 18:14	๙. 11/06/2024 18:30	0.16	6-1	1
12	111 22 9898 งง	6	วางฉิล	๙.	11/06/2024 18:21	๙. 11/06/2024 18:24	0.03	6-6	0
13	100 BB AB กก	A	รับ สิ้นค้า	๙.	11/06/2024 18:25	๙. 11/06/2024 18:26	0.01	6-6	1
14	8888 88 II ขนข	II	รับ สิ้นค้า	๙.	11/06/2024 18:27	๙. 12/06/2024 04:42	10.15	6-1	0
15	88 PTTOR Weerapat Binukul... 1นค-3823กทม	Jetty	ส่ง สิ้นค้า	๙.	12/06/2024 05:42	๙. 12/06/2024 06:31	0.49	6-1	2
16	885 85 5 บุญ	5	ส่ง สิ้นค้า	๙.	12/06/2024 05:55	๙. 12/06/2024 05:58	0.03	6-6	2
17	582 PTTOR Weerapat Binukul... 1นค-3823กทม	Jetty	ส่ง สิ้นค้า	๙.	12/06/2024 06:40	๙. 12/06/2024 08:21	1.41	6-1	2
18	C45 EXPT 97-0625กทม	CHEVRON	รับ สิ้นค้า	๙.	12/06/2024 07:16	๙. 12/06/2024 09:07	1.52	6-1	1
19	45 GT 71-8704สข	JT	รับ สิ้นค้า	๙.	12/06/2024 07:45	๙. 12/06/2024 08:00	0.15	6-1	2
20	548 SAP คุณานนต ตามถานท... 71-9239สข	JT	รับ สิ้นค้า	๙.	12/06/2024 07:55	๙. 12/06/2024 08:21	0.26	6-1	2
21	547 MM อุทิศ นิลราหม... 71-3101สข	JT	รับ สิ้นค้า	๙.	12/06/2024 07:59	๙. 12/06/2024 10:29	2.30	6-1	2
22	543 MM เอกพจน์ เพชรบุ 19... 71-3005สข	JT	รับ สิ้นค้า	๙.	12/06/2024 08:00	๙. 12/06/2024 10:18	2.17	6-1	1
23	C11 GT สุทธิวิธ หนูตัน 19... 71-7902สข	JT	รับ สิ้นค้า	๙.	12/06/2024 08:01		0.00	6-?	1
24	574 CES ณรงค์ศักดิ์ สุทธิธ... ๗๔-7238สข	JT	ส่ง สิ้นค้า	๙.	12/06/2024 08:04	๙. 12/06/2024 09:21	1.16	6-1	1
25	C12 GT สิทธิประเสริฐ หน้... 72-3092สข	CHR	รับ สิ้นค้า	๙.	12/06/2024 08:12	๙. 12/06/2024 09:21	1.09	6-1	1
26	84 CES นข-8690สข	JETTY	ส่ง สิ้นค้า	๙.	12/06/2024 08:13	๙. 12/06/2024 09:22	1.09	6-1	2
27	658 MML Watcharit Suwanma... 2นค-6994กทม	PSB	ส่ง สิ้นค้า	๙.	12/06/2024 08:13	๙. 12/06/2024 09:07	0.53	6-1	1

IN-OUT Your company

IN ตั้งแต่ 01/06/2024@00:00 ถึง 28/06/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้ไปเข้าพบ Guest of	ประเภท Type		เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
1078	589 SIAM-SPY มนต์ หนูเหมื่อน 39... ๗๗484สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:37	๙. 18/06/2024 15:06	1.29	6-1	2
1079	699 OPF นราธร หวันยาหาว 1... 82-4246สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:39	๙. 18/06/2024 15:06	1.27	6-1	2
1080	533 SK LOD5300161719K0Z3... 81-4321สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:40	๙. 18/06/2024 14:23	0.43	6-1	2
1081	688 SAP JETTY 71-9175สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:41	๙. 18/06/2024 14:24	0.43	6-1	2
1082	588 AAL สุทธิชัย อินสระ 1... 79-6734กทม	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:43	๙. 18/06/2024 15:07	1.24	6-1	2
1083	536 OPF ภาพิน รัดนศรี 3... ๗๙824สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:44	๙. 18/06/2024 15:06	1.22	6-1	2
1084	571 SPKD X0GH620VV1756A062... 71-4673สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:45	๙. 18/06/2024 17:17	3.32	6-1	2
1085	900 NDT โภคินทร์ ทองน้อย ... ๙๖6263สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:46	๙. 18/06/2024 15:08	1.22	6-1	2
1086	988 AAL 64-2296กทม	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:48	๙. 18/06/2024 15:05	1.18	6-1	2
1087	599 AAL ปิยะพงศ์ หวังบุร... 69-6412	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:51	๙. 18/06/2024 14:16	0.25	6-1	2
1088	365 SSS โฉมพิน กัมมาคม 190... ๗๙8599สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:52	๙. 18/06/2024 14:16	0.25	6-1	2
1089	999 AAL ตะวี เจ๊ะหลี 190... 79-6733กทม	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:53	๙. 18/06/2024 15:08	1.15	6-1	2
1090	C599 AAL อภิวิชญ์ นันทกุล ... 62-9248กทม	CHEVRON	รับ สิ้นค้า	๙.	18/06/2024 13:54	๙. 18/06/2024 14:17	0.23	6-1	2
1091	233 MML อรุณ สงสุรินทร์ 3... 72-0871สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:55	๙. 18/06/2024 15:56	2.02	6-1	2
1092	369 WIPRO ปิติกพงศ์ กองสุข 3... ๗๔4270สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:56	๙. 18/06/2024 15:07	1.11	6-1	2
1093	652 SAP รุ่งโรจน์ เพชรเจีย ... 71-7875สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:58	๙. 18/06/2024 16:52	2.54	6-6	1
1094	644 GT สุชาติ นิลดิบ 390... 72-3094สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 13:59	๙. 18/06/2024 15:07	1.08	6-1	2
1095	685 GTE 61-2605กทม	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 14:02	๙. 18/06/2024 23:07	9.05	6-1	1
1096	88 AAL 78-0230กทม	JT	ส่ง สิ้นค้า	๙.	18/06/2024 14:08	๙. 18/06/2024 23:08	8.60	6-1	1
1097	477 GT LOYS323RL112770B3... 71-7858สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 14:28	๙. 18/06/2024 21:49	7.21	6-1	1
1098	562 MML มาดิค แก้วศิริ 19... 71-3004สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 14:51	๙. 18/06/2024 21:50	6.58	6-1	1
1099	554 AAL 79-6732กทม	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 15:04	๙. 18/06/2024 21:45	6.41	6-1	1
1100	51 AAL 79-6502กทม	JT	ส่ง สิ้นค้า	๙.	18/06/2024 15:06	๙. 18/06/2024 15:57	0.51	6-1	2
1101	416 AAL ตะวี เจ๊ะหลี 190... 79-6733กทม	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 15:06	๙. 18/06/2024 21:50	6.43	6-1	1
1102	659 AAL 90HR801CY1710FOR2... 79-6735กทม	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 15:19	๙. 18/06/2024 21:54	6.35	6-1	1
1103	752 GT สิทธิประเสริฐ หน้... 72-3092สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 15:25	๙. 18/06/2024 15:57	0.32	6-1	2
1104	85 GT 71-7904สข	JETTY	ส่ง สิ้นค้า	๙.	18/06/2024 15:28	๙. 18/06/2024 17:18	1.50	6-1	2

IN-OUT Your company

IN ตั้งแต่ 01/06/2024@00:00 ถึง 28/06/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
2518	572 MPC 98-1460กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 14:37	พ.อ. 27/06/2024 15:27	0.50	6-1	2
2519	845 STK ณัฐนนท์ จันทะสกล... 3คณภ6495กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 14:38	พ.อ. 27/06/2024 15:29	0.51	6-1	2
2520	66 PSW อรุณิด เจ๊ะสา 391... 71-7564สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 14:43	พ.อ. 27/06/2024 18:55	4.13	6-1	2
2521	542 GT นรินทร์ อินทสระ 59... 71-5727สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 14:45	พ.อ. 27/06/2024 15:26	0.41	6-1	2
2522	785 OK 82-8938สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 14:52	พ.อ. 27/06/2024 16:54	2.02	6-1	1
2523	744 AAL ณัฐภัทร คำปล้อง 1... 79-6503กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:00	พ.อ. 27/06/2024 21:05	6.05	6-1	2
2524	88 GT 72-3096สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:01	พ.อ. 27/06/2024 16:54	1.54	6-1	1
2525	574 AAL 79-6731กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:04	พ.อ. 27/06/2024 21:21	6.16	6-1	2
2526	522 AAL 90HR801CY1710FOR2... 79-6735กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:05	พ.อ. 27/06/2024 20:52	5.47	6-1	2
2527	69 GTE ถิตดาเร็ด ดินเคบ ... 79-3984กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:06	พ.อ. 27/06/2024 17:15	2.09	6-1	1
2528	57 AAL 79-6502กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:12	พ.อ. 27/06/2024 20:51	5.40	6-1	2
2529	64 BOA ปราโมทย์ แก้วผณี ... ขฉ-1570สข	JT	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:15	พ.อ. 27/06/2024 18:59	3.45	6-1	3
2530	111 MM 71-4432สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:27	พ.อ. 27/06/2024 21:43	6.17	6-1	2
2531	56 BP 70-6909กม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:35	พ.อ. 27/06/2024 16:54	1.19	6-1	1
2532	14 BP 82-1646สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:35	พ.อ. 27/06/2024 16:54	1.19	6-1	1
2533	95 EFC IT 639-828คพ	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:42	พ.อ. 27/06/2024 23:15	7.33	6-1	0
2534	552 TXP ชชาติ จันทะรัง ... 71-7598สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:43	พ.อ. 27/06/2024 16:56	1.13	6-1	1
2535	67 STP ยงยุทธ พิมพ์พะระโร ... 71-8571สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 15:45	พ.อ. 27/06/2024 17:41	1.56	6-1	2
2536	800 AAL 79-6735กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:09	พ.อ. 27/06/2024 21:20	5.12	6-1	2
2537	411 SM รณกร ไชยมะรัง 3900... พท2238สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:17	พ.อ. 27/06/2024 18:56	2.39	6-1	2
2538	65 DAL 68-0707กทม	JT	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:22	พ.อ. 27/06/2024 16:56	0.34	6-1	1
2539	536 SAP 71-8797สข	JT	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:33	พ.อ. 27/06/2024 16:56	0.23	6-1	1
2540	5C OPF พท-6859สข	JT	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:40	พ.อ. 27/06/2024 17:41	1.01	6-1	2
2541	73 SAP 71-8839สข	JT	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:40	พ.อ. 27/06/2024 20:56	4.15	6-1	2
2542	551 GT 71-8704สข	JT	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:43	พ.อ. 27/06/2024 20:51	4.08	6-1	2
2543	693 OPF นราธร หริณยาหาว 1... 82-4246สข	JETTY	ส่ง สิ้นค้า	พ.อ. 27/06/2024 16:53	พ.อ. 27/06/2024 17:28	0.35	6-1	2
2544	88 AAL ชัยวิจิตร รัตนพันธ์... 78-0974กทม	JETTY	รับ สิ้นค้า	พ.อ. 27/06/2024 16:59	พ.อ. 27/06/2024 20:54	3.55	6-1	2

IN-OUT Your company


IN ตั้งแต่ 01/06/2024@00:00 ถึง 28/06/2024@23:59

ลำดับ #	รายละเอียด Details	ผู้เข้าชม Guest of	ประเภท Type	เข้า/ไป IN	ออก/กลับ OUT	รวม h.mm	ประตู Gate	
2693	985 AAL 64-2294กทม	JETTY	ส่ง สิ้นค้า	พ.อ. 28/06/2024 15:00		0.00	6-?	1

สรุป

Visitor ที่เข้ามา	2,693
กลับไปแล้ว	2,457
ยังไม่กลับ	236
อยู่สั้นสุด (h.mm)	0.00
อยู่นานสุด (h.mm)	44.46
เฉลี่ย (h.mm)	2.46

Visitor by type



ติดคองงาน = 7
ผู้รับเหมา = 17
รับ สิ้นค้า = 577
วางบิล = 19
ส่ง สิ้นค้า = 2073

ภาคผนวก ข-18

บันทึกปริมาณการนำเรือเข้า-ออกร่องน้ำ

Vessel Port Call Year 2024

Month / 2023	PSB Berth 1-5 (Asset & CPOC & Other)	PSB Berth 6 (Chevron only)	Total PSB Berth 1-6
January	164	25	189
February	164	26	190
March	180	28	208
April	178	23	201
May	170	19	189
June	180	23	203

ภาคผนวก ข-19


เอกสารการขนส่งกากของเสียไปกำจัด

สรุปรายการนำส่งของเสียไปกำจัด
ระหว่างมกราคม-มิถุนายน พ.ศ. 2567

PSB Asset												
Weight of full blue and red rubbish skips report for 01-31 January 2024												
Line	Date	Location	DAN#No	QTY	Win No	Blue	เลขที่ใบรับ	Win No	Red	เลขที่ใบรับ	UWM	Remark
1	01/01/24	JETTY	2023120352	1	-	80715	530	0068327	-	-	07349	PSB JETTY
2	01/01/24	JETTY	2023120352	1	-	AT00029	420	0068328	-	-	07349	PSB JETTY
3	04/01/24	JETTY	2024010042	1	-	80951	490	0068458	-	-	07449	PSB JETTY
4	04/01/24	JETTY	2024010041	1	-	27134	790	0068461	-	-	07451	PSB JETTY
5	04/01/24	JETTY	2024010041	1	-	80739	370	0068462	-	-	07451	PSB JETTY
6	08/01/24	JETTY	2024010079	1	-	10426	500	0068564	-	-	06784	PSB JETTY
7	11/01/24	CANTEEN	2024010124	1	-	10427	460	0068716	-	-	06916	CANTEEN
8	11/01/24	CANTEEN	2024010132	1	-	80426	520	0068717	-	-	06916	CANTEEN
9	11/01/24	JETTY	2024010123	1	-	26201	340	0068737	-	-	06923	PSB JETTY
10	11/01/24	JETTY	2024010123	1	-	32615	540	0068739	-	-	06922	PSB JETTY
11	11/01/24	JETTY	2024010123	1	-	23026	570	0068740	-	-	06922	PSB JETTY
12	11/01/24	JETTY	2024010123	1	-	AT00029	460	0068741	-	-	06922	PSB JETTY
13	15/01/24	CANTEEN	2024010173	1	-	26031	340	0068872	-	-	07035	CANTEEN
14	18/01/24	CANTEEN	2024010198	1	-	20891	430	0068958	-	-	07140	CANTEEN
15	18/01/24	JETTY	2024010189	1	-	AT10363	590	0068961	-	-	07144	PSB JETTY
16	18/01/24	JETTY	2024010189	1	-	AT00029	940	0068962	-	-	07144	PSB JETTY
17	18/01/24	JETTY	2024010189	1	-	27134	370	0068963	-	-	07144	PSB JETTY
18	18/01/24	JETTY	2024010189	1	-	80739	400	0068966	-	-	07145	PSB JETTY
19	18/01/24	JETTY	2024010189	1	-	80933	470	0068965	-	-	07145	PSB JETTY
20	18/01/24	JETTY	2024010189	1	-	80951	390	0068964	-	-	07145	PSB JETTY
21	23/01/24	JETTY	2024010257	1	-	23026	440	0069146	-	-	06555	PSB JETTY
22	24/01/24	JETTY	2024010272	1	-	AT10363	490	0069203	-	-	06595	PSB JETTY
23	25/01/24	CANTEEN	2024010308	1	-	AT10430	540	0069218	-	-	06627	CANTEEN
24	25/01/24	JETTY	2024010307	1	-	80933	470	0069243	-	-	06655	PSB JETTY
25	25/01/24	JETTY	2024010307	1	-	80715	560	0069242	-	-	06655	PSB JETTY
26	27/01/24	JETTY	2024010316	1	-	20891	400	0069289	-	-	06697	PSB JETTY
27	27/01/24	JETTY	2024010316	1	-	10427	530	0069290	-	-	06697	PSB JETTY
29	27/01/24	JETTY	2024010316	1	-	26031	450	0069335	-	-	06697	PSB JETTY
30	29/01/24	PSB Heliport	2024010330	1	-	WMS-039	232	N/A	-	-	06748	PSB Heliport
31	29/01/24	PSB Heliport	2024010330	1	-	WMS-025	201	N/A	-	-	06748	PSB Heliport
32	30/01/24	JETTY	2024010336	1	-	18559	500	0069345	-	-	06046	PSB JETTY
32	30/01/24	JETTY	2024010336	1	-	27134	530	0069346	-	-	06046	PSB JETTY
34	30/01/24	JETTY	2024010336	1	-	AT16438	540	0069347	-	-	06046	PSB JETTY
35	31/01/24	CANTEEN	2024010362	1	-	23026	460	0069408	-	-	06084	CANTEEN
36	-	-	-	-	-	-	-	-	-	-	-	-
37	-	-	-	-	-	-	-	-	-	-	-	-
38	-	-	-	-	-	-	-	-	-	-	-	-
39	-	-	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-	-	-
41	-	-	-	-	-	-	-	-	-	-	-	-
42	-	-	-	-	-	-	-	-	-	-	-	-
43	-	-	-	-	-	-	-	-	-	-	-	-
44	-	-	-	-	-	-	-	-	-	-	-	-
45	-	-	-	-	-	-	-	-	-	-	-	-
Total				34	0		16,263		0			

Checked and Reporter By: 

PSB Asset												
Weight of full blue and red rubbish skips report for 01-29 February 2024												
Line	Date	Location	DAN#No	QTY	Win No	Blue	เลขที่ใบรับ	Win No	Red	เลขที่ใบรับ	UWM	Remark
1	03/02/24	JETTY	2024020032	1	-	32615	500	0069496	-	-	06156	PSB JETTY
2	03/02/24	JETTY	2024020032	1	-	AT00029	540	0069495	-	-	06156	PSB JETTY
3	03/02/24	JETTY	2024020032	1	-	AT16432	540	0069497	-	-	06156	PSB JETTY
4	05/02/24	CANTEEN	2024020060	1	-	20891	400	0069557	-	-	06187	CANTEEN
5	05/02/24	CANTEEN	2024020060	1	-	80271	490	0069554	-	-	06191	CANTEEN
6	07/02/24	JETTY	2024020068	1	-	20906	460	0069614	-	-	06243	PSB JETTY
7	07/02/24	JETTY	2024020068	1	-	27134	440	0069613	-	-	06243	PSB JETTY
8	07/02/24	JETTY	2024020068	1	-	18559	460	0069415	-	-	06243	PSB JETTY
9	10/02/24	CANTEEN	2024020107	1	-	20894	340	0069722	-	-	06342	CANTEEN
10	13/02/24	JETTY	2024020120	1	-	20891	300	0069804	-	-	06443	PSB JETTY
11	13/02/24	JETTY	2024020120	1	-	32615	450	0069797	-	-	06447	PSB JETTY
12	13/02/24	JETTY	2024020120	1	-	AT16432	600	0069796	-	-	06447	PSB JETTY
13	13/02/24	JETTY	2024020120	1	-	AT00029	390	0069798	-	-	06447	PSB JETTY
14	16/02/24	CANTEEN	2024020160	1	-	26031	470	0069910	-	-	21294	CANTEEN
15	16/02/24	JETTY	2024020153	1	-	18558	390	0069907	-	-	21299	PSB JETTY
16	16/02/24	JETTY	2024020153	1	-	26201	370	0069908	-	-	21299	PSB JETTY
17	16/02/24	JETTY	2024020153	1	-	AT16438	620	0069906	-	-	21299	PSB JETTY
18	17/02/24	CANTEEN	2024020178	1	-	23026	320	0069950	-	-	21374	CANTEEN
19	19/02/24	FREE ZONE	2024020139	1	-	Wooden box	1,630	0069994	-	-	21388	FREE ZONE
20	19/02/24	FREE ZONE	2024020139	1	-	80939	660	0069993	-	-	21388	FREE ZONE
21	20/02/24	JETTY	2024020197	1	-	80927	450	0070084	-	-	21472	PSB JETTY
22	20/02/24	JETTY	2024020197	1	-	80951	680	0070083	-	-	21472	PSB JETTY
23	20/02/24	JETTY	2024020197	1	-	AT00029	650	0070082	-	-	21472	PSB JETTY
24	20/02/24	JETTY	2024020197	1	-	AT16432	440	0070077	-	-	21473	PSB JETTY
25	22/02/24	JETTY	2024020228	1	-	AT16456	560	0070142	-	-	21529	PSB JETTY
26	22/02/24	JETTY	2024020228	1	-	AT10363	490	0070138	-	-	21529	PSB JETTY
27	22/02/24	CANTEEN	2024020229	1	-	80721	380	0070131	-	-	21529	CANTEEN
28	23/02/24	JETTY	2024020236	1	-	23026	600	0070173	-	-	21583	PSB JETTY
29	23/02/24	JETTY	2024020236	1	-	AT16450	390	0070172	-	-	21583	PSB JETTY
30	28/02/24	CANTEEN	2024020297	1	-	10426	470	0070300	-	-	09262	CANTEEN
31	28/02/24	JETTY	2024020286	1	-	80426	480	0070305	-	-	09264	PSB JETTY
32	28/02/24	JETTY	2024020286	1	-	18559	950	0070304	-	-	09264	PSB JETTY
33	-	-	-	-	-	-	-	-	-	-	-	-
34	-	-	-	-	-	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-	-	-
36	-	-	-	-	-	-	-	-	-	-	-	-
37	-	-	-	-	-	-	-	-	-	-	-	-
38	-	-	-	-	-	-	-	-	-	-	-	-
39	-	-	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-	-	-
41	-	-	-	-	-	-	-	-	-	-	-	-
42	-	-	-	-	-	-	-	-	-	-	-	-
43	-	-	-	-	-	-	-	-	-	-	-	-
Total				32	0		16,910		-			

Checked and Reporter By: 

PSB Asset												
Weight of full blue and red rubbish skips report for 01-31 March 2024												
Line	Date	Location	DAN#No	QTY	Win No	Blue	เลขที่ใบรับ	Win No	Red	เลขที่ใบรับ	UWM	Remark
1	01/03/24	SKL Heliport	2024030002	1	-	WMS-032	170	N/A	-	-	09298	SKL Heliport
2	01/03/24	SKL Heliport	2024030002	1	-	WMS-038	165	N/A	-	-	09298	SKL Heliport
3	03/03/24	JETTY	2024030006	1	-	80927	410	0070457	-	-	09427	PSB JETTY
4	03/03/24	JETTY	2024030006	1	-	80733	480	0070458	-	-	09427	PSB JETTY
5	03/03/24	JETTY	2024030006	1	-	AT16450	430	0070459	-	-	09427	PSB JETTY
6	04/03/24	CANTEEN	2024030049	1	-	80939	490	0070505	-	-	09473	CANTEEN
7	07/03/24	JETTY	2024030068	1	-	26201	420	0070633	-	-	09090	PSB JETTY
8	07/03/24	JETTY	2024030068	1	-	AT10361	540	0070634	-	-	09090	PSB JETTY
9	07/03/24	JETTY	2024030068	1	-	AT16432	450	0070632	-	-	09090	PSB JETTY
10	09/03/24	JETTY	2024030075	1	-	80945	560	0070664	-	-	09122	PSB JETTY
11	11/03/24	JETTY	2024030116	1	-	80933	570	0070757	-	-	09177	PSB JETTY
12	11/03/24	JETTY	2024030116	1	-	80951	550	0070758	-	-	09177	PSB JETTY
13	13/03/24	CANTEEN	2024030144	1	-	18560	550	0070810	-	-	25762	CANTEEN
14	13/03/24	CANTEEN	2024030144	1	-	20894	580	0070825	-	-	25769	CANTEEN
15	13/03/24	JETTY	2024030142	1	-	80939	420	0070808	-	-	25765	PSB JETTY
16	13/03/24	JETTY	2024030142	1	-	AT10428	360	0070809	-	-	25765	PSB JETTY
17	13/03/24	JETTY	2024030142	1	-	AT16456	450	0070807	-	-	25765	PSB JETTY
18	15/03/24	JETTY	2024030162	1	-	AT16450	630	0070945	-	-	25865	PSB JETTY
19	18/03/24	CANTEEN	2024030197	1	-	26201	380	0071027	-	-	25922	CANTEEN
20	19/03/24	JETTY	2024030210	1	-	AT10428	390	0071041	-	-	25940	PSB JETTY
21	19/03/24	JETTY	2024030210	1	-	AT16456	400	0071042	-	-	25940	PSB JETTY
22	19/03/24	JETTY	2024030210	1	-	80945	400	0071043	-	-	25940	PSB JETTY
23	19/03/24	JETTY	2024030210	1	-	80721	420	0071044	-	-	25941	PSB JETTY
24	19/03/24	JETTY	2024030210	1	-	18558	290	0071045	-	-	25941	PSB JETTY
25	21/03/24	JETTY	2024030232	1	-	80927	370	0071131	-	-	25533	PSB JETTY
26	21/03/24	JETTY	2024030232	1	-	80939	490	0071132	-	-	25533	PSB JETTY
27	25/03/24	JETTY	2024030289	1	-	80271	560	0071292	-	-	25691	PSB JETTY
28	25/03/24	JETTY	2024030289	1	-	80721	480	0071257	-	-	25633	PSB JETTY
29	25/03/24	JETTY	2024030304	1	-	AT16456	420	0071287	-	-	25700	PSB JETTY
30	26/03/24	CANTEEN	2024030312	1	-	20906	330	0071320	-	-	25724	CANTEEN
31	28/03/24	CANTEEN	2024030338	1	-	20894	460	0071387	-	-	25088	CANTEEN
32	30/03/24	JETTY	2024030358	1	-	AT16450	500	0071441	-	-	25154	PSB JETTY
33	30/03/24	JETTY	2024030358	1	-	80939	430	0071442	-	-	25154	PSB JETTY
34	31/03/24	JETTY	2024030368	1	-	26201	730	0071479	-	-	25163	PSB JETTY
35	31/03/24	JETTY	2024030368	1	-	80927	620	0071480	-	-	25163	PSB JETTY
36	31/03/24	JETTY	2024030368	1	-	AT10428	590	0071478	-	-	25163	PSB JETTY
37	-	-	-	-	-	-	-	-	-	-	-	-
38	-	-	-	-	-	-	-	-	-	-	-	-
39	-	-	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-	-	-
41	-	-	-	-	-	-	-	-	-	-	-	-
42	-	-	-	-	-	-	-	-	-	-	-	-
43	-	-	-	-	-	-	-	-	-	-	-	-
44	-	-	-	-	-	-	-	-	-	-	-	-
45	-	-	-	-	-	-	-	-	-	-	-	-
Total				36	0		16,485		0			

Checked and Reportor By:

PSB Asset												
Weight of full blue and red rubbish skips report for 01-30 April 2024												
Line	Date	Location	DAN#No	QTY	Win No	Blue	เลขที่ใบรับ	Win No	Red	เลขที่ใบรับ	UWM	Remark
1	03/04/24	CANTEEN	2024040047	1	-	18559	190	0071583	-	-	25291	CANTEEN
2	04/04/24	JETTY	2024040057	1	-	18558	500	0071613	-	-	25314	PSB JETTY
3	04/04/24	JETTY	2024040057	1	-	23027	640	0071615	-	-	25314	PSB JETTY
4	04/04/24	JETTY	2024040057	1	-	10427	520	0071614	-	-	25314	PSB JETTY
5	06/04/24	JETTY	2024040070	1	-	20971	410	0071686	-	-	25394	PSB JETTY
6	06/04/24	JETTY	2024040070	1	-	26031	440	0071687	-	-	25394	PSB JETTY
7	08/04/24	CANTEEN	2024040085	1	-	80271	420	0071713	-	-	25438	CANTEEN
8	10/04/24	JETTY	2024040101	1	-	80945	310	0071813	-	-	16286	PSB JETTY
9	10/04/24	JETTY	2024040101	1	-	AT10363	610	0071814	-	-	16286	PSB JETTY
10	10/04/24	JETTY	2024040101	1	-	AT16438	460	0071812	-	-	16286	PSB JETTY
11	11/04/24	JETTY	2024040126	1	-	80933	440	0071854	-	-	16315	PSB JETTY
12	11/04/24	JETTY	2024040126	1	-	AT10428	310	0071852	-	-	16315	PSB JETTY
13	12/04/24	CANTEEN	2024040132	1	-	AT16450	400	0071873	-	-	16330	CANTEEN
14	13/04/24	CANTEEN	2024040146	1	-	23027	450	0071901	-	-	16344	CANTEEN
15	13/04/24	JETTY	2024040142	1	-	18558	200	0071920	-	-	16348	PSB JETTY
16	13/04/24	JETTY	2024040142	1	-	10427	440	0071921	-	-	16348	PSB JETTY
17	16/04/24	JETTY	2024040175	1	-	80927	750	0072032	-	-	16432	PSB JETTY
18	16/04/24	JETTY	2024040179	1	-	18559	440	0072030	-	-	16432	PSB JETTY
19	20/04/24	JETTY	2024040212	1	-	80945	400	0072191	-	-	19790	PSB JETTY
20	20/04/24	JETTY	2024040212	1	-	80933	440	0072192	-	-	19790	PSB JETTY
21	21/04/24	JETTY	2024040218	1	-	26201	390	0072226	-	-	19829	PSB JETTY
22	22/04/24	CANTEEN	2024040238	1	-	AT10363	440	002246	-	-	07326	CANTEEN
23	23/04/24	FREE ZONE	2024040242	1	-	AT00029	590	0072307	-	-	19900	FREE ZONE
24	23/04/24	JETTY	2024040271	1	-	18558	480	0072335	-	-	19928	PSB JETTY
25	25/04/24	JETTY	2024040278	1	-	10427	460	0072410	-	-	19979	PSB JETTY
26	26/04/24	JETTY	2024040284	1	-	23027	580	0072449	-	-	20019	PSB JETTY
27	26/04/24	CANTEEN	2024040307	1	-	26201	440	0072448	-	-	20019	CANTEEN
28	26/04/24	CANTEEN	2024040307	1	-	32615	150	0072450	-	-	20019	CANTEEN
29	30/04/24	JETTY	2024040372	1	-	80426	570	0072573	-	-	20125	PSB JETTY
30	30/04/24	JETTY	2024040372	1	-	18560	630	0072572	-	-	20125	PSB JETTY
31	30/04/24	JETTY	2024040372	1	-	80933	460	0072574	-	-	20125	PSB JETTY
32	30/04/24	JETTY	2024040372	1	-	80945	530	0072582	-	-	20126	PSB JETTY
33	-	-	-	-	-	-	-	-	-	-	-	-
34	-	-	-	-	-	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-	-	-
36	-	-	-	-	-	-	-	-	-	-	-	-
37	-	-	-	-	-	-	-	-	-	-	-	-
38	-	-	-	-	-	-	-	-	-	-	-	-
39	-	-	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-	-	-
41	-	-	-	-	-	-	-	-	-	-	-	-
42	-	-	-	-	-	-	-	-	-	-	-	-
43	-	-	-	-	-	-	-	-	-	-	-	-
Total				32	0		14,490		0			


Checked and Reportor By:

PSB Asset												
Weight of full blue and red rubbish skips report for 01-31 May 2024												
Line	Date	Location	DAN#No	QTY	Win No	Blue	เลขที่ใบรับ	Win No	Red	เลขที่ใบรับ	UWM	Remark
1	07/05/24	CANTEEN	2024050039	1	-	18558	500	0072821	-	-	20355	CANTEEN
2	07/05/24	JETTY	2024050040	1	-	80271	320	0072818	-	-	20367	PSB JETTY
3	07/05/24	JETTY	2024050040	1	-	20894	540	0072817	-	-	20367	PSB JETTY
4	07/05/24	JETTY	2024050040	1	-	20891	660	0072816	-	-	20367	PSB JETTY
5	07/05/24	JETTY	2024050040	1	-	AT10360	740	0072826	-	-	20368	PSB JETTY
6	07/05/24	JETTY	2024050040	1	-	AT10430	400	0072825	-	-	20368	PSB JETTY
7	05/09/24	SKL Heliport	2024050086	1	-	WMS-032	148	N/A	-	-	20406	SKL Heliport
8	05/09/24	SKL Heliport	2024050086	1	-	WMS-038	168	N/A	-	-	20406	SKL Heliport
9	11/05/24	JETTY	2024050094	1	-	AT16456	530	0072998	-	-	23758	PSB JETTY
10	11/05/24	JETTY	2024050094	1	-	80933	440	0072997	-	-	23758	PSB JETTY
11	14/05/24	JETTY	2024050150	1	-	20894	510	0073100	-	-	23820	PSB JETTY
12	14/05/24	JETTY	2024050150	1	-	27135	390	0073099	-	-	23820	PSB JETTY
13	14/05/24	JETTY	2024050150	1	-	AT16450	380	0073098	-	-	23820	PSB JETTY
14	15/05/24	CANTEEN	2024050186	1	-	18558	460	0073146	-	-	23875	CANTEEN
15	16/05/24	CANTEEN	2024050191	1	-	AT00029	660	0073159	-	-	23912	CANTEEN
16	17/05/24	JETTY	2024050197	1	-	23031	470	0073230	-	-	23942	PSB JETTY
17	17/05/24	JETTY	2024050197	1	-	20971	500	0073231	-	-	23942	PSB JETTY
18	18/05/24	JETTY	2024050200	1	-	20906	440	0073256	-	-	23972	PSB JETTY
19	21/05/24	CANTEEN	2024050225	1	-	80939	560	0073379	-	-	24103	CANTEEN
20	22/05/24	JETTY	2024050224	1	-	80271	490	0073413	-	-	24131	PSB JETTY
21	22/05/24	JETTY	2024050230	1	-	26201	400	0073426	-	-	24138	PSB JETTY
22	23/05/24	FREE ZONE	2024050189	1	-	80927	500	0073444	-	-	24151	FREE ZONE
23	23/05/24	FREE ZONE	2024050189	1	-	Wooden box	1,490	0073443	-	-	24151	FREE ZONE
24	23/05/24	JETTY	2024050230	1	-	23031	400	0073447	-	-	24160	PSB JETTY
25	26/05/24	JETTY	2024050263	1	-	20971	660	0073544	-	-	09419	PSB JETTY
26	26/05/24	JETTY	2024050263	1	-	10426	550	0073543	-	-	09419	PSB JETTY
27	26/05/24	JETTY	2024050263	1	-	AT10360	520	0073542	-	-	09419	PSB JETTY
28	29/05/24	JETTY	2024050314	1	-	18562	670	0073662	-	-	28284	PSB JETTY
29	29/05/24	JETTY	2024050314	1	-	27135	460	0073663	-	-	28284	PSB JETTY
30	29/05/24	JETTY	2024050314	1	-	80927	420	0073664	-	-	28284	PSB JETTY
31	29/05/24	JETTY	2024050314	1	-	20894	520	0073692	-	-	28294	PSB JETTY
32	-	-	-	-	-	-	-	-	-	-	-	-
33	-	-	-	-	-	-	-	-	-	-	-	-
34	-	-	-	-	-	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-	-	-
36	-	-	-	-	-	-	-	-	-	-	-	-
37	-	-	-	-	-	-	-	-	-	-	-	-
38	-	-	-	-	-	-	-	-	-	-	-	-
39	-	-	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-	-	-
41	-	-	-	-	-	-	-	-	-	-	-	-
42	-	-	-	-	-	-	-	-	-	-	-	-
43	-	-	-	-	-	-	-	-	-	-	-	-
Total				31	0		15,896		0			

Checked and Reportor By: _____

PSB Asset												
Weight of full blue and red rubbish skips report for 01-30 June 2024												
Line	Date	Location	DAN#No	QTY	Win No	Blue	เลขที่ใบรับ	Win No	Red	เลขที่ใบรับ	UWM	Remark
1	01/06/24	JETTY	2024050341	1	-	AT10360	680	0073767	-	-	28407	PSB JETTY
2	01/06/24	JETTY	2024050341	1	-	80739	510	0073768	-	-	28407	PSB JETTY
3	01/06/24	JETTY	2024050341	1	-	23031	470	0073766	-	-	28407	PSB JETTY
4	01/06/24	JETTY	2024050341	1	-	80271	440	0073769	-	-	28408	PSB JETTY
5	01/06/24	CANTEEN	2024060002	1	-	AT00029	750	0073782	-	-	28414	CANTEEN
6	05/06/24	JETTY	2024060031	1	-	18562	310	0073902	-	-	28502	PSB JETTY
7	05/06/24	JETTY	2024060031	1	-	80939	630	0073899	-	-	28505	PSB JETTY
8	05/06/24	JETTY	2024060031	1	-	27135	590	0073900	-	-	28505	PSB JETTY
9	05/06/24	JETTY	2024060031	1	-	AT10363	600	0073901	-	-	28505	PSB JETTY
10	07/06/24	JETTY	2024060085	1	-	80927	560	0073958	-	-	28619	PSB JETTY
11	07/06/24	CANTEEN	2024060121	1	-	20894	350	0073990	-	-	28643	CANTEEN
12	08/06/24	CANTEEN	2024060124	1	-	AT16450	360	0074016	-	-	28643	CANTEEN
13	09/06/24	JETTY	2024060126	1	-	AT16456	460	0074035	-	-	28657	PSB JETTY
14	11/06/24	SKL Heliport	2024060153	1	-	WMS-025	234	N/A	-	-	28712	SKL Heliport
15	11/06/24	SKL Heliport	2024060153	1	-	WMS-039	184	N/A	-	-	28712	SKL Heliport
16	12/06/24	JETTY	2024060154	1	-	80970	770	0074165	-	-	28752	PSB JETTY
17	12/06/24	JETTY	2024060154	1	-	18562	400	0074166	-	-	28752	PSB JETTY
18	12/06/24	JETTY	2024060154	1	-	80721	430	0074167	-	-	28752	PSB JETTY
19	12/06/24	JETTY	2024060154	1	-	AT16432	690	0074153	-	-	28753	PSB JETTY
20	12/06/24	JETTY	2024060154	1	-	AT10363	530	0074154	-	-	28753	PSB JETTY
21	12/06/24	CANTEEN	2024060155	1	-	32615	340	0074152	-	-	28753	CANTEEN
22	15/06/24	JETTY	2024060171	1	-	27135	330	0074296	-	-	28858	PSB JETTY
23	15/06/24	JETTY	2024060171	1	-	23026	470	0074293	-	-	28868	PSB JETTY
24	17/06/24	CANTEEN	2024060182	1	-	80927	370	0074341	-	-	28905	CANTEEN
25	18/06/24	JETTY	2024060185	1	-	AT10430	210	2024-07	-	-	28928	PSB JETTY
26	18/06/24	JETTY	2024060185	1	-	AT16432	390	2024-09	-	-	28928	PSB JETTY
27	18/06/24	JETTY	2024060185	1	-	AT16450	340	2024-08	-	-	28928	PSB JETTY
28	21/06/24	JETTY	2024060237	1	-	18559	340	2024-06	-	-	28991	PSB JETTY
29	21/06/24	JETTY	2024060237	1	-	AT16456	760	2024-05	-	-	28991	PSB JETTY
30	23/06/24	SKL PIPE	2024060256	1	-	18558	710	0061913	-	-	31284	SKL PIPE
31	23/06/24	SKL PIPE	2024060256	1	-	23072	530	0061912	-	-	31284	SKL PIPE
32	24/06/24	CANTEEN	2024060270	1	-	80970	580	2024-10	-	-	31294	CANTEEN
33	25/06/24	SKL PIPE	2024060271	1	-	Wooden	4,750	0061968	-	-	31312	SKL PIPE
34	25/06/24	SKL PIPE	2024060271	1	-	Wooden	5,290	0061967	-	-	31313	SKL PIPE
35	25/06/24	SKL PIPE	2024060271	1	-	Wooden	4,570	0061966	-	-	31314	SKL PIPE
36	25/06/24	SKL PIPE	2024060271	1	-	Wooden	3,240	0062009	-	-	31357	SKL PIPE
37	25/06/24	JETTY	2024060275	1	-	AT10360	620	0062002	-	-	31351	PSB JETTY
38	25/06/24	JETTY	2024060275	1	-	AT10428	440	0062001	-	-	31351	PSB JETTY
39	27/06/24	JETTY	2024060351	1	-	20894	610	0062108	-	-	31441	PSB JETTY
40	27/06/24	JETTY	2024060351	1	-	27134	410	0062109	-	-	31441	PSB JETTY
41	27/06/24	SKL PIPE	2024060330	1	-	80951	720	0062112	-	-	31443	SKL PIPE
42	27/06/24	SKL PIPE	2024060330	1	-	AT10430	950	0062111	-	-	31443	SKL PIPE
43	28/06/24	JETTY	2024060375	1	-	80721	500	0062126	-	-	31455	PSB JETTY
44	28/06/24	JETTY	2024060375	1	-	AT16456	460	0062127	-	-	31455	PSB JETTY
45	28/06/24	SKL PIPE	2024060347	1	-	23027	1,040	0062140	-	-	31457	SKL PIPE
46	28/06/24	SKL PIPE	2024060347	1	-	80970	1,070	0062143	-	-	31461	SKL PIPE
47	29/06/24	SKL PIPE	2024060372	1	-	BS00602	80	0062278	-	-	31477	SKL PIPE

ตัวอย่างเอกสารกำกับการขนส่งของเสีย
(Manifest Form)



222 หมู่ 1 ต.หัวเขา อ.สิงหนคร จ.สงขลา 90280

ใบชั่งน้ำหนัก

เลขที่ใบสั่ง : 0068442

วันที่ : 04/01/2024

ขยะทั่วไป : Genaral waste

ชนิดสินค้านี้ : General waste

ชื่อผู้ส่ง :WMS company

รายการ	ลำดับ	วันที่	เวลา	น้ำหนัก(กก.)
รถเข้า >>>	32215	04/01/2024	10:42:24	8,240
<<< รถออก	23401	04/01/2024	10:47:07	7,590
หมายเหตุ: 2023120341, (PSB)			น้ำหนักสุทธิ	650

หมายเลข: 2023120341, (PSB)

พนักงานซึ่ง

พนักงานขับรถ



(Only Apply for Transportation Under PTTEP Operation)

No: 2023120341

Date: 29/12/2023

Section 1: Waste Generation

[illegible]

Section 2: Waste Transportation Under PTTEP Operation

Source to Transportation Vehicle (Vessel, Truck)

Waste Owner's or
Representative's Signature:

I certify that the wastes are classified, packaged, marked and labeled and in all respect in proper condition for transportation according to Waste Management Plan and best practices.

PSB Waste and Scrap

Received By :

Received Date : 02/01/21

I certify that all wastes have been transferred onto

Vessel	Month
1	1
2	2
3	3
4	4
5	5
6	6
7	7
8	8
9	9
10	10
11	11
12	12

Norms

Track	Registration no.
-------	------------------

Date: / /

Transportation Vehicle to Transit or Temporary Storage Area or Contractor Facility

Transporter's Signature: _____

I certify that the above mentioned wastes have been unloaded from the truck / vessel to

Name: _____

(Identify transit or temporary storage's name) _____

Date: ____/____/____

I certify that the above mentioned wastes have been properly

Transit or Temporary Storage's

Representative's Signature: _____

☐ stored at PTTEP temporary storage area (No. of wastes in section 1) _____

Name: _____

☐ Delivered to contractor facility (No. of wastes in section 1) _____

Date: / /



Reference D5 – 1 แบบตรวจการขนส่งของเสียอันตราย

[illegible]

Revision No: 02

UNCONTROLLED when printed.

Visit PSB SSHE Center for latest version.



Non and Hazardous waste

DAN#

N & H

06.3/2024

Date : 10 January 2024

ART Asset

G2N Asset

G2S Asset

G1 Asset

X

PSB Asset

Maintenance WS

SKL IT

Heliport SKL

PTT PRP

BKT PTT REP

CPOC

[illegible]

หมายเลขใบกำกับการขนส่งของเสีย: Manifest No.

06902

1. ส่วนของผู้ก่อมลพิษของเสีย: This section must be completed by the Generator

1) ชื่อ: Name 2) เลขประจำตัวผู้ก่อมลพิษของเสีย: Generator's ID

สถานที่ตั้ง: Generator's address โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency

1) ผู้ขนส่งของเสีย: Transporter 2) เลขประจำตัวผู้ขนส่งของเสีย: Transporter's ID

บริษัทที่ 1: The first company name เลขประจำตัวผู้ขนส่งของเสีย: Transporter's ID

บริษัทที่ 2: The second company name เลขประจำตัวผู้ขนส่งของเสีย: Transporter's ID

1) ผู้เก็บรวบรวม บำบัด และกำจัดของเสีย: Treatment Storage Disposal Facilities (TSDFs)

บริษัทที่ 1: First TSDF's company name เลขประจำตัวผู้เก็บรวบรวม บำบัด และกำจัดของเสีย: Disposer's ID

บริษัทที่ 2: Second TSDF's company name เลขประจำตัวผู้เก็บรวบรวม บำบัด และกำจัดของเสีย: Disposer's ID

รายละเอียดของของเสียที่ขนส่ง

ลำดับ No.	รายละเอียด Description	รหัสของของเสีย Waste profile no.	รหัสที่ผู้ขนส่ง Waste ID	ลักษณะของเสีย อันตราย Hazardous	ลักษณะของเสีย ไม่อันตราย Nonhazardous	จำนวน: No.	ชนิด: Type	ปริมาณสุทธิ: Quantity	หน่วยน้ำหนัก: Unit Wt / Vol	รายละเอียดเพิ่มเติม: Additional Information
1	Contaminated	HW1200	191211	X		1	Unit		PSB IT	
2	Contaminated material waste					1 box	Electronic waste			
3						1 bag	Printer cartridge			
4						2 EA	Lead battery			

รวมปริมาณของเสียทั้งหมด: Total Quantity ของเหลว: Liquid ☐ ลิตร: Liters ☐ ลูกบาศก์เมตร: cu.m ของแข็ง: Solid ☐ กิโลกรัม: Kgs. ☐ ตัน: Tons

การปฏิบัติที่ผู้ขนส่งของเสียต้องปฏิบัติตาม

Special Handling Instructions and additional information

คำรับรอง: ข้าพเจ้าขอรับรองว่าข้อมูลของเสียที่ระบุข้างต้น และมีการบรรจุติดป้ายหรือติดฉลากอย่างเหมาะสมตามที่กำหนดของกฎหมายทุกประการ:

Generator Certification: I hereby declare that the contents of this assignment are accurately described above and have been packed and labeled and are in the proper condition for transport according to regulations

ชื่อ: Generator's name ลายเซ็น: Signature วันที่: Date 10 เดือน: Month 1 พ.ศ.: Year 24

2. ส่วนของผู้ขนส่งของเสีย: This section must be completed by the Transporter

1) ชื่อผู้ขนส่งของเสีย: The first Transporter's name 2) พาหนะที่ใช้: ☒ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

เลขประจำตัวผู้ขนส่ง: Transporter's ID ☐ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency 3) เลขทะเบียนพาหนะ: Vehicle ID 92-7337 W 72-3443 W

คำรับรอง: ข้าพเจ้าขอรับรองว่าได้รับของเสียแล้วตามที่ระบุข้างต้น และมีการขนส่งเป็นไปตามข้อกำหนดของกฎหมายทุกประการ

Transporter Certification: I hereby declare that I have received the type and quantity of waste as described above by the generator and that waste has been transported according to regulations.

ออกใบส่งจากจังหวัด: From ไปยังจังหวัด: To ใช้ระยะเวลาประมาณ: Time spending ชม./วัน: Hours/Day

ชื่อผู้ขนส่งของเสีย: Transporter's name ลายเซ็น: Signature วันที่: Date 10 เดือน: Month 1 พ.ศ.: Year 24

1) ชื่อผู้ขนส่งของเสีย: The second transporter's name 6) พาหนะที่ใช้: ☐ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

เลขประจำตัวผู้ขนส่ง: Transporter's ID ☐ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency 7) เลขทะเบียนพาหนะ: Vehicle ID

คำรับรอง: ข้าพเจ้าขอรับรองว่าได้รับของเสียแล้วตามที่ระบุข้างต้น และมีการขนส่งเป็นไปตามข้อกำหนดของกฎหมายทุกประการ

Transporter Certification: I hereby declare that I have received the type and quantity of waste as described by the generator and that waste has been transported according to regulations.

ออกใบส่งจากจังหวัด: From ไปยังจังหวัด: To ใช้ระยะเวลาประมาณ: Time Spending ชม./วัน: Hours/Day

ชื่อผู้ขนส่งของเสีย: Transporter's Name ลายเซ็น: Signature วันที่: Date เดือน: Month พ.ศ.: Year

3. ส่วนของผู้ประกอบการบำบัดของเสีย: This section must be completed by TSDFs

1) ชื่อผู้รับกำจัด: TSDF's name 2) เลขประจำตัวผู้รับกำจัด: TSDF's ID

สถานที่ตั้ง: TSDF's address โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency

คำรับรอง: ข้าพเจ้าขอรับรองว่าได้รับของเสียแล้วตามที่ระบุข้างต้น TSDF certificate of arrival: I hereby declare that I have received the reference load.

สามารถกำจัดของเสียที่รับมาได้ในเวลา: Treatment period ☐ วัน: Day ☐ เดือน: Month ☐ ปี: Year นับจากวันที่ได้รับของเสีย: Since the day that received waste

ชื่อผู้รับกำจัด: TSDF's name ลายเซ็น: Signature วันที่: Date เดือน: Month พ.ศ.: Year

กรณีของเสียไม่ตรงตามที่แจ้ง: Discrepancy Notification

ประเภทของเสีย: Type of waste ปริมาณ: Quantity

การดำเนินการ: Action taken ☐ ส่งคืน: Returned ☐ จัดประเภทใหม่: Reclassified / รหัส: Waste ID วันที่กำจัด: Accepted (เหตุผล: Reason of action

วันที่ส่งคืน: Date returned (วันเดือนปี: dd / mm / yy) หมายเลขใบกำกับการขนส่งของเสียที่ส่งคืน: Returned manifest no

ลายเซ็น: TSDF's name ลายเซ็น: TSDF's name

หมายเลขใบกำกับการขนส่งของเสีย: Manifest No.

06901

1. ส่วนของผู้ก่อมลพิษของเสีย: This section must be completed by the Generator

1) ชื่อ: Name 2) เลขประจำตัวผู้ก่อมลพิษของเสีย: Generator's ID

สถานที่ตั้ง: Generator's address โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency

1) ผู้ขนส่งของเสีย: Transporter 2) เลขประจำตัวผู้ขนส่งของเสีย: Transporter's ID

บริษัทที่ 1: The first company name เลขประจำตัวผู้ขนส่งของเสีย: Transporter's ID

บริษัทที่ 2: The second company name เลขประจำตัวผู้ขนส่งของเสีย: Transporter's ID

1) ผู้เก็บรวบรวม บำบัด และกำจัดของเสีย: Treatment Storage Disposal Facilities (TSDFs)

บริษัทที่ 1: First TSDF's company name เลขประจำตัวผู้เก็บรวบรวม บำบัด และกำจัดของเสีย: Disposer's ID

บริษัทที่ 2: Second TSDF's company name เลขประจำตัวผู้เก็บรวบรวม บำบัด และกำจัดของเสีย: Disposer's ID

รายละเอียดของของเสียที่ขนส่ง

ลำดับ No.	รายละเอียด Description	รหัสของของเสีย Waste profile no.	รหัสที่ผู้ขนส่ง Waste ID	ลักษณะของเสีย อันตราย Hazardous	ลักษณะของเสีย ไม่อันตราย Nonhazardous	จำนวน: No.	ชนิด: Type	ปริมาณสุทธิ: Quantity	หน่วยน้ำหนัก: Unit Wt / Vol	รายละเอียดเพิ่มเติม: Additional Information
1	Commercial waste	900407	191213		X	1	Unit		PSB IT	
2	Commercial waste					2 D.	Cables			

รวมปริมาณของเสียทั้งหมด: Total Quantity ของเหลว: Liquid ☐ ลิตร: Liters ☐ ลูกบาศก์เมตร: cu.m ของแข็ง: Solid ☐ กิโลกรัม: Kgs. ☐ ตัน: Tons

การปฏิบัติที่ผู้ขนส่งของเสียต้องปฏิบัติตาม

Special Handling Instructions and additional information

คำรับรอง: ข้าพเจ้าขอรับรองว่าข้อมูลของเสียที่ระบุข้างต้น และมีการบรรจุติดป้ายหรือติดฉลากอย่างเหมาะสมตามที่กำหนดของกฎหมายทุกประการ:

Generator Certification: I hereby declare that the contents of this assignment are accurately described above and have been packed and labeled and are in the proper condition for transport according to regulations

ชื่อ: Generator's name ลายเซ็น: Signature วันที่: Date 10 เดือน: Month 1 พ.ศ.: Year 24

2. ส่วนของผู้ขนส่งของเสีย: This section must be completed by the Transporter

1) ชื่อผู้ขนส่งของเสีย: The first Transporter's name 2) พาหนะที่ใช้: ☒ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

เลขประจำตัวผู้ขนส่ง: Transporter's ID ☐ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency 3) เลขทะเบียนพาหนะ: Vehicle ID 92-7337 W 72-3443 W

คำรับรอง: ข้าพเจ้าขอรับรองว่าได้รับของเสียแล้วตามที่ระบุข้างต้น และมีการขนส่งเป็นไปตามข้อกำหนดของกฎหมายทุกประการ

Transporter Certification: I hereby declare that I have received the type and quantity of waste as described above by the generator and that waste has been transported according to regulations.

ออกใบส่งจากจังหวัด: From ไปยังจังหวัด: To ใช้ระยะเวลาประมาณ: Time spending ชม./วัน: Hours/Day

ชื่อผู้ขนส่งของเสีย: Transporter's name ลายเซ็น: Signature วันที่: Date 10 เดือน: Month 1 พ.ศ.: Year 24

1) ชื่อผู้ขนส่งของเสีย: The second transporter's name 6) พาหนะที่ใช้: ☐ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

เลขประจำตัวผู้ขนส่ง: Transporter's ID ☐ รถบรรทุก ☐ รถไฟ ☐ เรือ ☐ เครื่องบิน

โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency 7) เลขทะเบียนพาหนะ: Vehicle ID

คำรับรอง: ข้าพเจ้าขอรับรองว่าได้รับของเสียแล้วตามที่ระบุข้างต้น และมีการขนส่งเป็นไปตามข้อกำหนดของกฎหมายทุกประการ

Transporter Certification: I hereby declare that I have received the type and quantity of waste as described by the generator and that waste has been transported according to regulations.

ออกใบส่งจากจังหวัด: From ไปยังจังหวัด: To ใช้ระยะเวลาประมาณ: Time Spending ชม./วัน: Hours/Day

ชื่อผู้ขนส่งของเสีย: Transporter's Name ลายเซ็น: Signature วันที่: Date เดือน: Month พ.ศ.: Year

3. ส่วนของผู้ประกอบการบำบัดของเสีย: This section must be completed by TSDFs

1) ชื่อผู้รับกำจัด: TSDF's name 2) เลขประจำตัวผู้รับกำจัด: TSDF's ID

สถานที่ตั้ง: TSDF's address โทรศัพท์: Phone โทรสาร: Fax กรณีฉุกเฉิน: Emergency

คำรับรอง: ข้าพเจ้าขอรับรองว่าได้รับของเสียแล้วตามที่ระบุข้างต้น TSDF certificate of arrival: I hereby declare that I have received the reference load.

สามารถกำจัดของเสียที่รับมาได้ในเวลา: Treatment period ☐ วัน: Day ☐ เดือน: Month ☐ ปี: Year นับจากวันที่ได้รับของเสีย: Since the day that received waste

ชื่อผู้รับกำจัด: TSDF's name ลายเซ็น: Signature วันที่: Date เดือน: Month พ.ศ.: Year

กรณีของเสียไม่ตรงตามที่แจ้ง: Discrepancy Notification

ประเภทของเสีย: Type of waste ปริมาณ: Quantity

การดำเนินการ: Action taken ☐ ส่งคืน: Returned ☐ จัดประเภทใหม่: Reclassified / รหัส: Waste ID วันที่กำจัด: Accepted (เหตุผล: Reason of action

วันที่ส่งคืน: Date returned (วันเดือนปี: dd / mm / yy) หมายเลขใบกำกับการขนส่งของเสียที่ส่งคืน: Returned manifest no

ลายเซ็น: TSDF's name ลายเซ็น: TSDF's name



บริษัท ปตท.สำรวจและผลิตปิโตรเลียม จำกัด(มหาชน)

ปตท.สผ.

222 หมู่ 1 ต.หัวเขา อ.สิงหนคร จ.สงขลา 90280

ใบชั่งน้ำหนัก

เลขที่ใบชั่ง : 0068695

ทะเบียนรถ : 1 BOX.

วันที่ : 10/01/2024

ชนิดสินค้า : Electronic waste

ชื่อผู้ส่ง : WMS company

รายการ	ลำดับ	วันที่	เวลา	น้ำหนัก(กก.)
รถเข้า >>>	32357	10/01/2024	14:12:27	7,970
<<< รถออก	23525	10/01/2024	14:14:08	7,540
หมายเหตุ: PSB IT-050124-01, 2024010061, (PSB)			น้ำหนักสุทธิ	430

.....
พนักงานชั่ง

.....
พนักงานขับรถ



บริษัท ปตท.สำรวจและผลิตปิโตรเลียม จำกัด(มหาชน)

ปตท.สผ.

222 หมู่ 1 ต.หัวเขา อ.สิงหนคร จ.สงขลา 90280

ใบชั่งน้ำหนัก

เลขที่ใบชั่ง : 0068696

ทะเบียนรถ : 2 D. CABLES

วันที่ : 10/01/2024

ชนิดสินค้า : Hazardous waste

ชื่อผู้ส่ง : WMS company

รายการ	ลำดับ	วันที่	เวลา	น้ำหนัก(กก.)
รถเข้า >>>	32356	10/01/2024	14:11:20	7,720
<<< รถออก	23526	10/01/2024	14:14:19	7,540
หมายเหตุ: PSB IT-050124-01, 2024010061, (PSB)			น้ำหนักสุทธิ	180

.....
พนักงานชั่ง

.....
พนักงานขับรถ

PSB SKL IT
PSBIT-050124-01
PRINTER CARTRIDGE
น้ำหนัก 8 Kg



อริสมันต์

พนักงานช่าง



อริสมันต์

พนักงานขับรถ

PSB SKL IT
PSBIT-050124-01
LEAD BATTERY
น้ำหนัก 5 Kg



อริสมันต์

พนักงานช่าง



อริสมันต์

พนักงานขับรถ



PTTEP

PSB IT
DISPATCH ADVISE NOTE FORM

DAN #: PSBIT-050124-01

Date: 5-Jan-2024

FROM	TO	MEAN OF TRANSPORT	DATE DEPARTURE
Alee B. PSB IT	Waste Transit	Car	

[illegible]

PREPARED AND ISSUED	RECEIVED AND CHECKED	COMMENTS ON RECEPTION	PACKING DETAILS	
NAME: Alee B. PSB IT	NAME:		TOTAL BAG	
			TOTAL OTHER	
DATE: 05/01/24	DATE:	WEIGHT TOTAL (Kgs.) :		343



PTTEP

APPENDIX D: WASTE MANAGEMENT OPERATION

Reference D5 – 1 แบบตรวจการขนส่งของเดี่ยวอันตราย

[illegible]

Revision No: 02

UNCONTROLLED when printed.

Visit PSB SSHE Center for latest version.

ภาคผนวก ข-20

การเปิดให้เยี่ยมชมพื้นที่โครงการ PTTEP-PSB

ข้อมูลการเข้าเยี่ยมชม ฐานสนับสนุนการพัฒนาปิโตรเลียม สงขลา



มกราคม – มิถุนายน 2567

Stakeholder Engagement



CoP: CSV by Oil and Gas Companies in Singhanakhon

9 เม.ย. 67 ปตท.สผ. โดย OSB/S and OSB/A จัดประชุมหารือแนวทางการบูรณาการขับเคลื่อนกิจกรรมเพื่อสังคมในพื้นที่อำเภอสิงหนคร โดยเชิญเครือข่ายบริษัทในสาย Oil and Gas ร่วมแลกเปลี่ยนประสบการณ์ แนวทางที่ดำเนินการอยู่และแผนงาน รวมถึงความท้าทายในงานกิจกรรมเพื่อสังคมของแต่ละบริษัท โดยจะมีการสร้าง CoP Community of Practice ชุมชนแห่งการเรียนรู้ แลกเปลี่ยนแบ่งปันทรัพยากร บูรณาการความร่วมมือและขับเคลื่อนกิจกรรมร่วมกันในอนาคต ได้รับเกียรติจากผู้บริหารและผู้แทนจาก 17 บริษัทรวม 40 ท่านเข้าร่วม ณ ห้องประชุม B105 ฐานสนับสนุนการพัฒนาปิโตรเลียมสงขลา ปตท.สผ.



Energy Partner of Choice

ภาคผนวก ข-21

รายชื่อพนักงานจากท้องถิ่น

No.	ID	NAME	LASTNAME	POSITION	ORG.	DEPARTMENT	DIVISION	GROUP	LOCATION	Name Thai	Address
1	88393			Team Leader, Warehouse	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
2	88546			Officer, Public Affairs Support	OSB/A	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
3	89143			Office Service	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
4	89144			Technician	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
5	89146			Team Leader, Material Yard	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
6	89147			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
7	89166			Driver	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
8	89167			Skilled Technician, SSHE Services	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
9	89168			Assistant Officer, Helipoint	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
10	89173			Driver	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
11	89175			Driver	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
12	89176			Helper, Maintenance	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
13	89178			Technician, Luggage Inspection and Scanner	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
14	89180			Maid	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
15	89181			Maid	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
16	89182			Maid	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
17	89184			Technician, Maintenance and Inspection	EMI/S	EMI	ENX	EDM	Songkhla		จังหวัดสงขลา
18	88873			Operator, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
19	88691			Supervisor, Songkhla Facility Management	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
20	89049			Supervisor, Helipoint	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
21	89079			Officer, Material Coordination	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
22	89140			Supervisor, Construction	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
23	88520			Officer, Freight and Formalities Management Support	OLG/F	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
24	89185			Driver	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
25	89187			Maid	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
26	89189			Technician	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
27	89190			Operator, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
28	89226			Driver	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
29	89229			Officer, Helipoint	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
30	89239			Driver	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
31	89274			Caretaker	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
32	89411			Technician	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
33	89416			Assistant Officer, Helipoint	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
34	89419			Assistant Officer, Cost Coordination	OSB/B	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
35	89429			Foreman	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
36	89431			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
37	89432			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
38	89433			Foreman	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
39	89434			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
40	89435			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
41	89437			Foreman	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
42	89438			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
43	89439			Foreman	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
44	89440			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
45	89443			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
46	89444			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
47	89445			Officer, Jetty Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
48	89446			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
49	89448			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
50	89449			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
51	89501			Team Leader, Waste Management	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
52	89275			Transportation Service	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
53	89562			Assistant Officer, Business Coordination	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
54	89603			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
55	89630			Officer, Jetty Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
56	89655			Supervisor, Workshop	OTF	OTF	OWO	OPS	Songkhla		จังหวัดสงขลา
57	89729			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
58	89793			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
59	89820			Assistant Officer, Material Coordination	EMI/M	EMI	ENX	EDM	Songkhla		จังหวัดสงขลา
60	89821			Officer, Jetty Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
61	89822			Assistant Officer, Cost Coordination	OSB/B	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
62	89932			Foreman	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
63	89933			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
64	89934			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
65	89935			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
66	89986			Officer, Business Coordination Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
67	90003			Supervisor, Construction	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
68	90073			Operator, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
69	90074			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
70	90075			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
71	90137			Operator, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
72	90271			Team Leader, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
73	90299			Maid	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
74	90395			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
75	90400			Officer, Freight and Formalities Management Support	OLG/F	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
76	90401			Team Leader, Cost Coordination	OSB/B	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
77	90470			Assistant Officer, Public Affairs	OSB/A	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
78	90478			Driver	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
79	90429			Assistant Officer, HR Operations	PSL/OD	PSL	SHR	SBH	Songkhla		จังหวัดสงขลา
80	90517			Officer, Public Affairs Support	OSB/A	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
81	90539			Officer, Administration Support	OTF	OTF	OWO	OPS	Songkhla		จังหวัดสงขลา

No.	ID	NAME	LASTNAME	POSITION	ORG.	DEPARTMEN T	DIVISIO N	GROUP	LOCATION	Name Thai	Address
82	90572			Officer, Material Coordination	OTF	OTF	OWO	OPS	Songkhla		จังหวัดยะลา
83	90588			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
84	90677			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
85	90679			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
86	90681			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
87	90684			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
88	90685			Foreman	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
89	90686			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
90	62212			Onshore Coordinator	CPOC	CPOC	CPOC	CPOC	Songkhla		กรุงเทพมหานคร
91	90781			Officer, Business Coordination Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
92	90863			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
93	90864			Team Leader, Warehouse	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
94	62223			Admin Assistant	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
95	62224			Documentation Clerk	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
96	62226			Stock Controller	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
97	62227			Warehouse Supervisor	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
98	90890			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
99	90891			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดปัตตานี
100	90892			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
101	90903			Assistant Officer, Material Coordination	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
102	90978			Assistant Officer, HR Operations	PSL/OD	PSL	SHR	SBH	Songkhla		จังหวัดสงขลา
103	91037			Driver	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
104	91039			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
105	91145			Officer, SSHE Support	OTF	OTF	OWO	OPS	Songkhla		จังหวัดสงขลา
106	91171			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
107	91398			Team Leader, Offshore Execution	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
108	91423			Operator, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
109	91424			Driver	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
110	91444			Operator, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
111	91461			Driver	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
112	62500			Driver	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
113	91541			Assistant Officer, SSHE	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
114	91550			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
115	91583			Officer, Material Coordination	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
116	91644			Assistant Officer, Asset Coordination	PFO2/O	PFO2	PTF2	PDD	Songkhla		จังหวัดสงขลา
117	91705			Assistant Officer, Administration	OLG/O	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
118	91726			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
119	91776			Team Leader, Warehouse	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
120	91779			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
121	91780			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
122	91781			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
123	91881			Skilled Labour	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
124	91912			Supervisor, Jetty	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดปัตตานี
125	91906			Assistant Officer, Cost Coordination	OSB/B	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
126	91909			Senior Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
127	91923			Assistant Officer, Purchasing Services	ECM/S	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
128	91927			Assistant Officer, Heliport	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
129	91954			Supervisor, Construction	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดปัตตานี
130	92006			Driver	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
131	92017			Driver	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
132	92024			Driver	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
133	92044			Officer, Jetty Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
134	92108			Supervisor, Maintenance and Inspection	EMI/S	EMI	ENX	EDM	Songkhla		จังหวัดตาก
135	92154			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
136	92159			Storekeeper, Maintenance Workshop	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
137	92168			Supervisor, Construction	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
138	92237			Assistant Officer, Cost Coordination	OSB/B	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
139	92258			Supervisor, Inspection	EMI/I	EMI	ENX	EDM	Songkhla		จังหวัดสงขลา
140	92263			Officer, Cost Coordination Support	OSB/B	OSB	OSM	OPS	Songkhla		กรุงเทพมหานคร
141	62510			Stock Controller	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
142	92478			Clerk, Tally	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
143	62512			Material Coordinator (Issuing)	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
144	62517			Admin Assistant	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
145	62518			Helibase Coordinator	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
146	92610			Senior Technician, Inspection	EMI/I	EMI	ENX	EDM	Songkhla		จังหวัดศรีสะเกษ
147	62519			Supply Base Analyst	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
148	62520			Material Coordinator (Issuing)	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
149	92652			Assistant Officer, Business Coordination	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
150	92741			Storekeeper	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
151	92776			Driver	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
152	92793			Operator, Stock	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
153	62523			Jetty Operator	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสตูล
154	62525			Custom & Liaison Executive	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
155	62526			Onshore Material Coordinator Assistant	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
156	62531			Assistant Logistic Coordinator	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
157	62535			Logistics Operation Coordinator	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดนครศรีธรรมราช
158	63045			Material Coordinator (Receiving)	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
159	63125			Supervisor, Maintenance (Crane)	EMI/M	EMI	ENX	EDM	Songkhla		จังหวัดสงขลา
160	63393			Superintendent, Workshop	OTF	OTF	OWO	OPS	Songkhla		จังหวัดสงขลา
161	64113			Workshop and Material Supervisor	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
162	64439			Jetty Operator	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดกาญจนบุรี

No.	ID	NAME	LASTNAME	POSITION	ORG.	DEPARTMENT	DIVISION	GROUP	LOCATION	Name Thai	Address
163	64482			Officer, SSHE Support	OTF	OTF	OWO	OPS	Songkhla		จังหวัดสุราษฎร์ธานี
164	65021			Assistant Officer, Jetty	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
165	65028			Assistant Officer, Jetty	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดนครศรีธรรมราช
166	65033			Officer, Jetty Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
167	65077			Supervisor, Construction	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดนครปฐม
168	65629			Material Coordination Officer	PMW/W	PMW	PMM	PDI	Songkhla		จังหวัดสงขลา
169	66052			Assistant Officer, Heliport	OLG/A	OLG	OSM	OPS	Songkhla		จังหวัดสงขลา
170	66131			Officer, Songkhla Facilities Management Support	OSB/S	OSB	OSM	OPS	Songkhla		จังหวัดระยอง
171	66134			Assistant Officer, Business Coordination	OTF	OTF	OWO	OPS	Songkhla		จังหวัดสงขลา
172	66210			Assistant Officer, Purchasing Services	ECM/S	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
173	66233			Supervisor, Construction	ECM/F2	ECM	ENX	EDM	Songkhla		จังหวัดชลบุรี
174	66372			Radio Operator	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
175	66383			Marine Operations Supervisor	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดภูเก็ต
176	66483			Drilling Workshop and Material Assistant	CPOC	CPOC	CPOC	CPOC	Songkhla		จังหวัดสงขลา
177	66529			Assistant Officer, Public Affairs	OSB/A	OSB	OSM	OPS	Songkhla		จังหวัดสงขลา
178	66614			Senior Engineer, Marine Support	PMO/L	PMO	PMM	PDI	Songkhla		กรุงเทพมหานคร
179	66621			Assistant Officer, Project Planning	ECM/S	ECM	ENX	EDM	Songkhla		จังหวัดสงขลา
180	67076			Engineer, Marine Support	OLG/O	OLG	OSM	OPS	Songkhla		จังหวัดนนทบุรี
181	67138			Engineer, Marine Support	OLG/O	OLG	OSM	OPS	Songkhla		จังหวัดนนทบุรี
182	67256			Engineer, Inspection Support	EMI/I	EMI	ENX	EDM	Songkhla		จังหวัดนครศรีธรรมราช

No.	ID	NAME	LASTNAME	POSITION	ORG.	DEPARTMENT	DIVISION	GROUP	LOCATION	Working For	Name Thai	Address
1	64104			Assistant Officer, Public Affairs	OSB/A	OSB	OSM	OPS	Songkhla	PTTEP ED		จังหวัดสงขลา
2	64158			Assistant Officer, Administration	OTF	OTF	OWO	OPS	Songkhla	PTTEP ED		จังหวัดสงขลา
3	64230			Officer, Employee Relations	PSL/ER	PSL	SHR	SBH	Songkhla	PTTEP ED		จังหวัดนครศรีธรรมราช
4	64310			Officer, Public Affairs	OSB/A	OSB	OSM	OPS	Songkhla	PTTEP ED		จังหวัดสงขลา
5	65026			Officer, Material Coordination	OTF	OTF	OWO	OPS	Songkhla	PTTEP ED		จังหวัดสงขลา
6	65075			Assistant Officer, Purchasing Services	ECM/S	ECM	ENX	EDM	Songkhla	PTTEP ED		จังหวัดสงขลา
7	65089			Supervisor, Fabrication	ECM/F1	ECM	ENX	EDM	Songkhla	PTTEP ED		จังหวัดสงขลา
8	65104			Officer, Material Coordination	OTF	OTF	OWO	OPS	Songkhla	PTTEP ED		จังหวัดสงขลา
9	65123			Officer, Public Affairs	OSB/A	OSB	OSM	OPS	Songkhla	PTTEP ED		จังหวัดนครศรีธรรมราช
10	65125			Assistant Officer, Material Coordination	OTF	OTF	OWO	OPS	Songkhla	PTTEP ED		จังหวัดสงขลา
11	65458			Supervisor, Maintenance and Inspection	EMI/S	EMI	ENX	EDM	Songkhla	PTTEP ED		จังหวัดสุพรรณบุรี
12	65670			Senior Technician, Maintenance	EMI/S	EMI	ENX	EDM	Songkhla	PTTEP ED		จังหวัดสงขลา
13	65685			Assistant Officer, Asset Coordination	PFO1/O	PFO1	PTF1	PDD	Songkhla	PTTEP ED		จังหวัดสงขลา
14	65747			Supervisor, Fabrication	ECM/F1	ECM	ENX	EDM	Songkhla	PTTEP ED		จังหวัดยะลา
15	66005			Supervisor, Maintenance (Mechanical)	EMI/S	EMI	ENX	EDM	Songkhla	PTTEP ED		จังหวัดลพบุรี
16	66049			Senior Technician, Maintenance	EMI/S	EMI	ENX	EDM	Songkhla	PTTEP ED		จังหวัดสงขลา

PTTEP

EMPLOYEE_ID	FIRSTNAME	LASTNAME	FULLNAME	THAINAME	POSITION	DIVISION	DEPARTMENT	SECTION
33123					Officer, Building Services	OSM	OSB	OSB/S
40491					Supervisor, Material Coordination	OWO	OTF	
40544					Supervisor, Inspection and Corrosion	ENX	EMI	EMI/I
40549					Lead Technician, Maintenance and Inspection	ENX	EMI	EMI/S
40581					Supervisor, Warehouse and Material Yard	OSM	OSB	OSB/S
40654					Officer, Safety Services	OSM	OSB	OSB/S
41707					Lead Technician, Maintenance and Inspection	ENX	EMI	EMI/S
47099					Manager, Public Affairs Section	OSM	OSB	OSB/A
52796					Manager, Songkhla Support Base Section	OSM	OSB	OSB/S
53983					Engineer, Marine	OSM	OLG	OLG/O
55189					Officer, SSHE	OSM	OSB	OSB/S
56023					Supervisor, SSHE	OSM	OSB	OSB/S
57052					Engineer, Marine	OSM	OLG	OLG/O
57060					Supervisor, Maintenance and Inspection	EMI/S	EMI	ENX
58072					Base Superintendent	PDD	PDJ	
58080					Officer, Public Affairs	OSM	OSB	OSB/A