UGP	บริษัท อู่ทองกรีนพาวเวอร์ จำกัด ELECTRICAL SECTION	Document Title POWER TRANSFORMER INSPECTION	Form Number : UGP-FO-MN-308 Revision : 00 Issued Date : 1 May 2021

KKS TAG NO.:	10BFT03	USER NAME:	ESP Transformer 3	CAPACITY :	71.6 KVA
PRI. VOLTAGE:	400 V	SEC. VOLTAGE:	111 V DC	TYPE :	Rectifier
PRI. CURRENT:	2.6 A	SEC. CURRENT:	700 m ADC	FREQUENCY :	50 Hz
MANUFACTURER:	ADOR-CORONA	SERIAL NO.:	9218-01-06-2011	LOCATION :	ESP

INSPECTED DATE	PRI. VOLTAGE (KV)	SEC. VOLTAGE. (KV)	PRI. CURRENT (A)	SEC. CURRENT (A)	OIL TEMP. (<90 °C)	WINDING TEMP. (<100 °C)	OIL LEVEL (min-max)		TAP POSITION	SILICA GEL >35% *1	OIL LEAKAGE CHECK	FAN COOLING STATUS	FOUNDATION CHECK	INSPECTED BY	APPROVE BY	REMARK
							MAIN TANK	OLTC								
10/1/67	110 V	40	25	110	42	-	55	-	-	100	No	✓	Ok			
13/2/67	110 V	40	30	125	46	-	55	-	-	100	No	✓	Ok			
13/3/67	110 V	40	26	110	46	-	55	-	-	100	No	✓	Ok			
9/4/67	110 V	40	27	117	42	-	50	-	-	100	no	✓	Ok			
19/5/67	110 V	40	25	110	40	-	55	-	-	100	No	✓	ok			
11/6/67	110 V	34	40	110	40	-	55	-	-	90	No	✓	ok			

Note *1 : Silica gel color was changed more than 35%, Recomment to renew Silica gel (During Transformer outage)

This document is U THONG GREEN POWER Ltd. C-Segment and cannot be used, reproduced or transmited to thirds party without prior written permission.

UGP	บริษัท อู่ทองกรีนพาวเวอร์ จำกัด ELECTRICAL SECTION	Document Title POWER TRANSFORMER INSPECTION	Form Number : UGP-FO-MN-308 Revision : 00 Issued Date : 1 May 2021

KKS TAG NO.:	10BFT04	USER NAME:	ESP Transformer 4	CAPACITY :	71.6 KVA
PRI. VOLTAGE:	400 V	SEC. VOLTAGE:	111 V DC	TYPE :	Rectifier
PRI. CURRENT:	2.6 A	SEC. CURRENT:	700 m ADC	FREQUENCY :	50 Hz
MANUFACTURER:	ADOR-CORONA	SERIAL NO.:	9217-01-06-2011	LOCATION :	ESP

INSPECTED DATE	PRI. VOLTAGE (KV)	SEC. VOLTAGE. (KV)	PRI. CURRENT (A)	SEC. CURRENT (A)	OIL TEMP. (<90 °C)	WINDING TEMP. (<100 °C)	OIL LEVEL (min-max) MAIN TANK	OIL LEVEL (min-max) OLTC	TAP POSITION	SILICA GEL >35% *1	OIL LEAKAGE CHECK	FAN COOLING STATUS	FOUNDATION CHECK	INSPECTED BY	APPROVE BY	REMARK
16/1/67	140 V	42	50	140	50	-	60	-	-	100	No	/	Ok			
13/2/67	130V	40	52	146	52	-	60	-	-	100	No	/	Ok			
12/3/67	140V	42	52	138	50	-	60	-	-	100	No	/	Ok			
9/4/67	120 V	40	50	139	52	-	60	-	-	100	NO	/	Ok			
15/5/67	130V	40	50	140	50	-	60	-	-	100	No	/	ok			
11/6/67	150V	44	50	160	46	-	60	-	-	50	No	/	Ok			

Note *1 : Silica gel color was changed more than 35%, Recomment to renew Silica gel (During Transformer outage)

This document is U THONG GREEN POWER Ltd. C-Segment and cannot be used, reproduced or transmited to thirds party without prior written permission.