



BOILER FAN CHECK AND INSPECTION

Issued Date : 1 May 2021

Reference : Vibration result is in accordance with ISO 10816 Part 3 International standard

CAPACITY :	Impeller side 56 g	
	$V = 189460 \text{ m}^3/\text{h}$	$\Delta p_t = 375 \text{ daPa}$
	$n = 1450 = 49 \text{ Hz}$	$t_e = 195 \text{ }^\circ\text{C}$
	$N_{\max} = 1490 \text{ min}^{-1}$	$t_{\max} = 230^\circ\text{C}$
	$P_w = 238 \text{ kW}$	

This document is U THONG GREEN POWER Ltd. C-Segment and cannot be used, reproduced or transmitted to thirds party without prior written permission.

✓ = ปกติ X= ผิดปกติ