

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/100-101	ANALYTICAL DATE	: JANUARY 11-25, 2024
SAMPLING DATE	: JANUARY 10, 2024	APPROVED DATE	: JANUARY 25, 2024
RECEIVED DATE	: JANUARY 11, 2024		
SAMPLING BY	: Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-000๐		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360		
	* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๖-029		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.100	EFFLUENT No.101	STANDARD
pH at 25°C	-	pH meter	6.6	7.0	5.5-9.0
Temperature*	°C	Thermometer	34.7	32.4	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105°C	33	10	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180°C	320	330	3,000
BOD ₅ *	mg/L	Azide Modification Method	5	3	20
COD*	mg/L	Closed Reflux Method	30	18	120
Oil & Grease*	mg/L	Partition & Gravimetric Method	7	<5	5
TKN*	mg/L	Macro-Kjeldahl Method	2	<1	100
Conductivity	µmho/cm	Conductivity Meter	394	409	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	0	2.1	-
Hydrogen Cyanide (HCN)*	mg/L	Distill & Colorimetric	0.18	0.03	0.2
Formaldehyde*	mg/L	Distill & Colorimetric	<0.05	<0.05	1

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/100-101	ANALYTICAL DATE	: JANUARY 11-25, 2024
SAMPLING DATE	: JANUARY 10, 2024	APPROVED DATE	: JANUARY 25, 2024
RECEIVED DATE	: JANUARY 11, 2024		
SAMPLING BY	: Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-0002		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. : REGISTER NO. ๖-360		
	* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๖-029		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.100	EFFLUENT No.101	STANDARD
Arsenic (As)*	mg/L	Inductively Coupled Plasma-Hydride	<0.001	<0.001	0.25
Barium (Ba)*	mg/L	Inductively Coupled Plasma	0.079	0.070	1.0
Cadmium (Cd)*	mg/L	Inductively Coupled Plasma	<0.001	<0.001	0.03
Total Chromium (Cr)*	mg/L	Calculation Method	0.027	0.002	-
Chromium (Cr ⁺³)*	mg/L	Inductively Coupled Plasma	0.027	0.002	0.75
Chromium (Cr ⁺⁶)*	mg/L	Inductively Coupled Plasma	<0.003	<0.003	0.25
Copper (Cu)*	mg/L	Inductively Coupled Plasma	0.006	<0.001	2.0
Lead (Pb)*	mg/L	Inductively Coupled Plasma	<0.005	<0.005	0.2
Manganese (Mn)*	mg/L	Inductively Coupled Plasma	0.086	0.074	5.0
Mercury (Hg)*	mg/L	Inductively Coupled Plasma-Hydried	<0.0005	<0.0005	0.005
Nickel (Ni)*	mg/L	Inductively Coupled Plasma	0.048	0.011	1.0
Selenium (Se)*	mg/L	Inductively Coupled Plasma -Hydride	<0.001	<0.001	0.02
Zinc (Zn)*	mg/L	Inductively Coupled Plasma	0.099	0.021	5.0

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.

Book 134, Special Chapter 153 d, published in the Royal Gazette. dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.


RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/178-179	ANALYTICAL DATE	: JANUARY 23-31, 2024
SAMPLING DATE	: JANUARY 23, 2024	APPROVED DATE	: JANUARY 31, 2024
RECEIVED DATE	: JANUARY 23, 2024		
SAMPLING BY	: Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-0002		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360		
	* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๖-029		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.178	EFFLUENT No.179	STANDARD
pH at 25°C	-	pH meter	6.5	6.8	5.5-9.0
Temperature	°C	Thermometer	34.7	32.4	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	40	18	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180°C	260	280	3,000
BOD ₅ *	mg/L	Azide Modification Method	7	8	20
COD*	mg/L	Closed Reflux Method	57	30	120
Oil & Grease*	mg/L	Partition & Gravimetric Method	10	<5	5
Conductivity	µmho/cm	Conductivity Meter	327	310	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	8.6	2.1	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.



TE)

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/219-220	ANALYTICAL DATE	: FEBRUARY 1-14, 2024
SAMPLING DATE	: FEBRUARY 01, 2024	APPROVED DATE	: FEBRUARY 14, 2024
RECEIVED DATE	: FEBRUARY 01, 2024		
SAMPLING BY	: Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-000๒		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360		
	* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๖-029		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.219	EFFLUENT No.220	STANDARD
pH at 25°C	-	pH meter	5.9	6.7	5.5-9.0
Temperature	°C	Thermometer	34.0	31.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	29	11	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	220	250	3,000
BOD ₅ *	mg/L	Azide Modification Method	11	13	20
COD*	mg/L	Closed Reflux Method	57	74	120
Oil & Grease*	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	316	346	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	0.5	0.8	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	:	WATER NO.67/495-496			
SAMPLING DATE	:	FEBRUARY 20, 2024	ANALYTICAL DATE	:	FEBRUARY 20-29, 2024
RECEIVED DATE	:	FEBRUARY 20, 2024	APPROVED DATE	:	FEBRUARY 29, 2024
SAMPLING BY	:	Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-0002			
ANALYZED BY	:	ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360			
* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๖-029					

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.495	EFFLUENT No.496	STANDARD
pH at 25°C	-	pH meter	7.2	7.0	5.5-9.0
Temperature	°C	Thermometer	30.9	30.2	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	7.2	3.6	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180°C	220	320	3,000
BOD ₅ *	mg/L	Azide Modification Method	4	4	20
COD*	mg/L	Closed Reflux Method	14	14	120
Oil & Grease*	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	285	427	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.6	3.0	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/631-632	ANALYTICAL DATE	: MARCH 6-27, 2024
SAMPLING DATE	: MARCH 6, 2024	APPROVED DATE	: MARCH 27, 2024
RECEIVED DATE	: MARCH 6, 2024		
SAMPLING BY	: Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-0002		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360		
	* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๖-029		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.631	EFFLUENT No.632	STANDARD
pH at 25°C	-	pH meter	6.9	7.0	5.5-9.0
Temperature	°C	Thermometer	29.0	27.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	540	6.0	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180°C	330	320	3,000
BOD ₅ *	mg/L	Azide Modification Method	<2	2	20
COD*	mg/L	Closed Reflux Method	38	11	120
Oil & Grease*	mg/L	Partition & Gravimetric Method	26	<5	5
Conductivity	µmho/cm	Conductivity Meter	465	476	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	2.6	3.5	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	:	WATER NO.67/794-795			
SAMPLING DATE	:	MARCH 20, 2024	ANALYTICAL DATE	:	MARCH 21 - APRIL 11, 2024
RECEIVED DATE	:	MARCH 20, 2024	APPROVED DATE	:	APRIL 11, 2024
SAMPLING BY	:	Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-000๒			
ANALYZED BY	:	ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD., REGISTER NO. ๖-360			

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.794	EFFLUENT No.795	STANDARD
pH at 25°C	-	pH meter	7.0	7.1	5.5-9.0
Temperature	°C	Thermometer	36.7	33.4	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	38	<3	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	470	440	3,000
BOD ₅	mg/L	Azide Modification Method	3	3	20
COD	mg/L	Closed Reflux Method	50	27	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	580	548	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.7	2.4	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALYTY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/838-839	ANALYTICAL DATE	: APRIL 30, 2024
SAMPLING DATE	: APRIL 3, 2024	APPROVED DATE	: APRIL 30, 2024
RECEIVED DATE	: APRIL 4, 2024		
SAMPLING BY	: Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-0002		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.838	EFFLUENT No.839	STANDARD
pH at 25°C	-	pH meter	7.3	7.1	5.5-9.0
Temperature	°C	Thermometer	32.4	31.8	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	24	7.2	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	360	350	3,000
BOD ₅	mg/L	Azide Modification Method	<2	2	20
COD	mg/L	Closed Reflux Method	16	29	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
TKN	mg/L	Macro-Kjeldahl Method	<1	<1	100
Conductivity	µmho/cm	Conductivity Meter	514	476	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.6	4.7	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/838-839	ANALYTICAL DATE	: APRIL 30, 2024
SAMPLING DATE	: APRIL 3, 2024	APPROVED DATE	: APRIL 30, 2024
RECEIVED DATE	: APRIL 4, 2024		
SAMPLING BY	: Mr. KOMSAN KHAMONSA, REGISTER NO. ๖-360-๖-0002		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360		
* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๖-029			

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.838	EFFLUENT No.839	STANDARD
Hydrogen Cyanide (HCN)*	mg/L	Distill & Colorimetric	<0.01	<0.01	0.2
Formaldehyde*	mg/L	Distill & Colorimetric	<0.05	<0.05	1
Arsenic (As)*	mg/L	Inductively Coupled Plasma-Hydride	0.008	0.006	0.25
Barium (Ba)*	mg/L	Inductively Coupled Plasma	0.16	0.15	1.0
Cadmium (Cd)*	mg/L	Inductively Coupled Plasma	<0.001	<0.001	0.03
Total Chromium (Cr)*	mg/L	Calculation Method	<0.001	<0.001	-
Chromium (Cr ⁺³)*	mg/L	Inductively Coupled Plasma	<0.001	<0.001	0.75
Chromium (Cr ⁺⁶)*	mg/L	Inductively Coupled Plasma	<0.003	<0.003	0.25
Copper (Cu)*	mg/L	Inductively Coupled Plasma	0.018	0.016	2.0
Lead (Pb)*	mg/L	Inductively Coupled Plasma	<0.001	<0.001	0.2
Manganese (Mn)*	mg/L	Inductively Coupled Plasma	0.099	0.071	5.0
Mercury (Hg)*	mg/L	Inductively Coupled Plasma-Hydried	<0.001	<0.001	0.005
Nickel (Ni)*	mg/L	Inductively Coupled Plasma	0.031	0.030	1.0
Selenium (Se)*	mg/L	Inductively Coupled Plasma -Hydride	0.007	0.005	0.02
Zinc (Zn)*	mg/L	Inductively Coupled Plasma	0.13	0.093	5.0

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/1057-1058	ANALYTICAL DATE	: APRIL 17-MAY 14, 2024
SAMPLING DATE	: APRIL 17, 2024	APPROVED DATE	: MAY 14, 2024
RECEIVED DATE	: APRIL 17, 2024		
SAMPLING BY	: Mr. AEKKALUK PROMMI, REGISTER NO. ๖-360-๖-0006		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๖-360		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1057	EFFLUENT No.1058	STANDARD
pH at 25°C	-	pH meter	7.7	7.6	5.5-9.0
Temperature	°C	Thermometer	32.0	31.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	5.0	4.4	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	480	370	3,000
BOD ₅	mg/L	Azide Modification Method	15	3	20
COD	mg/L	Closed Reflux Method	51	35	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	568	540	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.9	2.5	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/1261-1262	ANALYTICAL DATE	: MAY 24, 2024
SAMPLING DATE	: MAY 2, 2024	APPROVED DATE	: MAY 24, 2024
RECEIVED DATE	: MAY 3, 2024		
SAMPLING BY	: Mr. AEKKALUK PROMMI, REGISTER NO. ๖-360-๓-0006		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO., LTD. REGISTER NO. ๖-360		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1261	EFFLUENT No.1262	STANDARD
pH at 25°C	-	pH meter	7.0	6.9	5.5-9.0
Temperature	°C	Thermometer	40.0	34.5	40
Total Suspended Solids (TSS)	mg/L	Dried at 105 ± 0.5 °C	59	17	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	240	320	3,000
BOD ₅	mg/L	Azide Modification Method	5	6	20
COD	mg/L	Closed Reflux Method	18	18	120
Oil & Grease	mg/L	Partition & Gravimetric Method	5	<5	5
Conductivity	µmho/cm	Conductivity Meter	351	427	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	2.9	1.7	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/1345-1346	ANALYTICAL DATE	: MAY 15-31, 2024
SAMPLING DATE	: MAY 15, 2024	APPROVED DATE	: MAY 31, 2024
RECEIVED DATE	: MAY 15, 2024		
SAMPLING BY	: Mr. AEKKALUK PROMMI, REGISTER NO. ๓-360-๓-0006		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO., LTD. REGISTER NO. ๓-360		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1345	EFFLUENT No.1346	STANDARD
pH at 25°C	-	pH meter	7.4	6.7	5.5-9.0
Temperature	°C	Thermometer	33.0	31.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 105 ± 0.5 °C	4.4	<3	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	300	390	3,000
BOD ₅	mg/L	Azide Modification Method	4	3	20
COD	mg/L	Closed Reflux Method	29	17	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	356	524	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	4.0	2.2	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/1494-1495	
SAMPLING DATE	: JUNE 5, 2024	ANALYTICAL DATE : JUNE 5-20, 2024
RECEIVED DATE	: JUNE 5, 2024	APPROVED DATE : JUNE 20, 2024
SAMPLING BY	: Mr. AEKKALUK PROMMI, REGISTER NO. ๓-360-๓-0006	
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๓-360	

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1494	EFFLUENT No.1495	STANDARD
pH at 25°C	-	pH meter	7.2	7.0	5.5-9.0
Temperature	°C	Thermometer	35.4	32.2	40
Total Suspended Solids (TSS)	mg/L	Dried at 103±0.5 °C	200	8.4	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	150	250	3,000
BOD ₅	mg/L	Azide Modification Method	<2	<2	20
COD	mg/L	Closed Reflux Method	<5	6	120
Oil & Grease	mg/L	Partition & Gravimetric Method	35	<5	5
Conductivity	µmho/cm	Conductivity Meter	229	484	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	5.2	2.2	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/1659-1660	ANALYTICAL DATE	: JUNE 19 - JULY 8, 2024
SAMPLING DATE	: JUNE 19, 2024	APPROVED DATE	: JULY 8, 2024
RECEIVED DATE	: JUNE 19, 2024		
SAMPLING BY	: Mr. AEKKALUK PROMMI, REGISTER NO. ๖-360-๖-0006		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO., LTD. REGISTER NO. ๖-360		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1659	EFFLUENT No.1660	STANDARD
pH at 25°C	-	pH meter	6.8	6.8	5.5-9.0
Temperature	°C	Thermometer	37.0	31.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105°C	36	5.2	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180°C	290	360	3,000
BOD ₅	mg/L	Azide Modification Method	6	2	20
COD	mg/L	Closed Reflux Method	32	38	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	410	483	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.3	1.2	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.