PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,483	TFL -61 -61T074		LC SLOP OIL TANK	PM FRAMEARRESTOR&EVC 61T074	3M			I			I			I			I	RLB	RLB-MLBO		PMT	109609	136972
4,484	TFL -61 -61T075A		LC DCC FEED TANK	Inservice tank inspection by LAW	1Y							I						IRI	IRI-INTP	A	SM	55362	57192
4,485	TFL -61 -61T075A		LC DCC FEED TANK	VIBRATION INSP & ANALYSIS M/C	2M		I		I		I		I		I		I	IRI	IRI-INVB	A	INT	95206	119715
4,486	TFL -61 -61T075A		LC DCC FEED TANK	INSULATION TEST MOTOR&INSPEC.MCC-61TN75A	1Y						T							RLB	RLB-ELBO	A	INS	141497	171104
4,487	TFL -61 -61T075A		LC DCC FEED TANK	PM MCC MODULE&INSPECTION MOTOR 61TN075A	1Y						I							RLB	RLB-ELBO	A	PMS	187909	218699
4,488	TFL -61 -61T075A		LC DCC FEED TANK	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN75A	1Y									I				RLB	RLB-ELBO	A	PMT	157744	188421
4,489	TFL -61 -61T075A		LC DCC FEED TANK	VERIFICATION : LT612701	1Y		V											RLB	RLB-ILBO	A	PMT	53242	55072
4,490	TFL -61 -61T075A		LC DCC FEED TANK	FUNCTION TEST : TCV612701	1Y			F										RLB	RLB-ILBO	A	PMT	53243	55073
4,491	TFL -61 -61T075A		LC DCC FEED TANK	INSPECTION : TE612701	1Y		I											RLB	RLB-ILBO	A	PMT	53244	55074
4,492	TFL -61 -61T075A		LC DCC FEED TANK	Inspection TFL-61TN75A	6M						I						I	RLB	RLB-MLBO	A	PMT	54323	56153
4,493	TFL -61 -61T075A		LC DCC FEED TANK	LUBRICATION TFL-61TN075A	2M		L		L		L		L		L		L	RLB	RLB-MLBO	A	PMT	84683	110076
4,494	TFL -61 -61T075A		LC DCC FEED TANK	PM ROOFVENT&EVC 61T075A	3M		I			I			I			I		RLB	RLB-MLBO	A	PMT	109621	136984
4,495	TFL -61 -61T075B		LC DCC FEED TANK	Inservice tank inspection by LAW	1Y							I						IRI	IRI-INTP	A	SM	55364	57194
4,496	TFL -61 -61T075B		LC DCC FEED TANK	VIBRATION INSP & ANALYSIS M/C	2M		I		I		I		I		I		I	IRI	IRI-INVB	A	INT	95207	119716
4,497	TFL -61 -61T075B		LC DCC FEED TANK	INSULATION TEST MOTOR&INSPEC.MCC-61TN75B	1Y						T							RLB	RLB-ELBO	A	INS	141499	171106
4,498	TFL -61 -61T075B		LC DCC FEED TANK	PM MCC MODULE&INSPECTION MOTOR 61TN075B	1Y						I							RLB	RLB-ELBO	A	PMS	187910	218700
4,499	TFL -61 -61T075B		LC DCC FEED TANK	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN75B	1Y									I				RLB	RLB-ELBO	A	PMT	157745	188422
4,500	TFL -61 -61T075B		LC DCC FEED TANK	VERIFICATION : LT612702	1Y							V						RLB	RLB-ILBO	A	PMT	53245	55075
4,501	TFL -61 -61T075B		LC DCC FEED TANK	FUNCTION TEST : TCV612702	1Y				F									RLB	RLB-ILBO	A	PMT	53246	55076
4,502	TFL -61 -61T075B		LC DCC FEED TANK	INSPECTION : TE612702	1Y							I						RLB	RLB-ILBO	A	PMT	53247	55077
4,503	TFL -61 -61T075B		LC DCC FEED TANK	Inspection TFL-61TN75B	6M						I						I	RLB	RLB-MLBO	A	PMT	54324	56154
4,504	TFL -61 -61T075B		LC DCC FEED TANK	LUBRICATION TFL-61TN075B	2M		L		L		L		L		L		L	RLB	RLB-MLBO	A	PMT	84684	110077
4,505	TFL -61 -61T075B		LC DCC FEED TANK	PM ROOFVENT&EVC 61T075B	3M			I			I			I			I	RLB	RLB-MLBO	A	PMT	109628	136991
4,506	TFL -61 -61T076A		LC FUEL OIL TANK	Inservice tank inspection by LAW	1Y							I						IRI	IRI-INTP	B	SM	55366	57196
4,507	TFL -61 -61T076A		LC FUEL OIL TANK	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB	B	INT	95158	119656
4,508	TFL -61 -61T076A		LC FUEL OIL TANK	PM MCC MODULE&INSPECTION MOTOR 61TN076A	1Y					I								RLB	RLB-ELBO	B	PMS	187911	218701
4,509	TFL -61 -61T076A		LC FUEL OIL TANK	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN76A	1Y							I						RLB	RLB-ELBO	B	PMT	157669	188347
4,510	TFL -61 -61T076A		LC FUEL OIL TANK	VERIFICATION : LT612301	1Y											V		RLB	RLB-ILBO	B	PMT	53248	55078
4,511	TFL -61 -61T076A		LC FUEL OIL TANK	VERIFICATION : TT612303	1Y										V			RLB	RLB-ILBO	B	PMT	53250	55080
4,512	TFL -61 -61T076A		LC FUEL OIL TANK	FUNCTION TEST : TV612303	1Y										F			RLB	RLB-ILBO	B	PMT	53251	55081
4,513	TFL -61 -61T076A		LC FUEL OIL TANK	INSPECTION : TE612301	1Y											I		RLB	RLB-ILBO	B	PMT	53252	55082
4,514	TFL -61 -61T076A		LC FUEL OIL TANK	Inspection TFL-61TN76A	6M						I						I	RLB	RLB-MLBO	B	PMT	54325	56155
4,515	TFL -61 -61T076A		LC FUEL OIL TANK	Lubrication TFL-61TN76A	2M		L		L		L		L		L		L	RLB	RLB-MLBO	B	PMT	80039	99006
4,516	TFL -61 -61T076A		LC FUEL OIL TANK	PM FRAMEARRESTOR&EVC 61T076A	3M	I			I			I			I			RLB	RLB-MLBO	B	PMT	109674	137035
4,517	TFL -61 -61T076B		LC FUEL OIL TANK	Inservice tank inspection by LAW	1Y								I					IRI	IRI-INTP	B	SM	55368	57198
4,518	TFL -61 -61T076B		LC FUEL OIL TANK	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB	B	INT	95160	119657
4,519	TFL -61 -61T076B		LC FUEL OIL TANK	PM MCC MODULE&INSPECTION MOTOR 61TN076B	1Y					I								RLB	RLB-ELBO	B	PMS	187912	218702
4,520	TFL -61 -61T076B		LC FUEL OIL TANK	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN76B	1Y							I						RLB	RLB-ELBO	B	PMT	157670	188348
4,521	TFL -61 -61T076B		LC FUEL OIL TANK	VERIFICATION : LT612302	1Y				V									RLB	RLB-ILBO	B	PMT	53253	55083
4,522	TFL -61 -61T076B		LC FUEL OIL TANK	VERIFICATION : TT612304	1Y										V			RLB	RLB-ILBO	B	PMT	53255	55085
4,523	TFL -61 -61T076B		LC FUEL OIL TANK	FUNCTION TEST : TV612304	1Y										F			RLB	RLB-ILBO	B	PMT	53256	55086
4,524	TFL -61 -61T076B		LC FUEL OIL TANK	INSPECTION : TE612302	1Y				I									RLB	RLB-ILBO	B	PMT	53257	55087
4,525	TFL -61 -61T076B		LC FUEL OIL TANK	Inspection TFL-61TN76B	6M						I						I	RLB	RLB-MLBO	B	PMT	54326	56156
4,526	TFL -61 -61T076B		LC FUEL OIL TANK	Lubrication TFL-61TN76B	2M		L		L		L		L		L		L	RLB	RLB-MLBO	B	PMT	80040	99007
4,527	TFL -61 -61T076B		LC FUEL OIL TANK	PM FRAMEARRESTOR&EVC 61T076B	3M			I			I			I			I	RLB	RLB-MLBO	B	PMT	109610	136973
4,528	TFL -61 -61T077		LC EXOL SLOP TANK	Inservice tank inspection by LAW	1Y								I					IRI	IRI-INTP		SM	55370	57200
4,529	TFL -61 -61T077		LC EXOL SLOP TANK	VERIFICATION : LT611301	1Y					V								RLB	RLB-ILBO		PMT	53258	55088
4,530	TFL -61 -61T077		LC EXOL SLOP TANK	FUNCTION TEST : PCV611301	1Y			F										RLB	RLB-ILBO		PMT	53259	55089
4,531	TFL -61 -61T077		LC EXOL SLOP TANK	FUNCTION TEST : TCV611301	1Y			F										RLB	RLB-ILBO		PMT	53260	55090
4,532	TFL -61 -61T077		LC EXOL SLOP TANK	INSPECTION : TE611301	1Y					I								RLB	RLB-ILBO		PMT	53261	55091
4,533	TFL -61 -61T077		LC EXOL SLOP TANK	PM BREATHER VALVE&EVC 61T077	3M			I			I			I			I	RLB	RLB-MLBO		PMT	109646	137009
4,534	TFL -61 -61T078		LC SLACK WAX (150N) TANK	Inservice tank inspection by LAW	1Y								I					IRI	IRI-INTP		SM	55372	57202
4,535	TFL -61 -61T078		LC SLACK WAX (150N) TANK	VERIFICATION : LT613701	1Y		V											RLB	RLB-ILBO		PMT	53262	55092
4,536	TFL -61 -61T078		LC SLACK WAX (150N) TANK	FUNCTION TEST : TCV613701	1Y						F							RLB	RLB-ILBO		PMT	53263	55093

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,537	TFL -61 -61T078		LC SLACK WAX (150N) TANK	INSPECTION : TE613701	1Y			I										RLB	RLB-ILBO		PMT	53264	55094
4,538	TFL -61 -61T078		LC SLACK WAX (150N) TANK	PM ROOFVENT&EVC 61T078	3M	I			I			I			I			RLB	RLB-MLBO		PMT	109614	136977
4,539	TFL -61 -61T079		LC SLACK WAX (OTHERS) TANK	Inservice tank inspection by LAW	1Y								I					IRI	IRI-INTP		SM	55374	57204
4,540	TFL -61 -61T079		LC SLACK WAX (OTHERS) TANK	VERIFICATION : LT613702	1Y		V											RLB	RLB-ILBO		PMT	53265	55095
4,541	TFL -61 -61T079		LC SLACK WAX (OTHERS) TANK	FUNCTION TEST : TCV613702	1Y						F							RLB	RLB-ILBO		PMT	53266	55096
4,542	TFL -61 -61T079		LC SLACK WAX (OTHERS) TANK	INSPECTION : TE613702	1Y		I											RLB	RLB-ILBO		PMT	53267	55097
4,543	TFL -61 -61T079		LC SLACK WAX (OTHERS) TANK	VERIFICATION : TT613703	1Y												V	RLB	RLB-ILBO		PMT	53269	55099
4,544	TFL -61 -61T079		LC SLACK WAX (OTHERS) TANK	PM ROOFVENT&EVC 61T079	3M			I			I			I			I	RLB	RLB-MLBO		PMT	109635	136998
4,545	TFL -61 -61T080		LC FRESH C3 LPG TANK	Pressure Relief Device Calibration (LAW)	1Y							I						IRI	IRI-INTP		SM	97882	122374
4,546	TFL -61 -61T080		LC FRESH C3 LPG TANK	Pressure Relief Device Calibration (LAW)	1Y							I						IRI	IRI-INTP		SM	97883	122375
4,547	TFL -61 -61T080		LC FRESH C3 LPG TANK	LSLL615102-INSPECTION LEVEL DISPLACER SW	1Y							I						RLB	RLB-ILBO		INS	151711	181759
4,548	TFL -61 -61T080		LC FRESH C3 LPG TANK	VERIFICATION : LT615101	1Y			V										RLB	RLB-ILBO		PMT	53270	55100
4,549	TFL -61 -61T080		LC FRESH C3 LPG TANK	FUNCTION TEST : LV615101	1Y			F										RLB	RLB-ILBO		PMT	53271	55101
4,550	TFL -61 -61T080		LC FRESH C3 LPG TANK	Pressure Relief Device Calibration ByLAW	1Y							I						RLB	RLB-MLBO		INT	154167	184124
4,551	TFL -61 -61T081		LC RECYCLE C3 LPG TANK	Pressure Relief Device Calibration (LAW)	1Y								I					IRI	IRI-INTP		SM	105297	130998
4,552	TFL -61 -61T081		LC RECYCLE C3 LPG TANK	Pressure Relief Device Calibration (LAW)	1Y								I					IRI	IRI-INTP		SM	105298	130999
4,553	TFL -61 -61T081		LC RECYCLE C3 LPG TANK	PM INSPEC.&TEST DELUGE VALVE SYSTEM-TFL	1Y												I	RLB	RLB-ELBO		PMT	79387	98040
4,554	TFL -61 -61T081		LC RECYCLE C3 LPG TANK	VERIFICATION : LT615201	1Y	V												RLB	RLB-ILBO		PMT	53273	55103
4,555	TFL -61 -61T081		LC RECYCLE C3 LPG TANK	INSPECTION : TE615201	1Y	I												RLB	RLB-ILBO		PMT	53274	55104
4,556	TFL -61 -61T082		LC RECYCLE C3 LPG TANK	Pressure Relief Device Calibration (LAW)	1Y							I						IRI	IRI-INTP		SM	105293	130994
4,557	TFL -61 -61T082		LC RECYCLE C3 LPG TANK	Pressure Relief Device Calibration (LAW)	1Y							I						IRI	IRI-INTP		SM	105296	130997
4,558	TFL -61 -61T082		LC RECYCLE C3 LPG TANK	PM INSPEC.&TEST DELUGE VALVE SYSTEM-TFL	1Y												I	RLB	RLB-ELBO		PMT	269954	302789
4,559	TFL -61 -61T082		LC RECYCLE C3 LPG TANK	VERIFICATION : LT615202	1Y	V												RLB	RLB-ILBO		PMT	53275	55105
4,560	TFL -61 -61T082		LC RECYCLE C3 LPG TANK	INSPECTION : TE615202	1Y	I												RLB	RLB-ILBO		PMT	53276	55106
4,561	TFL -61 -61T083		TRUCK LOADING SLOP OIL SUMP	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN83	1Y				I									RLB	RLB-ELBO	B	PMT	157755	188432
4,562	TFL -61 -61T083		TRUCK LOADING SLOP OIL SUMP	FUNCTION TEST : LS614601	1Y											F		RLB	RLB-ILBO	B	PMT	53277	55107
4,563	TFL -61 -61T084		BITUMEN SLOP OIL SUMP	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN84	1Y				I									RLB	RLB-ELBO	C	PMT	157756	188433
4,564	TFL -61 -61T085A		Tank 61T085A	PM; MCC MODULE&INSPECTION MOTOR 61TN085A	1Y						I							RLB	RLB-ELBO	B	PMS	187913	218703
4,565	TFL -61 -61T085A		Tank 61T085A	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN85A	1Y				I									RLB	RLB-ELBO	B	PMT	157752	188429
4,566	TFL -61 -61T085B		Tank 61T085B	PM; MCC MODULE&INSPECTION MOTOR 61TN085B	1Y						I							RLB	RLB-ELBO	B	PMS	187914	218704
4,567	TFL -61 -61T085B		Tank 61T085B	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN85B	1Y				I									RLB	RLB-ELBO	B	PMT	157753	188430
4,568	TFL -61 -61T085C		Tank 61T085C	PM; MCC MODULE&INSPECTION MOTOR 61TN085C	1Y						I							RLB	RLB-ELBO	B	PMS	187915	218705
4,569	TFL -61 -61T085C		Tank 61T085C	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN85C	1Y				I									RLB	RLB-ELBO	B	PMT	157754	188431
4,570	TFL -61 -61T101		LPG MIX TANK	Pressure Relief Device Calibration (LAW)	1Y							I						IRI	IRI-INTP		SM	97880	122372
4,571	TFL -61 -61T101		LPG MIX TANK	Pressure Relief Device Calibration (LAW)	1Y							I						IRI	IRI-INTP		SM	154168	184125
4,572	TFL -61 -61T101		LPG MIX TANK	VERIFICATION : LT610201	1Y							V						RLB	RLB-ILBO		PMT	53278	55108
4,573	TFL -61 -61T101		LPG MIX TANK	FUNCTION TEST : LV6110201	1Y							F						RLB	RLB-ILBO		PMT	53279	55109
4,574	TFL -61 -61T101		LPG MIX TANK	FUNCTION TEST : PCV6110203	1Y		F											RLB	RLB-ILBO		PMT	53280	55110
4,575	TFL -61 -61T101		LPG MIX TANK	Pressure Relief Device Calibration ByLAW	1Y							I						RLB	RLB-MLBO		INT	154169	184126
4,576	TFL -61 -61T102		LC FUEL OIL DAY TANK	Inservice tank inspection by LAW	1Y								I					IRI	IRI-INTP		SM	55376	57206
4,577	TFL -61 -61T102		LC FUEL OIL DAY TANK	INSPECTION : LT6110101	1Y		I											RLB	RLB-ILBO		PMT	53281	55111
4,578	TFL -61 -61T102		LC FUEL OIL DAY TANK	VERIFICATION : TT6110102	1Y							V						RLB	RLB-ILBO		PMT	53283	55113
4,579	TFL -61 -61T102		LC FUEL OIL DAY TANK	FUNCTION TEST : TV6110102	1Y							F						RLB	RLB-ILBO		PMT	53284	55114
4,580	TFL -61 -61T102		LC FUEL OIL DAY TANK	PM ROOFVENT&EVC 61T102	3M			I			I			I			I	RLB	RLB-MLBO		PMT	109634	136997
4,581	TFL -61 -61T102		LC FUEL OIL DAY TANK	INSPECTION : TE6110101	1Y		I											RTP	RTP-ITP2		PMT	53285	55115
4,582	TFL -61 -61T105		61T105	FUNCTION TEST : LSHL0003	1Y											F		RLB	RLB-ILBO		PMT	53286	55116
4,583	TFL -61 -61TN062A -N01		BLOWN ASPHALT (10/20) AGITATOR	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB		INT	95140	119627
4,584	TFL -61 -61TN062B -N01		BLOWN ASPHALT (10/20) AGITATOR	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB		INT	95142	119628
4,585	TFL -61 -61TN063A -N01		BLOWN ASPHALT (60/70) AGITATOR	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB		INT	95144	119649
4,586	TFL -61 -61TN063B -N01		BLOWN ASPHALT (60/70) AGITATOR	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB		INT	95147	119650
4,587	TFL -61 -61TN064A -N01		BLOWN ASPHALT (60/70) AGITATOR	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB		INT	95149	119651
4,588	TFL -61 -61TN064B -N01		BLOWN ASPHALT (60/70) AGITATOR	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB		INT	95151	119652
4,589	TFL -61 -61TN064C -N01		BLOWN ASPHALT (60/70) AGITATOR	VIBRATION INSP & ANALYSIS M/C	2M	I		I		I		I		I		I		IRI	IRI-INVB		INT	95152	119653
4,590	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	INSPECTION : FQ614801	1Y									I				RLB	RLB-ILBO		PMT	53298	55128

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,591	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	CALIBRATE : FT614801	1Y										V			RLB	RLB-ILBO		PMT	53299	55129
4,592	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : FV614801	1Y									F				RLB	RLB-ILBO		PMT	53300	55130
4,593	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	INSPECTION : FQ614802	1Y									I				RLB	RLB-ILBO		PMT	53301	55131
4,594	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	CALIBRATE : FT614802	1Y										V			RLB	RLB-ILBO		PMT	53302	55132
4,595	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : FV614802	1Y									F				RLB	RLB-ILBO		PMT	53303	55133
4,596	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	INSPECTION : FQ614803	1Y									I				RLB	RLB-ILBO		PMT	53304	55134
4,597	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	CALIBRATE : FT614803	1Y										V			RLB	RLB-ILBO		PMT	53305	55135
4,598	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : FV614803	1Y									F				RLB	RLB-ILBO		PMT	53306	55136
4,599	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	INSPECTION : FQ614804	1Y									I				RLB	RLB-ILBO		PMT	53307	55137
4,600	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	CALIBRATE : FT614804	1Y										V			RLB	RLB-ILBO		PMT	53308	55138
4,601	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : FV614804	1Y									F				RLB	RLB-ILBO		PMT	53309	55139
4,602	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	INSPECTION : FQ614805	1Y									I				RLB	RLB-ILBO		PMT	53310	55140
4,603	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	CALIBRATE : FT614805	1Y										V			RLB	RLB-ILBO		PMT	53311	55141
4,604	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : FV614805	1Y									F				RLB	RLB-ILBO		PMT	53312	55142
4,605	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	INSPECTION : FQ614806	1Y									I				RLB	RLB-ILBO		PMT	53313	55143
4,606	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	CALIBRATE : FT614806	1Y										V			RLB	RLB-ILBO		PMT	53314	55144
4,607	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : FV614806	1Y									F				RLB	RLB-ILBO		PMT	53315	55145
4,608	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : LIS614801	1Y									F				RLB	RLB-ILBO		PMT	53316	55146
4,609	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : PT614801	1Y									V				RLB	RLB-ILBO		PMT	53317	55147
4,610	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : PT614802	1Y									V				RLB	RLB-ILBO		PMT	53318	55148
4,611	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : PT614803	1Y									V				RLB	RLB-ILBO		PMT	53319	55149
4,612	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : PT614804	1Y									V				RLB	RLB-ILBO		PMT	53320	55150
4,613	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : PT614805	1Y									V				RLB	RLB-ILBO		PMT	53321	55151
4,614	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : PT614806	1Y									V				RLB	RLB-ILBO		PMT	53322	55152
4,615	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : TIC614801	1Y											F		RLB	RLB-ILBO		PMT	53324	55154
4,616	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : TT614801	1Y									V				RLB	RLB-ILBO		PMT	53325	55155
4,617	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	FUNCTION TEST : TV614801	1Y											F		RLB	RLB-ILBO		PMT	53326	55156
4,618	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : TT614802	1Y									V				RLB	RLB-ILBO		PMT	53332	55162
4,619	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : TT614803	1Y									V				RLB	RLB-ILBO		PMT	53333	55163
4,620	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : TT614804	1Y									V				RLB	RLB-ILBO		PMT	53334	55164
4,621	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : TT614805	1Y									V				RLB	RLB-ILBO		PMT	53335	55165
4,622	TFL -61 -ASPH		WEIGHT SCALE LINE A OF ASPH DRUMMING	VERIFICATION : TT614806	1Y									V				RLB	RLB-ILBO		PMT	53336	55166
4,623	TFL -61 -CV		CONTROL VALVE	HV615102-INSPECTION SHUT-OFF VALVE	1Y										I			RLB	RLB-ILBO		INS	151714	181762
4,624	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV610101	1Y										F			RLB	RLB-ILBO		PMT	53412	55242
4,625	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV610201	1Y										F			RLB	RLB-ILBO		PMT	53414	55244
4,626	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV0369	1Y					F								RLB	RLB-ILBO		PMT	53416	55246
4,627	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV610401	1Y										F			RLB	RLB-ILBO		PMT	53418	55248
4,628	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV610801	1Y										F			RLB	RLB-ILBO		PMT	53420	55250
4,629	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV611001	1Y										F			RLB	RLB-ILBO		PMT	53422	55252
4,630	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV611002	1Y							F						RLB	RLB-ILBO		PMT	53424	55254
4,631	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV611003	1Y									F				RLB	RLB-ILBO		PMT	53426	55256
4,632	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV611004	1Y							F						RLB	RLB-ILBO		PMT	53428	55258
4,633	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV611101	1Y										F			RLB	RLB-ILBO		PMT	53430	55260
4,634	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV611901	1Y										F			RLB	RLB-ILBO		PMT	53432	55262
4,635	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612401	1Y								F					RLB	RLB-ILBO		PMT	53434	55264
4,636	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612402	1Y								F					RLB	RLB-ILBO		PMT	53436	55266
4,637	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612601	1Y											F		RLB	RLB-ILBO		PMT	53438	55268
4,638	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612701	1Y											F		RLB	RLB-ILBO		PMT	53440	55270
4,639	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612801	1Y											F		RLB	RLB-ILBO		PMT	53442	55272
4,640	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612802	1Y											F		RLB	RLB-ILBO		PMT	53444	55274
4,641	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612901	1Y											F		RLB	RLB-ILBO		PMT	53446	55276
4,642	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV612902	1Y											F		RLB	RLB-ILBO		PMT	53448	55278
4,643	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV613001	1Y											F		RLB	RLB-ILBO		PMT	53450	55280
4,644	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV613101	1Y											F		RLB	RLB-ILBO		PMT	53452	55282

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,645	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV613102	1Y											F		RLB	RLB-ILBO		PMT	53454	55284
4,646	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV613301	1Y												F	RLB	RLB-ILBO		PMT	53456	55286
4,647	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV613302	1Y												F	RLB	RLB-ILBO		PMT	53458	55288
4,648	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV613501	1Y												F	RLB	RLB-ILBO		PMT	53460	55290
4,649	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV613502	1Y												F	RLB	RLB-ILBO		PMT	53462	55292
4,650	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV615102	1Y												F	RLB	RLB-ILBO		PMT	53464	55294
4,651	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV615201	1Y												F	RLB	RLB-ILBO		PMT	53466	55296
4,652	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV615202	1Y												F	RLB	RLB-ILBO		PMT	53468	55298
4,653	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : FV615203	1Y										F			RLB	RLB-ILBO		PMT	53470	55300
4,654	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV610201	1Y										F			RLB	RLB-ILBO		PMT	53573	55403
4,655	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV6110101	1Y										F			RLB	RLB-ILBO		PMT	53575	55405
4,656	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV6110201	1Y										F			RLB	RLB-ILBO		PMT	53577	55407
4,657	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV6110202	1Y										F			RLB	RLB-ILBO		PMT	53579	55409
4,658	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV6110252	1Y										F			RLB	RLB-ILBO		PMT	53581	55411
4,659	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV611201	1Y										F			RLB	RLB-ILBO		PMT	53583	55413
4,660	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV612201	1Y										F			RLB	RLB-ILBO		PMT	53585	55415
4,661	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV612301	1Y										F			RLB	RLB-ILBO		PMT	53587	55417
4,662	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV612401	1Y										F			RLB	RLB-ILBO		PMT	53589	55419
4,663	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV612402	1Y										F			RLB	RLB-ILBO		PMT	53591	55421
4,664	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV612501	1Y										F			RLB	RLB-ILBO		PMT	53593	55423
4,665	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV612502	1Y										F			RLB	RLB-ILBO		PMT	53595	55425
4,666	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV613701	1Y										F			RLB	RLB-ILBO		PMT	53597	55427
4,667	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV613702	1Y										F			RLB	RLB-ILBO		PMT	53599	55429
4,668	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV614001	1Y												F	RLB	RLB-ILBO		PMT	53601	55431
4,669	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV614101	1Y												F	RLB	RLB-ILBO		PMT	53603	55433
4,670	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV614102	1Y												F	RLB	RLB-ILBO		PMT	53605	55435
4,671	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV614201	1Y												F	RLB	RLB-ILBO		PMT	53607	55437
4,672	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV614202	1Y												F	RLB	RLB-ILBO		PMT	53609	55439
4,673	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV615101	1Y												F	RLB	RLB-ILBO		PMT	53611	55441
4,674	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV615201	1Y												F	RLB	RLB-ILBO		PMT	53613	55443
4,675	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV615202	1Y												F	RLB	RLB-ILBO		PMT	53615	55445
4,676	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : PV619573	1Y												F	RLB	RLB-ILBO		PMT	53617	55447
4,677	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : TV6110103	1Y							F						RLB	RLB-ILBO		PMT	53630	55460
4,678	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : HV615102	1Y										F			RLB	RLB-ILBO		PMT	53721	55551
4,679	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : HV615201	1Y										F			RLB	RLB-ILBO		PMT	53722	55552
4,680	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : HV615202	1Y										F			RLB	RLB-ILBO		PMT	53723	55553
4,681	TFL -61 -CV		CONTROL VALVE	FUNCTION TEST : XV000301	1Y										F			RLB	RLB-ILBO		PMT	53724	55554
4,682	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT610101	1Y										V			RLB	RLB-ILBO	B	PMT	53411	55241
4,683	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT610201	1Y										V			RLB	RLB-ILBO	B	PMT	53413	55243
4,684	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT0369	1Y					V								RLB	RLB-ILBO	B	PMT	53415	55245
4,685	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT610401	1Y										V			RLB	RLB-ILBO	B	PMT	53417	55247
4,686	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT610801	1Y										V			RLB	RLB-ILBO	B	PMT	53419	55249
4,687	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT611001	1Y										V			RLB	RLB-ILBO	B	PMT	53421	55251
4,688	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT611002	1Y							V						RLB	RLB-ILBO	B	PMT	53423	55253
4,689	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT611003	1Y									V				RLB	RLB-ILBO	B	PMT	53425	55255
4,690	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT611004	1Y							V						RLB	RLB-ILBO	B	PMT	53427	55257
4,691	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT611101	1Y										V			RLB	RLB-ILBO	B	PMT	53429	55259
4,692	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT611901	1Y										V			RLB	RLB-ILBO	B	PMT	53431	55261
4,693	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612401	1Y								V					RLB	RLB-ILBO	B	PMT	53433	55263
4,694	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612402	1Y								V					RLB	RLB-ILBO	B	PMT	53435	55265
4,695	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612601	1Y											V		RLB	RLB-ILBO	B	PMT	53437	55267
4,696	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612701	1Y											V		RLB	RLB-ILBO	B	PMT	53439	55269
4,697	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612801	1Y											V		RLB	RLB-ILBO	B	PMT	53441	55271
4,698	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612802	1Y											V		RLB	RLB-ILBO	B	PMT	53443	55273

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,699	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612901	1Y											V		RLB	RLB-ILBO	B	PMT	53445	55275
4,700	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT612902**	**1Y**											**V**		**RLB**	**RLB-ILBO**	**B**	**PMT**	**53447**	**55277**
4,701	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT613001	1Y											V		RLB	RLB-ILBO	B	PMT	53449	55279
4,702	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT613101**	**1Y**											**V**		**RLB**	**RLB-ILBO**	**B**	**PMT**	**53451**	**55281**
4,703	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT613102	1Y											V		RLB	RLB-ILBO	B	PMT	53453	55283
4,704	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT613301**	**1Y**												**V**	**RLB**	**RLB-ILBO**	**B**	**PMT**	**53455**	**55285**
4,705	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT613302	1Y												V	RLB	RLB-ILBO	B	PMT	53457	55287
4,706	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT613501**	**1Y**												**V**	**RLB**	**RLB-ILBO**	**B**	**PMT**	**53459**	**55289**
4,707	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT613502	1Y												V	RLB	RLB-ILBO	B	PMT	53461	55291
4,708	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT615102**	**1Y**												**V**	**RLB**	**RLB-ILBO**	**B**	**PMT**	**53463**	**55293**
4,709	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT615201	1Y												V	RLB	RLB-ILBO	B	PMT	53465	55295
4,710	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT615202**	**1Y**												**V**	**RLB**	**RLB-ILBO**	**B**	**PMT**	**53467**	**55297**
4,711	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT615203	1Y										V			RLB	RLB-ILBO	B	PMT	53469	55299
4,712	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT0004**	**1Y**		**V**											**RLB**	**RLB-ILBO**	**B**	**PMT**	**53471**	**55301**
4,713	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT0005	1Y		V											RLB	RLB-ILBO	B	PMT	53472	55302
4,714	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT0006**	**1Y**		**V**											**RLB**	**RLB-ILBO**	**B**	**PMT**	**53473**	**55303**
4,715	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT0007	1Y		V											RLB	RLB-ILBO	B	PMT	53474	55304
4,716	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT0008**	**1Y**			**V**										**RLB**	**RLB-ILBO**	**B**	**PMT**	**53475**	**55305**
4,717	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT0009	1Y			V										RLB	RLB-ILBO	B	PMT	53476	55306
4,718	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT0010**	**1Y**			**V**										**RLB**	**RLB-ILBO**	**B**	**PMT**	**53477**	**55307**
4,719	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT0011	1Y			V										RLB	RLB-ILBO	B	PMT	53478	55308
4,720	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT2001**	**1Y**	**V**												**RLB**	**RLB-ILBO**	**B**	**PMT**	**53479**	**55309**
4,721	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT2002	1Y	V												RLB	RLB-ILBO	B	PMT	53480	55310
4,722	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT2007**	**1Y**	**V**												**RLB**	**RLB-ILBO**	**B**	**PMT**	**53481**	**55311**
4,723	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT2008	1Y	V												RLB	RLB-ILBO	B	PMT	53482	55312
4,724	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT2011**	**1Y**		**V**											**RLB**	**RLB-ILBO**	**B**	**PMT**	**53483**	**55313**
4,725	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT2012	1Y		V											RLB	RLB-ILBO	B	PMT	53484	55314
4,726	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT2013**	**1Y**		**V**											**RLB**	**RLB-ILBO**	**B**	**PMT**	**53485**	**55315**
4,727	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612301	1Y										V			RLB	RLB-ILBO	B	PMT	53486	55316
4,728	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT612302**	**1Y**										**V**			**RLB**	**RLB-ILBO**	**B**	**PMT**	**53487**	**55317**
4,729	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612303	1Y			V										RLB	RLB-ILBO	B	PMT	53488	55318
4,730	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT612304**	**1Y**										**V**			**RLB**	**RLB-ILBO**	**B**	**PMT**	**53489**	**55319**
4,731	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612305	1Y										V			RLB	RLB-ILBO	B	PMT	53490	55320
4,732	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT612306**	**1Y**										**V**			**RLB**	**RLB-ILBO**	**B**	**PMT**	**53491**	**55321**
4,733	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612307	1Y										V			RLB	RLB-ILBO	B	PMT	53492	55322
4,734	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT612803**	**1Y**												**V**	**RLB**	**RLB-ILBO**	**B**	**PMT**	**53493**	**55323**
4,735	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT612804	1Y												V	RLB	RLB-ILBO	B	PMT	53494	55324
4,736	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT613103**	**1Y**												**V**	**RLB**	**RLB-ILBO**	**B**	**PMT**	**53495**	**55325**
4,737	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT613703	1Y												V	RLB	RLB-ILBO	B	PMT	53496	55326
4,738	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION : FT615101**	**1Y**												**V**	**RLB**	**RLB-ILBO**	**B**	**PMT**	**53497**	**55327**
4,739	TFL -61 -FLOW		Beneral Flow Device for Unit61	VERIFICATION : FT617501	1Y	V												RLB	RLB-ILBO	B	PMT	53498	55328
4,740	**TFL -61 -FLOW**		**Beneral Flow Device for Unit61**	**VERIFICATION FLOW TFL-FI0008A**	**1Y**				**V**									**RLB**	**RLB-ILBO**	**B**	**PMT**	**81204**	**100955**
4,741	TFL -61 -LUBE_T/L		Lube Truck Load	INSP.UPS&BATTERYS OF DCS LUBE TRUCK LOAD	6M	I						I						RLB	RLB-ELBO		PMT	250473	282754
4,742	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**INSPECTION : FQ614401**	**1Y**						**I**							**RLB**	**RLB-ILBO**		**PMT**	**53499**	**55329**
4,743	TFL -61 -LUBE_T/L		Lube Truck Load	CALIBRATE : FT614401	6M		V						V					RLB	RLB-ILBO		PMT	53500	55330
4,744	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : FV614401**	**1Y**						**F**							**RLB**	**RLB-ILBO**		**PMT**	**53501**	**55331**
4,745	TFL -61 -LUBE_T/L		Lube Truck Load	INSPECTION : FQ614402	1Y						I							RLB	RLB-ILBO		PMT	53502	55332
4,746	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : FV614402**	**1Y**						**F**							**RLB**	**RLB-ILBO**		**PMT**	**53504**	**55334**
4,747	TFL -61 -LUBE_T/L		Lube Truck Load	INSPECTION : FQ614403	1Y						I							RLB	RLB-ILBO		PMT	53505	55335
4,748	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**CALIBRATE : FT614403**	**6M**		**V**						**V**					**RLB**	**RLB-ILBO**		**PMT**	**53506**	**55336**
4,749	TFL -61 -LUBE_T/L		Lube Truck Load	FUNCTION TEST : FV614403	1Y						F							RLB	RLB-ILBO		PMT	53507	55337
4,750	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**INSPECTION : FQ614501**	**1Y**						**I**							**RLB**	**RLB-ILBO**		**PMT**	**53508**	**55338**
4,751	TFL -61 -LUBE_T/L		Lube Truck Load	CALIBRATE : FT614501	6M		V						V					RLB	RLB-ILBO		PMT	53509	55339
4,752	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : FV614501**	**1Y**						**F**							**RLB**	**RLB-ILBO**		**PMT**	**53510**	**55340**

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,753	TFL -61 -LUBE_T/L		Lube Truck Load	INSPECTION : FQ614502	1Y						I							RLB	RLB-ILBO		PMT	53511	55341
4,754	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**CALIBRATE : FT614502**	**6M**		**V**						**V**					**RLB**	**RLB-ILBO**		**PMT**	**53512**	**55342**
4,755	TFL -61 -LUBE_T/L		Lube Truck Load	FUNCTION TEST : FV614502	1Y						F							RLB	RLB-ILBO		PMT	53513	55343
4,756	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**INSPECTION : FQ614503**	**1Y**						**I**							**RLB**	**RLB-ILBO**		**PMT**	**53514**	**55344**
4,757	TFL -61 -LUBE_T/L		Lube Truck Load	CALIBRATE : FT614503	6M		V						V					RLB	RLB-ILBO		PMT	53515	55345
4,758	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : FV614503**	**1Y**						**F**							**RLB**	**RLB-ILBO**		**PMT**	**53516**	**55346**
4,759	TFL -61 -LUBE_T/L		Lube Truck Load	INSPECTION : FQ614601	1Y						I							RLB	RLB-ILBO		PMT	53517	55347
4,760	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**CALIBRATE : FT614601**	**6M**		**V**						**V**					**RLB**	**RLB-ILBO**		**PMT**	**53518**	**55348**
4,761	TFL -61 -LUBE_T/L		Lube Truck Load	FUNCTION TEST : FV614601	1Y						F							RLB	RLB-ILBO		PMT	53519	55349
4,762	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**INSPECTION : FQ614603**	**1Y**						**I**							**RLB**	**RLB-ILBO**		**PMT**	**53520**	**55350**
4,763	TFL -61 -LUBE_T/L		Lube Truck Load	CALIBRATE : FT614603	6M		V						V					RLB	RLB-ILBO		PMT	53521	55351
4,764	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : FV614603**	**1Y**						**F**							**RLB**	**RLB-ILBO**		**PMT**	**53522**	**55352**
4,765	TFL -61 -LUBE_T/L		Lube Truck Load	INSPECTION : FQ614604	1Y						I							RLB	RLB-ILBO		PMT	53523	55353
4,766	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : FV614604**	**1Y**						**F**							**RLB**	**RLB-ILBO**		**PMT**	**53525**	**55355**
4,767	TFL -61 -LUBE_T/L		Lube Truck Load	INSPECTION : FQ614701	1Y									I				RLB	RLB-ILBO		PMT	53526	55356
4,768	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**CALIBRATE : FT614701**	**1Y**										**V**			**RLB**	**RLB-ILBO**		**PMT**	**53527**	**55357**
4,769	TFL -61 -LUBE_T/L		Lube Truck Load	FUNCTION TEST : FV614701	1Y									F				RLB	RLB-ILBO		PMT	53528	55358
4,770	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**INSPECTION : FQ614703**	**1Y**									**I**				**RLB**	**RLB-ILBO**		**PMT**	**53529**	**55359**
4,771	TFL -61 -LUBE_T/L		Lube Truck Load	CALIBRATE : FT614703	1Y										V			RLB	RLB-ILBO		PMT	53530	55360
4,772	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : FV614703**	**1Y**									**F**				**RLB**	**RLB-ILBO**		**PMT**	**53531**	**55361**
4,773	TFL -61 -LUBE_T/L		Lube Truck Load	INSPECTION : FQ614704	1Y									I				RLB	RLB-ILBO		PMT	53532	55362
4,774	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**CALIBRATE : FT614704**	**1Y**										**V**			**RLB**	**RLB-ILBO**		**PMT**	**53533**	**55363**
4,775	TFL -61 -LUBE_T/L		Lube Truck Load	FUNCTION TEST : FV614704	1Y									F				RLB	RLB-ILBO		PMT	53534	55364
4,776	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : PT614401**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53535**	**55365**
4,777	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : PT614402	1Y						V							RLB	RLB-ILBO		PMT	53536	55366
4,778	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : PT614403**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53537**	**55367**
4,779	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : PT614501	1Y						V							RLB	RLB-ILBO		PMT	53538	55368
4,780	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : PT614502**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53539**	**55369**
4,781	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : PT614503	1Y						V							RLB	RLB-ILBO		PMT	53540	55370
4,782	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : PT614601**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53541**	**55371**
4,783	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : PT614603	1Y						V							RLB	RLB-ILBO		PMT	53542	55372
4,784	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : PT614604**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53543**	**55373**
4,785	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : PT614701	1Y						V							RLB	RLB-ILBO		PMT	53544	55374
4,786	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : PT614703**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53545**	**55375**
4,787	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : PT614704	1Y						V							RLB	RLB-ILBO		PMT	53546	55376
4,788	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**FUNCTION TEST : TCV614601**	**1Y**									**F**				**RLB**	**RLB-ILBO**		**PMT**	**53547**	**55377**
4,789	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : TT614401	1Y						V							RLB	RLB-ILBO		PMT	53560	55390
4,790	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : TT614402**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53561**	**55391**
4,791	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : TT614403	1Y						V							RLB	RLB-ILBO		PMT	53562	55392
4,792	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : TT614501**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53563**	**55393**
4,793	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : TT614502	1Y						V							RLB	RLB-ILBO		PMT	53564	55394
4,794	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : TT614503**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53565**	**55395**
4,795	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : TT614601	1Y						V							RLB	RLB-ILBO		PMT	53566	55396
4,796	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : TT614603**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53567**	**55397**
4,797	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : TT614604	1Y						V							RLB	RLB-ILBO		PMT	53568	55398
4,798	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : TT614701**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53569**	**55399**
4,799	TFL -61 -LUBE_T/L		Lube Truck Load	VERIFICATION : TT614703	1Y						V							RLB	RLB-ILBO		PMT	53570	55400
4,800	**TFL -61 -LUBE_T/L**		**Lube Truck Load**	**VERIFICATION : TT614704**	**1Y**						**V**							**RLB**	**RLB-ILBO**		**PMT**	**53571**	**55401**
4,801	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	10Y						I							IRI	IRI-INTP		INT	197752	228752
4,802	**TFL -61 -PIPING**		**PIPING SYSTEM TFL UNIT 61**	**Piping Inspection (Class3)**	**10Y**						**I**							**IRI**	**IRI-INTP**		**INT**	**197753**	**228753**
4,803	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	10Y						I							IRI	IRI-INTP		INT	197754	228754
4,804	**TFL -61 -PIPING**		**PIPING SYSTEM TFL UNIT 61**	**Piping Inspection (Class3)**	**10Y**						**I**							**IRI**	**IRI-INTP**		**INT**	**197755**	**228755**
4,805	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	10Y						I							IRI	IRI-INTP		INT	197756	228756
4,806	**TFL -61 -PIPING**		**PIPING SYSTEM TFL UNIT 61**	**Piping Inspection (Class3)**	**10Y**						**I**							**IRI**	**IRI-INTP**		**INT**	**197761**	**228761**

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,807	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	10Y						I							IRI	IRI-INTP		INT	197762	228762
4,808	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	10Y						I							IRI	IRI-INTP		INT	197763	228763
4,809	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class4L)	5Y						I							IRI	IRI-INTP		INT	198234	229234
4,810	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class4L)	5Y						I							IRI	IRI-INTP		INT	198235	229235
4,811	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class4L)	5Y						I							IRI	IRI-INTP		INT	198236	229236
4,812	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class4L)	5Y						I							IRI	IRI-INTP		INT	198237	229237
4,813	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class4L)	5Y						I							IRI	IRI-INTP		INT	198238	229238
4,814	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203511	234367
4,815	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203512	234368
4,816	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203513	234369
4,817	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203514	234370
4,818	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203515	234371
4,819	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203516	234372
4,820	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203517	234373
4,821	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203518	234374
4,822	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	203519	234375
4,823	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203521	234377
4,824	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203522	234378
4,825	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203523	234379
4,826	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203524	234380
4,827	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203525	234381
4,828	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203526	234382
4,829	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203528	234384
4,830	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203529	234385
4,831	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203530	234386
4,832	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203531	234387
4,833	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203532	234388
4,834	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203533	234389
4,835	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203534	234390
4,836	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203535	234391
4,837	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203536	234392
4,838	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203537	234393
4,839	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203538	234394
4,840	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203539	234395
4,841	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203540	234396
4,842	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203541	234397
4,843	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203542	234398
4,844	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203543	234399
4,845	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203544	234400
4,846	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203545	234401
4,847	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203546	234402
4,848	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203547	234403
4,849	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203548	234404
4,850	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203549	234405
4,851	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203550	234406
4,852	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203551	234407
4,853	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203552	234408
4,854	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203553	234409
4,855	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203554	234410
4,856	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203555	234411
4,857	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203556	234412
4,858	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203557	234413
4,859	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203558	234414
4,860	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203559	234415

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,861	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203560	234416
4,862	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203561	234417
4,863	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203562	234418
4,864	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203563	234419
4,865	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203564	234420
4,866	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203565	234421
4,867	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203566	234422
4,868	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203567	234423
4,869	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203568	234424
4,870	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203569	234425
4,871	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203570	234426
4,872	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203571	234427
4,873	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203572	234428
4,874	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203573	234429
4,875	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203574	234430
4,876	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203575	234431
4,877	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203576	234432
4,878	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203577	234433
4,879	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203578	234434
4,880	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203579	234435
4,881	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203580	234436
4,882	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203581	234437
4,883	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203582	234438
4,884	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203583	234439
4,885	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203584	234440
4,886	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203585	234441
4,887	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203586	234442
4,888	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203587	234443
4,889	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203588	234444
4,890	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203589	234445
4,891	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203590	234446
4,892	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203591	234447
4,893	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203592	234448
4,894	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203593	234449
4,895	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203594	234450
4,896	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203595	234451
4,897	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203596	234452
4,898	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203597	234453
4,899	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203598	234454
4,900	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203599	234455
4,901	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203600	234456
4,902	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203601	234457
4,903	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203602	234458
4,904	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203603	234459
4,905	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203604	234460
4,906	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203605	234461
4,907	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203606	234462
4,908	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203607	234463
4,909	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203608	234464
4,910	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203609	234465
4,911	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	203610	234466
4,912	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	208623	239525
4,913	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	208629	239531
4,914	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	208631	239533

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,915	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	208632	239534
4,916	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	208640	239542
4,917	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	208648	239550
4,918	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class3)	5Y					I								IRI	IRI-INTP		INT	208649	239551
4,919	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	208660	239562
4,920	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	208661	239563
4,921	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	208662	239564
4,922	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	208663	239565
4,923	TFL -61 -PIPING		PIPING SYSTEM TFL UNIT 61	Piping Inspection (Class1)	5Y					I								IRI	IRI-INTP		INT	208664	239566
4,924	TFL -61 -PRD		General PRD for Unit61	Pressure Relief Device Calibration(CODE)	5Y	I												RLB	RLB-MLBO		INT	102749	128431
4,925	TFL -61 -PRD		General PRD for Unit61	Pressure Relief Device Calibration (CODE	5Y											I		RLB	RLB-MLBO		INT	161913	192740
4,926	TFL -61 -PRD		General PRD for Unit61	Pressure Relief Device Calibration (CODE	5Y											I		RLB	RLB-MLBO		INT	161933	192760
4,927	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT6102O1	1Y										V			RLB	RLB-ILBO		PMT	53572	55402
4,928	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT6110101	1Y										V			RLB	RLB-ILBO		PMT	53574	55404
4,929	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT6110201	1Y										V			RLB	RLB-ILBO		PMT	53576	55406
4,930	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT6110202	1Y										V			RLB	RLB-ILBO		PMT	53578	55408
4,931	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT6110252	1Y										V			RLB	RLB-ILBO		PMT	53580	55410
4,932	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT611201	1Y										V			RLB	RLB-ILBO		PMT	53582	55412
4,933	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612201	1Y										V			RLB	RLB-ILBO		PMT	53584	55414
4,934	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612301	1Y										V			RLB	RLB-ILBO		PMT	53586	55416
4,935	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612401	1Y										V			RLB	RLB-ILBO		PMT	53588	55418
4,936	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612402	1Y										V			RLB	RLB-ILBO		PMT	53590	55420
4,937	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612501	1Y										V			RLB	RLB-ILBO		PMT	53592	55422
4,938	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612502	1Y										V			RLB	RLB-ILBO		PMT	53594	55424
4,939	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT613701	1Y										V			RLB	RLB-ILBO		PMT	53596	55426
4,940	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT613702	1Y										V			RLB	RLB-ILBO		PMT	53598	55428
4,941	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT614001	1Y											V		RLB	RLB-ILBO		PMT	53600	55430
4,942	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT614101	1Y											V		RLB	RLB-ILBO		PMT	53602	55432
4,943	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT614102	1Y											V		RLB	RLB-ILBO		PMT	53604	55434
4,944	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT614201	1Y											V		RLB	RLB-ILBO		PMT	53606	55436
4,945	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT614202	1Y											V		RLB	RLB-ILBO		PMT	53608	55438
4,946	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT615101	1Y											V		RLB	RLB-ILBO		PMT	53610	55440
4,947	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT615201	1Y											V		RLB	RLB-ILBO		PMT	53612	55442
4,948	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT615202	1Y											V		RLB	RLB-ILBO		PMT	53614	55444
4,949	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT619573	1Y											V		RLB	RLB-ILBO		PMT	53616	55446
4,950	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT0006	1Y		V											RLB	RLB-ILBO		PMT	53618	55448
4,951	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT0007	1Y		V											RLB	RLB-ILBO		PMT	53619	55449
4,952	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT0009	1Y								V					RLB	RLB-ILBO		PMT	53620	55450
4,953	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612803	1Y												V	RLB	RLB-ILBO		PMT	53621	55451
4,954	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT612804	1Y												V	RLB	RLB-ILBO		PMT	53622	55452
4,955	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT613103	1Y												V	RLB	RLB-ILBO		PMT	53623	55453
4,956	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT613703	1Y												V	RLB	RLB-ILBO		PMT	53624	55454
4,957	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT617101	1Y						V							RLB	RLB-ILBO		PMT	53625	55455
4,958	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT617201	1Y						V							RLB	RLB-ILBO		PMT	53626	55456
4,959	TFL -61 -PRESS		General Pressre Device for Unit61	VERIFICATION : PT617202	1Y						V							RLB	RLB-ILBO		PMT	53627	55457
4,960	TFL -61 -QMI_GD		General Gas Detector for Unit61	INSPECTION GAS DETECTOR	4M				I				I				I	CAN	CAN-Q25		INT	249363	281558
4,961	TFL -61 -QMI_GD		General Gas Detector for Unit61	VERIFY GAS DETECTOR GD-6101	4M				V				V				V	CAN	CAN-Q25		PMT	249343	281633
4,962	TFL -61 -QMI_GD		General Gas Detector for Unit61	VERIFY GAS DETECTOR GD-6102	4M				V				V				V	CAN	CAN-Q25		PMT	249344	281634
4,963	TFL -61 -QMI_GD		General Gas Detector for Unit61	VERIFY GAS DETECTOR GD-6103	4M				V				V				V	CAN	CAN-Q25		PMT	249345	281635
4,964	TFL -61 -QMI_GD		General Gas Detector for Unit61	VERIFY GAS DETECTOR GD-6104	4M				V				V				V	CAN	CAN-Q25		PMT	249346	281636
4,965	TFL -61 -QMI_GD		General Gas Detector for Unit61	VERIFY GAS DETECTOR GD-6105	4M				V				V				V	CAN	CAN-Q25		PMT	249347	281637
4,966	TFL -61 -T61T026A		150 BS RAFFINATE AGITATOR	Inspection TFL-61TN26A	6M				I						I			RLB	RLB-MLBO		PMT	54327	56157
4,967	TFL -61 -T61T026A		150 BS RAFFINATE AGITATOR	Lubrication TFL-61TN26A	2M		L		L		L		L		L		L	RLB	RLB-MLBO		PMT	80036	99003
4,968	TFL -61 -TEMP		General Temp Device for Unit61	TT612851-INSPECTION TEMP.TRANS.& PROBE	1Y							I						RLB	RLB-ILBO		INS	264590	297239

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
4,969	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT6110103	1Y							V						RLB	RLB-ILBO		PMT	53629	55459
4,970	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT0007	1Y								V					RLB	RLB-ILBO		PMT	53648	55478
4,971	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT6110451	1Y									V				RLB	RLB-ILBO		PMT	53649	55479
4,972	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT6110851	1Y									V				RLB	RLB-ILBO		PMT	53650	55480
4,973	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT6111003	1Y									V				RLB	RLB-ILBO		PMT	53651	55481
4,974	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT6111051	1Y									V				RLB	RLB-ILBO		PMT	53652	55482
4,975	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT6111052	1Y										V			RLB	RLB-ILBO		PMT	53653	55483
4,976	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT6111951	1Y										V			RLB	RLB-ILBO		PMT	53654	55484
4,977	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT612503	1Y			V										RLB	RLB-ILBO		PMT	53655	55485
4,978	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT613051	1Y							V						RLB	RLB-ILBO		PMT	53657	55487
4,979	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT613351	1Y								V					RLB	RLB-ILBO		PMT	53658	55488
4,980	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT613352	1Y								V					RLB	RLB-ILBO		PMT	53659	55489
4,981	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT613551	1Y								V					RLB	RLB-ILBO		PMT	53660	55490
4,982	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT613552	1Y								V					RLB	RLB-ILBO		PMT	53661	55491
4,983	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT617101	1Y						V							RLB	RLB-ILBO		PMT	53662	55492
4,984	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT617201	1Y						V							RLB	RLB-ILBO		PMT	53663	55493
4,985	TFL -61 -TEMP		General Temp Device for Unit61	VERIFICATION : TT617202	1Y						V							RLB	RLB-ILBO		PMT	53664	55494
4,986	TFL -65 -CO2		CO2	PM INSPECTION AND TEST CO2 SYSTEM - TFL	1Y			I										RLB	RLB-ELBO	A	PMT	79386	98039
4,987	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P301" -PS#1	1Y				I									RLB	RLB-ELBO	C	PMS	79389	97793
4,988	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P303" -PS#3	1Y				I									RLB	RLB-ELBO	C	PMS	79390	97794
4,989	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P304" -PS#4	1Y				I									RLB	RLB-ELBO	C	PMS	79391	97795
4,990	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P305" -PS#5	1Y				I									RLB	RLB-ELBO	C	PMS	79392	97796
4,991	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P306" -PS#6	1Y				I									RLB	RLB-ELBO	C	PMS	79393	97797
4,992	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P307" -PS#7	1Y				I									RLB	RLB-ELBO	C	PMS	79394	97798
4,993	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P308" -PS#8	1Y				I									RLB	RLB-ELBO	C	PMS	79395	97799
4,994	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P309" -PS#9	1Y				I									RLB	RLB-ELBO	C	PMS	79396	97800
4,995	TFL -65 -DIVO		Divo Pumps for Unit65	PM; DIVO AND CONTROLPANEL "61P310" -PS#10	1Y				I									RLB	RLB-ELBO	C	PMS	79397	97801
4,996	TFL -65 -FAL		Fire Alarm System for Unit65	PM FAL-PB (LCS-Asphalt T/L)	3M	I			I			I			I			RLB	RLB-ELBO	A	PMT	48889	50719
4,997	TFL -65 -FAL		Fire Alarm System for Unit65	PM FAL SMOKE (LCS-Asphalt T/L)	6M			I						I				RLB	RLB-ELBO	A	PMT	48890	50720
4,998	TFL -65 -FAL		Fire Alarm System for Unit65	PM FAL-PB (LCS-LUBE T/L)	3M	I			I			I			I			RLB	RLB-ELBO	A	PMT	98966	124229
4,999	TFL -65 -FAL		Fire Alarm System for Unit65	PM FAL-PB (PS#1-10,Drumming Unit,LUBE T/	3M	I			I			I			I			RLB	RLB-ELBO	A	PMT	98967	124230
5,000	TFL -65 -FAL		Fire Alarm System for Unit65	PM FAL SMOKE (LCS-LUBE T/L)	6M			I						I				RLB	RLB-ELBO	A	PMT	98968	124231
5,001	TFL -65 -FAL		Fire Alarm System for Unit65	PM FAL SMOKE MCC & CCR TFL	6M			I						I				RLB	RLB-ELBO	A	PMT	98969	124232
5,002	TFL -65 -GROUND-LN		GROUND-LN	INSPECTION GROUNDING,TFL-65-GROUND-LN	1Y					P								RLB	RLB-ELBO	C	PMT	88742	112066
5,003	TFL -ASP		UNIT ASP TFL	INSP.UPS&BATTERYS OF DCS ASPH TRUCK LOAD	6M	I						I						RLB	RLB-ELBO		PMT	250474	282755
5,004	TFL -ASP-AIR		Air Conditioner for General Uint	LTL:PM AIR ล้างFILTER FCU,ตัดน้ำล้าง CDU	3M		P			P			P			P		RLB	RLB-ELBO	C	PMT	126468	155875
5,005	TFL -ASP-AIR		Air Conditioner for General Uint	ATL:PM AIR ล้างFILTER FCU,ตัดน้ำล้าง CDU	3M		P			P			P			P		RLB	RLB-ELBO	C	PMT	126469	155876
5,006	TFL -BDG-AIR		AIR CONDITIONS MCC/CCR TANKFARM LUBE	PM AIR ล้างFILTER FCU และตัดน้ำล้าง CDU	3M			P			P			P			P	RLB	RLB-ELBO	C	PMT	126467	155874
5,007	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.001	6M						P						P	RLB	RLB-ILBO		PMT	265151	297829
5,008	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.002	6M						P						P	RLB	RLB-ILBO		PMT	265152	297830
5,009	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.003	6M						P						P	RLB	RLB-ILBO		PMT	265153	297831
5,010	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.004	6M						P						P	RLB	RLB-ILBO		PMT	265154	297832
5,011	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.005	6M						P						P	RLB	RLB-ILBO		PMT	265155	297833
5,012	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.006	6M						P						P	RLB	RLB-ILBO		PMT	265156	297834
5,013	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.007	6M						P						P	RLB	RLB-ILBO		PMT	265157	297835
5,014	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.008	6M						P						P	RLB	RLB-ILBO		PMT	265158	297836
5,015	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.009	6M						P						P	RLB	RLB-ILBO		PMT	265159	297837
5,016	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.010	6M						P						P	RLB	RLB-ILBO		PMT	265160	297838
5,017	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.011	6M						P						P	RLB	RLB-ILBO		PMT	265161	297839
5,018	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.012	6M						P						P	RLB	RLB-ILBO		PMT	265162	297840
5,019	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.013	6M						P						P	RLB	RLB-ILBO		PMT	265163	297841
5,020	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.014	6M						P						P	RLB	RLB-ILBO		PMT	265164	297842
5,021	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL No.015	6M						P						P	RLB	RLB-ILBO		PMT	265165	297843
5,022	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL MONITOR No.01	6M						P							RLB	RLB-ILBO		PMT	265166	297844

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
5,023	TFL -BDG-CCTV_ATL		CCTV AREA ASPHALT TRUCK LOAD	PM CCTV AREA ATL MONITOR No.02	6M						P						P	RLB	RLB-ILBO		PMT	265167	297845
5,024	**TFL -BDG-CCTV_ATL**		**CCTV AREA ASPHALT TRUCK LOAD**	**PM CCTV AREA ATL MONITOR No.03**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265168**	**297846**
5,025	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.001	6M						P						P	RLB	RLB-ILBO		PMT	265121	297761
5,026	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.002**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265122**	**297762**
5,027	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.003	6M						P						P	RLB	RLB-ILBO		PMT	265123	297763
5,028	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.004**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265124**	**297764**
5,029	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.005	6M						P						P	RLB	RLB-ILBO		PMT	265125	297765
5,030	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.006**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265126**	**297766**
5,031	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.007	6M						P						P	RLB	RLB-ILBO		PMT	265127	297767
5,032	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.008**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265128**	**297768**
5,033	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.009	6M						P						P	RLB	RLB-ILBO		PMT	265129	297809
5,034	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.010**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265130**	**297810**
5,035	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.011	6M						P						P	RLB	RLB-ILBO		PMT	265131	297811
5,036	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.012**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265132**	**297812**
5,037	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.013	6M						P						P	RLB	RLB-ILBO		PMT	265133	297813
5,038	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.014**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265134**	**297772**
5,039	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.015	6M						P						P	RLB	RLB-ILBO		PMT	265135	297773
5,040	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.016**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265136**	**297774**
5,041	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.017	6M						P						P	RLB	RLB-ILBO		PMT	265137	297775
5,042	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.018**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265138**	**297776**
5,043	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.019	6M						P						P	RLB	RLB-ILBO		PMT	265139	297777
5,044	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.020**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265140**	**297778**
5,045	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.021	6M						P						P	RLB	RLB-ILBO		PMT	265141	297779
5,046	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.022**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265142**	**297780**
5,047	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.023	6M						P						P	RLB	RLB-ILBO		PMT	265143	297781
5,048	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL No.024**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265144**	**297782**
5,049	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL No.025	6M						P						P	RLB	RLB-ILBO		PMT	265145	297783
5,050	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL MONITOR No.01**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265146**	**297784**
5,051	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL MONITOR No.02	6M						P						P	RLB	RLB-ILBO		PMT	265147	297785
5,052	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL MONITOR No.03**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265148**	**297786**
5,053	TFL -BDG-CCTV_LTL		CCTV AREA LUBE TRUCK LOAD	PM CCTV AREA LTL MONITOR No.04	6M						P						P	RLB	RLB-ILBO		PMT	265149	297787
5,054	**TFL -BDG-CCTV_LTL**		**CCTV AREA LUBE TRUCK LOAD**	**PM CCTV AREA LTL MONITOR No.05**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265150**	**297788**
5,055	TFL -BDG-CCTV_TANK		CCTV AREA LUBE TANK	PM CCTV AREA TANK No.001	6M						P						P	RLB	RLB-ILBO		PMT	265169	297847
5,056	**TFL -BDG-CCTV_TANK**		**CCTV AREA LUBE TANK**	**PM CCTV AREA TANK No.002**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265170**	**297848**
5,057	TFL -BDG-CCTV_TANK		CCTV AREA LUBE TANK	PM CCTV AREA TANK No.003	6M						P						P	RLB	RLB-ILBO		PMT	265171	297849
5,058	**TFL -BDG-CCTV_TANK**		**CCTV AREA LUBE TANK**	**PM CCTV AREA TANK MONITOR No.01**	**6M**						**P**						**P**	**RLB**	**RLB-ILBO**		**PMT**	**265172**	**297850**
5,059	TFL -BDG-CCTV_TANK		CCTV AREA LUBE TANK	PM CCTV AREA TANK MONITOR No.02	6M						P						P	RLB	RLB-ILBO		PMT	265173	297851
5,060	**TFL -CCR-DCS**		**DCS for General Unit**	**Inspection**	**3M**			**I**			**I**			**I**			**I**	**CCS**	**CCS-SYS**		**PMT**	**116670**	**144891**
5,061	TFL -CCR-DCS		DCS for General Unit	Backup Program	6M			I						I				CCS	CCS-SYS		PMT	116671	144892
5,062	**TFL -CCR-DCS**		**DCS for General Unit**	**Update Anti-virus**	**3M**			**U**			**U**			**U**			**U**	**CCS**	**CCS-SYS**		**PMT**	**116911**	**145118**
5,063	TFL -CCR-INTERCOM		INTERCOM AREA CCR TFL	PM INTERCOM	1Y		P											CES	CES-INST		PMT	146398	176108
5,064	**TFL -E2C**		**TANK FARM LUBE UNIT**	**PARTIAL DISCHARGE SIGNAL MEASURING**	**12M**								**I**					**CCH**	**CCH-SWRL**		**PMT**	**87367**	**108163**
5,065	TFL -E2C-61MTR103		61MTR103	OIL ANALYSIS (DGA,DIELEC, IFT,ACID,MOIS)	1Y						Q							CCH	CCH-TRTL	A	PMT	79383	98036
5,066	**TFL -E2C-61MTR103**		**61MTR103**	**VISUAL INSPECT DISTRIBUTION TRANSFORMER**	**2W**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**RLB**	**RLB-ELBO**	**A**	**PMT**	**48895**	**50725**
5,067	TFL -E2C-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61TN062B	1Y					I								RLB	RLB-ELBO	B	PMT	48909	50739
5,068	**TFL -E2C-MCC**		**MCC**	**INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN62A**	**1Y**					**I**								**RLB**	**RLB-ELBO**	**B**	**PMT**	**157638**	**188316**
5,069	TFL -E2C-MCC		MCC	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN62B	1Y					I								RLB	RLB-ELBO	B	PMT	157639	188317
5,070	**TFL -E2C-MCC**		**MCC**	**INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN63A**	**1Y**					**I**								**RLB**	**RLB-ELBO**	**B**	**PMT**	**157640**	**188318**
5,071	TFL -E2C-MCC		MCC	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN63B	1Y					I								RLB	RLB-ELBO	B	PMT	157641	188319
5,072	**TFL -E2C-MCC**		**MCC**	**INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN64A**	**1Y**					**I**								**RLB**	**RLB-ELBO**	**B**	**PMT**	**157642**	**188320**
5,073	TFL -E2C-MCC		MCC	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN64B	1Y					I								RLB	RLB-ELBO	B	PMT	157643	188321
5,074	**TFL -E2C-MCC**		**MCC**	**INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN64C**	**1Y**					**I**								**RLB**	**RLB-ELBO**	**B**	**PMT**	**157644**	**188322**
5,075	TFL -E2C-MCC		MCC	วัดค่า INSULATION RESISTANCE MOTOR TR@UN	1Y						T							RLB	RLB-ELBO	B	PMT	157762	188301
5,076	**TFL -E2C-MCC**		**MCC**	**วัดค่า INSULATION RESISTANCE MOTOR TR@AUG**	**1Y**								**T**					**RLB**	**RLB-ELBO**	**B**	**PMT**	**157763**	**188302**

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: LUBE YEAR: 2024

Form No.
Effective Date 10.06.2024
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Functional Location Description	Maintenance Item Description	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	ABC In.	Maint. Act. Type	Main. Plan	Maintenance Item
5,077	TFL -E2C-MCC		MCC	วัดค่า INSULATION RESISTANCE MOTOR TR@OCT	1Y										T			RLB	RLB-ELBO	B	PMT	157764	188303
5,078	**TFL -E2D**		**TANK FARM LUBE UNIT**	**PARTIAL DISCHARGE SIGNAL MEASURING**	**12M**								**I**					**CCH**	**CCH-SWRL**		**PMT**	**87370**	**108166**
5,079	TFL -E2D-65DC101		CHARGER 110VDC	PM CHARGER E38D-65DC101-1-BC	1Y							P						CCH	CCH-UPS	A	PMT	251900	284307
5,080	**TFL -E2D-65DC101**		**CHARGER 110VDC**	**PM CHARGER E38D-65DC101-2-BC**	**1Y**							**P**						**CCH**	**CCH-UPS**	**A**	**PMT**	**251901**	**284308**
5,081	TFL -E2D-65DC101		CHARGER 110VDC	INSPECT CHARGER E38D-65DC101-1-BC	6M				I						I			CCH	CCH-UPS	A	PMT	251902	284309
5,082	**TFL -E2D-65DC101**		**CHARGER 110VDC**	**INSPECT CHARGER E38D-65DC101-2-BC**	**6M**				**I**						**I**			**CCH**	**CCH-UPS**	**A**	**PMT**	**251903**	**284310**
5,083	TFL -E2D-65DC101		CHARGER 110VDC	PM BATTERY FOR 65DC101-BATT1	1Y	P												CCH	CCH-UPS	A	PMT	251904	284311
5,084	**TFL -E2D-65DC101**		**CHARGER 110VDC**	**PM BATTERY FOR 65DC101-BATT2**	**1Y**	**P**												**CCH**	**CCH-UPS**	**A**	**PMT**	**251905**	**284312**
5,085	TFL -E2D-65UPS101		UPS 220VAC	PM UPS E38D-65UPS101-1	1Y							P						CCH	CCH-UPS		PMT	251894	284301
5,086	**TFL -E2D-65UPS101**		**UPS 220VAC**	**PM UPS E38D-65UPS101-2**	**1Y**							**P**						**CCH**	**CCH-UPS**		**PMT**	**251895**	**284302**
5,087	TFL -E2D-65UPS101		UPS 220VAC	INSPECT UPS E38D-65UPS101-1	6M				I						I			CCH	CCH-UPS		PMT	251896	284303
5,088	**TFL -E2D-65UPS101**		**UPS 220VAC**	**INSPECT UPS E38D-65UPS101-2**	**6M**				**I**						**I**			**CCH**	**CCH-UPS**		**PMT**	**251897**	**284304**
5,089	TFL -E2D-65UPS101		UPS 220VAC	PM BATTERY FOR 65UPS101-BATT1	1Y	P												CCH	CCH-UPS		PMT	251898	284305
5,090	**TFL -E2D-65UPS101**		**UPS 220VAC**	**PM BATTERY FOR 65UPS101-BATT2**	**1Y**	**P**												**CCH**	**CCH-UPS**		**PMT**	**251899**	**284306**
5,091	TFL -E2D-MCC		MCC	PM M/ SWITCHGEAR + TEST RELAY	2Y		P											CCH	CCH-SWRL	C	PMT	48915	50745
5,092	**TFL -E2D-MCC**		**MCC**	**PM M/ SWITCHGEAR + TEST RELAY**	**2Y**			**P**										**CCH**	**CCH-SWRL**	**C**	**PMT**	**48916**	**50746**
5,093	TFL -E2D-MCC		MCC	PM M/ SWITCHGEAR + TEST RELAY	2Y		P											CCH	CCH-SWRL	C	PMT	48924	50754
5,094	**TFL -E2D-MCC**		**MCC**	**PM M/ SWITCHGEAR + TEST RELAY**	**2Y**			**P**										**CCH**	**CCH-SWRL**	**C**	**PMT**	**48925**	**50755**
5,095	TFL -E2D-MCC		MCC	PM M/ SWITCHGEAR + TEST RELAY	2Y		P											CCH	CCH-SWRL	C	PMT	48942	50772
5,096	**TFL -E2D-MCC**		**MCC**	**PM M/ SWITCHGEAR + TEST RELAY**	**2Y**			**P**										**CCH**	**CCH-SWRL**	**C**	**PMT**	**48943**	**50773**
5,097	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61P151A	1Y		I											RLB	RLB-ELBO	C	INT	100816	126100
5,098	**TFL -E2D-MCC**		**MCC**	**PM MCC MODULE&INSPECTION MOTOR 61P151B**	**1Y**	**I**												**RLB**	**RLB-ELBO**	**C**	**INT**	**100817**	**126101**
5,099	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61TN0N083	1Y					I								RLB	RLB-ELBO	C	PMS	129244	158690
5,100	**TFL -E2D-MCC**		**MCC**	**PM MCC MODULE&INSPECTION MOTOR 61TN0N084**	**1Y**					**I**								**RLB**	**RLB-ELBO**	**C**	**PMS**	**129245**	**158691**
5,101	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61P037A	1Y				I									RLB	RLB-ELBO	C	PMT	48934	50764
5,102	**TFL -E2D-MCC**		**MCC**	**PM MCC MODULE&INSPECTION MOTOR 61P043A**	**1Y**			**I**										**RLB**	**RLB-ELBO**	**C**	**PMT**	**48937**	**50767**
5,103	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61P074A	1Y			I										RLB	RLB-ELBO	C	PMT	48959	50789
5,104	**TFL -E2D-MCC**		**MCC**	**PM MCC MODULE&INSPECTION MOTOR 61TN085A**	**1Y**							**I**						**RLB**	**RLB-ELBO**	**C**	**PMT**	**129246**	**158692**
5,105	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61TN085B	1Y							I						RLB	RLB-ELBO	C	PMT	129247	158693
5,106	**TFL -E2D-MCC**		**MCC**	**PM MCC MODULE&INSPECTION MOTOR 61TN085C**	**1Y**							**I**						**RLB**	**RLB-ELBO**	**C**	**PMT**	**129248**	**158694**
5,107	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61TN037A	1Y							I						RLB	RLB-ELBO	C	PMT	129249	158695
5,108	**TFL -E2D-MCC**		**MCC**	**PM MCC MODULE&INSPECTION MOTOR 61TN037C**	**1Y**							**I**						**RLB**	**RLB-ELBO**	**C**	**PMT**	**129250**	**158696**
5,109	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61TN038A	1Y							I						RLB	RLB-ELBO	C	PMT	129251	158697
5,110	**TFL -E2D-MCC**		**MCC**	**PM MCC MODULE&INSPECTION MOTOR 61TN051**	**1Y**					**I**								**RLB**	**RLB-ELBO**	**C**	**PMT**	**129252**	**158698**
5,111	TFL -E2D-MCC		MCC	PM MCC MODULE&INSPECTION MOTOR 61TN052	1Y					I								RLB	RLB-ELBO	C	PMT	129253	158699
5,112	**TFL -E2D-MCC**		**MCC**	**INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN36C**	**1Y**							**I**						**RLB**	**RLB-ELBO**	**C**	**PMT**	**157659**	**188337**
5,113	TFL -E2D-MCC		MCC	INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN37C	1Y							I						RLB	RLB-ELBO	C	PMT	157661	188339
5,114	**TFL -E2D-MCC**		**MCC**	**INSP.CONDUIT,FLEX.&SEAL SILICONE 61TN37A**	**1Y**							**I**						**RLB**	**RLB-ELBO**	**C**	**PMT**	**157676**	**188354**
5,115	TFL -E2D-MCC		MCC	INSP.CONDUIT,FLEX.&SEAL SILICONE 61P509B	1Y										I			RLB	RLB-ELBO	C	PMT	157738	188415
5,116	**TFL -E2D-MCC**		**MCC**	**วัดค่า INSULATION RESISTANCE MOTOR TR@UN**	**1Y**							T						**RLB**	**RLB-ELBO**	**C**	**PMT**	**157759**	**188298**
5,117	TFL -E2D-MCC		MCC	วัดค่า INSULATION RESISTANCE MOTOR TR@AUG	1Y								T					RLB	RLB-ELBO	C	PMT	157760	188299
5,118	**TFL -E2D-MCC**		**MCC**	**วัดค่า INSULATION RESISTANCE MOTOR TR@OCT**	**1Y**											**T**		**RLB**	**RLB-ELBO**	**C**	**PMT**	**157761**	**188300**
5,119	TFL -E2D-SWGR		POWER SWITCH GEAR	PM M/ SWITCHGEAR + TEST RELAY	2Y		P											CCH	CCH-SWRL	A	PMT	48919	50749
5,120	**TFL -E2D-SWGR**		**POWER SWITCH GEAR**	**PM M/ SWITCHGEAR + TEST RELAY**	**2Y**			**P**										**CCH**	**CCH-SWRL**	**A**	**PMT**	**48920**	**50750**
5,121	TFL -E2D-TRM		Transformer	OIL ANALYSIS (DGA,DIELEC, IFT,ACID,MOIS)	1Y						Q							CCH	CCH-TRTL	A	PMT	79384	98037
5,122	**TFL -E2D-TRM**		**Transformer**	**VISUAL INSPECT DISTRIBUTION TRANSFORMER**	**2W**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**I**	**RLB**	**RLB-ELBO**	**A**	**PMT**	**48998**	**50828**
5,123	TFL -E2D-TRM		Transformer	VISUAL INSPECT DISTRIBUTION TRANSFORMER	2W	I	I	I	I	I	I	I	I	I	I	I	I	RLB	RLB-ELBO	A	PMT	122023	150806
5,124	**TFL -E2D-UND_GROUND**		**Under Ground Power System**	**INSPECTION 6.3KV UNDERGROUND CABLE**	**6M**				**P**							**P**		**RLB**	**RLB-ELBO**	**A**	**PMT**	**122197**	**151059**
5,125	TFL -E2D-UND_GROUND		Under Ground Power System	TFL:ควบคุม แรม. ตัดปลวกและวางยาเบื้องหุ้ม	1M	I	I	I	I	I	I	I	I	I	I	I	I	RLB	RLB-ELBO	A	PMT	149835	179640
5,126	**TFL -E2D-UND_GROUND**		**Under Ground Power System**	**TFL:ควบคุมแรม.ตัดปลวกลงท่อให้ต้นแยกสายไฟ**	**3M**	**I**			**I**			**I**				**I**		**RLB**	**RLB-ELBO**	**A**	**PMT**	**149841**	**179646**

เอกสารแนบที่ 11

สำเนาหนังสืออนุญาตให้โรงงานมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

CPRO รับวันที่ 25 พ.ค. NO. CPRO 643 /25.64
IAO รับวันที่ 27 / 5 / 64 NO. 678 / 64
1/3

ที่ อก ๐๓๑๗/ ๔๔๑๖

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๐๙ เมษายน ๒๕๖๔

เรื่อง หนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

เรียน ผู้รับใบอนุญาตประกอบกิจการโรงงาน บริษัท ไออาร์พีซี จำกัด (มหาชน)

อ้างถึง คำขอเลขที่ ๐๔๗๒ ลงรับวันที่ ๒ เมษายน ๒๕๖๔

ตามคำขอที่อ้างถึง ท่านแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ของ บริษัท ไออาร์พีซี จำกัด (มหาชน) ทะเบียนโรงงานเลขที่ ข ๓-๕๐(๔)-๑/๔๑ รย ประกอบกิจการผลิตน้ำมันหล่อลื่นพื้นฐาน (Lube Base Oil) ตั้งอยู่ ณ เลขที่ ๒๔๙ หมู่ที่ ๕ เขตประกอบการอุตสาหกรรม บริษัท ไออาร์พีซี จำกัด (มหาชน) ถนนสุขุมวิท ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง โทรศัพท์ ๐ ๓๘๖๑ ๑๓๓๓

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว รับแจ้งการให้มีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน และให้ท่านยื่นคำขอแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงานครั้งต่อไป ภายในวันที่ ๑๖ เมษายน ๒๕๖๗ โดยมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ดังนี้

ผู้จัดการสิ่งแวดล้อม	นายเสกสรรค์ ตราตรี

ลำดับ	ผู้ควบคุมระบบบำบัด	เลขทะเบียน	มลพิษน้ำ	มลพิษอากาศ	มลพิษจากอุตสาหกรรม
๑				✓	
๒			✓		
๓					✓

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษจากอุตสาหกรรม
๑		✓	✓	✓
๒		✓		✓
๓		✓	✓	✓
๔		✓		
๕		✓		✓
๖		✓	✓	✓
๗			✓	✓
๘			✓	✓
๙			✓	
๑๐		✓	✓	✓

ลำดับ ๑๑...

2/3

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษจากอุตสาหกรรม
๑๑		✓		✓
๑๒				✓
๑๓		✓	✓	✓
๑๔				✓
๑๕		✓		
๑๖		✓		✓
๑๗		✓		✓
๑๘				✓
๑๙		✓	✓	✓
๒๐			✓	✓
๒๑			✓	✓
๒๒			✓	✓
๒๓		✓		
๒๔		✓	✓	✓
๒๕			✓	✓
๒๖				✓
๒๗		✓	✓	
๒๘		✓		✓
๒๙		✓	✓	
๓๐		✓	✓	
๓๑			✓	
๓๒			✓	
๓๓			✓	✓
๓๔		✓		✓
๓๕			✓	✓
๓๖		✓	✓	✓
๓๗				✓
๓๘		✓		
๓๙		✓		✓
๔๐		✓		

ลำดับ ๔๑...

สก รับวันที่ 27 / 12 / 65 NO. 287 / 65

สำเนาคู่ฉบับ

ที่ อก ๐๓๑๓/๑ ๐ ๐ ๗ ๒

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๒ สิงหาคม ๒๕๖๕

รต์ โรจนจันทร์)
เร่ปฏิบัติการ

เรื่อง หนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

เรียน ผู้รับใบอนุญาตประกอบกิจการโรงงาน บริษัท ไออาร์พีซี จำกัด (มหาชน)

อ้างถึง คำขอเลขที่ ๐๘๖๒ ลงรับวันที่ ๒๐ กรกฎาคม ๒๕๖๕

ตามคำขอที่อ้างถึง ท่านแจ้งการยกเลิกบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ของ บริษัท ไออาร์พีซี จำกัด (มหาชน) ทะเบียนโรงงานเลขที่ ๙๑๐๙๐๒๐๐๑๒๕๔๑๘(ข๓-๕๐(๔)-๑/๔๑รย) ประกอบกิจการผลิตน้ำมันหล่อลื่นพื้นฐาน (Lube Base Oil) ตั้งอยู่ ณ เลขที่ ๒๙๙ หมู่ที่ ๕ เขตประกอบการอุตสาหกรรม บริษัท ไออาร์พีซี จำกัด (มหาชน) ถนนสุขุมวิท ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง โทรศัพท์ ๐ ๓๘๖๑ ๑๓๓๓

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว รับแจ้งการยกเลิกบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน และให้ท่านยื่นคำขอแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงานครั้งต่อไป ภายในวันที่ ๑๖ เมษายน ๒๕๖๗ โดยมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ดังนี้

ผู้จัดการสิ่งแวดล้อม	นายเสกสรรค์ ตราตรี

ลำดับ	ผู้ควบคุมระบบบำบัด	เลขทะเบียน	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑		๐๒๐-๕๘-๐๐๕๒๙		✓	
๒		๑๐๓-๕๐-๐๐๓๖๓	✓		
๓		๐๐๓-๕๘-๐๐๗๑๕			✓

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑		✓	✓	✓
๒		✓		✓
๓		✓	✓	✓
๔		✓		✓
๕		✓	✓	✓
๖			✓	✓
๗			✓	✓
๘			✓	
๙		✓	✓	✓
๑๐		✓		✓

ลำดับ ๑๑...

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑๑				✓
๑๒		✓	✓	✓
๑๓				✓
๑๔		✓		
๑๕		✓		✓
๑๖		✓		✓
๑๗				✓
๑๘		✓	✓	✓
๑๙			✓	✓
๒๐			✓	✓
๒๑			✓	✓
๒๒		✓		
๒๓		✓	✓	✓
๒๔			✓	✓
๒๕				✓
๒๖		✓	✓	
๒๗		✓		✓
๒๘		✓	✓	
๒๙		✓	✓	
๓๐			✓	
๓๑			✓	
๓๒			✓	✓
๓๓		✓		✓
๓๔			✓	✓
๓๕		✓	✓	✓
๓๖				✓
๓๗		✓		
๓๘		✓		✓
๓๙		✓		
๔๐		✓		

ลำดับ ๔๑...

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๔๑	[redacted]		✓	
๔๒			✓	
๔๓			✓	
๔๔				✓
๔๕				✓
๔๖			✓	✓
๔๗				✓

หมายเหตุ ๑. การแจ้งการมี/ยกเลิก/เพิ่มเติม/เปลี่ยนแปลง บุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ต้องส่งหนังสือฉบับนี้ด้วย
๒. ยกเลิกหนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ที่ อก ๐๓๑๓/๔๔๑๖ ลงวันที่ ๙ เมษายน ๒๕๖๔

จึงเรียนมาเพื่อโปรดทราบ

[redacted]

3/3

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๔๑		✓		
๔๒		✓		
๔๓			✓	
๔๔			✓	
๔๕			✓	
๔๖				✓
๔๗				✓
๔๘				✓
๔๙			✓	✓
๕๐				✓

หมายเหตุ ๑. การแจ้งการมี/ยกเลิก/เพิ่มเติม/เปลี่ยนแปลง บุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ต้องส่งหนังสือฉบับนี้ด้วย
๒. ยกเลิกหนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ที่ อก ๐๓๑๗/๑๒๑๗๖ ลงวันที่ ๔ กันยายน ๒๕๖๒

จึงเรียนมาเพื่อโปรดทราบ

[redacted]

[redacted]

กจญ.รับที่ 047/25 67 รับที่ 83/0454 เวลา 1720

CCOE รับที่ 161 25.67
วันที่ 25/4/67 เวลา 8.00น.



อก.รับวันที่ 3/5/67 NO. 033/67

ที่ อก ๐๓๑๗/ ๓๘๒๗

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๑๗ เมษายน ๒๕๖๗

เรื่อง หนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

เรียน ผู้รับใบอนุญาตประกอบกิจการโรงงาน บริษัท ไออาร์พีซี จำกัด (มหาชน)

อ้างถึง คำขอเลขที่ ๐๔๙๐ ลงรับวันที่ ๙ เมษายน ๒๕๖๗

ตามคำขอที่อ้างถึง ท่านแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ของ บริษัท ไออาร์พีซี จำกัด (มหาชน) ทะเบียนโรงงานเลขที่ ๙๑๐๙๐๒๐๐๑๒๕๔๑๘ (ข๓-๕๐(๔)-๑/๔๑รย) ประกอบกิจการผลิตน้ำมันหล่อลื่นพื้นฐาน ตั้งอยู่ ณ เลขที่ ๒๙๙ หมู่ที่ ๕ ถนนสุขุมวิท ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง โทรศัพท์ ๐ ๓๘๖๑ ๑๓๓๓ ความละเอียดแจ้งแล้ว นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว รับแจ้งการให้มีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน และให้ท่านยื่นคำขอแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงานครั้งต่อไป ภายในวันที่ ๑๖ เมษายน ๒๕๗๐ โดยมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ดังนี้

ผู้จัดการสิ่งแวดล้อม	นายเสกสรรค์ ตราตรี

ลำดับ	ผู้ควบคุมระบบบำบัด	เลขทะเบียน	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑	[redacted]	๐๒๐-๕๘-๐๐๕๒๙		✓	
๒		๑๐๐-๖๖-๐๐๓๗๙	✓		
๓		๐๐๓-๕๘-๐๐๗๑๕			✓

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑	[redacted]	✓	✓	✓
๒		✓		✓
๓		✓	✓	✓
๔		✓		✓
๕		✓	✓	✓
๖		✓	✓	✓
๗			✓	
๘		✓	✓	✓
๙		✓	✓	✓
๑๐				✓

ลำดับ ๑๑...

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษจากอุตสาหกรรม
๑๑	[redacted]	✓	✓	✓
๑๒				✓
๑๓		✓		
๑๔		✓		✓
๑๕		✓		✓
๑๖		✓	✓	✓
๑๗			✓	✓
๑๘			✓	✓
๑๙			✓	✓
๒๐		✓		
๒๑		✓	✓	✓
๒๒			✓	✓
๒๓				✓
๒๔		✓	✓	✓
๒๕		✓	✓	✓
๒๖		✓	✓	✓
๒๗		✓	✓	
๒๘			✓	
๒๙			✓	
๓๐			✓	✓
๓๑		✓	✓	✓
๓๒		✓	✓	✓
๓๓		✓	✓	✓
๓๔		✓	✓	✓
๓๕		✓		
๓๖		✓		✓
๓๗		✓	✓	✓
๓๘		✓		
๓๙			✓	
๔๐		✓	✓	✓

ลำดับ ๔๑...

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษจากอุตสาหกรรม
๔๑	[redacted]		✓	
๔๒				✓
๔๓				✓
๔๔			✓	✓
๔๕				✓
๔๖		✓		✓
๔๗		✓		
๔๘		✓		
๔๙			✓	
๕๐				✓

หมายเหตุ ๑. การแจ้งการมี/ยกเลิก/เพิ่มเติม/เปลี่ยนแปลง บุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ต้องส่งหนังสือฉบับนี้ด้วย
๒. ยกเลิกหนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ที่ อก ๐๓๓๓/๑๐๐๗๒ ลงวันที่ ๒ สิงหาคม ๒๕๖๕

จึงเรียนมาเพื่อโปรดทราบ

[redacted]

กองส่งเสริมเทคโนโลยีสิ่งแวดล้อมโรงงาน
กลุ่มกำกับบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน
โทรศัพท์ ๐ ๒๔๓๐ ๖๓๑๕ ต่อ ๒๔๐๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๕ ต่อ ๒๔๙๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

[redacted]

เอกสารแนบที่ 12

แผนการตรวจวัดสารอินทรีย์ระเหยง่ายประจำปี (VOC Fugitive)

แผนการตรวจวัด VOCS fugitives year 2024

LBOD	jan	feb	mar	apr	may	jun	jul	aug	sep	oct	nov
shift A											
shift B											
shift C											
shift D											

LBOT	jan	feb	mar	apr	may	jun	jul	aug	sep	oct	nov
shift A											
shift B											
shift C											
shift D											

PWUT	jan	feb	mar	apr	may	jun	jul	aug	sep	oct	nov
shift A											
shift B											
shift C											
shift D											

plant	total points
LBOD	3595
LBOT	4711
PWUT	299

total points fugitive of C5 8605 items

หมายเหตุ การรายงาน ผลการตรวจวัดให้ทางราชการจะแบ่งเป็น 2 ช่วงคือ
1.เดือนกรกฎาคม เป็นการรายงานความคืบหน้า
2.เดือนธันวาคม เป็นการรายงานการตรวจวัดทั้งหมด

เอกสารแนบที่ 13

เอกสารแบบรายงานการตรวจวัดการรั่วซึมของสารอินทรีย์ระเหยง่าย (รว3/1)

แบบรายงานผลการตรวจวัดการรั่วซึม ของสารอินทรีย์ระเหยจากอุปกรณ์และการซ่อมแซมอุปกรณ์ในโรงงานอุตสาหกรรม (รว.3/1)

ประจำปี พ.ศ. 2567 รอบที่ 1

ระหว่างเดือน มกราคม ถึงเดือน มิถุนายน

(1 แบบรายงานต่อ 1 โรงงาน)

1. รายละเอียดเกี่ยวกับโรงงาน

ชื่อโรงงาน บริษัท ไออาร์พีซี จำกัด (มหาชน)

ทะเบียนโรงงานเลขที่ ข3-50(4)-1/41รย

2. ข้อมูลปริมาณสารอินทรีย์ระเหย

ปริมาณสารอินทรีย์ระเหยรวมที่มีหรือใช้ในกระบวนการผลิต 650787.09 ตันต่อปี

ประเภทอุปกรณ์	สถานะสารอินทรีย์ระเหย	จำนวนอุปกรณ์ทั้งหมดของโรงงาน		จำนวนอุปกรณ์ที่ต้องตรวจวัดการรั่วซึมในรอบการรายงานครั้งนี้			ปริมาณสารอินทรีย์ระเหยรวมในรูปมีเทนที่รั่วซึมจากอุปกรณ์ที่ตรวจวัดการรั่วซึมทั้งหมดในรอบการรายงานครั้งนี้ (กิโลกรัม)
		จำนวนอุปกรณ์ที่ต้องตรวจวัดการรั่วซึม (จุด)	จำนวนอุปกรณ์ที่ได้รับการยกเว้นไม่ต้องตรวจวัดการรั่วซึม (จุด)	จำนวนอุปกรณ์ที่ตรวจวัดการรั่วซึมทั้งหมด (จุด)	จำนวนอุปกรณ์ที่มีผลการตรวจวัดเกินจากเกณฑ์การควบคุมการรั่วซึม (จุด)	จำนวนอุปกรณ์ที่ได้รับการซ่อมแซมให้อยู่ในเกณฑ์การควบคุมการรั่วซึม (จุด)	
วาล์ว (Valves)	แก๊ส	1055	0	40	0	0	1.36
วาล์ว (Valves)	ของเหลว	7234	0	8	0	0	0.27
ปั๊ม (Pumps)	ของเหลว	202	0	0	0	0	0.00
อุปกรณ์ลดความดัน (Pressure Relief Devices)	แก๊ส	4	0	0	0	0	0.00
อุปกรณ์ลดความดัน (Pressure Relief Devices)	ของเหลว	366	0	1	0	0	0.02
เครื่องอัดอากาศ (Compressors)	ทั้งหมด	4	0	0	0	0	0.00
ขอต่อหรือหน้าแปลน (Connectors or Flanges)	ทั้งหมด	8847	0	250	0	0	0.34
ท่อส่งปลายเปิด (Open-Ended Lines)	ทั้งหมด	260	0	0	0	0	0.00
จุดเก็บตัวอย่างสารเคมี (Sampling Connections)	ทั้งหมด	59	0	0	0	0	0.00
อุปกรณ์ที่ใช้กวนหรือผสมของเหลว (Agitators or Mixers)	ทั้งหมด	32	0	0	0	0	0.00

3. ปัญหา อุปสรรค และวิธีการแก้ไข

เอกสารแนบที่ 14

เอกสาร Noise Contour

เอกสารแนบที่ 15

เอกสารโครงการปลูกป่าเป็นแนวกันชนโดยรอบเขตประกอบการฯ

มีแนวต้นสนโตแล้วอายุ 7- 10 ปี





มีแนวต้นสนโตแล้วอายุ 7- 10 ปี



มีแนวต้นสนโตแล้วอายุ 7- 10 ปี และแนวไม้ยืนต้นอายุ 2 ปีกว่า







พิธีเปิดโครงการจัดทำแนวป้องกัน (Protection Strip)
เพื่อเฉลิมพระเกียรติพระบาทสมเด็จพระเจ้าอยู่หัว
IRPC


IRPC











IRPC
บริษัท ไออาร์พีซี จำกัด (มหาชน)





แนวคิดการปลูกป่าไม้ธรรมชาติ (Eco Forest)

" การปลูกป่าโดยใช้พันธุ์ไม้ท้องถิ่น "
ของ ศ.ดร.อาคิระ มิยาวากิ






โตโยต้าบ้านโพธิ์ใช้พันธุ์ไม้ดั้งเดิม (**Native Species**) กว่า 32 **Species**

Key Success Factor

1. สร้างเนินดินปลูกป่า (**Mound**) ขุดลอกดินเดิมออก 50 ซม. แล้วนำไปผสมหน้าดิน ปุ๋ยและวัสดุบำรุงดิน ตามสัดส่วนที่เหมาะสมเพียงพอสำหรับการเจริญเติบโต 3 ปี แล้วนำกลับมาทำเป็นเนินสูง 1.60 เมตร ช่วยระบายน้ำและอากาศ



2. ปลูกต้นไม้ดั้งเดิมกว่า 34 สายพันธุ์ บนเนินดิน 108 เนิน เมื่อสิงหาคม 2551







3. เพาะกล้าไม้จากเมล็ด มีระบบรากแข็งแรง

4. ปลูกแบบสุ่ม หนาแน่น ไม่เป็นแนว ให้แย่งกันหาแสงแดด ทำให้ต้นสูงไว






Olive Project

ภายใน 1ปี ต้นไม้รอด 88 % สูงเฉลี่ย 157.6 ซม.
สิงหาคม 2553 (2ปี) ต้นไม้รอด 86 % สูงเฉลี่ย 224.4 ซม.
อัตราการเจริญเติบโต 10 เท่าของป่าธรรมชาติ







เปรียบเทียบความแตกต่างของการเจริญเติบโตของต้นไม้ ระหว่างการปลูกตามทฤษฎีของ ศ.ดร.อาคิระ ซึ่งเจริญเติบโตได้ดีกว่าวิธีการปลูกทั่วไป



ปลูกป่าแบบธรรมชาติที่ **Yokohama Tire** ปลูกมาแล้ว 1 ปี




ปลูกป่าแบบธรรมชาติที่ **Yokohama Tire** ปลูกมาแล้ว 2 ปี




ปลูกป่าแบบธรรมชาติที่ Yokohama Tire ปลูกมาแล้ว 3 ปี






แนวจัดทำ Protection Strip ในปี 2554 ตามทฤษฎีใหม่




KOBELCO





Initiative #25 Olive Project



ห้างหุ้นส่วนจำกัด สวนแมโจ้เนอร์สเซอรี่

5/40 ม.2 ต.เชิงเนิน อ.เมืองระยอง จ. ระยอง 21000

โทรศัพท์ 038-617670 , 038-861267 เลขประจำตัวผู้เสียภาษี 021353900575

Landscape Design

แผนปฏิบัติงานตัดหญ้าสวนหย่อม - ตัดแต่ง -ทำโคน - ปี 2567

เดือน มกราคม 2567

ลำดับ	พื้นที่ปฏิบัติงาน	วันที่ 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
1	เกาะกลางสาย A สุขุมวิท- I2, I5																															
2	เกาะกลางถนน สาย B																															
3	เกาะกลางถนนสาย C																															
4	เกาะกลางถนนสาย D - F																															
5	เกาะสวนปาล์ม สนามหญ้ารอบโรงอาหาร																															
6	อาคารดับเพลิง-บูมราคัม-ทับทิม MS IP																															
7	OFFICE LUBE , QC5 , TLLB, LBOD, TWUT																															
8	PS PLANT , EBSM																															
9	WWT 3																															
10	สวนหย่อมหน้าแปลงมะกอก																															
11	สวนหย่อมลานสิงแวดล้อม																															
12	สนามหญ้าสวนหย่อม ยางมะตอย																															
13	โรงกรองน้ำ																															
14	สวนหย่อม NaNo																															
15	สวนหย่อม UHV																															
16	สนามหญ้าตึก A และ B																															
17	สนามหญ้าสวนหย่อมหน้าป้าย																															
18	สนามหญ้ารอบสนามบอล																															
19	สนามหญ้าสวนหย่อมสโมสร - สวนสุขภาพ																															
20	สนามหญ้าสวนหย่อม รอบ Sport Complex																															
21	สนามหญ้าพื้นที่ ศูนย์นวัตกรรม IIC																															

หมายเหตุ วันหยุด แผนปฏิบัติงาน วันเข้าชดเชย

ห้างหุ้นส่วนจำกัด สวนแมโจ้เนอร์สเซอรี่

5/40 ม.2 ต.เชิงเนิน อ.เมืองระยอง จ. ระยอง 21000

โทรศัพท์ 038-617670 , 038-861267 เลขประจำตัวผู้เสียภาษี 021353900575

Landscape Design

แผนปฏิบัติงานตัดหญ้าสวนหย่อม - ตัดแต่ง -ทำโคน - ปี 2567

เดือน กุมภาพันธ์ 2567

ลำดับ	พื้นที่ปฏิบัติงาน	วันที่ 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29		
1	เกาะกลางสาย A สุขุมวิท- I2, I5																															
2	เกาะกลางถนน สาย B																															
3	เกาะกลางถนนสาย C																															
4	เกาะกลางถนนสาย D - F																															
5	เกาะสวนปาล์ม สนามหญ้ารอบโรงอาหาร																															
6	อาคารดับเพลิง-บูมราคัม-ทับทิม MS IP																															
7	OFFICE LUBE , QC5 , TLLB, LBOD, TWUT																															
8	PS PLANT , EBSM																															
9	WWT 3																															
10	สวนหย่อมหน้าแปลงมะกอก																															
11	สวนหย่อมลานสิงแวดล้อม																															
12	สนามหญ้าสวนหย่อม ยางมะตอย																															
13	โรงกรองน้ำ																															
14	สวนหย่อม NaNo																															
15	สวนหย่อม UHV																															
16	สนามหญ้าตึก A และ B																															
17	สนามหญ้าสวนหย่อมหน้าป้าย																															
18	สนามหญ้ารอบสนามบอล																															
19	สนามหญ้าสวนหย่อมสโมสร - สวนสุขภาพ																															
20	สนามหญ้าสวนหย่อม รอบ Sport Complex																															
21	สนามหญ้าพื้นที่ ศูนย์นวัตกรรม IIC																															

หมายเหตุ วันหยุด แผนปฏิบัติงาน วันเข้าชดเชย

ห้างหุ้นส่วนจำกัด สวนแมโจ้เนอร์สเซอรี่
5/40 ม.2 ต.เชิงเนิน อ.เมืองระยอง จ. ระยอง 21000
โทรศัพท์ 038-617670 , 038-861267 เลขประจำตัวผู้เสียภาษี 0213539005 75

Landscape Design

แผนปฏิบัติงานตัดหญ้าสวนหย่อม - ตัดแต่ง -ทำโคน - ปี 2567

เดือน มีนาคม 2567

ลำดับ	พื้นที่ปฏิบัติงาน	วันที่ 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
1	เกาะกลางสาย A สุขุมวิท- I2, I5																															
2	เกาะกลางถนน สาย B																															
3	เกาะกลางถนนสาย C																															
4	เกาะกลางถนนสาย D - F																															
5	เกาะสวนปาล์ม สนามหญ้ารอบโรงอาหาร																															
6	อาคารดับเพลิง-บุษราคัม-ทับทิม MS IP																															
7	OFFICE LUBE , QC5 , TLLB, LBOD, TWUT																															
8	PS PLANT , EBSM																															
9	WWT 3																															
10	สวนหย่อมหน้าแปลงมะกอก																															
11	สวนหย่อมลานสิ่งแวดล้อม																															
12	สนามหญ้าสวนหย่อม ยางมะตอย																															
13	โรงกรองน้ำ																															
14	สวนหย่อม NaNo																															
15	สวนหย่อม UHV																															
16	สนามหญ้าคึก A และ B																															
17	สนามหญ้าสวนหย่อมหน้าป้าย																															
18	สนามหญ้ารอบสนามบอล																															
19	สนามหญ้าสวนหย่อมสโมสร - สวนสุขภาพ																															
20	สนามหญ้าสวนหย่อม รอบ Sport Complex																															
21	สนามหญ้าพื้นที่ ศูนย์นวัตกรรม IIC																															

หมายเหตุ วันหยุด แผนปฏิบัติงาน วันเข้าชดเชย

ห้างหุ้นส่วนจำกัด สวนแมโจ้เนอร์สเซอรี่
5/40 ม.2 ต.เชิงเนิน อ.เมืองระยอง จ. ระยอง 21000
โทรศัพท์ 038-617670 , 038-861267 เลขประจำตัวผู้เสียภาษี 0213539005 75

Landscape Design

แผนปฏิบัติงานตัดหญ้าสวนหย่อม - ตัดแต่ง -ทำโคน - ปี 2567

เดือน เมษายน 2567

ลำดับ	พื้นที่ปฏิบัติงาน	วันที่ 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
1	เกาะกลางสาย A สุขุมวิท- I2, I5																														
2	เกาะกลางถนน สาย B																														
3	เกาะกลางถนนสาย C																														
4	เกาะกลางถนนสาย D - F																														
5	เกาะสวนปาล์ม สนามหญ้ารอบโรงอาหาร																														
6	อาคารดับเพลิง-บุษราคัม-ทับทิม MS IP																														
7	OFFICE LUBE , QC5 , TLLB, LBOD, TWUT																														
8	PS PLANT , EBSM																														
9	WWT 3																														
10	สวนหย่อมหน้าแปลงมะกอก																														
11	สวนหย่อมลานสิ่งแวดล้อม																														
12	สนามหญ้าสวนหย่อม ยางมะตอย																														
13	โรงกรองน้ำ																														
14	สวนหย่อม NaNo																														
15	สวนหย่อม UHV																														
16	สนามหญ้าคึก A และ B																														
17	สนามหญ้าสวนหย่อมหน้าป้าย																														
18	สนามหญ้ารอบสนามบอล																														
19	สนามหญ้าสวนหย่อมสโมสร - สวนสุขภาพ																														
20	สนามหญ้าสวนหย่อม รอบ Sport Complex																														
21	สนามหญ้าพื้นที่ ศูนย์นวัตกรรม IIC																														

หมายเหตุ วันหยุด แผนปฏิบัติงาน วันเข้าชดเชย

ห้างหุ้นส่วนจำกัด สวนแมโจ้เนอร์สเซอรี่
5/40 ม.2 ต.เชิงเนิน อ.เมืองระยอง จ. ระยอง 21000
โทรศัพท์ 038-617670 , 038-861267 เลขประจำตัวผู้เสียภาษี 021353900575

แผนปฏิบัติงานตัดหญ้าสวนหย่อม - ตัดแต่ง -ทำโคน- ปี 2567

เดือน พฤษภาคม 2567

ลำดับ	พื้นที่ปฏิบัติงาน	วันที่ 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
1	เกาะกลางสาย A สุขุมวิท- I2, I5																															
2	เกาะกลางถนน สาย B																															
3	เกาะกลางถนนสาย C																															
4	เกาะกลางถนนสาย D - F																															
5	เกาะสวนปาล์ม สนามหญ้ารอบโรงอาหาร																															
6	อาคารดับเพลิง-บุษราคัม-ทับทิม MS IP																															
7	OFFICE LUBE , QC5 , TLLB, LBOD, TWUT																															
8	PS PLANT , EBSM																															
9	WWT 3																															
10	สวนหย่อมหน้าแปลงมะกอก																															
11	สวนหย่อมลานสิ่งแวดล้อม																															
12	สนามหญ้าสวนหย่อม ยางมะตอย																															
13	โรงกรองน้ำ																															
14	สวนหย่อม NaNo																															
15	สวนหย่อม UHV																															
16	สนามหญ้าเด็ก A และ B																															
17	สนามหญ้าสวนหย่อมหน้าป้าย																															
18	สนามหญ้ารอบสนามบอล																															
19	สนามหญ้าสวนหย่อมสโมสร - สวนสุขภาพ																															
20	สนามหญ้าสวนหย่อม รอบ Sport Complex																															
21	สนามหญ้าพื้นที่ ศูนย์นวัตกรรม IIC																															

หมายเหตุ วันหยุด แผนปฏิบัติงาน วันเข้าชดเชย

ห้างหุ้นส่วนจำกัด สวนแมโจ้เนอร์สเซอรี่
5/40 ม.2 ต.เชิงเนิน อ.เมืองระยอง จ. ระยอง 21000
โทรศัพท์ 038-617670 , 038-861267 เลขประจำตัวผู้เสียภาษี 021353900575


แผนปฏิบัติงานตัดหญ้าสวนหย่อม - ตัดแต่ง -ทำโคน- ปี 2567

เดือน มิถุนายน 2567

ลำดับ	พื้นที่ปฏิบัติงาน	วันที่ 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
1	เกาะกลางสาย A สุขุมวิท- I2, I5																														
2	เกาะกลางถนน สาย B																														
3	เกาะกลางถนนสาย C																														
4	เกาะกลางถนนสาย D - F																														
5	เกาะสวนปาล์ม สนามหญ้ารอบโรงอาหาร																														
6	อาคารดับเพลิง-บุษราคัม-ทับทิม MS IP																														
7	OFFICE LUBE , QC5 , TLLB, LBOD, TWUT																														
8	PS PLANT , EBSM																														
9	WWT 3																														
10	สวนหย่อมหน้าแปลงมะกอก																														
11	สวนหย่อมลานสิ่งแวดล้อม																														
12	สนามหญ้าสวนหย่อม ยางมะตอย																														
13	โรงกรองน้ำ																														
14	สวนหย่อม NaNo																														
15	สวนหย่อม UHV																														
16	สนามหญ้าเด็ก A และ B																														
17	สนามหญ้าสวนหย่อมหน้าป้าย																														
18	สนามหญ้ารอบสนามบอล																														
19	สนามหญ้าสวนหย่อมสโมสร - สวนสุขภาพ																														
20	สนามหญ้าสวนหย่อม รอบ Sport Complex																														
21	สนามหญ้าพื้นที่ ศูนย์นวัตกรรม IIC																														

หมายเหตุ วันหยุด แผนปฏิบัติงาน วันเข้าชดเชย






Samsung Galaxy A05
มิถุนายน 11, 2024 08:56


Samsung Galaxy A05
มิถุนายน 12, 2024 15:15




E SAVING RULES
Goal Zero


09:44
04 มิ.ย. 2567
อ.
Timemark App
เวลา & สถานที่จริง


09:51
07 มิ.ย. 2567
ศ.
Timemark App
เวลา & สถานที่จริง

