ภาคผนวก ข-13

Action Plan กรณีผลการวิเคราะห์คุณภาพน้ำเสียไม่อยู่ในเกณฑ์มาตรฐาน

	รายการที่.	รายละเอียด	ผลกระทบ	วิธีการแก้ไข	ระยะเวลาการแก้ไข	ผลการทดสอบ	หมายเหตุ
	1	สาเหตุของผลวิเคราะห์คุณภาพน้ำเสียไม่อยู่ในเกณฑ์มาตรฐานกำหนด					
		1.1 Submersible Pump (Aerator Pump, Return Pump) ชำรุดไม่สามารถใช้งานได้สาเหตุเนื่องจาก Short Turn ตรวจสอบพบขยะติดที่ตัวใบพัด Pump (เช่น เศษผ้าทำความสะอาด, เศษผ้าไม่ถูพื้น, เศษไม้	ปริมาณ Oxygen ไม่เพียงพอต่อการนำไปใช้ย่อยสารอินทรีย์ในน้ำเสีย ส่งผลให้ค่า TDS สูง และมีตะกอนลอยสะสม	นำ Pump ออกไป Overhaul - พันขดลวดใหม่ - เปลี่ยนลูกปืน - เปลี่ยน Mechanical Seal - เปลี่ยน O-Ring - เปลี่ยนสายไฟ - เปลี่ยนน้ำมันเครื่อง - กลึงปลอกลูกปืน หน้า-หลัง	15-20 วัน	Equipmemt Testing Report (Pump or Control system)	1. ขอความร่วมมือผู้ใช้งานไม่ทิ้งเศษผ้า, เศษขยะแข็ง, หรือเศษขยะอื่นๆที่ Pump ไม่สามารถตัดได้ 2. ผลการวัดน้ำหลังดำเนินการแก้ไข อ้างอิงจากผลการวัดน้ำในรอบถัดไป
		1.2 การทิ้งน้ำที่มีค่าสารละลายสูงจากผู้ใช้งาน เช่น สารเคมีที่ชักล้าง หรือการล้างรถไฟในโรงซ่อมบำรุง	ส่งผลให้ค่า TDS และค่า TKN สูง	แจ้งผู้ใช้งานงดทิ้งน้ำทิ้งที่เกิดจากการชักล้างโดยให้ทิ้งน้ำชักล้างลงราง Gutter และเติมน้ำประปาเพื่อเจือจางสารชักล้าง	-	Analysis Report	แจ้งผู้ใช้งานให้ทิ้งน้ำชักล้างลงราง Gutter และเติมน้ำประปาเพื่อเจือจางสารชักล้าง
		1.3 มีกากอุจจาระ/ไขมันสะสมมาก/ตะกอนลอยมาก	ส่งผลให้ค่า TDS และค่า Sulfide สูง	จัดจ้างบริษัทสูบไปกำจัด และเติมเชื้อจุลินทรีย์หลังสูบ	1-2 วัน	Analysis Report	ต้องทำการขอ Work Perit

ภาคผนวก ข-14

Checklist การตักไขมันออกจากถัง Grease Trap

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: [redacted]

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-1-67	30	กรัม	[redacted]	
2-1-67	30	กรัม		
3-1-67	30	กรัม		
4-1-67	30	กรัม		
5-1-67	30	กรัม		
6-1-67	40	กรัม		
7-1-67	30	กรัม		
8-1-67	30	กรัม		
9-1-67	40	กรัม		
10-1-67	30	กรัม		
11-1-67	40	กรัม		
12-1-67	30	กรัม		
13-1-67	40	กรัม		
14-1-67	30	กรัม		
15-1-67	30	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่าง

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: [redacted]

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-1-67	30	กรัม	[redacted]	
17-1-67	30	กรัม		
18-1-67	30	กรัม		
19-1-67	30	กรัม		
20-1-67	30	กรัม		
21-1-67	40	กรัม		
22-1-67	30	กรัม		
23-1-67	40	กรัม		
24-1-67	30	กรัม		
25-1-67	30	กรัม		
26-1-67	30	กรัม		
27-1-67	30	กรัม		
28-1-67	30	กรัม		
29-1-67	30	กรัม		
30-1-67	30	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดเก่า ประจำเดือน: ธันวาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31-1-67	40	กรัม	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านก๋วยจั๊บ ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) (กรัม.)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-1-67	0.30	กรัม	[redacted]	
2/1/67	0.30	กรัม		
3/1/67	0.40	กรัม		
4/1/67	0.50	กรัม		
5/1/67	0.30	กรัม		
6/1/67	0.40	กรัม		
7/1/67	0.30	กรัม		
8/1/67	0.50	กรัม		
9/1/67	0.30	กรัม		
10/1/67	0.30	กรัม		
11/1/67	0.50	กรัม		
12/1/67	0.40	กรัม		
13/1/67	0.50	กรัม		
14/1/67	0.30	กรัม		
15/1/67	0.30	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านลำลิ่ง ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) (กรัม)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/1/67	30	กรัม	[redacted]	
17/1/67	50	กรัม		
18/1/67	20	กรัม		
19/1/67	40	กรัม		
20/1/67	30	กรัม		
21/1/67	30	กรัม		
22/1/67	40	กรัม		
23/1/67	30	กรัม		
24/1/67	50	กรัม		
25/1/67	30	กรัม		
26/1/67	30	กรัม		
27/1/67	20	กรัม		
28/1/67	30	กรัม		
29/1/67	40	กรัม		
30/1/67	50	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงให้มิดิการรั่วไหลได้

Form no: AERA3-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านลำลิ่ง ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) (กรัม)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/1/67	50	กรัม	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงให้มิดิการรั่วไหลได้

Form no: AERA3-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: หลังหมาก ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) (กรัม)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/1/67	.80	กรัม	[redacted]	
2/1/67	.00	กรัม		
3/1/67	.30	กรัม		
4/1/67	.30	กรัม		
5/1/67	.30	กรัม		
6/1/67	.30	กรัม		
7/1/67	.60	กรัม		
8/1/67	.30	กรัม		
9/1/67	.40	กรัม		
10/1/67	.30	กรัม		
11/1/67	.50	กรัม		
12/1/67	.40	กรัม		
13/1/67	.50	กรัม		
14/1/67	.30	กรัม		
15/1/67	20	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: หลังหมาก ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) (กรัม)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/1/67	50	กรัม	[redacted]	
17/1/67	30	กรัม		
18/1/67	30	กรัม		
19/1/67	40	กรัม		
20/1/67	50	กรัม		
21/1/67	30	กรัม		
22/1/67	50	กรัม		
23/1/67	20	กรัม		
24/1/67	30	กรัม		
25/1/67	10	กรัม		
26/1/67	20	กรัม		
27/1/67	30	กรัม		
28/1/67	20	กรัม		
29/1/67	30	กรัม		
30/1/67	40	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: หลังหมาก ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) ถังใบ	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/1/67	90 กก.	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วรองถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RKH ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	30 กก.	[redacted]	
2	30 กก.		
3	30 กก.		
4	30 กก.		
5	30 กก.		
6	30 กก.		
7	20 กก.		
8	20 กก.		
9	30 กก.		
10	30 กก.		
11	30 กก.		
12	30 กก.		
13	30 กก.		
14	20 กก.		
15	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วรองถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชั้น ประจำเดือน: กรกฎา

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	30 ถัง	[redacted]	
17	30 ถัง		
18	30 ถัง		
19	30 ถัง		
20	30 ถัง		
21	20 ถัง		
22	30 ถัง		
23	20 ถัง		
24	30 ถัง		
25	30 ถัง		
26	30 ถัง		
27	30 ถัง		
28	30 ถัง		
29	30 ถัง		
30	30 ถัง		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชั้น ประจำเดือน: กรกฎา

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31	20 ถัง	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-CLN-F8-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ศูนย์ มักกะสัน ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/01/67	20 กรัม	[redacted]	
2/01/67	30 กรัม		
3/01/67	20 กรัม		
4/01/67	20 กรัม		
5/01/67	30 กรัม		
6/01/67	20 กรัม		
7/01/67	20 กรัม		
8/01/67	30 กรัม		
9/01/67	30 กรัม		
10/01/67	30 กรัม		
11/01/67	20 กรัม		
12/01/67	20 กรัม		
13/01/67	20 กรัม		
14/01/67	20 กรัม		
15/01/67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ศูนย์ มักกะสัน ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/01/67	30 กรัม	[redacted]	
17/01/67	30 กรัม		
18/01/67	30 กรัม		
19/01/67	30 กรัม		
20/01/67	20 กรัม		
21/01/67	20 กรัม		
22/01/67	30 กรัม		
23/01/67	30 กรัม		
24/01/67	30 กรัม		
25/01/67	30 กรัม		
26/01/67	30 กรัม		
27/01/67	20 กรัม		
28/01/67	20 กรัม		
29/01/67	20 กรัม		
30/01/67	30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: สุภาชิ มักกะสัน ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/01/67	20 กิโล	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F8-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTB ประจำเดือน: มกราคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	30 กิโล	[redacted]	
2	30 กิโล		
3	30 กิโล		
4	30 กิโล		
5	20 กิโล		
6	30 กิโล		
7	20 กิโล		
8	20 กิโล		
9	30 กิโล		
10	30 กิโล		
11	30 กิโล		
12	30 กิโล		
13	20 กิโล		
14	20 กิโล		
15	20 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F8-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: กรกฎาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	30 กิโล	[redacted]	
17	30 กิโล		
18	30 กิโล		
19	30 กิโล		
30	30 กิโล		
31	30 กิโล		
33	30 กิโล		
35	30 กิโล		
38	30 กิโล		
39	30 กิโล		
42	30 กิโล		
43	30 กิโล		
47	30 กิโล		
54	30 กิโล		
30	30 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: กรกฎาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31	30 กิโล	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RDR ประจำเดือน: กรกฎาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	30 กิโล	[redacted]	
2	30 กิโล		
3	30 กิโล		
4	30 กิโล		
5	30 กิโล		
6	30 กิโล		
7	30 กิโล		
8	40 กิโล		
9	40 กิโล		
10	30 กิโล		
11	30 กิโล		
12	30 กิโล		
13	30 กิโล		
14	30 กิโล		
15	30 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RDR ประจำเดือน: กรกฎาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	30 กิโล	[redacted]	
17	30 กิโล		
18	30 กิโล		
19	30 กิโล		
20	30 กิโล		
21	30 กิโล		
22	30 กิโล		
23	30 กิโล		
24	30 กิโล		
25	30 กิโล		
26	30 กิโล		
27	30 กิโล		
28	30 กิโล		
29	30 กิโล		
30	30 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RDR ประจำเดือน: [illegible]

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31	30 กิโล	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA3-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องแม่บ้าน ประจำเดือน: ม.ค 64

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (กรัม)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/1/64	300 กรัม	[redacted]	
14/1/64	300 กรัม		
21/1/64	300 กรัม		
28/1/64	300 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA3-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: คอนโด 1 ประจำเดือน: ก.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/1/67	900 กรัม	[redacted]	
14/1/67	900 กรัม		
21/1/67	900 กรัม		
28/1/67	900 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: คอนโด 2 ประจำเดือน: ก.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/1/67	800 กรัม	[redacted]	
14/1/67	200 กรัม		
21/1/67	200 กรัม		
28/1/67	200 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชั้น 3 CCR ประจำเดือน: ม.ค. 17

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/1/17	300 กรัม	[redacted]	
14/1/17	300 กรัม		
21/1/17	300 กรัม		
28/1/17	300 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องอาหาร ประจำเดือน: ม.ค.17

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/1/17	500 กรัม	[redacted]	
14/1/17	500 กรัม		
21/1/17	500 กรัม		
28/1/17	500 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดระยอง ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1 - 2 - 67	30	กรัม	[redacted]	
2 - 2 - 67	30	กรัม		
3 - 2 - 67	20	กรัม		
4 - 2 - 67	30	กรัม		
5 - 2 - 67	20	กรัม		
6 - 2 - 67	30	กรัม		
7 - 2 - 67	30	กรัม		
8 - 2 - 67	20	กรัม		
9 - 2 - 67	20	กรัม		
10 - 2 - 67	30	กรัม		
11 - 2 - 67	30	กรัม		
12 - 2 - 67	40	กรัม		
13 - 2 - 67	30	กรัม		
14 - 2 - 67	40	กรัม		
15 - 2 - 67	30	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN F8-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดระยอง ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16 - 2 - 67		30	[redacted]	
17 - 2 - 67		40		
18 - 2 - 67		30		
19 - 2 - 67		40		
20 - 2 - 67		30		
21 - 2 - 67		40		
22 - 2 - 67		40		
23 - 2 - 67		40		
24 - 2 - 67		40		
25 - 2 - 67		30		
26 - 2 - 67		40		
27 - 2 - 67		30		
28 - 2 - 67		40		
29 - 2 - 67		40		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN F8-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: สวิฟท์ลาดพร้าว ประจำเดือน: กุมภาพันธ์ 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร) กรัม	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-2-67	40 กรัม	[redacted]	
2-2-67	80 กรัม		
3-2-67	60 กรัม		
4-2-67	30 กรัม		
5-2-67	40 กรัม		
6-2-67	40 กรัม		
7-2-67	60 กรัม		
8-2-67	30 กรัม		
9-2-67	60 กรัม		
10-2-67	40 กรัม		
11-2-67	60 กรัม		
12-2-67	30 กรัม		
13-2-67	40 กรัม		
14-2-67	60 กรัม		
15-2-67	40 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: สวิฟท์ลาดพร้าว ประจำเดือน: กุมภาพันธ์ 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-2-67	60 กรัม	[redacted]	
17-2-67	40 กรัม		
18-2-67	40 กรัม		
19-2-67	60 กรัม		
20-2-67	40 กรัม		
21-2-67	30 กรัม		
22-2-67	60 กรัม		
23-2-67	40 กรัม		
24-2-67	50 กรัม		
25-2-67	50 กรัม		
26-2-67	30 กรัม		
27-2-67	50 กรัม		
28-2-67	30 กรัม		
29-2-67	40 กรัม		
-			

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ราชมงคล ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) กรอบ	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-2-67	60 กรอบ	[redacted]	
2-2-67	40- กรอบ		
3-2-67	30- กรอบ		
4-2-67	60- กรอบ		
5-2-67	40- กรอบ		
6-2-67	40- กรอบ		
7-2-67	30- กรอบ		
8-2-67	60- กรอบ		
9-2-67	40- กรอบ		
10-2-67	60- กรอบ		
11-2-67	30- กรอบ		
12-2-67	40 กรอบ		
13-2-67	60 กรอบ		
14-2-67	30- กรอบ		
15-2-67	60 กรอบ		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-0000M-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ราชมงคล ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-2-67	40 กรอบ	[redacted]	
17-2-67	60 กรอบ		
18-2-67	30 กรอบ		
19-2-67	60 กรอบ		
20-2-67	40 กรอบ		
21-2-67	60 กรอบ		
22-2-67	50 กรอบ		
23-2-67	40 กรอบ		
24-2-67	50 กรอบ		
25-2-67	30 กรอบ		
26-2-67	50 กรอบ		
27-2-67	40 กรอบ		
28-2-67	50 กรอบ		
29-2-67	50 กรอบ		
30-			

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-0000M-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RRR ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	30 กรัม	[redacted]	
2	30 กรัม		
3	30 กรัม		
4	30 กรัม		
5	30 กรัม		
6	30 กรัม		
7	30 กรัม		
8	30 กรัม		
9	30 กรัม		
10	30 กรัม		
11	30 กรัม		
12	30 กรัม		
13	30 กรัม		
14	30 กรัม		
15	30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RRR ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	30 กรัม	[redacted]	
17	30 กรัม		
18	30 กรัม		
19	30 กรัม		
20	30 กรัม		
21	30 กรัม		
22	30 กรัม		
23	30 กรัม		
24	30 กรัม		
25	30 กรัม		
26	30 กรัม		
27	30 กรัม		
28	30 กรัม		
29	30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ลัดกะสิ้น ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1 - 2 - 67	20 กรัม	[redacted]	
2 - 2 - 67	20 กรัม		
3 - 2 - 67	20 กรัม		
4 - 2 - 67	30 กรัม		
5 - 2 - 67	30 กรัม		
6 - 2 - 67	20 กรัม		
7 - 2 - 67	30 กรัม		
8 - 2 - 67	20 กรัม		
9 - 2 - 67	20 กรัม		
10 - 2 - 67	30 กรัม		
11 - 2 - 67	30 กรัม		
12 - 2 - 67	20 กรัม		
13 - 2 - 67	30 กรัม		
14 - 2 - 67	20 กรัม		
15 - 2 - 67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ลัดกะสิ้น ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16 - 2 - 67	20 กรัม	[redacted]	
17 - 2 - 67	30 กรัม		
18 - 2 - 67	20 กรัม		
19 - 2 - 67	20 กรัม		
20 - 2 - 67	30 กรัม		
21 - 2 - 67	30 กรัม		
22 - 2 - 67	20 กรัม		
23 - 2 - 67	30 กรัม		
24 - 2 - 67	20 กรัม		
25 - 2 - 67	20 กรัม		
26 - 2 - 67	20 กรัม		
27 - 2 - 67	30 กรัม		
28 - 2 - 67	20 กรัม		
29 - 2 - 67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RBR ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	30 กิโล	[redacted]	
2	30 กิโล		
3	30 กิโล		
4	30 กิโล		
5	30 กิโล		
6	30 กิโล		
7	30 กิโล		
8	30 กิโล		
9	20 กิโล		
10	30 กิโล		
11	30 กิโล		
12	30 กิโล		
13	30 กิโล		
14	30 กิโล		
15	30 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดหมักถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RBR ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	30 กิโล	[redacted]	
17	20 กิโล		
18	30 กิโล		
19	30 กิโล		
20	30 กิโล		
21	30 กิโล		
22	30 กิโล		
23	30 กิโล		
24	30 กิโล		
25	30 กิโล		
26	30 กิโล		
27	30 กิโล		
28	30 กิโล		
29	30 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดหมักถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-XXXXX-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	20 กรัม	[redacted]	
2	20 กรัม		
3	20 กรัม		
4	30 กรัม		
6	20 กรัม		
7	20 กรัม		
8	25 กรัม		
9	30 กรัม		
10	30 กรัม		
11	30 กรัม		
12	20 กรัม		
13	20 กรัม		
14	20 กรัม		
15	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AEBA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: กุมภาพันธ์

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	20 กรัม	[redacted]	
17	20 กรัม		
18	30 กรัม		
19	30 กรัม		
20	20 กรัม		
21	30 กรัม		
22	30 กรัม		
23	20 กรัม		
24	30 กรัม		
25	20 กรัม		
26	20 กรัม		
27	20 กรัม		
28	20 กรัม		
29	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AEBA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: อาคาร 3 CCT ประจำเดือน: ก.ค. 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/2/67	300 กรัม	[redacted]	
11/2/67	300 กรัม		
19/2/67	300 กรัม		
25/2/67	300 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: อาคาร 1 ประจำเดือน: ก.ค. 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/2/67	200 กรัม	[redacted]	
11/2/67	200 กรัม		
19/2/67	200 กรัม		
25/2/67	200 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องแค่มีงาน ประจำเดือน: ก.ค. 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
4/7/67	200 กรัม	[redacted]	
11/7/67	200 กรัม		
18/7/67	200 กรัม		
25/7/67	200 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ออฟฟิศ 2 ประจำเดือน: ก.ค. 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
4/7/67	900 กรัม	[redacted]	
11/7/67	900 กรัม		
18/7/67	900 กรัม		
25/7/67	900 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดกางเง้ง ประจำเดือน: มีนาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-3-67	40	กรัม	[redacted]	
2-3-67	40	กรัม		
3-3-67	40	กรัม		
4-3-67	40	กรัม		
5-3-67	30	กรัม		
6-3-67	30	กรัม		
7-3-67	40	กรัม		
8-3-67	40	กรัม		
9-3-67	40	กรัม		
10-3-67	40	กรัม		
11-3-67	30	กรัม		
12-3-67	40	กรัม		
13-3-67	40	กรัม		
14-3-67	40	กรัม		
15-3-67	40	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดกางเง้ง ประจำเดือน: มีนาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-3-67	40	กรัม	[redacted]	
17-3-67	40	กรัม		
18-3-67	40	กรัม		
19-3-67	40	กรัม		
20-3-67	40	กรัม		
21-3-67	40	กรัม		
22-3-67	40	กรัม		
23-3-67	40	กรัม		
24-3-67	40	กรัม		
25-3-67	50	กรัม		
26-3-67	40	กรัม		
27-3-67	40	กรัม		
28-3-67	40	กรัม		
29-3-67	40	กรัม		
30-3-67	40	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-03004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ครัวกลางปีก ประจำเดือน: มีนาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31-3-67	40	ถุงใส	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้างทับช้าง ประจำเดือน: มีนาคม 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/3/67	40 กรัม	[redacted]	
2/03/67	50 กรัม		
3/03/67	30 กรัม		
4/03/67	50 กรัม		
5/03/67	40 กรัม		
6/03/67	30 กรัม		
7/03/67	50 กรัม		
8/03/67	40 กรัม		
9/03/67	30 กรัม		
10/03/67	40 กรัม		
11/03/67	50 กรัม		
12/03/67	30 กรัม		
13/03/67	40 กรัม		
14/03/67	50 กรัม		
15/03/67	40 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: มหาชัยสิงห์ ประจำเดือน: มีนาคม 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/3/67	40 กรัม	[redacted]	
17/3/67	60 กรัม		
18/3/67	30 กรัม		
19/3/67	40 กรัม		
20/3/67	40 กรัม		
21/3/67	50 กรัม		
22/3/67	40 กรัม		
23/3/67	60 กรัม		
24/3/67	40 กรัม		
25/3/67	60 กรัม		
26/3/67	30 กรัม		
27/3/67	60 กรัม		
28/3/67	60 กรัม		
29/3/67	50 กรัม		
30/3/67	40 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ปั๊มอาร์ยสิงห์ ประจำเดือน: มีนาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/3/67	30กรัม	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชัวหมาก ประจำเดือน: มีนาคม 2567

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/03/67	50 กรัม	[redacted]	
2/03/67	40 กรัม		
3/03/67	50 กรัม		
4/03/67	50 กรัม		
5/03/67	40 กรัม		
6/03/67	50 กรัม		
7/03/67	40 กรัม		
8/03/67	50 กรัม		
9/03/67	40 กรัม		
10/03/67	50 กรัม		
11/03/67	40 กรัม		
12/03/67	50 กรัม		
13/03/67	50 กรัม		
14/03/67	50 กรัม		
15/03/67	50 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชัวหมาก ประจำเดือน: มีนาคม 2567

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/3/67	50 กรัม	[redacted]	
17/3/67	40 กรัม		
18/3/67	50 กรัม		
19/3/67	50 กรัม		
20/3/67	40 กรัม		
21/3/67	50 กรัม		
22/3/67	40 กรัม		
23/3/67	50 กรัม		
24/3/67	50 กรัม		
25/3/67	40 กรัม		
26/3/67	50 กรัม		
27/3/67	50 กรัม		
28/3/67	40 กรัม		
29/3/67	50 กรัม		
30/3/67	50 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชฎาพร ประจำเดือน: มีนาคม 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/3/67	40 กิโล	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RSA ประจำเดือน: มีนาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	20 กิโล	[redacted]	
2	20 กิโล		
3	20 กิโล		
4	20 กิโล		
5	20 กิโล		
6	20 กิโล		
7	20 กิโล		
8	20 กิโล		
9	20 กิโล		
10	20 กิโล		
11	20 กิโล		
12	20 กิโล		
13	20 กิโล		
14	20 กิโล		
15	20 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านกา ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	50 กิโล	[redacted]	
17	50 กิโล		
18	50 กิโล		
19	50 กิโล		
20	50 กิโล		
21	50 กิโล		
22	50 กิโล		
23	50 กิโล		
24	50 กิโล		
25	50 กิโล		
26	50 กิโล		
27	50 กิโล		
28	50 กิโล		
29	50 กิโล		
30	50 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านกา ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31	50 กิโล	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F6-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ศูนย์ฯ มักกะสัน ประจำเดือน: มีนาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (มิลลิ)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-3-67	60 กรัม	[redacted]	
2-3-67	30 กรัม		
3-3-67	30 กรัม		
4-3-67	30 กรัม		
5-3-67	30 กรัม		
6-3-67	30 กรัม		
7-3-67	30 กรัม		
8-3-67	30 กรัม		
9-3-67	20 กรัม		
10-3-67	50 กรัม		
11-3-67	20 กรัม		
12-3-67	30 กรัม		
13-3-67	30 กรัม		
14-3-67	20 กรัม		
15-3-67	30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ศูนย์ฯ มักกะสัน ประจำเดือน: มีนาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (มิลลิ)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-3-67	20 กรัม	[redacted]	
17-3-67	20 กรัม		
18-3-67	30 กรัม		
19-3-67	30 กรัม		
20-3-67	30 กรัม		
21-3-67	30 กรัม		
22-3-67	30 กรัม		
23-3-67	20 กรัม		
24-3-67	20 กรัม		
25-3-67	30 กรัม		
26-3-67	20 กรัม		
27-3-67	30 กรัม		
28-3-67	20 กรัม		
29-3-67	30 กรัม		
30-3-67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ศูนย์ ม้าบุคลิน ประจำเดือน: สิงหาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31 - 5 - 67	30 กก้อน	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F8-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RPR ประจำเดือน: สิงหาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	20 กก.	[redacted]	
2	20 กก.		
3	20 กก.		
4	20 กก.		
5	30 กก.		
6	30 กก.		
7	20 กก.		
8	20 กก.		
9	20 กก.		
10	20 กก.		
11	20 กก.		
12	20 กก.		
13	20 กก.		
14	20 กก.		
15	30 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F8-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RPR ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	20 กก.	[redacted]	
15	20 กก.		
17	20 กก.		
19	20 กก.		
20	30 กก.		
21	30 กก.		
22	20 กก.		
23	20 กก.		
24	20 กก.		
25	20 กก.		
26	20 กก.		
27	20 กก.		
28	20 กก.		
29	30 กก.		
30	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F6-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RPR ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31	30 กก.	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F6-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: DTF ประจำเดือน: สิงหาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	50 กก.	[redacted]	
2	50 กก.		
3	50 กก.		
4	50 กก.		
5	30 กก.		
6	50 กก.		
7	50 กก.		
8	50 กก.		
9	50 กก.		
10	30 กก.		
11	50 กก.		
12	50 กก.		
13	50 กก.		
14	50 กก.		
15	30 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: DTF ประจำเดือน: สิงหาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	50 กก.	[redacted]	
17	50 กก.		
18	30 กก.		
19	50 กก.		
20	30 กก.		
21	50 กก.		
22	50 กก.		
23	50 กก.		
24	50 กก.		
25	50 กก.		
26	50 กก.		
27	50 กก.		
28	50 กก.		
29	30 กก.		
30	30 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: DTH ประจำเดือน: ตุลาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31	10 กิโล	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ดอนเมือง 1 ประจำเดือน: ส.ค. 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (กรัม)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/8/67	200 กรัม	[redacted]	
9/8/67	200 กรัม		
16/8/67	200 กรัม		
23/8/67	200 กรัม		
30/8/67	200 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ออฟฟิศ 2 ประจำเดือน: มี.ค 17

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/3/17	200 กรัม	[redacted]	
9/3/17	200กรัม		
16/3/17	200 กรัม		
23/3/17	200กรัม		
30/3/17	200กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตึกแม่ฉันทร์ ประจำเดือน: มี.ค 17

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/3/17	100 กรัม	[redacted]	
9/3/17	100 กรัม		
16/3/17	100กรัม		
23/3/17	100 กรัม		
30/3/17	100กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องอาหาร ประจำเดือน: มี.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/3/67	300กรัม	[redacted]	
9/3/67	300กรัม		
16/3/67	300กรัม		
23/3/67	300กรัม		
30/3/67	300กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องอาหาร ประจำเดือน: มี.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/3/67	300 กรัม	[redacted]	
9/3/67	300กรัม		
16/3/67	300กรัม		
23/3/67	300กรัม		
30/3/67	300กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-E0004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดตาหนิ ประจำเดือน: มีนาคม 64

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-4-67	40	กรัม	[redacted]	
2-4-67	40	กรัม		
3-4-67	40	กรัม		
4-4-67	40	กรัม		
5-4-67	40	กรัม		
6-4-67	40	กรัม		
7-4-67	40	กรัม		
8-4-67	40	กรัม		
9-4-67	40	กรัม		
10-4-67	50	กรัม		
11-4-67	40	กรัม		
12-4-67	40	กรัม		
13-4-67	40	กรัม		
14-4-67	40	กรัม		
15-4-67	40	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดตาหนิ ประจำเดือน: มีนาคม 64

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-4-67	40	กรัม	[redacted]	
17-4-67	40	กรัม		
18-4-67	30	กรัม		
19-4-67	45	กรัม		
20-4-67	40	กรัม		
21-4-67	35	กรัม		
22-4-67	40	กรัม		
23-4-67	45	กรัม		
24-4-67	45	กรัม		
25-4-67	40	กรัม		
26-4-67	45	กรัม		
27-4-67	45	กรัม		
28-4-67	40	กรัม		
29-4-67	40	กรัม		
30-4-67	45	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ภัทรกัลยาณิวัฒนา ประจำเดือน: มีนาคม 2567

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/4/67	40 กรัม	[redacted]	
2/4/67	30 กรัม		
3/4/67	50 กรัม		
4/4/67	40 กรัม		
5/4/67	50 กรัม		
6/4/67	30 กรัม		
7/4/67	50 กรัม		
8/4/67	40 กรัม		
9/4/67	50 กรัม		
10/4/67	30 กรัม		
11/4/67	30 กรัม		
12/4/67	50 กรัม		
13/4/67	40 กรัม		
14/4/67	40 กรัม		
15/4/67	50 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดฝาถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ภัทรกัลยาณิวัฒนา ประจำเดือน: มีนาคม 2567

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/4/67	40 กรัม	[redacted]	
17/4/67	50 กรัม		
18/4/67	40 กรัม		
19/4/67	35 กรัม		
20/4/67	50 กรัม		
21/4/67	45 กรัม		
22/4/67	30 กรัม		
23/4/67	45 กรัม		
24/4/67	40 กรัม		
25/4/67	50 กรัม		
26/4/67	40 กรัม		
27/4/67	45 กรัม		
28/4/67	30 กรัม		
29/4/67	40 กรัม		
30/4/67	40 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดฝาถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: หน้าหลาก ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) (กรัม)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/4/67	60 กรัม	[redacted]	
2/4/67	60 กรัม		
3/4/67	40 กรัม		
4/4/67	40 กรัม		
5/4/67	50 กรัม		
6/4/67	60 กรัม		
7/4/67	40 กรัม		
8/4/67	30 กรัม		
9/4/67	40 กรัม		
10/4/67	60 กรัม		
11/4/67	50 กรัม		
12/4/67	60 กรัม		
13/4/67	80 กรัม		
14/4/67	40 กรัม		
15/4/67	50 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: หน้าหลาก ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร) (กรัม)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/4/67	40 กรัม	[redacted]	
17/4/67	30 กรัม		
18/4/67	40 กรัม		
19/4/67	40 กรัม		
20/4/67	60 กรัม		
21/4/67	60 กรัม		
22/4/67	40 กรัม		
23/4/67	60 กรัม		
24/4/67	30 กรัม		
26/4/67	50 กรัม		
26/4/67	30 กรัม		
27/4/67	40 กรัม		
28/4/67	60 กรัม		
29/4/67	40 กรัม		
30/4/67	60 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชั้น1 ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	10 กก	[redacted]	
2	10 กก		
3	10 กก		
4	10 กก		
5	10 กก		
6	10 กก		
7	10 กก		
8	10 กก		
9	10 กก		
10	10 กก		
11	10 กก		
12	10 กก		
13	10 กก		
14	10 กก		
15	10 กก		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชั้น1 ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	10 กก	[redacted]	
17	10 กก		
18	10 กก		
19	10 กก		
20	10 กก		
21	10 กก		
22	10 กก		
23	10 กก		
24	10 กก		
25	10 กก		
26	10 กก		
27	10 กก		
28	10 กก		
29	10 กก		
30	10 กก		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ฟู่ถาวิน มักกะสัน ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/4/67	20 กรัม	[redacted]	
2/4/67	30 กรัม		
3/4/67	20 กรัม		
4/4/67	20 กรัม		
5/4/67	20 กรัม		
6/4/67	20 กรัม		
7/4/67	10 กรัม		
8/4/67	20 กรัม		
9/4/67	20 กรัม		
10/4/67	30 กรัม		
11/4/67	30 กรัม		
12/4/67	20 กรัม		
13/4/67	20 กรัม		
14/4/67	10 กรัม		
15/4/67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีฐารั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ฟู่ถาวิน มักกะสัน ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/4/67	20 กรัม	[redacted]	
17/4/67	30 กรัม		
18/4/67	20 กรัม		
19/4/67	20 กรัม		
20/4/67	20 กรัม		
21/4/67	10 กรัม		
22/4/67	30 กรัม		
23/4/67	20 กรัม		
24/4/67	20 กรัม		
25/4/67	20 กรัม		
26/4/67	30 กรัม		
27/4/67	20 กรัม		
28/4/67	10 กรัม		
29/4/67	20 กรัม		
30/4/67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีฐารั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RDR ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	20 กก.	[redacted]	
2	20 กก.		
3	20 กก.		
4	20 กก.		
5	20 กก.		
6	20 กก.		
7	20 กก.		
8	20 กก.		
9	20 กก.		
10	20 กก.		
11	20 กก.		
12	20 กก.		
13	20 กก.		
14	20 กก.		
15	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RDR ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	20 กก.	[redacted]	
17	20 กก.		
18	20 กก.		
19	20 กก.		
20	20 กก.		
21	20 กก.		
22	20 กก.		
23	20 กก.		
24	20 กก.		
25	20 กก.		
26	20 กก.		
27	20 กก.		
28	20 กก.		
29	20 กก.		
30	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-60004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1	20 กก.	[redacted]	
2	20 กก.		
3	20 กก.		
4	20 กก.		
5	20 กก.		
6	30 กก.		
7	20 กก.		
8	20 กก.		
9	20 กก.		
10	20 กก.		
11	20 กก.		
12	20 กก.		
13	30 กก.		
14	20 กก.		
15	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: เมษายน

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16	20 กก.	[redacted]	
17	20 กก.		
18	20 กก.		
19	20 กก.		
20	20 กก.		
21	20 กก.		
22	20 กก.		
23	30 กก.		
24	20 กก.		
25	20 กก.		
26	20 กก.		
27	20 กก.		
28	20 กก.		
29	30 กก.		
30	30 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านเขย่าน้ำหวาน ประจำเดือน: เมษายน ๖๗

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
๗/๔/๖๗	๘๐๐ กรัม	[redacted]	
๑๔/๔/๖๗	๘๐๐ กรัม		
๒๑/๔/๖๗	๘๐๐ กรัม		
๒๘/๔/๖๗	๘๐๐กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ออฟฟิศ ๒ ประจำเดือน: เมษายน ๖๗

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
๗/๔/๖๗	๙๐๐ กรัม	[redacted]	
๑๔/๔/๖๗	๙๐๐กรัม		
๒๑/๔/๖๗	๙๐๐ กรัม		
๒๘/๔/๖๗	๙๐๐กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: อินเด CCY ประจำเดือน: เมษายน 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/4/67	300กรัม	[redacted]	
14/4/67	300กรัม		
21/4/67	300กรัม		
28/4/67	300กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: อาโฟล 1 ประจำเดือน: เมษายน 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/4/67	900กรัม	[redacted]	
14/4/67	900กรัม		
21/4/67	900กรัม		
28/4/67	900กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องอาหาร ประจำเดือน: เมษายน 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
7/4/67	500กรัม	[redacted]	
14/4/67	500กรัม		
21/4/67	500กรัม		
28/4/67	500กรัม		

ข้อควรระวัง:
1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตาดตาะพัง ประจำเดือน: พฤษภาคม 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-5-67	40	กรัม	[redacted]	
2-5-67	45	กรัม		
3-5-67	40	กรัม		
4-5-67	45	กรัม		
5-5-67	45	กรัม		
6-5-67	40	กรัม		
7-5-67	40	กรัม		
8-5-67	45	กรัม		
9-5-67	45	กรัม		
10-5-67	40	กรัม		
11-5-67	45	กรัม		
12-5-67	40	กรัม		
13-5-67	45	กรัม		
14-5-67	40	กรัม		
15-5-67	45	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตาดตาะพัง ประจำเดือน: พฤษภาคม 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-5-67	40	กรัม	[redacted]	
17-5-67	45	กรัม		
18-5-67	45	กรัม		
19-5-67	40	กรัม		
20-5-67	40	กรัม		
21-5-67	45	กรัม		
22-5-67	45	กรัม		
23-5-67	45	กรัม		
24-5-67	40	กรัม		
25-5-67	40	กรัม		
26-5-67	40	กรัม		
27-5-67	45	กรัม		
28-5-67	40	กรัม		
29-5-67	45	กรัม		
30-5-67	40	กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ตลาดวงนิง ประจำเดือน: พฤษภาคม 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31-5-67	45	กรัม	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านครัวลุงช้าง ประจำเดือน: พฤษภาคม /67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-5-67		30 กรัม	[redacted]	
2-5-67		50 กรัม		
3-5-67		40 กรัม		
4-5-67		30 กรัม		
5-5-67		50 กรัม		
6-5-67		40 กรัม		
7-5-67		30 กรัม		
8-5-67		40 กรัม		
9-5-67		50 กรัม		
10-5-67		30 กรัม		
11-5-67		40 กรัม		
12-5-67		30 กรัม		
13-5-67		60 กรัม		
14-5-67		50 กรัม		
15-5-67		30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านอาหารสยาม ประจำเดือน: พฤษภาคม 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-5-67	40 กก.	[redacted]	
17-5-67	50 กก.		
18-5-67	30 กก.		
19-5-67	50 กก.		
20-5-67	40 กก.		
21-5-67	40 กก.		
22-5-67	50 กก.		
23-5-67	40 กก.		
24-5-67	30 กก.		
25-5-67	50 กก.		
26-5-67	40 กก.		
27-5-67	50 กก.		
28-5-67	30 กก.		
29-5-67	40 กก.		
30-5-67	50 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านอาหารสยาม ประจำเดือน: พฤษภาคม 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร) กก.	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31-5-67	40 กก.	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้างหมาก ประจำเดือน: พฤษภาคม 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-5-67		50 กรัม	[redacted]	
2-5-67		50 กรัม		
3-5-67		40 กรัม		
4-5-67		50 กรัม		
5-5-67		40 กรัม		
6-5-67		30 กรัม		
7-5-67		40 กรัม		
8-5-67		50 กรัม		
9-5-67		40 กรัม		
10-5-67		50 กรัม		
11-5-67		40 กรัม		
12-5-67		50 กรัม		
13-5-67		40 กรัม		
14-5-67		50 กรัม		
15-5-67		30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้างหมาก ประจำเดือน: พฤษภาคม 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-5-67		50 กรัม	[redacted]	
17-5-67		40 กรัม		
18-5-67		40 กรัม		
19-5-67		50 กรัม		
20-5-67		40 กรัม		
21-5-67		40 กรัม		
22-5-67		50 กรัม		
23-5-67		40 กรัม		
24-5-67		50 กรัม		
25-5-67		30 กรัม		
26-5-67		40 กรัม		
27-5-67		50 กรัม		
28-5-67		30 กรัม		
29-5-67		40 กรัม		
30-5-67		50 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: หัวหมาก ประจำเดือน: พฤศจิกายน 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31 ต.ค.-67	ถังใส	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RRR ประจำเดือน: กรกฎาคม 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/07/68	10 ลิตร	[redacted]	
2/07/68	10 ลิตร		
3/07/68	10 ลิตร		
4/07/68	10 ลิตร		
5/07/68	10 ลิตร		
6/07/68	30 ลิตร		
7/07/68	10 ลิตร		
8/07/68	10 ลิตร		
9/07/68	10 ลิตร		
10/07/68	10 ลิตร		
11/07/68	10 ลิตร		
12/07/68	10 ลิตร		
13/07/68	10 ลิตร		
14/07/68	10 ลิตร		
15/07/68	10 ลิตร		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: กุมภาพันธ์ 2568

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/2/68	10 ลิตร	[redacted]	
17/2/68	10 ลิตร		
18/2/68	10 ลิตร		
19/2/68	10 ลิตร		
20/2/68	10 ลิตร		
21/2/68	10 ลิตร		
22/2/68	10 ลิตร		
23/2/68	10 ลิตร		
24/2/68	10 ลิตร		
25/2/68	10 ลิตร		
26/2/68	10 ลิตร		
27/2/68	10 ลิตร		
28/2/68	10 ลิตร		
29/2/68	10 ลิตร		
1/3/68	10 ลิตร		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: กุมภาพันธ์ 2568

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/2/68	10 ลิตร	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: สำนักงาน MAS ประจำเดือน: พฤษภาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/5/67	30 กรัม	[redacted]	
2/5/67	30 กรัม		
3/5/67	30 กรัม		
4/5/67	20 กรัม		
5/5/67	20 กรัม		
6/5/67	30 กรัม		
7/5/67	30 กรัม		
8/5/67	20 กรัม		
9/5/67	20 กรัม		
10/5/67	30 กรัม		
11/5/67	20 กรัม		
12/5/67	20 กรัม		
13/5/67	30 กรัม		
14/5/67	30 กรัม		
15/5/67	30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: สำนักงาน MAS ประจำเดือน: พฤษภาคม

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/5/67	30 กรัม	[redacted]	
17/5/67	30 กรัม		
18/5/67	20 กรัม		
19/5/67	20 กรัม		
20/5/67	30 กรัม		
21/5/67	30 กรัม		
22/5/67	30 กรัม		
23/5/67	30 กรัม		
24/5/67	30 กรัม		
25/5/67	20 กรัม		
26/5/67	20 กรัม		
27/5/67	30 กรัม		
28/5/67	30 กรัม		
29/5/67	30 กรัม		
30/5/67	30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: สกาโน่ MAS ประจำเดือน: พฤษภาคม

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/5/67	30 กรัม	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FB-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RPP ประจำเดือน: กุมภาพันธ์ 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/2/67	50 กรัม	[redacted]	
2/2/67	50 กรัม		
3/2/67	50 กรัม		
4/2/67	50 กรัม		
5/2/67	50 กรัม		
6/2/67	50 กรัม		
7/2/67	50 กรัม		
8/2/67	50 กรัม		
9/2/67	50 กรัม		
10/2/67	50 กรัม		
11/2/67	50 กรัม		
12/2/67	50 กรัม		
13/2/67	50 กรัม		
14/2/67	50 กรัม		
15/2/67	50 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FB-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RDR ประจำเดือน: กุมภาพันธ์ 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/2/68	20 กก.	[redacted]	
2/2/68	20 กก.		
3/2/68	20 กก.		
4/2/68	20 กก.		
5/2/68	20 กก.		
6/2/68	20 กก.		
7/2/68	20 กก.		
8/2/68	20 กก.		
9/2/68	20 กก.		
10/2/68	20 กก.		
11/2/68	20 กก.		
12/2/68	20 กก.		
13/2/68	20 กก.		
14/2/68	20 กก.		
15/2/68	20 กก.		
16/2/68	20 กก.		
17/2/68	20 กก.		
18/2/68	20 กก.		
19/2/68	20 กก.		
20/2/68	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RDR ประจำเดือน: กุมภาพันธ์ 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
21/2/68	20 กก.	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: กุมภาพันธ์ 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/2/68	20 กก.	[redacted]	
2/2/68	20 กก.		
3/2/68	20 กก.		
4/2/68	20 กก.		
5/2/68	20 กก.		
6/2/68	20 กก.		
7/2/68	20 กก.		
8/2/68	20 กก.		
9/2/68	20 กก.		
10/2/68	20 กก.		
11/2/68	20 กก.		
12/2/68	20 กก.		
13/2/68	20 กก.		
14/2/68	20 กก.		
15/2/68	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: กุมภาพันธ์ 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/2/68	20 กก.	[redacted]	
17/2/68	20 กก.		
18/2/68	20 กก.		
19/2/68	20 กก.		
20/2/68	20 กก.		
21/2/68	20 กก.		
22/2/68	20 กก.		
23/2/68	20 กก.		
24/2/68	20 กก.		
25/2/68	20 กก.		
26/2/68	20 กก.		
27/2/68	20 กก.		
28/2/68	20 กก.		
29/2/68	20 กก.		
30/2/68	20 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: กุมภาพันธ์ 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
31/01/25	30 ลิตร	[redacted]	

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ออฟฟิศ 1 ประจำเดือน: ก.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
5/5/67	200 กรัม	[redacted]	
12/5/67	200 กรัม		
19/5/67	200 กรัม		
26/5/67	200 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดผนึกถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: คอนโด 2 ประจำเดือน: พ.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
5/5/67	900 กรัม	[redacted]	
12/5/67	900 กรัม		
19/5/67	900 กรัม		
26/5/67	900 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องแม่บ้าน ประจำเดือน: พ.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
5/5/67	100 กรัม	[redacted]	
12/5/67	100 กรัม		
19/5/67	100 กรัม		
26/5/67	100 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องอาหาร ประจำเดือน: พ.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
5/5/67	500 กรัม	[redacted]	
12/5/67	500 กรัม		
19/5/67	500 กรัม		
26/5/67	500 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชั้น 3 CCR ประจำเดือน: พ.ค. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
5/5/67	300 กรัม	[redacted]	
12/5/67	300 กรัม		
19/5/67	300 กรัม		
26/5/67	300 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: มิถุนายน 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-6-67	45	กรีม	[redacted]	
2-6-67	40	กรีม		
3-6-67	40	กรีม		
4-6-67	45	กรีม		
5-6-67	40	กรีม		
6-6-67	45	กรีม		
7-6-67	40	กรีม		
8-6-67	45	กรีม		
9-6-67	40	กรีม		
10-6-67	40	กรีม		
11-6-67	45	กรีม		
12-6-67	40	กรีม		
13-6-67	40	กรีม		
14-6-67	40	กรีม		
15-6-67	45	กรีม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: [redacted] ประจำเดือน: มิถุนายน 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-6-67	40	กรีม	[redacted]	
17-6-67	40	กรีม		
18-6-67	40	กรีม		
19-6-67	45	กรีม		
20-6-67	40	กรีม		
21-6-67	40	กรีม		
22-6-67	40	กรีม		
23-6-67	40	กรีม		
24-6-67	45	กรีม		
25-6-67	40	กรีม		
26-6-67	40	กรีม		
27-6-67	40	กรีม		
28-6-67	45	กรีม		
29-6-67	40	กรีม		
30-6-67	40	กรีม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-F6-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: สาขาสวัสดิการ ประจำเดือน: มิ.ย. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-6-67	40 กร	[redacted]	
2-6-67	60 กร		
3-6-67	50 กร		
4-6-67	50 กร		
5-6-67	30 กรัม		
6-6-67	40 กรัม		
7-6-67	50 กรัม		
8-6-67	30 กรัม		
9-6-67	40 กรัม		
10-6-67	50 กรัม		
11-6-67	40 กรัม		
12-6-67	60 กรัม		
13-6-67	30 กรัม		
14-6-67	50 กรัม		
15-6-67	40 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-[illegible]

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ร้านสวัสดิการ ประจำเดือน: มิ.ย. 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-6-67	กรัม	[redacted]	
17-6-67	40 กรัม		
18-6-67	50 กรัม		
19-6-67	50 กรัม		
20-6-67	40 กรัม		
21-6-67	40 กรัม		
22-6-67	60 กรัม		
23-6-67	60 กรัม		
24-6-67	60 กรัม		
25-6-67	40 กรัม		
26-6-67	60 กรัม		
27-6-67	50 กรัม		
28-6-67	40 กรัม		
29-6-67	60 กรัม		
30-6-67	45 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีกลิ่นรั่วไหลได้

Form no: AERA1-OPS-[illegible]

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: รถิรามาก ประจำเดือน: มิถุนายน / 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1-6-67		40 กรัม	[redacted]	
2-6-67		60 กรัม		
3-6-67		30 กรัม		
4-6-67		60 กรัม		
5-6-67		40 กรัม		
6-6-67		40 กรัม		
7-6-67		30 กรัม		
8-6-67		60 กรัม		
9-6-67		40 กรัม		
10-6-67		60 กรัม		
11-6-67		40 กรัม		
12-6-67		60 กรัม		
13-6-67		50 กรัม		
14-6-67		40 กรัม		
15-6-67		30 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: รถิรามาก ประจำเดือน: มิถุนายน / 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)		ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16-6-67		30 กรัม	[redacted]	
17-6-67		40 กรัม		
18-6-67		60 กรัม		
19-6-67		30 กรัม		
20-6-67		50 กรัม		
21-6-67		30 กรัม		
22-6-67		40 กรัม		
23-6-67		60 กรัม		
24-6-67		30 กรัม		
25-6-67		40 กรัม		
26-6-67		30 กรัม		
27-6-67		60 กรัม		
28-6-67		40 กรัม		
29-6-67		30 กรัม		
30-6-67		50 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RKN ประจำเดือน: สิงหาคม พ.ศ. 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/8/68	10 กก.	[redacted]	
2/8/68	10 กก.		
3/8/68	10 กก.		
4/8/68	10 กก.		
5/8/68	10 กก.		
6/8/68	10 กก.		
7/8/68	10 กก.		
8/8/68	10 กก.		
9/8/68	10 กก.		
10/8/68	10 กก.		
11/8/68	10 กก.		
12/8/68	10 กก.		
13/8/68	10 กก.		
14/8/68	10 กก.		
15/8/68	10 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RKN ประจำเดือน: สิงหาคม พ.ศ. 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/8/68	10 กก.	[redacted]	
17/8/68	10 กก.		
18/8/68	10 กก.		
19/8/68	10 กก.		
20/8/68	10 กก.		
21/8/68	10 กก.		
22/8/68	10 กก.		
23/8/68	10 กก.		
24/8/68	10 กก.		
25/8/68	10 กก.		
26/8/68	10 กก.		
27/8/68	10 กก.		
28/8/68	10 กก.		
29/8/68	10 กก.		
30/8/68	10 กก.		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่

2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ศูนย์ฯ มักกะสัน ประจำเดือน: มิถุนายน 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/6/67	20 กรัม	[redacted]	
2/6/67	20 กรัม		
3/6/67	30 กรัม		
4/6/67	30 กรัม		
5/6/67	30 กรัม		
6/6/67	30 กรัม		
7/6/67	30 กรัม		
8/6/67	20 กรัม		
9/6/67	20 กรัม		
10/6/67	30 กรัม		
11/6/67	30 กรัม		
12/6/67	30 กรัม		
13/6/67	30 กรัม		
14/6/67	30 กรัม		
15/6/67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FB-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ศูนย์ฯ มักกะสัน ประจำเดือน: มิถุนายน 2567

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/6/67	20 กรัม	[redacted]	
17/6/67	30 กรัม		
18/6/67	30 กรัม		
19/6/67	30 กรัม		
20/6/67	30 กรัม		
21/6/67	30 กรัม		
22/6/67	20 กรัม		
23/6/67	20 กรัม		
24/6/67	30 กรัม		
25/6/67	30 กรัม		
26/6/67	30 กรัม		
27/6/67	30 กรัม		
28/6/67	30 กรัม		
29/6/67	20 กรัม		
30/6/67	20 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FB-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RPR ประจำเดือน: ธันวาคม พ.ศ. 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
1/12/68	50 ลิตร	[redacted]	
2/12/68	50 ลิตร		
3/12/68	50 ลิตร		
4/12/68	50 ลิตร		
5/12/68	50 ลิตร		
6/12/68	50 ลิตร		
7/12/68	50 ลิตร		
8/12/68	50 ลิตร		
9/12/68	50 ลิตร		
10/12/68	50 ลิตร		
11/12/68	50 ลิตร		
12/12/68	50 ลิตร		
13/12/68	50 ลิตร		
14/12/68	50 ลิตร		
15/12/68	50 ลิตร		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: RPR ประจำเดือน: ธันวาคม พ.ศ. 2568

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
16/12/68	50 ลิตร	[redacted]	
17/12/68	50 ลิตร		
18/12/68	50 ลิตร		
19/12/68	50 ลิตร		
20/12/68	50 ลิตร		
21/12/68	50 ลิตร		
22/12/68	50 ลิตร		
23/12/68	50 ลิตร		
24/12/68	50 ลิตร		
25/12/68	50 ลิตร		
26/12/68	50 ลิตร		
27/12/68	50 ลิตร		
28/12/68	50 ลิตร		
29/12/68	50 ลิตร		
30/12/68	50 ลิตร		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: สิงหาคม ๒๕๖๕

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
๑/๘/๖๕	๑๐ ลิตร	[redacted]	
๒/๘/๖๕	๑๐ ลิตร		
๓/๘/๖๕	๑๐ ลิตร		
๔/๘/๖๕	๑๐ ลิตร		
๕/๘/๖๕	๑๐ ลิตร		
๖/๘/๖๕	๑๐ ลิตร		
๗/๘/๖๕	๑๐ ลิตร		
๘/๘/๖๕	๑๐ ลิตร		
๙/๘/๖๕	๑๐ ลิตร		
๑๐/๘/๖๕	๑๐ ลิตร		
๑๑/๘/๖๕	๑๐ ลิตร		
๑๒/๘/๖๕	๑๐ ลิตร		
๑๓/๘/๖๕	๑๐ ลิตร		
๑๔/๘/๖๕	๑๐ ลิตร		
๑๕/๘/๖๕	๑๐ ลิตร		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: PTT ประจำเดือน: สิงหาคม ๒๕๖๕

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (ลิตร)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
๑๖/๘/๖๕	๑๐ ลิตร	[redacted]	
๑๗/๘/๖๕	๑๐ ลิตร		
๑๘/๘/๖๕	๑๐ ลิตร		
๑๙/๘/๖๕	๑๐ ลิตร		
๒๐/๘/๖๕	๑๐ ลิตร		
๒๑/๘/๖๕	๑๐ ลิตร		
๒๒/๘/๖๕	๑๐ ลิตร		
๒๓/๘/๖๕	๑๐ ลิตร		
๒๔/๘/๖๕	๑๐ ลิตร		
๒๕/๘/๖๕	๑๐ ลิตร		
๒๖/๘/๖๕	๑๐ ลิตร		
๒๗/๘/๖๕	๑๐ ลิตร		
๒๘/๘/๖๕	๑๐ ลิตร		
๒๙/๘/๖๕	๑๐ ลิตร		
๓๐/๘/๖๕	๑๐ ลิตร		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณขยะไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ดอนโต๊ะ 1 ประจำเดือน: มิ.ย 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (กิโล)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/6/67	900 กิโล	[redacted]	
9/6/67	900 กิโล		
16/6/67	900 กิโล		
23/6/67	900 กิโล		
30/6/67	900 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ดอนโต๊ะ 2 ประจำเดือน: มิ.ย 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (กิโล)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/6/67	900 กิโล	[redacted]	
9/6/67	900 กิโล		
16/6/67	900 กิโล		
23/6/67	900 กิโล		
30/6/67	900 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERAS-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ห้องเพ้นท์พ ประจำเดือน: มิ.ย 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (กรัม)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/6/67	400 กรัม	[redacted]	
9/6/67	400 กรัม		
16/6/67	400 กรัม		
23/6/67	400 กรัม		
30/6/67	400 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

ASIA ERA ONE

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: หน้าอาคาร ประจำเดือน: มิ.ย 67

วันที่ปฏิบัติงาน	ปริมาณของไขมัน (กรัม)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/6/67	500 กรัม	[redacted]	
9/6/67	500 กรัม		
16/6/67	500 กรัม		
23/6/67	500 กรัม		
30/6/67	500 กรัม		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด
2. ปริมาณของไขมันให้วัดโดยการตวง หน่วยวัดปริมาตรเป็นลิตร
3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ของไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

Form no: AERA1-OPS-CLN-FR-00004-01

แบบฟอร์มบันทึกการทำความสะอาดถังดักไขมัน

สถานที่: ชั้น 3 CCT ประจำเดือน: มิ.ย 67

วันที่ปฏิบัติงาน	ปริมาณขยะไขมัน (กิโล)	ผู้ปฏิบัติงาน	ผู้ตรวจสอบ
2/6/67	300 กิโล	[redacted]	
9/6/67	300 กิโล		
16/6/67	300 กิโล		
23/6/67	300 กิโล		
30/6/67	300 กิโล		

ข้อควรระวัง: 1. กรุณาปฏิบัติตามขั้นตอนการทำความสะอาดถังดักไขมันอย่างเคร่งครัด

2. ปริมาณขยะไขมันให้วัดโดยการชั่ง หน่วยวัดปริมาตรเป็นลิตร

3. กรุณาตรวจสอบความสมบูรณ์, รอยรั่วของถุงที่ใส่ขยะไขมันทุกครั้ง และปิดมัดถุงไม่ให้มีการรั่วไหลได้

ภาคผนวก ข-15

การตรวจสอบประสิทธิภาพของระบบบำบัดน้ำเสีย

(Wastewater Treatment)

Preventive Maintenance BES Y1

Work Order No.:	96154973
Funct.Location:	BES-SAN-RPR Ratchaprarop Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1689
MNT. Call No.: 32
MNT. Item No.: 2979
MNT. Task Grp.: BES_SAN GC.: 39
Plan Date: 03.01.2024
Basic Start Date: 11.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@RPR (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@RPR (Wast wate treatment) (Y1)	3	15.0 MIN	
0020 0010	RPR-G-WWT-01	0	0.0	
0020 0020	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0020 0030	Use form : PMW-BES-70000-050-LN	0	0.0	
0030	Final checking and testing by	0	0.0	47
0030 0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Activity No.	Date	Time	Date	Time	Travelling Time	Waiting Time	Working Time	Maintenance ID
0020	5/11/2024	1:30	5/11/2024	1:30	-	-	10	44

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Break on/off required (Y/N)	Confirmed by Customer (Name)	Signature
Start Working Time	5/11/2024	1:30	Y	[redacted]	
End Working Time / Malfunction End** / ETO	5/11/2024	1:40			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y = Break on/off required , N = Break on/off not required

SRTET

6. MAINTENANCE ACTION

Failure Cause Code	Failure Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐ 1-Restricted Ser. Major Failure	☐ 4-Unrestricted Ser. Major Failure
☐ 2-Restricted Ser.-Minor Failure	☐ 5-Unrestricted Ser. Minor Failure
☐ 3-Restricted Ser.-No failure	☐ 6-Unrestricted Ser. No Failure

9. SERVICE OR WARRANTY

☐ Repair
☐ Additional Service (Support)
☐ Warranty (DLP, Normal Warranty)

Checked by Supervisor	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

WORK ORDER NO. : 96154933 | STATION: APR | LOCATION: Corridor

EQUIPMENT NO : WWT - 01 | SERIAL NO. : | DATE INSPECTION : 5/11/2024

FREQUENCY: [ ] W [ ] 1M [ ] 2M [ ] 3M [ ] 6M [✓] 1Y

CHECK: JAN ✓ | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	[✓] Normal	[ ] Fault	
2	Check the condition of motor	Normal condition	[-] Normal	[ ] Fault	
3	Check the connection of pump & motor	Normal condition	[-] Normal	[ ] Fault	
4	Check the defect of pump and motor while its running	Normal condition	[-] Normal	[ ] Fault	
5	Check the defection of electrical part	Normal operation	[-] Normal	[ ] Fault	
6	Check all equipment inside the cabinet control	Normal condition	[-] Normal	[ ] Fault	
7	Check leakage of all valve and pipe	Not leakage	[-] Normal	[ ] Fault	
8	Check the operation of floating valve	Normal condition	[-] Normal	[ ] Fault	
9	Check the condition of all connector	Tight and not loose	[-] Normal	[ ] Fault	
10	Measure and record running current of motor	Standard	R .....A S .....A T .....A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N.....V S - N.....V T - N.....V	R - S.....V S - T.....V T - R.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	[ ] Normal	[ ] Fault
13	Check all the anchors	Tight and not loose	[ ] Normal	[ ] Fault
14	Check and tighten terminal wiring	Tight and not loose	[ ] Normal	[ ] Fault
15	Check and clean magnetic contactor	Normal condition	[ ] Normal	[ ] Fault

Recommendations / Remark : No water equipment

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.					
2.					

Service By :	Position	Start Date	End Date
1. [redacted]	Tech	5/11/2024	5/11/2024
2.	Tech		
3.		Start Time	End Time
4.		1:30	5:45
5.			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By	Confirmed B	Approved By :
Date : 5/11/2024	Date : 05 M.A. 2567	Date : 23 Jun 67

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

Preventive Maintenance BES Y1

Work Order No.:	96155183
Funct.Location:	BES-SAN-MAS Makkasan Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1680
MNT. Call No.: 39
MNT. Item No.: 2976
MNT. Task Grp.: BES-SAN GC: 36
Plan Date: 03.01.2024
Basic Start Date: 11.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@MAS (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@MAS (Wast water treatment) (Y1)	4	30.0 MIN	
0020-0010	MAS-G-WWT-01	0	0.0	
0020-0020	MAS-G-WWT-02	0	0.0	
0020-0030	Follow Procedure : PRW-BES-70000-059-T11	0	0.0	
0020-0040	Use form : FMW-BES-70000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030-0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit

SIEMENS

WW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Activity No.	Active Start Date	Active Start Time	Active End Date	Active End Time	Travelling Time	Waiting Time	Working Time	Manpower ID
001	26/11/2024	9 : 00	26/11/2024	4 : 00	-	-	1:30	4+4

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be interveved by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Location Head (Print Name)	Signature
Start Working Time	26/11/2024	9 : 00	Y	[redacted]	[redacted]
End Working Time / Malfunction End** / TRD	26/11/2024	4 : 00			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not [illegible] as the time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

AERA ONE

28/11/24

6. MAINTENANCE ACTION

Failure Code	Failure Code Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

1-RestrictedSer. Major Failure	4-UnrestrictSer. Major Failure
2-RestrictedSer. Minor Failure	5-UnrestrictSer. Minor Failure
3-RestrictedSer. No failure	6-UnrestrictSer. No Failure

9. SERVICE OR WARRANTY

- Repair
- Additional Service (Support)
- Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Pte. 2022 All Rights Reserved
Uncontrolled if printed out or copied

WW

WORK ORDER NO. : 01155183	STATION : MAS	LOCATION : STORM
EQUIPMENT NO : AT blower 01	SERIAL NO. : -	DATE INSPECTION : 28/11/2024

FREQUENCY	W	1M	2M	3M	6M	1Y
CHECK	JAN / FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result	Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal ☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal ☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal ☐ Fault	
4	Check the detect of pump and motor while it's running	Normal condition	☑ Normal ☐ Fault	
5	Check the detection of electrical part	Normal operation	☑ Normal ☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal ☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal ☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal ☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal ☐ Fault	
10	Measure and record running current of motor	Standard	I1 3.00 A I2 3.88 A I3 3.96 A	
11	Measure and record supply voltage	220+10%[198-242V] 400+10%[360-440V]	R-N 234 V R-S 410 V S-N 219 V S-T 416 V T-N 228 V T-R 414 V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal ☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal ☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal ☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal ☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	Ac clamp Meter	305	A23A081U	24/8/25	
2.					

Service P		Position	Start Date	End Date
1	[redacted]	Tech	26/11/2024	26/11/2024
2		Tech		
3			Start Time	End Time
4.			9:00	16:00
5.				

Signature :
Checked By : [redacted]
Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO. : WMP0193 | STATION : MAS | LOCATION : Ground

EQUIPMENT NO : Air blower 02 | SERIAL NO. : | DATE INSPECTION : 28/11/2024

FREQUENCY: W | 1M | 2M | 3M | 6M | 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	R ..0.62..A S ..0.62..A T ..0.60..A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R-N ..219..V R-S ..410..V S-N ..230..V S-T ..415..V T-N ..227..V T-R ..409..V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	Ac clamp Meter	233	A7522C0114	26/8/24	—
2					

Service	Position	Start Date	End Date
1. [redacted]	Tech.	28/11/2024	28/11/24
2.	Tech.		
3		Start Time	End Time
4		9 : 00	16 : 00
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date : 28 พ.ย. 2567	Date : 6/02/67

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO. : WMP0185 | STATION : MAS | LOCATION : Ground

EQUIPMENT NO : Return pump 01 | SERIAL NO. : | DATE INSPECTION : 28/11/2024

FREQUENCY: W | 1M | 2M | 3M | 6M | 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	R ..0.60..A S ..0.63..A T ..0.60..A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R-N ..230..V R-S ..401..V S-N ..231..V S-T ..402..V T-N ..230..V T-R ..402..V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	Ac clamp Meter	233	A2330514	26/8/24	
2					

Service	Position	Start Date	End Date
1. [redacted]	Tech.	28/11/2024	28/11/24
2	Tech.		
3		Start Time	End Time
4		9 : 00	16 : 00
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date : 28 พ.ย. 2567	Date : 6/02/67

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO.: 96155187 | STATION: MAS | LOCATION: FOUND
EQUIPMENT NO.: Return pump 02 | SERIAL NO.: | DATE INSPECTION: 08/1/24
FREQUENCY: W | 1M | 2M | 3M | 6M | 1Y
CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 1 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	Normal	Fault	
2	Check the condition of motor	Normal condition	Normal	Fault	
3	Check the connection of pump & motor	Normal condition	Normal	Fault	
4	Check the defect of pump and motor while it's running	Normal condition	Normal	Fault	
5	Check the defection of electrical part	Normal operation	Normal	Fault	
6	Check all equipment inside the cabinet control	Normal condition	Normal	Fault	
7	Check leakage of all valve and pipe	Not leakage	Normal	Fault	
8	Check the operation of floating valve	Normal condition	Normal	Fault	
9	Check the condition of all connector	Tight and not loose	Normal	Fault	
10	Measure and record running current of motor	Standard	R ...A S ...A T ...A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R-N ...V S-N ...V T-N ...V R-S ...V S-T ...V T-R ...V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	Normal	Fault	
13	Check all the anchors	Tight and not loose	Normal	Fault	
14	Check and tighten terminal wiring	Tight and not loose	Normal	Fault	
15	Check and clean magnetic contactor	Normal condition	Normal	Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	Ac clamp meter	324	44330414	26/8/24	
2.					

Service [redacted]

	Manhour	Start Date	End Date
1.	2ch	08/1/24	08/1/24
2.	2ch		
3.		Start Time	End Time
4.		08.00	10.00
5.			

Technician	Senior Technician / Supervisor	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked :	Confirmed By :	Approved By :
Date :	Date : 2 0 AUG 2024	Date : 6/01/67

Copyright © WHA & Wireless Co., Ltd. 2022 All Rights Reserved.

Preventive Maintenance BES Y1

Work Order No.: 96155187
Funct.Location: BES-SAN-PTH
Phaya Thai Station
Equipment: N/A
Location: N/A
Mileage/Operation (hr): _____

MNT. Plan No.: 1688
MNT. Call No.: 32
MNT. Item No.: 2978
MNT. Task Grp.: BES SAN GC: 38
Plan Date: 03.01.2024
Basic Start Date: 11.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@PTH (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@PTH (Wast water treatment) (Y1)	3	15.0 MIN	
0020 0010	PTH G WWT-01	0	0.0	
0020 0020	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0020 0030	Use form : FMW-BES-70000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	47
0030 0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WWW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Person in charge No.	Activity Start Date	Activity Start Time	Activity End Date	Activity End Time	Total Working Time	Total Waiting Time	Total Pause Time	Maintenance ID
0026	4/1/24	05:00	4/1/24	05:30	-	-	30	47

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Back on/off required (Y/N)	Confirmed by	Signature
Start Working Time	4/1/24	05:00		[redacted]	
End Working Time / Malfunction End** / PPO	4/1/24	05:30	Y		

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same when maintenance activities finish. Y = Back on/off required, N = Back on/off not required

6. MAINTENANCE ACTION

Failure Part Code	Failure Part Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐ 1-RestrictedSer.-Major Failure	☐ 4 UnrestrictSer. Major Failure
☐ 2-RestrictedSer.-Minor Failure	☐ 5-UnrestrictSer. Minor Failure
☐ 3-RestrictedSer.-No Failure	☐ 6 UnrestrictSer. No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (DLP, Normal Warranty)

Confirmed by Station Staff	Checked by Maintenance Supervisor	Closed by Station	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Pte. Ltd. All Rights Reserved
Uncontrolled if printed out or copied

WWW

WORK ORDER NO.: 96155187	STATION: PTH		LOCATION: Corridor
EQUIPMENT NO.: WWT - 01	SERIAL NO.: -		DATE INSPECTION: 4/1/24
FREQUENCY	☐ W ☐ 1M ☐ 2M ☐ 3M ☐ 6M ☑ 1Y		
CHECK	JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC		

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result	Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal ☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal ☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal ☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal ☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal ☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal ☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal ☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal ☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal ☐ Fault	
10	Measure and record running current of motor	Standard	I1 ....A I2 ....A I3 ....A	
11	Measure and record supply voltage	380+10%(180-242V) 400+10%(360-440V)	R - N ....V R - S ....V S - N ....V S - T ....V T - N ....V T - R V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal ☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal ☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal ☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal ☐ Fault	

Recommendations / Remark : Vibration Ok No motor equipment

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1					
2					

Service	Position	Start Date	End Date
1. [redacted]	Tech	4/1/24	4/1/24
2.	Tech	Start Time	End Time
3		05:00	05:30
4			
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date : 3-4-24 05:57

Copyright © Wee & Wardcare Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

Preventive Maintenance BES Y1

Work Order No.:	96155238
Funct.Location:	BES-SAN-RKH Ramkhamhaeng Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.:	1690
MNT. Call No.:	52
MNT. Item No.:	2980
MNT. Task Grp.:	BES-SAN GC : 10
Plan Date:	10.01.2024
Basic Start Date:	11.01.2024
Basic End Date:	31.01.2024

1.WORK ORDER DESCRIPTION : PM@RKH (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@RKH (Wast water treatment) (Y1)	3	15.0 MIN	
0020-0010	RKH-G-WWT-01	0	0.0	
0020-0020	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0020-0030	Use form : FMW-BES-70000-056 EN	0	0.0	
0030	Final checking and testing by	0	0.0	107
0030-0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit

SIEMENS

4. MAINTENANCE TIME RECORDING* (1 or more activities, please continue page 4)

Operation No.	Actual Start Date	Actual Start Time	Actual Finish Date	Actual Finish Time	Travelling Time	Waiting Time	Working Time	Maintenance ID
0020	6/1/24	23:00	6/1/24	23:20	-	-	20	107, 157

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Break (Y/N) required (Y/N)	Confirmed by Customer (Name)	Signature
Start Working Time	6/1/24	23:00	Y	[redacted]	
End Working Time / Malfunction End** (EPD)	6/1/24	23:20			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y = Break on/off required , N = Break on/off not required

6. MAINTENANCE ACTION

RKH

Failure Cause Code	Failure Cause Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐	1-Restricted/Ser. Major Failure	☐	4-Unrestricted/Ser. Major Failure
☐	2-Restricted/Ser.-Minor Failure	☐	5-Unrestricted/Ser. Minor Failure
☐	3-Restricted/Ser.-No failure	☐	6-Unrestricted/Ser. No Failure

9. SERVICE OR WARRANTY

☐	Repair
☐	Additional Service (Support)
☐	Warranty (DLP, Normal Warranty)

Prepared by Supervisor	Approved by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Form	Airport Rail Link Project
Work Order Confirmation Form	Effective Date: 15 JUN 2022
Document Code: FMC-FRC-00000-006-EN-A	Page 3 of 4

Copyright © Siemens Mobility Ltd. 2022. All Rights Reserved. Uncontrolled if printed out or copied

WORK ORDER NO.: 96155233 | STATION: RKH | LOCATION: Ground
EQUIPMENT NO.: WWT | SERIAL NO.: | DATE INSPECTION: 6/11/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☐ 3M ☐ 6M ☑ 1Y

CHECK	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
	✓											

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result	Remark
1	Check the shaft cover of pump	Normal condition	☐ Normal ☐ Fault	
2	Check the condition of motor	Normal condition	☐ Normal ☐ Fault	
3	Check the connection of pump & motor	Normal condition	☐ Normal ☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☐ Normal ☐ Fault	
5	Check the defection of electrical part	Normal operation	☐ Normal ☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☐ Normal ☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☐ Normal ☐ Fault	
8	Check the operation of flowing valve	Normal condition	☐ Normal ☐ Fault	
9	Check the condition of all connector	Tight and not loose	☐ Normal ☐ Fault	
10	Measure and record running current of motor	Standard	I1 .....A I2 .....A I3 .....A	
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N.....V R - S.....V S - N.....V S - T.....V T - N.....V T - R.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal ☐ Fault
13	Check all the anchors	Tight and not loose	☐ Normal ☐ Fault
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal ☐ Fault
15	Check and clean magnetic contactor	Normal condition	☐ Normal ☐ Fault

Recommendations / Remark: No motor equipment.

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.					
2.					
3					

[redacted]

	Position	Start Date	End Date
	Eng	6/11/24	6/11/24
	Tech	Start Time	End Time
		13.00	13.20

Technician	Senior Technician / Engineer	Senior Engineer
[redacted]		

Signature :
Checked by :
Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved
Uncontrolled if printed out or copied

Preventive Maintenance BES Y1

Work Order No.:	96155343
Funct.Location:	BES SAN DPK Depot Klongton
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1687
MNT. Call No.: 32
MNT. Item No.: 2977
MNT. Task Grp.: BES-SAN GC: 37
Plan Date: 10.01.2024
Basic Start Date: 10.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@DPK (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@DPK (Wast water treatment) (Y1)	4	30.0 MIN	
0020 0010	DPK G WWT 01	0	0.0	
0020 0020	DPK G WWT 02	0	0.0	
0020 0030	DPK G WWT 03	0	0.0	
0020 0040	DPK G-WWT-04	0	0.0	
0020 0050	Follow Procedure : PKW-BLS-70000-059-111	0	0.0	
0020 0060	Use form : PMW-BLS-70000-056-UN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030 0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Activity No.	Start Date	Start Time	End Date	End Time	Actual Break (minute)	Total Break Time	Working Time (minute)	Maintainer ID
0010	16/1/24	11:00	16/1/24	18:00	-	-	60	111

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	16/1/24	11:00	N	[redacted]	
End Working Time / Malfunction End** / FFO	16/1/24	18:00			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y - Book on/off required . N – Book on/off not required

6. MAINTENANCE ACTION

Failure Code	Failure Cont. Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐ 1-RestrictedSer.-Major Failure	☐ 4-UnrestrictSer.-Major Failure
☐ 2-RestrictedSer.-Minor Failure	☐ 5-UnrestrictSer.-Minor Failure
☐ 3-RestrictedSer.-No failure	☐ 6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (D.F.P, Normal Warranty)

Checked by Site Leader	Confirmed by Manager / Supervisor	Checked by Section	Checked by FSC
[redacted]	[redacted]		
Signature / Date	Signature / Date	Signature / Date	Signature / Date

27 Apr 2024

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WW

WORK ORDER NO. : 96155343	STATION : DRK			LOCATION : MW2 / Envelope	
EQUIPMENT NO. : Duct - Chamber	SERIAL NO. :			DATE INSPECTION : 16/1/24	
FREQUENCY	☐ W	☐ 1M	☐ 2M	☐ 3M	☐ 6M ☑ 1Y
CHECK	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result	Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal ☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal ☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal ☐ Fault	
4	Check the detect of pump and motor while it's running	Normal condition	☑ Normal ☐ Fault	
5	Check the defaction of electrical part	Normal operation	☑ Normal ☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal ☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal ☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal ☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal ☐ Fault	
10	Measure and record running current of motor	Standard	R 3.06 A S 2.93 A T 3.07 A	
11	Measure and record supply voltage	380+10%(198.9±9V) 400+10%(360 ±18V)	R - N 224 V R - S 388 V S - N 224 V S - T 390 V T - N 226 V T - R 391 V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal ☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal ☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal ☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal ☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	AC Clamp meter	325	43350716	26/8/24	
2.					

Service By :	Position	Start Date	End Date
[redacted]	Tech	16/1/24	16/1/24
	Tech	Start Time	End Time
		11:00	12:00

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date : 16/1/24	Date : 16 JAN 2567	Date : 6/02/67

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO.: 96165545 | STATION: DPK | LOCATION: MWS / Process

EQUIPMENT NO.: WWT - Return Pump | SERIAL NO.: | DATE INSPECTION: 16/1/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☐ 3M ☐ 6M ☑ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the detect of pump and motor while its running	Normal condition	☑ Normal	☐ Fault	
5	Check the detection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	R ..0.8.. A S ..0.6.. A T ..0.6.. A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ..224.. V R - S ..398.. V S - N ..224.. V S - T ..399.. V T - N ..225.. V T - R ..397.. V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	AC Clamp Meter	824	45350514	26/2/24	-
2.					

Service By :	Position	Start Date	End Date
1. [redacted]	Tech	16/1/24	16/1/24
2.			
3.	Tech	Start Time	End Time
4.		11:00	12:00
5.			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date : 16 JAN 2024	Date : 6/02/24

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO.: 96165545 | STATION: DPK | LOCATION: MWS / Process

EQUIPMENT NO.: WWT - Aerator | SERIAL NO.: | DATE INSPECTION: 16/1/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☐ 3M ☐ 6M ☑ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the detect of pump and motor while its running	Normal condition	☑ Normal	☐ Fault	
5	Check the detection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	R ..2.8.. A S ..2.6.. A T ..2.6.. A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ..224.. V R - S ..391.. V S - N ..224.. V S - T ..393.. V T - N ..225.. V T - R ..391.. V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	AC Clamp Meter	585	45350516	26/2/24	-
2.					

Service By :	Position	Start Date	End Date
1. [redacted]	Tech	16/1/24	16/1/24
2.			
3.	Tech	Start Time	End Time
4.		11:00	12:00
5.			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date : 16 JAN 2024	Date : 6/02/24

Form: Check Sheet PM_Sanitary-Plumbing System - Waste Water Treatment
Document Code: FMW-BRS-70000-056-EN-A
Airport Rail Link Project
Effective Date: 25 FEB 2022
Page 3 of 3

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved
Uncontrolled if printed out or copied

WORK ORDER NO.: 96155343	STATION: BRK	LOCATION: HUM (Workshop)
EQUIPMENT NO: WWT- Return	SERIAL NO.:	DATE INSPECTION: 16/1/24

FREQUENCY	W	1M	2M	3M	6M	1Y
CHECK						✓

JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

DESCRIPTION OF MAINTENANCE EVENY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	✓ Normal	Fault	
2	Check the condition of motor	Normal condition	✓ Normal	Fault	
3	Check the connection of pump & motor	Normal condition	✓ Normal	Fault	
4	Check the defect of pump and motor while it's running	Normal condition	✓ Normal	Fault	
5	Check the defection of electrical part	Normal operation	✓ Normal	Fault	
6	Check all equipment inside the cabinet control	Normal condition	✓ Normal	Fault	
7	Check leakage of all valve and pipe	Not leakage	✓ Normal	Fault	
8	Check the operation of floating valve	Normal condition	✓ Normal	Fault	
9	Check the condition of all connector	Tight and not loose	✓ Normal	Fault	
10	Measure and record running current of motor	Standard	R ..0.62.. A S ..0.61.. A T ..0.61.. A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ..225.. V S - N ..223.. V T - N ..224.. V	R - S ..392.. V S - T ..390.. V T - R ..391.. V	

DESCRIPTION OF MAINTENANCE EVENY 1 YEAR

NO.	Description	Standard	Result		Remark
12	Check the vibration of equipment	Standard	✓ Normal	Fault	
13	Check all the anchors	Tight and not loose	✓ Normal	Fault	
14	Check and tighten terminal wiring	Tight and not loose	✓ Normal	Fault	
15	Check and clean magnetic contactor	Normal condition	✓ Normal	Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	AC Clamp Meter	345	45930914	26/3/24	

Service By :	POSITION	Start Date	End Date
1. [redacted]	Tech	16/1/24	16/1/24
2.			
3	Tech	Start Time	End Time
4		11:00	12:00
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date : 16/1/24	Date : 16 JAN 2024	Date : 6/02/24

Copyright © Wee & Wanbee Co., Ltd. 2022 All Rights Reserved

Preventive Maintenance BES Y1

Work Order No.:	96155403
Funct.Location:	BES-SAN-HUM Humark Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1091
MNT. Call No.: 32
MNT. Item No.: 2981
MNT. Task Grp.: BES-SAN-GC-41
Plan Date: 17.01.2024
Basic Start Date: 11.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@HUM (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@HUM (Wast water treatment) (Y1)	3	15.0 MIN	
0020 0010	HUM G WWT-01	0	0.0	
0020 0020	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0020 0030	Use form : FMW-BES-70000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	167
0030 0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit

SIEMENS

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Activity No.	Start Date	Start Time	End Date	End Time	Travelling Time	Waiting Time	Working Time	Remark(s)
0090	6/1/24	20:35	6/1/24	21:00	-	-	25	107,159

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Break Down Facilitated (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	6/1/24	20:35	[redacted]	[redacted]	
End Working Time / Malfunction End** (CFE)	6/1/24	21:00			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessarily the same as the time when maintenance activities finish. Y = Break on/off required , N = Break on/off not required

6. MAINTENANCE ACTION

Failure Hint Code	Failure Hint Text
Cause Code	**Cause Text**
Action Code	**Action Text**

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐ 1-RestrictedSer. Major Failure	☐ 4-UnrestrictSer.-Major Failure
☐ 2-RestrictedSer.-Minor Failure	☐ 5-UnrestrictSer. Minor Failure
☐ 3-RestrictedSer-No failure	☐ 6-UnrestrictSer. No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (DLP, Normal Warranty)

Checked by Supervisor	Checked by Maintenance Management	Closed by Station	Checked by FRS
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO.: 6[illegible]4 | STATION: HUH | LOCATION: Station
EQUIPMENT NO: S-WWT-01 | SERIAL NO.: - | DATE INSPECTION: 6/1/24

FREQUENCY: ☐ W ☐ 1M | 2M ☐ 3M | 6M ☑ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 1 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☐ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☐ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☐ Normal	☐ Fault	
4	Check the noise of pump and motor while it's running	Normal condition	☐ Normal	☐ Fault	
6	Check the defection of electrical part	Normal operation	☐ Normal	☐ Fault	
9	Check all equipment inside the cabinet control	Normal condition	☐ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☐ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☐ Normal	☐ Fault	
5	Check the condition of all connector	Tight and not loose	☐ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 .....A I2 .....A I3 .....A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N.....V S - N.....V T - N.....V	R - S.....V S - T.....V T - R.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault
13	Check all the motors	Tight and not loose	☐ Normal	☐ Fault
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault

Recommendations / Remark: No motor Equipment

Consumables / Spare Part Used:

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.					
2.					

Service By: [redacted] | Position: Engr / Tech | Start Date: 1/1/24 | End Date: 6/1/24 | Start Time: 9a.35 | End Time: 21:00

Technician	Senior Technician / Engineer	
Signature: [redacted]	Sign: [redacted]	Signature: [redacted]
Checked:	Confirmed:	Approved By:
Date:	Date:	Date: 7, Jun, 22

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved
Uncontrolled if printed out or copied

Preventive Maintenance BES Y1

Work Order No.:	96155519
Funct.Location:	BES-SAN-TSS
	Traction Sub Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1694
MNT. Call No.: 40
MNT. Item No.: 2984
MNT. Task Grp.: BES SAN GC.: 44
Plan Date: 17.01.2024
Basic Start Date: 11.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@TSS (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@TSS (Wast water treatment) (Y1)	3	15.0 MIN	
0020-0010	TSS-G-WWT-01	0	0.0	
0020-0020	Follow Procedure . PRW-BES-70000-059-TH	0	0.0	
0020-0030	Use form . FMW-BES-70000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	107
0030-0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS MW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Actual Start Date	Actual Start Time	Actual End Date	Actual End Time	Actual Duration (Hours)	Actual Duration (Minutes)	Actual Duration (Days)	Employee ID
0020	10/1/24	11 : 20	10/1/24	11 : 40	-	-	20	107,150
		:		:				
		:		:				
		:		:				

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be in-crossed by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	10/1/24	11 : 20			[redacted]
End Working Time / Malfunction End** / FFO	10/1/24	11 : 40			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y – Book on/off required , N – Book on/off not required

6. MAINTENANCE ACTION

Failure Code	Failure Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

- ☐ 1-RestrictedSer -Major Failure
- ☐ 2-RestrictedSer -Minor Failure
- ☐ 3-RestrictedSer -No failure
- ☐ 4-UnrestrictSer -Major Failure
- ☐ 5-UnrestrictSer -Minor Failure
- ☐ 6-UnrestrictSer -No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (D.F, Normal Warranty)

Supervised by	Checked by Maintenance Supervisor	Closed by Section	Checked by FRC
[redacted]	[redacted]		
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Form
Work Order Confirmation Form
Document Code: LMO-FRC-00000-006-EN-A

Aircraft Rail Line Project
Effective Date: 15 JUN 2022
Page 3 of 4

Copyright © Siemens Mobility Ltd. 2022. All Rights Reserved. Uncontrolled if printed out or copied

WORK ORDER NO.: 96155519 | STATION: TSS | LOCATION: Ground
EQUIPMENT NO.: WWT | SERIAL NO.: | DATE INSPECTION: 10/11/24
FREQUENCY: ☐ W ☐ 1M ☐ 2M ☐ 3M ☐ 6M ☑ 1Y
CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☐ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☐ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☐ Normal	☐ Fault	
4	Check the defect of pump and motor while its coupling	Normal condition	☐ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☐ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☐ Normal	☐ Fault	
7	Check leakage of all valve and pipe	No leakage	☐ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☐ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☐ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	R .....A		
			S .....A		
			T .....A		
11	Measure and record supply voltage	230+10%(198-242V) 400+10%(360-440V)	R - N.....V	R - S.....V	
			S - N.....V	S - T.....V	
			T - N.....V	T - R.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark: No motor equipment

Consumables / Spare Part Used:

Measuring Instrument

NO.	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1					
2					

Service By :	Position	Start Date	End Date
1. [redacted]	Eng	10/11/24	10/11/24
2			
3	Tech	Start Time	End Time
4		11.20	11.40
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]		Signature : [redacted]
Checked By		Approved By :
Date :		Date : 05 Nov 24

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved. | Uncontrolled if printed and or copied

Preventive Maintenance BES Y1

Work Order No.: 96155604
Funct.Location: BES-SAN-LKB
Latchalang Station
Equipment: N/A
Location: N/A
Mileage/Operation (hr):

MNT. Plan No.: 1693
MNT. Call No.: 32
MNT. Item No.: 2983
MNT. Task Grp.: BES SAN GO2 43
Plan Date: 24.01.2024
Basic Start Date: 11.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@LKB (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@LKB (Wast water treatment) (Y1)	3	15.0 MIN	
0020 0010	LKB-G-WWT-01	0	0.0	
0020 0020	Follow Procedure : PRW-BES-/0000-059-TH	0	0.0	
0020 0030	Use form : FMW-BES-/0000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	107
0030 0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Activity No	Activity Start Date	Activity Start Time	Activity End Date	Activity End Time	Activity Duration (minutes) Travel Time	Activity Duration (minutes) Work Time	Activity Duration (minutes) Total Time	Maintainer ID
0006	4/1/24	17 50	4/1/24	18 20	-	-	30	107,150

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed By	Signature
Start Working Time	4/1/24	17 50	Y	[redacted]	
End Working Time / Malfunction End** / FFO	4/1/24	18 20			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End
when maintenance activities finish, Y = Book on/off required , N = Book on/off not required

6. MAINTENANCE ACTION

Failure Unit Code	Failure Unit Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

- ☐ 1-RestrictedSer.-Major Failure
- ☐ 2 RestrictedSer. Minor Failure
- ☐ 3 RestrictedSer. No failure
- ☐ 4-UnrestrictSer.-Major Failure
- ☐ 5-UnrestrictSer.-Minor Failure
- ☐ 6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (DLP, Normal Warranty)

Checked By Service Leader	Checked By Number / Supervisor	Closed By Station	Checked By FRC
4/1/24	049 25.01.24	049 25.01.24	
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WW

WORK ORDER NO. : 0615b6A	STATION : L-K05	LOCATION : Station
EQUIPMENT NO : WWT-01	SERIAL NO. : --	DATE INSPECTION : 4/1/24

FREQUENCY: ☐ W ☐ 1M ☐ 3M ☐ 6M ☑ 1Y

CHECK: JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☐ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☐ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☐ Normal	☐ Fault	
4	Check the noise of pump and motor while its running	Normal condition	☐ Normal	☐ Fault	
5	Check the distortion of electrical part	Normal operation	☐ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☐ Normal	☐ Fault	
7	Check leakage of all valve and pipe	No leakage	☐ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☐ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☐ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	R .....A S .....A T .....A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N.....V S - N.....V T - N.....V	R - S.....V S - T.....V T - R.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark : No Water Equipment

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.					
2.					

Service By :

	Position	Start Date	End Date
1. [redacted]	Engr	4/1/24	4/1/24
2.			
3. [redacted]	Tech	Start Time	End Time
4.		17.50	18.20
5.			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature :
Checked By : [redacted]	Confirmed By : [redacted]	Approved By :
Date : 4/1/24	Date : 05 JUN 2567	Date : 25 JUL 67

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved
Uncontrolled if printed out or copied

Preventive Maintenance BES Y1

Work Order No.:	96155674
Funct.Location:	BES-SAN-BTC
	Bantuphchang Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1692
MNT. Call No.: 52
MNT. Item No.: 2980
MNT. Task Grp.: BES-SAN GC.: 42
Plan Date: 24.01.2024
Basic Start Date: 31.01.2024
Basic End Date: 31.01.2024

1.WORK ORDER DESCRIPTION : PM@BTC (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0020	PM@BTC (Wast water treatment) (Y1)	3	15.0 MIN	
0020-0010	BTC G-WWT 01	0	0.0	
0020-0030	Follow Progedure : PRW BES 70000 059 TH	0	0.0	
0020-0030	Use form : FMW-BES-70000-036-EN	0	0.0	
0030	Final checking and testing by	0	0.0	150
0030-0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Activity No.	Actual Start Date	Actual Start Time	Actual End Date	Actual End Time	Break Time	Travel Time	Actual Man Hours	Maintenance ID
0020	4/1/24	23:00	4/1/24	23:25	-	-	25	107,150

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Break-in Required (Y/N)	Confirmed by (Name) / Signature
Start Working Time	4/1/24	23:00	[redacted]	[redacted]
End Working Time / Malfunction End** / FFO	4/1/24	23:25		

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

AERA ONE

6. MAINTENANCE ACTION

Failure Code	Failure Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐ 1-RestrictedSer.-Major Failure	☐ 4-UnrestrictSer.-Major Failure
☐ 2-RestrictedSer.-Minor Failure	☐ 5-UnrestrictSer.-Minor Failure
☐ 3-RestrictedSer.-No failure	☐ 6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

☐	Repair
☐	Additional Service (Support)
☐	Warranty (DLP, Normal Warranty)

Checked by Maintainer	Checked by Manager / Supervisor	Closed by Section	Checked by PRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved. Uncontrolled if printed or copied

WORK ORDER NO. : 96158510 | STATION : ATC | LOCATION : Ground

EQUIPMENT NO : B-WWT-01 | SERIAL NO. : - | DATE INSPECTION : 4/1/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☐ 3M ☐ 6M ☑ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☐ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☐ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☐ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☐ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☐ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☐ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☐ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☐ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☐ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 .....A I2 .....A I3 .....A		
11	Measure and record supply voltage	230+10%(190-242V) 400+10%(360-440V)	R - N.....V S - N.....V T - N.....V	R - S.....V S - T.....V T - R.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark : No motor equipment

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1					
2					

Service By :

	Position	Start Date	End Date
1. [redacted]	Eng	4/1/24	4/1/24
2.			
3.	Tech	Start Time	End Time
4		22:00	22:55
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature :	[redacted]
Checked By :	Approved By :	
Date :	Date :	2, No. 07

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.:	96158510
Funct.Location:	BES-SAN-IUM Humark Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1691
MNT. Call No.: 33
MNT. Item No.: 2981
MNT. Task Grp.: BES-SAN GC: 41
Plan Date: 17.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@HUM (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@HUM (Wast water treatment) (M3)	3	15.0 MIN	
0010-0010	HUM-G-WWT-01	0	0.0	
0010-0020	Follow Procedure : PRW BES 70000-059-TH	0	0.0	
0010-0030	Use form : FMW-BES-70000-050-EN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030 0010	WP or TP Required ( ) Yes (/) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start		Activity End		Activity Duration (minute)			Maintainer ID
	Date	Time	Date	Time	Travelling Time	Waiting Time	Working Time	
0010	5/4/24	14:45	5/4/24	15:00	–	–	15	47
		:		:				
		:		:				
		:		:				

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add them up and input into one.

HUM

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	5/4/24	14:45	[redacted]		
End Working Time / Malfunction End** / FFD	5/4/24	15:00			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessarily to be the same as the time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	**Cause Text**
Action Code	**Action Text**

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐	1-RestrictedSer. Major Failure	☐	4-UnrestrictSer.-Major Failure
☐	2-RestrictedSer. Minor Failure	☐	5-UnrestrictSer.-Minor Failure
☐	3-RestrictedSer.-No failure	☐	6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

☐	Repair
☐	Additional Service (Support)
☐	Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WW

WORK ORDER NO. : 9615 6510	STATION : HUM		LOCATION : Ground
EQUIPMENT NO. : TWT -01	SERIAL NO. : –		DATE INSPECTION : 5/4/24
FREQUENCY	☐ W ☐ 1M ☐ 2M ☑ 3M ☐ 6M ☐ 1Y		
CHECK	JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC		

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☐ Normal	☑ Fault	Leak
2	Check the condition of motor	Normal condition	☐ Normal	☑ Fault	Leak
3	Check the connection of pump & motor	Normal condition	☐ Normal	☑ Fault	Leak
4	Check the defect of pump and motor while its running	Normal condition	☐ Normal	☑ Fault	Leak
5	Check the defection of electrical part	Normal operation	☐ Normal	☑ Fault	Leak
6	Check all equipment inside the cabinet control	Normal condition	☐ Normal	☑ Fault	Leak
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☐ Normal	☑ Fault	Leak
9	Check the condition of all connector	Tight and not loose	☐ Normal	☑ Fault	Leak
10	Measure and record running current of motor	Standard	I1 ....A I2 ....A I3 ....A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ....V S - N ....V T - N V	R - S ....V S - T ....V T - R V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault

Recommendations / Remark :

Leak at gland

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.					
2.					

Service By :	Position	Start Date	End Date
1. [redacted]	Tech	5/4/24	5/4/24
2.			
3.	Tech	Start Time	End Time
4.		14:45	15:00
5.			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date : 5/4/24	Date :	Date : 25/4/24

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved
Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.:	96158512
Funct.Location:	BES-SAN-RKH Ramkhamhaeng Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1090
MNT. Call No.: 33
MNT. Item No.: 2980
MNT. Task Grp.: BES-SAN GC: 40
Plan Date: 10.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@RKH (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@RKH (Wast water treatment) (M3)	3	15.0 MIN	
0010 0010	RK11-G-WWT-01	0	0.0	
0010 0020	Follow Procedure : PRW BES-70000-059-TH	0	0.0	
0010 0030	Use form : FMW-BES-70000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	(049)
0030 0010	WP or TP Required ( ) Yes (/) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start Date	Activity Start Time	Activity End Date	Activity End Time	Activity Duration (minute) Travelling Time	Waiting Time	Working Time	Maintainer ID
0010	10/4/24	02:10	10/4/24	02:30	-		20	[redacted]

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	10/4/24	02:10	Y	[redacted]	
End Working Time / Malfunction End** / FFO	10/4/24	02:30			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y = book on/off required , N = book on/off not required

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	**Cause Text**
Action Code	**Action Text**

RKH

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐ 1-RestrictedSer. Major Failure	☐ 4-UnrestrictSer.-Major Failure
☐ 2-RestrictedSer. Minor Failure	☐ 5-UnrestrictSer.-Minor Failure
☐ 3-RestrictedSer.-No failure	☒ 6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

☑ Repair
☐ Additional Service (Support)
☐ Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed or copied

WORK ORDER NO.: 96158512 | STATION: RWH | LOCATION: Ground
EQUIPMENT NO: WWT | SERIAL NO.: - | DATE/INSPECTION: 10/4/24
FREQUENCY: W | 1M | 2M | 3M | 6M | 1Y
CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	✓ Normal	Fault	
2	Check the condition of motor	Normal condition	✓ Normal	Fault	
3	Check the connection of pump & motor	Normal condition	✓ Normal	Fault	
4	Check the defect of pump and motor while it's running	Normal condition	Normal	✓ Fault	
5	Check the defection of electrical part	Normal operation	Normal	✓ Fault	
6	Check all equipment inside the cabinet control	Normal condition	Normal	✓ Fault	
7	Check leakage of all valve and pipe	Not leakage	Normal	✓ Fault	
8	Check the operation of floating valve	Normal condition	Normal	✓ Fault	
9	Check the condition of all connector	Tight and not loose	Normal	✓ Fault	
10	Measure and record running current of motor	Standard	R .....A S .....A S .....A		
11	Measure and record supply voltage	220+10%(196.24V) 380+10%(340.44V)	R - N.....V S - N.....V T - N.....V	R - S.....V S - T.....V T - N.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	Normal	Fault	
13	Check all the anchors	Tight and not loose	Normal	Fault	
14	Check and tighten terminal wiring	Tight and not loose	Normal	Fault	
15	Check and clean magnetic contactor	Normal condition	Normal	Fault	

Recommendations / Remark :
Dry contact & Control Cabinet

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1					
2					

Service By :	Position	Start Date	End Date
1. [redacted]	BES Tech	10/4/24	10/4/24
2.			
3.		Start Time	End Time
4		02.10	02.30
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date : 10/4/24	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.: 96158557
Funct.Location: BES-SAN-RPR
Ratchaprarop Station
Equipment: N/A
Location: N/A
Mileage/Operation (hr):

MNT. Plan No.: 1689
MNT. Call No.: 33
MNT. Item No.: 2079
MNT. Task Grp.: BES-SAN GC.: 39
Plan Date: 03.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@RPR (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@RPR (Wast water treatment) (M3)	3	150 MIN	
0010 0010	RPR-G-WWT-01	0	0.0	
0010-0020	Follow Procedure : PRW BES 70000-059-TH	0	0.0	
0010 0030	Use form : FMW-BES-70000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030-0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WWW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start Date	Activity Start Time	Activity End Date	Activity End Time	Activity Duration (minute) Travelling Time	Waiting Time	Working Time	Maintainer ID
0010	7/4/24	10:15	7/4/24	10:30	-	-	15	140

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by	Signature
Start Working Time	7/4/24	10:15	Y	[redacted]	
End Working Time / Malfunction End** / PFO	7/4/24	10:30			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same with time when maintenance activities finish. Y – Book on/off required , N – Book on/off not required

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	**Cause Text**
Action Code	**Action Text**

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

- ☐ 1-RestrictedSer.-Major Failure
- ☐ 2-RestrictedSer.-Minor Failure
- ☐ 3 RestrictedSer.-No failure
- ☐ 4-UnrestrictedSer.-Major Failure
- ☐ 5-UnrestrictedSer.-Minor Failure
- ☐ 6 UnrestrictedSer.-No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WWW

WORK ORDER NO. : 0100557	STATION : KPR	LOCATION : Concourse
EQUIPMENT NO : WWT - 01	SERIAL NO. : -	DATE INSPECTION : 7/4/24

FREQUENCY	W	1M	2M	3M	6M	1Y
CHECK	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet (only)	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 .....A I2 .....A I3 .....A		
11	Measure and record supply voltage	220+10%(198.22V) 400+10%(380.44V)	R - N.....V S - N.....V T - N.....V	R - S.....V S - T.....V T - R.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1					
2					

Service By :		Position	Start Date	End Date
1.	[redacted]	Tech	7/4/24	7/4/24
2.		Tech	Start Time	End Time
3.			10.15	10.30
4.				
5.				

	Technician	Senior Technician / Engineer	Senior Engineer
Signature :	[redacted]	[redacted]	[redacted]
Checked By :			
Date :			

Copyright © Wah & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.:	96158613
Funct.Location:	BES-SAN-PTH
	Phaya Thai Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1688
MNT. Call No.: 33
MNT. Item No.: 2978
MNT. Task Grp.: BES-SAN GC.: 38
Plan Date: 03.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@PTH (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@PTH (Wast water treatment) (M3)	3	15.0 MIN	
0010 0010	PTH-G-WWT-01	0	0.0	
0010-0020	Follow Procedure : PRW-BES-70000 059 TH	0	0.0	
0010 0030	Use form : FMW BES 70000-056-EN	0	0.0	
0030	Final checking and testing by	0	0.0	
0030-0010	WI or IP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS WKW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start Date	Activity Start Time	Activity End Date	Activity End Time	Activity Duration (minute) Travelling Time	Waiting Time	Working Time	Maintainer ID
0010	3/4/24	21 : 00	3/4/24	21 : 30	-	-	30	47

* Maintenance time must be recorded at actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Employee (Name)	Signature
Start Working Time	3/4/24	21 : 00	Y	[redacted]	
End Working Time / Malfunction End** / FFO	3/4/24	21 : 30			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	**Cause Text**
Action Code	**Action Text**

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐	1-RestrictedSer.-Major Failure	☐	4 UnrestrictSer.-Major Failure
☐	2-RestrictedSer.-Minor Failure	☐	5 UnrestrictSer.-Minor Failure
☐	3 RestrictedSer.-No failure	☐	6 UnrestrictSer. No Failure

9. SERVICE OR WARRANTY

☐	Repair
☐	Additional Service (Support)
☐	Warranty (O.E.P. Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

WORK ORDER NO.: 96158615 | STATION: PTH | LOCATION: G-WWT-01

EQUIPMENT NO.: Waste Water Treatment | SERIAL NO.: - | DATE INSPECTION: 8/4/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☑ 3M ☐ 6M ☐ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while its running	Normal condition	☑ Normal	☐ Fault	
5	Check the detection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of air compressor	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	R = A		
			S = A		
			T = A		
11	Measure and record supply voltage	230+10%(198-242V) 400+10%(360-440V)	R - N = V	R - S = V	
			S - N = V	S - T = V	
			T - N = V	T - R = V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark:

Consumables / Spare Part Used:

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.					
2.					

Service		Position	Start Date	End Date
1.	[redacted]	Tech	8/4/24	8/4/24
2.				
3.		Tech	Start Time	End Time
4.			21:00	21:30
5.				

Technician	Senior Technician / Engineer	Senior Engineer
Signature: [redacted]	Signature: [redacted]	Signature: [redacted]
Checked By:	Confirmed By:	Approved By:
Date:	Date:	Date: 7/8

Form: Airport Rail Link Project

Check Sheet PM_Sanitary Plumbing System Waste Water Treatment | Effective Date: 25 FEB 2022

Document Code: PMW-ut S-70000-0584 N-A | Page 3 of 3

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.: 96158614
Funct.Location: BES-SAN-MAS
Makkasan Station
Equipment: N/A
Location: N/A

Mileage/Operation (hr):

MNT. Plan No.: 1686
MNT. Call No.: 33
MNT. Item No.: 2976
MNT. Task Grp.: BES-SAN GC.: 36
Plan Date: 03.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@MAS (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@MAS (Wast water treatment) (M3)	1	30.0 MIN	
0010-0010	MAS-G-WWT-01	0	0.0	
0010-0020	MAS-G-WWT-03	0	0.0	
0010-0030	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0010-0040	Use form : PMW BES 70000 056 EN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030-0010	WI or TI Required ( ) Yes (/) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removal unit.

SIEMENS

WWW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start		Activity End		Activity Duration (minute)			Maintainer ID
	Date	Time	Date	Time	Traveling Time	Waiting Time	Working Time	
0010	8/4/24	14:02	8/4/24	16:02	—	—	120	[redacted]

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	8/4/24	14:02	Y	[redacted]	
End Working Time / Malfunction End** / FFO	8/4/24	16:02			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

- ☐ 1-RestrictedSer.-Major Failure
- ☐ 2-RestrictedSer.-Minor Failure
- ☐ 3-RestrictedSer. No failure
- ☐ 4-UnrestrictSer.-Major Failure
- ☐ 5-UnrestrictSer.-Minor Failure
- ☐ 6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WWW

WORK ORDER NO. : 9413814	STATION : CP PS	LOCATION : Ground	
EQUIPMENT NO : Return 1	SERIAL NO. : —	DATE INSPECTION : 8/4/24	

FREQUENCY: ☐ W | ☐ 1M | ☐ 3M | ☑ 3M | ☐ 6M | ☐ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while are running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 3.36 A I2 3.36 A I3 3.43 A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N 234 V R - S 410 V S - N 238 V S - T 410 V T - N 238 V T - R 416 V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	AC clamp meter	Fluke 323	A33831Cm	31/12/24	
2.					

Service By :

	Position	Start Date	End Date
1. [redacted]	Tech	8/4/24	8/4/24
2.	Tech		
3.		Start Time	End Time
4.		14:02	16:02
5.			

Technician	Senior Technician / Engineer	
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO. : CM153614 | STATION : CM03 | LOCATION : Ground
EQUIPMENT NO : Return 2 | SERIAL NO. : | DATE INSPECTION : 8/4/24

FREQUENCY: W | 1M | 2M | 3M | 6M | 1Y
CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	Normal	Fault	
2	Check the condition of motor	Normal condition	Normal	Fault	
3	Check the connection of pump & motor	Normal condition	Normal	Fault	
4	Check the defect of pump and motor while it's running	Normal condition	Normal	Fault	
5	Check the defection of electrical part	Normal operation	Normal	Fault	
6	Check all equipment inside the cabinet control	Normal condition	Normal	Fault	
7	Check leakage of all valve and pipe	Not leakage	Normal	Fault	
8	Check the operation of floating valve	Normal condition	Normal	Fault	
9	Check the condition of all connector	Tight and not loose	Normal	Fault	
10	Measure and record running current of motor	Standard	R ...3.66...A S ...3.66...A T ...3.65...A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ...414...V S - N ...414...V T - N ...414...V R - S ...414...V S - T ...414...V T - R ...414...V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

NO.	Description	Standard	Result		Remark
12	Check the vibration of equipment	Standard	Normal	Fault	
13	Check all the anchors	Tight and not loose	Normal	Fault	
14	Check and tighten terminal wiring	Tight and not loose	Normal	Fault	
15	Check and clean magnetic contactor	Normal condition	Normal	Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	AC clamp meter	Fluke 325	45950/2004	9/12/24	
2					

Service By :	Position	Start Date	End Date
1. [redacted]	Tech	8/4/24	8/4/24
2.	Tech		
3		Start Time	End Time
4		14:02	16:02
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By	Confirmed By	Approved By :
Date :	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO. : CM153614 | STATION : CM03 | LOCATION : Ground
EQUIPMENT NO : Air blower 1 | SERIAL NO. : | DATE INSPECTION : 8/4/24

FREQUENCY: W | 1M | 2M | 3M | 6M | 1Y
CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	Normal	Fault	
2	Check the condition of motor	Normal condition	Normal	Fault	
3	Check the connection of pump & motor	Normal condition	Normal	Fault	
4	Check the defect of pump and motor while it's running	Normal condition	Normal	Fault	
5	Check the defection of electrical part	Normal operation	Normal	Fault	
6	Check all equipment inside the cabinet control	Normal condition	Normal	Fault	
7	Check leakage of all valve and pipe	Not leakage	Normal	Fault	
8	Check the operation of floating valve	Normal condition	Normal	Fault	
9	Check the condition of all connector	Tight and not loose	Normal	Fault	
10	Measure and record running current of motor	Standard	R ...5.38...A S ...5.41...A T ...5.21...A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ...390...V S - N ...393...V T - N ...396...V R - S ...414...V S - T ...418...V T - R ...415...V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

NO.	Description	Standard	Result		Remark
12	Check the vibration of equipment	Standard	Normal	Fault	
13	Check all the anchors	Tight and not loose	Normal	Fault	
14	Check and tighten terminal wiring	Tight and not loose	Normal	Fault	
15	Check and clean magnetic contactor	Normal condition	Normal	Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	AC clamp meter	Fluke 325	45950/2004	9/12/24	
2					

Service By :	Position	Start Date	End Date
1. [redacted]	Tech	8/4/24	8/4/24
2.	Tech		
3		Start Time	End Time
4		14:02	16:02
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By	Confirmed By	Approved By :
Date :	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved
Uncontrolled if printed out or copied

WORK ORDER NO. : 96158614	STATION : CCGA	LOCATION : Ground
EQUIPMENT NO : Air blower	SERIAL NO. :	DATE INSPECTION : 8/4/24

FREQUENCY	W	1M	2M	3M	6M	1Y
CHECK	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	✓ Normal	Fault	
2	Check the condition of motor	Normal condition	✓ Normal	Fault	
3	Check the connection of pump & motor	Normal condition	✓ Normal	Fault	
4	Check the defect of pump and motor while it's running	Normal condition	✓ Normal	Fault	
5	Check the defection of electrical part	Normal operation	✓ Normal	Fault	
6	Check all equipment inside the cabinet control	Normal condition	✓ Normal	Fault	
7	Check leakage of all valve and pipe	Not leakage	✓ Normal	Fault	
8	Check the operation of floating valve	Normal condition	✓ Normal	Fault	
9	Check the condition of all connector	Tight and not loose	✓ Normal	Fault	
10	Measure and record running current of motor	Standard	R ...3.83...A S ...3.15...A T ...3.34...A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ...228...V S - N ...219...V T - N ...228...V	R - S ...410...V S - T ...410...V T - R ...414...V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

NO.	Description	Standard	Result		Remark
12	Check the vibration of equipment	Standard	Normal	Fault	
13	Check all the anchors	Tight and not loose	Normal	Fault	
14	Check and tighten terminal wiring	Tight and not loose	Normal	Fault	
15	Check and clean magnetic contactor	Normal condition	Normal	Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	AC Clamp meter	Fluke 325	45820340cw	7/10/24	
2					

Service By	Position	Start Date	End Date
1. [redacted]	Tech	8/4/24	8/4/24
2.	Tech		
3.		Start Time	End Time
4		10:00	16:00
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.:	96158648
Func.Location:	BES-SAN-DPK Depot Kinnaton
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1687
MNT. Call No.: 33
MNT. Item No.: 2077
MNT. Task Grp.: BES-SAN GC.: 37
Plan Date: 10.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@DPK (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@DPK (Wast water treatment) (M3)	4	30.0 MIN	
0010-0010	DPK-G-WWT-01	0	0.0	
0010-0020	DPK-G-WWT-02	0	0.0	
0010-0030	DPK-G-WWT-03	0	0.0	
0010-0040	DPK-G-WWT-04	0	0.0	
0010-0050	Follow Procedure : FMW-BES-70000-059-TH	0	0.0	
0010-0060	Use form : FMW BES 70000 056 EN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030-0010	WI or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS WSW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start		Activity End		Activity Duration (minute)			Maintainer ID
	Date	Time	Date	Time	Travelling Time	Waiting Time	Working Time	
0010	20/4/24	09:50	20/4/24	11:50	-	-	120	AA.

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	20/4/24	09:50	N	[redacted]	
End Working Time / Malfunction End** / FTO	20/4/24	11:50			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	**Cause Text**
Action Code	**Action Text**

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

- ☐ 1-RestrictedSer. Major Failure
- ☐ 2-RestrictedSer.-Minor Failure
- ☐ 3-RestrictedSer.-No failure
- ☐ 4-UnrestrictSer.-Major Failure
- ☐ 5-UnrestrictSer.-Minor Failure
- ☐ 6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

- ☐ Repair
- ☐ Additional Service (Support)
- ☐ Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WSW

WORK ORDER NO.: 41536[redacted]	STATION: DPK	LOCATION: [redacted]	
EQUIPMENT NO: WWT-EB-01	SERIAL NO.: -	DATE INSPECTION: 20/04/24	

FREQUENCY	W	1M	2M	3M	5M	1Y
CHECK	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	Normal	Fault	
2	Check the condition of motor	Normal condition	Normal	Fault	
3	Check the connection of pump & motor	Normal condition	Normal	Fault	
4	Check the defect of pump and motor while it's running	Normal condition	Normal	Fault	
5	Check the defection of electrical part	Normal operation	Normal	Fault	
6	Check all equipment inside the cabinet control	Normal condition	Normal	Fault	
7	Check leakage of all valve and pipe	Not leakage	Normal	Fault	
8	Check the operation of floating valve	Normal condition	Normal	Fault	
9	Check the condition of all connector	Tight and not loose	Normal	Fault	
10	Measure and record running current of motor	Standard	I1 8.4A I2 8.3A I3 8.4A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R-N 237V R-S 407V S-N 237V S-T 407V T-N 237V T-R 407V		

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	Normal	Fault	
13	Check all the anchors	Tight and not loose	Normal	Fault	
14	Check and tighten terminal wiring	Tight and not loose	Normal	Fault	
15	Check and clean magnetic contactor	Normal condition	Normal	Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	[redacted]	8905	AB8A0818	06/8/24	--

	Position	Start Date	End Date
[redacted]	Bot M	20/04/24	20/04/24
	Top M	Start Time	End Time
		09:50	11:50

Technician	Senior Technician / Engineer	
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date :

Copyright © Wah & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

WORK ORDER NO. : 9615848 | STATION : DPK | LOCATION : [redacted]
EQUIPMENT NO : WWT-BP-01 | SERIAL NO. : — | DATE INSPECTION : 30/4/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☑ 3M ☐ 6M ☐ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 0.34 A I2 0.36 A I3 0.34 A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N 234 V S - N 233 V T - N 234 V	R - S 404 V S - T 404 V T - R 404 V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	HC Clamp Meter	3287	170805454	26/5/24	—
2.					

Service By :

	Position	Start Date	End Date
[redacted]	Tech.	30/4/24	30/4/24
	Tech.	Start Time	End Time
		09:30	11:30

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

WORK ORDER NO. : 9615848 | STATION : DPK | LOCATION : [redacted]
EQUIPMENT NO : WWT-BP-02 | SERIAL NO. : — | DATE INSPECTION : 30/4/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☑ 3M ☐ 6M ☐ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 0.34 A I2 0.36 A I3 0.35 A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N 231 V S - N 230 V T - N 230 V	R - S 399 V S - T 399 V T - R 401 V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.	HC Clamp Meter	3287	170805454	26/5/24	—
2.					

Service By :

	Position	Start Date	End Date
[redacted]	Tech.	30/4/24	30/4/24
	Tech.	Start Time	End Time
		09:30	11:30

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date :

Form: Check Sheet PM_Sanitary Plumbing System_Waste Water Treatment | Airport Rail Link Project
Effective Date: 26 FEB 2022
Document Code : MW-IR-S-70000-0581-N-A | Page 3 of 3
Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

WORK ORDER NO.: 96158148	STATION: DPK	LOCATION: [redacted]
EQUIPMENT NO.: WWT-RP-02	SERIAL NO.: -	DATE INSPECTION: 30/4/24

FREQUENCY: ☐ W ☐ 1M ☐ 2M ☑ 3M ☐ 6M ☐ 1Y

CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of air valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connection	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 0.40 A I2 0.41 A I3 0.345 A		
11	Measure and record supply voltage	220+10%(198 ≤≤V) 380+10%(360 ≤≤V)	R - N. 227 V S - N. 228 V T - N. 225 V	R - S. 392 V S - T. 400 V T - R. 394 V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark :

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1	AC Clamp Meter	305E	A1340080JD	06/8/24	-

Supplier	Position	Start Date	End Date
[redacted]	Tech	30/4/2024	30/4/2024
	Tech	Start Time 09:30	End Time 11:00

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature [redacted]
Checked By	Confirmed By	Approved
Date :	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.:	**96158802**
Funct.Location:	**BES-SAN-TSS**
	Traction Sub Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1694
MNT. Call No.: 41
MNT. Item No.: 2984
MNT. Task Grp.: BES-SAN GC: 44
Plan Date: 17.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@TSS (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@TSS (Wast water treatment) (M3)	3	15.0 MIN	
0010-0010	TSS G WWT 01	0	0.0	
0010-0020	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0010-0030	Use form : FMW-BES-70000-056 EN	0	0.0	
0030	Final checking and testing by	0	0.0	
0030-0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WSW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start		Activity End		Activity Duration (minute)			Maintainer ID
	Date	Time	Date	Time	Travelling Time	Waiting Time	Working Time	
0010	2/4/24	9:30	2/4/24	9:59	-	-	29	47

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off recorded (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	2/4/24	9:30	[redacted]		
End Working Time / Malfunction End** / FFD	2/4/24	9:59			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be the same as the time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	**Cause Text**
Action Code	**Action Text**

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐	1 RestrictedSer.-Major Failure	☐	4 UnrestrictSer.-Major Failure
☐	2 RestrictedSer.-Minor Failure	☐	5 UnrestrictSer.-Minor Failure
☐	3 RestrictedSer. No failure	☐	6 UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

☐	Repair
☐	Additional Service (Support)
☐	Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved. Uncontrolled if printed out or copied

WSW

WORK ORDER NO. : 9650207 | STATION : TSS | LOCATION : Ground
EQUIPMENT NO : [redacted] | SERIAL NO. : - | DATE INSPECTION : 2/4/24
FREQUENCY: ☐ W ☐ 1M ☐ 2M ☑ 3M ☐ 6M ☐ 1Y
CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☐ Normal	☑ Fault	
2	Check the condition of motor	Normal condition	☐ Normal	☑ Fault	
3	Check the connection of pump & motor	Normal condition	☐ Normal	☑ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☐ Normal	☑ Fault	
5	Check the defection of electrical part	Normal operation	☐ Normal	☑ Fault	
6	Check all equipment inside the cubinet control	Normal condition	☐ Normal	☑ Fault	
7	Check leakage of all valve and pipe	Not leakage	☐ Normal	☑ Fault	
8	Check the operation of floating valve	Normal condition	☐ Normal	☑ Fault	
9	Check the condition of all connector	Tight and not loose	☐ Normal	☑ Fault	
10	Measure and record running current of motor	Standard	I1 = A I2 = A I3 = A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N = V S - N = V T - N = V	R - S = V S - T = V T - R = V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark : NO

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1.					
2.					

Service By	Position	Start Date	End Date
1. [redacted]	Tech	2/4/24	2/4/24
2.		Start Time	End Time
3.		9:30	9:59
4.			
5.			

	Senior Technician / Engineer	
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved Uncontrolled if printed out or copied

Preventive Maintenance BES M3

Work Order No.:	96158805
Funct.Location:	BES-SAN-LKB
	Lakrabang Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1693
MNT. Call No.: 33
MNT. Item No.: 2083
MNT. Task Grp.: BES-SAN GC: 43
Plan Date: 24.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@LKB (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@LKB (Wast water treatment) (M3)	3	15.0 MIN	
0010-0010	LKB G WWT 01	0	0.0	
0010-0020	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0010-0030	Use form : TMW BES 70000 056 EN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030-0010	WP or TP Required ( ) Yes (/) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WMW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start Date	Activity Start Time	Activity End Date	Activity End Time	Activity Duration (minute) Traveling Time	Waiting Time	Working Time	Maintainer ID
0010	11/4/24	13 :00	11/4/24	13 :15	–	–	15	108
		:		:				
		:		:				
		:		:				

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	11/4/24	13 :00	Y	[redacted]	
End Working Time / Malfunction End** / FFO	11/4/24	13 :15			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is not necessary to be recorded as the time when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

SRTE

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	Cause Text
Action Code	Action Text

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐ 1-RestrictedSer.-Major Failure	☐ 4-UnrestrictSer. Major Failure
☐ 2-RestrictedSer.-Minor Failure	☐ 5-UnrestrictSer. Minor Failure
☐ 3-RestrictedSer. No failure	☐ 6-UnrestrictSer.-No Failure

9. SERVICE OR WARRANTY

☐ Repair
☐ Additional Service (Support)
☐ Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by PRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved.
Uncontrolled if printed out or saved

WORK ORDER NO.: 9158405 | STATION: LKB | LOCATION: Ground.
EQUIPMENT NO: WWT-01 | SERIAL NO.: - | DATE INSPECTION: 11/4/24
FREQUENCY: ☐ W ☐ 1M ☐ 2M ☑ 3M ☐ 6M ☐ 1Y
CHECK: JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result		Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal	☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal	☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal	☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal	☐ Fault	
5	Check the defection of electrical part	Normal operation	☑ Normal	☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal	☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal	☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal	☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal	☐ Fault	
10	Measure and record running current of motor	Standard	I1 ....=.....A I2 ....=.....A I3 ....=.....A		
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N.....=.....V S - N.....=.....V T - N.....=.....V	R - S.....=.....V S - T.....=.....V T - R.....=.....V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☐ Normal	☐ Fault	
13	Check all the anchors	Tight and not loose	☐ Normal	☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☐ Normal	☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☐ Normal	☐ Fault	

Recommendations / Remark :

Satisfactory

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1					
2					

Service By	Position	Start Date	End Date
1. [redacted]	Tech	11/4/24	11/4/24
2.			
3	Tech	Start Time 13:00	End Time 13:15
4			
5			

Technician	Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :	Approved By :
Date :	Date :	Date :

Copyright © Wee & Wireless Co., Ltd. 2022 All Rights Reserved.
Uncontrolled if printed not to copied

Preventive Maintenance BES M3

Work Order No.:	96159100
Funct.Location:	BES-SAN-BTC
	Bantha phalang Station
Equipment:	N/A
Location:	N/A
Mileage/Operation (hr):	

MNT. Plan No.: 1692
MNT. Call No.: 33
MNT. Item No.: 2982
MNT. Task Grp.: BES SAN GC.: 42
Plan Date: 24.04.2024
Basic Start Date: 01.04.2024
Basic End Date: 30.04.2024

1.WORK ORDER DESCRIPTION : PM@BTC (Wast water treatment)

2.MAINTENANCE TASKS

Activity No.	Activity Description	Man	Duration	Object List
0010	PM@BTC (Wast water treatment) (M3)	3	15.0 MIN	
0010-0010	BTC C WWT 01	0	0.0	
0010-0020	Follow Procedure : PRW-BES-70000-059-TH	0	0.0	
0010-0030	Use form : FMW-BES 70000 056 EN	0	0.0	
0030	Final checking and testing by	0	0.0	049
0030-0010	WP or TP Required ( ) Yes (✓) No	0	0.0	

3.EXCHANGE EQUIPMENT / REPLACEABLE UNITS

SAP Mat. No.	SAP Material Description	Qty.	Equipment No. of installed unit	Equipment No. of removed unit.

SIEMENS

WWW

4. MAINTENANCE TIME RECORDING* (For more activities, please continue page 4)

Operation No.	Activity Start		Activity End		Activity Duration (in hours)			Maintainer ID
	Date	Time	Date	Time	Travelling Time	Waiting Time	Working Time	
0010	5/4/24	19:00	5/4/24	19:30	-	-	30	197

* Maintenance time must be recorded as actual time of an activity is carried out. For example, if there are two activities which are the same activity type but be intervened by the other activity type, two activities must be recorded individually. Do not add these two durations into one.

5. MALFUNCTION END CONFIRMATION (CORRECTIVE MAINTENANCE)

	Date	Time	Book on/off required (Y/N)	Confirmed by Landlord (Name)	Signature
Start Working Time	5/4/24	19.00	Y	[redacted]	
End Working Time / Malfunction End** / FFD	5/4/24	19:30			

**Malfunction End is whether time when the failure is cleared or disappear itself. Malfunction End time is the moment in the equipment log when maintenance activities finish. Y = Book on/off required , N = Book on/off not required

AERA ONE

6. MAINTENANCE ACTION

Failure mnt. Code	Failure mnt. Text
Cause Code	**Cause Text**
Action Code	**Action Text**

7. REMARK (ADDITIONAL INFORMATION)

8. EFFECT ON OPERATION

☐	1-RestrictedSer.-Major Failure	☐	4 UnrestrictSer.-Major Failure
☐	2-RestrictedSer.-Minor Failure	☐	5 UnrestrictSer.-Minor Failure
☐	3 RestrictedSer.-No failure	☐	6-UnrestrictSer. No Failure

9. SERVICE OR WARRANTY

☐	Repair
☐	Additional Service (Support)
☐	Warranty (DLP, Normal Warranty)

Checked by Shift Leader	Checked by Manager / Supervisor	Closed by Section	Checked by FRC
[redacted]			
Signature / Date	Signature / Date	Signature / Date	Signature / Date

Copyright © Siemens Mobility Ltd. 2022 All Rights Reserved

Uncontrolled if printed out or copied

WWW

WORK ORDER NO.: 96159100	STATION: BTC		LOCATION: Ground
EQUIPMENT NO: WWT – 01	SERIAL NO.:		DATE INSPECTION: 5/4/24
FREQUENCY	W	1M	2M ☑ 3M ☐ 6M ☐ 1Y
CHECK	JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC		

DESCRIPTION OF MAINTENANCE EVERY 3 MONTH

NO.	Description	Standard	Result	Remark
1	Check the shaft cover of pump	Normal condition	☑ Normal ☐ Fault	
2	Check the condition of motor	Normal condition	☑ Normal ☐ Fault	
3	Check the connection of pump & motor	Normal condition	☑ Normal ☐ Fault	
4	Check the defect of pump and motor while it's running	Normal condition	☑ Normal ☐ Fault	
5	Check the defection of electrical part	Normal operation	☐ Normal ☐ Fault	
6	Check all equipment inside the cabinet control	Normal condition	☑ Normal ☐ Fault	
7	Check leakage of all valve and pipe	Not leakage	☑ Normal ☐ Fault	
8	Check the operation of floating valve	Normal condition	☑ Normal ☐ Fault	
9	Check the condition of all connector	Tight and not loose	☑ Normal ☐ Fault	
10	Measure and record running current of motor	Standard	R ....A S ....A T ....A	
11	Measure and record supply voltage	220+10%(198-242V) 400+10%(360-440V)	R - N ....V R - S ....V S - N ....V S - T ....V T - N ....V T - R V	

DESCRIPTION OF MAINTENANCE EVERY 1 YEAR

12	Check the vibration of equipment	Standard	☑ Normal ☐ Fault	
13	Check all the anchors	Tight and not loose	☑ Normal ☐ Fault	
14	Check and tighten terminal wiring	Tight and not loose	☑ Normal ☐ Fault	
15	Check and clean magnetic contactor	Normal condition	☑ Normal ☐ Fault	

Recommendations / Remark : Lubricant

Consumables / Spare Part Used :

Measuring Instrument

Item	Instrument Name	Model No.	Serial No.	Expire Date	Remark
1					
2					

Service By

	Position	Start Date	End Date
1. [redacted]	Tech	5/4/24	5/4/24
2.	Tech		
3		Start Time	End Time
4		19:00	19:30
5			

Senior Technician / Engineer	Senior Engineer
Signature : [redacted]	Signature : [redacted]
Checked By :	Confirmed By :
Date : 5/	Date :

Copyright © Wire & Wireless Co., Ltd. 2022 All Rights Reserved.

Uncontrolled if printed out or copied