

ผลวิเคราะห์คุณภาพน้ำทั้งโครงการ KANTARY BAY RAYONG อาคาร 1



United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsak 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Tel. 0 2763 2828 Fax 0 2763 2800 www.uaiconsultant.com E-mail: uae@uaiconsultant.com




TESTING
No. 0063

ANALYSIS REPORT

CUSTOMER NAME : KASEMKIJ COMPANY LIMITED (KANTARY BAY HOTEL RAYONG)
ADDRESS : 50, 50/2 RIEPJAIFANG ROAD PAK NAM MUEANG RAYONG RAYONG 21000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT OF KANTARY BAY, RAYONG
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : JANUARY 20, 2021
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS AMONRAT PUTTALEE

RECEIVED DATE : JANUARY 21, 2021
ANALYTICAL DATE : JANUARY 21-27, 2021
REPORT NO. : 2021-U08539
WORK NO. : 2020-009024
ANALYSIS NO. : T21AA958-0001 - T21AA958-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21AA958-0001	2 T21AA958-0002		
pH ^a	-	ELECTROMETRIC METHOD (SM: 4500-H ⁺ B)	7.2 (25°C)	7.0 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND ^c	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	1,968	10.6	≤ 30	2.0
SUSPENDED SOLIDS ^a	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	1,558	ND	≤ 40	5.0
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD UAE TP.TN.02 (KJELDAHL METHOD); SM: 4500-Norg C	38.4	14.8	≤ 35	1.5
FAT, OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	95	ND	≤ 20	3



- DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL .
- REPORTED ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY.



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21AA958-0001	2 T21AA958-0002		
MICROBIOLOGY						
FAECAL COLIFORM BACTERIA A ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM 9221 E)	>150,000	< 18	-	18
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID	YELLOW/CLEAR		
SEDIMENT			BROWN	YELLOW		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

RESULT 1 : INFLUENT (RYG 1)

RESULT 2 : EFFLUENT (RYG 1)

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL. 122,
PART 125 D, DATED DECEMBER 29, 2005.

^a : PARAMETER ANALYSED OF THE EFFLUENT IS SAMPLING BY CUSTOMER ON FEBRUARY 4, 2021 ANALYSIS NO. T21AB792-0001
(ANALYTICAL DATE : FEBRUARY 5-10, 2021)

ND : NON-DETECTABLE

SUBSTITUTED REPORT FOR REPORT NO. 2021-U05211, DATED FEBRUARY 2, 2020.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

FEBRUARY 16, 2021

ANALYSIS REPORT

CUSTOMER NAME : KASEMKIJ COMPANY LIMITED (KANTARY BAY HOTEL RAYONG)
ADDRESS : 50, 50/2 RIEPJAIFANG ROAD PAK NAM MUEANG RAYONG RAYONG 21000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT OF KANTARY BAY, RAYONG
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : FEBRUARY 3, 2021
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS AMONRAT PUTTALEE

RECEIVED DATE : FEBRUARY 4, 2021
ANALYTICAL DATE : FEBRUARY 4-10, 2021
REPORT NO. : 2021-U08802
WORK NO. : 2021-000633
ANALYSIS NO. : T21AB726-0001 - T21AB726-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21AB726-0001	2 T21AB726-0002		
pH ^a	-	ELECTROMETRIC METHOD (SM 4500-H ⁺ B)	9.0 (25°C)	7.1 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND ^b	mg/L	AZIDE MODIFICATION METHOD (SM 4500-O C AND 5210 B)	202	7.9	≤ 30	2.0
SUSPENDED SOLIDS ^a	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM 2540 D)	203	9.1	≤ 40	5.0
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD UAE.TP.TN.02 (KJELDAHL METHOD); SM 4500-Norg C	30.0	16.8	≤ 35	1.5
FAT, OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM 5620 B)	36	ND	≤ 20	3
MICROBIOLOGY						
FAECAL COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM 9221 E)	>150,000	< 1.8	-	1.8
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID	YELLOW/CLEAR		
SEDIMENT			BROWN	BROWN		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

RESULT 1 : INFLUENT (RYG 1)

RESULT 2 : EFFLUENT (RYG 1)

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL. 122, PART 125 D, DATED DECEMBER 29, 2005.

ND : NON-DETECTABLE.



(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

FEBRUARY 16, 2021



ANALYSIS REPORT

CUSTOMER NAME : KASEMKI COMPANY LIMITED (KANTARY BAY HOTEL RAYONG)
ADDRESS : 50, 50/2 RUEPJAIFANG ROAD PAK NAM MUEANG RAYONG RAYONG 21000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemki.com
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT OF KANTARY BAY, RAYONG
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : MARCH 30, 2021
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS AMONRAT PUTTALEE

RECEIVED DATE : MARCH 30, 2021
ANALYTICAL DATE : MARCH 30 - APRIL 5, 2021
REPORT NO. : 2021-UJ2102
WORK NO. : 2021-001477
ANALYSIS NO. : T21AF356-0001 - T21AF356-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21AF356-0001	2 T21AF356-0002		
pH ^c	-	ELECTROMETRIC METHOD (SM: 4500-H ⁺ B)	8.0 (25°C)	6.8 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	140	14.6	≤ 30	2.0
SUSPENDED SOLIDS ^a	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	217	7.4	≤ 40	5.0
TOTAL KJELDAHL NITROGEN ^a	mg/L	IN-HOUSE METHOD UAE.TP.TN.02 (KJELDAHL METHOD); SM: 4500-Norg C	27.1	6.6	≤ 35	1.5
FAT, OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	10	ND	≤ 20	3
MICROBIOLOGY						
FAECAL COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 E)	>160,000	790	-	1.8
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID	YELLOW/CLEAR		
SEDIMENT			BROWN	YELLOW		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23RD EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23RD EDITION, 2017.

RESULT 1 : INFLUENT (RYG 1)

RESULT 2 : EFFLUENT (RYG 1)


REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL. 122, PART 125 D, DATED DECEMBER 29, 2005.

ND : NON-DETECTABLE.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
 LABORATORY SUPERVISOR

APRIL 9, 2021



• DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL .
 • REPORTED ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY.

1/1





United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsak 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Tel. 0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com



NSC-TISI-TIS 17025
TESTING 0207



TESTING
No. 0063

ANALYSIS REPORT

CUSTOMER NAME : KASEMKIJ COMPANY LIMITED (KANTARY BAY HOTEL RAYONG)
ADDRESS : 50, 50/2 RIEPJAIFANG ROAD PAK NAM MUEANG RAYONG RAYONG 21000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT OF KANTARY BAY, RAYONG
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : APRIL 21, 2021
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS AMONRAT PUTTALEE

RECEIVED DATE : APRIL 22, 2021
ANALYTICAL DATE : APRIL 22-29, 2021
REPORT NO. : 2021-027268
WORK NO. : 2021-002374
ANALYSIS NO. : T21AG693-0003 - T21AG693-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21AG693-0003	2 T21AG693-0004		
pH ^c	-	ELECTROMETRIC METHOD (SM: 4500-H ⁺ B)	8.4 (25°C)	7.0 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND ^c	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	945	9.4	≤ 30	2.0
SUSPENDED SOLIDS ^a	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	487	12.1	≤ 40	5.0
TOTAL KJELDAHL NITROGEN ^c	mg/L	IN-HOUSE METHOD: UAE.TP.TN.02 (KJELDAHL METHOD); SM: 4500-Norg C	31.1	10.0	≤ 35	1.5
FAT, OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5620 B)	93	ND	≤ 20	3
MICROBIOLOGY						
FAECAL COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 E)	>150,000	< 1.8	-	1.8
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID	YELLOW/TURBID		
SEDIMENT			YELLOW	YELLOW		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23RD EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23RD EDITION, 2017.

RESULT 1 : INFLUENT (RYG 1)

RESULT 2 : EFFLUENT (RYG 1)


REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL. 122, PART 125 D, DATED DECEMBER 29, 2005.

ND : NON-DETECTABLE

Benjawan V.

(MISS BENJAWAN VIRIYOTHAI)
LABORATORY SUPERVISOR

MAY 7, 2021



- DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL .
- REPORTED ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY.

1/1





United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsuk 41, Sukhumvit Road, Bangkok, Phrakhanong, Bangkok 10260

Tel. 0 2763 2828 Fax 0 2763 2600 www.uaeconsultant.com E-mail: uae@uaeconsultant.com



NSC-TIS-TIS 17625
TESTING 0287




TESTING
No. 0063

ANALYSIS REPORT

CUSTOMER NAME : KASEMKI COMPANY LIMITED (KANTARY BAY HOTEL RAYONG)
ADDRESS : 50, 50/2 RIEPJAIFANG ROAD PAK NAM MUEANG RAYONG RAYONG 21000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemki.com
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT OF KANTARY BAY, RAYONG
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : MAY 12, 2021
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS AMONRAT PUTTALEE

RECEIVED DATE : MAY 13, 2021
ANALYTICAL DATE : MAY 13-19, 2021
REPORT NO. : 2021-U37116
WORK NO. : 2021-003212
ANALYSIS NO. : T21A1069-0001 - T21A1069-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21A1069-0001	2 T21A1069-0002		
pH ⁰	-	ELECTROMETRIC METHOD (SM: 4500-H ⁺ B)	9.1 (26°C)	6.9 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND ¹	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O ₂ C AND 5210 B)	229	2.1	≤ 30	2.0
SUSPENDED SOLIDS ²	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	143	9.8	≤ 40	5.0
TOTAL KJELDAHL NITROGEN ³	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: 4500-Norg C	21.1	20.0	≤ 35	1.5
FAT, OIL AND GREASE ⁴	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	43	ND	≤ 20	3



- DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL.
- REPORTED ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY.

1/2





United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phra Khanong, Bangkok 10260

Tel. 0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com



NSC-TISI-TIS 17925
TESTING 0207



TESTING
No. 0063

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21A1069-0001	2 T21A1069-0003		
MICROBIOLOGY						
FAECAL COLIFORM BACTERIA a	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 E)	>160,000	< 1.8	-	1.8
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			BROWN/TURBID	YELLOW/TURBID		
SEDIMENT			BROWN	BROWN		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23RD EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23RD EDITION, 2017.

RESULT 1 : INFLUENT (RYG 1)

RESULT 2 : EFFLUENT (RYG 1)

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL. 122, PART 125 D, DATED DECEMBER 29, 2005.

ND : NON-DETECTABLE


^A : SAMPLING ON MAY 27, 2021, ANALYSIS NO. T21A1021-0001 (ANALYTICAL DATE : MAY 28- JUNE 5, 2021)

SUBSTITUTED REPORT FOR REPORT NO. 2021-U33410, DATED MAY 27, 2021.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

JUNE 8, 2021



• DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL.

• REPORTED ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY.

2/2

2021-U37116



United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Tel. 0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com



NSC-TIS-TIS 17825
TESTING 0207



TESTING
No. 0063

ANALYSIS REPORT

CUSTOMER NAME : KASEMKI COMPANY LIMITED (KANTARY BAY HOTEL RAYONG)
ADDRESS : 50, 50/2 RIEPJAIFANG ROAD PAK NAM MUEANG RAYONG RAYONG 21000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemki.com
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT OF KANTARY BAY, RAYONG
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : JUNE 9, 2021
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS AMONRAT PUTTALEE

RECEIVED DATE : JUNE 10, 2021
ANALYTICAL DATE : JUNE 10-18, 2021
REPORT NO. : 2021-045891
WORK NO. : 2021-003736
ANALYSIS NO. : T21AB90-0001 - T21AB90-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21AB90-0001	2 T21AB90-0002		
pH [±]	-	ELECTROMETRIC METHOD (SM: 4500-H ⁺ B)	7.4 (25°C)	7.1 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND [±]	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	283	ND	≤ 30	2.0
SUSPENDED SOLIDS [±]	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	251	17.6	≤ 40	5.0
TOTAL KJELDAHL NITROGEN [±]	mg/L	IN-HOUSE METHOD: UAETP:WAS.001 (KJELDAHL METHOD); SM: 4500-Norg C	23.9	19.7	≤ 35	1.5
FAT, OIL AND GREASE [±]	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	55	ND	≤ 20	3

ISO 9001:2015 CERTIFIED
 ISO 14001:2015 CERTIFIED
 BY SSI GROUP (THAILAND) CO., LTD.

• DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL .
 • REPORTED ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY.

1/2



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT
			1 T21A390-0001	2 T21A390-0002		
MICROBIOLOGY						
FAECAL COLIFORM BACTERIA ^a	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM 9221 E)	>160,000	< 1.8	-	1.6
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID	YELLOW/TURBID		
SEDIMENT			BROWN	BROWN		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

RESULT 1 : INFLUENT (RYG 1)

RESULT 2 : EFFLUENT (RYG 1)

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL. 122,
PART 125 D, DATED DECEMBER 29, 2005.

^a : PARAMETER ANALYSED OF THE EFFLUENT WAS SAMPLING BY CUSTOMER ON JUNE 28, 2021, ANALYSIS NO. T21A317-0001
(ANALYTICAL DATE : JUNE 29 - JULY 4, 2021)


ND : NON-DETECTABLE

SUBSTITUTED REPORT FOR REPORT NO. 2021-U41143 DATED JUNE 22, 2021

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

JULY 12, 2021



• DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL .
• REPORTED ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY.

2/2

2021-U45891