

**FIRE HOSE CABINET REPORT**

DATE..20.../01 /.2024.... FREQUENCY: 1 MONTH

EQUIPMENT LOCATION	HOSE CABINET	FIRE EXTINGUISHER	FIRE HOSE OR HOSE REEL	NOZZLE	HOSE COUPLING	HYDRANT PIPE & VALVES	Place	Type	Choked Date
<b>Building A 1.1</b>							<b>Room</b>		
FHC-01 Main car park	OK	10.P	OK	OK	1	OK	Car park	Softex	10-Jan-24
Floor 1 FHC-A1.1/1	OK	15 P	OK	OK	1	OK	116	Softex	10-Jan-24
Floor 2 FHC-A1.1/2	OK	15 P	OK	OK	1	OK	126	Softex	10-Jan-24
Floor 3 FHC-A1.1/3	OK	15 P	OK	OK	1	OK	136	Softex	10-Jan-24
Floor 4 FHC-A1.1/4	OK	15 P	OK	OK	1	OK	146	Softex	10-Jan-24
<b>Building A 1.2</b>									
FHC-02	OK	X	OK	OK	1+2	OK	Jungle	Dry Chemical	
Floor 1 FHC-A1.2/1	OK	10. P	OK	OK	1	OK	216	Softex	10-Jan-24
Floor 2 FHC-A1.2/2	OK	15.P	OK	OK	1	OK	226	Softex	10-Jan-24
Floor 3 FHC-A1.2/3	OK	15 P	OK	OK	1	OK	236	Softex	10-Jan-24
Floor 4 FHC-A1.2/4	OK	15 P	OK	OK	1	OK	246	Softex	10-Jan-24
VIG Changing Room		15 P							
<b>Building A 1.3</b>									
FHC-03	OK	X	OK	OK	1+2	OK	Jungle	Dry Chemical	
Floor 1 FHC-A1.3/1	OK	10.P	OK	OK	1	OK	311	Softex	10-Jan-24
Floor 2 FHC-A1.3/2	OK	15 P	OK	OK	1	OK	321	Softex	10-Jan-24
Floor 3 FHC-A1.3/3	OK	15 P	OK	OK	1	OK	331	Softex	10-Jan-24
Floor 4 FHC-A1.3/4	OK	15 P	OK	OK	1	OK	341	Softex	10-Jan-24
<b>Building A 1.4</b>									
FHC-04	OK	X	OK	OK	2+2	OK	Front M 4	Dry Chemical	
Floor 1 FHC-A1.4/1	OK	15 P	OK	OK	1	OK	416	Softex	10-Jan-24
Floor 2 FHC-A1.4/2	OK	15 P	OK	OK	1	OK	426	Softex	10-Jan-24
Floor 3 FHC-A1.4/3	OK	15 P	OK	OK	1	OK	436	Softex	10-Jan-24
Floor 4 FHC-A1.4/4	OK	15 P	OK	OK	1	OK	446	Softex	10-Jan-24
<b>Building A 1.5</b>									
FHC-05	OK	X	OK	OK	1+2	OK	Jungle	Dry Chemical	
Floor 1 FHC-A1.5/1	OK	15 P	OK	OK	1	OK	511	Softex	10-Jan-24
Floor 2 FHC-A1.5/2	OK	15 P	OK	OK	1	OK	521	Halotron	10-Jan-24
Floor 3 FHC-A1.5/3	OK	15 P	OK	OK	1	OK	531	Softex	10-Jan-24
Floor 4 FHC-A1.5/4	OK	15 P	OK	OK	1	OK	541	Softex	10-Jan-24
<b>Building A 1.6</b>									
FHC-06	OK	15P	OK	OK	2+1	OK	Out 611	Softex	7-Jan-24
FHC-07	OK	15P	OK	OK	2+1	OK	R617	Softex	7-Jan-24
Floor 1 FHC-A1.6/1	OK	15 P	OK	OK	1	OK	R615	Softex	7-Jan-24
Floor 2 FHC-A1.6/2	OK	15 P	OK	OK	1	OK	R625	Softex	7-Jan-24
Floor 3 FHC-A1.6/3	OK	15 P	OK	OK	1	OK	R635	Softex	7-Jan-24
Floor 4 FHC-A1.6/4	OK	15 P	OK	OK	1	OK	R645	Softex	7-Jan-24
<b>Building A 1.7</b>									
FHC-08	OK	10. P	OK	OK	2+2	OK	Out 717	Halotron	7-Jan-24
Floor 1 FHC-A1.7/1	OK	15 P	OK	OK	1	OK	R714	Softex	7-Jan-24
Floor 2 FHC-A1.7/2	OK	15 P	OK	OK	1	OK	R724	Softex	7-Jan-24

Floor 3	FHC-A1.7/3	OK	15 P	OK	OK	1	OK	R734	Softex	7-Jan-24
Floor 4	FHC-A1.7/4	OK	15 P	OK	OK	1	OK	R744	Softex	7-Jan-24
<b>Building A 1.8</b>										
Floor 1	FHC-A1.8/1	OK	15 P	OK	OK	1	OK	R816	Softex	7-Jan-24
Floor 2	FHC-A1.8/2	OK	10. P	OK	OK	1	OK	R826	Halotron	7-Jan-24
Floor 3	FHC-A1.8/3	OK	15 P	OK	OK	1	OK	R836	Softex	7-Jan-24
Floor 4	FHC-A1.8/4	OK	15 P	OK	OK	1	OK	R846	Softex	7-Jan-24
<b>Building A 1.9</b>										
FHC-09		OK	15 P	OK	OK	2+2	OK	Out 914	Softex	7-Jan-24
FHC-10		OK	15 P	OK	OK	2+2	OK	Out917	Softex	7-Jan-24
Floor 1	FHC-A1.9/1	OK	15 P	OK	OK	1	OK	R 914	Softex	7-Jan-24
Floor 2	FHC-A1.9/2	OK	15 P	OK	OK	1	OK	R924	Softex	7-Jan-24
Floor 3	FHC-A1.9/3	OK	15 P	OK	OK	1	OK	R934	Softex	7-Jan-24
Floor 4	FHC-A1.9/4	OK	15 P	OK	OK	1	OK	R944	Softex	7-Jan-24
<b>Building A 2 Lobby Area</b>										
Floor 1	FHC-A2/1	OK	15 P	OK	OK	1	OK	Tour Counter	Softex	6-Jan-24
Floor 2	FHC-A2/2	OK	15 P/15 P	OK	OK	1	OK	Excom	Softex/Water Mist Type	6-Jan-24
FO back office			10/15 P						Softex / Softex	6-Jan-24
Reservation Dept.			15 P						BAFFC	6-Jan-24
Main Entrance Guardhouse			15 P						Dry	6-Jan-24
<b>Building A 3</b>										
Floor 1	FHC-A3/1	OK	15 P	OK	OK	1	OK	Mare (IN)	Softex	6-Jan-24
Floor 1			15P	OK	OK	1	OK	Kitchen	Wet	6-Jan-24
Floor 1	FHC-13	OK	15P/15P(Foam)	OK	OK	1	OK	Mare (BS)	Wet Chemical / Foam	6-Jan-24
Floor 2	FHC-A3/2	OK	15P	OK	OK	1	OK	Luna Bar	Softex	6-Jan-24
<b>Building A 4</b>										
FHC -11		OK	15P	OK	OK	2+2	OK	Gas Store	Softex	6-Jan-24
FHC-12		OK	15P	OK	OK	2+2	OK	Car park	BF2000	6-Jan-24
FHC-A4/1		OK	15 P /15P	OK	OK	1	OK	Cove Kitchen	Wet / Wet	6-Jan-24
FHC-A4/2		OK	15 P	OK	OK	1	OK	Cove in	Softex	6-Jan-24
Showing kitchen			10 P /15 P						Softex / Softex	6-Jan-24
<b>Building A 5</b>										
Splash Bar			15P					Splash Bar	Softex	6-Jan-24
Barefoot Bar			X					Barefoot	Softex	6-Jan-24
FHC-A5/1		OK	15P	OK	OK	1	OK	Kids Club	Softex	6-Jan-24
FHC-A5/2		OK	15 P/15P	OK	OK	1	OK	Club lounge	Water Mist/Water Mist Type	6-Jan-24
<b>Building A 6</b>										
Fitness			15 P					In Fitness	Water Mist Type	6-Jan-24
Behind Spa			15 P					Behind Spa	Halotron	6-Jan-24
Floor 1	FHC-A6/1	OK	15 P	OK	OK	1	OK	SPA	Softex	6-Jan-24
Floor 2	FHC-A6/2	OK	10 P/15 P	OK	OK	1	OK	Call Center	Softex/Softex	6-Jan-24
<b>Building A 7 Ball Room</b>										
FHC-14		OK		OK	OK	1	OK	Loading		
Floor 1	FHC-A7/1	OK	15 P	OK	OK	1	OK	Back FI 1	Water Mist	8-Jan-24
Floor 1	FHC-A7/2	OK	15 P	OK	OK	1	OK	Front FI1	Water Mist	8-Jan-24
Floor 2	FHC-A7/3	OK	15 P	OK	OK	1	OK	Front FI2	Water Mist	8-Jan-24
Floor 2	FHC-A7/4	OK	15 P	OK	OK	1	OK	Back FI 2	Water Mist	8-Jan-24
Bakery Room			15P						Softex	8-Jan-24
Generator			15 P					Behind A. 7	Softex	8-Jan-24

Building A 8										
Main Storeroom			10. P					Softex	8-Jan-24	
Garbage room area			X					Dry Chemical		
Gas Store			15 P					Softex	8-Jan-24	
Chiller plant	FHC-A8/1	OK	10P/15 P	OK	OK	1	OK	Under A 8	Softex/Softex	8-Jan-24
Floor 1	FHC-A8/2	OK	15 P	OK	OK	1	OK	Uniform	Softex	8-Jan-24
Floor 2	FHC-A8/3		15 P	OK	OK	1	OK	FI 2	Wet	8-Jan-24
Floor 2	HR/ FC		15 P					FI 2	ABFFC	8-Jan-24
Floor 2	Canteen		15 P/15P					FI 2	Softex/Water Mist Type	8-Jan-24
Building A 9										
Chemical Store			15 P					A9	Softex	10-Jan-24
FHC-15		OK	10 P/15 P	OK	OK	2+2	OK	A.9	Softex/Softex	10-Jan-24
FHC-A9/1		OK	10 P/15 P	OK	OK	1	OK	ENG. In	Softex/Softex	10-Jan-24
Fire pump room			15 P					Fire pump	Halotron	10-Jan-24
Villa										
FHC-16		OK		OK	OK	1	OK	Villa 1		
FHC-17		OK		OK	OK	1		Villa 3		
FHC-18		OK	10P	OK	OK	1	OK	Villa 9	Dry	Expired
Under Villa 2-10		Villa 3,5,7,9 = 10P			Villa 2,4,6,8,10 = 15P					12-Jan-24
		Fire Extinguisher grand total good condition tanks total 101 tanks							10P = 19 tanks, 15P = 82 tanks	
		Fire Extinguisher Expired = 1 tanks								
		Fireman Team Cabinet								
SCBA (Self Control Breathing Apparatas)			2 Set							
A: Fire Fighting Uniform = 6 PCS			B: Fire Boot = 6 Pcs							
Fire Nozzle ( Small) = 1 pcs			D : Fire Axes = 2 Pcs ( Big)							
Fire Nozzle ( Big) = 2 pcs			E : Fire Axes = 2 Pcs ( Small)							
C: Fire Helmet = 6 Pcs			F : Fire Grove = 6 Pcs							
Building 1.1 - 1.5 Check by: Khun Peeyachat, Supervisor					Under Villa 4 = Halotron, Under Villa 2,3,5,6,7,8,9,10 = Softex					
Others areas and Villa 1-10 Check by : Khun Karom, Supervisor										
Building 1. 6-1. 9 Check by: Khun Peeyachat, Supervisor										

Approved by: Chaowalith Pholla Asst. Chief Security Date: 20 January 2024

### FIRE HOSE CABINET REPORT

DATE..20.../02 /.2024.... FREQUENCY: <u>1</u> MONTH									
EQUIPMENT LOCATION	HOSE CABINET	FIRE EXTINGUISHER	FIRE HOSE OR HOSE REEL	NOZZLE	HOSE COUPLING	HYDRANT PIPE & VALVES	Place	Type	Cheked Date
<b>Building A 1.1</b>							<b>Room</b>		
FHC-01 Main car park	OK	10.P	OK	OK	1	OK	Car park	Softex	9-Feb-24
Floor 1 FHC-A1.1/1	OK	15 P	OK	OK	1	OK	116	Softex	9-Feb-24
Floor 2 FHC-A1.1/2	OK	15 P	OK	OK	1	OK	126	Softex	9-Feb-24
Floor 3 FHC-A1.1/3	OK	15 P	OK	OK	1	OK	136	Softex	9-Feb-24
Floor 4 FHC-A1.1/4	OK	15 P	OK	OK	1	OK	146	Softex	9-Feb-24
<b>Building A 1.2</b>									
FHC-02	OK		OK	OK	1+2	OK	Jungle		
Floor 1 FHC-A1.2/1	OK	10. P	OK	OK	1	OK	216	Softex	9-Feb-24
Floor 2 FHC-A1.2/2	OK	15.P	OK	OK	1	OK	226	Softex	9-Feb-24
Floor 3 FHC-A1.2/3	OK	15 P	OK	OK	1	OK	236	Softex	9-Feb-24
Floor 4 FHC-A1.2/4	OK	15 P	OK	OK	1	OK	246	Softex	9-Feb-24
VIG Changing Room		15 P							
<b>Building A 1.3</b>									
FHC-03	OK		OK	OK	1+2	OK	Jungle		
Floor 1 FHC-A1.3/1	OK	10.P	OK	OK	1	OK	311	Softex	9-Feb-24
Floor 2 FHC-A1.3/2	OK	15 P	OK	OK	1	OK	321	Softex	9-Feb-24
Floor 3 FHC-A1.3/3	OK	15 P	OK	OK	1	OK	331	Softex	9-Feb-24
Floor 4 FHC-A1.3/4	OK	15 P	OK	OK	1	OK	341	Softex	9-Feb-24
<b>Building A 1.4</b>									
FHC-04	OK		OK	OK	2+2	OK	Front M 4		
Floor 1 FHC-A1.4/1	OK	15 P	OK	OK	1	OK	416	Softex	9-Feb-24
Floor 2 FHC-A1.4/2	OK	15 P	OK	OK	1	OK	426	Softex	9-Feb-24
Floor 3 FHC-A1.4/3	OK	15 P	OK	OK	1	OK	436	Softex	9-Feb-24
Floor 4 FHC-A1.4/4	OK	15 P	OK	OK	1	OK	446	Softex	9-Feb-24
<b>Building A 1.5</b>									
FHC-05	OK		OK	OK	1+2	OK	Jungle		
Floor 1 FHC-A1.5/1	OK	15 P	OK	OK	1	OK	511	Softex	9-Feb-24
Floor 2 FHC-A1.5/2	OK	15 P	OK	OK	1	OK	521	Halotron	9-Feb-24
Floor 3 FHC-A1.5/3	OK	15 P	OK	OK	1	OK	531	Softex	9-Feb-24
Floor 4 FHC-A1.5/4	OK	15 P	OK	OK	1	OK	541	Softex	9-Feb-24
<b>Building A 1.6</b>									
FHC-06	OK	15P	OK	OK	2+1	OK	Out 611	Softex	8-Feb-24
FHC-07	OK	15P	OK	OK	2+1	OK	R617	Softex	8-Feb-24
Floor 1 FHC-A1.6/1	OK	15 P	OK	OK	1	OK	R615	Softex	8-Feb-24
Floor 2 FHC-A1.6/2	OK	15 P	OK	OK	1	OK	R625	Softex	8-Feb-24
Floor 3 FHC-A1.6/3	OK	15 P	OK	OK	1	OK	R635	Softex	8-Feb-24
Floor 4 FHC-A1.6/4	OK	15 P	OK	OK	1	OK	R645	Softex	8-Feb-24
<b>Building A 1.7</b>									
FHC-08	OK	10. P	OK	OK	2+2	OK	Out 717	Halotron	8-Feb-24
Floor 1 FHC-A1.7/1	OK	15 P	OK	OK	1	OK	R714	Softex	8-Feb-24
Floor 2 FHC-A1.7/2	OK	15 P	OK	OK	1	OK	R724	Softex	8-Feb-24

Floor 3	FHC-A1.7/3	OK	15 P	OK	OK	1	OK	R734	Softex	8-Feb-24
Floor 4	FHC-A1.7/4	OK	15 P	OK	OK	1	OK	R744	Softex	8-Feb-24
<b>Building A 1.8</b>										
Floor 1	FHC-A1.8/1	OK	15 P	OK	OK	1	OK	R816	Softex	8-Feb-24
Floor 2	FHC-A1.8/2	OK	10. P	OK	OK	1	OK	R826	Halotron	8-Feb-24
Floor 3	FHC-A1.8/3	OK	15 P	OK	OK	1	OK	R836	Softex	8-Feb-24
Floor 4	FHC-A1.8/4	OK	15 P	OK	OK	1	OK	R846	Softex	8-Feb-24
<b>Building A 1.9</b>										
<b>FHC-09</b>		OK	15 P	OK	OK	2+2	OK	Out 914	Softex	8-Feb-24
<b>FHC-10</b>		OK	15 P	OK	OK	2+2	OK	Out917	Softex	8-Feb-24
Floor 1	FHC-A1.9/1	OK	15 P	OK	OK	1	OK	R 914	Softex	8-Feb-24
Floor 2	FHC-A1.9/2	OK	15 P	OK	OK	1	OK	R924	Softex	8-Feb-24
Floor 3	FHC-A1.9/3	OK	15 P	OK	OK	1	OK	R934	Softex	8-Feb-24
Floor 4	FHC-A1.9/4	OK	15 P	OK	OK	1	OK	R944	Softex	8-Feb-24
<b>Building A 2 Lobby Area</b>										
Floor 1	FHC-A2/1	OK	15 P	OK	OK	1	OK	Tour Counter	Softex	10-Feb-24
Floor 2	FHC-A2/2	OK	15 P/15 P	OK	OK	1	OK	Excom	Softex/Water Mist Type	10-Feb-24
FO back office			10/15 P						Softex / Softex	10-Feb-24
Reservation Dept.			15 P						BAFFC	10-Feb-24
Main Entrance Guardhouse			15 P						Dry	10-Feb-24
<b>Building A 3</b>										
Floor 1	FHC-A3/1	OK	15 P	OK	OK	1	OK	Mare (IN)	Softex	10-Feb-24
Floor 1			15P	OK	OK	1	OK	Kitchen	Wet	10-Feb-24
Floor 1	FHC-13	OK	15P/15P(Foam)	OK	OK	1	OK	Mare (BS)	Wet Chemical / Foam	10-Feb-24
Floor 2	FHC-A3/2	OK	15P	OK	OK	1	OK	Luna Bar	Softex	10-Feb-24
<b>Building A 4</b>										
<b>FHC -11</b>		OK	15P	OK	OK	2+2	OK	Gas Store	Softex	10-Feb-24
<b>FHC-12</b>		OK	15P	OK	OK	2+2	OK	Car park	BF2000	10-Feb-24
FHC-A4/1		OK	15 P /15P	OK	OK	1	OK	Cove Kitchen	Wet / Wet	10-Feb-24
FHC-A4/2		OK	15 P	OK	OK	1	OK	Cove in	Softex	10-Feb-24
Showing kitchen			10 P /15 P						Softex / Softex	10-Feb-24
<b>Building A 5</b>										
Splash Bar			15P					Splash Bar	Softex	10-Feb-24
Barefoot Bar								Barefoot		
FHC-A5/1		OK	15P	OK	OK	1	OK	Kids Club	Softex	10-Feb-24
FHC-A5/2		OK	15 P/15P	OK	OK	1	OK	Club lounge	Water Mist/Water Mist Type	10-Feb-24
<b>Building A 6</b>										
Fitness			15 P					In Fitness	Water Mist Type	10-Feb-24
Behind Spa			15 P					Behind Spa	Halotron	10-Feb-24
Floor 1	FHC-A6/1	OK	15 P	OK	OK	1	OK	SPA	Softex	10-Feb-24
Floor 2	FHC-A6/2	OK	10 P/15 P	OK	OK	1	OK	Call Center	Softex/Softex	10-Feb-24
<b>Building A 7 Ball Room</b>										
FHC-14		OK		OK	OK	1	OK	Loading		
Floor 1 FHC-A7/1		OK	15 P	OK	OK	1	OK	Back FI 1	Water Mist	11-Feb-24
Floor 1 FHC-A7/2		OK	15 P	OK	OK	1	OK	Front FI1	Water Mist	11-Feb-24
Floor 2 FHC-A7/3		OK	15 P	OK	OK	1	OK	Front FI2	Water Mist	11-Feb-24
Floor 2 FHC-A7/4		OK	15 P	OK	OK	1	OK	Back FI 2	Water Mist	11-Feb-24
Bakery Room			15P						Softex	
<b>Generator</b>			15 P					Behind A. 7	Softex	

Building A 8									
Main Storeroom		10. P						Softex	11-Feb-24
Garbage room area									
Gas Store		15 P						Softex	11-Feb-24
Chiller plant FHC-A8/1	OK	10P/15 P	OK	OK	1	OK	Under A 8	Softex/Softex	11-Feb-24
Floor 1 FHC-A8/2	OK	15 P	OK	OK	1	OK	Uniform	Softex	11-Feb-24
Floor 2 FHC-A8/3		15 P	OK	OK	1	OK	FI 2	Wet	11-Feb-24
Floor 2 HR/ FC		15 P					FI 2	ABFFC	11-Feb-24
Floor 2 Canteen		15 P/15P					FI 2	Softex/Water Mist Type	11-Feb-24
Building A 9									
Chemical Store		15 P					A9	Softex	11-Feb-24
FHC-15	OK	10 P/15 P	OK	OK	2+2	OK	A.9	Softex/Softex	11-Feb-24
FHC-A9/1	OK	10 P/15 P	OK	OK	1	OK	ENG. In	Softex/Softex	11-Feb-24
Fire pump room		15 P					Fire pump	Halotron	11-Feb-24
Villa									
FHC-16	OK		OK	OK	1	OK	Villa 1		
FHC-17	OK		OK	OK	1		Villa 3		
FHC-18	OK		OK	OK	1	OK	Villa 9		
Under Villa 2-10	Villa 3,5,7,9 = 10P			Villa 2,4,6,8,10 = 15P					15-Feb-24
	Fire Extinguisher grand total good condition to total 101 tanks							10P = 19 tanks, 15P = 82 tanks	
	Fire Extinguisher Expired = 1 tanks								
Fireman Team Cabinet									
SCBA (Self Control Breathing Apparatas)			2 Set						
A: Fire Fighting Uniform = 6 PCS			B: Fire Boot = 6 Pcs						
Fire Nozzle ( Small) = 1 pcs			D : Fire Axes = 2 Pcs ( Big)						
Fire Nozzle ( Big) = 2 pcs			E : Fire Axes = 2 Pcs ( Small)						
C: Fire Helmet = 6 Pcs			F : Fire Grove = 6 Pcs						
Building 1.1 - 1.5 Check by: Khun Peeyachat, Supervisor				Under Villa 4 = Halotron, Under Villa 2,3,5,6,7,8,9,10 = Softex					
Others areas and Villa 1-10 Check by : Khun Karom, Supervisor									
Building 1. 6-1. 9 Check by: Khun Peeyachat, Supervisor									

Approved by: Chaowalith Pholla Asst. Chief Security Date: 20 February 2024

### FIRE HOSE CABINET REPORT

DATE..20.../03 /.2024.... FREQUENCY: 1 MONTH

EQUIPMENT LOCATION	HOSE CABINET	FIRE EXTINGUISHER	FIRE HOSE OR HOSE REEL	NOZZLE	HOSE COUPLING	HYDRANT PIPE & VALVES	Place	Type	Choked Date
<b>Building A 1.1</b>							<b>Room</b>		
FHC-01 Main car park	OK	10.P	OK	OK	1	OK	Car park	Softex	7-Mar-24
Floor 1 FHC-A1.1/1	OK	15 P	OK	OK	1	OK	116	Softex	7-Mar-24
Floor 2 FHC-A1.1/2	OK	15 P	OK	OK	1	OK	126	Softex	7-Mar-24
Floor 3 FHC-A1.1/3	OK	15 P	OK	OK	1	OK	136	Softex	7-Mar-24
Floor 4 FHC-A1.1/4	OK	15 P	OK	OK	1	OK	146	Softex	7-Mar-24
<b>Building A 1.2</b>									
FHC-02	OK		OK	OK	1+2	OK	Jungle		
Floor 1 FHC-A1.2/1	OK	10. P	OK	OK	1	OK	216	Softex	7-Mar-24
Floor 2 FHC-A1.2/2	OK	15.P	OK	OK	1	OK	226	Softex	7-Mar-24
Floor 3 FHC-A1.2/3	OK	15 P	OK	OK	1	OK	236	Softex	7-Mar-24
Floor 4 FHC-A1.2/4	OK	15 P	OK	OK	1	OK	246	Softex	7-Mar-24
VIG Changing Room		15 P							
<b>Building A 1.3</b>									
FHC-03	OK		OK	OK	1+2	OK	Jungle		
Floor 1 FHC-A1.3/1	OK	10.P	OK	OK	1	OK	311	Softex	7-Mar-24
Floor 2 FHC-A1.3/2	OK	15 P	OK	OK	1	OK	321	Softex	7-Mar-24
Floor 3 FHC-A1.3/3	OK	15 P	OK	OK	1	OK	331	Softex	7-Mar-24
Floor 4 FHC-A1.3/4	OK	15 P	OK	OK	1	OK	341	Softex	7-Mar-24
<b>Building A 1.4</b>									
FHC-04	OK		OK	OK	2+2	OK	Front M 4		
Floor 1 FHC-A1.4/1	OK	15 P	OK	OK	1	OK	416	Softex	7-Mar-24
Floor 2 FHC-A1.4/2	OK	15 P	OK	OK	1	OK	426	Softex	7-Mar-24
Floor 3 FHC-A1.4/3	OK	15 P	OK	OK	1	OK	436	Softex	7-Mar-24
Floor 4 FHC-A1.4/4	OK	15 P	OK	OK	1	OK	446	Softex	7-Mar-24
<b>Building A 1.5</b>									
FHC-05	OK		OK	OK	1+2	OK	Jungle		
Floor 1 FHC-A1.5/1	OK	15 P	OK	OK	1	OK	511	Softex	7-Mar-24
Floor 2 FHC-A1.5/2	OK	15 P	OK	OK	1	OK	521	Halotron	7-Mar-24
Floor 3 FHC-A1.5/3	OK	15 P	OK	OK	1	OK	531	Softex	7-Mar-24
Floor 4 FHC-A1.5/4	OK	15 P	OK	OK	1	OK	541	Softex	7-Mar-24
<b>Building A 1.6</b>									
FHC-06	OK	15P	OK	OK	2+1	OK	Out 611	Softex	6-Mar-24
FHC-07	OK	15P	OK	OK	2+1	OK	R617	Softex	6-Mar-24
Floor 1 FHC-A1.6/1	OK	15 P	OK	OK	1	OK	R615	Softex	6-Mar-24
Floor 2 FHC-A1.6/2	OK	15 P	OK	OK	1	OK	R625	Softex	6-Mar-24
Floor 3 FHC-A1.6/3	OK	15 P	OK	OK	1	OK	R635	Softex	6-Mar-24
Floor 4 FHC-A1.6/4	OK	15 P	OK	OK	1	OK	R645	Softex	6-Mar-24
<b>Building A 1.7</b>									
FHC-08	OK	10. P	OK	OK	2+2	OK	Out 717	Halotron	6-Mar-24
Floor 1 FHC-A1.7/1	OK	15 P	OK	OK	1	OK	R714	Softex	6-Mar-24
Floor 2 FHC-A1.7/2	OK	15 P	OK	OK	1	OK	R724	Softex	6-Mar-24

Floor 3	FHC-A1.7/3	OK	15 P	OK	OK	1	OK	R734	Softex	6-Mar-24
Floor 4	FHC-A1.7/4	OK	15 P	OK	OK	1	OK	R744	Softex	6-Mar-24
<b>Building A 1.8</b>										
Floor 1	FHC-A1.8/1	OK	15 P	OK	OK	1	OK	R816	Softex	6-Mar-24
Floor 2	FHC-A1.8/2	OK	10. P	OK	OK	1	OK	R826	Halotron	6-Mar-24
Floor 3	FHC-A1.8/3	OK	15 P	OK	OK	1	OK	R836	Softex	6-Mar-24
Floor 4	FHC-A1.8/4	OK	15 P	OK	OK	1	OK	R846	Softex	6-Mar-24
<b>Building A 1.9</b>										
FHC-09		OK	15 P	OK	OK	2+2	OK	Out 914	Softex	6-Mar-24
FHC-10		OK	15 P	OK	OK	2+2	OK	Out917	Softex	6-Mar-24
Floor 1	FHC-A1.9/1	OK	15 P	OK	OK	1	OK	R 914	Softex	6-Mar-24
Floor 2	FHC-A1.9/2	OK	15 P	OK	OK	1	OK	R924	Softex	6-Mar-24
Floor 3	FHC-A1.9/3	OK	15 P	OK	OK	1	OK	R934	Softex	6-Mar-24
Floor 4	FHC-A1.9/4	OK	15 P	OK	OK	1	OK	R944	Softex	6-Mar-24
<b>Building A 2 Lobby Area</b>										
Floor 1	FHC-A2/1	OK	15 P	OK	OK	1	OK	Tour Counter	Softex	12-Mar-24
Floor 2	FHC-A2/2	OK	15 P/15 P	OK	OK	1	OK	Excom	Softex/Water Mist Type	12-Mar-24
FO back office			10/15 P						Softex / Softex	12-Mar-24
Reservation Dept.			15 P						BAFFC	12-Mar-24
Main Entrance Guardhouse			15 P						Dry	12-Mar-24
<b>Building A 3</b>										
Floor 1	FHC-A3/1	OK	15 P	OK	OK	1	OK	Mare (IN)	Softex	13-Mar-24
Floor 1			15P	OK	OK	1	OK	Kitchen	Wet	13-Mar-24
Floor 1	FHC-13	OK	15P/15P(Foam)	OK	OK	1	OK	Mare (BS)	Wet Chemical / Foam	13-Mar-24
Floor 2	FHC-A3/2	OK	15P	OK	OK	1	OK	Luna Bar	Softex	13-Mar-24
<b>Building A 4</b>										
FHC -11		OK	15P	OK	OK	2+2	OK	Gas Store	Softex	13-Mar-24
FHC-12		OK	15P	OK	OK	2+2	OK	Car park	BF2000	13-Mar-24
FHC-A4/1		OK	15 P /15P	OK	OK	1	OK	Cove Kitchen	Wet / Wet	13-Mar-24
FHC-A4/2		OK	15 P	OK	OK	1	OK	Cove in	Softex	13-Mar-24
Showing kitchen			10 P /15 P						Softex / Softex	13-Mar-24
<b>Building A 5</b>										
Splash Bar			15P					Splash Bar	Softex	13-Mar-24
Barefoot Bar								Barefoot		
FHC-A5/1		OK	15P	OK	OK	1	OK	Kids Club	Softex	13-Mar-24
FHC-A5/2		OK	15 P/15P	OK	OK	1	OK	Club lounge	Water Mist/Water Mist Type	13-Mar-24
<b>Building A 6</b>										
Fitness			15 P					In Fitness	Water Mist Type	13-Mar-24
Behind Spa			15 P					Behind Spa	Halotron	13-Mar-24
Floor 1	FHC-A6/1	OK	15 P	OK	OK	1	OK	SPA	Softex	13-Mar-24
Floor 2	FHC-A6/2	OK	10 P/15 P	OK	OK	1	OK	Call Center	Softex/Softex	13-Mar-24
<b>Building A 7 Ball Room</b>										
FHC-14		OK		OK	OK	1	OK	Loading		
Floor 1 FHC-A7/1		OK	15 P	OK	OK	1	OK	Back Fl 1	Water Mist	9-Mar-24
Floor 1 FHC-A7/2		OK	15 P	OK	OK	1	OK	Front Fl1	Water Mist	9-Mar-24
Floor 2 FHC-A7/3		OK	15 P	OK	OK	1	OK	Front Fl2	Water Mist	9-Mar-24
Floor 2 FHC-A7/4		OK	15 P	OK	OK	1	OK	Back Fl 2	Water Mist	9-Mar-24
Bakery Room			15P						Softex	9-Mar-24
Generator			15 P					Behind A. 7	Softex	9-Mar-24



Building A 8										
Main Storeroom			10. P					Softex	9-Mar-24	
Garbage room area										
Gas Store			15 P					Softex	9-Mar-24	
Chiller plant	FHC-A8/1	OK	10P/15 P	OK	OK	1	OK	Under A 8	Softex/Softex	9-Mar-24
Floor 1	FHC-A8/2	OK	15 P	OK	OK	1	OK	Uniform	Softex	9-Mar-24
Floor 2	FHC-A8/3		15 P	OK	OK	1	OK	FI 2	Wet	9-Mar-24
Floor 2	HR/ FC		15 P					FI 2	ABFFC	9-Mar-24
Floor 2	Canteen		15 P/15P					FI 2	Softex/Water Mist Type	9-Mar-24
Building A 9										
Chemical Store			15 P					A9	Softex	8-Mar-24
FHC-15		OK	10 P/15 P	OK	OK	2+2	OK	A.9	Softex/Softex	8-Mar-24
FHC-A9/1		OK	10 P/15 P	OK	OK	1	OK	ENG. In	Softex/Softex	8-Mar-24
Fire pump room			15 P					Fire pump	Halotron	8-Mar-24
Villa										
FHC-16		OK		OK	OK	1	OK	Villa 1		
FHC-17		OK		OK	OK	1		Villa 3		
FHC-18		OK		OK	OK	1	OK	Villa 9		
Under Villa 2-10		Villa 3,5,7,9 = 10P			Villa 2,4,6,8,10 = 15P					8-Mar-24
		Fire Extinguisher grand total good condition to total 101 tanks							10P = 19 tanks, 15P = 82 tanks	
		Fire Extinguisher Expired = 1 tanks								
Fireman Team Cabinet										
SCBA (Self Control Breathing Apparatas)			2 Set							
A: Fire Fighting Uniform = 6 PCS			B: Fire Boot = 6 Pcs							
Fire Nozzle ( Small) = 1 pcs			D : Fire Axes = 2 Pcs ( Big)							
Fire Nozzle ( Big) = 2 pcs			E : Fire Axes = 2 Pcs ( Small)							
C: Fire Helmet = 6 Pcs			F : Fire Grove = 6 Pcs							
Building 1.1 - 1.5 Check by: Khun Peeyachat, Supervisor					Under Villa 4 = Halotron, Under Villa 2,3,5,6,7,8,9,10 = Softex					
Others areas and Villa 1-10 Check by : Khun Karom, Supervisor										
Building 1. 6-1. 9 Check by: Khun Peeyachat, Supervisor										

Approved by: Chaowalith Pholla Asst. Chief Security Date: 20 March 2024

**FIRE HOSE CABINET REPORT**

DATE..20.../04 /2024....

FREQUENCY: 1 MONTH

EQUIPMENT LOCATION	HOSE CABINET	FIRE EXTINGUISHER	FIRE HOSE OR HOSE REEL	NOZZLE	HOSE COUPLING	HYDRANT PIPE & VALVES	Place	Type	Choked Date
<b>Building A 1.1</b>							<b>Room</b>		
FHC-01 Main car park	OK	10.P	OK	OK	1	OK	Car park	Softex	7-Apr-24
Floor 1 FHC-A1.1/1	OK	15 P	OK	OK	1	OK	116	Softex	7-Apr-24
Floor 2 FHC-A1.1/2	OK	15 P	OK	OK	1	OK	126	Softex	7-Apr-24
Floor 3 FHC-A1.1/3	OK	15 P	OK	OK	1	OK	136	Softex	7-Apr-24
Floor 4 FHC-A1.1/4	OK	15 P	OK	OK	1	OK	146	Softex	7-Apr-24
<b>Building A 1.2</b>									
FHC-02	OK		OK	OK	1+2	OK	<b>Jungle</b>		
Floor 1 FHC-A1.2/1	OK	10. P	OK	OK	1	OK	216	Softex	7-Apr-24
Floor 2 FHC-A1.2/2	OK	15.P	OK	OK	1	OK	226	Softex	7-Apr-24
Floor 3 FHC-A1.2/3	OK	15 P	OK	OK	1	OK	236	Softex	7-Apr-24
Floor 4 FHC-A1.2/4	OK	15 P	OK	OK	1	OK	246	Softex	7-Apr-24
VIG Changing Room		15 P							
<b>Building A 1.3</b>									
FHC-03	OK		OK	OK	1+2	OK	<b>Jungle</b>		
Floor 1 FHC-A1.3/1	OK	10.P	OK	OK	1	OK	311	Softex	7-Apr-24
Floor 2 FHC-A1.3/2	OK	15 P	OK	OK	1	OK	321	Softex	7-Apr-24
Floor 3 FHC-A1.3/3	OK	15 P	OK	OK	1	OK	331	Softex	7-Apr-24
Floor 4 FHC-A1.3/4	OK	15 P	OK	OK	1	OK	341	Softex	7-Apr-24
<b>Building A 1.4</b>									
FHC-04	OK		OK	OK	2+2	OK	<b>Front M 4</b>		
Floor 1 FHC-A1.4/1	OK	15 P	OK	OK	1	OK	416	Softex	7-Apr-24
Floor 2 FHC-A1.4/2	OK	15 P	OK	OK	1	OK	426	Softex	7-Apr-24
Floor 3 FHC-A1.4/3	OK	15 P	OK	OK	1	OK	436	Softex	7-Apr-24
Floor 4 FHC-A1.4/4	OK	15 P	OK	OK	1	OK	446	Softex	7-Apr-24
<b>Building A 1.5</b>									
FHC-05	OK		OK	OK	1+2	OK	<b>Jungle</b>		
Floor 1 FHC-A1.5/1	OK	15 P	OK	OK	1	OK	511	Softex	7-Apr-24
Floor 2 FHC-A1.5/2	OK	15 P	OK	OK	1	OK	521	Halotron	7-Apr-24
Floor 3 FHC-A1.5/3	OK	15 P	OK	OK	1	OK	531	Softex	7-Apr-24
Floor 4 FHC-A1.5/4	OK	15 P	OK	OK	1	OK	541	Softex	7-Apr-24
<b>Building A 1.6</b>									
FHC-06	OK	15P	OK	OK	2+1	OK	<b>Out 611</b>	Softex	9-Apr-24
FHC-07	OK	15P	OK	OK	2+1	OK	R617	Softex	9-Apr-24
Floor 1 FHC-A1.6/1	OK	15 P	OK	OK	1	OK	R615	Softex	9-Apr-24
Floor 2 FHC-A1.6/2	OK	15 P	OK	OK	1	OK	R625	Softex	9-Apr-24
Floor 3 FHC-A1.6/3	OK	15 P	OK	OK	1	OK	R635	Softex	9-Apr-24
Floor 4 FHC-A1.6/4	OK	15 P	OK	OK	1	OK	R645	Softex	9-Apr-24
<b>Building A 1.7</b>									
FHC-08	OK	10. P	OK	OK	2+2	OK	<b>Out 717</b>	Halotron	9-Apr-24
Floor 1 FHC-A1.7/1	OK	15 P	OK	OK	1	OK	R714	Softex	9-Apr-24
Floor 2 FHC-A1.7/2	OK	15 P	OK	OK	1	OK	R724	Softex	9-Apr-24

Floor 3	FHC-A1.7/3	OK	15 P	OK	OK	1	OK	R734	Softex	9-Apr-24
Floor 4	FHC-A1.7/4	OK	15 P	OK	OK	1	OK	R744	Softex	9-Apr-24
<b>Building A 1.8</b>										
Floor 1	FHC-A1.8/1	OK	15 P	OK	OK	1	OK	R816	Softex	9-Apr-24
Floor 2	FHC-A1.8/2	OK	10. P	OK	OK	1	OK	R826	Halotron	9-Apr-24
Floor 3	FHC-A1.8/3	OK	15 P	OK	OK	1	OK	R836	Softex	9-Apr-24
Floor 4	FHC-A1.8/4	OK	15 P	OK	OK	1	OK	R846	Softex	9-Apr-24
<b>Building A 1.9</b>										
<b>FHC-09</b>		OK	15 P	OK	OK	2+2	OK	<b>Out 914</b>	Softex	9-Apr-24
<b>FHC-10</b>		OK	15 P	OK	OK	2+2	OK	<b>Out917</b>	Softex	9-Apr-24
Floor 1	FHC-A1.9/1	OK	15 P	OK	OK	1	OK	R 914	Softex	9-Apr-24
Floor 2	FHC-A1.9/2	OK	15 P	OK	OK	1	OK	R924	Softex	9-Apr-24
Floor 3	FHC-A1.9/3	OK	15 P	OK	OK	1	OK	R934	Softex	9-Apr-24
Floor 4	FHC-A1.9/4	OK	15 P	OK	OK	1	OK	R944	Softex	9-Apr-24
<b>Building A 2 Lobby Area</b>										
Floor 1	FHC-A2/1	OK	15 P	OK	OK	1	OK	Tour Counter	Softex	10-Apr-24
Floor 2	FHC-A2/2	OK	15 P/15 P	OK	OK	1	OK	Excom	Softex/Water Mist Type	10-Apr-24
FO back office			10/15 P						Softex / Softex	10-Apr-24
Reservation Dept.			15 P						BAFFC	10-Apr-24
Main Entrance Guardhouse			15 P						Dry	10-Apr-24
<b>Building A 3</b>										
Floor 1	FHC-A3/1	OK	15 P	OK	OK	1	OK	Mare (IN)	Softex	10-Apr-24
Floor 1			15P	OK	OK	1	OK	Kitchen	Wet	10-Apr-24
Floor 1	FHC-13	OK	15P/15P(Foam)	OK	OK	1	OK	Mare (BS)	Wet Chemical / Foam	10-Apr-24
Floor 2	FHC-A3/2	OK	15P	OK	OK	1	OK	Luna Bar	Softex	10-Apr-24
<b>Building A 4</b>										
<b>FHC -11</b>		OK	15P	OK	OK	2+2	OK	Gas Store	Softex	14-Apr-24
<b>FHC-12</b>		OK	15P	OK	OK	2+2	OK	Car park	BF2000	14-Apr-24
FHC-A4/1		OK	15 P /15P	OK	OK	1	OK	Cove Kitchen	Wet / Wet	14-Apr-24
FHC-A4/2		OK	15 P	OK	OK	1	OK	Cove in	Softex	14-Apr-24
Showing kitchen			10 P /15 P						Softex / Softex	14-Apr-24
<b>Building A 5</b>										
Splash Bar			15P					Splash Bar	Softex	14-Apr-24
Barefoot Bar								Barefoot		
FHC-A5/1		OK	15P	OK	OK	1	OK	Kids Club	Softex	14-Apr-24
FHC-A5/2		OK	15 P/15P	OK	OK	1	OK	Club lounge	Water Mist/Water Mist Type	14-Apr-24
<b>Building A 6</b>										
Fitness			15 P					In Fitness	Water Mist Type	14-Apr-24
Behind Spa			15 P					Behind Spa	Halotron	14-Apr-24
Floor 1	FHC-A6/1	OK	15 P	OK	OK	1	OK	SPA	Softex	14-Apr-24
Floor 2	FHC-A6/2	OK	10 P/15 P	OK	OK	1	OK	Call Center	Softex/Softex	14-Apr-24
<b>Building A 7 Ball Room</b>										
<b>FHC-14</b>		OK		OK	OK	1	OK	<b>Loading</b>		
Floor 1	FHC-A7/1	OK	15 P	OK	OK	1	OK	Back Fl 1	Water Mist	13-Apr-24
Floor 1	FHC-A7/2	OK	15 P	OK	OK	1	OK	Front Fl1	Water Mist	13-Apr-24
Floor 2	FHC-A7/3	OK	15 P	OK	OK	1	OK	Front Fl2	Water Mist	13-Apr-24
Floor 2	FHC-A7/4	OK	15 P	OK	OK	1	OK	Back Fl 2	Water Mist	13-Apr-24
Bakery Room			15P						Softex	13-Apr-24
<b>Generator</b>			15 P					Behind A. 7	Softex	13-Apr-24

Building A 8												
Main Storeroom			10. P					Softex	13-Apr-24			
Garbage room area												
Gas Store			15 P					Softex	13-Apr-24			
Chiller plant	FHC-A8/1	OK	10P/15 P	OK	OK	1	OK	Under A 8	Softex/Softex	13-Apr-24		
Floor 1	FHC-A8/2	OK	15 P	OK	OK	1	OK	Uniform	Softex	13-Apr-24		
Floor 2	FHC-A8/3		15 P	OK	OK	1	OK	FI 2	Wet	13-Apr-24		
Floor 2	HR/ FC		15 P					FI 2	ABFFC	13-Apr-24		
Floor 2	Canteen		15 P/15P					FI 2	Softex/Water Mist Type	13-Apr-24		
Building A 9												
Chemical Store			15 P					A9	Softex	13-Apr-24		
FHC-15		OK	10 P/15 P	OK	OK	2+2	OK	A.9	Softex/Softex	13-Apr-24		
FHC-A9/1		OK	10 P/15 P	OK	OK	1	OK	ENG. In	Softex/Softex	13-Apr-24		
Fire pump room			15 P					Fire pump	Halotron	13-Apr-24		
Villa												
FHC-16		OK		OK	OK	1	OK	Villa 1				
FHC-17		OK		OK	OK	1		Villa 3				
FHC-18		OK		OK	OK	1	OK	Villa 9				
Under Villa 2-10		Villa 3,5,7,9 = 10P			Villa 2,4,6,8,10 = 15P					13-Apr-24		
		Fire Extinguisher grand total good condition & total 101 tanks							10P = 19 tanks, 15P = 82 tanks			
		Fire Extinguisher Expired = 1 tanks										
Fireman Team Cabinet												
SCBA (Self Control Breathing Apparatas)			2 Set									
A: Fire Fighting Uniform = 6 PCS			B: Fire Boot = 6 Pcs									
Fire Nozzle ( Small) = 1 pcs			D : Fire Axes = 2 Pcs ( Big)									
Fire Nozzle ( Big) = 2 pcs			E : Fire Axes = 2 Pcs ( Small)									
C: Fire Helmet = 6 Pcs			F : Fire Grove = 6 Pcs									
Building 1.1 - 1.5 Check by: Khun Peeyachat, Supervisor					Under Villa 4 = Halotron, Under Villa 2,3,5,6,7,8,9,10 = Softex							
Others areas and Villa 1-10 Check by : Khun Karom, Supervisor												
Building 1. 6-1. 9 Check by: Khun Peeyachat, Supervisor												

Approved by: Chaowalith Pholla Asst. Chief Security Date: 20 April 2024

**FIRE HOSE CABINET REPORT**

DATE..18.../05 /.2024.... FREQUENCY: <u>1</u> MONTH									
EQUIPMENT LOCATION	HOSE CABINET	FIRE EXTINGUISHER	FIRE HOSE OR HOSE REEL	NOZZLE	HOSE COUPLING	HYDRANT PIPE & VALVES	Place	Type	Cheked Date
<b>Building A 1.1</b>							Room		
FHC-01 Main car park	OK	10.P	OK	OK	1	OK	Car park	Softex	10-May-24
Floor 1 FHC-A1.1/1	OK	15 P	OK	OK	1	OK	116	Softex	10-May-24
Floor 2 FHC-A1.1/2	OK	15 P	OK	OK	1	OK	126	Softex	10-May-24
Floor 3 FHC-A1.1/3	OK	15 P	OK	OK	1	OK	136	Softex	10-May-24
Floor 4 FHC-A1.1/4	OK	15 P	OK	OK	1	OK	146	Softex	10-May-24
<b>Building A 1.2</b>									
FHC-02	OK		OK	OK	1+2	OK	Jungle		10-May-24
Floor 1 FHC-A1.2/1	OK	10. P	OK	OK	1	OK	216	Softex	10-May-24
Floor 2 FHC-A1.2/2	OK	15.P	OK	OK	1	OK	226	Softex	10-May-24
Floor 3 FHC-A1.2/3	OK	15 P	OK	OK	1	OK	236	Softex	10-May-24
Floor 4 FHC-A1.2/4	OK	15 P	OK	OK	1	OK	246	Softex	10-May-24
VIG Changing Room		15 P							
<b>Building A 1.3</b>									
FHC-03	OK		OK	OK	1+2	OK	Jungle		10-May-24
Floor 1 FHC-A1.3/1	OK	10.P	OK	OK	1	OK	311	Softex	10-May-24
Floor 2 FHC-A1.3/2	OK	15 P	OK	OK	1	OK	321	Softex	10-May-24
Floor 3 FHC-A1.3/3	OK	15 P	OK	OK	1	OK	331	Softex	10-May-24
Floor 4 FHC-A1.3/4	OK	15 P	OK	OK	1	OK	341	Softex	10-May-24
<b>Building A 1.4</b>									
FHC-04	OK		OK	OK	2+2	OK	Front M 4		10-May-24
Floor 1 FHC-A1.4/1	OK	15 P	OK	OK	1	OK	416	Softex	10-May-24
Floor 2 FHC-A1.4/2	OK	15 P	OK	OK	1	OK	426	Softex	10-May-24
Floor 3 FHC-A1.4/3	OK	15 P	OK	OK	1	OK	436	Softex	10-May-24
Floor 4 FHC-A1.4/4	OK	15 P	OK	OK	1	OK	446	Softex	10-May-24
<b>Building A 1.5</b>									
FHC-05	OK		OK	OK	1+2	OK	Jungle		10-May-24
Floor 1 FHC-A1.5/1	OK	15 P	OK	OK	1	OK	511	Softex	10-May-24
Floor 2 FHC-A1.5/2	OK	15 P	OK	OK	1	OK	521	Halotron	10-May-24
Floor 3 FHC-A1.5/3	OK	15 P	OK	OK	1	OK	531	Softex	10-May-24
Floor 4 FHC-A1.5/4	OK	15 P	OK	OK	1	OK	541	Softex	10-May-24
<b>Building A 1.6</b>									
FHC-06	OK	15P	OK	OK	2+1	OK	Out 611	Softex	12-May-24
FHC-07	OK	15P	OK	OK	2+1	OK	R617	Softex	12-May-24
Floor 1 FHC-A1.6/1	OK	15 P	OK	OK	1	OK	R615	Softex	12-May-24
Floor 2 FHC-A1.6/2	OK	15 P	OK	OK	1	OK	R625	Softex	12-May-24
Floor 3 FHC-A1.6/3	OK	15 P	OK	OK	1	OK	R635	Softex	12-May-24
Floor 4 FHC-A1.6/4	OK	15 P	OK	OK	1	OK	R645	Softex	12-May-24
<b>Building A 1.7</b>									
FHC-08	OK	10. P	OK	OK	2+2	OK	Out 717	Halotron	12-May-24
Floor 1 FHC-A1.7/1	OK	15 P	OK	OK	1	OK	R714	Softex	12-May-24
Floor 2 FHC-A1.7/2	OK	15 P	OK	OK	1	OK	R724	Softex	12-May-24

Floor 3	FHC-A1.7/3	OK	15 P	OK	OK	1	OK	R734	Softex	12-May-24
Floor 4	FHC-A1.7/4	OK	15 P	OK	OK	1	OK	R744	Softex	12-May-24
<b>Building A 1.8</b>										
Floor 1	FHC-A1.8/1	OK	15 P	OK	OK	1	OK	R816	Softex	12-May-24
Floor 2	FHC-A1.8/2	OK	10. P	OK	OK	1	OK	R826	Halotron	12-May-24
Floor 3	FHC-A1.8/3	OK	15 P	OK	OK	1	OK	R836	Softex	12-May-24
Floor 4	FHC-A1.8/4	OK	15 P	OK	OK	1	OK	R846	Softex	12-May-24
<b>Building A 1.9</b>										
<b>FHC-09</b>		OK	15 P	OK	OK	2+2	OK	<b>Out 914</b>	Softex	12-May-24
<b>FHC-10</b>		OK	15 P	OK	OK	2+2	OK	<b>Out917</b>	Softex	12-May-24
Floor 1	FHC-A1.9/1	OK	15 P	OK	OK	1	OK	R 914	Softex	12-May-24
Floor 2	FHC-A1.9/2	OK	15 P	OK	OK	1	OK	R924	Softex	12-May-24
Floor 3	FHC-A1.9/3	OK	15 P	OK	OK	1	OK	R934	Softex	12-May-24
Floor 4	FHC-A1.9/4	OK	15 P	OK	OK	1	OK	R944	Softex	12-May-24
<b>Building A 2 Lobby Area</b>										
Floor 1	FHC-A2/1	OK	15 P	OK	OK	1	OK	Tour Counter	Softex	7-May-24
Floor 2	FHC-A2/2	OK	15 P/15 P	OK	OK	1	OK	Excom	Softex/Water Mist Type	7-May-24
FO back office			10/15 P						Softex / Softex	7-May-24
Reservation Dept.			15 P						BAFFC	7-May-24
Main Entrance Guardhouse			15 P						Dry	7-May-24
<b>Building A 3</b>										
Floor 1	FHC-A3/1	OK	15 P	OK	OK	1	OK	Mare (IN)	Softex	7-May-24
Floor 1			15P	OK	OK	1	OK	Kitchen	Wet	7-May-24
Floor 1	FHC-13	OK	15P/15P(Foam)	OK	OK	1	OK	Mare (BS)	Wet Chemical / Foam	7-May-24
Floor 2	FHC-A3/2	OK	15P	OK	OK	1	OK	Luna Bar	Softex	7-May-24
<b>Building A 4</b>										
<b>FHC -11</b>		OK	15P	OK	OK	2+2	OK	Gas Store	Softex	7-May-24
<b>FHC-12</b>		OK	15P	OK	OK	2+2	OK	Car park	BF2000	7-May-24
FHC-A4/1		OK	15 P /15P	OK	OK	1	OK	Cove Kitchen	Wet / Wet	7-May-24
FHC-A4/2		OK	15 P	OK	OK	1	OK	Cove in	Softex	7-May-24
Showing kitchen			10 P /15 P						Softex / Softex	7-May-24
<b>Building A 5</b>										
Splash Bar			15P					Splash Bar	Softex	8-May-24
Barefoot Bar								Barefoot		8-May-24
FHC-A5/1		OK	15P	OK	OK	1	OK	Kids Club	Softex	8-May-24
FHC-A5/2		OK	15 P/15P	OK	OK	1	OK	Club lounge	Water Mist/Water Mist Type	8-May-24
<b>Building A 6</b>										
Fitness			15 P					In Fitness	Water Mist Type	8-May-24
Behind Spa			15 P					Behind Spa	Halotron	8-May-24
Floor 1	FHC-A6/1	OK	15 P	OK	OK	1	OK	SPA	Softex	8-May-24
Floor 2	FHC-A6/2	OK	10 P/15 P	OK	OK	1	OK	Call Center	Softex/Softex	8-May-24
<b>Building A 7 Ball Room</b>										
<b>FHC-14</b>		OK		OK	OK	1	OK	<b>Loading</b>		
Floor 1 FHC-A7/1		OK	15 P	OK	OK	1	OK	Back Fl 1	Water Mist	9-May-24
Floor 1 FHC-A7/2		OK	15 P	OK	OK	1	OK	Front Fl1	Water Mist	9-May-24
Floor 2 FHC-A7/3		OK	15 P	OK	OK	1	OK	Front Fl2	Water Mist	9-May-24
Floor 2 FHC-A7/4		OK	15 P	OK	OK	1	OK	Back Fl 2	Water Mist	9-May-24
Bakery Room			15P						Softex	9-May-24
<b>Generator</b>			15 P					Behind A. 7	Softex	9-May-24

Building A 8									
Main Storeroom		10. P						Softex	9-May-24
Garbage room area									
Gas Store		15 P						Softex	9-May-24
Chiller plant FHC-A8/1	OK	10P/15 P	OK	OK	1	OK	Under A 8	Softex/Softex	9-May-24
Floor 1 FHC-A8/2	OK	15 P	OK	OK	1	OK	Uniform	Softex	9-May-24
Floor 2 FHC-A8/3		15 P	OK	OK	1	OK	FI 2	Wet	9-May-24
Floor 2 HR/ FC		15 P					FI 2	ABFFC	9-May-24
Floor 2 Canteen		15 P/15P					FI 2	Softex/Water Mist Type	9-May-24
Building A 9									
Chemical Store		15 P					A9	Softex	17-May-24
FHC-15	OK	10 P/15 P	OK	OK	2+2	OK	A.9	Softex/Softex	17-May-24
FHC-A9/1	OK	10 P/15 P	OK	OK	1	OK	ENG. In	Softex/Softex	17-May-24
Fire pump room		15 P					Fire pump	Halotron	17-May-24
Villa									
FHC-16	OK		OK	OK	1	OK	Villa 1		
FHC-17	OK		OK	OK	1		Villa 3		
FHC-18	OK		OK	OK	1	OK	Villa 9		
Under Villa 2-10	Villa 3,5,7,9 = 10P			Villa 2,4,6,8,10 = 15P					17-May-24
	Fire Extinguisher grand total good condition ti total 101 tanks							10P = 19 tanks, 15P = 82 tanks	
	Fire Extinguisher Expired = 1 tanks								
Fireman Team Cabinet									
SCBA (Self Control Breathing Apparatas)			2 Set						
A: Fire Fighting Uniform = 6 PCS			B: Fire Boot = 6 Pcs						
Fire Nozzle ( Small) = 1 pcs			D : Fire Axes = 2 Pcs ( Big)						
Fire Nozzle ( Big) = 2 pcs			E : Fire Axes = 2 Pcs ( Small)						
C: Fire Helmet = 6 Pcs			F : Fire Grove = 6 Pcs						
Building 1.1 - 1.5 Check by: Khun Peeyachat, Supervisor				Under Villa 4 = Halotron, Under Villa 2,3,5,6,7,8,9,10 = Softex					
Others areas and Villa 1-10 Check by : Khun Karom, Supervisor									
Building 1. 6-1. 9 Check by: Khun Peeyachat, Supervisor									

Approved by: Chaowalith Pholla Asst. Chief Security Date: 18 May 2024

**FIRE HOSE CABINET REPORT**

DATE..18.../06 /.2024.... FREQUENCY: 1 MONTH

EQUIPMENT LOCATION	HOSE CABINET	FIRE EXTINGUISHER	FIRE HOSE OR HOSE REEL	NOZZLE	HOSE COUPLING	HYDRANT PIPE & VALVES	Place	Type	Cheked Date
<b>Building A 1.1</b>							<b>Room</b>		
FHC-01 Main car park	OK	10.P	OK	OK	1	OK	Car park	Softex	7-Jun-24
Floor 1 FHC-A1.1/1	OK	15 P	OK	OK	1	OK	116	Softex	7-Jun-24
Floor 2 FHC-A1.1/2	OK	15 P	OK	OK	1	OK	126	Softex	7-Jun-24
Floor 3 FHC-A1.1/3	OK	15 P	OK	OK	1	OK	136	Softex	7-Jun-24
Floor 4 FHC-A1.1/4	OK	15 P	OK	OK	1	OK	146	Softex	7-Jun-24
<b>Building A 1.2</b>									
FHC-02	OK		OK	OK	1+2	OK	Jungle		7-Jun-24
Floor 1 FHC-A1.2/1	OK	10. P	OK	OK	1	OK	216	Softex	7-Jun-24
Floor 2 FHC-A1.2/2	OK	15.P	OK	OK	1	OK	226	Softex	7-Jun-24
Floor 3 FHC-A1.2/3	OK	15 P	OK	OK	1	OK	236	Softex	7-Jun-24
Floor 4 FHC-A1.2/4	OK	15 P	OK	OK	1	OK	246	Softex	7-Jun-24
VIG Changing Room		15 P							
<b>Building A 1.3</b>									
FHC-03	OK		OK	OK	1+2	OK	Jungle		7-Jun-24
Floor 1 FHC-A1.3/1	OK	10.P	OK	OK	1	OK	311	Softex	7-Jun-24
Floor 2 FHC-A1.3/2	OK	15 P	OK	OK	1	OK	321	Softex	7-Jun-24
Floor 3 FHC-A1.3/3	OK	15 P	OK	OK	1	OK	331	Softex	7-Jun-24
Floor 4 FHC-A1.3/4	OK	15 P	OK	OK	1	OK	341	Softex	7-Jun-24
<b>Building A 1.4</b>									
FHC-04	OK		OK	OK	2+2	OK	Front M 4		8-Jun-24
Floor 1 FHC-A1.4/1	OK	15 P	OK	OK	1	OK	416	Softex	8-Jun-24
Floor 2 FHC-A1.4/2	OK	15 P	OK	OK	1	OK	426	Softex	8-Jun-24
Floor 3 FHC-A1.4/3	OK	15 P	OK	OK	1	OK	436	Softex	8-Jun-24
Floor 4 FHC-A1.4/4	OK	15 P	OK	OK	1	OK	446	Softex	8-Jun-24
<b>Building A 1.5</b>									
FHC-05	OK		OK	OK	1+2	OK	Jungle		8-Jun-24
Floor 1 FHC-A1.5/1	OK	15 P	OK	OK	1	OK	511	Softex	8-Jun-24
Floor 2 FHC-A1.5/2	OK	15 P	OK	OK	1	OK	521	Halotron	8-Jun-24
Floor 3 FHC-A1.5/3	OK	15 P	OK	OK	1	OK	531	Softex	8-Jun-24
Floor 4 FHC-A1.5/4	OK	15 P	OK	OK	1	OK	541	Softex	8-Jun-24
<b>Building A 1.6</b>									
FHC-06	OK	15P	OK	OK	2+1	OK	Out 611	Softex	8-Jun-24
FHC-07	OK	15P	OK	OK	2+1	OK	R617	Softex	8-Jun-24
Floor 1 FHC-A1.6/1	OK	15 P	OK	OK	1	OK	R615	Softex	8-Jun-24
Floor 2 FHC-A1.6/2	OK	15 P	OK	OK	1	OK	R625	Softex	8-Jun-24
Floor 3 FHC-A1.6/3	OK	15 P	OK	OK	1	OK	R635	Softex	8-Jun-24
Floor 4 FHC-A1.6/4	OK	15 P	OK	OK	1	OK	R645	Softex	8-Jun-24
<b>Building A 1.7</b>									
FHC-08	OK	10. P	OK	OK	2+2	OK	Out 717	Halotron	13-Jun-24
Floor 1 FHC-A1.7/1	OK	15 P	OK	OK	1	OK	R714	Softex	13-Jun-24
Floor 2 FHC-A1.7/2	OK	15 P	OK	OK	1	OK	R724	Softex	13-Jun-24



Floor 3	FHC-A1.7/3	OK	15 P	OK	OK	1	OK	R734	Softex	13-Jun-24
Floor 4	FHC-A1.7/4	OK	15 P	OK	OK	1	OK	R744	Softex	13-Jun-24
<b>Building A 1.8</b>										
Floor 1	FHC-A1.8/1	OK	15 P	OK	OK	1	OK	R816	Softex	13-Jun-24
Floor 2	FHC-A1.8/2	OK	10. P	OK	OK	1	OK	R826	Halotron	13-Jun-24
Floor 3	FHC-A1.8/3	OK	15 P	OK	OK	1	OK	R836	Softex	13-Jun-24
Floor 4	FHC-A1.8/4	OK	15 P	OK	OK	1	OK	R846	Softex	13-Jun-24
<b>Building A 1.9</b>										
<b>FHC-09</b>		OK	15 P	OK	OK	2+2	OK	<b>Out 914</b>	Softex	13-Jun-24
<b>FHC-10</b>		OK	15 P	OK	OK	2+2	OK	<b>Out917</b>	Softex	13-Jun-24
Floor 1	FHC-A1.9/1	OK	15 P	OK	OK	1	OK	R 914	Softex	13-Jun-24
Floor 2	FHC-A1.9/2	OK	15 P	OK	OK	1	OK	R924	Softex	13-Jun-24
Floor 3	FHC-A1.9/3	OK	15 P	OK	OK	1	OK	R934	Softex	13-Jun-24
Floor 4	FHC-A1.9/4	OK	15 P	OK	OK	1	OK	R944	Softex	13-Jun-24
<b>Building A 2 Lobby Area</b>										
Floor 1	FHC-A2/1	OK	15 P	OK	OK	1	OK	Tour Counter	Softex	9-Jun-24
Floor 2	FHC-A2/2	OK	15 P/15 P	OK	OK	1	OK	Excom	Softex/Water Mist Type	9-Jun-24
FO back office			10/15 P						Softex / Softex	9-Jun-24
Reservation Dept.			15 P						BAFFC	9-Jun-24
Main Entrance Guardhouse			15 P						Dry	9-Jun-24
<b>Building A 3</b>										
Floor 1	FHC-A3/1	OK	15 P	OK	OK	1	OK	Mare (IN)	Softex	9-Jun-24
Floor 1			15P	OK	OK	1	OK	Kitchen	Wet	9-Jun-24
Floor 1	FHC-13	OK	15P/15P(Foam)	OK	OK	1	OK	Mare (BS)	Wet Chemical / Foam	9-Jun-24
Floor 2	FHC-A3/2	OK	15P	OK	OK	1	OK	Luna Bar	Softex	9-Jun-24
<b>Building A 4</b>										
<b>FHC -11</b>		OK	15P	OK	OK	2+2	OK	Gas Store	Softex	9-Jun-24
<b>FHC-12</b>		OK	15P	OK	OK	2+2	OK	Car park	BF2000	9-Jun-24
FHC-A4/1		OK	15 P /15P	OK	OK	1	OK	Cove Kitchen	Wet / Wet	9-Jun-24
FHC-A4/2		OK	15 P	OK	OK	1	OK	Cove in	Softex	9-Jun-24
Showing kitchen			10 P /15 P						Softex / Softex	9-Jun-24
<b>Building A 5</b>										
Splash Bar			15P					Splash Bar	Softex	9-Jun-24
Barefoot Bar								Barefoot		9-Jun-24
FHC-A5/1		OK	15P	OK	OK	1	OK	Kids Club	Softex	9-Jun-24
FHC-A5/2		OK	15 P/15P	OK	OK	1	OK	Club lounge	Water Mist/Water Mist Type	9-Jun-24
<b>Building A 6</b>										
Fitness			15 P					In Fitness	Water Mist Type	9-Jun-24
Behind Spa			15 P					Behind Spa	Halotron	9-Jun-24
Floor 1	FHC-A6/1	OK	15 P	OK	OK	1	OK	SPA	Softex	9-Jun-24
Floor 2	FHC-A6/2	OK	10 P/15 P	OK	OK	1	OK	Call Center	Softex/Softex	9-Jun-24
<b>Building A 7 Ball Room</b>										
<b>FHC-14</b>		OK		OK	OK	1	OK	<b>Loading</b>		6-Jun-24
Floor 1	FHC-A7/1	OK	15 P	OK	OK	1	OK	Back Fl 1	Water Mist	6-Jun-24
Floor 1	FHC-A7/2	OK	15 P	OK	OK	1	OK	Front Fl1	Water Mist	6-Jun-24
Floor 2	FHC-A7/3	OK	15 P	OK	OK	1	OK	Front Fl2	Water Mist	6-Jun-24
Floor 2	FHC-A7/4	OK	15 P	OK	OK	1	OK	Back Fl 2	Water Mist	6-Jun-24
Bakery Room			15P						Softex	6-Jun-24
<b>Generator</b>			15 P					Behind A. 7	Softex	6-Jun-24

<b>Building A 8</b>									
Main Storeroom		10. P						Softex	10-Jun-24
Garbage room area									
Gas Store		15 P						Softex	10-Jun-24
Chiller plant	FHC-A8/1	OK	10P/15 P	OK	OK	1	OK	Under A 8	Softex/Softex
Floor 1	FHC-A8/2	OK	15 P	OK	OK	1	OK	Uniform	Softex
Floor 2	FHC-A8/3		15 P	OK	OK	1	OK	FI 2	Wet
Floor 2	HR/ FC		15 P					FI 2	ABFFC
Floor 2	Canteen		15 P/15P					FI 2	Softex/Water Mist Type
<b>Building A 9</b>									
Chemical Store			15 P					A9	Softex
FHC-15		OK	10 P/15 P	OK	OK	2+2	OK	A.9	Softex/Softex
FHC-A9/1		OK	10 P/15 P	OK	OK	1	OK	ENG. In	Softex/Softex
Fire pump room			15 P					Fire pump	Halotron
Villa									
FHC-16		OK		OK	OK	1	OK	Villa 1	
FHC-17		OK		OK	OK	1		Villa 3	
FHC-18		OK		OK	OK	1	OK	Villa 9	
Under Villa 2-10	Villa 3,5,7,9 = 10P			Villa 2,4,6,8,10 = 15P					6-Jun-24
	<b>Fire Extinguisher grand total good condition to total 101 tanks</b>							<b>10P = 19 tanks, 15P = 82 tanks</b>	
	<b>Fire Extinguisher Expired = 1 tanks</b>								
<b>Fireman Team Cabinet</b>									
SCBA (Self Control Breathing Apparatas)				<b>2 Set</b>					
<b>A: Fire Fighting Uniform = 6 PCS</b>				<b>B: Fire Boot = 6 Pcs</b>					
Fire Nozzle ( Small) = 1 pcs				<b>D : Fire Axes = 2 Pcs ( Big)</b>					
<b>Fire Nozzle ( Big) = 2 pcs</b>				<b>E : Fire Axes = 2 Pcs ( Small)</b>					
<b>C: Fire Helmet = 6 Pcs</b>				<b>F : Fire Grove = 6 Pcs</b>					
Building 1.1 - 1.5 Check by: Khun Peeyachat, Supervisor					Under Villa 4 = Halotron, Under Villa 2,3,5,6,7,8,9,10 = Softex				
Others areas and Villa 1-10 Check by : Khun Karom, Supervisor									
Building 1. 6-1. 9 Check by: Khun Peeyachat, Supervisor									