

## เอกสารแนบ 4

เอกสารผลการตรวจวัดคุณภาพสิ่งแวดล้อม



## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคารD)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เทาขุ่น มีตะกอน มีกลิ่น  
SAMPLING DATE : JANUARY 31, 2024  
SAMPLING TIME : 10:40  
SAMPLING BY : นายปริญญา กล้าน้อย


REPORT NO. : RN240110175  
SOURCE : WASTEWATER  
RECEIVED DATE : JANUARY 31, 2024  
DATE : JANUARY 31 - FEBRUARY 12, 2024  
REPORT DATE : FEBRUARY 13, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	7.7 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	72.8	-	-
Suspended Solids	mg/l	Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	30.0	-	-
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	50.0	-	-
Grease & Oil	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 × 10 <sup>6</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED.,2017 (AWWA,APHA, WEF)

Remark : 1. - Not available .

2. \* Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)



Scientist



Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*



## ANALYSIS REPORT

CUSTOMER NAME : เดอะไลน์ พหลโยธิน พาร์ค (อาคารD)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลืองขุ่น มีตะกอน มีกลิ่น  
SAMPLING DATE : JANUARY 31, 2024  
SAMPLING TIME : 10:40  
SAMPLING BY : นายปริญญา กล้าน้อย

REPORT NO. : RN240110176  
SOURCE : WASTEWATER  
RECEIVED DATE : JANUARY 31, 2024  
DATE : JANUARY 31 - FEBRUARY 12, 2024  
REPORT DATE : FEBRUARY 13, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	7.2 at 25°C	-	5-9
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	16.5	-	≤20
Suspended Solids	mg/l	Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	27.0	-	≤30
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	9.2	-	≤35
Grease & Oil	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	N.D.	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	1.5 × 10 <sup>5</sup>	-	-


SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED.,2017 (AWWA,APHA, WEF)

Remark : 1. - Not available .

- Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)
- N.D. (Not Detectable) หมายถึง ตรวจไม่พบ



Scientist



Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*



## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคารD)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เตาชุ่น มีตะกอน มีกลิ่น  
SAMPLING DATE : FEBRUARY 14, 2024  
SAMPLING TIME : 13:20  
SAMPLING BY : นายปริญญา กล้าน้อย

REPORT NO. : RN240210321  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : FEBRUARY 14, 2024  
ANALYTICAL DATE : FEBRUARY 14-23, 2024  
REPORT DATE : FEBRUARY 23, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	5.8 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	90.4	-	-
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	425.0	-	-
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	63.0	-	-
Grease & Oil	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	4.4 x 10 <sup>4</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED.,2017 (AWWA,APHA, WEF)

Remark : 1. - Not available .

2. Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)

Scientist

Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*





## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคารD)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลืองใส มีตะกอน มีกลิ่น  
SAMPLING DATE : FEBRUARY 14, 2024  
SAMPLING TIME : 13:20  
SAMPLING BY : นายปริญญา กล้าน้อย

REPORT NO. : RN240110322  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : FEBRUARY 14, 2024  
ANALYTICAL DATE : FEBRUARY 14-23, 2024  
REPORT DATE : FEBRUARY 23, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	8.0 at 25°C	-	5-9
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	19.5	-	≤20
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	15.0	-	≤30
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	7.7	-	≤35
Grease & Oil	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	N.D.	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	1.1 × 10 <sup>4</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED.,2017 (AWWA,APHA, WEF)

Remark : 1. - Not available .

2. Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)
3. N.D. (Not Detectable) หมายถึง ตรวจไม่พบ

Scientist

Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*



## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ตี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เทาขุ่น มีตะกอน มีกลิ่น  
SAMPLING DATE : MARCH 11, 2024  
SAMPLING TIME : 13:10  
SAMPLING BY : นายพีรพล ถวิลหวั่ง

REPORT NO. : RN240310578  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : MARCH 11, 2024  
ANALYTICAL DATE : MARCH 11-21, 2024  
REPORT DATE : MARCH 22, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	5.2 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O <sub>2</sub> G, 5210 B.)	40.2	-	-
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	8,465.0	-	-
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	29.0	-	-
Grease & Oil	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	6.8	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 <sup>6</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED.,2017 (AWWA,APHA, WEF)

Remark : 1. - Not available .

2. Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)

Scientist

Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*



## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลืองใส มีตะกอน มีกลิ่น  
SAMPLING DATE : MARCH 11, 2024  
SAMPLING TIME : 13:10  
SAMPLING BY : นายพีรพล ถวิลหวัง

REPORT NO. : RN240310579  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : MARCH 11, 2024  
ANALYTICAL DATE : MARCH 11-21, 2024  
REPORT DATE : MARCH 22, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	7.2 at 25°C	-	5-9
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	13.0	-	≤20
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	25.0	-	≤30
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	10.0	-	≤35
Grease & Oil	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	N.D.	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	1.6 x 10 <sup>5</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED., 2017 (AWWA, APHA, WEF)

Remark : 1. - Not available .

2. \* Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)

3. N.D. (Not Detectable) หมายถึง ตรวจไม่พบ

Scientist

Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*





## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เทาขุ่น มีตะกอน มีกลิ่น  
SAMPLING DATE : APRIL 17, 2024  
SAMPLING TIME : 14:00  
SAMPLING BY : นายพีรพล ถวิลหวัง

REPORT NO. : RN240410895  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : APRIL 17, 2024  
ANALYTICAL DATE : APRIL 17-29, 2024  
REPORT DATE : APRIL 29, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	6.8 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	61.8	-	-
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	467.0	-	-
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	49.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	5.2	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 <sup>6</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED.,2017 (AWWA,APHA, WEF)

Remark : 1. - Not available .

2. \* Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)



Scientist



Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*





ห้องปฏิบัติการวิเคราะห์เอกชน บริษัท โอกลา เทสติ้ง แอนด์ คอนซัลติง เซอร์วิส จำกัด

63/13 เพชรเกษม ซอย 7 แขวงวัดท่าพระ เขตบางกอกใหญ่ กรุงเทพฯ 10600

โทร: (66)02-868-1246

โทรสาร: (66)02-868-0860

Website: [www.okla-testing.com](http://www.okla-testing.com)

J-NAC Group

## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลืองใส มีตะกอน มีกลิ่น  
SAMPLING DATE : APRIL 17, 2024  
SAMPLING TIME : 14:00  
SAMPLING BY : นายพีรพล ถวิลหวัง

REPORT NO. : RN240410896  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : APRIL 17, 2024  
ANALYTICAL DATE : APRIL 17-29, 2024  
REPORT DATE : APRIL 29, 2024


PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	6.9 at 25°C	-	5-9
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	12.3	-	≤20
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	23.0	-	≤30
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	6.7	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	N.D.	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 <sup>6</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED., 2017 (AWWA, APHA, WEF)


Remark : 1. - Not available .

2. \* Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)

3. N.D. (Not Detectable) หมายถึง ตรวจไม่พบ



Analyst



Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. \*\*\*



## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พลัสโฮม พาร์ค (อาคาร ตี)  
ADDRESS : ถนนพลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เทาขุ่น มีตะกอน มีกลิ่น  
SAMPLING DATE : MAY 22, 2024  
SAMPLING TIME : 11:30  
SAMPLING BY : นายรัชชัย จักรพันธุ์

REPORT NO. : RN240511260  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : MAY 22, 2024  
ANALYTICAL DATE : MAY 22 - JUNE 04, 2024  
REPORT DATE : JUNE 04, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	7.3 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O <sub>2</sub> G, 5210 B.)	54.8	-	-
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	2,470.0	-	-
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	39.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	7.2	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 <sup>6</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED., 2017 (AWWA, APHA, WEF)

Remark : 1. - Not available .

2. Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)

Scientist

Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*

## ANALYSIS REPORT


CUSTOMER NAME	: เดอะ โกลด์ โฮเทลโยธิน พาร์ค (อาคาร ดี)	REPORT NO.	: RN240511261
ADDRESS	: ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900	SAMPLING SOURCE	: WASTEWATER
SAMPLING LOCATION	: บ่อพักน้ำใส	RECEIVED DATE	: MAY 22, 2024
SAMPLING METHOD	: GRAB	ANALYTICAL DATE	: MAY 22 - JUNE 04, 2024
SAMPLING CONDITION	: NORMAL	REPORT DATE	: JUNE 04, 2024
CHARACTERISTICS OF WATER	: เหลืองขุ่น มีตะกอน มีกลิ่น		
SAMPLING DATE	: MAY 22, 2024		
SAMPLING TIME	: 11:30		
SAMPLING BY	: นายรัชชัย จักรพันธุ์		


PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	7.9 at 25°C	-	5-9
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	29.5	-	≤20
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	34.0	-	≤30
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	25.0	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	N.D.	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 × 10 <sup>6</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED., 2017 (AWWA, APHA, WEF)

Remark : 1. - Not available .

2. Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)
3. N.D. (Not Detectable) หมายถึง ตรวจไม่พบ

  
 Scientist

  
 Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.\*\*\*





## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ไฮอิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลืองขุ่น มีตะกอน มีกลิ่น  
SAMPLING DATE : JUNE 12, 2024  
SAMPLING TIME : 12:30  
SAMPLING BY : นายพีรพล ฤวิลหวัง

REPORT NO. : RN240611440  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : JUNE 12, 2024  
ANALYTICAL DATE : JUNE 12-24, 2024  
REPORT DATE : JUNE 24, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	7.4 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O <sub>2</sub> G, 5210 B.)	66.6	-	-
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	2,060.0	-	-
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	41.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	6.8	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 <sup>6</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED., 2017 (AWWA, APHA, WEF)

Remark : 1. - Not available .

2. Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)

Scientist

Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. \*\*\*



## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ตี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลืองใส มีตะกอน มีกลิ่น  
SAMPLING DATE : JUNE 12, 2024  
SAMPLING TIME : 12:30  
SAMPLING BY : นายพีรพล ถวิลหวัง

REPORT NO. : RN240611441  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : JUNE 12, 2024  
ANALYTICAL DATE : JUNE 12-24, 2024  
REPORT DATE : JUNE 24, 2024

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H <sup>+</sup> B.)	7.0 at 25°C	-	5-9
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	28.5	-	≤20
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105 °C (SM: 2540 D.)	24.0	-	≤30
Sulfide as H <sub>2</sub> S	mg/l	Iodometric (SM: 4500-S <sup>2-</sup> F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)	17.0	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	N.D.	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	1.5 x 10 <sup>5</sup>	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 23<sup>rd</sup> ED., 2017 (AWWA, APHA, WEF)

Remark : 1. - Not available .

2. Notification of the Ministry of Natural Resources and Environment, dated November 7, B.E. 2548 (2005), which was published in the Royal Government Gazette, Vol. 122, Part 125D dated December 19, B.E. 2548 (2005) . (Category A)
3. N.D. (Not Detectable) หมายถึง ตรวจไม่พบ

Scientist

Environmental Laboratory Section Manager

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. \*\*\*