

ภาคผนวก จ

---

## Pool Daily Check List

Date	Time	วัดค่าน้ำ		ดูตะกอน		PUMP 1&2					ล้างกรอง		ระดับน้ำ		ไฟไดโอสระ		เดิม	Record by	
		CL	PH	NO	YES	NO	YES	Volt/Amp.			Filter 1.		บ่อพัก	No	YES	No	YES		1 kg
								SR	ST	RT	No	YES							
1/1/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2		✓		✓		✓		Ni	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	Ni	
1/2/2024	6.30	3.0	6.8		✓		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓		Ni	
	22.30	0.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓	✓		✓		✓	✓	Chang	
1/3/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/4/2024	6.30	3.0	7.2	✓	###		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/5/2024	6.30	3.6	7.2		✓		✓	380/7.2	380/7.2	380/7.2	✓	✓		✓		✓	✓	To	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/6/2024	6.30	3.0	6.8				✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	To	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	Chang	
1/7/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.5	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/8/2024	6.30	3.0	6.8		✓		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	Chang	
1/9/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/10/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/11/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/12/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/13/2024	6.30	3.0	6.8		✓		✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	To	
	22.30	1.5	6.8	✓			✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	Chang	
1/14/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/15/2024	6.30	3.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	6.8	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/16/2024	6.30	3.0	7.2		✓		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/17/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/18/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/19/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/20/2024	6.30	3.6	7.2		✓		✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	To	
	22.30	1.5	7.2	✓			✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	Chang	
1/21/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.5	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/22/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/23/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.5	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/24/2024	6.30	3.0	7.2		✓		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/25/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/26/2024	6.30	3.0	7.2		✓		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
	22.30	1.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/27/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
	22.30	1.5	7.2	✓			✓	380/7.2	380/7.2	380/7.2		✓		✓		✓	✓	Chang	
1/28/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.5	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
1/29/2024	6.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	Chang	
	22.30	1.5	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/30/2024	6.30	3.6	7.2		✓		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
	22.30	3.0	7.2	✓			✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
1/31/2024	6.30	3.0	7.2		✓		✓	380/7.2	380/7.2	380/7.2	✓			✓		✓	✓	To	
	22.30							380/	380/	380/									

ผู้ดำเนินการ(Technicain / Senior Technicain )

ลงชื่อ

ผู้ตรวจสอบ(หัวหน้าหน่วย)

ลงชื่อ

ผู้ช่วยผู้จัดการแผนกซ่อมบำรุง / ผู้จัดการแผนกซ่อมบำรุง

ลงชื่อ

Tom

R



# POOL DAILY CHECK LIST

MONTH/YEAR: 1-29/2/24

DATE	04 00								14 00							
	CL (1-3)	PH (7.2- 7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2- 7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1	2.0	7.2	8	/	/	/	/	To	3.0	7.2	8	/	/	/	/	To
2	3.0	7.2	8	/	/	/	/	To	0.2	7.2	10	/	/	/	/	To
3	1.5	7.2	8	/	/	/	/	To	1.5	6.8	10	✓	✓	✓	✓	Ni
4	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	6.8	15	✓	✓	✓	✓	Ni
5	3.0	7.2	8	✓	✓	✓	✓	Ni	0.2	7.8	20	/	/	/	/	To
6	3.0	7.2	10	/	/	/	/	To	0.2	6.8	23	/	/	/	/	To
7	3.0	7.2	10	/	/	/	/	To	0.2	6.8	23	/	/	/	/	To
8	3.0	7.2	8	/	/	/	/	To	1.0	6.8	22	/	/	/	/	Beer
9	1.0	7.2	8	/	/	/	/	Beer	0.2	7.2	20	/	/	/	/	Beer
10	3.0	7.2	10	/	/	/	/	Beer	0.1	7.2	16	/	/	/	/	Beer
11	3.0	7.2	11	/	/	/	/	Beer	0.1	6.8	8	/	/	/	/	To
12	3.0	7.2	10	/	/	/	/	To	0.2	7.2	8	/	/	/	/	To
13	3.0	7.2	8	/	/	/	/	To	0.2	7.2	8	/	/	/	/	To
14	3.0	7.2	8	/	/	/	/	To	0.1	7.2	25	/	/	/	/	Beer
15	3.0	7.2	8	/	/	/	/	Beer	0.1	7.4	8	/	/	/	/	To
16	3.0	7.2	8	/	/	/	/	To	0.1	7.2	20	/	/	/	/	Beer
17	7.5	7.2	10	/	/	/	/	Beer	1.0	7.2	20	/	/	/	/	Beer
18	3.0	7.2	10	/	/	/	/	Beer	0.0	7.8	8	/	/	/	/	To
19	3.0	7.2	10	/	/	/	/	To	0.2	7.8	8	/	/	/	/	To
20	0.6	7.6	8	/	/	/	/	To	0.2	6.8	8	/	/	/	/	To
21	3.0	7.2	8	/	/	/	/	To	0.2	7.2	8	/	/	/	/	To
22	3.0	7.2	8	/	/	/	/	To	0.2	6.8	8	/	/	/	/	To
23	3.0	6.8	8	/	/	/	/	To	0.1	7.2	25	/	/	/	/	Beer
24	3.0	6.8	10	/	/	/	/	Beer	0.2	6.8	23	/	/	/	/	Beer
25	3.0	6.8	10	/	/	/	/	Beer	0.0	6.8	10	/	/	/	/	To
26	3.0	6.8	8	/	/	/	/	To	0.2	6.8	8	/	/	/	/	To
27	3.0	7.2	7.8	/	/	/	/	To	0.2	6.8	8	/	/	/	/	To
28	3.0	7.2	8	/	/	/	/	To	0.0	6.8	8	/	/	/	/	To
29	3.0	7.2	8	/	/	/	/	To	0.0	7.2	8	/	/	/	/	To
30	0.0	7.2	8	/	/	/	/	To								
31																

REMARK: Pool equipment condition

Verified by Chief Engineer

Date

20/2/24

# POOL DAILY CHECK LIST



MONTH/YEAR: 1-31 / 3 / 2024

SUKHUMVIT 11

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1	3.00	7.2	10/10	✓	✓	✓	✓	To	4.0	6.8	18	✓	✓	✓	✓	To
2	3.00	7.2	8/10	✓	✓	✓	✓	To	1.5	6.8	20	✓	✓	✓	✓	Ni
3	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	6.8	20	✓	✓	✓	✓	Ni
4	3.0	7.2	15	✓	✓	✓	✓	Ni	1.0	6.8	18	✓	✓	✓	✓	Ni
5	3.0	7.2	10	✓	✓	✓	✓	Ni	0.2	6.8	10	✓	✓	✓	✓	To
6	3.0	7.2	10	✓	✓	✓	✓	To	0.0	6.8	60	✓	✓	✓	✓	To
7	1.5	6.8	10	✓	✓	✓	✓	To	0.0	7.2	10	✓	✓	✓	✓	To
8	3.0	6.8	10	✓	✓	✓	✓	To	0.0	7.2	25	✓	✓	✓	✓	Beer
9	3.0	6.8	10	✓	✓	✓	✓	Beer	0.0	2.2	25	✓	✓	✓	✓	Beer
10	1.5	6.8	11	✓	✓	✓	✓	Beer	1.0	7.2	20	✓	✓	✓	✓	Ni
11	3.0	7.2	13	✓	✓	✓	✓	Ni	0.0	7.2	20	✓	✓	✓	✓	Ni
12	3.0	7.2	15	✓	✓	✓	✓	Ni	0.0	7.2	23	✓	✓	✓	✓	Beer
13	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	23	✓	✓	✓	✓	Beer
14	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	25	✓	✓	✓	✓	Beer
15	3.0	6.8	11	✓	✓	✓	✓	Beer	0.2	6.8	26	✓	✓	✓	✓	Beer
16	3.0	6.8	10	✓	✓	✓	✓	Beer	0.0	6.8	28	✓	✓	✓	✓	Beer
17	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	25	✓	✓	✓	✓	Ni
18	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
19	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	26	✓	✓	✓	✓	Beer
20	3.0	6.8	11	✓	✓	✓	✓	Beer	0.2	6.8	26	✓	✓	✓	✓	Beer
21	3.0	6.8	10	✓	✓	✓	✓	Beer	0.2	6.8	26	✓	✓	✓	✓	Beer
22	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	25	✓	✓	✓	✓	Beer
23	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	25	✓	✓	✓	✓	Beer
24	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	20	✓	✓	✓	✓	Ni
25	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
26	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	26	✓	✓	✓	✓	Beer
27	1.5	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	26	✓	✓	✓	✓	Beer
28	3.0	6.8	12	✓	✓	✓	✓	Beer	0.0	6.8	26	✓	✓	✓	✓	Beer
29	3.0	6.8	12	✓	✓	✓	✓	Beer	0.0	6.8	26	✓	✓	✓	✓	Beer
30	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	26	✓	✓	✓	✓	Beer
31	3.0	6.8	11	✓	✓	✓	✓	Beer	0.0	6.8	25	✓	✓	✓	✓	Ni

REMARK

Verified by Chief Engineer [Signature]

Date 31/3/24



# POOL DAILY CHECK LIST

MONTH/YEAR: 1-30, 4/2024

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓ / X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓ / X	Record by
1	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
2	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Chang
3	3.0	6.8	10	✓	✓	✓	✓	Chang	1.0	6.8	25	✓	✓	✓	✓	Chang
4	3.0	6.8	15	✓	✓	✓	✓	Chang	0.0	6.8	20	✓	✓	✓	✓	Ni
5	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
6	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	20	✓	✓	✓	✓	Ni
7	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
8	3.0	6.8	10	✓	✓	✓	✓	Ni	1.0	6.8	25	✓	✓	✓	✓	Ni
9	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Chang
10	3.0	6.8	10	✓	✓	✓	✓	Chang	1.0	6.8	25	✓	✓	✓	✓	Chang
11	3.0	6.8	10	✓	✓	✓	✓	Chang	0.0	6.8	20	✓	✓	✓	✓	Ni
12	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
13	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	20	✓	✓	✓	✓	Ni
14	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
15	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
16	3.0	6.8	10	✓	✓	✓	✓	Chang	0.0	6.8	25	✓	✓	✓	✓	Chang
17	3.0	6.8	10	✓	✓	✓	✓	Chang	1.0	6.8	25	✓	✓	✓	✓	Chang
18	3.0	6.8	10	✓	✓	✓	✓	Chang	1.0	6.8	25	✓	✓	✓	✓	Ni
19	3.0	6.8	10	✓	✓	✓	✓	Ni	1.0	6.8	25	✓	✓	✓	✓	Ni
20	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
21	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	20	✓	✓	✓	✓	Ni
22	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Ni
23	1.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Chang
24	3.0	7.2	10	✓	✓	✓	✓	Chang	0.0	7.2	25	✓	✓	✓	✓	Chang
25	3.0	7.2	10	✓	✓	✓	✓	Chang	0.0	6.8	25	✓	✓	✓	✓	Ni
26	3.0	6.8	15	✓	✓	✓	✓	Ni	0.0	6.8	20	✓	✓	✓	✓	Ni
27	3.0	6.8	15	✓	✓	✓	✓	Ni	1.0	6.8	25	✓	✓	✓	✓	Ni
28	3.0	6.8	15	✓	✓	✓	✓	Ni	1.0	6.8	25	✓	✓	✓	✓	Ni
29	3.0	6.8	15	✓	✓	✓	✓	Ni	1.0	6.8	25	✓	✓	✓	✓	Ni
30	3.0	6.8	10	✓	✓	✓	✓	Ni	0.0	6.8	25	✓	✓	✓	✓	Chang
1/5	3.0	6.8	10	✓	✓	✓	✓	Chang								

REMARK: Pool equipment condition

Verified by Chief Engineer

Date

30/4/24

# POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR: 1-31 / 5/2024

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water √/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water √/X	Record by
1	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	25	/	/	/	/	Chang
2	3.0	6.8	10	/	/	/	/	Chang	0.2	6.8	25	/	/	/	/	To
3	3.0	6.8	10	/	/	/	/	To	0.2	6.8	10	/	/	/	/	To
4	3.0	6.8	10	/	/	/	/	To	1.0	6.8	20	/	/	/	/	Chang
5	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	20	/	/	/	/	Chang
6	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	20	/	/	/	/	Chang
7	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	20	/	/	/	/	Chang
8	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	20	/	/	/	/	Chang
9	3.0	6.8	10	/	/	/	/	Chang	0.2	6.8	10	/	/	/	/	To
10	3.0	6.8	10	/	/	/	/	To	0.2	6.8	10	/	/	/	/	To
11	3.0	6.8	10	/	/	/	/	To	0.2	6.8	25	/	/	/	/	Chang
12	3.0	6.8	10	/	/	/	/	Chang	1.5	6.8	25	/	/	/	/	Chang
13	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	25	/	/	/	/	Chang
14	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	20	/	/	/	/	To
15	3.0	6.8	10	/	/	/	/	To	1.5	6.8	20	/	/	/	/	To
16	3.0	6.8	10	/	/	/	/	To	1.5	6.8	10	/	/	/	/	To
17	3.0	6.8	10	/	/	/	/	To	1.8	6.8	10	/	/	/	/	To
18	3.0	6.8	10	/	/	/	/	To	1.0	6.8	10	/	/	/	/	Chang
19	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	20	/	/	/	/	Chang
20	3.0	6.8	10	/	/	/	/	Chang	1.0	6.8	20	/	/	/	/	Chang
21	3.0	6.8	10	/	/	/	/	Chang	0.2	6.8	20	/	/	/	/	Chang
22	3.0	6.8	10	/	/	/	/	Chang	1.5	6.8	20	/	/	/	/	Chang
23	3.0	6.8	10	/	/	/	/	Chang	1.5	7.2	10	/	/	/	/	To
24	3.0	7.2	10	/	/	/	/	To	0.2	7.2	10	/	/	/	/	To
25	3.0	6.8	10	/	/	/	/	To	1.5	6.8	10	/	/	/	/	Chang
26	3.0	6.8	10	/	/	/	/	Chang	0.2	6.8	20	/	/	/	/	Chang
27	3.0	6.8	10	/	/	/	/	Chang	0.2	6.8	25	/	/	/	/	Chang
28	3.0	6.8	10	/	/	/	/	Chang	1.5	6.8	20	/	/	/	/	mon
29	3.0	6.8	10	/	/	/	/	mon	0.2	6.8	25	/	/	/	/	Chang
30	3.0	6.8	10	/	/	/	/	Chang	0.2	6.8	15	/	/	/	/	To
31	3.0	6.8	10	/	/	/	/	To	1.5	7.2	10	/	/	/	/	To

REMARK

Verified by Chief Engineer  Date 31/5/24



# POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR: 1-30 / 6/2024

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1	3.0	7.2	10	✓	✓	✓	✓	To	3.0	7.2	10	✓	✓	✓	✓	Ni
2	3.0	7.2	15	✓	✓	✓	✓	Ni	1.0	7.2	25	✓	✓	✓	✓	Ni
3	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	7.2	15	✓	✓	✓	✓	Ni
4	3.0	7.2	10	✓	✓	✓	✓	Ni	0.2	7.2	10	✓	✓	✓	✓	To
5	3.0	7.2	10	✓	✓	✓	✓	To	6.2	6.8	10	✓	✓	✓	✓	To
6	3.0	6.8	10	✓	✓	✓	✓	To	0.2	6.8	10	✓	✓	✓	✓	To
7	3.0	7.2	10	✓	✓	✓	✓	To	0.2	6.8	10	✓	✓	✓	✓	To
8	3.0	6.8	10	✓	✓	✓	✓	To	0.2	6.8	15	✓	✓	✓	✓	Ni
9	3.0	6.8	10	✓	✓	✓	✓	Ni	0.2	6.8	10	✓	✓	✓	✓	Ni
10	3.0	6.8	10	✓	✓	✓	✓	Ni	0.2	6.8	10	✓	✓	✓	✓	To
11	3.0	6.8	10	✓	✓	✓	✓	To	0.2	6.8	15	✓	✓	✓	✓	To
12	3.0	6.8	15	✓	✓	✓	✓	To	—	—	—	✓	✓	✓	✓	To
13	—	—	—	—	—	—	—	To	—	—	—	✓	✓	✓	✓	To
14	—	—	—	—	—	—	—	To	—	—	—	✓	✓	✓	✓	To
15	—	—	—	—	—	—	—	To	—	—	—	✓	✓	✓	✓	Ni
16	—	—	—	—	—	—	—	Ni	—	—	—	✓	✓	✓	✓	Ni
17	—	—	—	—	—	—	—	Ni	—	—	—	✓	✓	✓	✓	To
18	—	—	—	—	—	—	—	To	—	—	20	✓	✓	✓	✓	To
19	3.0	7.8	15	✓	✓	✓	✓	To	3.0	7.2	28	✓	✓	✓	✓	To
20	3.0	7.8	10	✓	✓	✓	✓	To	3.0	7.2	15	✓	✓	✓	✓	To
21	3.0	7.6	10	✓	✓	✓	✓	To	1.5	7.2	10	✓	✓	✓	✓	To
22	3.0	7.2	10	✓	✓	✓	✓	To	3.0	7.2	10	✓	✓	✓	✓	Ni
23	3.0	7.2	15	✓	✓	✓	✓	Ni	0.2	7.2	20	✓	✓	✓	✓	Ni
24	3.0	7.2	10	✓	✓	✓	✓	Ni	3.0	7.2	18	✓	✓	✓	✓	To
25	3.0	7.6	10	✓	✓	✓	✓	To	1.5	7.2	15	✓	✓	✓	✓	To
26	3.0	7.2	10	✓	✓	✓	✓	To	3.0	7.2	12	✓	✓	✓	✓	To
27	3.0	7.2	10	✓	✓	✓	✓	To	3.0	7.2	15	✓	✓	✓	✓	To
28	1.5	7.2	15	✓	✓	✓	✓	To	3.0	7.2	10	✓	✓	✓	✓	To
29	3.0	7.2	10	✓	✓	✓	✓	To	3.0	7.2	15	✓	✓	✓	✓	Ni
30	3.0	7.2	20	✓	✓	✓	✓	Ni	3.0	7.2	20	✓	✓	✓	✓	Ni
31																

REMARK # วันที่ 13 มีเหตุการน้ำขึ้นสูงได้ปรับระดับน้ำขึ้นขึ้นตามแผนการที่ระบุไว้แล้ว วันที่ 13/6/24

Verified by Chief Engineer

Date

30/6/24