



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/7

Customer/Code	Naithon Beach Company Limited/6N-047	Sampling Date ^[5]	June 21, 2024
Customer Address	28/35 Moo 4, Sakhu Subdistrict, Thalang District, Phuket 83110	Receiving Date	June 24, 2024
Sampling Source ^[5]	Wastewater Treatment Systems	Analyzed Date	June 24 - July 3, 2024
Sampling Method ^[5]	Grab Sample	Report Date	July 3, 2024
Sampling By ^[5]	Miss. Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6706121

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.38 AM
Analysis No.	25672296

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25°C	-	SM : 4500-H ⁺ B	7.0	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	5.7	≤ 40
3. Total Suspended Solids	mg/L	SM : 2540 D	56.0	≤ 50
4. Total Dissolved Solids	mg/L	SM : 2540 C	462	≤ 500 ^[5]
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	7.6	≤ 20
6. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.3	≤ 3.0
7. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	23.1	≤ 40

Physical Appearance Sample 25672296 : Clear liquid, colorless, no sediment Container : Normal PE 2.0 L,G 1.0 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017


[2] : According to Ministerial Regulations No. 51 (1998) issued under the Building Control Act 1979 (Building Type C)

[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250


[4] : Outside the scope of certification, TIS 17025-2561, test number 0548


[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used.

Reported By : 
Miss. Rattiya Khunnaim (๖-250-๖-0005)

Approved By : 
Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Analyst

3/9/67

Laboratory Manager

3/9/67



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกสาร
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/7

Customer/Code	Naithon Beach Company Limited/6N-047	Sampling Date ^[5]	June 21, 2024
Customer Address	28/35 Moo 4, Sakhu Subdistrict, Thalung District, Phuket 83110	Receiving Date	June 24, 2024
Sampling Source ^[5]	Wastewater Treatment Systems	Analyzed Date	June 24 - July 3, 2024
Sampling Method ^[5]	Grab Sample	Report Date	July 3, 2024
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6706121

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.38 AM
Analysis No.	25672296

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	< 0.5
9. Ammonia- Nitrogen ^{[3][4]}	mg/L	SM : 4500-NH ₃ C	18.8	≤ 25.0
10. Organic -Nitrogen ^{[3][4]}	mg/L	SM : 4500-NH ₃ C	4.3	≤ 15.0

Physical Appearance Sample 25672296 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : According to Ministerial Regulations No. 51 (1998) issued under the Building Control Act 1979 (Building Type C)

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2561, test number 0548

[5] : Information received from customers

Reported By :

Miss. Rattiya Khunnaim

Laboratory Analyst

27/7/24

Approved By :

Miss. Saowapa Nukaew

Laboratory Manager

27/7/24

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์น้ำ

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 5/7

Customer/Code	Naithon Beach Company Limited/6N-047	Sampling Date ^[5]	June 21, 2024
Customer Address	28/35 Moo 4, Sakhu Subdistrict, Thalang District, Phuket 83110	Receiving Date	June 24, 2024
Sampling Source ^[5]	Storage Tank	Analyzed Date	June 24 - July 3, 2024
Sampling Method ^[5]	Grab Sample	Report Date	July 3, 2024
Sampling By ^[5]	Miss. Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6706121

Sampling Name ^[5]	Water Supply
Sampling Time ^[5]	10.48 AM
Analysis No.	25672298

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25°C	-	SM : 4500-H ⁺ B	7.1	6.5-8.5

Physical Appearance Sample 25672298 : Clear liquid, colorless, no sediment Container Normal : PE 4.0 L,G 1.0 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017


[2] : Quality of Water Supply Authority. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2561, test number 0548


[5] : Information received from customers

Reported By :


Miss. Rattiya Khunnaim (๖-250-๖-0005)

Laboratory Analyst
๖/๖/๖๖

Aproved By :


Miss. Saowapa Nukacw (๖-250-๖-0002)

Laboratory Manager
๖/๖/๖๖

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 6/7

Customer/Code	Naithon Beach Company Limited/6N-047	Sampling Date ^[5]	June 21, 2024
Customer Address	28/35 Moo 4, Sakhu Subdistrict, Thalang District, Phuket 83110	Receiving Date	June 24, 2024
Sampling Source ^[5]	Storage Tank	Analyzed Date	June 24 - July 3, 2024
Sampling Method ^[5]	Grab Sample	Report Date	July 3, 2024
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6706121

Sampling Name ^[5]	Water Supply
Sampling Time ^[5]	10.48 AM
Analysis No.	25672298

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
2. Turbidity ^{[3][4]}	NTU	SM : 2130 B	0.6	≤ 4.0
3. Non - Carbonate Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2330 A	123	-
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	68.0	≤ 250
5. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.3
6. Color ^{[3][4]}	Pt- Co Unit	SM : 2120 B	2.0	≤ 15
7. Manganese ^{[3][4]}	mg/L	SM : 3500-Mn B	Not Detected	≤ 0.3
8. Nitrate ^{[3][4]}	mg/L NO ₃ -N	SM : 4500-NO ₃ ⁻ E	Not Detected	≤ 50
9. Sulfate ^{[3][4]}	mg/L	SM : 4500-SO ₄ ²⁻ E	24.0	≤ 250
10. Fluoride ^{[3][4]}	mg/L F	SM : 4500-F ⁻ E	0.4	≤ 0.7
11. Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM : 9221 B	< 1.8 ^[6]	Not Detected
12. Fecal Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM : 9221 E	< 1.8 ^[6]	Not Detected

Physical Appearance Sample 25672298 : Clear liquid, colorless, no sediment Container Normal : PE 4.0 L, G 1.0 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.


[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2561, test number 0548

[5] : Information received from customers

[6] : < 1.8 = Not Detected

Reported By :



Miss. Rattiya Khunnaim

Laboratory Analyst

9/7/67

Aproved By :



Miss. Saowapa Nukaew

Laboratory Manager

9/2/67



BC&E

ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 7/7

Customer/Code	Naithon Beach Company Limited/6N-047	Sampling Date ^[5]	June 21, 2024
Customer Address	28/35 Moo 4, Sakhu Subdistrict, Thalang District, Phuket 83110	Receiving Date	June 24, 2024
Sampling Source ^[5]	Storage Tank	Analyzed Date	June 24 - July 3, 2024
Sampling Method ^[5]	Grab Sample	Report Date	July 3, 2024
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6706121

Sampling Name ^[5]	Water Supply
Sampling Time ^[5]	10.48 AM
Analysis No.	25672298

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
13. E.Coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected
14. Standard Plate Count ^{[3][4]}	CFU/mL	SM : 9222 B	Not Detected	-
15. Copper ^{[3][4]}	mg/L Cu	SM : 3111 B	0.1	≤ 2.0
16. Zinc ^{[3][4]}	mg/L Zn	SM : 3111 B	Not Detected	≤ 3.0
17. Total Solids ^{[3][4]}	mg/L	SM : 2540 C	204	-
18. Lead ^{[3][4][7]}	mg/L Pb	SM : 3111 B	0.0002	≤ 0.01
19. Cadmium ^{[3][4][6]}	mg/L Cd	SM : 3111 B	0.0001	≤ 0.003
20. Arsenic ^{[3][4][6]}	mg/L As	SM : 3114 C	Not Detected	≤ 0.01
21. Mercury ^{[3][4][6]}	mg/L Hg	SM : 3112 B	Not Detected	≤ 0.001
22. Selenium ^{[3][4][6]}	mg/L Se	SM : 3114 C	Not Detected	≤ 0.01
23. Cyanide ^{[3][4][6]}	mg/L CN	SM : 4500-CN- C & SM : 4500-CN- E	Not Detected	≤ 0.07

Physical Appearance Sample 25672298 : Clear liquid, colorless, no sediment Container Normal : PE 4.0 L, G 1.0 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.


[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250

[4] : Outside the scope of certification, TIS 17025-2561, test number 0548

[5] : Information received from customers

[7] : Analysis of subcontracting

Reported By :




Miss. Rattiya Khunnaim

Laboratory Analyst

3, 7, 67

Aproved By :



Miss. Saowapa Nukaew

Laboratory Manager

9, 7, 67



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124
PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/7

Customer/Code	Naithon Beach Company Limited/6N-047	Sampling Date ^[5]	June 21, 2024
Customer Address	28/35 Moo 4, Sakhu Subdistrict, Thalang District, Phuket 83110	Receiving Date	June 24, 2024
Sampling Source ^[5]	Storage Tank	Analyzed Date	June 24 - July 3, 2024
Sampling Method ^[5]	Grab Sample	Report Date	July 3, 2024
Sampling By ^[5]	Miss. Yonlatda Thaneerat (7-250-0-0003)	Report No.	PKT6706121

Sampling Name ^[5]	Raw Water
Sampling Time ^[5]	10.45 AM
Analysis No.	25672297

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25°C	-	SM : 4500-H ⁺ B	7.3	6.5-8.5
2. Total Dissolved Solids	mg/L	SM : 2540 C	98.2	≤ 600

Physical Appearance Sample 25672297 : Clear liquid, colorless, no sediment Container Normal : PE 500 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017


[2] : Quality of Water Supply Authority. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250


[4] : Outside the scope of certification, TIS 17025-2561, test number 0548

[5] : Information received from customers


Reported By :


Miss. Rattiya Khunnaim (7-250-0-0005)


Laboratory Analyst



Aproved By :


Miss. Saowapa Nukaew (7-250-0-0002)

Laboratory Manager





ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน 7-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 4/7

Customer/Code	Naithon Beach Company Limited/6N-047	Sampling Date ^[5]	June 21, 2024
Customer Address	28/35 Moo 4, Sakhu Subdistrict, Thalang District, Phuket 83110	Receiving Date	June 24, 2024
Sampling Source ^[5]	Storage Tank	Analyzed Date	June 24 - July 3, 2024
Sampling Method ^[5]	Grab Sample	Report Date	July 3, 2024
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6706121

Sampling Name ^[5]	Raw Water
Sampling Time ^[5]	10.45 AM
Analysis No.	25672297

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Turbidity ^{[3][4]}	NTU	SM : 2130 B	1.8	≤ 4.0
4. Total Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2340 C	100	≤ 300
5. Non - Carbonate Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2330 A	94.0	-
6. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	51.0	≤ 250
7. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	0.1	≤ 0.3
8. Color ^{[3][4]}	Pt- Co Unit	SM : 2120 B	4.0	≤ 15
9. Manganese ^{[3][4]}	mg/L	SM : 3500-Mn B	Not Detected	≤ 0.3
10. Nitrate ^{[3][4]}	mg/L NO ₃ -N	SM : 4500-NO ₃ ⁻ E	Not Detected	≤ 50
11. Sulfate ^{[3][4]}	mg/L	SM : 4500-SO ₄ ²⁻ E	23.0	≤ 250
12. Fluoride ^{[3][4]}	mg/L F	SM : 4500-F ⁻ E	0.2	≤ 0.7

Physical Appearance Sample 25672297 : Clear liquid, colorless, no sediment Container Normal : PE 500 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017


[2] : Quality of Water Supply Authority. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2561, test number 0548

[5] : Information received from customers

Reported By :




Miss. Rattiya Khunnaim

Laboratory Analyst

2, 9, 67

Aproved By :



Miss. Saowapa Nukaew

Laboratory Manager

9, 9, 67



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.