


ภาคผนวกที่ 7

เอกสารรายงานการตรวจสอบคุณภาพสระว่ายน้ำ


ประจำเดือน กรกฎาคม 2567 - ธันวาคม 2567

เอกสารตรวจสอบคุณภาพสระว่ายน้ำประจำเดือน



My Story Ladprao 71

Check Chlorine Swimming Pool



Month : พฤษภาคม 2567 อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	ชัชวาล	
2	1.5	7.2	1.5	7.2	ชัชวาล	
3	1.6	7.2	1.5	7.2	ชัชวาล	
4	1.6	7.2	1.5	7.2	ชัชวาล	
5	1.6	7.2	1.5	7.2	ชัชวาล	
6	1.5	7.2	1.5	7.2	ชัชวาล	
7	3.0	6.8	3.0	6.8	ชัชวาล	
8	3.0	6.8	3.0	6.8	ชัชวาล	
9	3.0	6.8	3.0	6.8	ชัชวาล	
10	1.5	7.2	1.5	7.2	ชัชวาล	
11	1.5	7.2	1.5	7.2	ชัชวาล	
12	1.5	7.2	1.5	7.2	ชัชวาล	
13	1.5	7.2	1.5	7.2	ชัชวาล	
14	1.5	7.2	1.5	7.2	ชัชวาล	
15	0.5	7.8	3.0	7.2	ชัชวาล	
16	3.0	6.8	3.0	6.8	ชัชวาล	
17	3.0	6.8	3.0	6.8	ชัชวาล	
18	3.0	6.8	3.0	6.8	ชัชวาล	
19	3.0	6.8	3.0	6.8	ชัชวาล	
20	3.0	6.8	3.0	6.8	ชัชวาล	
21	1.5	7.2	1.5	7.2	ชัชวาล	
22	1.5	7.2	1.5	7.2	ชัชวาล	
23	1.5	7.2	1.5	7.2	ชัชวาล	
24	1.6	7.2	1.5	7.2	ชัชวาล	
25	1.5	7.2	1.0	7.2	ชัชวาล	
26	1.0	7.2	3.0	7.2	ชัชวาล	
27	3.0	6.8	3.0	6.8	ชัชวาล	
28	3.0	6.8	3.0	6.8	ชัชวาล	
29	3.0	6.8	1.5	6.8	ชัชวาล	
30	1.5	7.2	1.5	7.2	ชัชวาล	
31	1.6	7.2	1.5	7.2	ชัชวาล	

Remark : Spa and Swimming Pool Water Quality
 The pool water quality should have the following range of values:

- a. pH of 7.2 to 7.5
- b. Total alkalinity of 90 to 110ppm
- c. Calcium hardness of 200 to 275ppm
- d. Free residue chlorine of 1.0 to 1.5ppm
- e. Free of Bacteria.
- f. For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : กรกฎาคม 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	คุณพร	
2	1.5	7.2	1.5	7.2	คุณพร	
3	1.5	7.2	1.5	7.2	คุณพร	
4	2.0	6.8	3.0	6.8	คุณพร	
5	3.0	6.8	3.0	6.8	คุณพร	
6	3.0	6.8	3.0	6.8	คุณพร	
7	3.0	6.8	3.0	6.8	คุณพร	
8	3.0	6.8	3.0	6.8	คุณพร	
9	1.5	7.2	1.5	7.2	คุณพร	
10	1.5	7.2	1.5	7.2	คุณพร	
11	1.5	7.2	1.5	7.2	คุณพร	
12	1.5	7.2	1.5	7.2	คุณพร	
13	1.5	7.2	1.5	7.2	คุณพร	
14	3.0	6.8	3.0	6.8	คุณพร	
15	2.0	6.8	3.0	6.8	คุณพร	
16	3.0	6.8	3.0	6.8	คุณพร	
17	3.0	6.8	3.0	6.8	คุณพร	
18	1.5	7.2	1.5	7.2	คุณพร	
19	1.5	7.2	1.5	7.2	คุณพร	
20	1.5	7.2	1.5	7.2	คุณพร	
21	1.5	7.2	1.5	7.2	คุณพร	
22	1.5	7.2	1.5	7.2	คุณพร	
23	1.5	7.2	1.5	7.2	คุณพร	
24	3.0	6.8	3.0	6.8	คุณพร	
25	3.0	6.8	3.0	6.8	คุณพร	
26	3.0	6.8	3.0	6.8	คุณพร	
27	3.0	6.8	3.0	6.8	คุณพร	
28	3.0	6.8	3.0	6.8	คุณพร	
29	3.0	6.8	3.0	6.8	คุณพร	
30	1.5	7.2	1.5	7.2	คุณพร	
31	1.5	7.2	1.5	7.2	คุณพร	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : 25 April 2517

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	✓	
2	1.5	6.8	1.5	6.8	✓	
3	1.0	6.8	1.0	6.8	✓	
4	3.0	7.2	3.0	7.2	✓	
5	3.0	7.2	3.0	7.2	✓	
6	3.0	7.2	3.0	7.2	✓	
7	3.0	7.2	3.0	7.2	✓	
8	3.0	7.2	3.0	7.2	✓	
9	1.5	6.8	1.5	6.8	✓	
10	1.5	6.8	1.5	6.8	✓	
11	1.5	6.8	1.5	6.8	✓	
12	1.0	6.8	1.0	6.8	✓	
13	3.0	6.8	3.0	6.8	✓	
14	3.0	7.2	3.0	7.2	✓	
15	3.0	7.2	3.0	7.2	✓	
16	1.5	7.2	1.5	7.2	✓	
17	1.5	7.2	1.5	7.2	✓	
18	1.5	7.2	1.5	7.2	✓	
19	1.5	6.8	1.5	6.8	✓	
20	3.0	6.8	3.0	6.8	✓	
21	3.0	6.8	3.0	6.8	✓	
22	3.0	6.8	3.0	6.8	✓	
23	1.5	7.2	1.5	7.2	✓	
24	1.5	7.2	1.5	7.2	✓	
25	1.5	7.2	1.5	7.2	✓	
26	1.0	7.2	1.0	7.2	✓	
27	3.0	7.2	3.0	7.2	✓	
28	3.0	6.8	3.0	6.8	✓	
29	3.0	6.8	3.0	6.8	✓	
30	3.0	6.8	3.0	6.8	✓	
31	1.5	6.8	1.5	6.8	✓	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 26°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : สิงหาคม 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	รณกฤษ	
2	3.0	6.8	3.0	6.8	รณกฤษ	
3	3.0	6.8	3.0	6.8	รณกฤษ	
4	3.0	6.8	3.0	6.8	รณกฤษ	
5	3.0	6.8	3.0	6.8	รณกฤษ	
6	1.5	7.2	1.5	7.2	รณกฤษ	
7	1.5	7.2	1.5	7.2	รณกฤษ	
8	1.5	7.2	1.5	7.2	รณกฤษ	
9	1.5	7.2	1.5	7.2	รณกฤษ	
10	3.0	6.8	3.0	6.8	รณกฤษ	
11	3.0	6.8	3.0	6.8	รณกฤษ	
12	3.0	6.8	3.0	6.8	รณกฤษ	
13	3.0	6.8	3.0	6.8	รณกฤษ	
14	3.0	6.8	3.0	6.8	รณกฤษ	
15	1.5	7.2	1.5	7.2	รณกฤษ	
16	1.5	7.2	1.5	7.2	รณกฤษ	
17	1.5	7.2	1.5	7.2	รณกฤษ	
18	1.5	7.2	1.5	7.2	รณกฤษ	
19	3.0	6.8	3.0	6.8	รณกฤษ	
20	3.0	6.8	3.0	6.8	รณกฤษ	
21	3.0	6.8	3.0	6.8	รณกฤษ	
22	3.0	6.8	3.0	6.8	รณกฤษ	
23	3.0	6.8	3.0	6.8	รณกฤษ	
24	1.5	7.2	1.5	7.2	รณกฤษ	
25	1.5	7.2	1.5	7.2	รณกฤษ	
26	1.5	7.2	1.5	7.2	รณกฤษ	
27	3.0	6.8	3.0	6.8	รณกฤษ	
28	3.0	6.8	3.0	6.8	รณกฤษ	
29	3.0	6.8	3.0	6.8	รณกฤษ	
30	3.0	6.8	3.0	6.8	รณกฤษ	
31	3.0	6.8	3.0	6.8	รณกฤษ	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : กันยายน 2567

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	✓	
2	1.5	7.2	1.5	7.2	✓	
3	1.5	7.2	1.5	7.2	✓	
4	1.0	7.2	1.0	7.2	✓	
5	3.0	6.8	3.0	6.8	✓	
6	3.0	6.8	3.0	6.8	✓	
7	3.0	6.8	3.0	6.8	✓	
8	3.0	6.8	3.0	6.8	✓	
9	3.0	6.8	3.0	6.8	✓	
10	3.0	6.8	3.0	6.8	✓	
11	1.5	7.2	1.5	7.2	✓	
12	1.5	7.2	1.5	7.2	✓	
13	1.5	7.2	1.5	7.2	✓	
14	1.5	7.2	1.5	7.2	✓	
15	1.5	7.2	1.5	7.2	✓	
16	1.0	7.2	1.0	7.2	✓	
17	3.0	6.8	3.0	6.8	✓	
18	3.0	6.8	3.0	6.8	✓	
19	3.0	6.8	3.0	6.8	✓	
20	3.0	6.8	3.0	6.8	✓	
21	1.5	6.8	1.5	6.8	✓	
22	1.5	7.2	1.5	7.2	✓	
23	1.5	7.2	1.5	7.2	✓	
24	1.5	7.2	1.5	7.2	✓	
25	1.5	7.2	1.5	7.2	✓	
26	1.5	7.2	1.5	7.2	✓	
27	1.5	7.2	1.5	7.2	✓	
28	1.5	7.2	1.5	7.2	✓	
29	3.0	6.8	3.0	6.8	✓	
30	3.0	6.8	3.0	6.8	✓	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C.



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : กันยายน 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	ประจักษ์	
2	1.5	7.2	1.5	7.2	ประจักษ์	
3	1.5	7.2	1.5	7.2	ประจักษ์	
4	3.0	6.8	3.0	6.8	ประจักษ์	
5	3.0	6.8	3.0	6.8	ประจักษ์	
6	3.0	6.8	3.0	6.8	ประจักษ์	
7	3.0	6.8	3.0	6.8	ประจักษ์	
8	1.5	7.2	3.0	6.8	ประจักษ์	
9	1.5	7.2	1.5	7.2	ประจักษ์	
10	1.5	7.2	1.5	7.2	ประจักษ์	
11	3.0	6.8	1.5	7.2	ประจักษ์	
12	3.0	6.8	3.0	6.8	ประจักษ์	
13	3.0	6.8	3.0	6.8	ประจักษ์	
14	3.0	6.8	3.0	6.8	ประจักษ์	
15	3.0	6.8	3.0	6.8	ประจักษ์	
16	1.5	7.2	1.5	7.2	ประจักษ์	
17	1.5	7.2	1.5	7.2	ประจักษ์	
18	1.5	7.2	1.5	7.2	ประจักษ์	
19	1.5	7.2	3.0	6.8	ประจักษ์	
20	3.0	6.8	3.0	6.8	ประจักษ์	
21	3.0	6.8	3.0	6.8	ประจักษ์	
22	3.0	6.8	3.0	6.8	ประจักษ์	
23	3.0	6.8	1.5	7.2	ประจักษ์	
24	1.5	7.2	1.5	7.2	ประจักษ์	
25	1.5	7.2	1.5	7.2	ประจักษ์	
26	1.5	7.2	1.5	7.2	ประจักษ์	
27	1.5	7.2	3.0	6.8	ประจักษ์	
28	3.0	6.8	3.0	6.8	ประจักษ์	
29	3.0	6.8	3.0	6.8	ประจักษ์	
30	3.0	6.8	3.0	6.8	ประจักษ์	
31	3.0	6.8	3.0	6.8	ประจักษ์	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : ๑๐/๑๒ ๒๕๖๓

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	✓	
2	3.0	6.7	3.0	6.7	✓	
3	3.0	6.7	3.0	6.7	✓	
4	1.5	6.8	1.5	6.7	✓	
5	1.5	7.2	1.5	7.2	✓	
6	1.5	7.2	1.5	7.2	✓	
7	1.5	7.2	1.5	7.2	✓	
8	1.5	7.2	1.5	7.2	✓	
9	1.5	7.2	1.5	7.2	✓	
10	1.0	7.2	1.0	7.2	✓	
11	3.0	6.7	3.0	6.7	✓	
12	3.0	6.8	3.0	6.8	✓	
13	3.0	6.8	3.0	6.8	✓	
14	3.0	6.8	3.0	6.8	✓	
15	3.0	6.8	3.0	6.8	✓	
16	1.5	7.2	1.5	7.2	✓	
17	1.5	7.2	1.5	7.2	✓	
18	1.5	7.2	1.5	7.2	✓	
19	1.5	7.2	1.5	7.2	✓	
20	1.5	7.2	1.5	7.2	✓	
21	1.5	7.2	1.5	7.2	✓	
22	1.5	7.2	1.5	7.2	✓	
23	1.5	7.2	1.5	7.2	✓	
24	1.0	7.2	1.0	7.2	✓	
25	1.0	7.2	1.0	7.2	✓	
26	3.0	6.7	3.0	6.7	✓	
27	3.0	6.8	3.0	6.8	✓	
28	3.0	6.8	3.0	6.8	✓	
29	3.0	6.8	3.0	6.8	✓	
30	3.0	6.7	3.0	6.7	✓	
31	3.0	6.8	3.0	6.8	✓	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : ตุลาคม 2567

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	6.8	3.0	6.8	อ.กมล	
2	3.0	6.8	3.0	6.8	อ.กมล	
3	3.0	6.8	3.0	6.8	อ.กมล	
4	3.0	6.8	3.0	6.8	อ.กมล	
5	3.0	6.8	3.0	6.8	อ.กมล	
6	1.5	7.2	1.5	7.2	อ.กมล	
7	1.5	7.2	1.5	7.2	อ.กมล	
8	1.5	7.2	1.5	7.2	อ.กมล	
9	1.5	7.2	1.5	7.2	อ.กมล	
10	3.0	6.8	3.0	6.8	อ.กมล	
11	3.0	6.8	3.0	7.2	อ.กมล	
12	3.0	6.8	3.0	6.8	อ.กมล	
13	3.0	6.8	3.0	6.8	อ.กมล	
14	1.5	7.2	1.5	7.2	อ.กมล	
15	1.5	7.2	1.5	7.2	อ.กมล	
16	1.5	7.2	1.5	7.2	อ.กมล	
17	1.5	7.2	1.5	7.2	อ.กมล	
18	1.5	7.2	1.5	7.2	อ.กมล	
19	3.0	6.8	3.0	6.8	อ.กมล	
20	3.0	6.8	3.0	6.8	อ.กมล	
21	3.0	6.8	3.0	6.8	อ.กมล	
22	3.0	6.8	3.0	6.8	อ.กมล	
23	3.0	6.8	3.0	6.8	อ.กมล	
24	1.5	7.2	1.5	7.2	อ.กมล	
25	1.5	7.2	1.5	7.2	อ.กมล	
26	1.5	7.2	1.5	7.2	อ.กมล	
27	1.5	7.2	1.5	7.2	อ.กมล	
28	1.5	7.2	1.5	7.2	อ.กมล	
29	3.0	6.8	3.0	6.8	อ.กมล	
30	3.0	6.8	3.0	6.8	อ.กมล	
31	3.0	6.8	3.0	6.8	อ.กมล	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : พฤษภาคม 2567

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	✓	
2	1.5	7.2	1.5	7.2	✓	
3	1.5	7.2	1.5	7.2	✓	
4	1.5	7.2	1.5	7.2	✓	
5	1.5	7.2	1.5	7.2	✓	
6	1.5	7.2	1.5	7.2	✓	
7	1.0	7.2	1.0	7.2	✓	
8	1.0	7.2	1.0	7.2	✓	
9	3.0	6.8	3.0	6.8	✓	
10	3.0	6.8	3.0	6.8	✓	
11	3.0	6.8	3.0	6.8	✓	
12	3.0	6.8	3.0	6.8	✓	
13	3.0	6.8	3.0	6.8	✓	
14	1.5	7.2	1.5	7.2	✓	
15	1.5	7.2	1.5	7.2	✓	
16	1.5	7.2	1.5	7.2	✓	
17	1.5	7.2	1.5	7.2	✓	
18	1.5	7.2	1.5	7.2	✓	
19	1.5	7.2	1.5	7.2	✓	
20	1.5	7.2	1.5	7.2	✓	
21	1.5	7.2	1.5	7.2	✓	
22	1.0	7.2	1.0	7.2	✓	
23	3.0	6.8	3.0	6.8	✓	
24	3.0	6.8	3.0	6.8	✓	
25	3.0	6.8	3.0	6.8	✓	
26	3.0	6.8	3.0	6.8	✓	
27	3.0	6.8	3.0	6.8	✓	
28	3.0	6.8	3.0	6.8	✓	
29	3.0	6.8	3.0	6.8	✓	
30	1.5	7.2	1.5	7.2	✓	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.6
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month :

พฤษภาคม

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	อ.พรพร	
2	1.5	7.2	1.5	7.2	อ.พรพร	
3	3.0	6.8	3.0	6.8	อ.พรพร	
4	3.0	6.8	3.0	6.8	อ.พรพร	
5	3.0	6.8	3.0	6.8	อ.พรพร	
6	3.0	6.8	3.0	6.8	อ.พรพร	
7	1.5	7.2	1.5	7.2	อ.พรพร	
8	1.5	7.2	1.5	7.2	อ.พรพร	
9	1.5	7.2	1.5	7.2	อ.พรพร	
10	3.0	6.4	3.0	6.8	อ.พรพร	
11	3.0	6.8	3.0	6.8	อ.พรพร	
12	3.0	6.8	3.0	6.8	อ.พรพร	
13	3.0	6.8	3.0	6.8	อ.พรพร	
14	3.0	6.4	3.0	6.8	อ.พรพร	
15	1.5	7.2	1.5	7.2	อ.พรพร	
16	1.5	7.2	1.5	7.2	อ.พรพร	
17	1.5	7.2	1.5	7.2	อ.พรพร	
18	1.5	7.2	1.5	7.2	อ.พรพร	
19	3.0	7.2	3.0	6.8	อ.พรพร	
20	3.0	6.8	3.0	6.8	อ.พรพร	
21	3.0	6.8	3.0	6.8	อ.พรพร	
22	3.0	6.8	3.0	6.8	อ.พรพร	
23	1.5	7.2	1.5	7.2	อ.พรพร	
24	1.5	7.2	1.5	7.2	อ.พรพร	
25	1.5	7.2	1.5	7.2	อ.พรพร	
26	1.5	7.2	1.5	7.2	อ.พรพร	
27	3.0	6.8	3.0	6.4	อ.พรพร	
28	3.0	6.8	3.0	6.8	อ.พรพร	
29	3.0	6.8	3.0	6.8	อ.พรพร	
30	3.0	6.8	3.0	6.4	อ.พรพร	
31	3.0	6.8	3.0	6.8	อ.พรพร	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 80 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residual chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : ธันวาคม 2567

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	✓	
2	1.5	7.2	1.5	7.2	✓	
3	1.5	7.2	1.5	7.2	✓	
4	1.5	7.2	1.5	7.2	✓	
5	1.5	7.2	1.5	7.2	✓	
6	1.0	7.2	1.0	7.2	✓	
7	3.0	6.8	3.0	6.8	✓	
8	3.0	6.8	3.0	6.8	✓	
9	3.0	6.8	3.0	6.8	✓	
10	3.0	6.8	3.0	6.8	✓	
11	3.0	6.8	3.0	6.8	✓	
12	3.0	6.8	3.0	6.8	✓	
13	3.0	6.8	3.0	6.8	✓	
14	1.5	7.2	1.5	7.2	✓	
15	1.5	7.2	1.5	7.2	✓	
16	1.5	7.2	1.5	7.2	✓	
17	1.5	7.2	1.5	7.2	✓	
18	1.5	7.2	1.5	7.2	✓	
19	1.5	7.2	1.5	7.2	✓	
20	1.5	7.2	1.5	7.2	✓	
21	1.5	7.2	1.5	7.2	✓	
22	1.0	7.2	1.0	7.2	✓	
23	3.0	6.8	3.0	6.8	✓	
24	3.0	6.8	3.0	6.8	✓	
25	3.0	6.8	3.0	6.8	✓	
26	3.0	6.8	3.0	6.8	✓	
27	1.5	7.2	1.5	7.2	✓	
28	1.5	7.2	1.5	7.2	✓	
29	1.5	7.2	1.5	7.2	✓	
30	1.5	7.2	1.5	7.2	✓	
31	1.5	7.2	1.5	7.2	✓	


Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : ธันวาคม 2564

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	ธนศักดิ์	
2	1.5	7.2	1.5	7.2	ธนศักดิ์	
3	1.5	7.2	1.5	7.2	ธนศักดิ์	
4	1.5	7.2	1.5	7.2	ธนศักดิ์	
5	1.5	7.2	1.5	7.2	ธนศักดิ์	
6	3.0	6.8	3.0	6.8	ธนศักดิ์	
7	3.0	6.8	3.0	6.8	ธนศักดิ์	
8	3.0	6.8	3.0	6.8	ธนศักดิ์	
9	3.0	6.8	3.0	6.8	ธนศักดิ์	
10	3.0	6.8	3.0	6.8	ธนศักดิ์	
11	1.5	7.2	1.5	7.2	ธนศักดิ์	
12	1.5	7.2	1.5	7.2	ธนศักดิ์	
13	1.5	7.2	1.5	7.2	ธนศักดิ์	
14	3.0	6.8	3.0	6.8	ธนศักดิ์	
15	3.0	6.8	3.0	6.8	ธนศักดิ์	
16	3.0	6.8	3.0	6.8	ธนศักดิ์	
17	3.0	6.8	3.0	6.8	ธนศักดิ์	
18	1.5	7.2	1.5	7.2	ธนศักดิ์	
19	1.5	7.2	1.5	7.2	ธนศักดิ์	
20	1.5	7.2	1.5	7.2	ธนศักดิ์	
21	3.0	6.8	3.0	6.8	ธนศักดิ์	
22	3.0	6.8	3.0	6.8	ธนศักดิ์	
23	3.0	6.8	3.0	6.8	ธนศักดิ์	
24	3.0	6.8	3.0	6.8	ธนศักดิ์	
25	3.0	6.8	3.0	6.8	ธนศักดิ์	
26	1.5	7.2	1.5	7.2	ธนศักดิ์	
27	1.5	7.2	1.5	7.2	ธนศักดิ์	
28	1.5	7.2	1.5	7.2	ธนศักดิ์	
29	3.0	6.8	3.0	6.8	ธนศักดิ์	
30	3.0	6.8	3.0	6.8	ธนศักดิ์	
31	3.0	6.8	3.0	6.8	ธนศักดิ์	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C