

DIALY LOG SHEET FIRE PUMP

วันที่	เวลา	DC.Volt#1(13.3V)	DC.Volt#2(13.3V)	AMP # 1	AMP # 2	Enging Speet (RPM)	Fuel Level (Lites) > 700	Pressure(PSI)	Record By	Remark
6 / 7 / 67	15:00	14.8	13.8	1.4	2.4	3000	7.49	179		
11 / 7 / 67	15:00	14.9	13.8	1.4	2.5	3000	7.49	180		
18 / 7 / 67	15:00	14.9	13.8	1.9	2.5	3000	7.48	178		
25 / 7 / 67	15:00	14.8	13.9	1.8	2.5	3000	7.48	178		
1 / 8 / 67	15:00	14.8	13.6	1.4	2.4	3000	7.46	178		
8 / 8 / 67	15:00	14.8	13.6	1.9	2.4	3000	7.46	178		
15 / 8 / 67	15:00	14.8	13.9	1.9	2.6	3000	7.47	179		
22 / 8 / 67	15:00	14.8	13.8	1.9	2.6	3000	7.47	178		
29 / 8 / 67	15:00	14.8	13.8	1.9	2.6	3000	7.46	180		
5 / 9 / 67	15:00	14.8	13.6	1.8	2.4	3000	7.46	179		
12 / 9 / 67	15:00	14.8	13.5	1.8	2.4	3000	7.46	179		
19 / 9 / 67	15:00	14.8	13.7	1.9	2.5	3000	7.46	178		
26 / 9 / 67	15:00	14.8	13.8	1.9	2.5	3000	7.45	178		
3 / 10 / 67	15:00	14.8	13.8	1.8	2.6	3000	7.45	178		
10 / 10 / 67	15:00	14.8	13.6	1.8	2.6	3000	7.45	179		
17 / 10 / 67	15:00	14.8	13.6	1.8	2.6	3000	7.45	179		
24 / 10 / 67	15:00	14.8	13.5	1.8	2.4	3000	7.44	179		

DIALY LOG SHEET FIRE PUMP

[illegible]

01038

[illegible]

20 Aug 12

DIALY LOG SHEET GENERATOR ENGINE MODEL																			
Date	Unit	Test	freq (Hz)	vol (N-L-L-L)			Ampere			Load (kW)	Oil KPA	Water Temp (Coolant)	Inlet Temp	D.C Volt	Engine Speed (RPM)	Fuel Level (Litres)	Customer (Hour)	record by	Remark
				A-B	B-C	C-A	A	B	C										
02/08/67	17:10	/	50	399	399	399	-	-	-	633	35	35	27.7	1500	1710	49/21m			
04/08/67	17:10	/	50	399	399	399				615	43	35	28.0	1300	1700	49/21m			
16/08/67	17:10		50	399	399	399				627	42	46	28	1300	1708	49/21m			
23/08/67	17:10		50	399	399	399	-	-	-	615	43	45	28.0	1300	1707	49/21m			
30/08/67	17:10		50	399	399	399				627	40	48	28.0	1300	1706	50/11m			

217-5

[illegible]

DIALECT LOAN SHEET GENERATOR ENGINE MODEL

[illegible]

[illegible][illegible]