

ภาคผนวก ข.5

ข้อมูลด้าน CEMs ของโครงการ

ภาคผนวก ข.5.1

ผลการตรวจวัด NO_x และ O_2 ด้วย CEMs ระหว่างเดือนกรกฎาคม ถึงธันวาคม พ.ศ.2567

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/07/2024 00:00 | 30.61 | 0 | 93.03 | 1.7 | 35.6 | |
| 01/07/2024 01:00 | 30.64 | 0 | 92.95 | 1.7 | 35.3 | |
| 01/07/2024 02:00 | 30.64 | 0 | 93.05 | 1.7 | 35 | |
| 01/07/2024 03:00 | 30.65 | 0 | 92.99 | 1.7 | 35.1 | |
| 01/07/2024 04:00 | 30.64 | 0 | 92.97 | 1.7 | 35.1 | |
| 01/07/2024 05:00 | 30.67 | 0 | 92.97 | 1.7 | 34.8 | |
| 01/07/2024 06:00 | 30.68 | 0.4 | 93.13 | 1.7 | 34.5 | |
| 01/07/2024 07:00 | 31.04 | 0 | 93.41 | 1.7 | 32.7 | |
| 01/07/2024 08:00 | 43.96 | 0 | 100.38 | 1.7 | 27 | |
| 01/07/2024 09:00 | 34.04 | 0 | 95.65 | 1.7 | 23.4 | |
| 01/07/2024 10:00 | 34.16 | 0 | 94.96 | 1.7 | 23.4 | |
| 01/07/2024 11:00 | 34.32 | 0 | 95.33 | 1.7 | 23.5 | |
| 01/07/2024 12:00 | 22.4 | 0 | 92.62 | 1.8 | 47.4 | |
| 01/07/2024 13:00 | 34.57 | 0 | 94.88 | 1.7 | 25 | |
| 01/07/2024 14:00 | 34.54 | 0 | 95.33 | 1.6 | 23.6 | |
| 01/07/2024 15:00 | 34.57 | 0 | 95 | 1.6 | 23.5 | |
| 01/07/2024 16:00 | 34.49 | 0 | 94.82 | 1.6 | 23.4 | |
| 01/07/2024 17:00 | 34.36 | 0 | 94.43 | 1.6 | 23.6 | |
| 01/07/2024 18:00 | 34.21 | 0 | 94.4 | 1.6 | 23.3 | |
| 01/07/2024 19:00 | 34.07 | 0 | 94.31 | 1.5 | 23.3 | |
| 01/07/2024 20:00 | 34.19 | 0 | 94.31 | 1.5 | 23.2 | |
| 01/07/2024 21:00 | 34.34 | 0 | 94.63 | 1.5 | 23 | |
| 01/07/2024 22:00 | 34.32 | 0 | 94.73 | 1.5 | 23 | |
| 01/07/2024 23:00 | 34.28 | 0 | 94.68 | 1.5 | 23.1 | |
| 02/07/2024 00:00 | 8.31 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 8.31 | 0 | 92.62 | 1.5 | 23 | |
| MinDate | 02/07/2024 00:00 | 01/07/2024 00:00 | 01/07/2024 12:00 | 01/07/2024 19:00 | 01/07/2024 21:00 | |
| Maximum | 43.96 | 0.4 | 100.38 | 1.8 | 47.4 | |
| MaxDate | 01/07/2024 08:00 | 01/07/2024 06:00 | 01/07/2024 08:00 | 01/07/2024 12:00 | 01/07/2024 12:00 | |
| Avg | 32.03 | 0.02 | 94.37 | 1.6 | 28.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.1 | 0.1 | 1.6 | 0.1 | 6.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | | |
| 01/07/2024 00:00 | 30.55 | 0.08 | 93.06 | 0 | 30.7 | |
| 01/07/2024 01:00 | 30.58 | 0.03 | 92.98 | 0 | 30.4 | |
| 01/07/2024 02:00 | 30.58 | 0.06 | 93.11 | 0 | 30.2 | |
| 01/07/2024 03:00 | 30.59 | 0.08 | 93.06 | 0 | 30.1 | |
| 01/07/2024 04:00 | 30.57 | 0.04 | 93.04 | 0 | 30.1 | |
| 01/07/2024 05:00 | 30.61 | 0.04 | 92.99 | 0 | 30.1 | |
| 01/07/2024 06:00 | 30.61 | 0.08 | 93.2 | 0 | 29.9 | |
| 01/07/2024 07:00 | 30.98 | 0.17 | 93.41 | 0 | 28.2 | |
| 01/07/2024 08:00 | 43.91 | 0.24 | 100.38 | 0 | 25.8 | |
| 01/07/2024 09:00 | 33.97 | 0.3 | 95.45 | 0 | 18.5 | |
| 01/07/2024 10:00 | 34.09 | 0.29 | 94.88 | 0 | 18.6 | |
| 01/07/2024 11:00 | 34.27 | 0.29 | 95.27 | 0 | 18.6 | |
| 01/07/2024 12:00 | 22.36 | 0.29 | 92.62 | 0 | 44.8 | |
| 01/07/2024 13:00 | 34.46 | 0.27 | 94.96 | 0 | 20.4 | |
| 01/07/2024 14:00 | 34.47 | 0.26 | 95.33 | 0 | 18.9 | |
| 01/07/2024 15:00 | 34.5 | 0.24 | 95.17 | 0 | 18.8 | |
| 01/07/2024 16:00 | 34.42 | 0.22 | 94.99 | 0 | 18.6 | |
| 01/07/2024 17:00 | 34.3 | 0.2 | 94.55 | 0 | 18.7 | |
| 01/07/2024 18:00 | 34.14 | 0.45 | 94.65 | 0 | 18.3 | |
| 01/07/2024 19:00 | 34 | 0.05 | 94.6 | 0 | 18.2 | |
| 01/07/2024 20:00 | 34.12 | 0.03 | 94.57 | 0 | 18.1 | |
| 01/07/2024 21:00 | 34.28 | 0 | 94.77 | 0 | 18 | |
| 01/07/2024 22:00 | 34.26 | 0 | 94.84 | 0 | 17.9 | |
| 01/07/2024 23:00 | 34.22 | 0 | 94.83 | 0 | 17.9 | |
| 02/07/2024 00:00 | 39.98 | 0.01 | 95.65 | 0 | 34.9 | |
| Minimum | 22.36 | 0 | 92.62 | 0 | 17.9 | |
| MinDate | 01/07/2024 12:00 | 01/07/2024 21:00 | 01/07/2024 12:00 | 01/07/2024 00:00 | 01/07/2024 22:00 | |
| Maximum | 43.91 | 0.45 | 100.38 | 0 | 44.8 | |
| MaxDate | 01/07/2024 08:00 | 01/07/2024 18:00 | 01/07/2024 08:00 | 01/07/2024 00:00 | 01/07/2024 12:00 | |
| Avg | 33.23 | 0.15 | 94.49 | 0 | 24.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 3.8 | 0.1 | 1.6 | 0 | 7.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/07/2024 00:00 | 8.31 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 02:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 03:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 04:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 06:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 07:00 | 13.5 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/07/2024 08:00 | 34.47 | 0 | 95.22 | 1.7 | 30.7 | |
| 02/07/2024 09:00 | 34.56 | 0 | 95.59 | 1.7 | 29.8 | |
| 02/07/2024 10:00 | 34.58 | 0 | 95.75 | 1.7 | 30 | |
| 02/07/2024 11:00 | 34.52 | 0 | 96.11 | 1.7 | 30.4 | |
| 02/07/2024 12:00 | 22.49 | 0.16 | 93.85 | 1.9 | 53.6 | |
| 02/07/2024 13:00 | 34.66 | 0.04 | 95.29 | 1.7 | 32.4 | |
| 02/07/2024 14:00 | 34.57 | 0 | 95.61 | 1.7 | 30.4 | |
| 02/07/2024 15:00 | 34.59 | 0 | 95.45 | 1.7 | 30.6 | |
| 02/07/2024 16:00 | 34.52 | 0 | 95.27 | 1.7 | 30.7 | |
| 02/07/2024 17:00 | 34.42 | 0 | 95.12 | 1.6 | 30.6 | |
| 02/07/2024 18:00 | 34.33 | 0 | 94.77 | 1.6 | 30.6 | |
| 02/07/2024 19:00 | 34.16 | 0 | 94.39 | 1.6 | 30 | |
| 02/07/2024 20:00 | 34.21 | 0 | 94.52 | 1.6 | 29.5 | |
| 02/07/2024 21:00 | 34.37 | 0 | 94.96 | 1.6 | 29.2 | |
| 02/07/2024 22:00 | 34.47 | 0 | 95.16 | 1.6 | 29.1 | |
| 02/07/2024 23:00 | 34.39 | 0 | 94.97 | 1.6 | 28.9 | |
| 03/07/2024 00:00 | 40.74 | 0 | 95.13 | 1.6 | 43.3 | |
| Minimum | 0 | 0 | 93.85 | 1.6 | 28.9 | |
| MinDate | 02/07/2024 01:00 | 02/07/2024 01:00 | 02/07/2024 12:00 | 02/07/2024 17:00 | 02/07/2024 23:00 | |
| Maximum | 40.74 | 0.38 | 96.11 | 1.9 | 53.6 | |
| MaxDate | 03/07/2024 00:00 | 02/07/2024 06:00 | 02/07/2024 11:00 | 02/07/2024 12:00 | 02/07/2024 12:00 | |
| Avg | 24.07 | 0.03 | 95.13 | 1.7 | 32.3 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 0.5 | 0.1 | 6.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/07/2024 00:00 | 39.98 | 0.01 | 95.65 | 0 | 34.9 | |
| 02/07/2024 01:00 | 48.21 | 0 | 95.24 | 0 | 34.9 | |
| 02/07/2024 02:00 | 48.54 | 0.04 | 94.97 | 0 | 35.3 | |
| 02/07/2024 03:00 | 48.99 | 0 | 95.35 | 0 | 35.6 | |
| 02/07/2024 04:00 | 48.95 | 0 | 95.6 | 0 | 35.1 | |
| 02/07/2024 05:00 | 48.91 | 0 | 96.03 | 0 | 35 | |
| 02/07/2024 06:00 | 48.79 | 0 | 95.75 | 0 | 34.5 | |
| 02/07/2024 07:00 | 37.16 | 0.02 | 94.54 | 0 | 33.6 | |
| 02/07/2024 08:00 | 34.38 | 0.08 | 94.68 | 0 | 18.5 | |
| 02/07/2024 09:00 | 34.49 | 0.14 | 95.05 | 0 | 17.5 | |
| 02/07/2024 10:00 | 34.51 | 0.14 | 95.27 | 0 | 17.6 | |
| 02/07/2024 11:00 | 34.47 | 0.21 | 95.53 | 0 | 17.7 | |
| 02/07/2024 12:00 | 22.32 | 0.22 | 93.29 | 0 | 46 | |
| 02/07/2024 13:00 | 34.55 | 0.2 | 94.78 | 0 | 19.6 | |
| 02/07/2024 14:00 | 34.51 | 0.14 | 95.1 | 0 | 17.7 | |
| 02/07/2024 15:00 | 34.52 | 0.08 | 95.09 | 0 | 17.8 | |
| 02/07/2024 16:00 | 34.46 | 0.09 | 95.02 | 0 | 17.8 | |
| 02/07/2024 17:00 | 34.35 | 0.09 | 94.92 | 0 | 17.8 | |
| 02/07/2024 18:00 | 34.27 | 0.31 | 94.62 | 0 | 17.9 | |
| 02/07/2024 19:00 | 34.1 | 0.02 | 94.26 | 0 | 17.5 | |
| 02/07/2024 20:00 | 34.14 | 0 | 94.39 | 0 | 17.3 | |
| 02/07/2024 21:00 | 34.31 | 0 | 94.48 | 0 | 17.2 | |
| 02/07/2024 22:00 | 34.41 | 0 | 94.65 | 0 | 17.3 | |
| 02/07/2024 23:00 | 34.32 | 0 | 94.43 | 0 | 17.2 | |
| 03/07/2024 00:00 | 7.78 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.78 | 0 | 93.29 | 0 | 17.2 | |
| MinDate | 03/07/2024 00:00 | 02/07/2024 01:00 | 02/07/2024 12:00 | 02/07/2024 00:00 | 02/07/2024 21:00 | |
| Maximum | 48.99 | 0.31 | 96.03 | 0 | 46 | |
| MaxDate | 02/07/2024 03:00 | 02/07/2024 18:00 | 02/07/2024 05:00 | 02/07/2024 00:00 | 02/07/2024 12:00 | |
| Avg | 36.62 | 0.07 | 94.95 | 0 | 24.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.6 | 0 | 9.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/07/2024 00:00 | 40.74 | 0 | 95.13 | 1.6 | 43.3 | |
| 03/07/2024 01:00 | 48.96 | 0 | 95.38 | 1.6 | 40.8 | |
| 03/07/2024 02:00 | 48.9 | 0 | 96.01 | 1.6 | 41.2 | |
| 03/07/2024 03:00 | 48.81 | 0 | 96.2 | 1.7 | 41 | |
| 03/07/2024 04:00 | 48.78 | 0 | 96.12 | 1.7 | 40.6 | |
| 03/07/2024 05:00 | 48.81 | 0 | 96.23 | 1.7 | 40.6 | |
| 03/07/2024 06:00 | 48.78 | 0.28 | 96.28 | 1.7 | 40.2 | |
| 03/07/2024 07:00 | 41.22 | 0 | 96.48 | 1.7 | 39.1 | |
| 03/07/2024 08:00 | 34.03 | 0 | 94.97 | 1.7 | 31.5 | |
| 03/07/2024 09:00 | 34.52 | 0 | 95.42 | 1.7 | 27.6 | |
| 03/07/2024 10:00 | 34.54 | 0 | 95.84 | 1.7 | 27.9 | |
| 03/07/2024 11:00 | 34.47 | 0 | 95.6 | 1.7 | 28 | |
| 03/07/2024 12:00 | 22.11 | 0 | 92.43 | 1.8 | 50.8 | |
| 03/07/2024 13:00 | 34.6 | 0 | 94.51 | 1.7 | 29.4 | |
| 03/07/2024 14:00 | 34.48 | 0 | 95.01 | 1.6 | 26.8 | |
| 03/07/2024 15:00 | 34.55 | 0 | 95.14 | 1.7 | 27.1 | |
| 03/07/2024 16:00 | 34.45 | 0 | 94.74 | 1.7 | 27.3 | |
| 03/07/2024 17:00 | 34.25 | 0 | 94.37 | 1.6 | 26.8 | |
| 03/07/2024 18:00 | 34.24 | 0 | 94.33 | 1.6 | 26.6 | |
| 03/07/2024 19:00 | 34.09 | 0 | 94.05 | 1.6 | 26.5 | |
| 03/07/2024 20:00 | 34.15 | 0 | 94.27 | 1.6 | 26.4 | |
| 03/07/2024 21:00 | 34.32 | 0 | 94.87 | 1.6 | 26.3 | |
| 03/07/2024 22:00 | 34.25 | 0 | 94.86 | 1.6 | 26.2 | |
| 03/07/2024 23:00 | 34.17 | 0 | 94.82 | 1.6 | 26.1 | |
| 04/07/2024 00:00 | 8.33 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| Minimum | 8.33 | 0 | 92.43 | 1.6 | 26.1 | |
| MinDate | 04/07/2024 00:00 | 03/07/2024 00:00 | 03/07/2024 12:00 | 03/07/2024 00:00 | 03/07/2024 23:00 | |
| Maximum | 48.96 | 0.28 | 96.48 | 1.8 | 50.8 | |
| MaxDate | 03/07/2024 01:00 | 03/07/2024 06:00 | 03/07/2024 07:00 | 03/07/2024 12:00 | 03/07/2024 12:00 | |
| Avg | 36.82 | 0.01 | 95.13 | 1.7 | 32.8 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.2 | 0.1 | 0.9 | 0.1 | 7.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/07/2024 00:00 | 7.78 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 07:00 | 9.48 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/07/2024 08:00 | 33.87 | 0 | 95.7 | 0 | 26.8 | |
| 03/07/2024 09:00 | 34.45 | 0 | 95.34 | 0 | 22.8 | |
| 03/07/2024 10:00 | 34.47 | 0.02 | 95.73 | 0 | 23 | |
| 03/07/2024 11:00 | 34.4 | 0.06 | 95.59 | 0 | 23.1 | |
| 03/07/2024 12:00 | 22.08 | 0.08 | 92.58 | 0 | 46.4 | |
| 03/07/2024 13:00 | 34.52 | 0.05 | 94.68 | 0 | 24.2 | |
| 03/07/2024 14:00 | 34.42 | 0 | 94.9 | 0 | 21.7 | |
| 03/07/2024 15:00 | 34.48 | 0 | 95.15 | 0 | 22 | |
| 03/07/2024 16:00 | 34.38 | 0.01 | 94.89 | 0 | 22.2 | |
| 03/07/2024 17:00 | 34.19 | 0 | 94.44 | 0 | 21.6 | |
| 03/07/2024 18:00 | 34.17 | 0.22 | 94.41 | 0 | 21.5 | |
| 03/07/2024 19:00 | 34.02 | 0.04 | 94.17 | 0 | 21.4 | |
| 03/07/2024 20:00 | 34.09 | 0.04 | 94.43 | 0 | 21.4 | |
| 03/07/2024 21:00 | 34.25 | 0.1 | 94.93 | 0 | 21.3 | |
| 03/07/2024 22:00 | 34.18 | 0.16 | 94.89 | 0 | 21.2 | |
| 03/07/2024 23:00 | 34.11 | 0.15 | 94.87 | 0 | 21.1 | |
| 04/07/2024 00:00 | 39.99 | 0.16 | 95.51 | 0 | 39.2 | |
| Minimum | 0 | 0 | 92.58 | 0 | 21.1 | |
| MinDate | 03/07/2024 01:00 | 03/07/2024 00:00 | 03/07/2024 12:00 | 03/07/2024 08:00 | 03/07/2024 23:00 | |
| Maximum | 39.99 | 0.22 | 95.73 | 0 | 46.4 | |
| MaxDate | 04/07/2024 00:00 | 03/07/2024 18:00 | 03/07/2024 10:00 | 03/07/2024 08:00 | 03/07/2024 12:00 | |
| Avg | 23.73 | 0.04 | 94.84 | 0 | 24.8 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 0.7 | 0 | 7.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/07/2024 00:00 | 8.33 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 06:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 07:00 | 11.07 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 04/07/2024 08:00 | 34.23 | 0 | 94.86 | 1.7 | 30.8 | |
| 04/07/2024 09:00 | 34.39 | 0 | 94.79 | 1.7 | 29 | |
| 04/07/2024 10:00 | 34.44 | 0 | 95.11 | 1.7 | 28.8 | |
| 04/07/2024 11:00 | 34.41 | 0 | 95.36 | 1.7 | 29.2 | |
| 04/07/2024 12:00 | 22.03 | 0 | 92.2 | 1.9 | 56.3 | |
| 04/07/2024 13:00 | 34.59 | 0 | 94.42 | 1.7 | 31.3 | |
| 04/07/2024 14:00 | 34.5 | 0 | 94.83 | 1.7 | 29.3 | |
| 04/07/2024 15:00 | 34.37 | 0 | 94.71 | 1.7 | 28.8 | |
| 04/07/2024 16:00 | 34.42 | 0 | 94.84 | 1.7 | 28.5 | |
| 04/07/2024 17:00 | 34.26 | 0 | 94.41 | 1.7 | 28.3 | |
| 04/07/2024 18:00 | 34.13 | 0 | 94.07 | 1.7 | 28 | |
| 04/07/2024 19:00 | 33.97 | 0 | 93.96 | 1.7 | 27.9 | |
| 04/07/2024 20:00 | 34.03 | 0 | 93.95 | 1.7 | 27.7 | |
| 04/07/2024 21:00 | 34.22 | 0 | 94.38 | 1.7 | 27.7 | |
| 04/07/2024 22:00 | 34.2 | 0 | 94.65 | 1.7 | 27.6 | |
| 04/07/2024 23:00 | 34.16 | 0 | 94.6 | 1.7 | 27.4 | |
| 05/07/2024 00:00 | 40.63 | 0 | 95.1 | 1.8 | 42.8 | |
| Minimum | 0 | 0 | 92.2 | 1.7 | 27.4 | |
| MinDate | 04/07/2024 01:00 | 04/07/2024 00:00 | 04/07/2024 12:00 | 04/07/2024 08:00 | 04/07/2024 23:00 | |
| Maximum | 40.63 | 0.21 | 95.36 | 1.9 | 56.3 | |
| MaxDate | 05/07/2024 00:00 | 04/07/2024 06:00 | 04/07/2024 11:00 | 04/07/2024 12:00 | 04/07/2024 12:00 | |
| Avg | 23.86 | 0.01 | 94.48 | 1.7 | 31.1 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0 | 0.7 | 0.1 | 7.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/07/2024 00:00 | 39.99 | 0.16 | 95.51 | 0 | 39.2 | |
| 04/07/2024 01:00 | 48.25 | 0.13 | 94.99 | 0 | 40.7 | |
| 04/07/2024 02:00 | 48.67 | 0.16 | 95.12 | 0 | 42 | |
| 04/07/2024 03:00 | 48.83 | 0.15 | 95.41 | 0 | 42.5 | |
| 04/07/2024 04:00 | 48.66 | 0.19 | 95.58 | 0 | 42 | |
| 04/07/2024 05:00 | 48.6 | 0.24 | 95.6 | 0 | 41.1 | |
| 04/07/2024 06:00 | 48.67 | 0.15 | 95.87 | 0 | 40.8 | |
| 04/07/2024 07:00 | 39.22 | 0.14 | 94.97 | 0 | 38.7 | |
| 04/07/2024 08:00 | 34.2 | 0.19 | 94.26 | 0 | 22.9 | |
| 04/07/2024 09:00 | 34.33 | 0.23 | 94.68 | 0 | 20.9 | |
| 04/07/2024 10:00 | 34.38 | 0.33 | 95 | 0 | 20.8 | |
| 04/07/2024 11:00 | 34.35 | 0.4 | 95.23 | 0 | 21.1 | |
| 04/07/2024 12:00 | 22 | 0.43 | 92.32 | 0 | 49.4 | |
| 04/07/2024 13:00 | 34.53 | 0.32 | 94.35 | 0 | 23.1 | |
| 04/07/2024 14:00 | 34.43 | 0.11 | 94.37 | 0 | 21.1 | |
| 04/07/2024 15:00 | 34.3 | 0.07 | 94.29 | 0 | 20.8 | |
| 04/07/2024 16:00 | 34.35 | 0.09 | 94.49 | 0 | 20.6 | |
| 04/07/2024 17:00 | 34.19 | 0.1 | 94.18 | 0 | 20.4 | |
| 04/07/2024 18:00 | 34.06 | 0.45 | 93.93 | 0 | 20.2 | |
| 04/07/2024 19:00 | 33.9 | 0.06 | 93.84 | 0 | 20.2 | |
| 04/07/2024 20:00 | 33.96 | 0.06 | 93.87 | 0 | 20.1 | |
| 04/07/2024 21:00 | 34.15 | 0.07 | 94.13 | 0 | 20.1 | |
| 04/07/2024 22:00 | 34.13 | 0.09 | 94.39 | 0 | 20 | |
| 04/07/2024 23:00 | 34.1 | 0.11 | 94.32 | 0 | 19.9 | |
| 05/07/2024 00:00 | 8.23 | 0.18 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 8.23 | 0.06 | 92.32 | 0 | 19.9 | |
| MinDate | 05/07/2024 00:00 | 04/07/2024 19:00 | 04/07/2024 12:00 | 04/07/2024 00:00 | 04/07/2024 23:00 | |
| Maximum | 48.83 | 0.45 | 95.87 | 0 | 49.4 | |
| MaxDate | 04/07/2024 03:00 | 04/07/2024 18:00 | 04/07/2024 06:00 | 04/07/2024 00:00 | 04/07/2024 12:00 | |
| Avg | 36.58 | 0.18 | 94.61 | 0 | 28.7 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0 | 10.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/07/2024 00:00 | 40.63 | 0 | 95.1 | 1.8 | 42.8 | |
| 05/07/2024 01:00 | 49.05 | 0.09 | 94.82 | 1.7 | 39.6 | |
| 05/07/2024 02:00 | 49.14 | 0 | 95.75 | 1.7 | 39.7 | |
| 05/07/2024 03:00 | 49.13 | 0 | 96.04 | 1.8 | 39.4 | |
| 05/07/2024 04:00 | 49.06 | 0 | 96.05 | 1.8 | 39 | |
| 05/07/2024 05:00 | 48.98 | 0 | 96.42 | 1.8 | 38.8 | |
| 05/07/2024 06:00 | 49.03 | 0.15 | 96.4 | 1.8 | 38.9 | |
| 05/07/2024 07:00 | 40.8 | 0 | 95.97 | 1.8 | 39.5 | |
| 05/07/2024 08:00 | 33.61 | 0 | 94.39 | 1.8 | 31.1 | |
| 05/07/2024 09:00 | 34.39 | 0 | 94.98 | 1.8 | 26.9 | |
| 05/07/2024 10:00 | 34.5 | 0 | 95.39 | 1.8 | 27.2 | |
| 05/07/2024 11:00 | 34.47 | 0 | 95.53 | 1.8 | 27.3 | |
| 05/07/2024 12:00 | 21.96 | 0 | 92.53 | 1.9 | 54.8 | |
| 05/07/2024 13:00 | 34.66 | 0 | 94.9 | 1.8 | 29 | |
| 05/07/2024 14:00 | 34.58 | 0 | 95.27 | 1.7 | 26.8 | |
| 05/07/2024 15:00 | 34.58 | 0 | 95.26 | 1.7 | 26.6 | |
| 05/07/2024 16:00 | 34.31 | 0 | 94.72 | 1.7 | 26.3 | |
| 05/07/2024 17:00 | 34.15 | 0 | 94.43 | 1.7 | 26.3 | |
| 05/07/2024 18:00 | 34.11 | 0 | 94.36 | 1.7 | 26.1 | |
| 05/07/2024 19:00 | 34.1 | 0 | 94.52 | 1.7 | 25.8 | |
| 05/07/2024 20:00 | 34.14 | 0 | 94.55 | 1.7 | 25.9 | |
| 05/07/2024 21:00 | 34.31 | 0 | 95.02 | 1.7 | 26 | |
| 05/07/2024 22:00 | 37.39 | 0 | 96.01 | 1.7 | 27.5 | |
| 05/07/2024 23:00 | 39.01 | 0 | 97.04 | 1.7 | 28.3 | |
| 06/07/2024 00:00 | 28.49 | 0 | 93.83 | 1.8 | 45.7 | |
| Minimum | 21.96 | 0 | 92.53 | 1.7 | 25.8 | |
| MinDate | 05/07/2024 12:00 | 05/07/2024 00:00 | 05/07/2024 12:00 | 05/07/2024 01:00 | 05/07/2024 19:00 | |
| Maximum | 49.14 | 0.15 | 97.04 | 1.9 | 54.8 | |
| MaxDate | 05/07/2024 02:00 | 05/07/2024 06:00 | 05/07/2024 23:00 | 05/07/2024 12:00 | 05/07/2024 12:00 | |
| Avg | 37.94 | 0.01 | 95.17 | 1.8 | 33 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0 | 1 | 0.1 | 8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/07/2024 00:00 | 8.23 | 0.18 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 01:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 02:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 04:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 05:00 | 0 | 0.14 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 06:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 07:00 | 9.49 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/07/2024 08:00 | 33.53 | 0.21 | 94.9 | 0 | 26.5 | |
| 05/07/2024 09:00 | 34.33 | 0.22 | 94.63 | 0 | 22.3 | |
| 05/07/2024 10:00 | 34.44 | 0.24 | 94.99 | 0 | 22.6 | |
| 05/07/2024 11:00 | 34.4 | 0.38 | 95.16 | 0 | 22.6 | |
| 05/07/2024 12:00 | 21.43 | 0.44 | 92.15 | 0 | 53.7 | |
| 05/07/2024 13:00 | 34.57 | 0.42 | 94.66 | 0 | 24.1 | |
| 05/07/2024 14:00 | 34.52 | 0.37 | 94.8 | 0 | 21.7 | |
| 05/07/2024 15:00 | 34.53 | 0.16 | 94.78 | 0 | 21.5 | |
| 05/07/2024 16:00 | 34.25 | 0.11 | 94.4 | 0 | 21.2 | |
| 05/07/2024 17:00 | 34.09 | 0.06 | 94.11 | 0 | 21.2 | |
| 05/07/2024 18:00 | 34.05 | 0.38 | 94.07 | 0 | 21 | |
| 05/07/2024 19:00 | 34.04 | 0.06 | 94.21 | 0 | 20.8 | |
| 05/07/2024 20:00 | 34.09 | 0.08 | 94.27 | 0 | 20.9 | |
| 05/07/2024 21:00 | 34.24 | 0.12 | 94.64 | 0 | 21 | |
| 05/07/2024 22:00 | 37.34 | 0.23 | 95.5 | 0 | 22.8 | |
| 05/07/2024 23:00 | 38.95 | 0.18 | 96.6 | 0 | 23.7 | |
| 06/07/2024 00:00 | 28.44 | 0.16 | 93.48 | 0 | 39.3 | |
| Minimum | 0 | 0.06 | 92.15 | 0 | 20.8 | |
| MinDate | 05/07/2024 01:00 | 05/07/2024 02:00 | 05/07/2024 12:00 | 05/07/2024 08:00 | 05/07/2024 19:00 | |
| Maximum | 38.95 | 0.44 | 96.6 | 0 | 53.7 | |
| MaxDate | 05/07/2024 23:00 | 05/07/2024 12:00 | 05/07/2024 23:00 | 05/07/2024 08:00 | 05/07/2024 12:00 | |
| Avg | 23.56 | 0.2 | 94.55 | 0 | 25.1 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.4 | 0.1 | 0.9 | 0 | 8.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/07/2024 00:00 | 28.49 | 0 | 93.83 | 1.8 | 45.7 | |
| 06/07/2024 01:00 | 29.46 | 0 | 92.67 | 1.8 | 44.2 | |
| 06/07/2024 02:00 | 31.14 | 0 | 92.87 | 1.8 | 38.7 | |
| 06/07/2024 03:00 | 31.77 | 0 | 93.21 | 1.8 | 36.2 | |
| 06/07/2024 04:00 | 31.73 | 0 | 93.1 | 1.8 | 36 | |
| 06/07/2024 05:00 | 31.59 | 0 | 93.09 | 1.8 | 36.3 | |
| 06/07/2024 06:00 | 31.56 | 0.34 | 93.21 | 1.8 | 36.6 | |
| 06/07/2024 07:00 | 31.49 | 0 | 93.63 | 1.8 | 36 | |
| 06/07/2024 08:00 | 45.52 | 0 | 100.57 | 1.9 | 30.7 | |
| 06/07/2024 09:00 | 45.7 | 0 | 102.79 | 1.9 | 31 | |
| 06/07/2024 10:00 | 45.67 | 0 | 103.01 | 1.9 | 31.7 | |
| 06/07/2024 11:00 | 45.72 | 0 | 102.97 | 1.8 | 32.2 | |
| 06/07/2024 12:00 | 31.74 | 0.01 | 96.57 | 1.8 | 31.5 | |
| 06/07/2024 13:00 | 45.61 | 0 | 100.49 | 1.8 | 34.7 | |
| 06/07/2024 14:00 | 46.65 | 0 | 101.8 | 1.7 | 37.9 | |
| 06/07/2024 15:00 | 45.52 | 0 | 101.75 | 1.8 | 33.4 | |
| 06/07/2024 16:00 | 45.54 | 0 | 101.75 | 1.7 | 32.7 | |
| 06/07/2024 17:00 | 45.57 | 0 | 101.86 | 1.7 | 31.6 | |
| 06/07/2024 18:00 | 45.55 | 0 | 102.01 | 1.7 | 30.5 | |
| 06/07/2024 19:00 | 45.68 | 0 | 102.08 | 1.7 | 29.3 | |
| 06/07/2024 20:00 | 45.73 | 0 | 102.19 | 1.7 | 29 | |
| 06/07/2024 21:00 | 45.82 | 0 | 102.78 | 1.7 | 28.8 | |
| 06/07/2024 22:00 | 45.75 | 0 | 102.84 | 1.7 | 28.6 | |
| 06/07/2024 23:00 | 45.59 | 0 | 102.63 | 1.8 | 28.4 | |
| 07/07/2024 00:00 | 31.56 | 0 | 95.85 | 1.7 | 33.2 | |
| Minimum | 28.49 | 0 | 92.67 | 1.7 | 28.4 | |
| MinDate | 06/07/2024 00:00 | 06/07/2024 00:00 | 06/07/2024 01:00 | 06/07/2024 14:00 | 06/07/2024 23:00 | |
| Maximum | 46.65 | 0.34 | 103.01 | 1.9 | 45.7 | |
| MaxDate | 06/07/2024 14:00 | 06/07/2024 06:00 | 06/07/2024 10:00 | 06/07/2024 08:00 | 06/07/2024 00:00 | |
| Avg | 39.85 | 0.01 | 98.78 | 1.8 | 33.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.4 | 0.1 | 4.3 | 0.1 | 4.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/07/2024 00:00 | 28.44 | 0.16 | 93.48 | 0 | 39.3 | |
| 06/07/2024 01:00 | 29.41 | 0.11 | 92.61 | 0 | 37.6 | |
| 06/07/2024 02:00 | 31.08 | 0.06 | 92.76 | 0 | 33.4 | |
| 06/07/2024 03:00 | 31.71 | 0.06 | 93.11 | 0 | 31.4 | |
| 06/07/2024 04:00 | 31.67 | 0.09 | 93.04 | 0 | 31.1 | |
| 06/07/2024 05:00 | 31.52 | 0.1 | 92.98 | 0 | 31.4 | |
| 06/07/2024 06:00 | 31.49 | 0.11 | 93.19 | 0 | 31.9 | |
| 06/07/2024 07:00 | 31.44 | 0.23 | 93.49 | 0 | 31.5 | |
| 06/07/2024 08:00 | 45.43 | 0.32 | 100.97 | 0 | 30.6 | |
| 06/07/2024 09:00 | 45.63 | 0.36 | 102.88 | 0 | 31.8 | |
| 06/07/2024 10:00 | 45.59 | 0.44 | 102.55 | 0 | 33.4 | |
| 06/07/2024 11:00 | 45.65 | 0.43 | 102.64 | 0 | 34.1 | |
| 06/07/2024 12:00 | 31.69 | 0.42 | 96.18 | 0 | 27.5 | |
| 06/07/2024 13:00 | 45.45 | 0.41 | 100.22 | 0 | 36.3 | |
| 06/07/2024 14:00 | 46.35 | 0.38 | 101.35 | 0 | 40.5 | |
| 06/07/2024 15:00 | 45.46 | 0.36 | 101.52 | 0 | 35.7 | |
| 06/07/2024 16:00 | 45.47 | 0.32 | 101.56 | 0 | 34.5 | |
| 06/07/2024 17:00 | 45.5 | 0.3 | 101.7 | 0 | 33.3 | |
| 06/07/2024 18:00 | 45.48 | 0.4 | 101.86 | 0 | 31.7 | |
| 06/07/2024 19:00 | 45.61 | 0.04 | 102.06 | 0 | 30.1 | |
| 06/07/2024 20:00 | 45.65 | 0 | 102.4 | 0 | 29 | |
| 06/07/2024 21:00 | 45.74 | 0 | 102.73 | 0 | 28.8 | |
| 06/07/2024 22:00 | 45.69 | 0 | 102.78 | 0 | 28.3 | |
| 06/07/2024 23:00 | 45.52 | 0.34 | 102.59 | 0 | 27.9 | |
| 07/07/2024 00:00 | 31.49 | 0.13 | 95.6 | 0 | 28.5 | |
| Minimum | 28.44 | 0 | 92.61 | 0 | 27.5 | |
| MinDate | 06/07/2024 00:00 | 06/07/2024 20:00 | 06/07/2024 01:00 | 06/07/2024 00:00 | 06/07/2024 12:00 | |
| Maximum | 46.35 | 0.44 | 102.88 | 0 | 40.5 | |
| MaxDate | 06/07/2024 14:00 | 06/07/2024 10:00 | 06/07/2024 09:00 | 06/07/2024 00:00 | 06/07/2024 14:00 | |
| Avg | 39.77 | 0.22 | 98.65 | 0 | 32.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0.2 | 4.3 | 0 | 3.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/07/2024 00:00 | 31.56 | 0 | 95.85 | 1.7 | 33.2 | |
| 07/07/2024 01:00 | 31.54 | 0 | 93.68 | 1.7 | 31.8 | |
| 07/07/2024 02:00 | 31.59 | 0 | 93.67 | 1.7 | 31.9 | |
| 07/07/2024 03:00 | 31.47 | 0 | 93.72 | 1.7 | 32.5 | |
| 07/07/2024 04:00 | 31.44 | 0 | 93.67 | 1.7 | 32.3 | |
| 07/07/2024 05:00 | 31.44 | 0 | 93.63 | 1.7 | 32.3 | |
| 07/07/2024 06:00 | 31.39 | 0.28 | 93.67 | 1.7 | 32.3 | |
| 07/07/2024 07:00 | 31.17 | 0 | 94.05 | 1.8 | 34.1 | |
| 07/07/2024 08:00 | 31.02 | 0 | 94.02 | 1.8 | 32.6 | |
| 07/07/2024 09:00 | 31 | 0 | 94.03 | 1.7 | 32.3 | |
| 07/07/2024 10:00 | 30.99 | 0 | 94.15 | 1.7 | 31.7 | |
| 07/07/2024 11:00 | 30.97 | 0 | 94.38 | 1.7 | 31 | |
| 07/07/2024 12:00 | 31.13 | 0 | 94.13 | 1.7 | 29.5 | |
| 07/07/2024 13:00 | 31.04 | 0 | 93.47 | 1.7 | 31 | |
| 07/07/2024 14:00 | 31.13 | 0 | 93.7 | 1.7 | 32.6 | |
| 07/07/2024 15:00 | 31.17 | 0 | 93.52 | 1.7 | 30.6 | |
| 07/07/2024 16:00 | 31.14 | 0 | 93.27 | 1.7 | 30.4 | |
| 07/07/2024 17:00 | 31.09 | 0 | 93.04 | 1.7 | 33.2 | |
| 07/07/2024 18:00 | 44.99 | 0 | 99.7 | 1.7 | 27.5 | |
| 07/07/2024 19:00 | 45.1 | 0 | 101.67 | 1.7 | 27 | |
| 07/07/2024 20:00 | 45.08 | 0 | 101.64 | 1.7 | 27.1 | |
| 07/07/2024 21:00 | 45.1 | 0 | 101.96 | 1.7 | 26.9 | |
| 07/07/2024 22:00 | 45.12 | 0 | 101.98 | 1.7 | 26.5 | |
| 07/07/2024 23:00 | 30.98 | 0 | 95.14 | 1.7 | 32.6 | |
| 08/07/2024 00:00 | 30.94 | 0 | 93.4 | 1.7 | 32.2 | |
| Minimum | 30.94 | 0 | 93.04 | 1.7 | 26.5 | |
| MinDate | 08/07/2024 00:00 | 07/07/2024 00:00 | 07/07/2024 17:00 | 07/07/2024 00:00 | 07/07/2024 22:00 | |
| Maximum | 45.12 | 0.28 | 101.98 | 1.8 | 34.1 | |
| MaxDate | 07/07/2024 22:00 | 07/07/2024 06:00 | 07/07/2024 22:00 | 07/07/2024 07:00 | 07/07/2024 07:00 | |
| Avg | 33.98 | 0.01 | 95.41 | 1.7 | 31 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.7 | 0.1 | 3.1 | 0 | 2.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/07/2024 00:00 | 31.49 | 0.13 | 95.6 | 0 | 28.5 | |
| 07/07/2024 01:00 | 31.49 | 0.15 | 93.6 | 0 | 27.1 | |
| 07/07/2024 02:00 | 31.53 | 0.17 | 93.49 | 0 | 27.2 | |
| 07/07/2024 03:00 | 31.41 | 0.16 | 93.53 | 0 | 27.7 | |
| 07/07/2024 04:00 | 31.38 | 0.19 | 93.47 | 0 | 27.4 | |
| 07/07/2024 05:00 | 31.38 | 0.15 | 93.44 | 0 | 27.3 | |
| 07/07/2024 06:00 | 31.33 | 0.16 | 93.46 | 0 | 27.1 | |
| 07/07/2024 07:00 | 31.11 | 0.24 | 93.8 | 0 | 29.4 | |
| 07/07/2024 08:00 | 30.96 | 0.34 | 93.75 | 0 | 28.5 | |
| 07/07/2024 09:00 | 30.96 | 0.39 | 93.82 | 0 | 28.1 | |
| 07/07/2024 10:00 | 30.93 | 0.38 | 93.99 | 0 | 27.7 | |
| 07/07/2024 11:00 | 30.91 | 0.39 | 94.2 | 0 | 27.1 | |
| 07/07/2024 12:00 | 31.08 | 0.38 | 93.99 | 0 | 25.7 | |
| 07/07/2024 13:00 | 30.99 | 0.27 | 93.38 | 0 | 26.5 | |
| 07/07/2024 14:00 | 31.07 | 0.21 | 93.6 | 0 | 26.2 | |
| 07/07/2024 15:00 | 31.11 | 0.22 | 93.52 | 0 | 26.4 | |
| 07/07/2024 16:00 | 31.09 | 0.13 | 93.31 | 0 | 25.9 | |
| 07/07/2024 17:00 | 31.04 | 0.04 | 93.02 | 0 | 28.5 | |
| 07/07/2024 18:00 | 44.85 | 0.01 | 99.9 | 0 | 27.7 | |
| 07/07/2024 19:00 | 45.03 | 0 | 101.76 | 0 | 27.2 | |
| 07/07/2024 20:00 | 45 | 0 | 101.71 | 0 | 27.2 | |
| 07/07/2024 21:00 | 45.03 | 0 | 101.88 | 0 | 27.1 | |
| 07/07/2024 22:00 | 45.05 | 0 | 101.85 | 0 | 26.5 | |
| 07/07/2024 23:00 | 30.91 | 0.21 | 94.8 | 0 | 29 | |
| 08/07/2024 00:00 | 30.88 | 0.09 | 93.19 | 0 | 28.6 | |
| Minimum | 30.88 | 0 | 93.02 | 0 | 25.7 | |
| MinDate | 08/07/2024 00:00 | 07/07/2024 19:00 | 07/07/2024 17:00 | 07/07/2024 00:00 | 07/07/2024 12:00 | |
| Maximum | 45.05 | 0.39 | 101.88 | 0 | 29.4 | |
| MaxDate | 07/07/2024 22:00 | 07/07/2024 09:00 | 07/07/2024 21:00 | 07/07/2024 00:00 | 07/07/2024 07:00 | |
| Avg | 33.92 | 0.18 | 95.28 | 0 | 27.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.7 | 0.1 | 3.2 | 0 | 1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/07/2024 00:00 | 30.94 | 0 | 93.4 | 1.7 | 32.2 | |
| 08/07/2024 01:00 | 30.93 | 0 | 93.22 | 1.7 | 32.3 | |
| 08/07/2024 02:00 | 30.99 | 0 | 93.2 | 1.7 | 32 | |
| 08/07/2024 03:00 | 30.96 | 0 | 93.3 | 1.7 | 32.1 | |
| 08/07/2024 04:00 | 30.97 | 0 | 93.22 | 1.7 | 32 | |
| 08/07/2024 05:00 | 30.99 | 0 | 93.18 | 1.7 | 31.8 | |
| 08/07/2024 06:00 | 30.98 | 0.21 | 93.34 | 1.7 | 31.9 | |
| 08/07/2024 07:00 | 31.39 | 0 | 93.85 | 1.7 | 30 | |
| 08/07/2024 08:00 | 42.66 | 0 | 99.6 | 1.7 | 27.2 | |
| 08/07/2024 09:00 | 34.4 | 0 | 95.57 | 1.7 | 23.5 | |
| 08/07/2024 10:00 | 34.55 | 0 | 95.24 | 1.7 | 23.3 | |
| 08/07/2024 11:00 | 34.6 | 0 | 95.27 | 1.7 | 23.2 | |
| 08/07/2024 12:00 | 21.94 | 0 | 92.39 | 1.8 | 49.9 | |
| 08/07/2024 13:00 | 34.71 | 0 | 95.05 | 1.7 | 24.6 | |
| 08/07/2024 14:00 | 34.65 | 0 | 95.77 | 1.7 | 23.2 | |
| 08/07/2024 15:00 | 34.66 | 0 | 94.8 | 1.7 | 23.1 | |
| 08/07/2024 16:00 | 34.53 | 0 | 94.87 | 1.7 | 23.3 | |
| 08/07/2024 17:00 | 34.37 | 0 | 94.65 | 1.7 | 23.5 | |
| 08/07/2024 18:00 | 34.35 | 0 | 94.42 | 1.6 | 23.5 | |
| 08/07/2024 19:00 | 34.11 | 0 | 94.23 | 1.6 | 23.3 | |
| 08/07/2024 20:00 | 34.18 | 0 | 94.38 | 1.6 | 23.1 | |
| 08/07/2024 21:00 | 34.35 | 0 | 94.72 | 1.6 | 23 | |
| 08/07/2024 22:00 | 34.41 | 0 | 95 | 1.6 | 23 | |
| 08/07/2024 23:00 | 34.35 | 0 | 95.04 | 1.6 | 22.9 | |
| 09/07/2024 00:00 | 7.89 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.89 | 0 | 92.39 | 1.6 | 22.9 | |
| MinDate | 09/07/2024 00:00 | 08/07/2024 00:00 | 08/07/2024 12:00 | 08/07/2024 18:00 | 08/07/2024 23:00 | |
| Maximum | 42.66 | 0.21 | 99.6 | 1.8 | 49.9 | |
| MaxDate | 08/07/2024 08:00 | 08/07/2024 06:00 | 08/07/2024 08:00 | 08/07/2024 12:00 | 08/07/2024 12:00 | |
| Avg | 32.11 | 0.01 | 94.49 | 1.7 | 27.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.1 | 0 | 1.4 | 0.1 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/07/2024 00:00 | 30.88 | 0.09 | 93.19 | 0 | 28.6 | |
| 08/07/2024 01:00 | 30.87 | 0.1 | 92.99 | 0 | 28.7 | |
| 08/07/2024 02:00 | 30.93 | 0.14 | 92.96 | 0 | 28.4 | |
| 08/07/2024 03:00 | 30.9 | 0.13 | 93.07 | 0 | 28.5 | |
| 08/07/2024 04:00 | 30.91 | 0.17 | 92.99 | 0 | 28.3 | |
| 08/07/2024 05:00 | 30.93 | 0.18 | 92.99 | 0 | 28.1 | |
| 08/07/2024 06:00 | 30.93 | 0.19 | 93.1 | 0 | 28.2 | |
| 08/07/2024 07:00 | 31.34 | 0.23 | 93.55 | 0 | 26.3 | |
| 08/07/2024 08:00 | 42.55 | 0.32 | 99.51 | 0 | 26.7 | |
| 08/07/2024 09:00 | 34.34 | 0.41 | 95.49 | 0 | 19.5 | |
| 08/07/2024 10:00 | 34.49 | 0.4 | 95.15 | 0 | 19.1 | |
| 08/07/2024 11:00 | 34.54 | 0.33 | 95.2 | 0 | 19 | |
| 08/07/2024 12:00 | 21.91 | 0.31 | 92.31 | 0 | 45.4 | |
| 08/07/2024 13:00 | 34.69 | 0.3 | 95.03 | 0 | 20.5 | |
| 08/07/2024 14:00 | 34.59 | 0.32 | 95.52 | 0 | 19 | |
| 08/07/2024 15:00 | 34.6 | 0.38 | 94.83 | 0 | 18.9 | |
| 08/07/2024 16:00 | 34.47 | 0.26 | 94.83 | 0 | 19.2 | |
| 08/07/2024 17:00 | 34.31 | 0.28 | 94.82 | 0 | 19.3 | |
| 08/07/2024 18:00 | 34.28 | 0.28 | 94.6 | 0 | 19.2 | |
| 08/07/2024 19:00 | 34.05 | 0.23 | 94.33 | 0 | 18.9 | |
| 08/07/2024 20:00 | 34.12 | 0.2 | 94.37 | 0 | 18.7 | |
| 08/07/2024 21:00 | 34.29 | 0.18 | 94.56 | 0 | 18.6 | |
| 08/07/2024 22:00 | 34.35 | 0.18 | 94.84 | 0 | 18.6 | |
| 08/07/2024 23:00 | 34.29 | 0.41 | 94.84 | 0 | 18.5 | |
| 09/07/2024 00:00 | 40.22 | 0.09 | 95.69 | 0 | 35.4 | |
| Minimum | 21.91 | 0.09 | 92.31 | 0 | 18.5 | |
| MinDate | 08/07/2024 12:00 | 08/07/2024 00:00 | 08/07/2024 12:00 | 08/07/2024 00:00 | 08/07/2024 23:00 | |
| Maximum | 42.55 | 0.41 | 99.51 | 0 | 45.4 | |
| MaxDate | 08/07/2024 08:00 | 08/07/2024 09:00 | 08/07/2024 08:00 | 08/07/2024 00:00 | 08/07/2024 12:00 | |
| Avg | 33.35 | 0.24 | 94.43 | 0 | 24 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 3.7 | 0.1 | 1.5 | 0 | 6.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/07/2024 00:00 | 7.89 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 06:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 07:00 | 11.25 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/07/2024 08:00 | 33.99 | 0 | 94.88 | 1.7 | 31.4 | |
| 09/07/2024 09:00 | 34.58 | 0 | 95.28 | 1.7 | 29.4 | |
| 09/07/2024 10:00 | 34.61 | 0 | 95.11 | 1.7 | 29.5 | |
| 09/07/2024 11:00 | 34.57 | 0 | 95.28 | 1.7 | 29.3 | |
| 09/07/2024 12:00 | 22.26 | 0 | 92.56 | 1.9 | 51.1 | |
| 09/07/2024 13:00 | 34.73 | 0 | 95 | 1.7 | 31.1 | |
| 09/07/2024 14:00 | 34.74 | 0 | 95.43 | 1.7 | 29.3 | |
| 09/07/2024 15:00 | 34.61 | 0 | 95.31 | 1.7 | 29.3 | |
| 09/07/2024 16:00 | 34.47 | 0 | 95.15 | 1.7 | 29.4 | |
| 09/07/2024 17:00 | 34.35 | 0 | 94.93 | 1.7 | 29 | |
| 09/07/2024 18:00 | 34.31 | 0 | 94.7 | 1.7 | 28.8 | |
| 09/07/2024 19:00 | 34.2 | 0 | 94.49 | 1.6 | 28.4 | |
| 09/07/2024 20:00 | 34.29 | 0 | 94.53 | 1.6 | 28.2 | |
| 09/07/2024 21:00 | 34.42 | 0 | 94.92 | 1.6 | 28.1 | |
| 09/07/2024 22:00 | 34.36 | 0 | 94.96 | 1.6 | 28 | |
| 09/07/2024 23:00 | 34.27 | 0 | 95.17 | 1.6 | 27.9 | |
| 10/07/2024 00:00 | 40.28 | 0 | 95.81 | 1.7 | 41.5 | |
| Minimum | 0 | 0 | 92.56 | 1.6 | 27.9 | |
| MinDate | 09/07/2024 01:00 | 09/07/2024 00:00 | 09/07/2024 12:00 | 09/07/2024 19:00 | 09/07/2024 23:00 | |
| Maximum | 40.28 | 0.15 | 95.81 | 1.9 | 51.1 | |
| MaxDate | 10/07/2024 00:00 | 09/07/2024 06:00 | 10/07/2024 00:00 | 09/07/2024 12:00 | 09/07/2024 12:00 | |
| Avg | 23.93 | 0.01 | 94.91 | 1.7 | 31.2 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0 | 0.7 | 0.1 | 6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/07/2024 00:00 | 40.22 | 0.09 | 95.69 | 0 | 35.4 | |
| 09/07/2024 01:00 | 48.15 | 0.1 | 95.14 | 0 | 34.6 | |
| 09/07/2024 02:00 | 48.36 | 0.1 | 95.12 | 0 | 34.9 | |
| 09/07/2024 03:00 | 48.43 | 0.15 | 95.52 | 0 | 34.7 | |
| 09/07/2024 04:00 | 48.39 | 0.21 | 95.48 | 0 | 34.7 | |
| 09/07/2024 05:00 | 48.36 | 0.25 | 95.47 | 0 | 35 | |
| 09/07/2024 06:00 | 48.36 | 0.26 | 95.94 | 0 | 35 | |
| 09/07/2024 07:00 | 39.57 | 0.26 | 95.11 | 0 | 32 | |
| 09/07/2024 08:00 | 33.87 | 0.21 | 94.81 | 0 | 20.6 | |
| 09/07/2024 09:00 | 34.52 | 0.23 | 95.22 | 0 | 18 | |
| 09/07/2024 10:00 | 34.56 | 0.28 | 95.19 | 0 | 18.1 | |
| 09/07/2024 11:00 | 34.5 | 0.28 | 95.31 | 0 | 17.9 | |
| 09/07/2024 12:00 | 21.91 | 0.36 | 92.61 | 0 | 45.8 | |
| 09/07/2024 13:00 | 34.61 | 0.38 | 95.24 | 0 | 19.8 | |
| 09/07/2024 14:00 | 34.67 | 0.37 | 95.41 | 0 | 17.9 | |
| 09/07/2024 15:00 | 34.55 | 0.32 | 95.17 | 0 | 17.9 | |
| 09/07/2024 16:00 | 34.42 | 0.27 | 95.03 | 0 | 18.1 | |
| 09/07/2024 17:00 | 34.29 | 0.22 | 94.82 | 0 | 17.9 | |
| 09/07/2024 18:00 | 34.25 | 0.08 | 94.5 | 0 | 17.9 | |
| 09/07/2024 19:00 | 34.14 | 0.01 | 94.26 | 0 | 17.6 | |
| 09/07/2024 20:00 | 34.23 | 0 | 94.28 | 0 | 17.5 | |
| 09/07/2024 21:00 | 34.36 | 0 | 94.56 | 0 | 17.5 | |
| 09/07/2024 22:00 | 34.3 | 0 | 94.59 | 0 | 17.5 | |
| 09/07/2024 23:00 | 34.19 | 0.41 | 94.9 | 0 | 17.4 | |
| 10/07/2024 00:00 | 7.89 | 0.26 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.89 | 0 | 92.61 | 0 | 17.4 | |
| MinDate | 10/07/2024 00:00 | 09/07/2024 20:00 | 09/07/2024 12:00 | 09/07/2024 00:00 | 09/07/2024 23:00 | |
| Maximum | 48.43 | 0.41 | 95.94 | 0 | 45.8 | |
| MaxDate | 09/07/2024 03:00 | 09/07/2024 23:00 | 09/07/2024 06:00 | 09/07/2024 00:00 | 09/07/2024 12:00 | |
| Avg | 36.6 | 0.2 | 94.97 | 0 | 24.7 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9 | 0.1 | 0.7 | 0 | 9.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/07/2024 00:00 | 40.28 | 0 | 95.81 | 1.7 | 41.5 | |
| 10/07/2024 01:00 | 48.35 | 0 | 95.54 | 1.7 | 39.8 | |
| 10/07/2024 02:00 | 48.46 | 0 | 95.8 | 1.7 | 39.6 | |
| 10/07/2024 03:00 | 48.48 | 0 | 95.91 | 1.7 | 39.4 | |
| 10/07/2024 04:00 | 48.52 | 0 | 95.93 | 1.7 | 39.1 | |
| 10/07/2024 05:00 | 48.57 | 0 | 95.92 | 1.7 | 39 | |
| 10/07/2024 06:00 | 48.67 | 0.34 | 96.21 | 1.7 | 38.9 | |
| 10/07/2024 07:00 | 39.7 | 0 | 95.89 | 1.8 | 39 | |
| 10/07/2024 08:00 | 34.17 | 0 | 94.95 | 1.7 | 29.6 | |
| 10/07/2024 09:00 | 34.52 | 0 | 95.1 | 1.7 | 27.4 | |
| 10/07/2024 10:00 | 34.59 | 0 | 95.29 | 1.7 | 27.3 | |
| 10/07/2024 11:00 | 34.47 | 0 | 95.22 | 1.7 | 27.3 | |
| 10/07/2024 12:00 | 22.17 | 0 | 92.31 | 1.8 | 49.3 | |
| 10/07/2024 13:00 | 34.6 | 0 | 94.94 | 1.7 | 29 | |
| 10/07/2024 14:00 | 34.53 | 0 | 95.51 | 1.7 | 27.7 | |
| 10/07/2024 15:00 | 34.5 | 0 | 95.1 | 1.7 | 27.7 | |
| 10/07/2024 16:00 | 34.48 | 0 | 94.8 | 1.7 | 27.5 | |
| 10/07/2024 17:00 | 34.29 | 0 | 94.61 | 1.7 | 27.3 | |
| 10/07/2024 18:00 | 34.26 | 0 | 94.36 | 1.7 | 27.3 | |
| 10/07/2024 19:00 | 34.17 | 0 | 94.36 | 1.6 | 26.9 | |
| 10/07/2024 20:00 | 34.21 | 0 | 94.41 | 1.6 | 26.5 | |
| 10/07/2024 21:00 | 34.36 | 0 | 94.84 | 1.6 | 26.4 | |
| 10/07/2024 22:00 | 34.3 | 0 | 94.71 | 1.6 | 26.9 | |
| 10/07/2024 23:00 | 34.14 | 0 | 94.21 | 1.6 | 27 | |
| 11/07/2024 00:00 | 7.81 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.81 | 0 | 92.31 | 1.6 | 26.4 | |
| MinDate | 11/07/2024 00:00 | 10/07/2024 00:00 | 10/07/2024 12:00 | 10/07/2024 19:00 | 10/07/2024 21:00 | |
| Maximum | 48.67 | 0.34 | 96.21 | 1.8 | 49.3 | |
| MaxDate | 10/07/2024 06:00 | 10/07/2024 06:00 | 10/07/2024 06:00 | 10/07/2024 07:00 | 10/07/2024 12:00 | |
| Avg | 36.66 | 0.01 | 95.07 | 1.7 | 32.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0.1 | 6.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/07/2024 00:00 | 7.89 | 0.26 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 01:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 02:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 03:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 04:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 05:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 06:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 07:00 | 10.68 | 0.19 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/07/2024 08:00 | 34.09 | 0.21 | 95.72 | 0 | 24.2 | |
| 10/07/2024 09:00 | 34.47 | 0.2 | 95.13 | 0 | 22.1 | |
| 10/07/2024 10:00 | 34.53 | 0.2 | 95.19 | 0 | 21.9 | |
| 10/07/2024 11:00 | 34.42 | 0.24 | 95.17 | 0 | 21.9 | |
| 10/07/2024 12:00 | 22.18 | 0.22 | 92.38 | 0 | 44.7 | |
| 10/07/2024 13:00 | 34.51 | 0.24 | 95.09 | 0 | 23.4 | |
| 10/07/2024 14:00 | 34.47 | 0.3 | 95.34 | 0 | 22.1 | |
| 10/07/2024 15:00 | 34.43 | 0.36 | 95.11 | 0 | 22.1 | |
| 10/07/2024 16:00 | 34.42 | 0.33 | 94.9 | 0 | 21.9 | |
| 10/07/2024 17:00 | 34.23 | 0.22 | 94.74 | 0 | 21.5 | |
| 10/07/2024 18:00 | 34.2 | 0.19 | 94.52 | 0 | 21.6 | |
| 10/07/2024 19:00 | 34.11 | 0.13 | 94.38 | 0 | 21.3 | |
| 10/07/2024 20:00 | 34.15 | 0.09 | 94.36 | 0 | 21 | |
| 10/07/2024 21:00 | 34.3 | 0.08 | 94.63 | 0 | 21.1 | |
| 10/07/2024 22:00 | 34.23 | 0.12 | 94.56 | 0 | 21.4 | |
| 10/07/2024 23:00 | 34.08 | 0.29 | 94.15 | 0 | 21.7 | |
| 11/07/2024 00:00 | 40.5 | 0.16 | 95.2 | 0 | 40.7 | |
| Minimum | 0 | 0.08 | 92.38 | 0 | 21 | |
| MinDate | 10/07/2024 01:00 | 10/07/2024 21:00 | 10/07/2024 12:00 | 10/07/2024 08:00 | 10/07/2024 20:00 | |
| Maximum | 40.5 | 0.36 | 95.72 | 0 | 44.7 | |
| MaxDate | 11/07/2024 00:00 | 10/07/2024 15:00 | 10/07/2024 08:00 | 10/07/2024 08:00 | 10/07/2024 12:00 | |
| Avg | 23.84 | 0.21 | 94.74 | 0 | 24.4 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 0.7 | 0 | 7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/07/2024 00:00 | 7.81 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 05:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 06:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 07:00 | 11.07 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/07/2024 08:00 | 34.15 | 0 | 94.33 | 1.8 | 31.3 | |
| 11/07/2024 09:00 | 34.28 | 0 | 94.24 | 1.8 | 31.3 | |
| 11/07/2024 10:00 | 34.45 | 0 | 94.98 | 1.8 | 28.9 | |
| 11/07/2024 11:00 | 34.5 | 0 | 95.45 | 1.8 | 28.9 | |
| 11/07/2024 12:00 | 22.14 | 0 | 92.45 | 2 | 53.1 | |
| 11/07/2024 13:00 | 34.63 | 0 | 95.05 | 1.8 | 31.1 | |
| 11/07/2024 14:00 | 34.61 | 0 | 95.32 | 1.8 | 29.3 | |
| 11/07/2024 15:00 | 34.62 | 0 | 94.87 | 1.8 | 29.4 | |
| 11/07/2024 16:00 | 34.54 | 0 | 94.63 | 1.8 | 29.2 | |
| 11/07/2024 17:00 | 34.42 | 0 | 94.57 | 1.8 | 29.2 | |
| 11/07/2024 18:00 | 34.33 | 0 | 94.34 | 1.7 | 29.1 | |
| 11/07/2024 19:00 | 34.15 | 0 | 94.27 | 1.7 | 28.6 | |
| 11/07/2024 20:00 | 34.18 | 0 | 94.42 | 1.7 | 28.2 | |
| 11/07/2024 21:00 | 34.37 | 0 | 94.84 | 1.7 | 28.3 | |
| 11/07/2024 22:00 | 34.26 | 0 | 94.76 | 1.7 | 28.4 | |
| 11/07/2024 23:00 | 34.17 | 0 | 94.74 | 1.7 | 28.3 | |
| 12/07/2024 00:00 | 40.13 | 0 | 95.38 | 1.8 | 43 | |
| Minimum | 0 | 0 | 92.45 | 1.7 | 28.2 | |
| MinDate | 11/07/2024 01:00 | 11/07/2024 00:00 | 11/07/2024 12:00 | 11/07/2024 18:00 | 11/07/2024 20:00 | |
| Maximum | 40.13 | 0.3 | 95.45 | 2 | 53.1 | |
| MaxDate | 12/07/2024 00:00 | 11/07/2024 06:00 | 11/07/2024 11:00 | 11/07/2024 12:00 | 11/07/2024 12:00 | |
| Avg | 23.87 | 0.02 | 94.63 | 1.8 | 31.5 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 0.7 | 0.1 | 6.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/07/2024 00:00 | 40.5 | 0.16 | 95.2 | 0 | 40.7 | |
| 11/07/2024 01:00 | 48.7 | 0.2 | 95.48 | 0 | 41.3 | |
| 11/07/2024 02:00 | 48.61 | 0.23 | 95.49 | 0 | 41.4 | |
| 11/07/2024 03:00 | 48.67 | 0.18 | 95.52 | 0 | 41.3 | |
| 11/07/2024 04:00 | 48.8 | 0.08 | 95.47 | 0 | 41.6 | |
| 11/07/2024 05:00 | 48.69 | 0.04 | 95.14 | 0 | 39.6 | |
| 11/07/2024 06:00 | 48.77 | 0.05 | 95.81 | 0 | 39.2 | |
| 11/07/2024 07:00 | 39.32 | 0.03 | 94.8 | 0 | 37.7 | |
| 11/07/2024 08:00 | 34.1 | 0.03 | 93.56 | 0 | 22.8 | |
| 11/07/2024 09:00 | 34.22 | 0 | 93.73 | 0 | 20.5 | |
| 11/07/2024 10:00 | 34.39 | 0.03 | 94.56 | 0 | 20.2 | |
| 11/07/2024 11:00 | 34.44 | 0.16 | 95.07 | 0 | 20 | |
| 11/07/2024 12:00 | 22.1 | 0.27 | 92.24 | 0 | 46.2 | |
| 11/07/2024 13:00 | 34.56 | 0.3 | 94.8 | 0 | 22.3 | |
| 11/07/2024 14:00 | 34.55 | 0.35 | 95.08 | 0 | 20.4 | |
| 11/07/2024 15:00 | 34.56 | 0.31 | 94.8 | 0 | 20.4 | |
| 11/07/2024 16:00 | 34.48 | 0.27 | 94.63 | 0 | 20.2 | |
| 11/07/2024 17:00 | 34.36 | 0.25 | 94.52 | 0 | 20.2 | |
| 11/07/2024 18:00 | 34.27 | 0.24 | 94.43 | 0 | 20.1 | |
| 11/07/2024 19:00 | 34.09 | 0.21 | 94.3 | 0 | 19.8 | |
| 11/07/2024 20:00 | 34.12 | 0.21 | 94.42 | 0 | 19.5 | |
| 11/07/2024 21:00 | 34.31 | 0.19 | 94.68 | 0 | 19.7 | |
| 11/07/2024 22:00 | 34.2 | 0.16 | 94.55 | 0 | 19.8 | |
| 11/07/2024 23:00 | 34.12 | 0.47 | 94.52 | 0 | 19.6 | |
| 12/07/2024 00:00 | 8.28 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 8.28 | 0 | 92.24 | 0 | 19.5 | |
| MinDate | 12/07/2024 00:00 | 11/07/2024 09:00 | 11/07/2024 12:00 | 11/07/2024 00:00 | 11/07/2024 20:00 | |
| Maximum | 48.8 | 0.47 | 95.81 | 0 | 46.2 | |
| MaxDate | 11/07/2024 04:00 | 11/07/2024 23:00 | 11/07/2024 06:00 | 11/07/2024 00:00 | 11/07/2024 12:00 | |
| Avg | 36.69 | 0.18 | 94.7 | 0 | 28.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0 | 10.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/07/2024 00:00 | 40.13 | 0 | 95.38 | 1.8 | 43 | |
| 12/07/2024 01:00 | 48.48 | 0 | 95.37 | 1.8 | 40.9 | |
| 12/07/2024 02:00 | 48.66 | 0 | 95.61 | 1.7 | 40.7 | |
| 12/07/2024 03:00 | 48.56 | 0 | 95.65 | 1.8 | 41.1 | |
| 12/07/2024 04:00 | 48.41 | 0 | 95.56 | 1.8 | 41.2 | |
| 12/07/2024 05:00 | 48.57 | 0 | 95.73 | 1.8 | 40.7 | |
| 12/07/2024 06:00 | 48.69 | 0.21 | 96.05 | 1.8 | 40.2 | |
| 12/07/2024 07:00 | 39.91 | 0 | 95.44 | 1.8 | 40.8 | |
| 12/07/2024 08:00 | 34.32 | 0 | 94.49 | 1.8 | 30.4 | |
| 12/07/2024 09:00 | 34.48 | 0 | 94.37 | 1.8 | 27.9 | |
| 12/07/2024 10:00 | 34.55 | 0 | 94.51 | 1.8 | 28 | |
| 12/07/2024 11:00 | 34.55 | 0 | 94.7 | 1.8 | 28.1 | |
| 12/07/2024 12:00 | 22.12 | 0 | 92.31 | 1.9 | 53.1 | |
| 12/07/2024 13:00 | 34.81 | 0 | 94.48 | 1.8 | 30.3 | |
| 12/07/2024 14:00 | 34.71 | 0 | 94.99 | 1.8 | 27.9 | |
| 12/07/2024 15:00 | 34.66 | 0 | 94.56 | 1.7 | 27.6 | |
| 12/07/2024 16:00 | 34.59 | 0 | 94.5 | 1.7 | 27.3 | |
| 12/07/2024 17:00 | 34.46 | 0 | 94.23 | 1.7 | 27.1 | |
| 12/07/2024 18:00 | 34.42 | 0 | 94.02 | 1.7 | 26.9 | |
| 12/07/2024 19:00 | 34.24 | 0 | 93.96 | 1.7 | 26.7 | |
| 12/07/2024 20:00 | 34.13 | 0 | 93.87 | 1.7 | 26.7 | |
| 12/07/2024 21:00 | 34.29 | 0 | 94.1 | 1.7 | 26.8 | |
| 12/07/2024 22:00 | 37.47 | 0 | 95.66 | 1.7 | 28.1 | |
| 12/07/2024 23:00 | 39 | 0 | 96.79 | 1.7 | 28.7 | |
| 13/07/2024 00:00 | 28.48 | 0 | 93.12 | 1.8 | 45 | |
| Minimum | 22.12 | 0 | 92.31 | 1.7 | 26.7 | |
| MinDate | 12/07/2024 12:00 | 12/07/2024 00:00 | 12/07/2024 12:00 | 12/07/2024 02:00 | 12/07/2024 19:00 | |
| Maximum | 48.69 | 0.21 | 96.79 | 1.9 | 53.1 | |
| MaxDate | 12/07/2024 06:00 | 12/07/2024 06:00 | 12/07/2024 23:00 | 12/07/2024 12:00 | 12/07/2024 12:00 | |
| Avq | 37.87 | 0.01 | 94.78 | 1.8 | 33.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7 | 0 | 1 | 0.1 | 7.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/07/2024 00:00 | 8.28 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 01:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 02:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 03:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 04:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 05:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 06:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 07:00 | 10.79 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 12/07/2024 08:00 | 34.16 | 0.07 | 95.24 | 0 | 25.1 | |
| 12/07/2024 09:00 | 34.42 | 0.21 | 95.29 | 0 | 22.7 | |
| 12/07/2024 10:00 | 34.49 | 0.23 | 95.39 | 0 | 22.7 | |
| 12/07/2024 11:00 | 34.49 | 0.25 | 95.58 | 0 | 22.7 | |
| 12/07/2024 12:00 | 22.07 | 0.25 | 93.02 | 0 | 48.9 | |
| 12/07/2024 13:00 | 34.74 | 0.21 | 95.01 | 0 | 24.8 | |
| 12/07/2024 14:00 | 34.65 | 0.19 | 95.38 | 0 | 22.4 | |
| 12/07/2024 15:00 | 34.61 | 0.17 | 95.11 | 0 | 22 | |
| 12/07/2024 16:00 | 34.53 | 0.16 | 95.12 | 0 | 21.6 | |
| 12/07/2024 17:00 | 34.4 | 0.13 | 94.85 | 0 | 21.6 | |
| 12/07/2024 18:00 | 34.36 | 0.09 | 94.7 | 0 | 21.3 | |
| 12/07/2024 19:00 | 34.17 | 0.03 | 94.64 | 0 | 21.1 | |
| 12/07/2024 20:00 | 34.07 | 0.03 | 94.55 | 0 | 21.1 | |
| 12/07/2024 21:00 | 34.23 | 0.06 | 94.63 | 0 | 21.2 | |
| 12/07/2024 22:00 | 37.05 | 0.04 | 95.97 | 0 | 22.4 | |
| 12/07/2024 23:00 | 38.93 | 0.39 | 97.23 | 0 | 23.4 | |
| 13/07/2024 00:00 | 28.52 | 0.08 | 93.22 | 0 | 38.2 | |
| Minimum | 0 | 0 | 93.02 | 0 | 21.1 | |
| MinDate | 12/07/2024 01:00 | 12/07/2024 07:00 | 12/07/2024 12:00 | 12/07/2024 08:00 | 12/07/2024 19:00 | |
| Maximum | 38.93 | 0.39 | 97.23 | 0 | 48.9 | |
| MaxDate | 12/07/2024 23:00 | 12/07/2024 23:00 | 12/07/2024 23:00 | 12/07/2024 08:00 | 12/07/2024 12:00 | |
| Avq | 23.72 | 0.12 | 95 | 0 | 24.9 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.4 | 0.1 | 0.9 | 0 | 7.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/07/2024 00:00 | 28.48 | 0 | 93.12 | 1.8 | 45 | |
| 13/07/2024 01:00 | 30.9 | 0 | 92.66 | 1.8 | 38.7 | |
| 13/07/2024 02:00 | 31.96 | 0 | 93.03 | 1.8 | 34.7 | |
| 13/07/2024 03:00 | 32.34 | 0 | 93.1 | 1.8 | 33.4 | |
| 13/07/2024 04:00 | 32.29 | 0 | 93.04 | 1.8 | 33.3 | |
| 13/07/2024 05:00 | 32.16 | 0 | 93.11 | 1.8 | 33.1 | |
| 13/07/2024 06:00 | 32.2 | 0.17 | 93.33 | 1.8 | 33.2 | |
| 13/07/2024 07:00 | 32.19 | 0 | 93.49 | 1.8 | 34.7 | |
| 13/07/2024 08:00 | 46.17 | 0 | 100.33 | 1.8 | 32.1 | |
| 13/07/2024 09:00 | 46.21 | 0 | 102.32 | 1.8 | 32.3 | |
| 13/07/2024 10:00 | 46.17 | 0 | 102.11 | 1.8 | 32.9 | |
| 13/07/2024 11:00 | 46.09 | 0 | 102.02 | 1.8 | 33.3 | |
| 13/07/2024 12:00 | 32.06 | 0 | 95.88 | 1.8 | 30.8 | |
| 13/07/2024 13:00 | 45.81 | 0 | 99.97 | 1.8 | 34.8 | |
| 13/07/2024 14:00 | 46 | 0 | 101.57 | 1.8 | 35 | |
| 13/07/2024 15:00 | 45.99 | 0 | 101.33 | 1.8 | 34.9 | |
| 13/07/2024 16:00 | 45.87 | 0 | 101.26 | 1.8 | 33.7 | |
| 13/07/2024 17:00 | 45.77 | 0 | 101.2 | 1.8 | 32.7 | |
| 13/07/2024 18:00 | 45.84 | 0 | 101.18 | 1.7 | 31 | |
| 13/07/2024 19:00 | 45.75 | 0 | 101.57 | 1.7 | 29.8 | |
| 13/07/2024 20:00 | 45.88 | 0 | 101.66 | 1.8 | 30.1 | |
| 13/07/2024 21:00 | 46.1 | 0 | 101.91 | 1.8 | 30.5 | |
| 13/07/2024 22:00 | 46.14 | 0 | 102.05 | 1.8 | 29.8 | |
| 13/07/2024 23:00 | 46.15 | 0 | 102.07 | 1.8 | 29.6 | |
| 14/07/2024 00:00 | 32.04 | 0 | 94.9 | 1.7 | 32.8 | |
| Minimum | 28.48 | 0 | 92.66 | 1.7 | 29.6 | |
| MinDate | 13/07/2024 00:00 | 13/07/2024 00:00 | 13/07/2024 01:00 | 13/07/2024 18:00 | 13/07/2024 23:00 | |
| Maximum | 46.21 | 0.17 | 102.32 | 1.8 | 45 | |
| MaxDate | 13/07/2024 09:00 | 13/07/2024 06:00 | 13/07/2024 09:00 | 13/07/2024 00:00 | 13/07/2024 00:00 | |
| Avg | 40.26 | 0.01 | 98.33 | 1.8 | 33.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.2 | 0 | 4 | 0 | 3.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/07/2024 00:00 | 28.52 | 0.08 | 93.22 | 0 | 38.2 | |
| 13/07/2024 01:00 | 30.84 | 0.07 | 92.89 | 0 | 33.1 | |
| 13/07/2024 02:00 | 31.9 | 0.07 | 93.28 | 0 | 29.7 | |
| 13/07/2024 03:00 | 32.28 | 0.05 | 93.39 | 0 | 28.5 | |
| 13/07/2024 04:00 | 32.23 | 0.06 | 93.34 | 0 | 28.3 | |
| 13/07/2024 05:00 | 32.1 | 0.11 | 93.42 | 0 | 28.2 | |
| 13/07/2024 06:00 | 32.14 | 0.07 | 93.62 | 0 | 28 | |
| 13/07/2024 07:00 | 32.13 | 0.05 | 93.84 | 0 | 29.8 | |
| 13/07/2024 08:00 | 46.07 | 0.08 | 100.9 | 0 | 32.7 | |
| 13/07/2024 09:00 | 46.14 | 0.22 | 102.63 | 0 | 33.6 | |
| 13/07/2024 10:00 | 46.09 | 0.28 | 102.51 | 0 | 34.4 | |
| 13/07/2024 11:00 | 46.02 | 0.29 | 102.42 | 0 | 35.4 | |
| 13/07/2024 12:00 | 32 | 0.27 | 96.12 | 0 | 26.8 | |
| 13/07/2024 13:00 | 45.69 | 0.26 | 100.36 | 0 | 37 | |
| 13/07/2024 14:00 | 45.93 | 0.23 | 101.62 | 0 | 38 | |
| 13/07/2024 15:00 | 45.91 | 0.23 | 101.61 | 0 | 37.7 | |
| 13/07/2024 16:00 | 45.81 | 0.23 | 101.57 | 0 | 36.2 | |
| 13/07/2024 17:00 | 45.7 | 0.22 | 101.74 | 0 | 34.5 | |
| 13/07/2024 18:00 | 45.76 | 0.11 | 101.85 | 0 | 32 | |
| 13/07/2024 19:00 | 45.68 | 0.05 | 102.21 | 0 | 30.3 | |
| 13/07/2024 20:00 | 45.81 | 0.05 | 102.31 | 0 | 30.8 | |
| 13/07/2024 21:00 | 46.02 | 0.09 | 102.3 | 0 | 31.7 | |
| 13/07/2024 22:00 | 46.07 | 0.11 | 102.36 | 0 | 30.8 | |
| 13/07/2024 23:00 | 46.08 | 0.32 | 102.45 | 0 | 30.2 | |
| 14/07/2024 00:00 | 31.99 | 0.07 | 95.22 | 0 | 28.8 | |
| Minimum | 28.52 | 0.05 | 92.89 | 0 | 26.8 | |
| MinDate | 13/07/2024 00:00 | 13/07/2024 03:00 | 13/07/2024 01:00 | 13/07/2024 00:00 | 13/07/2024 12:00 | |
| Maximum | 46.14 | 0.32 | 102.63 | 0 | 38.2 | |
| MaxDate | 13/07/2024 09:00 | 13/07/2024 23:00 | 13/07/2024 09:00 | 13/07/2024 00:00 | 13/07/2024 00:00 | |
| Avg | 40.2 | 0.15 | 98.69 | 0 | 32.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.2 | 0.1 | 4.1 | 0 | 3.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/07/2024 00:00 | 32.04 | 0 | 94.9 | 1.7 | 32.8 | |
| 14/07/2024 01:00 | 31.99 | 0 | 92.77 | 1.7 | 31.4 | |
| 14/07/2024 02:00 | 31.9 | 0 | 92.73 | 1.8 | 32 | |
| 14/07/2024 03:00 | 31.65 | 0 | 92.41 | 1.8 | 33.3 | |
| 14/07/2024 04:00 | 31.42 | 0 | 92.43 | 1.8 | 34.3 | |
| 14/07/2024 05:00 | 31.24 | 0 | 92.59 | 1.8 | 34.9 | |
| 14/07/2024 06:00 | 31.17 | 0.36 | 92.75 | 1.8 | 35 | |
| 14/07/2024 07:00 | 30.93 | 0 | 92.82 | 1.8 | 35.3 | |
| 14/07/2024 08:00 | 30.82 | 0 | 93.04 | 1.8 | 34.7 | |
| 14/07/2024 09:00 | 30.92 | 0 | 92.95 | 1.8 | 34 | |
| 14/07/2024 10:00 | 30.97 | 0 | 93.08 | 1.8 | 32.7 | |
| 14/07/2024 11:00 | 30.93 | 0 | 93.24 | 1.8 | 32.1 | |
| 14/07/2024 12:00 | 30.93 | 0 | 93.59 | 1.8 | 32 | |
| 14/07/2024 13:00 | 30.96 | 0 | 93.28 | 1.8 | 31.7 | |
| 14/07/2024 14:00 | 31 | 0 | 93.22 | 1.8 | 31.7 | |
| 14/07/2024 15:00 | 30.89 | 0 | 92.76 | 1.7 | 31.9 | |
| 14/07/2024 16:00 | 30.84 | 0 | 92.46 | 1.7 | 32.4 | |
| 14/07/2024 17:00 | 30.84 | 0 | 92.39 | 1.7 | 32.6 | |
| 14/07/2024 18:00 | 44.81 | 0 | 98.6 | 1.7 | 28.4 | |
| 14/07/2024 19:00 | 44.87 | 0 | 100.51 | 1.7 | 27.2 | |
| 14/07/2024 20:00 | 44.89 | 0 | 100.97 | 1.7 | 27.3 | |
| 14/07/2024 21:00 | 44.87 | 0 | 101.41 | 1.8 | 27.2 | |
| 14/07/2024 22:00 | 44.88 | 0 | 101.69 | 1.8 | 27.1 | |
| 14/07/2024 23:00 | 30.84 | 0 | 95.11 | 1.7 | 34.5 | |
| 15/07/2024 00:00 | 30.74 | 0 | 92.87 | 1.7 | 33.7 | |
| Minimum | 30.74 | 0 | 92.39 | 1.7 | 27.1 | |
| MinDate | 15/07/2024 00:00 | 14/07/2024 00:00 | 14/07/2024 17:00 | 14/07/2024 00:00 | 14/07/2024 22:00 | |
| Maximum | 44.89 | 0.36 | 101.69 | 1.8 | 35.3 | |
| MaxDate | 14/07/2024 20:00 | 14/07/2024 06:00 | 14/07/2024 22:00 | 14/07/2024 02:00 | 14/07/2024 07:00 | |
| Avg | 33.89 | 0.01 | 94.58 | 1.8 | 32 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.6 | 0.1 | 3.2 | 0.1 | 2.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/07/2024 00:00 | 31.99 | 0.07 | 95.22 | 0 | 28.8 | |
| 14/07/2024 01:00 | 31.93 | 0.03 | 93.43 | 0 | 27.5 | |
| 14/07/2024 02:00 | 31.85 | 0.02 | 93.42 | 0 | 28.2 | |
| 14/07/2024 03:00 | 31.59 | 0.03 | 93.07 | 0 | 29.3 | |
| 14/07/2024 04:00 | 31.36 | 0.03 | 93.14 | 0 | 30 | |
| 14/07/2024 05:00 | 31.19 | 0.07 | 93.27 | 0 | 30.4 | |
| 14/07/2024 06:00 | 31.12 | 0.02 | 93.4 | 0 | 30.4 | |
| 14/07/2024 07:00 | 30.87 | 0 | 93.52 | 0 | 30.6 | |
| 14/07/2024 08:00 | 30.77 | 0.06 | 93.75 | 0 | 30 | |
| 14/07/2024 09:00 | 30.84 | 0.19 | 93.66 | 0 | 29.3 | |
| 14/07/2024 10:00 | 30.91 | 0.23 | 93.81 | 0 | 28.2 | |
| 14/07/2024 11:00 | 30.87 | 0.25 | 94.01 | 0 | 27.8 | |
| 14/07/2024 12:00 | 30.88 | 0.25 | 94.32 | 0 | 27.6 | |
| 14/07/2024 13:00 | 30.91 | 0.23 | 93.96 | 0 | 27.3 | |
| 14/07/2024 14:00 | 30.94 | 0.2 | 93.85 | 0 | 27.4 | |
| 14/07/2024 15:00 | 30.82 | 0.19 | 93.53 | 0 | 27.7 | |
| 14/07/2024 16:00 | 30.77 | 0.18 | 93.38 | 0 | 28.2 | |
| 14/07/2024 17:00 | 30.78 | 0.15 | 93.34 | 0 | 28.2 | |
| 14/07/2024 18:00 | 44.7 | 0.06 | 99.67 | 0 | 27.2 | |
| 14/07/2024 19:00 | 44.8 | 0 | 101.07 | 0 | 25.3 | |
| 14/07/2024 20:00 | 44.82 | 0 | 101.45 | 0 | 25.7 | |
| 14/07/2024 21:00 | 44.8 | 0.01 | 101.69 | 0 | 25.8 | |
| 14/07/2024 22:00 | 44.8 | 0.04 | 101.9 | 0 | 25.7 | |
| 14/07/2024 23:00 | 30.8 | 0.31 | 95.23 | 0 | 30.1 | |
| 15/07/2024 00:00 | 30.69 | 0.15 | 93.22 | 0 | 29.1 | |
| Minimum | 30.69 | 0 | 93.07 | 0 | 25.3 | |
| MinDate | 15/07/2024 00:00 | 14/07/2024 07:00 | 14/07/2024 03:00 | 14/07/2024 00:00 | 14/07/2024 19:00 | |
| Maximum | 44.82 | 0.31 | 101.9 | 0 | 30.6 | |
| MaxDate | 14/07/2024 20:00 | 14/07/2024 23:00 | 14/07/2024 22:00 | 14/07/2024 00:00 | 14/07/2024 07:00 | |
| Avg | 33.83 | 0.11 | 95.21 | 0 | 28.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.6 | 0.1 | 3.1 | 0 | 1.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/07/2024 00:00 | 30.74 | 0 | 92.87 | 1.7 | 33.7 | |
| 15/07/2024 01:00 | 30.74 | 0 | 92.73 | 1.8 | 33.7 | |
| 15/07/2024 02:00 | 30.72 | 0 | 92.78 | 1.8 | 33.6 | |
| 15/07/2024 03:00 | 30.71 | 0 | 92.81 | 1.8 | 33.6 | |
| 15/07/2024 04:00 | 30.7 | 0 | 92.95 | 1.8 | 33.5 | |
| 15/07/2024 05:00 | 30.77 | 0 | 93.07 | 1.8 | 33.4 | |
| 15/07/2024 06:00 | 30.76 | 0.28 | 93.09 | 1.8 | 33.1 | |
| 15/07/2024 07:00 | 30.96 | 0 | 93.13 | 1.8 | 32.3 | |
| 15/07/2024 08:00 | 43.82 | 0 | 99.96 | 1.8 | 27.3 | |
| 15/07/2024 09:00 | 34.06 | 0 | 95.56 | 1.8 | 24.1 | |
| 15/07/2024 10:00 | 34.15 | 0 | 94.7 | 1.8 | 24.1 | |
| 15/07/2024 11:00 | 34.11 | 0 | 94.22 | 1.7 | 23.8 | |
| 15/07/2024 12:00 | 21.93 | 0.01 | 90.78 | 1.8 | 54 | |
| 15/07/2024 13:00 | 34.26 | 0.21 | 91.78 | 1.7 | 25.8 | |
| 15/07/2024 14:00 | 34.2 | 0 | 93.64 | 1.7 | 23.8 | |
| 15/07/2024 15:00 | 34.2 | 0 | 93.77 | 1.7 | 23.6 | |
| 15/07/2024 16:00 | 34.17 | 0 | 94.04 | 1.7 | 23.3 | |
| 15/07/2024 17:00 | 34.05 | 0 | 93.99 | 1.7 | 23.3 | |
| 15/07/2024 18:00 | 34.16 | 0 | 94.02 | 1.7 | 23.4 | |
| 15/07/2024 19:00 | 34.01 | 0 | 93.96 | 1.7 | 23.3 | |
| 15/07/2024 20:00 | 34.09 | 0 | 93.96 | 1.7 | 23.1 | |
| 15/07/2024 21:00 | 34.35 | 0 | 94.22 | 1.7 | 23.1 | |
| 15/07/2024 22:00 | 34.43 | 0 | 94.11 | 1.7 | 23.1 | |
| 15/07/2024 23:00 | 34.27 | 0 | 94.37 | 1.7 | 23.2 | |
| 16/07/2024 00:00 | 7.8 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.8 | 0 | 90.78 | 1.7 | 23.1 | |
| MinDate | 16/07/2024 00:00 | 15/07/2024 00:00 | 15/07/2024 12:00 | 15/07/2024 00:00 | 15/07/2024 20:00 | |
| Maximum | 43.82 | 0.28 | 99.96 | 1.8 | 54 | |
| MaxDate | 15/07/2024 08:00 | 15/07/2024 06:00 | 15/07/2024 08:00 | 15/07/2024 01:00 | 15/07/2024 12:00 | |
| Avg | 31.93 | 0.02 | 93.77 | 1.7 | 28.3 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.1 | 0.1 | 1.6 | 0.1 | 7.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/07/2024 00:00 | 30.69 | 0.15 | 93.22 | 0 | 29.1 | |
| 15/07/2024 01:00 | 30.68 | 0.08 | 93.01 | 0 | 29.4 | |
| 15/07/2024 02:00 | 30.67 | 0.09 | 93.05 | 0 | 29.5 | |
| 15/07/2024 03:00 | 30.65 | 0.1 | 93.07 | 0 | 29.5 | |
| 15/07/2024 04:00 | 30.64 | 0.12 | 93.17 | 0 | 29.3 | |
| 15/07/2024 05:00 | 30.71 | 0.13 | 93.3 | 0 | 28.9 | |
| 15/07/2024 06:00 | 30.7 | 0.15 | 93.41 | 0 | 28.5 | |
| 15/07/2024 07:00 | 30.9 | 0.14 | 93.45 | 0 | 27.6 | |
| 15/07/2024 08:00 | 43.83 | 0.14 | 100.3 | 0 | 26 | |
| 15/07/2024 09:00 | 34 | 0.23 | 95.72 | 0 | 18.9 | |
| 15/07/2024 10:00 | 34.1 | 0.25 | 94.83 | 0 | 18.9 | |
| 15/07/2024 11:00 | 34.05 | 0.25 | 94.46 | 0 | 18.5 | |
| 15/07/2024 12:00 | 21.87 | 0.15 | 90.88 | 0 | 48.9 | |
| 15/07/2024 13:00 | 34.2 | 0.02 | 91.49 | 0 | 21 | |
| 15/07/2024 14:00 | 34.14 | 0 | 93.71 | 0 | 18.5 | |
| 15/07/2024 15:00 | 34.14 | 0.05 | 94.03 | 0 | 18.3 | |
| 15/07/2024 16:00 | 34.11 | 0.1 | 94.45 | 0 | 18 | |
| 15/07/2024 17:00 | 33.98 | 0.15 | 94.39 | 0 | 17.9 | |
| 15/07/2024 18:00 | 34.1 | 0.14 | 94.46 | 0 | 17.8 | |
| 15/07/2024 19:00 | 33.95 | 0.12 | 94.36 | 0 | 17.8 | |
| 15/07/2024 20:00 | 34.03 | 0.12 | 94.34 | 0 | 17.7 | |
| 15/07/2024 21:00 | 34.3 | 0.14 | 94.43 | 0 | 17.7 | |
| 15/07/2024 22:00 | 34.37 | 0.1 | 94.3 | 0 | 17.6 | |
| 15/07/2024 23:00 | 34.21 | 0.43 | 94.53 | 0 | 17.5 | |
| 16/07/2024 00:00 | 40.43 | 0.08 | 95.32 | 0 | 35.4 | |
| Minimum | 21.87 | 0 | 90.88 | 0 | 17.5 | |
| MinDate | 15/07/2024 12:00 | 15/07/2024 14:00 | 15/07/2024 12:00 | 15/07/2024 00:00 | 15/07/2024 23:00 | |
| Maximum | 43.83 | 0.43 | 100.3 | 0 | 48.9 | |
| MaxDate | 15/07/2024 08:00 | 15/07/2024 23:00 | 15/07/2024 08:00 | 15/07/2024 00:00 | 15/07/2024 12:00 | |
| Avg | 33.18 | 0.14 | 94.07 | 0 | 23.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 3.8 | 0.1 | 1.7 | 0 | 7.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/07/2024 00:00 | 7.8 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 06:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 07:00 | 11.14 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/07/2024 08:00 | 34.31 | 0 | 94.56 | 1.8 | 31.7 | |
| 16/07/2024 09:00 | 34.48 | 0 | 95.05 | 1.8 | 29.7 | |
| 16/07/2024 10:00 | 34.46 | 0 | 95.04 | 1.8 | 29.6 | |
| 16/07/2024 11:00 | 34.39 | 0 | 95.03 | 1.8 | 29.8 | |
| 16/07/2024 12:00 | 21.97 | 0 | 91.97 | 2 | 54.2 | |
| 16/07/2024 13:00 | 34.61 | 0 | 94.65 | 1.8 | 31.4 | |
| 16/07/2024 14:00 | 34.5 | 0 | 95.05 | 1.8 | 29.9 | |
| 16/07/2024 15:00 | 34.49 | 0 | 94.6 | 1.8 | 29.7 | |
| 16/07/2024 16:00 | 34.28 | 0 | 94.35 | 1.8 | 29.5 | |
| 16/07/2024 17:00 | 34.16 | 0 | 94.25 | 1.8 | 29.3 | |
| 16/07/2024 18:00 | 34.15 | 0 | 94.29 | 1.8 | 29.1 | |
| 16/07/2024 19:00 | 34.03 | 0 | 94.2 | 1.7 | 28.9 | |
| 16/07/2024 20:00 | 34.12 | 0 | 94.01 | 1.8 | 28.9 | |
| 16/07/2024 21:00 | 34.34 | 0 | 94.43 | 1.8 | 28.8 | |
| 16/07/2024 22:00 | 34.44 | 0 | 94.55 | 1.8 | 28.7 | |
| 16/07/2024 23:00 | 34.37 | 0 | 94.66 | 1.8 | 28.6 | |
| 17/07/2024 00:00 | 40.42 | 0 | 95.13 | 1.8 | 42.8 | |
| Minimum | 0 | 0 | 91.97 | 1.7 | 28.6 | |
| MinDate | 16/07/2024 01:00 | 16/07/2024 00:00 | 16/07/2024 12:00 | 16/07/2024 19:00 | 16/07/2024 23:00 | |
| Maximum | 40.42 | 0.21 | 95.13 | 2 | 54.2 | |
| MaxDate | 17/07/2024 00:00 | 16/07/2024 06:00 | 17/07/2024 00:00 | 16/07/2024 12:00 | 16/07/2024 12:00 | |
| Avg | 23.86 | 0.01 | 94.46 | 1.8 | 31.8 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0 | 0.7 | 0.1 | 6.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/07/2024 00:00 | 40.43 | 0.08 | 95.32 | 0 | 35.4 | |
| 16/07/2024 01:00 | 48.42 | 0.07 | 95.03 | 0 | 35.4 | |
| 16/07/2024 02:00 | 48.47 | 0.05 | 94.95 | 0 | 35.7 | |
| 16/07/2024 03:00 | 48.5 | 0.05 | 95.41 | 0 | 35.6 | |
| 16/07/2024 04:00 | 48.56 | 0.09 | 95.58 | 0 | 35.4 | |
| 16/07/2024 05:00 | 48.48 | 0.11 | 95.5 | 0 | 35.4 | |
| 16/07/2024 06:00 | 48.49 | 0.13 | 95.9 | 0 | 35.6 | |
| 16/07/2024 07:00 | 39.14 | 0.19 | 94.96 | 0 | 33.9 | |
| 16/07/2024 08:00 | 34.26 | 0.22 | 94.47 | 0 | 19.6 | |
| 16/07/2024 09:00 | 34.42 | 0.24 | 94.75 | 0 | 17.5 | |
| 16/07/2024 10:00 | 34.4 | 0.21 | 94.74 | 0 | 17.4 | |
| 16/07/2024 11:00 | 34.33 | 0.21 | 94.78 | 0 | 17.4 | |
| 16/07/2024 12:00 | 21.92 | 0.2 | 91.84 | 0 | 45.7 | |
| 16/07/2024 13:00 | 34.54 | 0.19 | 94.49 | 0 | 19.2 | |
| 16/07/2024 14:00 | 34.43 | 0.2 | 94.82 | 0 | 17.5 | |
| 16/07/2024 15:00 | 34.42 | 0.19 | 94.55 | 0 | 17.4 | |
| 16/07/2024 16:00 | 34.21 | 0.17 | 94.35 | 0 | 17.2 | |
| 16/07/2024 17:00 | 34.09 | 0.16 | 94.25 | 0 | 17 | |
| 16/07/2024 18:00 | 34.08 | 0.17 | 94.4 | 0 | 17.1 | |
| 16/07/2024 19:00 | 33.96 | 0.19 | 94.37 | 0 | 16.9 | |
| 16/07/2024 20:00 | 34.05 | 0.18 | 94.15 | 0 | 17.1 | |
| 16/07/2024 21:00 | 34.27 | 0.15 | 94.43 | 0 | 17.1 | |
| 16/07/2024 22:00 | 34.36 | 0.13 | 94.53 | 0 | 17.1 | |
| 16/07/2024 23:00 | 34.3 | 0.37 | 94.62 | 0 | 16.9 | |
| 17/07/2024 00:00 | 7.71 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.71 | 0.05 | 91.84 | 0 | 16.9 | |
| MinDate | 17/07/2024 00:00 | 16/07/2024 02:00 | 16/07/2024 12:00 | 16/07/2024 00:00 | 16/07/2024 19:00 | |
| Maximum | 48.56 | 0.37 | 95.9 | 0 | 45.7 | |
| MaxDate | 16/07/2024 04:00 | 16/07/2024 23:00 | 16/07/2024 06:00 | 16/07/2024 00:00 | 16/07/2024 12:00 | |
| Avg | 36.57 | 0.16 | 94.67 | 0 | 24.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0 | 9.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/07/2024 00:00 | 40.42 | 0 | 95.13 | 1.8 | 42.8 | |
| 17/07/2024 01:00 | 48.2 | 0 | 95.18 | 1.8 | 41.1 | |
| 17/07/2024 02:00 | 48.3 | 0 | 95.57 | 1.8 | 40.8 | |
| 17/07/2024 03:00 | 48.4 | 0 | 95.68 | 1.8 | 40.8 | |
| 17/07/2024 04:00 | 48.49 | 0 | 95.64 | 1.8 | 40.5 | |
| 17/07/2024 05:00 | 48.45 | 0 | 95.72 | 1.8 | 40.2 | |
| 17/07/2024 06:00 | 48.46 | 0.15 | 96.01 | 1.8 | 40 | |
| 17/07/2024 07:00 | 39.91 | 0 | 95.72 | 1.9 | 40.3 | |
| 17/07/2024 08:00 | 34.5 | 0 | 94.56 | 1.8 | 30.6 | |
| 17/07/2024 09:00 | 34.6 | 0 | 94.68 | 1.8 | 27.9 | |
| 17/07/2024 10:00 | 34.75 | 0 | 94.84 | 1.8 | 28.1 | |
| 17/07/2024 11:00 | 34.72 | 0 | 94.71 | 1.8 | 28.3 | |
| 17/07/2024 12:00 | 22.21 | 0 | 91.7 | 1.9 | 50.7 | |
| 17/07/2024 13:00 | 34.79 | 0 | 94.21 | 1.8 | 29.7 | |
| 17/07/2024 14:00 | 34.74 | 0 | 94.87 | 1.8 | 28 | |
| 17/07/2024 15:00 | 34.7 | 0 | 94.61 | 1.8 | 27.9 | |
| 17/07/2024 16:00 | 34.56 | 0 | 94.19 | 1.8 | 27.6 | |
| 17/07/2024 17:00 | 34.42 | 0 | 93.97 | 1.7 | 27.5 | |
| 17/07/2024 18:00 | 34.43 | 0 | 93.94 | 1.7 | 27.3 | |
| 17/07/2024 19:00 | 34.28 | 0 | 93.91 | 1.7 | 27 | |
| 17/07/2024 20:00 | 34.35 | 0 | 93.83 | 1.7 | 26.8 | |
| 17/07/2024 21:00 | 34.42 | 0 | 94.24 | 1.7 | 26.8 | |
| 17/07/2024 22:00 | 34.42 | 0 | 94.27 | 1.7 | 27 | |
| 17/07/2024 23:00 | 34.38 | 0 | 94.19 | 1.7 | 27 | |
| 18/07/2024 00:00 | 7.7 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.7 | 0 | 91.7 | 1.7 | 26.8 | |
| MinDate | 18/07/2024 00:00 | 17/07/2024 00:00 | 17/07/2024 12:00 | 17/07/2024 17:00 | 17/07/2024 20:00 | |
| Maximum | 48.49 | 0.15 | 96.01 | 1.9 | 50.7 | |
| MaxDate | 17/07/2024 04:00 | 17/07/2024 06:00 | 17/07/2024 06:00 | 17/07/2024 07:00 | 17/07/2024 12:00 | |
| Avg | 36.74 | 0.01 | 94.64 | 1.8 | 33.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9 | 0 | 0.9 | 0.1 | 7.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/07/2024 00:00 | 7.71 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 01:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 02:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 07:00 | 10.45 | 0.05 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/07/2024 08:00 | 34.42 | 0.11 | 95.55 | 0 | 25.2 | |
| 17/07/2024 09:00 | 34.54 | 0.21 | 95.56 | 0 | 22.5 | |
| 17/07/2024 10:00 | 34.68 | 0.24 | 95.69 | 0 | 22.8 | |
| 17/07/2024 11:00 | 34.65 | 0.22 | 95.47 | 0 | 22.8 | |
| 17/07/2024 12:00 | 22.13 | 0.16 | 92.5 | 0 | 46.1 | |
| 17/07/2024 13:00 | 34.69 | 0.11 | 95.06 | 0 | 24 | |
| 17/07/2024 14:00 | 34.67 | 0.15 | 95.59 | 0 | 22.2 | |
| 17/07/2024 15:00 | 34.62 | 0.15 | 95.46 | 0 | 22.1 | |
| 17/07/2024 16:00 | 34.49 | 0.14 | 95.05 | 0 | 21.8 | |
| 17/07/2024 17:00 | 34.36 | 0.09 | 94.82 | 0 | 21.9 | |
| 17/07/2024 18:00 | 34.36 | 0.09 | 94.86 | 0 | 21.6 | |
| 17/07/2024 19:00 | 34.2 | 0.09 | 94.84 | 0 | 21.2 | |
| 17/07/2024 20:00 | 34.28 | 0.08 | 94.79 | 0 | 21.2 | |
| 17/07/2024 21:00 | 34.35 | 0.06 | 95.03 | 0 | 21.1 | |
| 17/07/2024 22:00 | 34.36 | 0.05 | 94.98 | 0 | 21.3 | |
| 17/07/2024 23:00 | 34.32 | 0.31 | 94.89 | 0 | 21.4 | |
| 18/07/2024 00:00 | 40.22 | 0.09 | 95.45 | 0 | 40 | |
| Minimum | 0 | 0 | 92.5 | 0 | 21.1 | |
| MinDate | 17/07/2024 01:00 | 17/07/2024 03:00 | 17/07/2024 12:00 | 17/07/2024 08:00 | 17/07/2024 21:00 | |
| Maximum | 40.22 | 0.31 | 95.69 | 0 | 46.1 | |
| MaxDate | 18/07/2024 00:00 | 17/07/2024 23:00 | 17/07/2024 10:00 | 17/07/2024 08:00 | 17/07/2024 12:00 | |
| Avg | 23.9 | 0.1 | 95.03 | 0 | 24.7 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.6 | 0.1 | 0.7 | 0 | 7.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/07/2024 00:00 | 7.7 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 06:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 07:00 | 11.02 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/07/2024 08:00 | 34.49 | 0 | 95.11 | 1.8 | 30.6 | |
| 18/07/2024 09:00 | 34.45 | 0 | 95.14 | 1.8 | 29.2 | |
| 18/07/2024 10:00 | 34.48 | 0 | 95.17 | 1.9 | 29.3 | |
| 18/07/2024 11:00 | 34.44 | 0 | 95.1 | 1.8 | 29.5 | |
| 18/07/2024 12:00 | 22.19 | 0 | 91.97 | 2 | 53.6 | |
| 18/07/2024 13:00 | 34.58 | 0 | 94.18 | 1.8 | 31.1 | |
| 18/07/2024 14:00 | 34.28 | 0 | 94.2 | 1.8 | 28.8 | |
| 18/07/2024 15:00 | 34.46 | 0 | 94.07 | 1.8 | 28.8 | |
| 18/07/2024 16:00 | 34.39 | 0 | 93.75 | 1.8 | 28.6 | |
| 18/07/2024 17:00 | 34.29 | 0 | 93.69 | 1.8 | 28.5 | |
| 18/07/2024 18:00 | 34.13 | 0 | 93.53 | 1.8 | 28.3 | |
| 18/07/2024 19:00 | 33.93 | 0 | 93.4 | 1.8 | 28 | |
| 18/07/2024 20:00 | 34.03 | 0 | 93.43 | 1.8 | 27.8 | |
| 18/07/2024 21:00 | 34.2 | 0 | 93.84 | 1.8 | 27.8 | |
| 18/07/2024 22:00 | 34.23 | 0 | 93.88 | 1.8 | 27.9 | |
| 18/07/2024 23:00 | 34.15 | 0 | 93.86 | 1.8 | 27.8 | |
| 19/07/2024 00:00 | 40.36 | 0 | 94.68 | 1.8 | 42.7 | |
| Minimum | 0 | 0 | 91.97 | 1.8 | 27.8 | |
| MinDate | 18/07/2024 01:00 | 18/07/2024 00:00 | 18/07/2024 12:00 | 18/07/2024 08:00 | 18/07/2024 20:00 | |
| Maximum | 40.36 | 0.34 | 95.17 | 2 | 53.6 | |
| MaxDate | 19/07/2024 00:00 | 18/07/2024 06:00 | 18/07/2024 10:00 | 18/07/2024 12:00 | 18/07/2024 12:00 | |
| Avg | 23.83 | 0.02 | 94.06 | 1.8 | 31.1 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 0.8 | 0.1 | 6.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/07/2024 00:00 | 40.22 | 0.09 | 95.45 | 0 | 40 | |
| 18/07/2024 01:00 | 47.96 | 0.1 | 94.9 | 0 | 41.2 | |
| 18/07/2024 02:00 | 48.04 | 0.11 | 94.98 | 0 | 41 | |
| 18/07/2024 03:00 | 47.97 | 0.1 | 95.47 | 0 | 40.5 | |
| 18/07/2024 04:00 | 48 | 0.09 | 95.44 | 0 | 40.3 | |
| 18/07/2024 05:00 | 48.37 | 0.08 | 95.28 | 0 | 40.3 | |
| 18/07/2024 06:00 | 48.61 | 0.05 | 95.73 | 0 | 40.5 | |
| 18/07/2024 07:00 | 39.34 | 0.07 | 95.07 | 0 | 37.5 | |
| 18/07/2024 08:00 | 34.44 | 0.12 | 94.54 | 0 | 22.1 | |
| 18/07/2024 09:00 | 34.39 | 0.17 | 94.88 | 0 | 20.5 | |
| 18/07/2024 10:00 | 34.41 | 0.21 | 95.06 | 0 | 20.7 | |
| 18/07/2024 11:00 | 34.38 | 0.25 | 94.93 | 0 | 20.9 | |
| 18/07/2024 12:00 | 22.15 | 0.18 | 91.92 | 0 | 46.1 | |
| 18/07/2024 13:00 | 34.51 | 0.17 | 94.69 | 0 | 22.5 | |
| 18/07/2024 14:00 | 34.22 | 0.15 | 95.17 | 0 | 20.3 | |
| 18/07/2024 15:00 | 34.39 | 0.17 | 95.18 | 0 | 20.2 | |
| 18/07/2024 16:00 | 34.32 | 0.18 | 94.98 | 0 | 20 | |
| 18/07/2024 17:00 | 34.22 | 0.16 | 94.79 | 0 | 19.8 | |
| 18/07/2024 18:00 | 34.06 | 0.11 | 94.64 | 0 | 19.7 | |
| 18/07/2024 19:00 | 33.86 | 0.09 | 94.5 | 0 | 19.5 | |
| 18/07/2024 20:00 | 33.96 | 0.08 | 94.58 | 0 | 19.5 | |
| 18/07/2024 21:00 | 34.14 | 0.08 | 94.84 | 0 | 19.5 | |
| 18/07/2024 22:00 | 34.17 | 0.08 | 94.88 | 0 | 19.5 | |
| 18/07/2024 23:00 | 34.09 | 0.26 | 94.85 | 0 | 19.4 | |
| 19/07/2024 00:00 | 7.88 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.88 | 0.05 | 91.92 | 0 | 19.4 | |
| MinDate | 19/07/2024 00:00 | 18/07/2024 06:00 | 18/07/2024 12:00 | 18/07/2024 00:00 | 18/07/2024 23:00 | |
| Maximum | 48.61 | 0.26 | 95.73 | 0 | 46.1 | |
| MaxDate | 18/07/2024 06:00 | 18/07/2024 23:00 | 18/07/2024 06:00 | 18/07/2024 00:00 | 18/07/2024 12:00 | |
| Avg | 36.48 | 0.13 | 94.86 | 0 | 28 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9 | 0.1 | 0.7 | 0 | 10.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/07/2024 00:00 | 40.36 | 0 | 94.68 | 1.8 | 42.7 | |
| 19/07/2024 01:00 | 48.41 | 0 | 94.74 | 1.8 | 40.3 | |
| 19/07/2024 02:00 | 48.58 | 0 | 95.1 | 1.8 | 39.9 | |
| 19/07/2024 03:00 | 48.63 | 0 | 95.41 | 1.8 | 39.7 | |
| 19/07/2024 04:00 | 48.69 | 0 | 95.43 | 1.8 | 39.5 | |
| 19/07/2024 05:00 | 48.6 | 0 | 95.34 | 1.8 | 39.5 | |
| 19/07/2024 06:00 | 48.66 | 0.28 | 95.53 | 1.8 | 39.3 | |
| 19/07/2024 07:00 | 40.04 | 0 | 95.73 | 1.9 | 39.3 | |
| 19/07/2024 08:00 | 34.18 | 0 | 94.77 | 1.9 | 29.7 | |
| 19/07/2024 09:00 | 34.42 | 0 | 95.12 | 1.8 | 27 | |
| 19/07/2024 10:00 | 34.43 | 0 | 95.39 | 1.9 | 27 | |
| 19/07/2024 11:00 | 34.34 | 0 | 95.37 | 1.8 | 27.1 | |
| 19/07/2024 12:00 | 22.21 | 0 | 92.27 | 2 | 50.6 | |
| 19/07/2024 13:00 | 34.45 | 0 | 94.82 | 1.8 | 29.1 | |
| 19/07/2024 14:00 | 34.32 | 0 | 95.09 | 1.8 | 26.8 | |
| 19/07/2024 15:00 | 34.24 | 0 | 94.7 | 1.8 | 26.8 | |
| 19/07/2024 16:00 | 34.22 | 0 | 94.61 | 1.8 | 26.3 | |
| 19/07/2024 17:00 | 34.08 | 0 | 94.6 | 1.8 | 26.2 | |
| 19/07/2024 18:00 | 33.95 | 0 | 94.57 | 1.8 | 26.1 | |
| 19/07/2024 19:00 | 33.8 | 0 | 94.49 | 1.8 | 27.9 | |
| 19/07/2024 20:00 | 34.05 | 0 | 94.46 | 1.8 | 25.9 | |
| 19/07/2024 21:00 | 34.29 | 0 | 94.85 | 1.8 | 25.9 | |
| 19/07/2024 22:00 | 37.32 | 0 | 96.36 | 1.8 | 27.4 | |
| 19/07/2024 23:00 | 39.15 | 0 | 97.92 | 1.8 | 28.4 | |
| 20/07/2024 00:00 | 43.16 | 0 | 97.07 | 1.8 | 37.9 | |
| Minimum | 22.21 | 0 | 92.27 | 1.8 | 25.9 | |
| MinDate | 19/07/2024 12:00 | 19/07/2024 00:00 | 19/07/2024 12:00 | 19/07/2024 00:00 | 19/07/2024 20:00 | |
| Maximum | 48.69 | 0.28 | 97.92 | 2 | 50.6 | |
| MaxDate | 19/07/2024 04:00 | 19/07/2024 06:00 | 19/07/2024 23:00 | 19/07/2024 12:00 | 19/07/2024 12:00 | |
| Avg | 38.34 | 0.01 | 95.14 | 1.8 | 32.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.9 | 0.1 | 1 | 0.1 | 7.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/07/2024 00:00 | 7.88 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 01:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 02:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 06:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 07:00 | 10.31 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 19/07/2024 08:00 | 34.1 | 0.11 | 95.71 | 0 | 24.6 | |
| 19/07/2024 09:00 | 34.36 | 0.2 | 94.99 | 0 | 21.9 | |
| 19/07/2024 10:00 | 34.36 | 0.21 | 95.08 | 0 | 21.9 | |
| 19/07/2024 11:00 | 34.27 | 0.24 | 95.04 | 0 | 21.9 | |
| 19/07/2024 12:00 | 22.14 | 0.21 | 92.06 | 0 | 45.7 | |
| 19/07/2024 13:00 | 34.37 | 0.19 | 94.62 | 0 | 23.6 | |
| 19/07/2024 14:00 | 34.26 | 0.21 | 94.82 | 0 | 21.4 | |
| 19/07/2024 15:00 | 34.18 | 0.2 | 94.54 | 0 | 21.4 | |
| 19/07/2024 16:00 | 34.15 | 0.17 | 94.53 | 0 | 20.9 | |
| 19/07/2024 17:00 | 34.01 | 0.17 | 94.49 | 0 | 20.7 | |
| 19/07/2024 18:00 | 33.88 | 0.16 | 94.5 | 0 | 20.6 | |
| 19/07/2024 19:00 | 33.73 | 0.13 | 94.44 | 0 | 22.9 | |
| 19/07/2024 20:00 | 33.98 | 0.06 | 94.36 | 0 | 21.2 | |
| 19/07/2024 21:00 | 34.22 | 0 | 94.66 | 0 | 21.2 | |
| 19/07/2024 22:00 | 37.24 | 0.02 | 96.14 | 0 | 22.5 | |
| 19/07/2024 23:00 | 39.08 | 0.46 | 97.65 | 0 | 23.7 | |
| 20/07/2024 00:00 | 9.66 | 0.17 | ShutDown | ShutDown | ShutDown | |
| Minimum | 0 | 0 | 92.06 | 0 | 20.6 | |
| MinDate | 19/07/2024 01:00 | 19/07/2024 03:00 | 19/07/2024 12:00 | 19/07/2024 08:00 | 19/07/2024 18:00 | |
| Maximum | 39.08 | 0.46 | 97.65 | 0 | 45.7 | |
| MaxDate | 19/07/2024 23:00 | 19/07/2024 23:00 | 19/07/2024 23:00 | 19/07/2024 08:00 | 19/07/2024 12:00 | |
| Avg | 22.81 | 0.13 | 94.85 | 0 | 23.5 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 15.6 | 0.1 | 1.1 | 0 | 6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|-----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/07/2024 00:00 | 43.16 | 0 | 97.07 | 1.8 | 37.9 | |
| 20/07/2024 01:00 | 48.61 | 0 | 95.56 | 1.8 | 37.6 | |
| 20/07/2024 02:00 | 48.58 | 0 | 95.35 | 1.8 | 37.5 | |
| 20/07/2024 03:00 | 48.72 | 0 | 95.35 | 1.8 | 37.7 | |
| 20/07/2024 04:00 | 48.73 | 0 | 95.33 | 1.8 | 37.2 | |
| 20/07/2024 05:00 | 48.74 | 0.01 | 95.44 | 1.8 | 37.1 | |
| 20/07/2024 06:00 | 21.14 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 trip |
| 20/07/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 trip |
| 20/07/2024 08:00 | 4.73 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 trip |
| 20/07/2024 09:00 | 18.55 | 0.05 | <Samp | <Samp | <Samp | GT11 trip |
| 20/07/2024 10:00 | 44.56 | 0 | 101.93 | 2.3 | 37.4 | |
| 20/07/2024 11:00 | 47.67 | 0 | 97.95 | 2.2 | 42.4 | |
| 20/07/2024 12:00 | 47.16 | 0 | 97.45 | 2.2 | 42.7 | |
| 20/07/2024 13:00 | 47.32 | 0 | 98.19 | 2.2 | 42.6 | |
| 20/07/2024 14:00 | 47.6 | 0 | 98.8 | 2.2 | 41.9 | |
| 20/07/2024 15:00 | 47.71 | 0 | 98.76 | 2.2 | 41.8 | |
| 20/07/2024 16:00 | 47.88 | 0 | 98.61 | 2.2 | 41.7 | |
| 20/07/2024 17:00 | 47.92 | 0 | 98.59 | 2.2 | 41.6 | |
| 20/07/2024 18:00 | 48.04 | 0 | 98.62 | 2.1 | 41.9 | |
| 20/07/2024 19:00 | 48.3 | 0 | 98.66 | 2.1 | 41.4 | |
| 20/07/2024 20:00 | 48.46 | 0 | 98.83 | 2.1 | 41.2 | |
| 20/07/2024 21:00 | 48.53 | 0 | 99.35 | 2.1 | 41.1 | |
| 20/07/2024 22:00 | 48.59 | 0 | 99.65 | 2.1 | 40.9 | |
| 20/07/2024 23:00 | 48.45 | 0 | 99.54 | 2.1 | 41.1 | |
| 21/07/2024 00:00 | 48.44 | 0 | 99.38 | 2.1 | 40.9 | |
| Minimum | 0 | 0 | 95.33 | 1.8 | 37.1 | |
| MinDate | 20/07/2024 07:00 | 20/07/2024 00:00 | 20/07/2024 04:00 | 20/07/2024 00:00 | 20/07/2024 05:00 | |
| Maximum | 48.74 | 0.23 | 101.93 | 2.3 | 42.7 | |
| MaxDate | 20/07/2024 05:00 | 20/07/2024 06:00 | 20/07/2024 10:00 | 20/07/2024 10:00 | 20/07/2024 12:00 | |
| Avg | 41.9 | 0.01 | 98.02 | 2.1 | 40.3 | |
| Num | 25 | 25 | 21 | 21 | 21 | |
| Data[%] | 100 | 100 | 84 | 84 | 84 | |
| STD | 14.3 | 0 | 1.8 | 0.2 | 2.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/07/2024 00:00 | 9.66 | 0.17 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 02:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 03:00 | 0 | 0.05 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 04:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 05:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 06:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 07:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 08:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 09:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 10:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 11:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 12:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 13:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 14:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 15:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 16:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 17:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 18:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 19:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 20:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 21:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 20/07/2024 23:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 21/07/2024 00:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 0 | 0 | --- | --- | --- | |
| MinDate | 20/07/2024 01:00 | 20/07/2024 20:00 | 20/07/2024 00:00 | 20/07/2024 00:00 | 20/07/2024 00:00 | |
| Maximum | 9.66 | 0.38 | --- | --- | --- | |
| MaxDate | 20/07/2024 00:00 | 20/07/2024 23:00 | 20/07/2024 00:00 | 20/07/2024 00:00 | 20/07/2024 00:00 | |
| Avg | 0.39 | 0.12 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 1.9 | 0.1 | --- | --- | --- | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/07/2024 00:00 | 48.44 | 0 | 99.38 | 2.1 | 40.9 | |
| 21/07/2024 01:00 | 48.46 | 0 | 99.35 | 2.2 | 40.7 | |
| 21/07/2024 02:00 | 48.4 | 0 | 99.43 | 2.2 | 40.6 | |
| 21/07/2024 03:00 | 48.44 | 0 | 99.53 | 2.2 | 40.4 | |
| 21/07/2024 04:00 | 48.46 | 0 | 99.63 | 2.2 | 40 | |
| 21/07/2024 05:00 | 48.46 | 0 | 99.7 | 2.2 | 39.9 | |
| 21/07/2024 06:00 | 48.57 | 0.17 | 99.79 | 2.2 | 39.7 | |
| 21/07/2024 07:00 | 48.33 | 0 | 99.63 | 2.2 | 40.1 | |
| 21/07/2024 08:00 | 48.17 | 0 | 99.57 | 2.2 | 39.5 | |
| 21/07/2024 09:00 | 47.89 | 0 | 99.71 | 2.2 | 39.5 | |
| 21/07/2024 10:00 | 47.67 | 0 | 99.6 | 2.2 | 39.8 | |
| 21/07/2024 11:00 | 47.52 | 0 | 99.46 | 2.2 | 39.7 | |
| 21/07/2024 12:00 | 47.22 | 0 | 97 | 2.2 | 39.9 | |
| 21/07/2024 13:00 | 46.94 | 0 | 95.36 | 2.2 | 39.9 | |
| 21/07/2024 14:00 | 46.83 | 0 | 95.03 | 2.1 | 39.9 | |
| 21/07/2024 15:00 | 46.64 | 0 | 94.79 | 2.1 | 39.7 | |
| 21/07/2024 16:00 | 46.72 | 0 | 94.63 | 2.1 | 39.5 | |
| 21/07/2024 17:00 | 47.01 | 0 | 94.55 | 2.1 | 39.5 | |
| 21/07/2024 18:00 | 47.31 | 0 | 94.58 | 2.1 | 39.2 | |
| 21/07/2024 19:00 | 47.8 | 0 | 94.74 | 2.1 | 38.5 | |
| 21/07/2024 20:00 | 48.03 | 0 | 94.81 | 2.1 | 38.5 | |
| 21/07/2024 21:00 | 48.27 | 0 | 95.22 | 2 | 38.2 | |
| 21/07/2024 22:00 | 48.28 | 0 | 95.37 | 2.1 | 37.9 | |
| 21/07/2024 23:00 | 48.36 | 0 | 95.61 | 2.1 | 37.7 | |
| 22/07/2024 00:00 | 48.43 | 0 | 95.2 | 2.1 | 37.8 | |
| Minimum | 46.64 | 0 | 94.55 | 2 | 37.7 | |
| MinDate | 21/07/2024 15:00 | 21/07/2024 00:00 | 21/07/2024 17:00 | 21/07/2024 21:00 | 21/07/2024 23:00 | |
| Maximum | 48.57 | 0.17 | 99.79 | 2.2 | 40.9 | |
| MaxDate | 21/07/2024 06:00 | 21/07/2024 06:00 | 21/07/2024 06:00 | 21/07/2024 01:00 | 21/07/2024 00:00 | |
| Avg | 47.87 | 0.01 | 97.27 | 2.1 | 39.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 0.6 | 0 | 2.3 | 0.1 | 0.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/07/2024 00:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 01:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 02:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 03:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 04:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 05:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 06:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 07:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 08:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 09:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 10:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 11:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 12:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 13:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 14:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 15:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 16:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 17:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 18:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 19:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 20:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 21:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 22:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/07/2024 23:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 00:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.01 | --- | --- | --- | |
| MinDate | 21/07/2024 00:00 | 21/07/2024 22:00 | 21/07/2024 00:00 | 21/07/2024 00:00 | 21/07/2024 00:00 | |
| Maximum | 0 | 0.32 | --- | --- | --- | |
| MaxDate | 21/07/2024 00:00 | 21/07/2024 23:00 | 21/07/2024 00:00 | 21/07/2024 00:00 | 21/07/2024 00:00 | |
| Avg | 0 | 0.21 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/07/2024 00:00 | 48.43 | 0 | 95.2 | 2.1 | 37.8 | |
| 22/07/2024 01:00 | 48.37 | 0 | 95.49 | 2.1 | 37.4 | |
| 22/07/2024 02:00 | 48.44 | 0 | 95.63 | 2.1 | 37.4 | |
| 22/07/2024 03:00 | 48.47 | 0 | 95.56 | 2.1 | 37.5 | |
| 22/07/2024 04:00 | 48.42 | 0 | 95.59 | 2.1 | 37.8 | |
| 22/07/2024 05:00 | 48.62 | 0 | 95.67 | 2.1 | 37.5 | |
| 22/07/2024 06:00 | 48.64 | 0.34 | 95.78 | 2.1 | 37.2 | |
| 22/07/2024 07:00 | 48.49 | 0 | 95.81 | 2.1 | 37.2 | |
| 22/07/2024 08:00 | 48.11 | 0 | 95.48 | 2.1 | 37.4 | |
| 22/07/2024 09:00 | 47.31 | 0 | 95.66 | 2.2 | 35.5 | |
| 22/07/2024 10:00 | 47.09 | 0 | 95.64 | 2.2 | 36.3 | |
| 22/07/2024 11:00 | 47 | 0 | 95.56 | 2.2 | 36.9 | |
| 22/07/2024 12:00 | 46.94 | 0 | 95.61 | 2.2 | 37 | |
| 22/07/2024 13:00 | 47.12 | 0 | 95.53 | 2.1 | 37.9 | |
| 22/07/2024 14:00 | 47.18 | 0 | 95.43 | 2.1 | 38.2 | |
| 22/07/2024 15:00 | 47.19 | 0 | 94.93 | 2.1 | 37.6 | |
| 22/07/2024 16:00 | 45.91 | 0 | 95.2 | 2.1 | 33.9 | |
| 22/07/2024 17:00 | 26.88 | 0 | 92.14 | 2.2 | 45.8 | |
| 22/07/2024 18:00 | 30.98 | 0 | 93.14 | 2.1 | 33.1 | |
| 22/07/2024 19:00 | 33.01 | 0 | 93.46 | 2 | 26.9 | |
| 22/07/2024 20:00 | 32.93 | 0 | 93.46 | 2 | 27 | |
| 22/07/2024 21:00 | 32.95 | 0 | 93.77 | 2 | 27.1 | |
| 22/07/2024 22:00 | 32.93 | 0 | 93.87 | 2 | 27.2 | |
| 22/07/2024 23:00 | 7.75 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 92.14 | 2 | 26.9 | |
| MinDate | 23/07/2024 00:00 | 22/07/2024 00:00 | 22/07/2024 17:00 | 22/07/2024 19:00 | 22/07/2024 19:00 | |
| Maximum | 48.64 | 0.34 | 95.81 | 2.2 | 45.8 | |
| MaxDate | 22/07/2024 06:00 | 22/07/2024 06:00 | 22/07/2024 07:00 | 22/07/2024 09:00 | 22/07/2024 17:00 | |
| Avg | 40.37 | 0.01 | 94.94 | 2.1 | 35.5 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.1 | 0.1 | 1.1 | 0.1 | 4.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/07/2024 00:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 01:00 | 0 | 0.14 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 02:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 03:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 04:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 05:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 06:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 07:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 08:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 09:00 | 0 | 0.35 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 10:00 | 0 | 0.37 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 11:00 | 0 | 0.41 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 12:00 | 0 | 0.4 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 13:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 14:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 15:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 16:00 | 1.99 | 0.3 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/07/2024 17:00 | 24.37 | 0.29 | 89.21 | 0 | 47.9 | |
| 22/07/2024 18:00 | 35.33 | 0.3 | 95.26 | 0 | 26.4 | |
| 22/07/2024 19:00 | 32.94 | 0.3 | 94.16 | 0 | 24.1 | |
| 22/07/2024 20:00 | 32.86 | 0.25 | 94.12 | 0 | 24.4 | |
| 22/07/2024 21:00 | 32.89 | 0.2 | 94.28 | 0 | 24.6 | |
| 22/07/2024 22:00 | 32.87 | 0.25 | 94.31 | 0 | 24.6 | |
| 22/07/2024 23:00 | 39.38 | 0.23 | 95.39 | 0 | 36 | |
| 23/07/2024 00:00 | 46.85 | 0.05 | 96.3 | 0 | 33.7 | |
| Minimum | 0 | 0.05 | 89.21 | 0 | 24.1 | |
| MinDate | 22/07/2024 00:00 | 23/07/2024 00:00 | 22/07/2024 17:00 | 22/07/2024 17:00 | 22/07/2024 19:00 | |
| Maximum | 46.85 | 0.41 | 96.3 | 0 | 47.9 | |
| MaxDate | 23/07/2024 00:00 | 22/07/2024 11:00 | 23/07/2024 00:00 | 22/07/2024 17:00 | 22/07/2024 17:00 | |
| Avg | 11.18 | 0.27 | 94.13 | 0 | 30.2 | |
| Num | 25 | 25 | 8 | 8 | 8 | |
| Data[%] | 100 | 100 | 32 | 32 | 32 | |
| STD | 16.8 | 0.1 | 2.1 | 0 | 8.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/07/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 06:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 07:00 | 10.44 | 0.08 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 23/07/2024 08:00 | 33.81 | 0 | 94.97 | 2.2 | 31.9 | |
| 23/07/2024 09:00 | 34.12 | 0 | 95.15 | 2.2 | 29.3 | |
| 23/07/2024 10:00 | 34.1 | 0 | 95.16 | 2.2 | 29.7 | |
| 23/07/2024 11:00 | 34.19 | 0 | 95.32 | 2.2 | 29.8 | |
| 23/07/2024 12:00 | 21.96 | 0 | 92.41 | 2.4 | 52.9 | |
| 23/07/2024 13:00 | 34.59 | 0 | 94.76 | 2.2 | 31.4 | |
| 23/07/2024 14:00 | 34.5 | 0 | 95.3 | 2.2 | 29.8 | |
| 23/07/2024 15:00 | 34.49 | 0 | 94.85 | 2.1 | 29.6 | |
| 23/07/2024 16:00 | 34.34 | 0 | 94.55 | 2.1 | 31 | |
| 23/07/2024 17:00 | 34.17 | 0 | 94.35 | 2.1 | 29 | |
| 23/07/2024 18:00 | 34.1 | 0 | 94.12 | 2.1 | 29 | |
| 23/07/2024 19:00 | 34.03 | 0 | 93.91 | 2.1 | 28.5 | |
| 23/07/2024 20:00 | 34.08 | 0 | 94.21 | 2.1 | 28.4 | |
| 23/07/2024 21:00 | 34.25 | 0 | 94.37 | 2.1 | 28.6 | |
| 23/07/2024 22:00 | 34.28 | 0 | 94.41 | 2.1 | 28.5 | |
| 23/07/2024 23:00 | 34.17 | 0 | 94.48 | 2.1 | 28.3 | |
| 24/07/2024 00:00 | 40.63 | 0 | 95.08 | 2.1 | 42.9 | |
| Minimum | 0 | 0 | 92.41 | 2.1 | 28.3 | |
| MinDate | 23/07/2024 00:00 | 23/07/2024 00:00 | 23/07/2024 12:00 | 23/07/2024 15:00 | 23/07/2024 23:00 | |
| Maximum | 40.63 | 0.28 | 95.32 | 2.4 | 52.9 | |
| MaxDate | 24/07/2024 00:00 | 23/07/2024 06:00 | 23/07/2024 11:00 | 23/07/2024 12:00 | 23/07/2024 12:00 | |
| Avg | 23.45 | 0.01 | 94.55 | 2.2 | 31.7 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.9 | 0.1 | 0.7 | 0.1 | 6.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/07/2024 00:00 | 46.85 | 0.05 | 96.3 | 0 | 33.7 | |
| 23/07/2024 01:00 | 46.98 | 0.07 | 96.46 | 0 | 33.7 | |
| 23/07/2024 02:00 | 47.02 | 0.09 | 96.63 | 0 | 33.8 | |
| 23/07/2024 03:00 | 46.95 | 0.03 | 96.63 | 0 | 33.3 | |
| 23/07/2024 04:00 | 46.94 | 0 | 96.71 | 0 | 33.1 | |
| 23/07/2024 05:00 | 47.02 | 0.02 | 96.69 | 0 | 33.3 | |
| 23/07/2024 06:00 | 47.06 | 0.06 | 96.66 | 0 | 34.6 | |
| 23/07/2024 07:00 | 38.78 | 0.09 | 95.62 | 0 | 35.6 | |
| 23/07/2024 08:00 | 33.79 | 0.11 | 94.75 | 0 | 23.9 | |
| 23/07/2024 09:00 | 34.05 | 0.15 | 94.79 | 0 | 20.8 | |
| 23/07/2024 10:00 | 34.04 | 0.19 | 94.8 | 0 | 21.2 | |
| 23/07/2024 11:00 | 34.12 | 0.21 | 95.14 | 0 | 21.2 | |
| 23/07/2024 12:00 | 21.89 | 0.22 | 92.27 | 0 | 47.2 | |
| 23/07/2024 13:00 | 34.5 | 0.19 | 94.62 | 0 | 22.9 | |
| 23/07/2024 14:00 | 34.44 | 0.16 | 95.13 | 0 | 21.2 | |
| 23/07/2024 15:00 | 34.42 | 0.15 | 94.78 | 0 | 21 | |
| 23/07/2024 16:00 | 34.26 | 0.1 | 94.56 | 0 | 22.2 | |
| 23/07/2024 17:00 | 34.1 | 0.09 | 94.34 | 0 | 20.5 | |
| 23/07/2024 18:00 | 34.02 | 0.05 | 94.09 | 0 | 20.5 | |
| 23/07/2024 19:00 | 33.96 | 0.01 | 93.96 | 0 | 20.2 | |
| 23/07/2024 20:00 | 34.02 | 0.01 | 94.23 | 0 | 20.2 | |
| 23/07/2024 21:00 | 34.18 | 0.01 | 94.18 | 0 | 20.5 | |
| 23/07/2024 22:00 | 34.2 | 0 | 94.25 | 0 | 20.3 | |
| 23/07/2024 23:00 | 34.1 | 0.42 | 94.35 | 0 | 20.1 | |
| 24/07/2024 00:00 | 7.66 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.66 | 0 | 92.27 | 0 | 20.1 | |
| MinDate | 24/07/2024 00:00 | 23/07/2024 04:00 | 23/07/2024 12:00 | 23/07/2024 00:00 | 23/07/2024 23:00 | |
| Maximum | 47.06 | 0.42 | 96.71 | 0 | 47.2 | |
| MaxDate | 23/07/2024 06:00 | 23/07/2024 23:00 | 23/07/2024 04:00 | 23/07/2024 00:00 | 23/07/2024 12:00 | |
| Avg | 36.37 | 0.1 | 95.08 | 0 | 26.5 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 8.9 | 0.1 | 1.2 | 0 | 7.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/07/2024 00:00 | 40.63 | 0 | 95.08 | 2.1 | 42.9 | |
| 24/07/2024 01:00 | 48.52 | 0 | 95.3 | 2.1 | 40.4 | |
| 24/07/2024 02:00 | 48.41 | 0 | 95.58 | 2.1 | 40.4 | |
| 24/07/2024 03:00 | 48.38 | 0 | 95.55 | 2.1 | 40.3 | |
| 24/07/2024 04:00 | 48.46 | 0 | 95.58 | 2.1 | 40 | |
| 24/07/2024 05:00 | 48.47 | 0 | 95.35 | 2.1 | 40.1 | |
| 24/07/2024 06:00 | 48.65 | 0.21 | 95.53 | 2.1 | 39.7 | |
| 24/07/2024 07:00 | 39.95 | 0 | 95.9 | 2.2 | 39.8 | |
| 24/07/2024 08:00 | 33.99 | 0 | 94.16 | 2.2 | 30.6 | |
| 24/07/2024 09:00 | 34.49 | 0 | 52.63 | 2.2 | 26.9 | PICO pm CEMs |
| 24/07/2024 10:00 | 34.43 | 0.06 | 0 | 2.4 | 24.9 | PICO pm CEMs |
| 24/07/2024 11:00 | 34.45 | 0 | 0 | 2.4 | 24.9 | PICO pm CEMs |
| 24/07/2024 12:00 | 21.92 | 0 | 0 | 2.6 | 47.7 | PICO pm CEMs |
| 24/07/2024 13:00 | 34.45 | 0 | 0 | 2.4 | 26.1 | PICO pm CEMs |
| 24/07/2024 14:00 | 34.64 | 0 | 0 | 2.3 | 24.7 | PICO pm CEMs |
| 24/07/2024 15:00 | 34.58 | 1.02 | 0 | 2.3 | 21 | PICO pm CEMs |
| 24/07/2024 16:00 | 34.48 | 0.41 | 82.81 | 2.3 | 25.8 | PICO pm CEMs |
| 24/07/2024 17:00 | 34.27 | 1.47 | 92.92 | 2.3 | 23.8 | |
| 24/07/2024 18:00 | 34.16 | 0.49 | 93.18 | 2.3 | 24 | |
| 24/07/2024 19:00 | 34 | 0.41 | 93.3 | 2.3 | 23.8 | |
| 24/07/2024 20:00 | 34.23 | 0.35 | 93.43 | 2.3 | 23.9 | |
| 24/07/2024 21:00 | 34.4 | 0.32 | 93.95 | 2.3 | 23.9 | |
| 24/07/2024 22:00 | 34.45 | 0.42 | 94.06 | 2.3 | 23.8 | |
| 24/07/2024 23:00 | 34.27 | 0.51 | 94.12 | 2.3 | 23.5 | |
| 25/07/2024 00:00 | 7.48 | 0.57 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.48 | 0 | 0 | 2.1 | 21 | |
| MinDate | 25/07/2024 00:00 | 24/07/2024 00:00 | 24/07/2024 10:00 | 24/07/2024 00:00 | 24/07/2024 15:00 | |
| Maximum | 48.65 | 1.47 | 95.9 | 2.6 | 47.7 | |
| MaxDate | 24/07/2024 06:00 | 24/07/2024 17:00 | 24/07/2024 07:00 | 24/07/2024 12:00 | 24/07/2024 12:00 | |
| Avg | 36.65 | 0.25 | 68.68 | 2.3 | 31 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.2 | 0.4 | 41.4 | 0.1 | 8.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/07/2024 00:00 | 7.66 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 02:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 03:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 04:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 05:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 07:00 | 10.3 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/07/2024 08:00 | 33.89 | 0.12 | 95.46 | 0 | 25.6 | |
| 24/07/2024 09:00 | 34.43 | 0.16 | 94.94 | 0 | 16.4 | |
| 24/07/2024 10:00 | 34.37 | 0.09 | 94.71 | 1.5 | 29.6 | |
| 24/07/2024 11:00 | 34.38 | 0.08 | 12.52 | 0 | 21.8 | PICO pm CEMs |
| 24/07/2024 12:00 | 21.88 | 0.08 | 0 | 0 | 53.6 | PICO pm CEMs |
| 24/07/2024 13:00 | 34.81 | 0.05 | 0 | <Samp | <Samp | PICO pm CEMs |
| 24/07/2024 14:00 | 34.51 | 0.01 | 0 | <Samp | <Samp | PICO pm CEMs |
| 24/07/2024 15:00 | 34.51 | 0.29 | 48.22 | 0 | 24.7 | PICO pm CEMs |
| 24/07/2024 16:00 | 34.41 | 0.2 | 94.66 | 0 | 26.1 | |
| 24/07/2024 17:00 | 34.2 | 0.08 | 93.74 | 0 | 24.1 | |
| 24/07/2024 18:00 | 34.09 | 0.02 | 93.92 | 0 | 24.3 | |
| 24/07/2024 19:00 | 33.94 | 0.05 | 94.07 | 0 | 23.9 | |
| 24/07/2024 20:00 | 34.17 | 0.07 | 94.17 | 0 | 24.2 | |
| 24/07/2024 21:00 | 34.34 | 0.06 | 94.54 | 0 | 24.1 | |
| 24/07/2024 22:00 | 34.39 | 0.1 | 94.62 | 0 | 23.8 | |
| 24/07/2024 23:00 | 34.2 | 0.12 | 94.68 | 0 | 23.5 | |
| 25/07/2024 00:00 | 40.7 | 0.17 | 95.61 | 0 | 42.2 | |
| Minimum | 0 | 0 | 0 | 0 | 16.4 | |
| MinDate | 24/07/2024 01:00 | 24/07/2024 06:00 | 24/07/2024 12:00 | 24/07/2024 08:00 | 24/07/2024 09:00 | |
| Maximum | 40.7 | 0.29 | 95.61 | 1.5 | 42.2 | |
| MaxDate | 25/07/2024 00:00 | 24/07/2024 15:00 | 25/07/2024 00:00 | 24/07/2024 13:00 | 24/07/2024 13:00 | |
| Avg | 23.81 | 0.08 | 70.34 | 0.1 | 36.5 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 40.1 | 24 | 27.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/07/2024 00:00 | 7.48 | 0.57 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 01:00 | 0 | 0.4 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 02:00 | 0 | 0.36 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 03:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 04:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 05:00 | 0 | 0.4 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 06:00 | 0 | 0.85 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 07:00 | 11.19 | 1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/07/2024 08:00 | 34.56 | 0.7 | 94.94 | 2.4 | 27 | |
| 25/07/2024 09:00 | 34.54 | 0.69 | 95 | 2221.4 | 489.8 | PM CEMs |
| 25/07/2024 10:00 | 34.6 | 0.65 | 95.12 | 479.3 | 110.6 | PM CEMs |
| 25/07/2024 11:00 | 34.51 | 0.82 | 94.98 | 2.2 | 29.3 | |
| 25/07/2024 12:00 | 22.44 | 0.86 | 92.43 | 2.1 | 51.2 | |
| 25/07/2024 13:00 | 34.59 | 0.66 | 94.57 | 2 | 30.6 | |
| 25/07/2024 14:00 | 34.49 | 1.11 | 94.65 | 3 | 38.2 | |
| 25/07/2024 15:00 | 34.46 | 1.13 | 94.68 | 0 | 26.2 | |
| 25/07/2024 16:00 | 34.43 | 0.98 | 94.54 | 0 | 26 | |
| 25/07/2024 17:00 | 34.31 | 0.89 | 94.41 | 0 | 26.1 | |
| 25/07/2024 18:00 | 34.29 | 0.83 | 94.41 | 0 | 25.9 | |
| 25/07/2024 19:00 | 34.15 | 1.06 | 94.35 | 0 | 25.6 | |
| 25/07/2024 20:00 | 34.27 | 1.18 | 94.18 | 0 | 25.5 | |
| 25/07/2024 21:00 | 34.42 | 1.13 | 94.62 | 0 | 25.5 | |
| 25/07/2024 22:00 | 34.33 | 1.02 | 94.71 | 0 | 25.4 | |
| 25/07/2024 23:00 | 34.22 | 0.94 | 94.6 | 0 | 25.3 | |
| 26/07/2024 00:00 | 40.67 | 0.86 | 95.35 | 0 | 40.7 | |
| Minimum | 0 | 0.33 | 92.43 | 0 | 25.3 | |
| MinDate | 25/07/2024 01:00 | 25/07/2024 03:00 | 25/07/2024 12:00 | 25/07/2024 15:00 | 25/07/2024 23:00 | |
| Maximum | 40.67 | 1.18 | 95.35 | 3 | 38.2 | |
| MaxDate | 26/07/2024 00:00 | 25/07/2024 20:00 | 26/07/2024 00:00 | 25/07/2024 09:00 | 25/07/2024 09:00 | |
| Avg | 23.92 | 0.79 | 94.56 | 159.6 | 61.7 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.3 | 0.6 | 543.8 | 112.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/07/2024 00:00 | 40.7 | 0.17 | 95.61 | 0 | 42.2 | |
| 25/07/2024 01:00 | 48.18 | 0.19 | 95.23 | 0 | 43.3 | |
| 25/07/2024 02:00 | 48.22 | 0.19 | 95.41 | 0 | 43.2 | |
| 25/07/2024 03:00 | 48.22 | 0.17 | 95.56 | 0 | 43 | |
| 25/07/2024 04:00 | 48.33 | 0.15 | 95.58 | 0 | 42.8 | |
| 25/07/2024 05:00 | 48.23 | 0.13 | 95.52 | 0 | 42.5 | |
| 25/07/2024 06:00 | 48.1 | 0.19 | 95.72 | 0 | 42.1 | |
| 25/07/2024 07:00 | 39.03 | 0.21 | 95.15 | 0 | 39.5 | |
| 25/07/2024 08:00 | 34.43 | 0.21 | 94.84 | 0 | 24.5 | |
| 25/07/2024 09:00 | 34.48 | 0.22 | 94.98 | 0 | 23 | |
| 25/07/2024 10:00 | 34.53 | 0.23 | 95 | 0 | 23.2 | |
| 25/07/2024 11:00 | 34.46 | 0.2 | 94.59 | 0 | 22.7 | |
| 25/07/2024 12:00 | 22.38 | 0.17 | 92.07 | 0 | 46 | |
| 25/07/2024 13:00 | 34.41 | 0.2 | 94.54 | 0 | 24.4 | |
| 25/07/2024 14:00 | 34.42 | 0.14 | 94.63 | 0 | 22.2 | |
| 25/07/2024 15:00 | 34.39 | 0.43 | 94.57 | 0 | 22.1 | |
| 25/07/2024 16:00 | 34.36 | 0.1 | 94.48 | 0 | 22.1 | |
| 25/07/2024 17:00 | 34.24 | 0.1 | 94.35 | 0 | 22.2 | |
| 25/07/2024 18:00 | 34.23 | 0.1 | 94.34 | 0 | 22.3 | |
| 25/07/2024 19:00 | 34.09 | 0.13 | 94.32 | 0 | 22.1 | |
| 25/07/2024 20:00 | 34.2 | 0.1 | 94.22 | 0 | 22.1 | |
| 25/07/2024 21:00 | 34.35 | 0.09 | 94.5 | 0 | 22.1 | |
| 25/07/2024 22:00 | 34.27 | 0.1 | 94.53 | 0 | 22.1 | |
| 25/07/2024 23:00 | 34.15 | 0.1 | 94.46 | 0 | 22 | |
| 26/07/2024 00:00 | 7.6 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.6 | 0.08 | 92.07 | 0 | 22 | |
| MinDate | 26/07/2024 00:00 | 26/07/2024 00:00 | 25/07/2024 12:00 | 25/07/2024 00:00 | 25/07/2024 23:00 | |
| Maximum | 48.33 | 0.43 | 95.72 | 0 | 46 | |
| MaxDate | 25/07/2024 04:00 | 25/07/2024 15:00 | 25/07/2024 06:00 | 25/07/2024 00:00 | 25/07/2024 12:00 | |
| Avg | 36.56 | 0.16 | 94.76 | 0 | 30.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9 | 0.1 | 0.8 | 0 | 10 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/07/2024 00:00 | 40.67 | 0.86 | 95.35 | 0 | 40.7 | |
| 26/07/2024 01:00 | 48.44 | 0.82 | 95.02 | 0 | 38.2 | |
| 26/07/2024 02:00 | 48.34 | 0.78 | 95.38 | 0 | 38.2 | |
| 26/07/2024 03:00 | 48.35 | 0.77 | 95.53 | 0 | 38 | |
| 26/07/2024 04:00 | 48.39 | 0.81 | 95.47 | 0 | 37.9 | |
| 26/07/2024 05:00 | 48.39 | 0.93 | 95.46 | 0 | 37.7 | |
| 26/07/2024 06:00 | 48.45 | 0.98 | 95.87 | 0 | 37.4 | |
| 26/07/2024 07:00 | 39.92 | 0.68 | 95.67 | 0 | 37.2 | |
| 26/07/2024 08:00 | 34.16 | 0.79 | 94.95 | 0 | 27.1 | |
| 26/07/2024 09:00 | 34.53 | 0.72 | 95.26 | 0 | 24.3 | |
| 26/07/2024 10:00 | 34.59 | 0.64 | 95.23 | 0 | 24.4 | |
| 26/07/2024 11:00 | 34.54 | 0.74 | 95.28 | 0 | 24.2 | |
| 26/07/2024 12:00 | 22.41 | 1.29 | 92.26 | 0 | 45.9 | |
| 26/07/2024 13:00 | 34.61 | 0.76 | 94.69 | 0 | 25.6 | |
| 26/07/2024 14:00 | 34.55 | 0.61 | 95.14 | 0 | 24.2 | |
| 26/07/2024 15:00 | 34.51 | 0.61 | 94.81 | 0 | 23.9 | |
| 26/07/2024 16:00 | 34.43 | 1.16 | 93.95 | 0 | 23.7 | |
| 26/07/2024 17:00 | 34.31 | 1.4 | 94.22 | 0 | 23.5 | |
| 26/07/2024 18:00 | 34.19 | 1.25 | 94.47 | 0 | 23.1 | |
| 26/07/2024 19:00 | 34.13 | 0.91 | 94.66 | 0 | 23.1 | |
| 26/07/2024 20:00 | 34.27 | 0.79 | 94.48 | 0 | 23.3 | |
| 26/07/2024 21:00 | 34.53 | 0.9 | 94.93 | 0 | 23.4 | |
| 26/07/2024 22:00 | 37.73 | 0.85 | 96.63 | 0 | 24.8 | |
| 26/07/2024 23:00 | 38.34 | 0.97 | 97.53 | 0 | 25.1 | |
| 27/07/2024 00:00 | 28.22 | 1.22 | 93.9 | 0 | 41.1 | |
| Minimum | 22.41 | 0.61 | 92.26 | 0 | 23.1 | |
| MinDate | 26/07/2024 12:00 | 26/07/2024 14:00 | 26/07/2024 12:00 | 26/07/2024 00:00 | 26/07/2024 18:00 | |
| Maximum | 48.45 | 1.4 | 97.53 | 0 | 45.9 | |
| MaxDate | 26/07/2024 06:00 | 26/07/2024 17:00 | 26/07/2024 23:00 | 26/07/2024 00:00 | 26/07/2024 12:00 | |
| Avg | 37.8 | 0.89 | 95.05 | 0 | 30.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7 | 0.2 | 1 | 0 | 7.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/07/2024 00:00 | 7.6 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 01:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 02:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 03:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 04:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 05:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 06:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 07:00 | 10.33 | 0.19 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/07/2024 08:00 | 33.99 | 0.23 | 95.52 | 0 | 26.9 | |
| 26/07/2024 09:00 | 34.47 | 0.25 | 95.18 | 0 | 24.2 | |
| 26/07/2024 10:00 | 34.52 | 0.25 | 95.05 | 0 | 24.3 | |
| 26/07/2024 11:00 | 34.48 | 0.25 | 95.1 | 0 | 24.2 | |
| 26/07/2024 12:00 | 22.28 | 0.19 | 92.11 | 0 | 46.4 | |
| 26/07/2024 13:00 | 34.46 | 0.2 | 94.59 | 0 | 25.3 | |
| 26/07/2024 14:00 | 34.48 | 0.2 | 94.98 | 0 | 23.8 | |
| 26/07/2024 15:00 | 34.44 | 0.37 | 94.88 | 0 | 23.6 | |
| 26/07/2024 16:00 | 34.36 | 0.05 | 94.14 | 0 | 23.4 | |
| 26/07/2024 17:00 | 34.24 | 0 | 94.34 | 0 | 23.2 | |
| 26/07/2024 18:00 | 34.14 | 0.02 | 94.53 | 0 | 22.8 | |
| 26/07/2024 19:00 | 34.06 | 0.04 | 94.75 | 0 | 22.8 | |
| 26/07/2024 20:00 | 34.19 | 0.06 | 94.63 | 0 | 23.2 | |
| 26/07/2024 21:00 | 34.46 | 0.04 | 94.94 | 0 | 23.2 | |
| 26/07/2024 22:00 | 37.65 | 0.04 | 96.56 | 0 | 24.4 | |
| 26/07/2024 23:00 | 38.27 | 0 | 97.38 | 0 | 24.6 | |
| 27/07/2024 00:00 | 28.16 | 0 | 93.75 | 0 | 39.2 | |
| Minimum | 0 | 0 | 92.11 | 0 | 22.8 | |
| MinDate | 26/07/2024 01:00 | 26/07/2024 17:00 | 26/07/2024 12:00 | 26/07/2024 08:00 | 26/07/2024 18:00 | |
| Maximum | 38.27 | 0.37 | 97.38 | 0 | 46.4 | |
| MaxDate | 26/07/2024 23:00 | 26/07/2024 15:00 | 26/07/2024 23:00 | 26/07/2024 08:00 | 26/07/2024 12:00 | |
| Avg | 23.62 | 0.13 | 94.85 | 0 | 26.2 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.4 | 0.1 | 1.1 | 0 | 6.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/07/2024 00:00 | 28.22 | 1.22 | 93.9 | 0 | 41.1 | |
| 27/07/2024 01:00 | 28.88 | 1.12 | 93.22 | 0 | 40.5 | |
| 27/07/2024 02:00 | 29.06 | 0.89 | 93.27 | 0 | 40.2 | |
| 27/07/2024 03:00 | 29.01 | 0.65 | 93.49 | 0 | 40.3 | |
| 27/07/2024 04:00 | 28.92 | 0.68 | 93.43 | 0 | 40.4 | |
| 27/07/2024 05:00 | 28.89 | 0.93 | 93.27 | 0 | 40.2 | |
| 27/07/2024 06:00 | 28.91 | 1.43 | 93.29 | 0 | 40.1 | |
| 27/07/2024 07:00 | 28.81 | 1.38 | 93.3 | 0 | 39.7 | |
| 27/07/2024 08:00 | 42.76 | 0.91 | 99.2 | 0 | 27 | |
| 27/07/2024 09:00 | 42.81 | 0.84 | 100.84 | 0 | 26.3 | |
| 27/07/2024 10:00 | 42.8 | 0.8 | 100.94 | 0 | 26.3 | |
| 27/07/2024 11:00 | 42.74 | 0.73 | 101.12 | 0 | 26.4 | |
| 27/07/2024 12:00 | 28.7 | 0.8 | 95.07 | 0 | 38.8 | |
| 27/07/2024 13:00 | 42.75 | 0.62 | 99.44 | 0 | 27.6 | |
| 27/07/2024 14:00 | 42.83 | 0.6 | 101.02 | 0 | 26.4 | |
| 27/07/2024 15:00 | 42.78 | 0.63 | 100.57 | 0 | 26.1 | |
| 27/07/2024 16:00 | 42.64 | 1.01 | 99.86 | 0 | 25.9 | |
| 27/07/2024 17:00 | 42.49 | 0.86 | 99.78 | 0 | 25.8 | |
| 27/07/2024 18:00 | 42.46 | 1.24 | 99.74 | 0 | 25.5 | |
| 27/07/2024 19:00 | 42.3 | 2.36 | 99.37 | 0 | 25.4 | |
| 27/07/2024 20:00 | 42.55 | 2.19 | 99.75 | 0 | 25.3 | |
| 27/07/2024 21:00 | 42.72 | 1.81 | 100.4 | 0 | 25.2 | |
| 27/07/2024 22:00 | 42.65 | 1.75 | 100.45 | 0 | 25 | |
| 27/07/2024 23:00 | 42.52 | 1.93 | 100.21 | 0 | 25.1 | |
| 28/07/2024 00:00 | 28.48 | 2.47 | 94.12 | 0 | 39.7 | |
| Minimum | 28.22 | 0.6 | 93.22 | 0 | 25 | |
| MinDate | 27/07/2024 00:00 | 27/07/2024 14:00 | 27/07/2024 01:00 | 27/07/2024 00:00 | 27/07/2024 22:00 | |
| Maximum | 42.83 | 2.47 | 101.12 | 0 | 41.1 | |
| MaxDate | 27/07/2024 14:00 | 28/07/2024 00:00 | 27/07/2024 11:00 | 27/07/2024 00:00 | 27/07/2024 00:00 | |
| Avg | 37.11 | 1.19 | 97.56 | 0 | 31.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.9 | 0.6 | 3.3 | 0 | 7.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/07/2024 00:00 | 28.16 | 0 | 93.75 | 0 | 39.2 | |
| 27/07/2024 01:00 | 28.82 | 0 | 93.17 | 0 | 38.5 | |
| 27/07/2024 02:00 | 29 | 0 | 93.14 | 0 | 38.3 | |
| 27/07/2024 03:00 | 28.95 | 0 | 93.37 | 0 | 38.5 | |
| 27/07/2024 04:00 | 28.86 | 0.02 | 93.36 | 0 | 38.6 | |
| 27/07/2024 05:00 | 28.83 | 0.04 | 93.21 | 0 | 38.4 | |
| 27/07/2024 06:00 | 28.86 | 0 | 93.21 | 0 | 38.3 | |
| 27/07/2024 07:00 | 28.74 | 0.02 | 93.33 | 0 | 37.9 | |
| 27/07/2024 08:00 | 42.7 | 0.04 | 99.45 | 0 | 28.8 | |
| 27/07/2024 09:00 | 42.74 | 0.1 | 100.91 | 0 | 28.1 | |
| 27/07/2024 10:00 | 42.72 | 0.16 | 101 | 0 | 28.2 | |
| 27/07/2024 11:00 | 42.67 | 0.18 | 101.1 | 0 | 28.3 | |
| 27/07/2024 12:00 | 28.67 | 0.18 | 95.07 | 0 | 37.6 | |
| 27/07/2024 13:00 | 42.67 | 0.15 | 99.45 | 0 | 29.8 | |
| 27/07/2024 14:00 | 42.76 | 0.1 | 100.87 | 0 | 28.4 | |
| 27/07/2024 15:00 | 42.71 | 0.29 | 100.58 | 0 | 27.8 | |
| 27/07/2024 16:00 | 42.57 | 0.02 | 99.88 | 0 | 27 | |
| 27/07/2024 17:00 | 42.41 | 0 | 99.78 | 0 | 27 | |
| 27/07/2024 18:00 | 42.38 | 0 | 99.78 | 0 | 26.4 | |
| 27/07/2024 19:00 | 42.23 | 0 | 99.4 | 0 | 26.1 | |
| 27/07/2024 20:00 | 42.48 | 0 | 99.78 | 0 | 26.2 | |
| 27/07/2024 21:00 | 42.64 | 0 | 100.23 | 0 | 26.3 | |
| 27/07/2024 22:00 | 42.57 | 0 | 100.15 | 0 | 26 | |
| 27/07/2024 23:00 | 42.45 | 0 | 99.92 | 0 | 25.9 | |
| 28/07/2024 00:00 | 28.42 | 0 | 93.89 | 0 | 38.3 | |
| Minimum | 28.16 | 0 | 93.14 | 0 | 25.9 | |
| MinDate | 27/07/2024 00:00 | 27/07/2024 00:00 | 27/07/2024 02:00 | 27/07/2024 00:00 | 27/07/2024 23:00 | |
| Maximum | 42.76 | 0.29 | 101.1 | 0 | 39.2 | |
| MaxDate | 27/07/2024 14:00 | 27/07/2024 15:00 | 27/07/2024 11:00 | 27/07/2024 00:00 | 27/07/2024 00:00 | |
| Avg | 37.04 | 0.05 | 97.51 | 0 | 31.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.9 | 0.1 | 3.4 | 0 | 5.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/07/2024 00:00 | 28.48 | 2.47 | 94.12 | 0 | 39.7 | |
| 28/07/2024 01:00 | 28.58 | 1.95 | 92.7 | 0 | 40.7 | |
| 28/07/2024 02:00 | 28.52 | 2 | 92.69 | 0 | 40.9 | |
| 28/07/2024 03:00 | 28.42 | 2.13 | 92.63 | 0 | 41.2 | |
| 28/07/2024 04:00 | 28.12 | 2.59 | 92.57 | 0 | 41.6 | |
| 28/07/2024 05:00 | 27.83 | 2.21 | 92.54 | 0 | 42.3 | |
| 28/07/2024 06:00 | 27.71 | 1.64 | 92.79 | 0 | 42.4 | |
| 28/07/2024 07:00 | 27.54 | 0.9 | 92.91 | 0 | 42.5 | |
| 28/07/2024 08:00 | 27.48 | 2.03 | 92.66 | 0 | 42.3 | |
| 28/07/2024 09:00 | 27.49 | 1.89 | 92.99 | 0 | 41.7 | |
| 28/07/2024 10:00 | 27.57 | 0.88 | 93.32 | 0 | 41.4 | |
| 28/07/2024 11:00 | 27.59 | 0.94 | 93.18 | 0 | 41.1 | |
| 28/07/2024 12:00 | 27.61 | 0.88 | 93.07 | 0 | 40.9 | |
| 28/07/2024 13:00 | 27.61 | 0.81 | 93.23 | 0 | 40.9 | |
| 28/07/2024 14:00 | 27.62 | 0.74 | 93.06 | 0 | 41.1 | |
| 28/07/2024 15:00 | 27.58 | 0.72 | 92.63 | 0 | 41.2 | |
| 28/07/2024 16:00 | 27.54 | 0.74 | 92.52 | 0 | 41.1 | |
| 28/07/2024 17:00 | 27.44 | 0.74 | 92.5 | 0 | 41.4 | |
| 28/07/2024 18:00 | 41.25 | 0.62 | 97.8 | 0 | 24.8 | |
| 28/07/2024 19:00 | 41.24 | 0.67 | 98.99 | 0 | 23.6 | |
| 28/07/2024 20:00 | 41.18 | 0.73 | 98.98 | 0 | 23.7 | |
| 28/07/2024 21:00 | 41.13 | 0.69 | 99.14 | 0 | 23.8 | |
| 28/07/2024 22:00 | 41.1 | 0.71 | 99.23 | 0 | 23.7 | |
| 28/07/2024 23:00 | 27.25 | 1.16 | 93.69 | 0 | 40.7 | |
| 29/07/2024 00:00 | 27.3 | 1.35 | 92.33 | 0 | 41.8 | GT11 S/D |
| Minimum | 27.25 | 0.62 | 92.33 | 0 | 23.6 | |
| MinDate | 28/07/2024 23:00 | 28/07/2024 18:00 | 29/07/2024 00:00 | 28/07/2024 00:00 | 28/07/2024 19:00 | |
| Maximum | 41.25 | 2.59 | 99.23 | 0 | 42.5 | |
| MaxDate | 28/07/2024 18:00 | 28/07/2024 04:00 | 28/07/2024 22:00 | 28/07/2024 00:00 | 28/07/2024 07:00 | |
| Avg | 30.45 | 1.29 | 94.09 | 0 | 37.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.5 | 0.7 | 2.5 | 0 | 7.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/07/2024 00:00 | 28.42 | 0 | 93.89 | 0 | 38.3 | |
| 28/07/2024 01:00 | 28.52 | 0 | 92.64 | 0 | 38.7 | |
| 28/07/2024 02:00 | 28.46 | 0 | 92.48 | 0 | 38.9 | |
| 28/07/2024 03:00 | 28.36 | 0 | 92.41 | 0 | 39.3 | |
| 28/07/2024 04:00 | 28.06 | 0 | 92.38 | 0 | 39.4 | |
| 28/07/2024 05:00 | 27.76 | 0 | 92.36 | 0 | 39.8 | |
| 28/07/2024 06:00 | 27.65 | 0 | 92.54 | 0 | 39.8 | |
| 28/07/2024 07:00 | 27.48 | 0 | 92.66 | 0 | 39.9 | |
| 28/07/2024 08:00 | 27.41 | 0 | 92.44 | 0 | 39.7 | |
| 28/07/2024 09:00 | 27.42 | 0 | 92.78 | 0 | 39.2 | |
| 28/07/2024 10:00 | 27.51 | 0.07 | 93.13 | 0 | 39.4 | |
| 28/07/2024 11:00 | 27.53 | 0.17 | 93.02 | 0 | 39.3 | |
| 28/07/2024 12:00 | 27.54 | 0.14 | 92.99 | 0 | 39.1 | |
| 28/07/2024 13:00 | 27.55 | 0.12 | 93.09 | 0 | 39.2 | |
| 28/07/2024 14:00 | 27.55 | 0.13 | 92.87 | 0 | 39.6 | |
| 28/07/2024 15:00 | 27.52 | 0.23 | 92.58 | 0 | 39.6 | |
| 28/07/2024 16:00 | 27.47 | 0.06 | 92.55 | 0 | 39.5 | |
| 28/07/2024 17:00 | 27.38 | 0.03 | 92.56 | 0 | 39.7 | |
| 28/07/2024 18:00 | 41.16 | 0.01 | 97.97 | 0 | 25.5 | |
| 28/07/2024 19:00 | 41.17 | 0 | 99 | 0 | 23.7 | |
| 28/07/2024 20:00 | 41.11 | 0 | 99.02 | 0 | 23.6 | |
| 28/07/2024 21:00 | 41.06 | 0 | 99.06 | 0 | 23.8 | |
| 28/07/2024 22:00 | 41.02 | 0 | 99.11 | 0 | 23.6 | |
| 28/07/2024 23:00 | 27.21 | 0 | 93.79 | 0 | 39.4 | |
| 29/07/2024 00:00 | 27.24 | 0 | 92.89 | 0 | 39.5 | |
| Minimum | 27.21 | 0 | 92.36 | 0 | 23.6 | |
| MinDate | 28/07/2024 23:00 | 28/07/2024 00:00 | 28/07/2024 05:00 | 28/07/2024 00:00 | 28/07/2024 20:00 | |
| Maximum | 41.17 | 0.23 | 99.11 | 0 | 39.9 | |
| MaxDate | 28/07/2024 19:00 | 28/07/2024 15:00 | 28/07/2024 22:00 | 28/07/2024 00:00 | 28/07/2024 07:00 | |
| Avg | 30.38 | 0.04 | 94.01 | 0 | 36.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.5 | 0.1 | 2.5 | 0 | 6.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/07/2024 00:00 | 27.3 | 1.35 | 92.33 | 0 | 41.8 | |
| 29/07/2024 01:00 | 27.33 | 1.37 | 92.32 | 0 | 41.8 | |
| 29/07/2024 02:00 | 27.33 | 1.38 | 92.43 | 0 | 41.3 | |
| 29/07/2024 03:00 | 27.28 | 1.73 | 92.26 | 0 | 41.4 | |
| 29/07/2024 04:00 | 27.2 | 2.24 | 92.22 | 0 | 41.3 | |
| 29/07/2024 05:00 | 27.23 | 1.71 | 92.19 | 0 | 41 | |
| 29/07/2024 06:00 | 27.21 | 2.07 | 92.21 | 0 | 40.9 | |
| 29/07/2024 07:00 | 27.17 | 1.49 | 92.25 | 0 | 41.3 | |
| 29/07/2024 08:00 | 19.7 | 1.17 | <Samp | <Samp | <Samp | GT11 S/D |
| 29/07/2024 09:00 | 0 | 0.8 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 10:00 | 0 | 0.75 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 11:00 | 0 | 0.76 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 12:00 | 0 | 0.57 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 13:00 | 0 | 0.79 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 14:00 | 0 | 0.76 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 15:00 | 0 | 0.59 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 16:00 | 0 | 0.73 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 17:00 | 12.02 | 1.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/07/2024 18:00 | 32.7 | 1.44 | 92.65 | 0 | 33.6 | |
| 29/07/2024 19:00 | 32.54 | 2.13 | 92.89 | 0 | 34.6 | |
| 29/07/2024 20:00 | 32.49 | 1.12 | 93.15 | 0 | 34.5 | |
| 29/07/2024 21:00 | 32.41 | 0.84 | 93.2 | 0 | 34.5 | |
| 29/07/2024 22:00 | 32.42 | 0.75 | 93.45 | 0 | 34.3 | |
| 29/07/2024 23:00 | 38.72 | 0.88 | 95.24 | 0 | 37.8 | |
| 30/07/2024 00:00 | 46.26 | 0.61 | 95.9 | 0 | 31.7 | |
| Minimum | 0 | 0 | 93.88 | 1.3 | 26.7 | |
| MinDate | 29/05/2024 01:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 15:00 | 29/05/2024 23:00 | |
| Maximum | 40 | 0.19 | 95.98 | 1.4 | 44.9 | |
| MaxDate | 30/05/2024 00:00 | 29/05/2024 06:00 | 29/05/2024 14:00 | 29/05/2024 09:00 | 29/05/2024 12:00 | |
| Avg | 22.28 | 0.01 | 95.18 | 1.3 | 30.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.1 | 0 | 0.6 | 0.1 | 5.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/07/2024 00:00 | 27.24 | 0 | 92.89 | 0 | 39.5 | |
| 29/07/2024 01:00 | 27.27 | 0 | 92.86 | 0 | 39.4 | |
| 29/07/2024 02:00 | 27.27 | 0 | 92.96 | 0 | 39.1 | |
| 29/07/2024 03:00 | 27.22 | 0 | 92.78 | 0 | 39.3 | |
| 29/07/2024 04:00 | 27.14 | 0 | 92.74 | 0 | 39.3 | |
| 29/07/2024 05:00 | 27.17 | 0 | 92.62 | 0 | 38.8 | |
| 29/07/2024 06:00 | 27.15 | 0 | 92.79 | 0 | 38.7 | |
| 29/07/2024 07:00 | 27.11 | 0 | 92.83 | 0 | 39 | |
| 29/07/2024 08:00 | 33.73 | 0 | 94.32 | 0 | 37 | |
| 29/07/2024 09:00 | 46.27 | 0.03 | 97.01 | 0 | 31.2 | |
| 29/07/2024 10:00 | 46.28 | 0.02 | 95.85 | 0 | 31.5 | |
| 29/07/2024 11:00 | 46.36 | 0.01 | 96.09 | 0 | 31.5 | |
| 29/07/2024 12:00 | 46.3 | 0.01 | 95.83 | 0 | 33.2 | |
| 29/07/2024 13:00 | 46.48 | 0.03 | 95.74 | 0 | 31.4 | |
| 29/07/2024 14:00 | 46.41 | 0 | 95.78 | 0 | 31 | |
| 29/07/2024 15:00 | 46.35 | 0.43 | 95.56 | 0 | 31.5 | |
| 29/07/2024 16:00 | 46.53 | 0.06 | 96.63 | 0 | 30.9 | |
| 29/07/2024 17:00 | 36.89 | 0.02 | 95.11 | 0 | 33.1 | |
| 29/07/2024 18:00 | 32.63 | 0 | 92.6 | 0 | 25.2 | |
| 29/07/2024 19:00 | 32.47 | 0 | 92.75 | 0 | 25.8 | |
| 29/07/2024 20:00 | 32.42 | 0 | 92.99 | 0 | 25.8 | |
| 29/07/2024 21:00 | 32.34 | 0 | 92.88 | 0 | 25.7 | |
| 29/07/2024 22:00 | 32.36 | 0 | 93.16 | 0 | 25.6 | |
| 29/07/2024 23:00 | 7.85 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.84 | --- | 93.91 | 0 | 18.9 | |
| MinDate | 30/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 00:00 | 29/05/2024 23:00 | |
| Maximum | 47.72 | --- | 95.92 | 0 | 39.8 | |
| MaxDate | 29/05/2024 06:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 04:00 | |
| Avg | 36.95 | --- | 95.16 | 0 | 28.6 | |
| Num | 25 | 0 | 24 | 24 | 24 | |
| Data[%] | 100 | --- | 96 | 96 | 96 | |
| STD | 9 | --- | 0.5 | 0 | 9.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/07/2024 00:00 | 46.26 | 0.61 | 95.9 | 0 | 31.7 | |
| 30/07/2024 01:00 | 46.31 | 0.72 | 96.26 | 0 | 31.5 | |
| 30/07/2024 02:00 | 46.31 | 0.74 | 96.5 | 0 | 31.5 | |
| 30/07/2024 03:00 | 46.29 | 0.6 | 96.51 | 0 | 31.4 | |
| 30/07/2024 04:00 | 46.26 | 0.69 | 96.43 | 0 | 31.3 | |
| 30/07/2024 05:00 | 46.4 | 0.68 | 96.49 | 0 | 31.2 | |
| 30/07/2024 06:00 | 46.58 | 0.87 | 97.48 | 0 | 31.2 | |
| 30/07/2024 07:00 | 38.82 | 0.97 | 95.76 | 0 | 35.8 | |
| 30/07/2024 08:00 | 33.75 | 1.09 | 93.94 | 0 | 29.5 | |
| 30/07/2024 09:00 | 33.99 | 0.86 | 94.3 | 0 | 26.3 | |
| 30/07/2024 10:00 | 34.05 | 0.67 | 94.62 | 0 | 26.5 | |
| 30/07/2024 11:00 | 34.09 | 0.64 | 95.21 | 0 | 26.7 | |
| 30/07/2024 12:00 | 21.76 | 0.81 | 92.29 | 0 | 53.4 | |
| 30/07/2024 13:00 | 34.34 | 0.73 | 94.67 | 0 | 28.5 | |
| 30/07/2024 14:00 | 34.31 | 0.71 | 95.14 | 0 | 26.8 | |
| 30/07/2024 15:00 | 34.38 | 0.69 | 94.68 | 0 | 26.5 | |
| 30/07/2024 16:00 | 34.42 | 0.62 | 94.63 | 0 | 26.4 | |
| 30/07/2024 17:00 | 34.19 | 0.61 | 94.56 | 0 | 26.2 | |
| 30/07/2024 18:00 | 34.15 | 0.46 | 94.39 | 0 | 26.1 | |
| 30/07/2024 19:00 | 34.05 | 0.57 | 94.05 | 0 | 25.8 | |
| 30/07/2024 20:00 | 34.14 | 0.7 | 94.05 | 0 | 25.5 | |
| 30/07/2024 21:00 | 34.26 | 0.74 | 94.66 | 0 | 25.4 | |
| 30/07/2024 22:00 | 34.31 | 0.69 | 94.85 | 0 | 25.2 | |
| 30/07/2024 23:00 | 34.25 | 0.83 | 94.76 | 0 | 25.1 | |
| 31/07/2024 00:00 | 8.14 | 1.13 | ShutDown | ShutDown | ShutDown | GT11 SD |
| Minimum | 8.32 | 0 | 94.2 | 1.3 | 25.5 | |
| MinDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 00:00 | 30/05/2024 22:00 | |
| Maximum | 48.02 | 0.38 | 96.03 | 1.5 | 43.9 | |
| MaxDate | 30/05/2024 06:00 | 30/05/2024 06:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 37.19 | 0.02 | 95.04 | 1.4 | 32.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.5 | 0.1 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/07/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 01:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 02:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 03:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 04:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 05:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 06:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 07:00 | 10.01 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/07/2024 08:00 | 33.68 | 0.07 | 94.92 | 0 | 28 | |
| 30/07/2024 09:00 | 33.92 | 0.09 | 94.54 | 0 | 24.7 | |
| 30/07/2024 10:00 | 33.99 | 0.14 | 94.82 | 0 | 24.8 | |
| 30/07/2024 11:00 | 34.02 | 0.25 | 95.28 | 0 | 25 | |
| 30/07/2024 12:00 | 21.61 | 0.3 | 92.46 | 0 | 53.3 | |
| 30/07/2024 13:00 | 34.28 | 0.31 | 94.89 | 0 | 26.4 | |
| 30/07/2024 14:00 | 34.24 | 0.31 | 95.27 | 0 | 24.8 | |
| 30/07/2024 15:00 | 34.31 | 0.36 | 94.99 | 0 | 24.5 | |
| 30/07/2024 16:00 | 34.36 | 0 | 95 | 0 | 24.4 | |
| 30/07/2024 17:00 | 34.13 | 0 | 94.89 | 0 | 24.1 | |
| 30/07/2024 18:00 | 34.08 | 0 | 94.75 | 0 | 24.1 | |
| 30/07/2024 19:00 | 33.98 | 0 | 94.42 | 0 | 23.8 | |
| 30/07/2024 20:00 | 34.08 | 0 | 94.27 | 0 | 23.7 | |
| 30/07/2024 21:00 | 34.19 | 0 | 94.72 | 0 | 23.5 | |
| 30/07/2024 22:00 | 34.24 | 0 | 94.91 | 0 | 23.4 | |
| 30/07/2024 23:00 | 34.19 | 0 | 94.76 | 0 | 23.2 | |
| 31/07/2024 00:00 | 40.3 | 0 | 95.62 | 0 | 41 | |
| Minimum | 0 | --- | 94.25 | 0 | 20.5 | |
| MinDate | 30/05/2024 01:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 09:00 | 30/05/2024 19:00 | |
| Maximum | 39.65 | --- | 96.1 | 0 | 39.7 | |
| MaxDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 22.18 | --- | 95.12 | 0 | 24.5 | |
| Num | 25 | 0 | 16 | 16 | 16 | |
| Data[%] | 100 | --- | 64 | 64 | 64 | |
| STD | 16.1 | --- | 0.5 | 0 | 6.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/07/2024 00:00 | 8.14 | 1.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 01:00 | 0 | 0.86 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 02:00 | 0 | 0.85 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 03:00 | 0 | 0.85 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 04:00 | 0 | 0.69 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 05:00 | 0 | 0.6 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 06:00 | 0 | 0.84 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 07:00 | 11.15 | 0.98 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/07/2024 08:00 | 34.17 | 0.78 | 95.47 | 0 | 28.8 | |
| 31/07/2024 09:00 | 34.39 | 0.78 | 95.46 | 0 | 27.4 | |
| 31/07/2024 10:00 | 34.45 | 0.73 | 95.52 | 0 | 27.5 | |
| 31/07/2024 11:00 | 34.37 | 0.64 | 95.27 | 0 | 27.6 | |
| 31/07/2024 12:00 | 21.98 | 0.67 | 92.15 | 0 | 53 | |
| 31/07/2024 13:00 | 34.47 | 0.49 | 94.57 | 0 | 29.1 | |
| 31/07/2024 14:00 | 34.51 | 0.48 | 95.35 | 0 | 27.2 | |
| 31/07/2024 15:00 | 34.5 | 0.53 | 95.02 | 0 | 27.3 | |
| 31/07/2024 16:00 | 34.36 | 0.53 | 94.84 | 0 | 27.2 | |
| 31/07/2024 17:00 | 34.29 | 0.57 | 94.64 | 0 | 26.9 | |
| 31/07/2024 18:00 | 34.23 | 0.55 | 94.44 | 0 | 26.5 | |
| 31/07/2024 19:00 | 34.13 | 0.58 | 94.48 | 0 | 26.1 | |
| 31/07/2024 20:00 | 34.21 | 0.45 | 94.53 | 0 | 25.8 | |
| 31/07/2024 21:00 | 34.37 | 0.7 | 94.86 | 0 | 25.8 | |
| 31/07/2024 22:00 | 34.38 | 0.96 | 94.82 | 0 | 25.7 | |
| 31/07/2024 23:00 | 34.29 | 1.04 | 94.94 | 0 | 25.6 | |
| 01/08/2024 00:00 | 40.54 | 1.03 | 95.73 | 0 | 40.2 | |
| Minimum | 0 | 0.45 | 92.15 | 0 | 25.6 | |
| MinDate | 31/07/2024 01:00 | 31/07/2024 20:00 | 31/07/2024 12:00 | 31/07/2024 08:00 | 31/07/2024 23:00 | |
| Maximum | 40.54 | 1.13 | 95.73 | 0 | 53 | |
| MaxDate | 01/08/2024 00:00 | 31/07/2024 00:00 | 01/08/2024 00:00 | 31/07/2024 08:00 | 31/07/2024 12:00 | |
| Avg | 23.88 | 0.73 | 94.83 | 0 | 29.3 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.2 | 0.8 | 0 | 7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/07/2024 00:00 | 40.3 | 0 | 95.62 | 0 | 41 | |
| 31/07/2024 01:00 | 48.17 | 0 | 94.87 | 0 | 42.9 | |
| 31/07/2024 02:00 | 48.24 | 0 | 95.06 | 0 | 43.2 | |
| 31/07/2024 03:00 | 48.3 | 0 | 95.22 | 0 | 43.5 | |
| 31/07/2024 04:00 | 48.36 | 0 | 95.32 | 0 | 43.9 | |
| 31/07/2024 05:00 | 48.36 | 0 | 95.43 | 0 | 44.1 | |
| 31/07/2024 06:00 | 48.53 | 0 | 96.58 | 0 | 43.8 | |
| 31/07/2024 07:00 | 39.08 | 0 | 95.17 | 0 | 40.8 | |
| 31/07/2024 08:00 | 34.11 | 0 | 94.75 | 0 | 24.9 | |
| 31/07/2024 09:00 | 34.33 | 0 | 94.78 | 0 | 23.2 | |
| 31/07/2024 10:00 | 34.38 | 0.01 | 94.93 | 0 | 23.4 | |
| 31/07/2024 11:00 | 34.3 | 0 | 94.89 | 0 | 23.2 | |
| 31/07/2024 12:00 | 21.95 | 0 | 91.98 | 0 | 50.9 | |
| 31/07/2024 13:00 | 34.4 | 0 | 94.38 | 0 | 25 | |
| 31/07/2024 14:00 | 34.44 | 0 | 95.08 | 0 | 23.1 | |
| 31/07/2024 15:00 | 34.43 | 0.29 | 94.89 | 0 | 23.1 | |
| 31/07/2024 16:00 | 34.3 | 0.08 | 94.75 | 0 | 22.9 | |
| 31/07/2024 17:00 | 34.23 | 0.09 | 94.58 | 0 | 22.8 | |
| 31/07/2024 18:00 | 34.16 | 0.01 | 94.35 | 0 | 22.5 | |
| 31/07/2024 19:00 | 34.06 | 0 | 94.26 | 0 | 22.2 | |
| 31/07/2024 20:00 | 34.15 | 0 | 94.31 | 0 | 22.1 | |
| 31/07/2024 21:00 | 34.3 | 0 | 94.54 | 0 | 22.1 | |
| 31/07/2024 22:00 | 34.31 | 0 | 94.56 | 0 | 21.9 | |
| 31/07/2024 23:00 | 34.23 | 0 | 94.47 | 0 | 21.8 | |
| 01/08/2024 00:00 | 7.75 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.75 | 0 | 91.98 | 0 | 21.8 | |
| MinDate | 01/08/2024 00:00 | 31/07/2024 00:00 | 31/07/2024 12:00 | 31/07/2024 00:00 | 31/07/2024 23:00 | |
| Maximum | 48.53 | 0.29 | 96.58 | 0 | 50.9 | |
| MaxDate | 31/07/2024 06:00 | 31/07/2024 15:00 | 31/07/2024 06:00 | 31/07/2024 00:00 | 31/07/2024 12:00 | |
| Avg | 36.53 | 0.02 | 94.78 | 0 | 30.8 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0 | 10.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/08/2024 00:00 | 40.54 | 1.03 | 95.73 | 0 | 40.2 | |
| 01/08/2024 01:00 | 48.53 | 0.87 | 95.32 | 0 | 38.2 | |
| 01/08/2024 02:00 | 48.52 | 0.89 | 95.7 | 0 | 38.1 | |
| 01/08/2024 03:00 | 48.65 | 0.97 | 95.72 | 0 | 37.8 | |
| 01/08/2024 04:00 | 48.71 | 0.93 | 95.82 | 0 | 37.8 | |
| 01/08/2024 05:00 | 48.63 | 0.77 | 95.86 | 0 | 37.9 | |
| 01/08/2024 06:00 | 48.75 | 0.83 | 96.44 | 0 | 37.7 | |
| 01/08/2024 07:00 | 48.49 | 0.42 | 95.46 | 0 | 37.5 | |
| 01/08/2024 08:00 | 44.71 | 0.37 | 96.25 | 0 | 36.1 | |
| 01/08/2024 09:00 | 32.3 | 0.3 | 94.47 | 0 | 33.6 | |
| 01/08/2024 10:00 | 34.36 | 0.26 | 95 | 0 | 26 | |
| 01/08/2024 11:00 | 34.47 | 0.36 | 95.08 | 0 | 26 | |
| 01/08/2024 12:00 | 25.12 | 0.5 | 92.99 | 0 | 45.6 | |
| 01/08/2024 13:00 | 31.33 | 0.47 | 93.73 | 0 | 34.3 | |
| 01/08/2024 14:00 | 34.47 | 0.35 | 95.05 | 0 | 25.6 | |
| 01/08/2024 15:00 | 34.6 | 0.31 | 94.89 | 0 | 25.6 | |
| 01/08/2024 16:00 | 34.44 | 0.36 | 94.65 | 0 | 25.3 | |
| 01/08/2024 17:00 | 34.3 | 0.46 | 94.43 | 0 | 24.7 | |
| 01/08/2024 18:00 | 34.31 | 0.51 | 94.35 | 0 | 24.5 | |
| 01/08/2024 19:00 | 34.12 | 0.49 | 94.21 | 0 | 24.4 | |
| 01/08/2024 20:00 | 34.17 | 0.37 | 94.32 | 0 | 24.2 | |
| 01/08/2024 21:00 | 34.36 | 0.52 | 94.87 | 0 | 24 | |
| 01/08/2024 22:00 | 34.32 | 0.71 | 95 | 0 | 23.9 | |
| 01/08/2024 23:00 | 24.81 | 0.83 | 94.05 | 0 | 33.4 | |
| 02/08/2024 00:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.26 | 92.99 | 0 | 23.9 | |
| MinDate | 02/08/2024 00:00 | 01/08/2024 10:00 | 01/08/2024 12:00 | 01/08/2024 00:00 | 01/08/2024 22:00 | |
| Maximum | 48.75 | 1.03 | 96.44 | 0 | 45.6 | |
| MaxDate | 01/08/2024 06:00 | 01/08/2024 00:00 | 01/08/2024 06:00 | 01/08/2024 00:00 | 01/08/2024 12:00 | |
| Avg | 36.68 | 0.57 | 94.97 | 0 | 31.8 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.8 | 0.2 | 0.8 | 0 | 6.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/08/2024 00:00 | 7.75 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 01:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 02:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 05:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 06:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 08:00 | 5.15 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/08/2024 09:00 | 32.47 | 0.01 | 95.7 | 0 | 33.1 | |
| 01/08/2024 10:00 | 34.63 | 0.04 | 95.27 | 0 | 25.6 | |
| 01/08/2024 11:00 | 34.4 | 0.09 | 95.12 | 0 | 25.3 | |
| 01/08/2024 12:00 | 25.09 | 0.14 | 93 | 0 | 45.2 | |
| 01/08/2024 13:00 | 31.31 | 0.16 | 93.9 | 0 | 33.6 | |
| 01/08/2024 14:00 | 34.41 | 0.1 | 95.12 | 0 | 24.8 | |
| 01/08/2024 15:00 | 34.53 | 0.22 | 95.12 | 0 | 24.7 | |
| 01/08/2024 16:00 | 34.37 | 0.07 | 94.92 | 0 | 24.2 | |
| 01/08/2024 17:00 | 34.23 | 0.06 | 94.7 | 0 | 23.8 | |
| 01/08/2024 18:00 | 34.24 | 0 | 94.56 | 0 | 23.6 | |
| 01/08/2024 19:00 | 34.05 | 0 | 94.22 | 0 | 23.5 | |
| 01/08/2024 20:00 | 34.11 | 0 | 94.28 | 0 | 23.3 | |
| 01/08/2024 21:00 | 34.3 | 0 | 94.69 | 0 | 23.2 | |
| 01/08/2024 22:00 | 34.26 | 0 | 94.93 | 0 | 23.1 | |
| 01/08/2024 23:00 | 33.48 | 0.01 | 94.66 | 0 | 32.3 | |
| 02/08/2024 00:00 | 48.42 | 0 | 96.3 | 0 | 42.8 | |
| Minimum | 0 | 0 | 93 | 0 | 23.1 | |
| MinDate | 01/08/2024 01:00 | 01/08/2024 00:00 | 01/08/2024 12:00 | 01/08/2024 09:00 | 01/08/2024 22:00 | |
| Maximum | 48.42 | 0.22 | 96.3 | 0 | 45.2 | |
| MaxDate | 02/08/2024 00:00 | 01/08/2024 15:00 | 02/08/2024 00:00 | 01/08/2024 09:00 | 01/08/2024 12:00 | |
| Avg | 22.45 | 0.04 | 94.78 | 0 | 28.3 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.6 | 0.1 | 0.7 | 0 | 7.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/08/2024 00:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 01:00 | 0 | 0.51 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 02:00 | 0 | 0.41 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 03:00 | 0 | 0.39 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 04:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 05:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 06:00 | 0 | 0.59 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 07:00 | 0 | 0.59 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 08:00 | 5.58 | 0.84 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/08/2024 09:00 | 32.39 | 0.48 | 95.08 | 0 | 34.7 | |
| 02/08/2024 10:00 | 34.6 | 0.62 | 95.76 | 0 | 28.4 | |
| 02/08/2024 11:00 | 34.44 | 0.7 | 95.91 | 0 | 28.3 | |
| 02/08/2024 12:00 | 25.54 | 0.79 | 94.25 | 0 | 44.5 | |
| 02/08/2024 13:00 | 31.56 | 0.66 | 94.55 | 0 | 35.1 | |
| 02/08/2024 14:00 | 34.63 | 0.61 | 95.74 | 0 | 27.8 | |
| 02/08/2024 15:00 | 34.58 | 0.52 | 95.49 | 0 | 27.8 | |
| 02/08/2024 16:00 | 34.39 | 0.54 | 95.11 | 0 | 27.2 | |
| 02/08/2024 17:00 | 34.32 | 0.24 | 94.99 | 0 | 26.8 | |
| 02/08/2024 18:00 | 34.24 | 0.31 | 94.62 | 0 | 27.1 | |
| 02/08/2024 19:00 | 34.17 | 0.53 | 94.44 | 0 | 26.6 | |
| 02/08/2024 20:00 | 34.04 | 0.5 | 94.45 | 0 | 26.6 | |
| 02/08/2024 21:00 | 34.25 | 0.41 | 94.9 | 0 | 26.5 | |
| 02/08/2024 22:00 | 37.41 | 0.34 | 96.54 | 0 | 27.9 | |
| 02/08/2024 23:00 | 31.97 | 0.67 | 95.78 | 0 | 39.1 | |
| 03/08/2024 00:00 | 27.9 | 0.75 | 93.33 | 0 | 46.5 | |
| Minimum | 0 | 0.24 | 93.33 | 0 | 26.5 | |
| MinDate | 02/08/2024 00:00 | 02/08/2024 17:00 | 03/08/2024 00:00 | 02/08/2024 09:00 | 02/08/2024 21:00 | |
| Maximum | 37.41 | 0.84 | 96.54 | 0 | 46.5 | |
| MaxDate | 02/08/2024 22:00 | 02/08/2024 08:00 | 02/08/2024 22:00 | 02/08/2024 09:00 | 03/08/2024 00:00 | |
| Avg | 21.44 | 0.52 | 95.06 | 0 | 31.3 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.1 | 0.2 | 0.8 | 0 | 6.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/08/2024 00:00 | 48.42 | 0 | 96.3 | 0 | 42.8 | |
| 02/08/2024 01:00 | 48.51 | 0.01 | 95.17 | 0 | 43 | |
| 02/08/2024 02:00 | 48.53 | 0.03 | 95.44 | 0 | 42.8 | |
| 02/08/2024 03:00 | 48.58 | 0.01 | 95.56 | 0 | 43 | |
| 02/08/2024 04:00 | 48.56 | 0.03 | 95.56 | 0 | 42.7 | |
| 02/08/2024 05:00 | 48.58 | 0 | 95.56 | 0 | 42.7 | |
| 02/08/2024 06:00 | 48.63 | 0.01 | 96.77 | 0 | 42.6 | |
| 02/08/2024 07:00 | 48.61 | 0.05 | 95.24 | 0 | 42.4 | |
| 02/08/2024 08:00 | 44.27 | 0.03 | 95.76 | 0 | 39.7 | |
| 02/08/2024 09:00 | 32.32 | 0.03 | 94.75 | 0 | 30.5 | |
| 02/08/2024 10:00 | 34.53 | 0.18 | 95.43 | 0 | 23.3 | |
| 02/08/2024 11:00 | 34.36 | 0.26 | 95.64 | 0 | 23.1 | |
| 02/08/2024 12:00 | 25.42 | 0.26 | 93.99 | 0 | 42 | |
| 02/08/2024 13:00 | 31.41 | 0.24 | 94.35 | 0 | 31 | |
| 02/08/2024 14:00 | 34.57 | 0.2 | 95.44 | 0 | 22.5 | |
| 02/08/2024 15:00 | 34.51 | 0.45 | 95.35 | 0 | 22.5 | |
| 02/08/2024 16:00 | 34.32 | 0.06 | 95.06 | 0 | 22 | |
| 02/08/2024 17:00 | 34.25 | 0 | 94.95 | 0 | 21.7 | |
| 02/08/2024 18:00 | 34.17 | 0 | 94.69 | 0 | 21.9 | |
| 02/08/2024 19:00 | 34.11 | 0 | 94.58 | 0 | 21.7 | |
| 02/08/2024 20:00 | 33.98 | 0 | 94.43 | 0 | 21.6 | |
| 02/08/2024 21:00 | 34.19 | 0 | 94.71 | 0 | 21.7 | |
| 02/08/2024 22:00 | 37.34 | 0 | 96.42 | 0 | 23.2 | |
| 02/08/2024 23:00 | 31.91 | 0 | 95.64 | 0 | 34.1 | |
| 03/08/2024 00:00 | 27.84 | 0.01 | 93.27 | 0 | 40.6 | |
| Minimum | 25.42 | 0 | 93.27 | 0 | 21.6 | |
| MinDate | 02/08/2024 12:00 | 02/08/2024 00:00 | 03/08/2024 00:00 | 02/08/2024 00:00 | 02/08/2024 20:00 | |
| Maximum | 48.63 | 0.45 | 96.77 | 0 | 43 | |
| MaxDate | 02/08/2024 06:00 | 02/08/2024 15:00 | 02/08/2024 06:00 | 02/08/2024 00:00 | 02/08/2024 01:00 | |
| Avg | 38.48 | 0.07 | 95.2 | 0 | 32.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.7 | 0.1 | 0.8 | 0 | 9.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/08/2024 00:00 | 27.9 | 0.75 | 93.33 | 0 | 46.5 | |
| 03/08/2024 01:00 | 27.98 | 0.63 | 93.45 | 0 | 45.9 | |
| 03/08/2024 02:00 | 27.91 | 0.57 | 93.34 | 0 | 45.5 | |
| 03/08/2024 03:00 | 27.83 | 0.6 | 93.41 | 0 | 45.7 | |
| 03/08/2024 04:00 | 27.69 | 0.61 | 93.24 | 0 | 45.8 | |
| 03/08/2024 05:00 | 27.41 | 0.84 | 93.03 | 0 | 46.9 | |
| 03/08/2024 06:00 | 27.33 | 1.63 | 92.84 | 0 | 47.4 | |
| 03/08/2024 07:00 | 27.22 | 1.65 | 92.88 | 0 | 47 | |
| 03/08/2024 08:00 | 27.8 | 0.66 | 93.16 | 0 | 45.7 | |
| 03/08/2024 09:00 | 38.49 | 0.45 | 97.28 | 0 | 33.3 | |
| 03/08/2024 10:00 | 41.98 | 0.45 | 100.36 | 0 | 29.5 | |
| 03/08/2024 11:00 | 41.91 | 0.5 | 100.31 | 0 | 29.8 | |
| 03/08/2024 12:00 | 31.54 | 0.75 | 96.56 | 0 | 39.8 | |
| 03/08/2024 13:00 | 38.35 | 0.67 | 97.48 | 0 | 33.3 | |
| 03/08/2024 14:00 | 41.93 | 0.63 | 100.39 | 0 | 29.2 | |
| 03/08/2024 15:00 | 41.98 | 0.61 | 100.06 | 0 | 29.1 | |
| 03/08/2024 16:00 | 42 | 0.6 | 99.8 | 0 | 29 | |
| 03/08/2024 17:00 | 41.99 | 0.56 | 99.52 | 0 | 28.6 | |
| 03/08/2024 18:00 | 41.91 | 0.42 | 99.44 | 0 | 28.5 | |
| 03/08/2024 19:00 | 41.77 | 0.32 | 99.29 | 0 | 28.1 | |
| 03/08/2024 20:00 | 41.79 | 0.32 | 99.23 | 0 | 27.9 | |
| 03/08/2024 21:00 | 41.82 | 0.39 | 99.76 | 0 | 27.8 | |
| 03/08/2024 22:00 | 41.86 | 0.36 | 99.73 | 0 | 27.9 | |
| 03/08/2024 23:00 | 34.77 | 2.76 | 95.26 | 0 | 37.1 | |
| 04/08/2024 00:00 | 27.76 | 4.32 | 90.71 | 0 | 49.1 | |
| Minimum | 27.22 | 0.32 | 90.71 | 0 | 27.8 | |
| MinDate | 03/08/2024 07:00 | 03/08/2024 19:00 | 04/08/2024 00:00 | 03/08/2024 00:00 | 03/08/2024 21:00 | |
| Maximum | 42 | 4.32 | 100.39 | 0 | 49.1 | |
| MaxDate | 03/08/2024 16:00 | 04/08/2024 00:00 | 03/08/2024 14:00 | 03/08/2024 00:00 | 04/08/2024 00:00 | |
| Avg | 35.24 | 0.88 | 96.55 | 0 | 37 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.8 | 0.9 | 3.3 | 0 | 8.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | | |
| 03/08/2024 00:00 | 27.84 | 0.01 | 93.27 | 0 | 40.6 | |
| 03/08/2024 01:00 | 27.92 | 0.01 | 93.22 | 0 | 39.9 | |
| 03/08/2024 02:00 | 27.85 | 0 | 93.08 | 0 | 39.7 | |
| 03/08/2024 03:00 | 27.77 | 0 | 93.16 | 0 | 39.8 | |
| 03/08/2024 04:00 | 27.63 | 0 | 92.98 | 0 | 39.7 | |
| 03/08/2024 05:00 | 27.36 | 0 | 92.76 | 0 | 40.9 | |
| 03/08/2024 06:00 | 27.27 | 0 | 92.58 | 0 | 41.6 | |
| 03/08/2024 07:00 | 27.16 | 0 | 92.53 | 0 | 41.5 | |
| 03/08/2024 08:00 | 27.73 | 0 | 92.83 | 0 | 39.8 | |
| 03/08/2024 09:00 | 38.42 | 0 | 97.21 | 0 | 29.4 | |
| 03/08/2024 10:00 | 41.9 | 0.01 | 100.49 | 0 | 25.9 | |
| 03/08/2024 11:00 | 41.84 | 0.05 | 100.53 | 0 | 26.2 | |
| 03/08/2024 12:00 | 31.58 | 0.14 | 96.76 | 0 | 35 | |
| 03/08/2024 13:00 | 38.29 | 0.18 | 97.89 | 0 | 29.4 | |
| 03/08/2024 14:00 | 41.85 | 0.12 | 100.48 | 0 | 25.8 | |
| 03/08/2024 15:00 | 41.91 | 0.34 | 100.42 | 0 | 25.7 | |
| 03/08/2024 16:00 | 41.92 | 0.05 | 100.24 | 0 | 25.4 | |
| 03/08/2024 17:00 | 41.91 | 0 | 99.89 | 0 | 24.9 | |
| 03/08/2024 18:00 | 41.83 | 0 | 99.71 | 0 | 24.7 | |
| 03/08/2024 19:00 | 41.69 | 0 | 99.54 | 0 | 24.4 | |
| 03/08/2024 20:00 | 41.71 | 0 | 99.52 | 0 | 24.3 | |
| 03/08/2024 21:00 | 41.74 | 0 | 99.89 | 0 | 24.3 | |
| 03/08/2024 22:00 | 41.79 | 0 | 99.81 | 0 | 24.2 | |
| 03/08/2024 23:00 | 34.7 | 0 | 94.94 | 0 | 32.4 | |
| 04/08/2024 00:00 | 27.69 | 0 | 90.57 | 0 | 43.2 | |
| Minimum | 27.16 | 0 | 90.57 | 0 | 24.2 | |
| MinDate | 03/08/2024 07:00 | 03/08/2024 02:00 | 04/08/2024 00:00 | 03/08/2024 00:00 | 03/08/2024 22:00 | |
| Maximum | 41.92 | 0.34 | 100.53 | 0 | 43.2 | |
| MaxDate | 03/08/2024 16:00 | 03/08/2024 15:00 | 03/08/2024 11:00 | 03/08/2024 00:00 | 04/08/2024 00:00 | |
| Avg | 35.17 | 0.04 | 96.57 | 0 | 32.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.5 | 0 | 7.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/08/2024 00:00 | 27.76 | 4.32 | 90.71 | 0 | 49.1 | |
| 04/08/2024 01:00 | 27.8 | 1.88 | 91.84 | 0 | 48.6 | |
| 04/08/2024 02:00 | 27.81 | 0.69 | 91.88 | 0 | 48.4 | |
| 04/08/2024 03:00 | 27.84 | 0.5 | 92.18 | 0 | 48 | |
| 04/08/2024 04:00 | 27.77 | 0.46 | 92.15 | 0 | 47.7 | |
| 04/08/2024 05:00 | 27.68 | 0.47 | 92.34 | 0 | 47.8 | |
| 04/08/2024 06:00 | 27.6 | 0.87 | 92.38 | 0 | 49.6 | |
| 04/08/2024 07:00 | 27.32 | 0.55 | 92.48 | 0 | 46.7 | |
| 04/08/2024 08:00 | 27.12 | 0.44 | 92.62 | 0 | 46.4 | |
| 04/08/2024 09:00 | 27.13 | 0.5 | 92.82 | 0 | 46.8 | |
| 04/08/2024 10:00 | 27.19 | 0.5 | 93.08 | 0 | 46.6 | |
| 04/08/2024 11:00 | 27.18 | 0.51 | 93.53 | 0 | 45.7 | |
| 04/08/2024 12:00 | 27.19 | 0.58 | 93.81 | 0 | 45.3 | |
| 04/08/2024 13:00 | 27.28 | 0.66 | 93.43 | 0 | 44 | |
| 04/08/2024 14:00 | 27.4 | 0.6 | 93.14 | 0 | 43.7 | |
| 04/08/2024 15:00 | 27.4 | 0.56 | 92.72 | 0 | 43.7 | |
| 04/08/2024 16:00 | 27.35 | 0.33 | 92.38 | 0 | 43.9 | |
| 04/08/2024 17:00 | 27.34 | 0.25 | 92.43 | 0 | 43.5 | |
| 04/08/2024 18:00 | 34.24 | 0.44 | 94.3 | 0 | 36.1 | |
| 04/08/2024 19:00 | 41.12 | 0.7 | 98.57 | 0 | 27.2 | |
| 04/08/2024 20:00 | 41.1 | 0.7 | 98.7 | 0 | 26.2 | |
| 04/08/2024 21:00 | 41.09 | 0.63 | 99.06 | 0 | 26.2 | |
| 04/08/2024 22:00 | 27.21 | 0.86 | 93.88 | 0 | 43 | |
| 04/08/2024 23:00 | 27.15 | 0.88 | 91.71 | 0 | 47.1 | |
| 05/08/2024 00:00 | 27.12 | 2.27 | 91.29 | 0 | 46.9 | |
| Minimum | 27.12 | 0.25 | 90.71 | 0 | 26.2 | |
| MinDate | 04/08/2024 08:00 | 04/08/2024 17:00 | 04/08/2024 00:00 | 04/08/2024 00:00 | 04/08/2024 20:00 | |
| Maximum | 41.12 | 4.32 | 99.06 | 0 | 49.6 | |
| MaxDate | 04/08/2024 19:00 | 04/08/2024 00:00 | 04/08/2024 21:00 | 04/08/2024 00:00 | 04/08/2024 06:00 | |
| Avg | 29.33 | 0.85 | 93.34 | 0 | 43.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.8 | 2.2 | 0 | 7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/08/2024 00:00 | 27.69 | 0 | 90.57 | 0 | 43.2 | |
| 04/08/2024 01:00 | 27.73 | 0 | 92.08 | 0 | 42.2 | |
| 04/08/2024 02:00 | 27.75 | 0 | 92.09 | 0 | 42 | |
| 04/08/2024 03:00 | 27.78 | 0 | 92.48 | 0 | 41.3 | |
| 04/08/2024 04:00 | 27.7 | 0 | 92.43 | 0 | 41.2 | |
| 04/08/2024 05:00 | 27.62 | 0 | 92.59 | 0 | 41.3 | |
| 04/08/2024 06:00 | 27.53 | 0 | 92.6 | 0 | 43.2 | |
| 04/08/2024 07:00 | 27.25 | 0 | 92.67 | 0 | 41.4 | |
| 04/08/2024 08:00 | 27.06 | 0 | 92.85 | 0 | 41.1 | |
| 04/08/2024 09:00 | 27.08 | 0 | 92.97 | 0 | 40.6 | |
| 04/08/2024 10:00 | 27.13 | 0.01 | 93.22 | 0 | 40.2 | |
| 04/08/2024 11:00 | 27.12 | 0.03 | 93.64 | 0 | 39.4 | |
| 04/08/2024 12:00 | 27.13 | 0.11 | 94.04 | 0 | 39.1 | |
| 04/08/2024 13:00 | 27.22 | 0.18 | 93.65 | 0 | 38.1 | |
| 04/08/2024 14:00 | 27.35 | 0.1 | 93.29 | 0 | 37.9 | |
| 04/08/2024 15:00 | 27.33 | 0.28 | 92.98 | 0 | 38 | |
| 04/08/2024 16:00 | 27.29 | 0 | 92.55 | 0 | 37.8 | |
| 04/08/2024 17:00 | 27.27 | 0 | 92.7 | 0 | 37.7 | |
| 04/08/2024 18:00 | 34.18 | 0 | 94.88 | 0 | 32 | |
| 04/08/2024 19:00 | 41.04 | 0 | 98.94 | 0 | 23.9 | |
| 04/08/2024 20:00 | 41.02 | 0 | 98.93 | 0 | 22.9 | |
| 04/08/2024 21:00 | 41.02 | 0 | 99.27 | 0 | 23.1 | |
| 04/08/2024 22:00 | 27.16 | 0 | 94.14 | 0 | 39.1 | |
| 04/08/2024 23:00 | 27.08 | 0 | 91.58 | 0 | 43.6 | |
| 05/08/2024 00:00 | 27.06 | 0 | 91.14 | 0 | 43.7 | |
| Minimum | 27.06 | 0 | 90.57 | 0 | 22.9 | |
| MinDate | 04/08/2024 08:00 | 04/08/2024 00:00 | 04/08/2024 00:00 | 04/08/2024 00:00 | 04/08/2024 20:00 | |
| Maximum | 41.04 | 0.28 | 99.27 | 0 | 43.7 | |
| MaxDate | 04/08/2024 19:00 | 04/08/2024 15:00 | 04/08/2024 21:00 | 04/08/2024 00:00 | 05/08/2024 00:00 | |
| Avg | 29.26 | 0.03 | 93.53 | 0 | 38.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.1 | 2.3 | 0 | 6.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/08/2024 00:00 | 27.12 | 2.27 | 91.29 | 0 | 46.9 | |
| 05/08/2024 01:00 | 27.13 | 1.66 | 91.6 | 0 | 46.2 | |
| 05/08/2024 02:00 | 27.19 | 1.04 | 91.98 | 0 | 45.9 | |
| 05/08/2024 03:00 | 27.14 | 0.68 | 92.07 | 0 | 45.9 | |
| 05/08/2024 04:00 | 27.13 | 0.51 | 91.78 | 0 | 45.6 | |
| 05/08/2024 05:00 | 27.18 | 0.48 | 91.84 | 0 | 45.6 | |
| 05/08/2024 06:00 | 27.17 | 0.78 | 92.03 | 0 | 45.7 | |
| 05/08/2024 07:00 | 27.44 | 0.6 | 92.28 | 0 | 45.4 | |
| 05/08/2024 08:00 | 27.08 | 0.66 | 92.67 | 0 | 45.1 | |
| 05/08/2024 09:00 | 31.32 | 0.79 | 93.98 | 0 | 33.4 | |
| 05/08/2024 10:00 | 34.45 | 0.86 | 95.17 | 0 | 23.2 | |
| 05/08/2024 11:00 | 34.52 | 0.84 | 95.83 | 0 | 23.1 | |
| 05/08/2024 12:00 | 25.32 | 0.91 | 94.45 | 0 | 41.3 | |
| 05/08/2024 13:00 | 31.45 | 0.74 | 94.21 | 0 | 31.5 | |
| 05/08/2024 14:00 | 34.58 | 0.64 | 95.52 | 0 | 23.1 | |
| 05/08/2024 15:00 | 34.56 | 0.68 | 95.06 | 0 | 22.7 | |
| 05/08/2024 16:00 | 34.51 | 0.63 | 95.1 | 0 | 22.8 | |
| 05/08/2024 17:00 | 34.25 | 0.62 | 94.71 | 0 | 22.9 | |
| 05/08/2024 18:00 | 34.3 | 0.58 | 94.54 | 0 | 22.9 | |
| 05/08/2024 19:00 | 34.18 | 0.63 | 94.22 | 0 | 22.3 | |
| 05/08/2024 20:00 | 34.24 | 0.58 | 94.11 | 0 | 22 | |
| 05/08/2024 21:00 | 34.43 | 0.56 | 94.56 | 0 | 22 | |
| 05/08/2024 22:00 | 34.33 | 0.67 | 94.6 | 0 | 21.9 | |
| 05/08/2024 23:00 | 33.57 | 0.77 | 94.28 | 0 | 30.3 | |
| 06/08/2024 00:00 | 48.56 | 0.63 | 96.16 | 0 | 33.1 | |
| Minimum | 25.32 | 0.48 | 91.29 | 0 | 21.9 | |
| MinDate | 05/08/2024 12:00 | 05/08/2024 05:00 | 05/08/2024 00:00 | 05/08/2024 00:00 | 05/08/2024 22:00 | |
| Maximum | 48.56 | 2.27 | 96.16 | 0 | 46.9 | |
| MaxDate | 06/08/2024 00:00 | 05/08/2024 00:00 | 06/08/2024 00:00 | 05/08/2024 00:00 | 05/08/2024 00:00 | |
| Avg | 31.73 | 0.79 | 93.76 | 0 | 33.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5 | 0.4 | 1.5 | 0 | 10.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/08/2024 00:00 | 27.06 | 0 | 91.14 | 0 | 43.7 | |
| 05/08/2024 01:00 | 27.07 | 0 | 91.58 | 0 | 42.9 | |
| 05/08/2024 02:00 | 27.12 | 0 | 92.03 | 0 | 42.3 | |
| 05/08/2024 03:00 | 27.09 | 0 | 92.15 | 0 | 42.2 | |
| 05/08/2024 04:00 | 27.07 | 0 | 91.93 | 0 | 41.7 | |
| 05/08/2024 05:00 | 27.12 | 0 | 91.95 | 0 | 41.8 | |
| 05/08/2024 06:00 | 27.12 | 0 | 92.19 | 0 | 42.1 | |
| 05/08/2024 07:00 | 27.38 | 0 | 92.45 | 0 | 40.9 | |
| 05/08/2024 08:00 | 27.02 | 0.03 | 92.79 | 0 | 41.3 | |
| 05/08/2024 09:00 | 31.25 | 0.17 | 94.14 | 0 | 31.3 | |
| 05/08/2024 10:00 | 34.39 | 0.2 | 95.2 | 0 | 21.1 | |
| 05/08/2024 11:00 | 34.47 | 0.19 | 95.78 | 0 | 21 | |
| 05/08/2024 12:00 | 25.27 | 0.18 | 94.44 | 0 | 40.9 | |
| 05/08/2024 13:00 | 31.39 | 0.1 | 94.46 | 0 | 29.9 | |
| 05/08/2024 14:00 | 34.51 | 0.07 | 95.51 | 0 | 20.8 | |
| 05/08/2024 15:00 | 34.49 | 0.42 | 95.27 | 0 | 20.4 | |
| 05/08/2024 16:00 | 34.45 | 0.04 | 95.23 | 0 | 20.6 | |
| 05/08/2024 17:00 | 34.19 | 0.03 | 94.96 | 0 | 20.8 | |
| 05/08/2024 18:00 | 34.23 | 0.01 | 94.88 | 0 | 20.7 | |
| 05/08/2024 19:00 | 34.1 | 0 | 94.56 | 0 | 20.2 | |
| 05/08/2024 20:00 | 34.17 | 0 | 94.41 | 0 | 20 | |
| 05/08/2024 21:00 | 34.37 | 0 | 94.68 | 0 | 19.9 | |
| 05/08/2024 22:00 | 34.27 | 0 | 94.72 | 0 | 19.8 | |
| 05/08/2024 23:00 | 24.87 | 0 | 93.63 | 0 | 30 | |
| 06/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 0 | 0 | 91.14 | 0 | 19.8 | |
| MinDate | 06/08/2024 00:00 | 05/08/2024 00:00 | 05/08/2024 00:00 | 05/08/2024 00:00 | 05/08/2024 22:00 | |
| Maximum | 34.51 | 0.42 | 95.78 | 0 | 43.7 | |
| MaxDate | 05/08/2024 14:00 | 05/08/2024 15:00 | 05/08/2024 11:00 | 05/08/2024 00:00 | 05/08/2024 00:00 | |
| Avg | 29.38 | 0.06 | 93.75 | 0 | 30.7 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 7.1 | 0.1 | 1.5 | 0 | 10.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/08/2024 00:00 | 48.56 | 0.63 | 96.16 | 0 | 33.1 | |
| 06/08/2024 01:00 | 48.57 | 0.54 | 95.19 | 0 | 33 | |
| 06/08/2024 02:00 | 48.62 | 0.59 | 95.65 | 0 | 32.7 | |
| 06/08/2024 03:00 | 48.72 | 0.52 | 95.7 | 0 | 32.7 | |
| 06/08/2024 04:00 | 48.79 | 0.51 | 95.72 | 0 | 32.5 | |
| 06/08/2024 05:00 | 48.79 | 0.5 | 95.78 | 0 | 32.3 | |
| 06/08/2024 06:00 | 48.78 | 0.39 | 96.27 | 0 | 32.2 | |
| 06/08/2024 07:00 | 48.54 | 0.17 | 95.21 | 0 | 32 | |
| 06/08/2024 08:00 | 43.99 | 0.25 | 96.5 | 0 | 31.5 | |
| 06/08/2024 09:00 | 32.53 | 0.39 | 94.62 | 0 | 28.2 | |
| 06/08/2024 10:00 | 34.62 | 0.38 | 95.57 | 0 | 21.6 | |
| 06/08/2024 11:00 | 34.63 | 0.41 | 96.29 | 0 | 21.4 | |
| 06/08/2024 12:00 | 24.92 | 0.48 | 94.84 | 0 | 42.4 | |
| 06/08/2024 13:00 | 31.52 | 0.36 | 94.82 | 0 | 30.4 | |
| 06/08/2024 14:00 | 34.69 | 0.26 | 95.74 | 0 | 21.8 | |
| 06/08/2024 15:00 | 34.61 | 0.21 | 95.53 | 0 | 21.7 | |
| 06/08/2024 16:00 | 34.55 | 0.2 | 95.26 | 0 | 21.6 | |
| 06/08/2024 17:00 | 34.45 | 0.24 | 95.12 | 0 | 21.7 | |
| 06/08/2024 18:00 | 34.35 | 0.29 | 94.92 | 0 | 21.7 | |
| 06/08/2024 19:00 | 34.26 | 0.28 | 94.48 | 0 | 21.3 | |
| 06/08/2024 20:00 | 34.06 | 0.11 | 94.03 | 0 | 21 | |
| 06/08/2024 21:00 | 34.23 | 0.07 | 94.47 | 0 | 20.9 | |
| 06/08/2024 22:00 | 34.33 | 0.03 | 94.85 | 0 | 20.9 | |
| 06/08/2024 23:00 | 25.46 | 0.09 | 93.89 | 0 | 30.2 | |
| 07/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 93.89 | 0 | 20.9 | |
| MinDate | 07/08/2024 00:00 | 07/08/2024 00:00 | 06/08/2024 23:00 | 06/08/2024 00:00 | 06/08/2024 21:00 | |
| Maximum | 48.79 | 0.63 | 96.5 | 0 | 42.4 | |
| MaxDate | 06/08/2024 04:00 | 06/08/2024 00:00 | 06/08/2024 08:00 | 06/08/2024 00:00 | 06/08/2024 12:00 | |
| Avg | 37.06 | 0.32 | 95.28 | 0 | 27.5 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11 | 0.2 | 0.7 | 0 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 08:00 | 5.84 | 0.05 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/08/2024 09:00 | 32.47 | 0.07 | 95.86 | 0 | 31.8 | |
| 06/08/2024 10:00 | 34.56 | 0.1 | 95.57 | 0 | 25.1 | |
| 06/08/2024 11:00 | 34.56 | 0.11 | 96.17 | 0 | 24.9 | |
| 06/08/2024 12:00 | 24.84 | 0.1 | 94.68 | 0 | 44.9 | |
| 06/08/2024 13:00 | 31.45 | 0.09 | 94.85 | 0 | 33.2 | |
| 06/08/2024 14:00 | 34.62 | 0.07 | 95.59 | 0 | 25 | |
| 06/08/2024 15:00 | 34.54 | 0.34 | 95.13 | 0 | 24.8 | |
| 06/08/2024 16:00 | 34.48 | 0.05 | 95.22 | 0 | 24.6 | |
| 06/08/2024 17:00 | 34.38 | 0.05 | 95.21 | 0 | 24.7 | |
| 06/08/2024 18:00 | 34.29 | 0.08 | 95.04 | 0 | 24.6 | |
| 06/08/2024 19:00 | 34.19 | 0.04 | 94.68 | 0 | 23.8 | |
| 06/08/2024 20:00 | 33.99 | 0 | 94.33 | 0 | 23.4 | |
| 06/08/2024 21:00 | 34.17 | 0 | 94.49 | 0 | 23.3 | |
| 06/08/2024 22:00 | 34.25 | 0 | 94.77 | 0 | 23.3 | |
| 06/08/2024 23:00 | 33.16 | 0 | 94.49 | 0 | 31.8 | |
| 07/08/2024 00:00 | 48.27 | 0 | 96.35 | 0 | 42.3 | |
| Minimum | 0 | 0 | 94.33 | 0 | 23.3 | |
| MinDate | 06/08/2024 00:00 | 06/08/2024 00:00 | 06/08/2024 20:00 | 06/08/2024 09:00 | 06/08/2024 21:00 | |
| Maximum | 48.27 | 0.34 | 96.35 | 0 | 44.9 | |
| MaxDate | 07/08/2024 00:00 | 06/08/2024 15:00 | 07/08/2024 00:00 | 06/08/2024 09:00 | 06/08/2024 12:00 | |
| Avg | 22.16 | 0.05 | 95.15 | 0 | 28.2 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 0.1 | 0.6 | 0 | 6.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 01:00 | 0 | 0.86 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 02:00 | 0 | 0.51 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 03:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 04:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 05:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 06:00 | 0 | 0.6 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 07:00 | 0 | 0.35 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 08:00 | 5.58 | 0.76 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/08/2024 09:00 | 32.45 | 0.6 | 95.19 | 0 | 34.3 | |
| 07/08/2024 10:00 | 34.62 | 0.73 | 95.98 | 0 | 27.8 | |
| 07/08/2024 11:00 | 34.62 | 0.81 | 96.19 | 0 | 27.7 | |
| 07/08/2024 12:00 | 24.96 | 0.82 | 93.64 | 0 | 47.8 | |
| 07/08/2024 13:00 | 31.4 | 0.67 | 93.98 | 0 | 36.5 | |
| 07/08/2024 14:00 | 34.62 | 0.61 | 95.49 | 0 | 27.6 | |
| 07/08/2024 15:00 | 34.6 | 0.59 | 95.03 | 0 | 27.2 | |
| 07/08/2024 16:00 | 34.53 | 0.53 | 95.11 | 0 | 27 | |
| 07/08/2024 17:00 | 34.38 | 0.49 | 95 | 0 | 26.7 | |
| 07/08/2024 18:00 | 34.33 | 0.52 | 95.07 | 0 | 26.6 | |
| 07/08/2024 19:00 | 34.2 | 0.62 | 94.92 | 0 | 26.5 | |
| 07/08/2024 20:00 | 34.24 | 0.62 | 94.9 | 0 | 26.3 | |
| 07/08/2024 21:00 | 34.45 | 0.54 | 95.19 | 0 | 26 | |
| 07/08/2024 22:00 | 34.53 | 0.47 | 95.28 | 0 | 26.1 | |
| 07/08/2024 23:00 | 33.58 | 0.62 | 94.78 | 0 | 34.5 | |
| 08/08/2024 00:00 | 48.55 | 0.59 | 96.1 | 0 | 38.5 | |
| Minimum | 0 | 0 | 93.64 | 0 | 26 | |
| MinDate | 07/08/2024 00:00 | 07/08/2024 00:00 | 07/08/2024 12:00 | 07/08/2024 09:00 | 07/08/2024 21:00 | |
| Maximum | 48.55 | 0.86 | 96.19 | 0 | 47.8 | |
| MaxDate | 08/08/2024 00:00 | 07/08/2024 01:00 | 07/08/2024 11:00 | 07/08/2024 09:00 | 07/08/2024 12:00 | |
| Avg | 22.23 | 0.53 | 95.12 | 0 | 30.4 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 0.2 | 0.7 | 0 | 6.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/08/2024 00:00 | 48.27 | 0 | 96.35 | 0 | 42.3 | |
| 07/08/2024 01:00 | 49.01 | 0 | 94.67 | 0 | 42.8 | |
| 07/08/2024 02:00 | 49.05 | 0 | 95.9 | 0 | 42.5 | |
| 07/08/2024 03:00 | 49 | 0 | 96.06 | 0 | 42.9 | |
| 07/08/2024 04:00 | 48.93 | 0 | 96.08 | 0 | 42.5 | |
| 07/08/2024 05:00 | 48.75 | 0 | 96.22 | 0 | 41.7 | |
| 07/08/2024 06:00 | 48.89 | 0 | 96.87 | 0 | 41.9 | |
| 07/08/2024 07:00 | 48.73 | 0 | 95.84 | 0 | 42.2 | |
| 07/08/2024 08:00 | 44.26 | 0.04 | 96.04 | 0 | 39.2 | |
| 07/08/2024 09:00 | 32.37 | 0.06 | 94.91 | 0 | 29.8 | |
| 07/08/2024 10:00 | 34.56 | 0.16 | 95.5 | 0 | 22.8 | |
| 07/08/2024 11:00 | 34.55 | 0.19 | 95.75 | 0 | 22.7 | |
| 07/08/2024 12:00 | 24.85 | 0.13 | 93.33 | 0 | 44.4 | |
| 07/08/2024 13:00 | 31.32 | 0.05 | 93.68 | 0 | 32.2 | |
| 07/08/2024 14:00 | 34.55 | 0.03 | 95.06 | 0 | 22.6 | |
| 07/08/2024 15:00 | 34.54 | 0.25 | 94.71 | 0 | 22.2 | |
| 07/08/2024 16:00 | 34.47 | 0 | 94.94 | 0 | 22 | |
| 07/08/2024 17:00 | 34.32 | 0 | 94.84 | 0 | 21.8 | |
| 07/08/2024 18:00 | 34.27 | 0 | 94.95 | 0 | 21.7 | |
| 07/08/2024 19:00 | 34.14 | 0.05 | 94.83 | 0 | 21.6 | |
| 07/08/2024 20:00 | 34.17 | 0.05 | 94.79 | 0 | 21.4 | |
| 07/08/2024 21:00 | 34.38 | 0 | 94.89 | 0 | 21.3 | |
| 07/08/2024 22:00 | 34.47 | 0 | 94.94 | 0 | 21.5 | |
| 07/08/2024 23:00 | 25.19 | 0 | 93.96 | 0 | 30.8 | |
| 08/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0 | 93.33 | 0 | 21.3 | |
| MinDate | 08/08/2024 00:00 | 07/08/2024 00:00 | 07/08/2024 12:00 | 07/08/2024 00:00 | 07/08/2024 21:00 | |
| Maximum | 49.05 | 0.25 | 96.87 | 0 | 44.4 | |
| MaxDate | 07/08/2024 02:00 | 07/08/2024 15:00 | 07/08/2024 06:00 | 07/08/2024 00:00 | 07/08/2024 12:00 | |
| Avg | 37.08 | 0.04 | 95.21 | 0 | 31.5 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11.1 | 0.1 | 0.9 | 0 | 9.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/08/2024 00:00 | 48.55 | 0.59 | 96.1 | 0 | 38.5 | |
| 08/08/2024 01:00 | 48.7 | 0.42 | 95.37 | 0 | 38.4 | |
| 08/08/2024 02:00 | 48.74 | 0.53 | 95.88 | 0 | 38.1 | |
| 08/08/2024 03:00 | 48.79 | 0.45 | 95.96 | 0 | 37.9 | |
| 08/08/2024 04:00 | 48.86 | 0.42 | 95.93 | 0 | 37.6 | |
| 08/08/2024 05:00 | 48.86 | 0.37 | 96.02 | 0 | 37.5 | |
| 08/08/2024 06:00 | 48.83 | 0.74 | 96.49 | 0 | 37.4 | |
| 08/08/2024 07:00 | 48.61 | 0.43 | 96.04 | 0 | 37.2 | |
| 08/08/2024 08:00 | 44.98 | 0.53 | 97.13 | 0 | 35.9 | |
| 08/08/2024 09:00 | 32.44 | 0.77 | 95.05 | 0 | 33 | |
| 08/08/2024 10:00 | 34.47 | 0.76 | 95.29 | 0 | 25.8 | |
| 08/08/2024 11:00 | 34.4 | 0.71 | 94.85 | 0 | 25.5 | |
| 08/08/2024 12:00 | 25.06 | 0.74 | 93.23 | 0 | 43.8 | |
| 08/08/2024 13:00 | 31.45 | 0.62 | 94.09 | 0 | 33.4 | |
| 08/08/2024 14:00 | 34.48 | 0.63 | 95.33 | 0 | 25.6 | |
| 08/08/2024 15:00 | 34.49 | 0.63 | 95.01 | 0 | 25.6 | |
| 08/08/2024 16:00 | 34.47 | 0.67 | 94.81 | 0 | 25.4 | |
| 08/08/2024 17:00 | 34.35 | 0.63 | 94.7 | 0 | 25.4 | |
| 08/08/2024 18:00 | 34.34 | 0.58 | 94.74 | 0 | 25.3 | |
| 08/08/2024 19:00 | 34.13 | 0.52 | 94.69 | 0 | 25.5 | |
| 08/08/2024 20:00 | 34.19 | 0.45 | 94.48 | 0 | 25.1 | |
| 08/08/2024 21:00 | 34.44 | 0.48 | 94.84 | 0 | 24.8 | |
| 08/08/2024 22:00 | 34.44 | 0.44 | 95.03 | 0 | 24.7 | |
| 08/08/2024 23:00 | 24.88 | 0.46 | 94.06 | 0 | 33.9 | |
| 09/08/2024 00:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.3 | 93.23 | 0 | 24.7 | |
| MinDate | 09/08/2024 00:00 | 09/08/2024 00:00 | 08/08/2024 12:00 | 08/08/2024 00:00 | 08/08/2024 22:00 | |
| Maximum | 48.86 | 0.77 | 97.13 | 0 | 43.8 | |
| MaxDate | 08/08/2024 04:00 | 08/08/2024 09:00 | 08/08/2024 08:00 | 08/08/2024 00:00 | 08/08/2024 12:00 | |
| Avg | 37.08 | 0.55 | 95.21 | 0 | 31.7 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11.1 | 0.1 | 0.9 | 0 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 07:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 08:00 | 4.81 | 0.09 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/08/2024 09:00 | 32.38 | 0.19 | 96.55 | 0 | 31.3 | |
| 08/08/2024 10:00 | 34.41 | 0.2 | 95.72 | 0 | 23.9 | |
| 08/08/2024 11:00 | 34.34 | 0.02 | 95.31 | 0 | 23.5 | |
| 08/08/2024 12:00 | 24.96 | 0.05 | 93.51 | 0 | 42.7 | |
| 08/08/2024 13:00 | 31.39 | 0.09 | 94.38 | 0 | 31.8 | |
| 08/08/2024 14:00 | 34.4 | 0.11 | 95.52 | 0 | 23.4 | |
| 08/08/2024 15:00 | 34.43 | 0.25 | 95.39 | 0 | 23.4 | |
| 08/08/2024 16:00 | 34.41 | 0.07 | 95.25 | 0 | 23.1 | |
| 08/08/2024 17:00 | 34.28 | 0.04 | 95.06 | 0 | 23 | |
| 08/08/2024 18:00 | 34.28 | 0.03 | 95.12 | 0 | 23.1 | |
| 08/08/2024 19:00 | 34.06 | 0.02 | 95.05 | 0 | 23.3 | |
| 08/08/2024 20:00 | 34.12 | 0 | 94.85 | 0 | 22.9 | |
| 08/08/2024 21:00 | 34.38 | 0 | 95.06 | 0 | 22.8 | |
| 08/08/2024 22:00 | 34.37 | 0 | 95.19 | 0 | 22.6 | |
| 08/08/2024 23:00 | 33.6 | 0 | 94.95 | 0 | 31.8 | |
| 09/08/2024 00:00 | 48.48 | 0 | 96.29 | 0 | 42.6 | |
| Minimum | 0 | 0 | 93.51 | 0 | 22.6 | |
| MinDate | 08/08/2024 00:00 | 08/08/2024 00:00 | 08/08/2024 12:00 | 08/08/2024 09:00 | 08/08/2024 22:00 | |
| Maximum | 48.48 | 0.25 | 96.55 | 0 | 42.7 | |
| MaxDate | 09/08/2024 00:00 | 08/08/2024 15:00 | 08/08/2024 09:00 | 08/08/2024 09:00 | 08/08/2024 12:00 | |
| Avg | 22.12 | 0.05 | 95.2 | 0 | 27.2 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 0.1 | 0.7 | 0 | 6.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/08/2024 00:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 01:00 | 0 | 0.35 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 02:00 | 0 | 0.41 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 03:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 04:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 05:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 06:00 | 0 | 0.49 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 07:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 08:00 | 5.7 | 0.72 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/08/2024 09:00 | 32.49 | 0.43 | 95.94 | 0 | 33.3 | |
| 09/08/2024 10:00 | 34.6 | 0.57 | 95 | 0 | 27.1 | |
| 09/08/2024 11:00 | 34.48 | 0.78 | 94.64 | 0 | 26.5 | |
| 09/08/2024 12:00 | 25.07 | 0.72 | 92.58 | 0 | 46.4 | |
| 09/08/2024 13:00 | 31.45 | 0.53 | 93.77 | 0 | 34.6 | |
| 09/08/2024 14:00 | 34.59 | 0.46 | 95.29 | 0 | 26 | |
| 09/08/2024 15:00 | 34.56 | 0.42 | 94.79 | 0 | 26 | |
| 09/08/2024 16:00 | 34.41 | 0.27 | 94.55 | 0 | 25.9 | |
| 09/08/2024 17:00 | 34.31 | 0.31 | 94.41 | 0 | 25.6 | |
| 09/08/2024 18:00 | 34.18 | 0.29 | 94.31 | 0 | 25.6 | |
| 09/08/2024 19:00 | 33.98 | 0.32 | 94.1 | 0 | 25.5 | |
| 09/08/2024 20:00 | 34.18 | 0.31 | 93.94 | 0 | 25.4 | |
| 09/08/2024 21:00 | 34.31 | 0.41 | 94.5 | 0 | 25.3 | |
| 09/08/2024 22:00 | 37.46 | 0.52 | 96.24 | 0 | 26.8 | |
| 09/08/2024 23:00 | 31.93 | 0.81 | 95.24 | 0 | 36.7 | |
| 10/08/2024 00:00 | 28.5 | 1.05 | 92.95 | 0 | 43.7 | |
| Minimum | 0 | 0.23 | 92.58 | 0 | 25.3 | |
| MinDate | 09/08/2024 00:00 | 09/08/2024 04:00 | 09/08/2024 12:00 | 09/08/2024 09:00 | 09/08/2024 21:00 | |
| Maximum | 37.46 | 1.05 | 96.24 | 0 | 46.4 | |
| MaxDate | 09/08/2024 22:00 | 10/08/2024 00:00 | 09/08/2024 22:00 | 09/08/2024 09:00 | 09/08/2024 12:00 | |
| Avq | 21.45 | 0.46 | 94.52 | 0 | 30 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.1 | 0.2 | 1 | 0 | 6.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/08/2024 00:00 | 48.48 | 0 | 96.29 | 0 | 42.6 | |
| 09/08/2024 01:00 | 48.57 | 0 | 95.26 | 0 | 42.7 | |
| 09/08/2024 02:00 | 48.55 | 0 | 95.73 | 0 | 42.4 | |
| 09/08/2024 03:00 | 48.62 | 0 | 95.71 | 0 | 42.4 | |
| 09/08/2024 04:00 | 48.58 | 0 | 95.67 | 0 | 42.3 | |
| 09/08/2024 05:00 | 48.67 | 0 | 95.65 | 0 | 42.1 | |
| 09/08/2024 06:00 | 48.64 | 0 | 96.05 | 0 | 41.8 | |
| 09/08/2024 07:00 | 48.36 | 0 | 95.38 | 0 | 41.1 | |
| 09/08/2024 08:00 | 43.94 | 0.01 | 96.28 | 0 | 37.9 | |
| 09/08/2024 09:00 | 32.45 | 0 | 95.73 | 0 | 28.6 | |
| 09/08/2024 10:00 | 34.54 | 0.08 | 95.73 | 0 | 22.1 | |
| 09/08/2024 11:00 | 34.42 | 0.04 | 95.33 | 0 | 21.5 | |
| 09/08/2024 12:00 | 25.03 | 0 | 93.31 | 0 | 42.7 | |
| 09/08/2024 13:00 | 31.39 | 0 | 94.3 | 0 | 30.2 | |
| 09/08/2024 14:00 | 34.52 | 0 | 95.52 | 0 | 21.3 | |
| 09/08/2024 15:00 | 34.51 | 0.39 | 95.17 | 0 | 21.3 | |
| 09/08/2024 16:00 | 34.35 | 0 | 94.94 | 0 | 21.2 | |
| 09/08/2024 17:00 | 34.25 | 0.02 | 94.85 | 0 | 21 | |
| 09/08/2024 18:00 | 34.12 | 0 | 94.79 | 0 | 21 | |
| 09/08/2024 19:00 | 33.92 | 0 | 94.57 | 0 | 20.9 | |
| 09/08/2024 20:00 | 34.11 | 0 | 94.37 | 0 | 20.9 | |
| 09/08/2024 21:00 | 34.25 | 0 | 94.82 | 0 | 20.8 | |
| 09/08/2024 22:00 | 37.39 | 0 | 96.61 | 0 | 22.4 | |
| 09/08/2024 23:00 | 31.86 | 0.03 | 95.61 | 0 | 32.4 | |
| 10/08/2024 00:00 | 28.45 | 0.02 | 93.26 | 0 | 38 | |
| Minimum | 25.03 | 0 | 93.26 | 0 | 20.8 | |
| MinDate | 09/08/2024 12:00 | 09/08/2024 00:00 | 10/08/2024 00:00 | 09/08/2024 00:00 | 09/08/2024 21:00 | |
| Maximum | 48.67 | 0.39 | 96.61 | 0 | 42.7 | |
| MaxDate | 09/08/2024 05:00 | 09/08/2024 15:00 | 09/08/2024 22:00 | 09/08/2024 00:00 | 09/08/2024 01:00 | |
| Avq | 38.48 | 0.02 | 95.24 | 0 | 31.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.7 | 0.1 | 0.8 | 0 | 9.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/08/2024 00:00 | 28.5 | 1.05 | 92.95 | 0 | 43.7 | |
| 10/08/2024 01:00 | 28.7 | 0.94 | 93.16 | 0 | 43 | |
| 10/08/2024 02:00 | 28.62 | 0.92 | 93.12 | 0 | 43 | |
| 10/08/2024 03:00 | 28.47 | 0.79 | 93.21 | 0 | 43.3 | |
| 10/08/2024 04:00 | 28.24 | 0.71 | 93.17 | 0 | 43.9 | |
| 10/08/2024 05:00 | 28.1 | 0.62 | 93.08 | 0 | 44.4 | |
| 10/08/2024 06:00 | 28.1 | 0.67 | 93.06 | 0 | 44.5 | |
| 10/08/2024 07:00 | 27.98 | 0.47 | 93.58 | 0 | 43.6 | |
| 10/08/2024 08:00 | 28.14 | 0.57 | 93.76 | 0 | 43.3 | |
| 10/08/2024 09:00 | 38.76 | 0.54 | 97.92 | 0 | 33 | |
| 10/08/2024 10:00 | 42.15 | 0.55 | 101.26 | 0 | 29.3 | |
| 10/08/2024 11:00 | 42.06 | 0.59 | 101.52 | 0 | 29.4 | |
| 10/08/2024 12:00 | 31.58 | 0.66 | 97.88 | 0 | 38.8 | |
| 10/08/2024 13:00 | 38.49 | 0.54 | 98.41 | 0 | 33.1 | |
| 10/08/2024 14:00 | 42.07 | 0.44 | 101.37 | 0 | 29.4 | |
| 10/08/2024 15:00 | 42.13 | 0.45 | 100.81 | 0 | 28.6 | |
| 10/08/2024 16:00 | 42.09 | 0.4 | 100.31 | 0 | 28.5 | |
| 10/08/2024 17:00 | 42.06 | 0.41 | 100.19 | 0 | 28.2 | |
| 10/08/2024 18:00 | 41.93 | 0.38 | 99.84 | 0 | 28.6 | |
| 10/08/2024 19:00 | 41.77 | 0.31 | 99.58 | 0 | 28.1 | |
| 10/08/2024 20:00 | 41.8 | 0.2 | 99.43 | 0 | 27.6 | |
| 10/08/2024 21:00 | 41.87 | 0.15 | 99.87 | 0 | 27.5 | |
| 10/08/2024 22:00 | 41.86 | 0.14 | 100.12 | 0 | 27.4 | |
| 10/08/2024 23:00 | 34.83 | 0.4 | 97.54 | 0 | 34.1 | |
| 11/08/2024 00:00 | 28.01 | 0.56 | 93.08 | 0 | 42.7 | |
| Minimum | 27.98 | 0.14 | 92.95 | 0 | 27.4 | |
| MinDate | 10/08/2024 07:00 | 10/08/2024 22:00 | 10/08/2024 00:00 | 10/08/2024 00:00 | 10/08/2024 22:00 | |
| Maximum | 42.15 | 1.05 | 101.52 | 0 | 44.5 | |
| MaxDate | 10/08/2024 10:00 | 10/08/2024 00:00 | 10/08/2024 11:00 | 10/08/2024 00:00 | 10/08/2024 06:00 | |
| Avg | 35.53 | 0.54 | 97.13 | 0 | 35.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.5 | 0.2 | 3.4 | 0 | 7.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | | |
| 10/08/2024 00:00 | 28.45 | 0.02 | 93.26 | 0 | 38 | |
| 10/08/2024 01:00 | 28.65 | 0.01 | 93.28 | 0 | 37.4 | |
| 10/08/2024 02:00 | 28.57 | 0.05 | 93.26 | 0 | 37.4 | |
| 10/08/2024 03:00 | 28.4 | 0.07 | 93.35 | 0 | 37.6 | |
| 10/08/2024 04:00 | 28.18 | 0.09 | 93.31 | 0 | 37.9 | |
| 10/08/2024 05:00 | 28.04 | 0.08 | 93.23 | 0 | 38.4 | |
| 10/08/2024 06:00 | 28.04 | 0.08 | 93.17 | 0 | 38.4 | |
| 10/08/2024 07:00 | 27.92 | 0.14 | 93.7 | 0 | 37.7 | |
| 10/08/2024 08:00 | 28.08 | 0.25 | 93.94 | 0 | 37.5 | |
| 10/08/2024 09:00 | 38.68 | 0.32 | 98.1 | 0 | 29.6 | |
| 10/08/2024 10:00 | 42.08 | 0.36 | 101.18 | 0 | 26.3 | |
| 10/08/2024 11:00 | 41.98 | 0.37 | 101.43 | 0 | 26.6 | |
| 10/08/2024 12:00 | 31.52 | 0.34 | 97.79 | 0 | 34.1 | |
| 10/08/2024 13:00 | 38.42 | 0.28 | 98.44 | 0 | 29.9 | |
| 10/08/2024 14:00 | 41.99 | 0.26 | 101.21 | 0 | 26.9 | |
| 10/08/2024 15:00 | 42.05 | 0.36 | 100.88 | 0 | 26 | |
| 10/08/2024 16:00 | 42.02 | 0 | 100.46 | 0 | 25.3 | |
| 10/08/2024 17:00 | 41.98 | 0 | 100.32 | 0 | 24.9 | |
| 10/08/2024 18:00 | 41.86 | 0 | 100 | 0 | 25 | |
| 10/08/2024 19:00 | 41.7 | 0 | 99.69 | 0 | 24.4 | |
| 10/08/2024 20:00 | 41.72 | 0 | 99.54 | 0 | 23.8 | |
| 10/08/2024 21:00 | 41.8 | 0 | 99.85 | 0 | 23.9 | |
| 10/08/2024 22:00 | 41.79 | 0 | 100.05 | 0 | 24 | |
| 10/08/2024 23:00 | 34.75 | 0 | 97.49 | 0 | 29.9 | |
| 11/08/2024 00:00 | 27.94 | 0 | 93.38 | 0 | 36.8 | |
| Minimum | 27.92 | 0 | 93.17 | 0 | 23.8 | |
| MinDate | 10/08/2024 07:00 | 10/08/2024 16:00 | 10/08/2024 06:00 | 10/08/2024 00:00 | 10/08/2024 20:00 | |
| Maximum | 42.08 | 0.37 | 101.43 | 0 | 38.4 | |
| MaxDate | 10/08/2024 10:00 | 10/08/2024 11:00 | 10/08/2024 11:00 | 10/08/2024 00:00 | 10/08/2024 05:00 | |
| Avg | 35.46 | 0.12 | 97.21 | 0 | 31.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.5 | 0.1 | 3.3 | 0 | 6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/08/2024 00:00 | 28.01 | 0.56 | 93.08 | 0 | 42.7 | |
| 11/08/2024 01:00 | 28.03 | 0.57 | 93.07 | 0 | 42.2 | |
| 11/08/2024 02:00 | 28.03 | 0.49 | 93.11 | 0 | 41.8 | |
| 11/08/2024 03:00 | 27.98 | 0.5 | 93.17 | 0 | 41.7 | |
| 11/08/2024 04:00 | 27.96 | 0.57 | 93.14 | 0 | 41.9 | |
| 11/08/2024 05:00 | 27.86 | 0.48 | 93 | 0 | 42.1 | |
| 11/08/2024 06:00 | 27.73 | 0.74 | 93.07 | 0 | 42.8 | |
| 11/08/2024 07:00 | 27.49 | 0.49 | 93.34 | 0 | 43.1 | |
| 11/08/2024 08:00 | 27.34 | 0.53 | 93.15 | 0 | 43.8 | |
| 11/08/2024 09:00 | 27.38 | 0.52 | 93.12 | 0 | 44.3 | |
| 11/08/2024 10:00 | 27.36 | 0.5 | 93.14 | 0 | 45.2 | |
| 11/08/2024 11:00 | 27.27 | 0.53 | 93.83 | 0 | 45 | |
| 11/08/2024 12:00 | 27.34 | 0.55 | 94.34 | 0 | 44.2 | |
| 11/08/2024 13:00 | 27.36 | 0.47 | 93.61 | 0 | 43.5 | |
| 11/08/2024 14:00 | 27.39 | 0.37 | 93.05 | 0 | 44 | |
| 11/08/2024 15:00 | 27.44 | 0.37 | 92.82 | 0 | 43.2 | |
| 11/08/2024 16:00 | 27.41 | 0.34 | 92.73 | 0 | 43.5 | |
| 11/08/2024 17:00 | 27.4 | 0.34 | 92.64 | 0 | 43.2 | |
| 11/08/2024 18:00 | 34.35 | 0.28 | 94.66 | 0 | 35.9 | |
| 11/08/2024 19:00 | 41.22 | 0.19 | 99 | 0 | 26.4 | |
| 11/08/2024 20:00 | 41.19 | 0.03 | 98.86 | 0 | 26.4 | |
| 11/08/2024 21:00 | 41.2 | 0.23 | 99.01 | 0 | 25.7 | |
| 11/08/2024 22:00 | 27.33 | 0.45 | 93.89 | 0 | 41.1 | |
| 11/08/2024 23:00 | 27.4 | 0.32 | 92.87 | 0 | 41.9 | |
| 12/08/2024 00:00 | 27.41 | 0.26 | 92.97 | 0 | 41.8 | |
| Minimum | 27.27 | 0.03 | 92.64 | 0 | 25.7 | |
| MinDate | 11/08/2024 11:00 | 11/08/2024 20:00 | 11/08/2024 17:00 | 11/08/2024 00:00 | 11/08/2024 21:00 | |
| Maximum | 41.22 | 0.74 | 99.01 | 0 | 45.2 | |
| MaxDate | 11/08/2024 19:00 | 11/08/2024 06:00 | 11/08/2024 21:00 | 11/08/2024 00:00 | 11/08/2024 10:00 | |
| Avg | 29.48 | 0.43 | 93.95 | 0 | 40.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.2 | 1.9 | 0 | 5.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/08/2024 00:00 | 27.94 | 0 | 93.38 | 0 | 36.8 | |
| 11/08/2024 01:00 | 27.97 | 0 | 93.42 | 0 | 36.2 | |
| 11/08/2024 02:00 | 27.96 | 0 | 93.42 | 0 | 36 | |
| 11/08/2024 03:00 | 27.92 | 0 | 93.52 | 0 | 35.8 | |
| 11/08/2024 04:00 | 27.9 | 0 | 93.53 | 0 | 36 | |
| 11/08/2024 05:00 | 27.78 | 0 | 93.41 | 0 | 36.2 | |
| 11/08/2024 06:00 | 27.66 | 0 | 93.39 | 0 | 36.8 | |
| 11/08/2024 07:00 | 27.43 | 0 | 93.72 | 0 | 36.9 | |
| 11/08/2024 08:00 | 27.28 | 0.01 | 93.51 | 0 | 39.5 | |
| 11/08/2024 09:00 | 27.31 | 0.03 | 93.46 | 0 | 38.3 | |
| 11/08/2024 10:00 | 27.29 | 0.04 | 93.48 | 0 | 39.3 | |
| 11/08/2024 11:00 | 27.21 | 0.07 | 94.11 | 0 | 39.3 | |
| 11/08/2024 12:00 | 27.28 | 0.08 | 94.63 | 0 | 38.5 | |
| 11/08/2024 13:00 | 27.3 | 0.04 | 93.88 | 0 | 38 | |
| 11/08/2024 14:00 | 27.32 | 0.01 | 93.39 | 0 | 38.2 | |
| 11/08/2024 15:00 | 27.37 | 0.3 | 93.28 | 0 | 37.6 | |
| 11/08/2024 16:00 | 27.35 | 0.05 | 93.21 | 0 | 37.9 | |
| 11/08/2024 17:00 | 27.35 | 0.05 | 93.16 | 0 | 37.7 | |
| 11/08/2024 18:00 | 34.26 | 0.04 | 95.33 | 0 | 32.1 | |
| 11/08/2024 19:00 | 41.14 | 0.02 | 99.5 | 0 | 23.7 | |
| 11/08/2024 20:00 | 41.11 | 0 | 99.4 | 0 | 23.3 | |
| 11/08/2024 21:00 | 41.13 | 0 | 99.47 | 0 | 22.7 | |
| 11/08/2024 22:00 | 27.24 | 0 | 94.18 | 0 | 36.7 | |
| 11/08/2024 23:00 | 27.33 | 0 | 93.17 | 0 | 36.9 | |
| 12/08/2024 00:00 | 27.34 | 0 | 93.28 | 0 | 36.7 | |
| Minimum | 27.21 | 0 | 93.16 | 0 | 22.7 | |
| MinDate | 11/08/2024 11:00 | 11/08/2024 00:00 | 11/08/2024 17:00 | 11/08/2024 00:00 | 11/08/2024 21:00 | |
| Maximum | 41.14 | 0.3 | 99.5 | 0 | 39.5 | |
| MaxDate | 11/08/2024 19:00 | 11/08/2024 15:00 | 11/08/2024 19:00 | 11/08/2024 00:00 | 11/08/2024 08:00 | |
| Avg | 29.41 | 0.03 | 94.33 | 0 | 35.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.1 | 2 | 0 | 4.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/08/2024 00:00 | 27.41 | 0.26 | 92.97 | 0 | 41.8 | |
| 12/08/2024 01:00 | 27.42 | 0.37 | 92.98 | 0 | 41.2 | |
| 12/08/2024 02:00 | 27.43 | 0.5 | 92.98 | 0 | 41.3 | |
| 12/08/2024 03:00 | 27.28 | 0.35 | 92.41 | 0 | 45.5 | |
| 12/08/2024 04:00 | 27.24 | 0.48 | 92.3 | 0 | 44.6 | |
| 12/08/2024 05:00 | 27.26 | 0.47 | 92.57 | 0 | 43.6 | |
| 12/08/2024 06:00 | 27.26 | 0.77 | 92.68 | 0 | 43.7 | |
| 12/08/2024 07:00 | 27.14 | 0.4 | 92.77 | 0 | 43.4 | |
| 12/08/2024 08:00 | 27.15 | 0.37 | 92.92 | 0 | 43 | |
| 12/08/2024 09:00 | 27.19 | 0.53 | 92.95 | 0 | 43 | |
| 12/08/2024 10:00 | 27.21 | 0.56 | 92.97 | 0 | 42.9 | |
| 12/08/2024 11:00 | 27.17 | 0.55 | 92.88 | 0 | 43.2 | |
| 12/08/2024 12:00 | 27.21 | 0.49 | 93.41 | 0 | 43.3 | |
| 12/08/2024 13:00 | 27.23 | 0.45 | 93.15 | 0 | 43.3 | |
| 12/08/2024 14:00 | 27.22 | 0.42 | 92.81 | 0 | 42.9 | |
| 12/08/2024 15:00 | 27.26 | 0.44 | 92.55 | 0 | 42.7 | |
| 12/08/2024 16:00 | 27.13 | 0.38 | 92.3 | 0 | 42.9 | |
| 12/08/2024 17:00 | 27.13 | 0.38 | 92.26 | 0 | 43.4 | |
| 12/08/2024 18:00 | 34.09 | 0.26 | 94.2 | 0 | 34.9 | |
| 12/08/2024 19:00 | 40.95 | 0.14 | 98.63 | 0 | 24.7 | |
| 12/08/2024 20:00 | 40.95 | 0.18 | 98.8 | 0 | 24.5 | |
| 12/08/2024 21:00 | 40.87 | 0.22 | 99.17 | 0 | 24.3 | |
| 12/08/2024 22:00 | 26.99 | 0.36 | 94.1 | 0 | 40.5 | |
| 12/08/2024 23:00 | 27.09 | 0.24 | 92.46 | 0 | 42.8 | |
| 13/08/2024 00:00 | 27.06 | 0.48 | 92.21 | 0 | 42.8 | |
| Minimum | 26.99 | 0.14 | 92.21 | 0 | 24.3 | |
| MinDate | 12/08/2024 22:00 | 12/08/2024 19:00 | 13/08/2024 00:00 | 12/08/2024 00:00 | 12/08/2024 21:00 | |
| Maximum | 40.95 | 0.77 | 99.17 | 0 | 45.5 | |
| MaxDate | 12/08/2024 19:00 | 12/08/2024 06:00 | 12/08/2024 21:00 | 12/08/2024 00:00 | 12/08/2024 03:00 | |
| Avg | 29.13 | 0.4 | 93.58 | 0 | 40.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.7 | 0.1 | 2.1 | 0 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/08/2024 00:00 | 27.34 | 0 | 93.28 | 0 | 36.7 | |
| 12/08/2024 01:00 | 27.36 | 0 | 93.26 | 0 | 36.3 | |
| 12/08/2024 02:00 | 27.36 | 0 | 93.26 | 0 | 36.4 | |
| 12/08/2024 03:00 | 27.22 | 0 | 92.54 | 0 | 40.6 | |
| 12/08/2024 04:00 | 27.17 | 0 | 92.55 | 0 | 39.5 | |
| 12/08/2024 05:00 | 27.2 | 0 | 92.87 | 0 | 38.4 | |
| 12/08/2024 06:00 | 27.19 | 0.01 | 92.96 | 0 | 38.5 | |
| 12/08/2024 07:00 | 27.08 | 0 | 93.07 | 0 | 38.2 | |
| 12/08/2024 08:00 | 27.09 | 0.01 | 93.23 | 0 | 37.9 | |
| 12/08/2024 09:00 | 27.13 | 0.09 | 93.34 | 0 | 38.1 | |
| 12/08/2024 10:00 | 27.15 | 0.12 | 93.36 | 0 | 38.1 | |
| 12/08/2024 11:00 | 27.11 | 0.12 | 93.27 | 0 | 38.5 | |
| 12/08/2024 12:00 | 27.14 | 0.1 | 93.78 | 0 | 38.7 | |
| 12/08/2024 13:00 | 27.17 | 0.1 | 93.48 | 0 | 39 | |
| 12/08/2024 14:00 | 27.16 | 0.1 | 93.18 | 0 | 38.4 | |
| 12/08/2024 15:00 | 27.2 | 0.21 | 93.04 | 0 | 38.2 | |
| 12/08/2024 16:00 | 27.07 | 0.02 | 92.81 | 0 | 38.3 | |
| 12/08/2024 17:00 | 27.07 | 0.01 | 92.78 | 0 | 38.8 | |
| 12/08/2024 18:00 | 34.01 | 0 | 94.84 | 0 | 31.5 | |
| 12/08/2024 19:00 | 40.88 | 0 | 99.01 | 0 | 21.9 | |
| 12/08/2024 20:00 | 40.88 | 0 | 99.21 | 0 | 21.8 | |
| 12/08/2024 21:00 | 40.79 | 0 | 99.35 | 0 | 21.6 | |
| 12/08/2024 22:00 | 26.92 | 0 | 94.26 | 0 | 36.7 | |
| 12/08/2024 23:00 | 27.02 | 0 | 92.7 | 0 | 38.9 | |
| 13/08/2024 00:00 | 27 | 0 | 92.55 | 0 | 39.2 | |
| Minimum | 26.92 | 0 | 92.54 | 0 | 21.6 | |
| MinDate | 12/08/2024 22:00 | 12/08/2024 00:00 | 12/08/2024 03:00 | 12/08/2024 00:00 | 12/08/2024 21:00 | |
| Maximum | 40.88 | 0.21 | 99.35 | 0 | 40.6 | |
| MaxDate | 12/08/2024 19:00 | 12/08/2024 15:00 | 12/08/2024 21:00 | 12/08/2024 00:00 | 12/08/2024 03:00 | |
| Avg | 29.07 | 0.04 | 93.92 | 0 | 36 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.1 | 2.1 | 0 | 5.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/08/2024 00:00 | 27.06 | 0.48 | 92.21 | 0 | 42.8 | |
| 13/08/2024 01:00 | 27.01 | 0.3 | 92.15 | 0 | 43.1 | |
| 13/08/2024 02:00 | 27.05 | 0.19 | 92.23 | 0 | 42.6 | |
| 13/08/2024 03:00 | 27.03 | 0.22 | 92.31 | 0 | 42.4 | |
| 13/08/2024 04:00 | 26.99 | 0.22 | 92.33 | 0 | 42.6 | |
| 13/08/2024 05:00 | 27.04 | 0.29 | 92.36 | 0 | 42.5 | |
| 13/08/2024 06:00 | 27.05 | 0.71 | 92.47 | 0 | 42.1 | |
| 13/08/2024 07:00 | 27.32 | 0.51 | 92.75 | 0 | 41.5 | |
| 13/08/2024 08:00 | 26.99 | 0.54 | 93.07 | 0 | 40 | |
| 13/08/2024 09:00 | 31.12 | 0.68 | 93.9 | 0 | 30.3 | |
| 13/08/2024 10:00 | 34.21 | 0.77 | 95.17 | 0 | 21.3 | |
| 13/08/2024 11:00 | 34.26 | 0.76 | 95.85 | 0 | 21.3 | |
| 13/08/2024 12:00 | 25.2 | 0.8 | 93.81 | 0 | 38.5 | |
| 13/08/2024 13:00 | 31.48 | 0.64 | 94.2 | 0 | 29.4 | |
| 13/08/2024 14:00 | 34.52 | 0.58 | 95.39 | 0 | 23.1 | |
| 13/08/2024 15:00 | 34.48 | 0.49 | 95.06 | 0 | 20.9 | |
| 13/08/2024 16:00 | 34.49 | 0.31 | 95.18 | 0 | 20.8 | |
| 13/08/2024 17:00 | 34.36 | 0.32 | 94.95 | 0 | 20.9 | |
| 13/08/2024 18:00 | 34.28 | 0.31 | 94.48 | 0 | 21.1 | |
| 13/08/2024 19:00 | 34.2 | 0.44 | 94.28 | 0 | 20.8 | |
| 13/08/2024 20:00 | 34.28 | 0.48 | 94.27 | 0 | 20.7 | |
| 13/08/2024 21:00 | 34.53 | 0.62 | 94.68 | 0 | 20.6 | |
| 13/08/2024 22:00 | 34.59 | 0.68 | 94.93 | 0 | 20.5 | |
| 13/08/2024 23:00 | 33.78 | 0.76 | 94.55 | 0 | 28.8 | |
| 14/08/2024 00:00 | 48.5 | 0.67 | 96.18 | 0 | 31.1 | |
| Minimum | 25.2 | 0.19 | 92.15 | 0 | 20.5 | |
| MinDate | 13/08/2024 12:00 | 13/08/2024 02:00 | 13/08/2024 01:00 | 13/08/2024 00:00 | 13/08/2024 22:00 | |
| Maximum | 48.5 | 0.8 | 96.18 | 0 | 43.1 | |
| MaxDate | 14/08/2024 00:00 | 13/08/2024 12:00 | 14/08/2024 00:00 | 13/08/2024 00:00 | 13/08/2024 01:00 | |
| Avg | 31.67 | 0.51 | 93.95 | 0 | 30.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5 | 0.2 | 1.3 | 0 | 9.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/08/2024 00:00 | 27 | 0 | 92.55 | 0 | 39.2 | |
| 13/08/2024 01:00 | 26.95 | 0 | 92.42 | 0 | 39.9 | |
| 13/08/2024 02:00 | 26.98 | 0 | 92.51 | 0 | 39 | |
| 13/08/2024 03:00 | 26.96 | 0 | 92.59 | 0 | 38.8 | |
| 13/08/2024 04:00 | 26.94 | 0 | 92.61 | 0 | 39.1 | |
| 13/08/2024 05:00 | 26.99 | 0 | 92.65 | 0 | 38.8 | |
| 13/08/2024 06:00 | 26.98 | 0 | 92.75 | 0 | 38.3 | |
| 13/08/2024 07:00 | 27.26 | 0 | 93.05 | 0 | 37 | |
| 13/08/2024 08:00 | 26.93 | 0 | 93.38 | 0 | 36.9 | |
| 13/08/2024 09:00 | 31.02 | 0.08 | 94.3 | 0 | 28.1 | |
| 13/08/2024 10:00 | 34.14 | 0.11 | 95.37 | 0 | 18.7 | |
| 13/08/2024 11:00 | 34.19 | 0.2 | 96.11 | 0 | 18.8 | |
| 13/08/2024 12:00 | 25.2 | 0.19 | 94.13 | 0 | 37.5 | |
| 13/08/2024 13:00 | 31.42 | 0.11 | 94.56 | 0 | 27.5 | |
| 13/08/2024 14:00 | 34.46 | 0.09 | 95.65 | 0 | 18.7 | |
| 13/08/2024 15:00 | 34.42 | 0.36 | 95.38 | 0 | 18.3 | |
| 13/08/2024 16:00 | 34.44 | 0 | 95.55 | 0 | 18.4 | |
| 13/08/2024 17:00 | 34.29 | 0 | 95.38 | 0 | 18.3 | |
| 13/08/2024 18:00 | 34.22 | 0 | 95.05 | 0 | 18.5 | |
| 13/08/2024 19:00 | 34.14 | 0 | 94.83 | 0 | 18.2 | |
| 13/08/2024 20:00 | 34.22 | 0 | 94.79 | 0 | 18.2 | |
| 13/08/2024 21:00 | 34.46 | 0 | 95.07 | 0 | 18.1 | |
| 13/08/2024 22:00 | 34.53 | 0 | 95.24 | 0 | 18.1 | |
| 13/08/2024 23:00 | 24.7 | 0 | 94.37 | 0 | 27.4 | |
| 14/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | S/D GT12 |
| Minimum | 0 | 0 | 92.42 | 0 | 18.1 | |
| MinDate | 14/08/2024 00:00 | 13/08/2024 00:00 | 13/08/2024 01:00 | 13/08/2024 00:00 | 13/08/2024 21:00 | |
| Maximum | 34.53 | 0.36 | 96.11 | 0 | 39.9 | |
| MaxDate | 13/08/2024 22:00 | 13/08/2024 15:00 | 13/08/2024 11:00 | 13/08/2024 00:00 | 13/08/2024 01:00 | |
| Avg | 29.31 | 0.05 | 94.18 | 0 | 27.9 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 7.2 | 0.1 | 1.2 | 0 | 9.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/08/2024 00:00 | 48.5 | 0.67 | 96.18 | 0 | 31.1 | |
| 14/08/2024 01:00 | 48.55 | 0.59 | 95.44 | 0 | 31.1 | |
| 14/08/2024 02:00 | 48.59 | 0.49 | 95.93 | 0 | 30.8 | |
| 14/08/2024 03:00 | 48.59 | 0.5 | 96.04 | 0 | 30.7 | |
| 14/08/2024 04:00 | 48.67 | 0.45 | 95.99 | 0 | 30.6 | |
| 14/08/2024 05:00 | 48.73 | 0.42 | 96.14 | 0 | 30.6 | |
| 14/08/2024 06:00 | 48.73 | 0.36 | 96.47 | 0 | 30.6 | |
| 14/08/2024 07:00 | 48.42 | 0.25 | 95.84 | 0 | 30.6 | |
| 14/08/2024 08:00 | 45.85 | 0.33 | 96.85 | 0 | 29.1 | |
| 14/08/2024 09:00 | 32.45 | 0.47 | 95.28 | 0 | 28.3 | |
| 14/08/2024 10:00 | 34.54 | 0.46 | 95.78 | 0 | 20.7 | |
| 14/08/2024 11:00 | 34.52 | 0.42 | 96.43 | 0 | 20.9 | |
| 14/08/2024 12:00 | 24.91 | 0.53 | 94.97 | 0 | 40.8 | |
| 14/08/2024 13:00 | 31.44 | 0.39 | 94.96 | 0 | 29.5 | |
| 14/08/2024 14:00 | 34.67 | 0.34 | 96.03 | 0 | 20.8 | |
| 14/08/2024 15:00 | 34.67 | 0.32 | 95.23 | 0 | 20.7 | |
| 14/08/2024 16:00 | 34.55 | 0.23 | 94.81 | 0 | 20.7 | |
| 14/08/2024 17:00 | 34.4 | 0.29 | 94.72 | 0 | 20.5 | |
| 14/08/2024 18:00 | 34.43 | 0.31 | 94.7 | 0 | 20.5 | |
| 14/08/2024 19:00 | 34.28 | 0.19 | 94.4 | 0 | 20.5 | |
| 14/08/2024 20:00 | 34.38 | 0.15 | 94.45 | 0 | 20.5 | |
| 14/08/2024 21:00 | 34.51 | 0.18 | 94.98 | 0 | 20.4 | |
| 14/08/2024 22:00 | 34.52 | 0.2 | 95.18 | 0 | 20.4 | |
| 14/08/2024 23:00 | 25.67 | 0.2 | 94.43 | 0 | 29.6 | |
| 15/08/2024 00:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.15 | 94.4 | 0 | 20.4 | |
| MinDate | 15/08/2024 00:00 | 14/08/2024 20:00 | 14/08/2024 19:00 | 14/08/2024 00:00 | 14/08/2024 21:00 | |
| Maximum | 48.73 | 0.67 | 96.85 | 0 | 40.8 | |
| MaxDate | 14/08/2024 05:00 | 14/08/2024 00:00 | 14/08/2024 08:00 | 14/08/2024 00:00 | 14/08/2024 12:00 | |
| Avg | 37.14 | 0.36 | 95.47 | 0 | 26.3 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11 | 0.1 | 0.7 | 0 | 5.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 07:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 08:00 | 3.64 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/08/2024 09:00 | 32.38 | 0.16 | 96.67 | 0 | 33.1 | |
| 14/08/2024 10:00 | 34.47 | 0.2 | 95.77 | 0 | 24.9 | |
| 14/08/2024 11:00 | 34.46 | 0.2 | 96.38 | 0 | 25.1 | |
| 14/08/2024 12:00 | 24.85 | 0.2 | 94.83 | 0 | 44.1 | |
| 14/08/2024 13:00 | 31.38 | 0.17 | 95.02 | 0 | 33.1 | |
| 14/08/2024 14:00 | 34.6 | 0.15 | 95.93 | 0 | 24.7 | |
| 14/08/2024 15:00 | 34.6 | 0.31 | 95.36 | 0 | 24.2 | |
| 14/08/2024 16:00 | 34.48 | 0 | 94.98 | 0 | 23.9 | |
| 14/08/2024 17:00 | 34.33 | 0 | 94.94 | 0 | 23.4 | |
| 14/08/2024 18:00 | 34.36 | 0 | 94.95 | 0 | 23.4 | |
| 14/08/2024 19:00 | 34.21 | 0 | 94.72 | 0 | 23.2 | |
| 14/08/2024 20:00 | 34.32 | 0 | 94.67 | 0 | 23.2 | |
| 14/08/2024 21:00 | 34.45 | 0 | 95.02 | 0 | 23.1 | |
| 14/08/2024 22:00 | 34.46 | 0 | 95.18 | 0 | 23 | |
| 14/08/2024 23:00 | 33.21 | 0 | 94.78 | 0 | 31.3 | |
| 15/08/2024 00:00 | 48.18 | 0 | 96.43 | 0 | 41.7 | |
| Minimum | 0 | 0 | 94.67 | 0 | 23 | |
| MinDate | 14/08/2024 00:00 | 14/08/2024 00:00 | 14/08/2024 20:00 | 14/08/2024 09:00 | 14/08/2024 22:00 | |
| Maximum | 48.18 | 0.31 | 96.67 | 0 | 44.1 | |
| MaxDate | 15/08/2024 00:00 | 14/08/2024 15:00 | 14/08/2024 09:00 | 14/08/2024 09:00 | 14/08/2024 12:00 | |
| Avg | 22.1 | 0.06 | 95.35 | 0 | 27.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 17 | 0.1 | 0.7 | 0 | 6.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/08/2024 00:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 01:00 | 0 | 0.39 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 02:00 | 0 | 0.43 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 03:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 04:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 05:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 06:00 | 0 | 0.66 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 07:00 | 0 | 0.39 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 08:00 | 5.6 | 0.67 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/08/2024 09:00 | 32.5 | 0.62 | 95.24 | 0 | 34.5 | |
| 15/08/2024 10:00 | 34.71 | 0.69 | 96.05 | 0 | 27.9 | |
| 15/08/2024 11:00 | 34.58 | 0.76 | 96.78 | 0 | 27.8 | |
| 15/08/2024 12:00 | 24.82 | 0.75 | 94.68 | 0 | 46.1 | |
| 15/08/2024 13:00 | 31.4 | 0.67 | 94.78 | 0 | 35.7 | |
| 15/08/2024 14:00 | 34.56 | 0.3 | 95.24 | 0 | 27.3 | |
| 15/08/2024 15:00 | 34.32 | 0.1 | 95.1 | 0 | 27 | |
| 15/08/2024 16:00 | 34.48 | 0.42 | 95.27 | 0 | 26.7 | |
| 15/08/2024 17:00 | 34.39 | 0.42 | 95.23 | 0 | 26.9 | |
| 15/08/2024 18:00 | 34.34 | 0.31 | 94.93 | 0 | 26.8 | |
| 15/08/2024 19:00 | 34.19 | 0.34 | 94.78 | 0 | 26.6 | |
| 15/08/2024 20:00 | 34.24 | 0.46 | 94.77 | 0 | 26.5 | |
| 15/08/2024 21:00 | 34.46 | 0.5 | 95.24 | 0 | 26.4 | |
| 15/08/2024 22:00 | 34.47 | 0.53 | 95.41 | 0 | 26.3 | |
| 15/08/2024 23:00 | 33.46 | 0.61 | 95.05 | 0 | 34 | |
| 16/08/2024 00:00 | 48.27 | 0.38 | 96.39 | 0 | 38.2 | |
| Minimum | 0 | 0.1 | 94.68 | 0 | 26.3 | |
| MinDate | 15/08/2024 00:00 | 15/08/2024 15:00 | 15/08/2024 12:00 | 15/08/2024 09:00 | 15/08/2024 22:00 | |
| Maximum | 48.27 | 0.76 | 96.78 | 0 | 46.1 | |
| MaxDate | 16/08/2024 00:00 | 15/08/2024 11:00 | 15/08/2024 11:00 | 15/08/2024 09:00 | 15/08/2024 12:00 | |
| Avg | 22.19 | 0.47 | 95.31 | 0 | 30.3 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 0.2 | 0.6 | 0 | 5.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/08/2024 00:00 | 48.18 | 0 | 96.43 | 0 | 41.7 | |
| 15/08/2024 01:00 | 48.35 | 0 | 94.99 | 0 | 41.9 | |
| 15/08/2024 02:00 | 48.39 | 0 | 95.38 | 0 | 41.7 | |
| 15/08/2024 03:00 | 48.31 | 0 | 95.52 | 0 | 41.5 | |
| 15/08/2024 04:00 | 48.43 | 0 | 95.51 | 0 | 41.4 | |
| 15/08/2024 05:00 | 48.47 | 0 | 95.54 | 0 | 41.3 | |
| 15/08/2024 06:00 | 48.54 | 0 | 96.28 | 0 | 41.3 | |
| 15/08/2024 07:00 | 48.29 | 0 | 95.26 | 0 | 41.1 | |
| 15/08/2024 08:00 | 43.94 | 0 | 95.56 | 0 | 38.8 | |
| 15/08/2024 09:00 | 32.43 | 0.04 | 95.08 | 0 | 29.5 | |
| 15/08/2024 10:00 | 34.64 | 0.08 | 95.71 | 0 | 22.6 | |
| 15/08/2024 11:00 | 34.51 | 0.14 | 96.37 | 0 | 22.6 | |
| 15/08/2024 12:00 | 24.66 | 0.12 | 94.2 | 0 | 43.1 | |
| 15/08/2024 13:00 | 31.23 | 0.09 | 94.35 | 0 | 31.8 | |
| 15/08/2024 14:00 | 34.49 | 0 | 94.66 | 0 | 22.2 | |
| 15/08/2024 15:00 | 34.26 | 0.31 | 94.78 | 0 | 22 | |
| 15/08/2024 16:00 | 34.41 | 0.27 | 94.9 | 0 | 21.7 | |
| 15/08/2024 17:00 | 34.32 | 0.3 | 94.93 | 0 | 21.8 | |
| 15/08/2024 18:00 | 34.28 | 0.18 | 94.66 | 0 | 21.8 | |
| 15/08/2024 19:00 | 34.12 | 0.13 | 94.53 | 0 | 21.6 | |
| 15/08/2024 20:00 | 34.17 | 0.18 | 94.58 | 0 | 21.6 | |
| 15/08/2024 21:00 | 34.4 | 0.19 | 94.86 | 0 | 21.5 | |
| 15/08/2024 22:00 | 34.4 | 0.2 | 95 | 0 | 21.4 | |
| 15/08/2024 23:00 | 25.07 | 0.29 | 94.03 | 0 | 29.7 | |
| 16/08/2024 00:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0 | 94.03 | 0 | 21.4 | |
| MinDate | 16/08/2024 00:00 | 15/08/2024 00:00 | 15/08/2024 23:00 | 15/08/2024 00:00 | 15/08/2024 22:00 | |
| Maximum | 48.54 | 0.31 | 96.43 | 0 | 43.1 | |
| MaxDate | 15/08/2024 06:00 | 15/08/2024 15:00 | 15/08/2024 00:00 | 15/08/2024 00:00 | 15/08/2024 12:00 | |
| Avg | 36.89 | 0.11 | 95.13 | 0 | 31.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.9 | 0.1 | 0.7 | 0 | 9.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/08/2024 00:00 | 48.27 | 0.38 | 96.39 | 0 | 38.2 | |
| 16/08/2024 01:00 | 48.45 | 0.39 | 95.31 | 0 | 38.1 | |
| 16/08/2024 02:00 | 48.46 | 0.33 | 95.72 | 0 | 37.9 | |
| 16/08/2024 03:00 | 48.57 | 0.35 | 95.68 | 0 | 37.7 | |
| 16/08/2024 04:00 | 48.54 | 0.32 | 95.77 | 0 | 37.6 | |
| 16/08/2024 05:00 | 48.55 | 0.35 | 95.67 | 0 | 37.6 | |
| 16/08/2024 06:00 | 48.52 | 0.52 | 96.33 | 0 | 37.5 | |
| 16/08/2024 07:00 | 48.25 | 0.22 | 95.65 | 0 | 37.2 | |
| 16/08/2024 08:00 | 45.63 | 0.33 | 96.75 | 0 | 35.8 | |
| 16/08/2024 09:00 | 32.51 | 0.54 | 95.32 | 0 | 33.4 | |
| 16/08/2024 10:00 | 34.68 | 0.48 | 95.62 | 0 | 26 | |
| 16/08/2024 11:00 | 34.65 | 0.48 | 95.81 | 0 | 26 | |
| 16/08/2024 12:00 | 25.1 | 0.53 | 93.1 | 0 | 41.7 | |
| 16/08/2024 13:00 | 31.47 | 0.14 | 93.51 | 0 | 32.8 | |
| 16/08/2024 14:00 | 34.52 | 0.07 | 94.9 | 0 | 25.2 | |
| 16/08/2024 15:00 | 34.52 | 0.01 | 94.65 | 0 | 25.1 | |
| 16/08/2024 16:00 | 34.35 | 0.01 | 94.42 | 0 | 25 | |
| 16/08/2024 17:00 | 34.28 | 0.05 | 94.57 | 0 | 24.8 | |
| 16/08/2024 18:00 | 34.28 | 0.17 | 94.63 | 0 | 24.7 | |
| 16/08/2024 19:00 | 34.05 | 0.19 | 94.45 | 0 | 24.5 | |
| 16/08/2024 20:00 | 34.18 | 0.2 | 94.5 | 0 | 24.3 | |
| 16/08/2024 21:00 | 34.37 | 0.39 | 94.96 | 0 | 24.7 | |
| 16/08/2024 22:00 | 37.38 | 0.4 | 96.52 | 0 | 26 | |
| 16/08/2024 23:00 | 32.55 | 0.31 | 96.02 | 0 | 35.1 | |
| 17/08/2024 00:00 | 28.37 | 0.25 | 93.21 | 0 | 42.7 | |
| Minimum | 25.1 | 0.01 | 93.1 | 0 | 24.3 | |
| MinDate | 16/08/2024 12:00 | 16/08/2024 15:00 | 16/08/2024 12:00 | 16/08/2024 00:00 | 16/08/2024 20:00 | |
| Maximum | 48.57 | 0.54 | 96.75 | 0 | 42.7 | |
| MaxDate | 16/08/2024 03:00 | 16/08/2024 09:00 | 16/08/2024 08:00 | 16/08/2024 00:00 | 17/08/2024 00:00 | |
| Avg | 38.58 | 0.3 | 95.18 | 0 | 32 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.7 | 0.2 | 1 | 0 | 6.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/08/2024 00:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 01:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 02:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 03:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 04:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 05:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 06:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 07:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 08:00 | 3.73 | 4.05 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 16/08/2024 09:00 | 32.42 | 0.51 | 97.43 | 0 | 31.7 | |
| 16/08/2024 10:00 | 34.61 | 0.55 | 96.35 | 0 | 24.3 | |
| 16/08/2024 11:00 | 34.58 | 0.56 | 96.46 | 0 | 24.2 | |
| 16/08/2024 12:00 | 25.06 | 0.52 | 93.85 | 0 | 40.5 | |
| 16/08/2024 13:00 | 31.43 | 0.29 | 94 | 0 | 31 | |
| 16/08/2024 14:00 | 34.46 | 0.15 | 95 | 0 | 23.3 | |
| 16/08/2024 15:00 | 34.46 | 0.23 | 94.87 | 0 | 23.2 | |
| 16/08/2024 16:00 | 34.29 | 0.09 | 94.67 | 0 | 23.1 | |
| 16/08/2024 17:00 | 34.21 | 0.13 | 94.79 | 0 | 22.9 | |
| 16/08/2024 18:00 | 34.22 | 0.17 | 94.82 | 0 | 22.7 | |
| 16/08/2024 19:00 | 33.99 | 0.16 | 94.63 | 0 | 22.5 | |
| 16/08/2024 20:00 | 34.11 | 0.17 | 94.73 | 0 | 22.4 | |
| 16/08/2024 21:00 | 34.3 | 0.29 | 95.08 | 0 | 22.7 | |
| 16/08/2024 22:00 | 37.32 | 0.34 | 96.57 | 0 | 24.3 | |
| 16/08/2024 23:00 | 32.49 | 0.24 | 96.05 | 0 | 32.6 | |
| 17/08/2024 00:00 | 28.32 | 0.22 | 93.78 | 0 | 38.9 | |
| Minimum | 0 | 0.09 | 93.78 | 0 | 22.4 | |
| MinDate | 16/08/2024 00:00 | 16/08/2024 16:00 | 17/08/2024 00:00 | 16/08/2024 09:00 | 16/08/2024 20:00 | |
| Maximum | 37.32 | 4.05 | 97.43 | 0 | 40.5 | |
| MaxDate | 16/08/2024 22:00 | 16/08/2024 08:00 | 16/08/2024 09:00 | 16/08/2024 09:00 | 16/08/2024 12:00 | |
| Avg | 21.36 | 0.42 | 95.19 | 0 | 26.9 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.2 | 0.8 | 1.1 | 0 | 6.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/08/2024 00:00 | 28.37 | 0.25 | 93.21 | 0 | 42.7 | |
| 17/08/2024 01:00 | 28.63 | 0.33 | 93.1 | 0 | 42 | |
| 17/08/2024 02:00 | 28.62 | 0.35 | 93.23 | 0 | 41.5 | |
| 17/08/2024 03:00 | 28.54 | 0.38 | 93.16 | 0 | 41.6 | |
| 17/08/2024 04:00 | 28.33 | 0.35 | 93 | 0 | 42 | |
| 17/08/2024 05:00 | 28.26 | 0.32 | 92.89 | 0 | 42.7 | |
| 17/08/2024 06:00 | 28.05 | 0.61 | 92.92 | 0 | 43.7 | |
| 17/08/2024 07:00 | 27.76 | 0.59 | 92.81 | 0 | 44.6 | |
| 17/08/2024 08:00 | 27.73 | 0.56 | 92.94 | 0 | 44.2 | |
| 17/08/2024 09:00 | 38.26 | 0.33 | 97 | 0 | 32.3 | |
| 17/08/2024 10:00 | 41.65 | 0.36 | 100.54 | 0 | 27 | |
| 17/08/2024 11:00 | 41.6 | 0.38 | 100.88 | 0 | 27.2 | |
| 17/08/2024 12:00 | 31.05 | 0.53 | 96.73 | 0 | 37.7 | |
| 17/08/2024 13:00 | 38.18 | 0.4 | 97.57 | 0 | 31.4 | |
| 17/08/2024 14:00 | 41.61 | 0.35 | 99.41 | 0 | 27.1 | |
| 17/08/2024 15:00 | 41.54 | 0.44 | 99.16 | 0 | 26.9 | |
| 17/08/2024 16:00 | 41.52 | 0.26 | 99.53 | 0 | 26.5 | |
| 17/08/2024 17:00 | 41.54 | 0.21 | 99.48 | 0 | 26.5 | |
| 17/08/2024 18:00 | 41.49 | 0.25 | 99.49 | 0 | 26.5 | |
| 17/08/2024 19:00 | 41.44 | 0.23 | 99.36 | 0 | 26.3 | |
| 17/08/2024 20:00 | 41.38 | 0.34 | 99.35 | 0 | 26.2 | |
| 17/08/2024 21:00 | 41.36 | 0.42 | 99.74 | 0 | 26.1 | |
| 17/08/2024 22:00 | 41.36 | 0.3 | 99.74 | 0 | 25.9 | |
| 17/08/2024 23:00 | 34.35 | 0.39 | 97.67 | 0 | 33.2 | |
| 18/08/2024 00:00 | 27.51 | 0.49 | 93.17 | 0 | 42.7 | |
| Minimum | 27.51 | 0.21 | 92.81 | 0 | 25.9 | |
| MinDate | 18/08/2024 00:00 | 17/08/2024 17:00 | 17/08/2024 07:00 | 17/08/2024 00:00 | 17/08/2024 22:00 | |
| Maximum | 41.65 | 0.61 | 100.88 | 0 | 44.6 | |
| MaxDate | 17/08/2024 10:00 | 17/08/2024 06:00 | 17/08/2024 11:00 | 17/08/2024 00:00 | 17/08/2024 07:00 | |
| Avg | 35.21 | 0.38 | 96.64 | 0 | 34.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.3 | 0.1 | 3.1 | 0 | 7.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/08/2024 00:00 | 28.32 | 0.22 | 93.78 | 0 | 38.9 | |
| 17/08/2024 01:00 | 28.56 | 0.21 | 93.75 | 0 | 38.6 | |
| 17/08/2024 02:00 | 28.56 | 0.22 | 93.93 | 0 | 38.3 | |
| 17/08/2024 03:00 | 28.47 | 0.3 | 93.8 | 0 | 38 | |
| 17/08/2024 04:00 | 28.27 | 0.27 | 93.68 | 0 | 38.3 | |
| 17/08/2024 05:00 | 28.19 | 0.21 | 93.58 | 0 | 38.8 | |
| 17/08/2024 06:00 | 27.99 | 0.19 | 93.64 | 0 | 39.7 | |
| 17/08/2024 07:00 | 27.7 | 0.29 | 93.48 | 0 | 40.3 | |
| 17/08/2024 08:00 | 27.67 | 0.29 | 93.57 | 0 | 39.8 | |
| 17/08/2024 09:00 | 38.2 | 0.25 | 97.51 | 0 | 31 | |
| 17/08/2024 10:00 | 41.58 | 0.3 | 100.4 | 0 | 26.4 | |
| 17/08/2024 11:00 | 41.53 | 0.38 | 100.68 | 0 | 26.7 | |
| 17/08/2024 12:00 | 30.99 | 0.42 | 96.56 | 0 | 35.6 | |
| 17/08/2024 13:00 | 38.08 | 0.36 | 97.6 | 0 | 30.5 | |
| 17/08/2024 14:00 | 41.54 | 0.26 | 99.31 | 0 | 26.4 | |
| 17/08/2024 15:00 | 41.47 | 0.42 | 99.36 | 0 | 26 | |
| 17/08/2024 16:00 | 41.44 | 0.16 | 99.62 | 0 | 25.9 | |
| 17/08/2024 17:00 | 41.46 | 0.16 | 99.57 | 0 | 25.9 | |
| 17/08/2024 18:00 | 41.41 | 0.13 | 99.58 | 0 | 25.7 | |
| 17/08/2024 19:00 | 41.37 | 0.11 | 99.45 | 0 | 25.4 | |
| 17/08/2024 20:00 | 41.31 | 0.1 | 99.45 | 0 | 24.9 | |
| 17/08/2024 21:00 | 41.29 | 0.11 | 99.73 | 0 | 24.7 | |
| 17/08/2024 22:00 | 41.29 | 0.11 | 99.7 | 0 | 24.5 | |
| 17/08/2024 23:00 | 34.29 | 0.11 | 97.62 | 0 | 31.1 | |
| 18/08/2024 00:00 | 27.45 | 0.19 | 93.67 | 0 | 38.8 | |
| Minimum | 27.45 | 0.1 | 93.48 | 0 | 24.5 | |
| MinDate | 18/08/2024 00:00 | 17/08/2024 20:00 | 17/08/2024 07:00 | 17/08/2024 00:00 | 17/08/2024 22:00 | |
| Maximum | 41.58 | 0.42 | 100.68 | 0 | 40.3 | |
| MaxDate | 17/08/2024 10:00 | 17/08/2024 12:00 | 17/08/2024 11:00 | 17/08/2024 00:00 | 17/08/2024 07:00 | |
| Avg | 35.14 | 0.23 | 96.92 | 0 | 32 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.3 | 0.1 | 2.8 | 0 | 6.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/08/2024 00:00 | 27.51 | 0.49 | 93.17 | 0 | 42.7 | |
| 18/08/2024 01:00 | 27.55 | 0.56 | 92.95 | 0 | 42.7 | |
| 18/08/2024 02:00 | 27.53 | 0.54 | 92.95 | 0 | 42.6 | |
| 18/08/2024 03:00 | 27.56 | 0.56 | 92.93 | 0 | 42.6 | |
| 18/08/2024 04:00 | 27.47 | 0.57 | 92.9 | 0 | 42.8 | |
| 18/08/2024 05:00 | 27.43 | 0.53 | 92.85 | 0 | 42.9 | |
| 18/08/2024 06:00 | 27.39 | 0.47 | 92.76 | 0 | 43.2 | |
| 18/08/2024 07:00 | 27.3 | 0.32 | 92.92 | 0 | 42.6 | |
| 18/08/2024 08:00 | 27.24 | 0.28 | 93.2 | 0 | 42.5 | |
| 18/08/2024 09:00 | 27.26 | 0.17 | 93.41 | 0 | 43.4 | |
| 18/08/2024 10:00 | 27.27 | 0.17 | 93.61 | 0 | 44.1 | |
| 18/08/2024 11:00 | 27.27 | 0.35 | 93.72 | 0 | 42.4 | |
| 18/08/2024 12:00 | 27.29 | 0.32 | 93.68 | 0 | 41.8 | |
| 18/08/2024 13:00 | 27.35 | 0.23 | 93.23 | 0 | 40.9 | |
| 18/08/2024 14:00 | 27.32 | 0.68 | 92 | 0 | 43.2 | |
| 18/08/2024 15:00 | 27.31 | 0.65 | 92.24 | 0 | 42.4 | |
| 18/08/2024 16:00 | 27.29 | 0.28 | 92.42 | 0 | 42.3 | |
| 18/08/2024 17:00 | 27.29 | 0.27 | 92.78 | 0 | 43.3 | |
| 18/08/2024 18:00 | 33.9 | 0.17 | 94.78 | 0 | 33.2 | |
| 18/08/2024 19:00 | 41.06 | 0.08 | 99.04 | 0 | 24.9 | |
| 18/08/2024 20:00 | 41.04 | 0.21 | 99.15 | 0 | 24.8 | |
| 18/08/2024 21:00 | 41.04 | 0.17 | 99.44 | 0 | 24.7 | |
| 18/08/2024 22:00 | 27.21 | 0.37 | 94.14 | 0 | 40.9 | |
| 18/08/2024 23:00 | 27.23 | 0.41 | 92.85 | 0 | 42 | |
| 19/08/2024 00:00 | 27.3 | 0.52 | 92.75 | 0 | 42 | |
| Minimum | 27.21 | 0.08 | 92 | 0 | 24.7 | |
| MinDate | 18/08/2024 22:00 | 18/08/2024 19:00 | 18/08/2024 14:00 | 18/08/2024 00:00 | 18/08/2024 21:00 | |
| Maximum | 41.06 | 0.68 | 99.44 | 0 | 44.1 | |
| MaxDate | 18/08/2024 19:00 | 18/08/2024 14:00 | 18/08/2024 21:00 | 18/08/2024 00:00 | 18/08/2024 10:00 | |
| Avq | 29.26 | 0.37 | 93.83 | 0 | 40 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.2 | 2.1 | 0 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/08/2024 00:00 | 27.45 | 0.19 | 93.67 | 0 | 38.8 | |
| 18/08/2024 01:00 | 27.49 | 0.23 | 93.53 | 0 | 38.7 | |
| 18/08/2024 02:00 | 27.46 | 0.21 | 93.54 | 0 | 38.7 | |
| 18/08/2024 03:00 | 27.5 | 0.26 | 93.51 | 0 | 38.5 | |
| 18/08/2024 04:00 | 27.42 | 0.26 | 93.53 | 0 | 38.8 | |
| 18/08/2024 05:00 | 27.37 | 0.26 | 93.45 | 0 | 38.7 | |
| 18/08/2024 06:00 | 27.33 | 0.27 | 93.36 | 0 | 39.2 | |
| 18/08/2024 07:00 | 27.25 | 0.25 | 93.5 | 0 | 40.2 | |
| 18/08/2024 08:00 | 27.18 | 0.25 | 93.65 | 0 | 38.7 | |
| 18/08/2024 09:00 | 27.2 | 0.25 | 93.84 | 0 | 39.8 | |
| 18/08/2024 10:00 | 27.21 | 0.28 | 94.06 | 0 | 40.9 | |
| 18/08/2024 11:00 | 27.21 | 0.39 | 94.25 | 0 | 39.2 | |
| 18/08/2024 12:00 | 27.23 | 0.37 | 94.09 | 0 | 38.8 | |
| 18/08/2024 13:00 | 27.29 | 0.31 | 93.78 | 0 | 37.9 | |
| 18/08/2024 14:00 | 27.25 | 0.25 | 92.51 | 0 | 39.3 | |
| 18/08/2024 15:00 | 27.24 | 0.37 | 92.88 | 0 | 38.4 | |
| 18/08/2024 16:00 | 27.23 | 0.09 | 93.14 | 0 | 38.4 | |
| 18/08/2024 17:00 | 27.24 | 0.15 | 93.5 | 0 | 39.4 | |
| 18/08/2024 18:00 | 33.8 | 0.19 | 95.46 | 0 | 31.3 | |
| 18/08/2024 19:00 | 40.99 | 0.09 | 99.21 | 0 | 24.3 | |
| 18/08/2024 20:00 | 40.97 | 0.07 | 99.22 | 0 | 24.2 | |
| 18/08/2024 21:00 | 40.96 | 0.02 | 99.28 | 0 | 24 | |
| 18/08/2024 22:00 | 27.15 | 0.02 | 94.01 | 0 | 38.8 | |
| 18/08/2024 23:00 | 27.17 | 0.03 | 92.85 | 0 | 39.3 | |
| 19/08/2024 00:00 | 27.24 | 0.02 | 92.71 | 0 | 39.2 | |
| Minimum | 27.15 | 0.02 | 92.51 | 0 | 24 | |
| MinDate | 18/08/2024 22:00 | 18/08/2024 21:00 | 18/08/2024 14:00 | 18/08/2024 00:00 | 18/08/2024 21:00 | |
| Maximum | 40.99 | 0.39 | 99.28 | 0 | 40.9 | |
| MaxDate | 18/08/2024 19:00 | 18/08/2024 11:00 | 18/08/2024 21:00 | 18/08/2024 00:00 | 18/08/2024 10:00 | |
| Avq | 29.19 | 0.2 | 94.26 | 0 | 36.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.1 | 2 | 0 | 5.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/08/2024 00:00 | 27.3 | 0.52 | 92.75 | 0 | 42 | |
| 19/08/2024 01:00 | 27.29 | 0.52 | 92.77 | 0 | 41.8 | |
| 19/08/2024 02:00 | 27.28 | 0.42 | 93 | 0 | 41.5 | |
| 19/08/2024 03:00 | 27.25 | 0.36 | 93.12 | 0 | 41.2 | |
| 19/08/2024 04:00 | 27.22 | 0.3 | 93.05 | 0 | 41.1 | |
| 19/08/2024 05:00 | 27.29 | 0.21 | 93.04 | 0 | 40.9 | |
| 19/08/2024 06:00 | 27.31 | 0.72 | 93.05 | 0 | 40.8 | |
| 19/08/2024 07:00 | 27.56 | 0.44 | 93.43 | 0 | 39.9 | |
| 19/08/2024 08:00 | 27.76 | 0.46 | 93.54 | 0 | 38.4 | |
| 19/08/2024 09:00 | 31.49 | 0.5 | 94.33 | 0 | 28.2 | |
| 19/08/2024 10:00 | 34.35 | 0.47 | 95.54 | 0 | 21.7 | |
| 19/08/2024 11:00 | 34.51 | 0.54 | 96.32 | 0 | 22 | |
| 19/08/2024 12:00 | 25.8 | 0.6 | 94.62 | 0 | 38.4 | |
| 19/08/2024 13:00 | 31.65 | 0.44 | 94.61 | 0 | 28.9 | |
| 19/08/2024 14:00 | 34.65 | 0.36 | 95.87 | 0 | 22 | |
| 19/08/2024 15:00 | 34.63 | 0.36 | 95.66 | 0 | 22 | |
| 19/08/2024 16:00 | 34.49 | 0.29 | 95.41 | 0 | 22 | |
| 19/08/2024 17:00 | 34.31 | 0.06 | 94.82 | 0 | 22 | |
| 19/08/2024 18:00 | 34.3 | 0.01 | 94.43 | 0 | 22 | |
| 19/08/2024 19:00 | 34.19 | 0.04 | 94.24 | 0 | 21.7 | |
| 19/08/2024 20:00 | 34.28 | 0.08 | 94.5 | 0 | 21.5 | |
| 19/08/2024 21:00 | 34.45 | 0.01 | 94.86 | 0 | 21.2 | |
| 19/08/2024 22:00 | 34.44 | 0.02 | 94.85 | 0 | 21.2 | |
| 19/08/2024 23:00 | 25.07 | 0.15 | 94.37 | 0 | 30.5 | |
| 20/08/2024 00:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.01 | 92.75 | 0 | 21.2 | |
| MinDate | 20/08/2024 00:00 | 19/08/2024 18:00 | 19/08/2024 00:00 | 19/08/2024 00:00 | 19/08/2024 21:00 | |
| Maximum | 34.65 | 0.72 | 96.32 | 0 | 42 | |
| MaxDate | 19/08/2024 14:00 | 19/08/2024 06:00 | 19/08/2024 11:00 | 19/08/2024 00:00 | 19/08/2024 00:00 | |
| Avg | 29.55 | 0.32 | 94.26 | 0 | 30.5 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 7.1 | 0.2 | 1.1 | 0 | 9.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/08/2024 00:00 | 27.24 | 0.02 | 92.71 | 0 | 39.2 | |
| 19/08/2024 01:00 | 27.23 | 0.03 | 92.72 | 0 | 39.1 | |
| 19/08/2024 02:00 | 27.22 | 0.05 | 92.9 | 0 | 38.8 | |
| 19/08/2024 03:00 | 27.19 | 0.06 | 93.04 | 0 | 38.5 | |
| 19/08/2024 04:00 | 27.15 | 0.09 | 92.98 | 0 | 38.5 | |
| 19/08/2024 05:00 | 27.23 | 0.06 | 93 | 0 | 38.2 | |
| 19/08/2024 06:00 | 27.25 | 0.08 | 92.92 | 0 | 37.9 | |
| 19/08/2024 07:00 | 27.5 | 0.08 | 93.33 | 0 | 37.1 | |
| 19/08/2024 08:00 | 27.66 | 0.18 | 93.43 | 0 | 37.2 | |
| 19/08/2024 09:00 | 31.44 | 0.27 | 94.31 | 0 | 28.2 | |
| 19/08/2024 10:00 | 34.28 | 0.28 | 95.51 | 0 | 21.2 | |
| 19/08/2024 11:00 | 34.44 | 0.36 | 96.3 | 0 | 21.6 | |
| 19/08/2024 12:00 | 25.7 | 0.37 | 94.53 | 0 | 40 | |
| 19/08/2024 13:00 | 31.54 | 0.3 | 94.63 | 0 | 29 | |
| 19/08/2024 14:00 | 34.59 | 0.26 | 95.86 | 0 | 21.4 | |
| 19/08/2024 15:00 | 34.55 | 0.3 | 95.69 | 0 | 21.3 | |
| 19/08/2024 16:00 | 34.43 | 0.05 | 95.55 | 0 | 21.2 | |
| 19/08/2024 17:00 | 34.24 | 0 | 95.03 | 0 | 21.2 | |
| 19/08/2024 18:00 | 34.24 | 0 | 94.72 | 0 | 21.1 | |
| 19/08/2024 19:00 | 34.11 | 0 | 94.43 | 0 | 20.8 | |
| 19/08/2024 20:00 | 34.21 | 0 | 94.55 | 0 | 20.6 | |
| 19/08/2024 21:00 | 34.38 | 0 | 94.71 | 0 | 20.4 | |
| 19/08/2024 22:00 | 34.37 | 0 | 94.65 | 0 | 20.4 | |
| 19/08/2024 23:00 | 33.31 | 0 | 94.74 | 0 | 29.1 | |
| 20/08/2024 00:00 | 48.2 | 0 | 96.47 | 0 | 37.1 | |
| Minimum | 25.7 | 0 | 92.71 | 0 | 20.4 | |
| MinDate | 19/08/2024 12:00 | 19/08/2024 17:00 | 19/08/2024 00:00 | 19/08/2024 00:00 | 19/08/2024 21:00 | |
| Maximum | 48.2 | 0.37 | 96.47 | 0 | 40 | |
| MaxDate | 20/08/2024 00:00 | 19/08/2024 12:00 | 20/08/2024 00:00 | 19/08/2024 00:00 | 19/08/2024 12:00 | |
| Avg | 31.75 | 0.11 | 94.35 | 0 | 29.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.8 | 0.1 | 1.2 | 0 | 8.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/08/2024 00:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 01:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 02:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 03:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 04:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 05:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 06:00 | 0 | 0.5 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 07:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 08:00 | 7.17 | 1 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 20/08/2024 09:00 | 32.22 | 0.69 | 95.99 | 0 | 35.4 | |
| 20/08/2024 10:00 | 34.53 | 0.79 | 95.58 | 0 | 28.4 | |
| 20/08/2024 11:00 | 34.63 | 0.77 | 95.73 | 0 | 28.3 | |
| 20/08/2024 12:00 | 25.36 | 0.84 | 93.75 | 0 | 44.2 | |
| 20/08/2024 13:00 | 31.54 | 0.69 | 94.14 | 0 | 35.7 | |
| 20/08/2024 14:00 | 34.52 | 0.59 | 94.84 | 0 | 27.8 | |
| 20/08/2024 15:00 | 34.52 | 0.27 | 94.37 | 0 | 27.4 | |
| 20/08/2024 16:00 | 34.46 | 0.4 | 94.61 | 0 | 27.1 | |
| 20/08/2024 17:00 | 34.37 | 0.56 | 94.59 | 0 | 27.2 | |
| 20/08/2024 18:00 | 34.33 | 0.68 | 94.42 | 0 | 27.1 | |
| 20/08/2024 19:00 | 34.14 | 0.58 | 94.1 | 0 | 27 | |
| 20/08/2024 20:00 | 34.16 | 0.44 | 94.12 | 0 | 26.8 | |
| 20/08/2024 21:00 | 34.33 | 0.37 | 94.49 | 0 | 26.7 | |
| 20/08/2024 22:00 | 34.3 | 0.45 | 94.54 | 0 | 26.7 | |
| 20/08/2024 23:00 | 33.34 | 0.5 | 94.2 | 0 | 34.9 | |
| 21/08/2024 00:00 | 48.46 | 0.47 | 96.01 | 0 | 38.9 | |
| Minimum | 0 | 0.06 | 93.75 | 0 | 26.7 | |
| MinDate | 20/08/2024 00:00 | 20/08/2024 00:00 | 20/08/2024 12:00 | 20/08/2024 09:00 | 20/08/2024 21:00 | |
| Maximum | 48.46 | 1 | 96.01 | 0 | 44.2 | |
| MaxDate | 21/08/2024 00:00 | 20/08/2024 08:00 | 21/08/2024 00:00 | 20/08/2024 09:00 | 20/08/2024 12:00 | |
| Avg | 22.26 | 0.5 | 94.72 | 0 | 30.6 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 0.2 | 0.7 | 0 | 5.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/08/2024 00:00 | 48.2 | 0 | 96.47 | 0 | 37.1 | |
| 20/08/2024 01:00 | 48.34 | 0 | 95.04 | 0 | 37.6 | |
| 20/08/2024 02:00 | 49.08 | 0 | 95.25 | 0 | 38.9 | |
| 20/08/2024 03:00 | 48.91 | 0 | 95.84 | 0 | 38.4 | |
| 20/08/2024 04:00 | 48.67 | 0 | 95.68 | 0 | 38.3 | |
| 20/08/2024 05:00 | 48.68 | 0 | 95.68 | 0 | 37.6 | |
| 20/08/2024 06:00 | 48.89 | 0 | 96.07 | 0 | 38 | |
| 20/08/2024 07:00 | 48.63 | 0 | 95.59 | 0 | 38 | |
| 20/08/2024 08:00 | 42.96 | 0.05 | 95.96 | 0 | 32.7 | |
| 20/08/2024 09:00 | 32.22 | 0.12 | 95.03 | 0 | 27.6 | |
| 20/08/2024 10:00 | 34.47 | 0.19 | 95.97 | 0 | 20.3 | |
| 20/08/2024 11:00 | 34.56 | 0.16 | 96.29 | 0 | 20.3 | |
| 20/08/2024 12:00 | 25.33 | 0.15 | 94.35 | 0 | 38.6 | |
| 20/08/2024 13:00 | 31.48 | 0.08 | 94.72 | 0 | 28.7 | |
| 20/08/2024 14:00 | 34.45 | 0.02 | 95.24 | 0 | 19.8 | |
| 20/08/2024 15:00 | 34.45 | 0.16 | 94.97 | 0 | 19.7 | |
| 20/08/2024 16:00 | 34.39 | 0.09 | 95.32 | 0 | 19.6 | |
| 20/08/2024 17:00 | 34.3 | 0.22 | 95.34 | 0 | 19.6 | |
| 20/08/2024 18:00 | 34.26 | 0.24 | 95.18 | 0 | 19.5 | |
| 20/08/2024 19:00 | 34.08 | 0.15 | 94.88 | 0 | 19.6 | |
| 20/08/2024 20:00 | 34.1 | 0.03 | 94.84 | 0 | 19.6 | |
| 20/08/2024 21:00 | 34.26 | 0 | 95.17 | 0 | 19.5 | |
| 20/08/2024 22:00 | 34.23 | 0.02 | 95.13 | 0 | 19.6 | |
| 20/08/2024 23:00 | 25.06 | 0.02 | 94.4 | 0 | 28.9 | |
| 21/08/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 0 | 0 | 94.35 | 0 | 19.5 | |
| MinDate | 21/08/2024 00:00 | 20/08/2024 00:00 | 20/08/2024 12:00 | 20/08/2024 00:00 | 20/08/2024 18:00 | |
| Maximum | 49.08 | 0.24 | 96.47 | 0 | 38.9 | |
| MaxDate | 20/08/2024 02:00 | 20/08/2024 18:00 | 20/08/2024 00:00 | 20/08/2024 00:00 | 20/08/2024 02:00 | |
| Avg | 36.96 | 0.07 | 95.35 | 0 | 28.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11 | 0.1 | 0.6 | 0 | 8.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/08/2024 00:00 | 48.46 | 0.47 | 96.01 | 0 | 38.9 | |
| 21/08/2024 01:00 | 48.49 | 0.5 | 95.06 | 0 | 38.9 | |
| 21/08/2024 02:00 | 48.63 | 0.51 | 95.43 | 0 | 39.4 | |
| 21/08/2024 03:00 | 48.74 | 0.5 | 95.67 | 0 | 39.1 | |
| 21/08/2024 04:00 | 48.74 | 0.49 | 95.75 | 0 | 38.4 | |
| 21/08/2024 05:00 | 48.72 | 0.41 | 95.87 | 0 | 37.6 | |
| 21/08/2024 06:00 | 48.96 | 0.37 | 96.52 | 0 | 38.4 | |
| 21/08/2024 07:00 | 48.73 | 0.11 | 95.85 | 0 | 38.5 | |
| 21/08/2024 08:00 | 44.7 | 0.28 | 96.84 | 0 | 36.9 | |
| 21/08/2024 09:00 | 32.5 | 0.51 | 94.93 | 0 | 33.8 | |
| 21/08/2024 10:00 | 34.64 | 0.53 | 95.71 | 0 | 26.6 | |
| 21/08/2024 11:00 | 34.58 | 0.52 | 95.99 | 0 | 26.5 | |
| 21/08/2024 12:00 | 25.33 | 0.57 | 94.09 | 0 | 43.6 | |
| 21/08/2024 13:00 | 31.5 | 0.47 | 94.39 | 0 | 34.3 | |
| 21/08/2024 14:00 | 34.61 | 0.4 | 95.78 | 0 | 26.1 | |
| 21/08/2024 15:00 | 34.58 | 0.4 | 95.56 | 0 | 26.2 | |
| 21/08/2024 16:00 | 34.39 | 0.41 | 95.16 | 0 | 26.3 | |
| 21/08/2024 17:00 | 34.27 | 0.37 | 94.67 | 0 | 26.2 | |
| 21/08/2024 18:00 | 34.2 | 0.34 | 94.5 | 0 | 25.9 | |
| 21/08/2024 19:00 | 34.09 | 0.33 | 94.47 | 0 | 25.6 | |
| 21/08/2024 20:00 | 34.08 | 0.3 | 94.51 | 0 | 25.4 | |
| 21/08/2024 21:00 | 34.28 | 0.24 | 95 | 0 | 25.1 | |
| 21/08/2024 22:00 | 34.33 | 0.17 | 95.08 | 0 | 25 | |
| 21/08/2024 23:00 | 25.45 | 0.18 | 94.05 | 0 | 34 | |
| 22/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.05 | 0 | 25 | |
| MinDate | 22/08/2024 00:00 | 22/08/2024 00:00 | 21/08/2024 23:00 | 21/08/2024 00:00 | 21/08/2024 22:00 | |
| Maximum | 48.96 | 0.57 | 96.84 | 0 | 43.6 | |
| MaxDate | 21/08/2024 06:00 | 21/08/2024 12:00 | 21/08/2024 08:00 | 21/08/2024 00:00 | 21/08/2024 12:00 | |
| Avg | 37.08 | 0.38 | 95.29 | 0 | 32.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11 | 0.1 | 0.7 | 0 | 6.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/08/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 01:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 02:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 03:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 04:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 05:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 06:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 07:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 08:00 | 4.97 | 6.8 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 21/08/2024 09:00 | 32.38 | 0.37 | 96.33 | 0 | 32.1 | |
| 21/08/2024 10:00 | 34.57 | 0.41 | 95.79 | 0 | 25.1 | |
| 21/08/2024 11:00 | 34.51 | 0.41 | 95.92 | 0 | 24.9 | |
| 21/08/2024 12:00 | 25.31 | 0.4 | 94.03 | 0 | 42.2 | |
| 21/08/2024 13:00 | 31.42 | 0.37 | 94.45 | 0 | 32.5 | |
| 21/08/2024 14:00 | 34.54 | 0.34 | 95.68 | 0 | 24.1 | |
| 21/08/2024 15:00 | 34.51 | 0.42 | 95.65 | 0 | 24.4 | |
| 21/08/2024 16:00 | 34.32 | 0.07 | 95.43 | 0 | 24.4 | |
| 21/08/2024 17:00 | 34.2 | 0.03 | 94.97 | 0 | 24.1 | |
| 21/08/2024 18:00 | 34.12 | 0 | 94.77 | 0 | 23.9 | |
| 21/08/2024 19:00 | 34.02 | 0 | 94.76 | 0 | 23.6 | |
| 21/08/2024 20:00 | 34.02 | 0 | 94.81 | 0 | 23.5 | |
| 21/08/2024 21:00 | 34.22 | 0 | 95.1 | 0 | 23.2 | |
| 21/08/2024 22:00 | 34.27 | 0 | 95.08 | 0 | 23.1 | |
| 21/08/2024 23:00 | 33.16 | 0 | 94.6 | 0 | 31.4 | |
| 22/08/2024 00:00 | 48.15 | 0 | 96.33 | 0 | 42.4 | |
| Minimum | 0 | 0 | 94.03 | 0 | 23.1 | |
| MinDate | 21/08/2024 00:00 | 21/08/2024 18:00 | 21/08/2024 12:00 | 21/08/2024 09:00 | 21/08/2024 22:00 | |
| Maximum | 48.15 | 6.8 | 96.33 | 0 | 42.4 | |
| MaxDate | 22/08/2024 00:00 | 21/08/2024 08:00 | 21/08/2024 09:00 | 21/08/2024 09:00 | 22/08/2024 00:00 | |
| Avg | 22.11 | 0.41 | 95.23 | 0 | 27.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 1.3 | 0.7 | 0 | 6.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 03:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 04:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 05:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 06:00 | 0 | 0.36 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 07:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 08:00 | 4.07 | 0.6 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/08/2024 09:00 | 32.46 | 0.38 | 96.16 | 0 | 36.1 | |
| 22/08/2024 10:00 | 34.62 | 0.52 | 95.42 | 0 | 28.1 | |
| 22/08/2024 11:00 | 34.62 | 0.57 | 95.32 | 0 | 27.8 | |
| 22/08/2024 12:00 | 25.07 | 0.65 | 92.99 | 0 | 45.3 | |
| 22/08/2024 13:00 | 31.42 | 0.36 | 93.81 | 0 | 35.3 | |
| 22/08/2024 14:00 | 34.51 | 0.35 | 95.28 | 0 | 27.6 | |
| 22/08/2024 15:00 | 34.48 | 0.44 | 94.45 | 0 | 26.7 | |
| 22/08/2024 16:00 | 34.49 | 0.33 | 94.84 | 0 | 26.6 | |
| 22/08/2024 17:00 | 34.29 | 0.4 | 94.75 | 0 | 26.6 | |
| 22/08/2024 18:00 | 34.25 | 0.48 | 94.75 | 0 | 26.6 | |
| 22/08/2024 19:00 | 34.13 | 0.45 | 94.56 | 0 | 26.1 | |
| 22/08/2024 20:00 | 34.16 | 0.16 | 94.33 | 0 | 26.5 | |
| 22/08/2024 21:00 | 34.29 | 0.15 | 94.75 | 0 | 26.4 | |
| 22/08/2024 22:00 | 34.37 | 0.33 | 94.83 | 0 | 26.4 | |
| 22/08/2024 23:00 | 33.46 | 0.33 | 94.29 | 0 | 34.8 | |
| 23/08/2024 00:00 | 48.56 | 0.18 | 96.07 | 0 | 39 | |
| Minimum | 0 | 0 | 92.99 | 0 | 26.1 | |
| MinDate | 22/08/2024 00:00 | 22/08/2024 00:00 | 22/08/2024 12:00 | 22/08/2024 09:00 | 22/08/2024 19:00 | |
| Maximum | 48.56 | 0.65 | 96.16 | 0 | 45.3 | |
| MaxDate | 23/08/2024 00:00 | 22/08/2024 12:00 | 22/08/2024 09:00 | 22/08/2024 09:00 | 22/08/2024 12:00 | |
| Avg | 22.13 | 0.3 | 94.79 | 0 | 30.4 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 17 | 0.2 | 0.8 | 0 | 5.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/08/2024 00:00 | 48.15 | 0 | 96.33 | 0 | 42.4 | |
| 22/08/2024 01:00 | 48.38 | 0 | 95.1 | 0 | 42.6 | |
| 22/08/2024 02:00 | 48.35 | 0 | 95.54 | 0 | 42.5 | |
| 22/08/2024 03:00 | 48.38 | 0 | 95.64 | 0 | 42.1 | |
| 22/08/2024 04:00 | 48.42 | 0 | 95.62 | 0 | 42 | |
| 22/08/2024 05:00 | 48.54 | 0 | 95.69 | 0 | 42.2 | |
| 22/08/2024 06:00 | 48.52 | 0 | 95.98 | 0 | 41.8 | |
| 22/08/2024 07:00 | 48.35 | 0 | 95.54 | 0 | 41.3 | |
| 22/08/2024 08:00 | 45.07 | 0 | 95.97 | 0 | 38.6 | |
| 22/08/2024 09:00 | 32.4 | 0.01 | 95.42 | 0 | 31.2 | |
| 22/08/2024 10:00 | 34.55 | 0.09 | 95.82 | 0 | 23 | |
| 22/08/2024 11:00 | 34.55 | 0.1 | 95.88 | 0 | 22.6 | |
| 22/08/2024 12:00 | 25.02 | 0.07 | 93.57 | 0 | 41 | |
| 22/08/2024 13:00 | 31.4 | 0 | 94.18 | 0 | 30.5 | |
| 22/08/2024 14:00 | 34.45 | 0.01 | 95.42 | 0 | 22.7 | |
| 22/08/2024 15:00 | 34.41 | 0.28 | 94.84 | 0 | 22 | |
| 22/08/2024 16:00 | 34.43 | 0 | 95.27 | 0 | 21.8 | |
| 22/08/2024 17:00 | 34.23 | 0.01 | 95.22 | 0 | 21.8 | |
| 22/08/2024 18:00 | 34.19 | 0.05 | 95.19 | 0 | 21.8 | |
| 22/08/2024 19:00 | 34.06 | 0.03 | 94.93 | 0 | 21.4 | |
| 22/08/2024 20:00 | 34.08 | 0 | 94.68 | 0 | 21.9 | |
| 22/08/2024 21:00 | 34.23 | 0 | 95.06 | 0 | 21.7 | |
| 22/08/2024 22:00 | 34.3 | 0 | 95.11 | 0 | 21.8 | |
| 22/08/2024 23:00 | 25.06 | 0 | 93.94 | 0 | 30.9 | |
| 23/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0 | 93.57 | 0 | 21.4 | |
| MinDate | 23/08/2024 00:00 | 22/08/2024 00:00 | 22/08/2024 12:00 | 22/08/2024 00:00 | 22/08/2024 19:00 | |
| Maximum | 48.54 | 0.28 | 96.33 | 0 | 42.6 | |
| MaxDate | 22/08/2024 05:00 | 22/08/2024 15:00 | 22/08/2024 00:00 | 22/08/2024 00:00 | 22/08/2024 01:00 | |
| Avg | 36.94 | 0.03 | 95.25 | 0 | 31.3 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11 | 0.1 | 0.7 | 0 | 9.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/08/2024 00:00 | 48.56 | 0.18 | 96.07 | 0 | 39 | |
| 23/08/2024 01:00 | 48.67 | 0.22 | 95.33 | 0 | 38.9 | |
| 23/08/2024 02:00 | 48.6 | 0.26 | 95.62 | 0 | 38.6 | |
| 23/08/2024 03:00 | 48.67 | 0.29 | 95.68 | 0 | 38.5 | |
| 23/08/2024 04:00 | 48.62 | 0.3 | 95.66 | 0 | 38.4 | |
| 23/08/2024 05:00 | 48.82 | 0.2 | 95.68 | 0 | 38 | |
| 23/08/2024 06:00 | 48.95 | 0.52 | 96.18 | 0 | 37.9 | |
| 23/08/2024 07:00 | 48.66 | 0.14 | 95.78 | 0 | 37.6 | |
| 23/08/2024 08:00 | 47.16 | 0.24 | 97.26 | 0 | 35.6 | |
| 23/08/2024 09:00 | 32.64 | 0.48 | 95.5 | 0 | 33.4 | |
| 23/08/2024 10:00 | 34.68 | 0.48 | 95.59 | 0 | 25.8 | |
| 23/08/2024 11:00 | 34.66 | 0.5 | 95.65 | 0 | 26.1 | |
| 23/08/2024 12:00 | 25.13 | 0.52 | 93.36 | 0 | 44.8 | |
| 23/08/2024 13:00 | 31.48 | 0.41 | 93.61 | 0 | 33.7 | |
| 23/08/2024 14:00 | 34.58 | 0.08 | 94.84 | 0 | 25.1 | |
| 23/08/2024 15:00 | 34.48 | 0.11 | 94.58 | 0 | 24.9 | |
| 23/08/2024 16:00 | 34.39 | 0.04 | 94.48 | 0 | 24.6 | |
| 23/08/2024 17:00 | 34.19 | 0.11 | 94.49 | 0 | 24.4 | |
| 23/08/2024 18:00 | 34.19 | 0.12 | 94.34 | 0 | 24.5 | |
| 23/08/2024 19:00 | 34.07 | 0.1 | 94.13 | 0 | 24.5 | |
| 23/08/2024 20:00 | 34.07 | 0.04 | 94.13 | 0 | 24.4 | |
| 23/08/2024 21:00 | 34.37 | 0.08 | 94.59 | 0 | 24.3 | |
| 23/08/2024 22:00 | 37.49 | 0.04 | 96.14 | 0 | 25.8 | |
| 23/08/2024 23:00 | 31.48 | 0.1 | 95.46 | 0 | 37 | |
| 24/08/2024 00:00 | 27.81 | 0.12 | 92.79 | 0 | 44.6 | |
| Minimum | 25.13 | 0.04 | 92.79 | 0 | 24.3 | |
| MinDate | 23/08/2024 12:00 | 23/08/2024 16:00 | 24/08/2024 00:00 | 23/08/2024 00:00 | 23/08/2024 21:00 | |
| Maximum | 48.95 | 0.52 | 97.26 | 0 | 44.8 | |
| MaxDate | 23/08/2024 06:00 | 23/08/2024 06:00 | 23/08/2024 08:00 | 23/08/2024 00:00 | 23/08/2024 12:00 | |
| Avg | 38.66 | 0.23 | 95.08 | 0 | 32.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.9 | 0.2 | 1 | 0 | 7.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 08:00 | 2.39 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/08/2024 09:00 | 31.77 | 0.14 | 95.83 | 0 | 33.7 | |
| 23/08/2024 10:00 | 34.63 | 0.19 | 95.52 | 0 | 24.2 | |
| 23/08/2024 11:00 | 34.59 | 0.2 | 95.53 | 0 | 24.4 | |
| 23/08/2024 12:00 | 25.1 | 0.12 | 93.32 | 0 | 42.7 | |
| 23/08/2024 13:00 | 31.44 | 0.03 | 93.88 | 0 | 31.4 | |
| 23/08/2024 14:00 | 34.52 | 0 | 95.09 | 0 | 23.3 | |
| 23/08/2024 15:00 | 34.4 | 0.29 | 94.9 | 0 | 23.1 | |
| 23/08/2024 16:00 | 34.32 | 0.08 | 94.82 | 0 | 22.7 | |
| 23/08/2024 17:00 | 34.12 | 0.1 | 94.85 | 0 | 22.6 | |
| 23/08/2024 18:00 | 34.13 | 0.11 | 94.65 | 0 | 22.8 | |
| 23/08/2024 19:00 | 34 | 0.09 | 94.51 | 0 | 22.8 | |
| 23/08/2024 20:00 | 34 | 0.08 | 94.48 | 0 | 22.7 | |
| 23/08/2024 21:00 | 34.3 | 0.09 | 94.81 | 0 | 22.7 | |
| 23/08/2024 22:00 | 37.42 | 0.08 | 96.33 | 0 | 24.2 | |
| 23/08/2024 23:00 | 31.42 | 0.09 | 95.61 | 0 | 35.1 | |
| 24/08/2024 00:00 | 27.76 | 0.11 | 93.15 | 0 | 41.1 | |
| Minimum | 0 | 0 | 93.15 | 0 | 22.6 | |
| MinDate | 23/08/2024 00:00 | 23/08/2024 00:00 | 24/08/2024 00:00 | 23/08/2024 09:00 | 23/08/2024 17:00 | |
| Maximum | 37.42 | 0.29 | 96.33 | 0 | 42.7 | |
| MaxDate | 23/08/2024 22:00 | 23/08/2024 15:00 | 23/08/2024 22:00 | 23/08/2024 09:00 | 23/08/2024 12:00 | |
| Avg | 21.21 | 0.07 | 94.83 | 0 | 27.5 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.2 | 0.1 | 0.9 | 0 | 7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/08/2024 00:00 | 27.81 | 0.12 | 92.79 | 0 | 44.6 | |
| 24/08/2024 01:00 | 28.75 | 0.3 | 93.14 | 0 | 43 | |
| 24/08/2024 02:00 | 28.84 | 0.38 | 93.28 | 0 | 42.2 | |
| 24/08/2024 03:00 | 28.89 | 0.37 | 93.33 | 0 | 41.4 | |
| 24/08/2024 04:00 | 28.67 | 0.44 | 93.35 | 0 | 41.6 | |
| 24/08/2024 05:00 | 28.64 | 0.5 | 93.34 | 0 | 41.9 | |
| 24/08/2024 06:00 | 28.66 | 0.68 | 93.31 | 0 | 41.8 | |
| 24/08/2024 07:00 | 28.69 | 0.28 | 93.43 | 0 | 41.2 | |
| 24/08/2024 08:00 | 28.66 | 0.29 | 93.76 | 0 | 41.2 | |
| 24/08/2024 09:00 | 39.41 | 0.15 | 98.01 | 0 | 31.2 | |
| 24/08/2024 10:00 | 42.86 | 0.1 | 101.59 | 0 | 27.7 | |
| 24/08/2024 11:00 | 42.87 | 0.19 | 101.67 | 0 | 28 | |
| 24/08/2024 12:00 | 32.33 | 0.41 | 96.83 | 0 | 37.2 | |
| 24/08/2024 13:00 | 39.38 | 0.34 | 97.21 | 0 | 32.2 | |
| 24/08/2024 14:00 | 42.88 | 0.27 | 100.7 | 0 | 27.2 | |
| 24/08/2024 15:00 | 42.86 | 0.22 | 100.56 | 0 | 27 | |
| 24/08/2024 16:00 | 42.69 | 0.22 | 100.65 | 0 | 27.3 | |
| 24/08/2024 17:00 | 42.5 | 0.25 | 100.54 | 0 | 27.5 | |
| 24/08/2024 18:00 | 42.37 | 0.22 | 100.31 | 0 | 27 | |
| 24/08/2024 19:00 | 42.37 | 0.05 | 100.1 | 0 | 26.7 | |
| 24/08/2024 20:00 | 42.6 | 0.01 | 100.31 | 0 | 26.5 | |
| 24/08/2024 21:00 | 42.79 | 0.05 | 100.7 | 0 | 26.4 | |
| 24/08/2024 22:00 | 42.8 | 0.04 | 100.77 | 0 | 26.5 | |
| 24/08/2024 23:00 | 35.6 | 0.16 | 98.2 | 0 | 34.3 | |
| 25/08/2024 00:00 | 28.5 | 0.23 | 92.88 | 0 | 43.8 | |
| Minimum | 27.81 | 0.01 | 92.79 | 0 | 26.4 | |
| MinDate | 24/08/2024 00:00 | 24/08/2024 20:00 | 24/08/2024 00:00 | 24/08/2024 00:00 | 24/08/2024 21:00 | |
| Maximum | 42.88 | 0.68 | 101.67 | 0 | 44.6 | |
| MaxDate | 24/08/2024 14:00 | 24/08/2024 06:00 | 24/08/2024 11:00 | 24/08/2024 00:00 | 24/08/2024 00:00 | |
| Avg | 36.1 | 0.25 | 97.23 | 0 | 34.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.2 | 3.5 | 0 | 7.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/08/2024 00:00 | 27.76 | 0.11 | 93.15 | 0 | 41.1 | |
| 24/08/2024 01:00 | 28.68 | 0.2 | 93.36 | 0 | 38.7 | |
| 24/08/2024 02:00 | 28.78 | 0.26 | 93.5 | 0 | 38.5 | |
| 24/08/2024 03:00 | 28.83 | 0.28 | 93.49 | 0 | 37.5 | |
| 24/08/2024 04:00 | 28.61 | 0.35 | 93.6 | 0 | 37.5 | |
| 24/08/2024 05:00 | 28.57 | 0.36 | 93.67 | 0 | 37.7 | |
| 24/08/2024 06:00 | 28.6 | 0.32 | 93.6 | 0 | 37.7 | |
| 24/08/2024 07:00 | 28.62 | 0.27 | 93.74 | 0 | 36.9 | |
| 24/08/2024 08:00 | 28.6 | 0.33 | 94.02 | 0 | 37 | |
| 24/08/2024 09:00 | 39.32 | 0.33 | 98.22 | 0 | 30.6 | |
| 24/08/2024 10:00 | 42.78 | 0.3 | 101.7 | 0 | 28.1 | |
| 24/08/2024 11:00 | 42.79 | 0.41 | 101.8 | 0 | 28.8 | |
| 24/08/2024 12:00 | 32.26 | 0.47 | 96.66 | 0 | 35.3 | |
| 24/08/2024 13:00 | 39.3 | 0.41 | 97.29 | 0 | 31.5 | |
| 24/08/2024 14:00 | 42.8 | 0.26 | 100.69 | 0 | 27.1 | |
| 24/08/2024 15:00 | 42.78 | 0.26 | 100.66 | 0 | 27.1 | |
| 24/08/2024 16:00 | 42.62 | 0.18 | 100.77 | 0 | 27.6 | |
| 24/08/2024 17:00 | 42.42 | 0.21 | 100.79 | 0 | 27.5 | |
| 24/08/2024 18:00 | 42.3 | 0.15 | 100.43 | 0 | 26.6 | |
| 24/08/2024 19:00 | 42.3 | 0.01 | 100.25 | 0 | 26.3 | |
| 24/08/2024 20:00 | 42.52 | 0 | 100.48 | 0 | 26.1 | |
| 24/08/2024 21:00 | 42.72 | 0 | 100.67 | 0 | 26.1 | |
| 24/08/2024 22:00 | 42.72 | 0.03 | 100.68 | 0 | 26.3 | |
| 24/08/2024 23:00 | 35.54 | 0.11 | 98.04 | 0 | 32.8 | |
| 25/08/2024 00:00 | 28.45 | 0.11 | 93.3 | 0 | 40 | |
| Minimum | 27.76 | 0 | 93.15 | 0 | 26.1 | |
| MinDate | 24/08/2024 00:00 | 24/08/2024 20:00 | 24/08/2024 00:00 | 24/08/2024 00:00 | 24/08/2024 20:00 | |
| Maximum | 42.8 | 0.47 | 101.8 | 0 | 41.1 | |
| MaxDate | 24/08/2024 14:00 | 24/08/2024 12:00 | 24/08/2024 11:00 | 24/08/2024 00:00 | 24/08/2024 00:00 | |
| Avg | 36.03 | 0.23 | 97.38 | 0 | 32.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.4 | 0 | 5.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/08/2024 00:00 | 28.5 | 0.23 | 92.88 | 0 | 43.8 | |
| 25/08/2024 01:00 | 28.53 | 0.19 | 92.64 | 0 | 42.8 | |
| 25/08/2024 02:00 | 28.42 | 0.28 | 92.45 | 0 | 43.7 | |
| 25/08/2024 03:00 | 28.24 | 0.3 | 92.4 | 0 | 43.7 | |
| 25/08/2024 04:00 | 27.82 | 0.24 | 92.36 | 0 | 44.3 | |
| 25/08/2024 05:00 | 27.73 | 0.22 | 92.37 | 0 | 45.1 | |
| 25/08/2024 06:00 | 27.52 | 0.7 | 92.44 | 0 | 45.2 | |
| 25/08/2024 07:00 | 27.32 | 0.43 | 92.58 | 0 | 46.8 | |
| 25/08/2024 08:00 | 27.1 | 0.49 | 92.79 | 0 | 45 | |
| 25/08/2024 09:00 | 27.21 | 0.6 | 92.84 | 0 | 45.4 | |
| 25/08/2024 10:00 | 27.22 | 0.64 | 92.84 | 0 | 45.4 | |
| 25/08/2024 11:00 | 27.18 | 0.62 | 92.96 | 0 | 45.6 | |
| 25/08/2024 12:00 | 27.23 | 0.61 | 93.12 | 0 | 45.3 | |
| 25/08/2024 13:00 | 27.3 | 0.52 | 92.78 | 0 | 44.6 | |
| 25/08/2024 14:00 | 27.27 | 0.5 | 92.71 | 0 | 44.1 | |
| 25/08/2024 15:00 | 27.3 | 0.51 | 92.35 | 0 | 45.7 | |
| 25/08/2024 16:00 | 27.24 | 0.49 | 92.15 | 0 | 43.9 | |
| 25/08/2024 17:00 | 27.24 | 0.46 | 92.04 | 0 | 44.1 | |
| 25/08/2024 18:00 | 34.19 | 0.36 | 94.06 | 0 | 36 | |
| 25/08/2024 19:00 | 41.01 | 0.34 | 98.61 | 0 | 25.7 | |
| 25/08/2024 20:00 | 40.99 | 0.36 | 98.89 | 0 | 25.7 | |
| 25/08/2024 21:00 | 40.95 | 0.38 | 99.19 | 0 | 25.1 | |
| 25/08/2024 22:00 | 27.09 | 0.3 | 93.82 | 0 | 43.7 | |
| 25/08/2024 23:00 | 27.17 | 0.23 | 92.49 | 0 | 44.9 | |
| 26/08/2024 00:00 | 27.13 | 0.32 | 92.44 | 0 | 44.3 | |
| Minimum | 27.09 | 0.19 | 92.04 | 0 | 25.1 | |
| MinDate | 25/08/2024 22:00 | 25/08/2024 01:00 | 25/08/2024 17:00 | 25/08/2024 00:00 | 25/08/2024 21:00 | |
| Maximum | 41.01 | 0.7 | 99.19 | 0 | 46.8 | |
| MaxDate | 25/08/2024 19:00 | 25/08/2024 06:00 | 25/08/2024 21:00 | 25/08/2024 00:00 | 25/08/2024 07:00 | |
| Avg | 29.4 | 0.41 | 93.45 | 0 | 42 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.2 | 2.1 | 0 | 6.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/08/2024 00:00 | 28.45 | 0.11 | 93.3 | 0 | 40 | |
| 25/08/2024 01:00 | 28.47 | 0.05 | 93.26 | 0 | 39.1 | |
| 25/08/2024 02:00 | 28.37 | 0.08 | 93.14 | 0 | 39.5 | |
| 25/08/2024 03:00 | 28.17 | 0.07 | 93.12 | 0 | 39.6 | |
| 25/08/2024 04:00 | 27.76 | 0.06 | 93.05 | 0 | 39.8 | |
| 25/08/2024 05:00 | 27.67 | 0 | 93.05 | 0 | 40.3 | |
| 25/08/2024 06:00 | 27.46 | 0 | 93.11 | 0 | 40.7 | |
| 25/08/2024 07:00 | 27.26 | 0.06 | 93.19 | 0 | 40.5 | |
| 25/08/2024 08:00 | 27.04 | 0.18 | 93.43 | 0 | 40.9 | |
| 25/08/2024 09:00 | 27.15 | 0.24 | 93.51 | 0 | 41.1 | |
| 25/08/2024 10:00 | 27.15 | 0.26 | 93.5 | 0 | 41.3 | |
| 25/08/2024 11:00 | 27.13 | 0.26 | 93.51 | 0 | 41.7 | |
| 25/08/2024 12:00 | 27.17 | 0.26 | 93.62 | 0 | 41.3 | |
| 25/08/2024 13:00 | 27.25 | 0.22 | 93.16 | 0 | 40.6 | |
| 25/08/2024 14:00 | 27.2 | 0.21 | 93.26 | 0 | 40.2 | |
| 25/08/2024 15:00 | 27.24 | 0.42 | 93.08 | 0 | 41.8 | |
| 25/08/2024 16:00 | 27.18 | 0.05 | 92.95 | 0 | 40.3 | |
| 25/08/2024 17:00 | 27.18 | 0.02 | 92.91 | 0 | 40.4 | |
| 25/08/2024 18:00 | 34.15 | 0 | 95.07 | 0 | 33.9 | |
| 25/08/2024 19:00 | 40.93 | 0 | 99.05 | 0 | 24.6 | |
| 25/08/2024 20:00 | 40.91 | 0 | 99.24 | 0 | 24.5 | |
| 25/08/2024 21:00 | 40.88 | 0 | 99.37 | 0 | 23.8 | |
| 25/08/2024 22:00 | 27.01 | 0 | 93.97 | 0 | 41 | |
| 25/08/2024 23:00 | 27.11 | 0 | 93.03 | 0 | 41.6 | |
| 26/08/2024 00:00 | 27.07 | 0 | 92.96 | 0 | 41.4 | |
| Minimum | 27.01 | 0 | 92.91 | 0 | 23.8 | |
| MinDate | 25/08/2024 22:00 | 25/08/2024 05:00 | 25/08/2024 17:00 | 25/08/2024 00:00 | 25/08/2024 21:00 | |
| Maximum | 40.93 | 0.42 | 99.37 | 0 | 41.8 | |
| MaxDate | 25/08/2024 19:00 | 25/08/2024 15:00 | 25/08/2024 21:00 | 25/08/2024 00:00 | 25/08/2024 15:00 | |
| Avg | 29.33 | 0.1 | 94.03 | 0 | 38.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.1 | 2 | 0 | 5.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/08/2024 00:00 | 27.13 | 0.32 | 92.44 | 0 | 44.3 | |
| 26/08/2024 01:00 | 27.2 | 0.37 | 92.42 | 0 | 44 | |
| 26/08/2024 02:00 | 27.16 | 0.36 | 92.33 | 0 | 43.9 | |
| 26/08/2024 03:00 | 27.13 | 0.37 | 92.28 | 0 | 44.1 | |
| 26/08/2024 04:00 | 27.14 | 0.37 | 92.19 | 0 | 43.8 | |
| 26/08/2024 05:00 | 27.19 | 0.34 | 92.26 | 0 | 43.4 | |
| 26/08/2024 06:00 | 27.21 | 0.48 | 92.24 | 0 | 43.5 | |
| 26/08/2024 07:00 | 27.53 | 0.36 | 92.48 | 0 | 43.6 | |
| 26/08/2024 08:00 | 27.75 | 0.41 | 92.83 | 0 | 41.9 | |
| 26/08/2024 09:00 | 31.3 | 0.46 | 93.86 | 0 | 32 | |
| 26/08/2024 10:00 | 34.32 | 0.46 | 94.98 | 0 | 22.1 | |
| 26/08/2024 11:00 | 34.39 | 0.46 | 95.39 | 0 | 22.2 | |
| 26/08/2024 12:00 | 25.27 | 0.53 | 93.93 | 0 | 41.1 | |
| 26/08/2024 13:00 | 31.45 | 0.43 | 93.89 | 0 | 30.8 | |
| 26/08/2024 14:00 | 34.67 | 0.31 | 95.17 | 0 | 22 | |
| 26/08/2024 15:00 | 34.63 | 0.31 | 94.92 | 0 | 21.9 | |
| 26/08/2024 16:00 | 34.62 | 0.29 | 94.82 | 0 | 21.9 | |
| 26/08/2024 17:00 | 34.32 | 0.28 | 94.51 | 0 | 21.8 | |
| 26/08/2024 18:00 | 34.3 | 0.29 | 94.2 | 0 | 22 | |
| 26/08/2024 19:00 | 34.1 | 0.28 | 93.99 | 0 | 22 | |
| 26/08/2024 20:00 | 34.23 | 0.17 | 93.78 | 0 | 21.3 | |
| 26/08/2024 21:00 | 34.51 | 0.04 | 94.08 | 0 | 21.2 | |
| 26/08/2024 22:00 | 34.55 | 0.03 | 94.21 | 0 | 21.1 | |
| 26/08/2024 23:00 | 25.05 | 0.17 | 93.57 | 0 | 31.1 | |
| 27/08/2024 00:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.03 | 92.19 | 0 | 21.1 | |
| MinDate | 27/08/2024 00:00 | 26/08/2024 22:00 | 26/08/2024 04:00 | 26/08/2024 00:00 | 26/08/2024 22:00 | |
| Maximum | 34.67 | 0.53 | 95.39 | 0 | 44.3 | |
| MaxDate | 26/08/2024 14:00 | 26/08/2024 12:00 | 26/08/2024 11:00 | 26/08/2024 00:00 | 26/08/2024 00:00 | |
| Avq | 29.49 | 0.32 | 93.62 | 0 | 32 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 7.1 | 0.1 | 1.1 | 0 | 10.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/08/2024 00:00 | 27.07 | 0 | 92.96 | 0 | 41.4 | |
| 26/08/2024 01:00 | 27.14 | 0 | 92.95 | 0 | 40.7 | |
| 26/08/2024 02:00 | 27.1 | 0 | 92.81 | 0 | 40.8 | |
| 26/08/2024 03:00 | 27.06 | 0 | 92.79 | 0 | 41 | |
| 26/08/2024 04:00 | 27.08 | 0 | 92.73 | 0 | 40.8 | |
| 26/08/2024 05:00 | 27.13 | 0 | 92.8 | 0 | 40.1 | |
| 26/08/2024 06:00 | 27.15 | 0 | 92.74 | 0 | 40.2 | |
| 26/08/2024 07:00 | 27.47 | 0 | 92.97 | 0 | 40.1 | |
| 26/08/2024 08:00 | 27.63 | 0.05 | 93.33 | 0 | 40 | |
| 26/08/2024 09:00 | 31.23 | 0.16 | 94.37 | 0 | 31.2 | |
| 26/08/2024 10:00 | 34.25 | 0.19 | 95.25 | 0 | 20.9 | |
| 26/08/2024 11:00 | 34.32 | 0.18 | 95.58 | 0 | 21.1 | |
| 26/08/2024 12:00 | 25.23 | 0.17 | 94.17 | 0 | 41.4 | |
| 26/08/2024 13:00 | 31.38 | 0.11 | 94.23 | 0 | 30.3 | |
| 26/08/2024 14:00 | 34.6 | 0.06 | 95.41 | 0 | 21 | |
| 26/08/2024 15:00 | 34.57 | 0.29 | 95.34 | 0 | 20.8 | |
| 26/08/2024 16:00 | 34.55 | 0.04 | 95.33 | 0 | 20.6 | |
| 26/08/2024 17:00 | 34.26 | 0.03 | 95.04 | 0 | 20.3 | |
| 26/08/2024 18:00 | 34.23 | 0.02 | 94.8 | 0 | 20.4 | |
| 26/08/2024 19:00 | 34.03 | 0 | 94.62 | 0 | 20.4 | |
| 26/08/2024 20:00 | 34.17 | 0 | 94.43 | 0 | 19.8 | |
| 26/08/2024 21:00 | 34.44 | 0 | 94.66 | 0 | 19.7 | |
| 26/08/2024 22:00 | 34.48 | 0 | 94.74 | 0 | 19.6 | |
| 26/08/2024 23:00 | 33.58 | 0 | 94.49 | 0 | 28.7 | |
| 27/08/2024 00:00 | 48.39 | 0 | 96.13 | 0 | 36.9 | |
| Minimum | 25.23 | 0 | 92.73 | 0 | 19.6 | |
| MinDate | 26/08/2024 12:00 | 26/08/2024 00:00 | 26/08/2024 04:00 | 26/08/2024 00:00 | 26/08/2024 22:00 | |
| Maximum | 48.39 | 0.29 | 96.13 | 0 | 41.4 | |
| MaxDate | 27/08/2024 00:00 | 26/08/2024 15:00 | 27/08/2024 00:00 | 26/08/2024 00:00 | 26/08/2024 00:00 | |
| Avq | 31.7 | 0.05 | 94.19 | 0 | 30.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.9 | 0.1 | 1.1 | 0 | 9.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/08/2024 00:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 01:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 02:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 03:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 04:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 05:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 06:00 | 0 | 0.49 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 07:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 08:00 | 5.91 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/08/2024 09:00 | 32.44 | 0.35 | 95.31 | 0 | 35 | |
| 27/08/2024 10:00 | 34.49 | 0.39 | 95.32 | 0 | 29 | |
| 27/08/2024 11:00 | 34.52 | 0.44 | 95.3 | 0 | 28.7 | |
| 27/08/2024 12:00 | 25.13 | 0.53 | 93.52 | 0 | 45.7 | |
| 27/08/2024 13:00 | 31.43 | 0.45 | 93.93 | 0 | 36.2 | |
| 27/08/2024 14:00 | 34.5 | 0.16 | 94.97 | 0 | 27.7 | |
| 27/08/2024 15:00 | 34.51 | 0.11 | 95.09 | 0 | 27.5 | |
| 27/08/2024 16:00 | 34.4 | 0.22 | 95.16 | 0 | 27.3 | |
| 27/08/2024 17:00 | 34.19 | 0.22 | 94.84 | 0 | 27.2 | |
| 27/08/2024 18:00 | 34.12 | 0.17 | 94.84 | 0 | 27 | |
| 27/08/2024 19:00 | 34.14 | 0.07 | 94.61 | 0 | 27 | |
| 27/08/2024 20:00 | 34.28 | 0.02 | 94.51 | 0 | 26.9 | |
| 27/08/2024 21:00 | 34.53 | 0.02 | 94.99 | 0 | 26.8 | |
| 27/08/2024 22:00 | 34.53 | 0.06 | 95.06 | 0 | 26.8 | |
| 27/08/2024 23:00 | 33.71 | 0.19 | 94.88 | 0 | 35.1 | |
| 28/08/2024 00:00 | 48.9 | 0.43 | 95.7 | 0 | 39.7 | |
| Minimum | 0 | 0.02 | 93.52 | 0 | 26.8 | |
| MinDate | 27/08/2024 00:00 | 27/08/2024 20:00 | 27/08/2024 12:00 | 27/08/2024 09:00 | 27/08/2024 21:00 | |
| Maximum | 48.9 | 0.53 | 95.7 | 0 | 45.7 | |
| MaxDate | 28/08/2024 00:00 | 27/08/2024 12:00 | 28/08/2024 00:00 | 27/08/2024 09:00 | 27/08/2024 12:00 | |
| Avg | 22.23 | 0.23 | 94.88 | 0 | 30.9 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 0.2 | 0.5 | 0 | 5.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/08/2024 00:00 | 48.39 | 0 | 96.13 | 0 | 36.9 | |
| 27/08/2024 01:00 | 48.54 | 0 | 95.45 | 0 | 37.3 | |
| 27/08/2024 02:00 | 48.42 | 0 | 95.72 | 0 | 37 | |
| 27/08/2024 03:00 | 48.54 | 0 | 95.85 | 0 | 36.8 | |
| 27/08/2024 04:00 | 48.68 | 0 | 95.8 | 0 | 37.4 | |
| 27/08/2024 05:00 | 48.86 | 0 | 95.94 | 0 | 37.6 | |
| 27/08/2024 06:00 | 48.84 | 0 | 95.9 | 0 | 37.6 | |
| 27/08/2024 07:00 | 48.3 | 0 | 95.89 | 0 | 36.5 | |
| 27/08/2024 08:00 | 43.5 | 0 | 96.04 | 0 | 34 | |
| 27/08/2024 09:00 | 32.37 | 0.04 | 95.16 | 0 | 26.2 | |
| 27/08/2024 10:00 | 34.43 | 0.1 | 95.45 | 0 | 19.6 | |
| 27/08/2024 11:00 | 34.45 | 0.14 | 95.35 | 0 | 19.5 | |
| 27/08/2024 12:00 | 25.08 | 0.11 | 93.42 | 0 | 39.7 | |
| 27/08/2024 13:00 | 31.38 | 0.09 | 93.81 | 0 | 28.3 | |
| 27/08/2024 14:00 | 34.43 | 0 | 94.63 | 0 | 19 | |
| 27/08/2024 15:00 | 34.45 | 0.25 | 94.74 | 0 | 19 | |
| 27/08/2024 16:00 | 34.34 | 0.21 | 94.85 | 0 | 18.8 | |
| 27/08/2024 17:00 | 34.13 | 0.23 | 94.56 | 0 | 18.8 | |
| 27/08/2024 18:00 | 34.05 | 0.18 | 94.47 | 0 | 18.7 | |
| 27/08/2024 19:00 | 34.08 | 0.1 | 94.21 | 0 | 18.8 | |
| 27/08/2024 20:00 | 34.22 | 0.07 | 94.15 | 0 | 18.8 | |
| 27/08/2024 21:00 | 34.46 | 0.07 | 94.45 | 0 | 18.8 | |
| 27/08/2024 22:00 | 34.47 | 0.07 | 94.51 | 0 | 18.7 | |
| 27/08/2024 23:00 | 24.57 | 0.13 | 94 | 0 | 28.3 | |
| 28/08/2024 00:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0 | 93.42 | 0 | 18.7 | |
| MinDate | 28/08/2024 00:00 | 27/08/2024 00:00 | 27/08/2024 12:00 | 27/08/2024 00:00 | 27/08/2024 18:00 | |
| Maximum | 48.86 | 0.25 | 96.13 | 0 | 39.7 | |
| MaxDate | 27/08/2024 05:00 | 27/08/2024 15:00 | 27/08/2024 00:00 | 27/08/2024 00:00 | 27/08/2024 12:00 | |
| Avg | 36.92 | 0.08 | 95.02 | 0 | 27.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11 | 0.1 | 0.8 | 0 | 8.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/08/2024 00:00 | 48.9 | 0.43 | 95.7 | 0 | 39.7 | |
| 28/08/2024 01:00 | 49.15 | 1.85 | 95.19 | 0 | 39.1 | |
| 28/08/2024 02:00 | 49.21 | 0.33 | 95.68 | 0 | 39 | |
| 28/08/2024 03:00 | 49.18 | 0.49 | 95.62 | 0 | 39.1 | |
| 28/08/2024 04:00 | 49.07 | 0.41 | 95.79 | 0 | 38.5 | |
| 28/08/2024 05:00 | 48.96 | 0.34 | 95.92 | 0 | 38 | |
| 28/08/2024 06:00 | 49.06 | 0.51 | 96.17 | 0 | 38.5 | |
| 28/08/2024 07:00 | 49.1 | 0.06 | 96.02 | 0 | 38.7 | |
| 28/08/2024 08:00 | 44.21 | 0.19 | 96.57 | 0 | 37 | |
| 28/08/2024 09:00 | 32.57 | 0.22 | 94.68 | 0 | 33.1 | |
| 28/08/2024 10:00 | 34.64 | 0.35 | 95.38 | 0 | 26.7 | |
| 28/08/2024 11:00 | 34.55 | 0.47 | 95.6 | 0 | 26.7 | |
| 28/08/2024 12:00 | 25.36 | 0.55 | 93.23 | 0 | 44.6 | |
| 28/08/2024 13:00 | 31.41 | 0.39 | 93.68 | 0 | 35 | |
| 28/08/2024 14:00 | 34.53 | 0.35 | 94.94 | 0 | 26.1 | |
| 28/08/2024 15:00 | 34.66 | 0.31 | 94.79 | 0 | 26.2 | |
| 28/08/2024 16:00 | 34.41 | 0.23 | 94.38 | 0 | 26.2 | |
| 28/08/2024 17:00 | 34.2 | 0.12 | 94.05 | 0 | 26.1 | |
| 28/08/2024 18:00 | 34.17 | 0.13 | 94.02 | 0 | 25.7 | |
| 28/08/2024 19:00 | 34.08 | 0.24 | 94.11 | 0 | 25.5 | |
| 28/08/2024 20:00 | 34.22 | 0.3 | 94.17 | 0 | 25.4 | |
| 28/08/2024 21:00 | 34.33 | 0.33 | 94.66 | 0 | 25.4 | |
| 28/08/2024 22:00 | 34.42 | 0.4 | 94.79 | 0 | 25.3 | |
| 28/08/2024 23:00 | 24.97 | 0.48 | 93.83 | 0 | 34.8 | |
| 29/08/2024 00:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.06 | 93.23 | 0 | 25.3 | |
| MinDate | 29/08/2024 00:00 | 28/08/2024 07:00 | 28/08/2024 12:00 | 28/08/2024 00:00 | 28/08/2024 22:00 | |
| Maximum | 49.21 | 1.85 | 96.57 | 0 | 44.6 | |
| MaxDate | 28/08/2024 02:00 | 28/08/2024 01:00 | 28/08/2024 08:00 | 28/08/2024 00:00 | 28/08/2024 12:00 | |
| Avg | 37.17 | 0.39 | 94.96 | 0 | 32.5 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 11.2 | 0.3 | 0.9 | 0 | 6.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/08/2024 00:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 01:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 02:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 03:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 04:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 06:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 07:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 08:00 | 6.08 | 0.24 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/08/2024 09:00 | 32.43 | 0.27 | 95.9 | 0 | 30.9 | |
| 28/08/2024 10:00 | 34.57 | 0.41 | 95.59 | 0 | 24.6 | |
| 28/08/2024 11:00 | 34.49 | 0.51 | 95.69 | 0 | 24.6 | |
| 28/08/2024 12:00 | 25.29 | 0.49 | 93.4 | 0 | 42.7 | |
| 28/08/2024 13:00 | 31.31 | 0.43 | 93.97 | 0 | 32.4 | |
| 28/08/2024 14:00 | 34.47 | 0.4 | 95.14 | 0 | 23.7 | |
| 28/08/2024 15:00 | 34.59 | 0.44 | 95.18 | 0 | 23.6 | |
| 28/08/2024 16:00 | 34.34 | 0.03 | 94.86 | 0 | 23.5 | |
| 28/08/2024 17:00 | 34.14 | 0 | 94.59 | 0 | 23.2 | |
| 28/08/2024 18:00 | 34.11 | 0 | 94.51 | 0 | 23 | |
| 28/08/2024 19:00 | 34.02 | 0 | 94.57 | 0 | 22.8 | |
| 28/08/2024 20:00 | 34.16 | 0 | 94.6 | 0 | 22.8 | |
| 28/08/2024 21:00 | 34.27 | 0 | 94.94 | 0 | 22.9 | |
| 28/08/2024 22:00 | 34.36 | 0 | 95.01 | 0 | 22.9 | |
| 28/08/2024 23:00 | 33.55 | 0 | 94.66 | 0 | 31.7 | |
| 29/08/2024 00:00 | 48.41 | 0 | 96.34 | 0 | 42.3 | |
| Minimum | 0 | 0 | 93.4 | 0 | 22.8 | |
| MinDate | 28/08/2024 00:00 | 28/08/2024 17:00 | 28/08/2024 12:00 | 28/08/2024 09:00 | 28/08/2024 19:00 | |
| Maximum | 48.41 | 0.51 | 96.34 | 0 | 42.7 | |
| MaxDate | 29/08/2024 00:00 | 28/08/2024 11:00 | 29/08/2024 00:00 | 28/08/2024 09:00 | 28/08/2024 12:00 | |
| Avg | 22.18 | 0.16 | 94.93 | 0 | 27.4 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.9 | 0.2 | 0.7 | 0 | 6.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/08/2024 00:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 01:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 02:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 03:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 04:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 05:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 06:00 | 0 | 0.63 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 07:00 | 0 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 08:00 | 4.38 | 0.76 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/08/2024 09:00 | 32.39 | 0.46 | 95.32 | 0 | 35.9 | |
| 29/08/2024 10:00 | 34.62 | 0.49 | 95.33 | 0 | 28 | |
| 29/08/2024 11:00 | 34.56 | 0.55 | 95.31 | 0 | 28.5 | |
| 29/08/2024 12:00 | 25.35 | 0.69 | 93.15 | 0 | 46.9 | |
| 29/08/2024 13:00 | 31.71 | 0.57 | 93.97 | 0 | 37.9 | |
| 29/08/2024 14:00 | 34.71 | 0.55 | 95.26 | 0 | 28.2 | |
| 29/08/2024 15:00 | 34.67 | 0.56 | 94.41 | 0 | 27.8 | |
| 29/08/2024 16:00 | 34.5 | 0.49 | 94.01 | 0 | 27.6 | |
| 29/08/2024 17:00 | 34.11 | 0.59 | 93.91 | 0 | 26.9 | |
| 29/08/2024 18:00 | 34.28 | 0.65 | 94.27 | 0 | 26.8 | |
| 29/08/2024 19:00 | 34.16 | 0.62 | 94.44 | 0 | 26.6 | |
| 29/08/2024 20:00 | 34.29 | 0.42 | 94.45 | 0 | 26.5 | |
| 29/08/2024 21:00 | 34.44 | 0.38 | 94.91 | 0 | 26.4 | |
| 29/08/2024 22:00 | 34.52 | 0.39 | 95.16 | 0 | 26.5 | |
| 29/08/2024 23:00 | 33.83 | 0.43 | 94.68 | 0 | 35.4 | |
| 30/08/2024 00:00 | 48.88 | 0.36 | 96.03 | 0 | 39.2 | |
| Minimum | 0 | 0 | 93.88 | 1.3 | 26.7 | |
| MinDate | 29/05/2024 01:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 15:00 | 29/05/2024 23:00 | |
| Maximum | 40 | 0.19 | 95.98 | 1.4 | 44.9 | |
| MaxDate | 30/05/2024 00:00 | 29/05/2024 06:00 | 29/05/2024 14:00 | 29/05/2024 09:00 | 29/05/2024 12:00 | |
| Avg | 22.28 | 0.01 | 95.18 | 1.3 | 30.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.1 | 0 | 0.6 | 0.1 | 5.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/08/2024 00:00 | 48.41 | 0 | 95.34 | 0 | 42.3 | |
| 29/08/2024 01:00 | 48.48 | 0 | 95.33 | 0 | 42.6 | |
| 29/08/2024 02:00 | 48.64 | 0 | 95.48 | 0 | 42.4 | |
| 29/08/2024 03:00 | 48.76 | 0 | 95.44 | 0 | 42.6 | |
| 29/08/2024 04:00 | 48.78 | 0 | 95.5 | 0 | 42.5 | |
| 29/08/2024 05:00 | 48.73 | 0 | 95.47 | 0 | 42.4 | |
| 29/08/2024 06:00 | 48.72 | 0 | 95.87 | 0 | 42.8 | |
| 29/08/2024 07:00 | 48.41 | 0 | 95.28 | 0 | 42.3 | |
| 29/08/2024 08:00 | 45.26 | 0 | 95.87 | 0 | 38.8 | |
| 29/08/2024 09:00 | 32.44 | 0 | 94.84 | 0 | 30.7 | |
| 29/08/2024 10:00 | 34.55 | 0 | 95.1 | 0 | 22.7 | |
| 29/08/2024 11:00 | 34.5 | 0.05 | 95.22 | 0 | 23.2 | |
| 29/08/2024 12:00 | 25.3 | 0.1 | 93.1 | 0 | 42.8 | |
| 29/08/2024 13:00 | 31.58 | 0.07 | 93.82 | 0 | 33.1 | |
| 29/08/2024 14:00 | 34.64 | 0.08 | 94.97 | 0 | 22.7 | |
| 29/08/2024 15:00 | 34.61 | 0.34 | 94.46 | 0 | 22.3 | |
| 29/08/2024 16:00 | 34.44 | 0 | 94.09 | 0 | 22.1 | |
| 29/08/2024 17:00 | 34.05 | 0 | 93.97 | 0 | 21.6 | |
| 29/08/2024 18:00 | 34.21 | 0 | 94.25 | 0 | 21.5 | |
| 29/08/2024 19:00 | 34.09 | 0 | 94.39 | 0 | 21.4 | |
| 29/08/2024 20:00 | 34.22 | 0 | 94.41 | 0 | 21.4 | |
| 29/08/2024 21:00 | 34.38 | 0 | 94.7 | 0 | 21.3 | |
| 29/08/2024 22:00 | 34.46 | 0 | 94.72 | 0 | 21.4 | |
| 29/08/2024 23:00 | 24.53 | 0 | 93.55 | 0 | 31.1 | |
| 30/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.84 | --- | 93.91 | 0 | 18.9 | |
| MinDate | 30/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 00:00 | 29/05/2024 23:00 | |
| Maximum | 47.72 | --- | 95.92 | 0 | 39.8 | |
| MaxDate | 29/05/2024 06:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 04:00 | |
| Avg | 36.95 | --- | 95.16 | 0 | 28.6 | |
| Num | 25 | 0 | 24 | 24 | 24 | |
| Data[%] | 100 | --- | 96 | 96 | 96 | |
| STD | 9 | --- | 0.5 | 0 | 9.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/08/2024 00:00 | 48.88 | 0.36 | 96.03 | 0 | 39.2 | |
| 30/08/2024 01:00 | 48.83 | 0.4 | 95.74 | 0 | 39.3 | |
| 30/08/2024 02:00 | 48.84 | 0.32 | 95.99 | 0 | 38.9 | |
| 30/08/2024 03:00 | 48.87 | 0.27 | 96.03 | 0 | 38.9 | |
| 30/08/2024 04:00 | 48.85 | 0.29 | 96.02 | 0 | 38.9 | |
| 30/08/2024 05:00 | 48.77 | 0.39 | 95.93 | 0 | 39 | |
| 30/08/2024 06:00 | 48.84 | 0.33 | 96.3 | 0 | 38.9 | |
| 30/08/2024 07:00 | 48.69 | 0.05 | 96.01 | 0 | 38.5 | |
| 30/08/2024 08:00 | 45.13 | 0.31 | 96.88 | 0 | 36.2 | |
| 30/08/2024 09:00 | 32.48 | 0.42 | 94.38 | 0 | 33.6 | |
| 30/08/2024 10:00 | 34.63 | 0.39 | 94.93 | 0 | 26.6 | |
| 30/08/2024 11:00 | 34.52 | 0.4 | 94.94 | 0 | 26.8 | |
| 30/08/2024 12:00 | 25.02 | 0.44 | 93.45 | 0 | 47.1 | |
| 30/08/2024 13:00 | 31.44 | 0.3 | 93.56 | 0 | 35.4 | |
| 30/08/2024 14:00 | 34.56 | 0.24 | 94.62 | 0 | 26.4 | |
| 30/08/2024 15:00 | 34.51 | 0.24 | 94.39 | 0 | 26.1 | |
| 30/08/2024 16:00 | 34.34 | 0.23 | 94.26 | 0 | 26 | |
| 30/08/2024 17:00 | 34.17 | 0.2 | 94.19 | 0 | 25.6 | |
| 30/08/2024 18:00 | 34.13 | 0.23 | 94.14 | 0 | 25.6 | |
| 30/08/2024 19:00 | 34.01 | 0.26 | 93.94 | 0 | 25.5 | |
| 30/08/2024 20:00 | 34.16 | 0.25 | 94.05 | 0 | 25.3 | |
| 30/08/2024 21:00 | 34.34 | 0.22 | 94.51 | 0 | 25.3 | |
| 30/08/2024 22:00 | 37.49 | 0.23 | 96.1 | 0 | 26.9 | |
| 30/08/2024 23:00 | 32.08 | 0.28 | 95.22 | 0 | 38.2 | |
| 31/08/2024 00:00 | 28.24 | 0.21 | 92.55 | 0 | 46.9 | |
| Minimum | 8.32 | 0 | 94.2 | 1.3 | 25.5 | |
| MinDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 00:00 | 30/05/2024 22:00 | |
| Maximum | 48.02 | 0.38 | 96.03 | 1.5 | 43.9 | |
| MaxDate | 30/05/2024 06:00 | 30/05/2024 06:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 37.19 | 0.02 | 95.04 | 1.4 | 32.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.5 | 0.1 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/08/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 08:00 | 4.71 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/08/2024 09:00 | 32.41 | 0.07 | 95.93 | 0 | 32 | |
| 30/08/2024 10:00 | 34.57 | 0.14 | 95.4 | 0 | 25 | |
| 30/08/2024 11:00 | 34.46 | 0.19 | 95.32 | 0 | 25.1 | |
| 30/08/2024 12:00 | 24.96 | 0.16 | 93.79 | 0 | 45.3 | |
| 30/08/2024 13:00 | 31.39 | 0.09 | 94.07 | 0 | 33.4 | |
| 30/08/2024 14:00 | 34.5 | 0.06 | 95.07 | 0 | 24.3 | |
| 30/08/2024 15:00 | 34.44 | 0.29 | 94.89 | 0 | 24.1 | |
| 30/08/2024 16:00 | 34.27 | 0.04 | 94.86 | 0 | 23.8 | |
| 30/08/2024 17:00 | 34.11 | 0.04 | 94.79 | 0 | 23.5 | |
| 30/08/2024 18:00 | 34.07 | 0.04 | 94.73 | 0 | 23.5 | |
| 30/08/2024 19:00 | 33.94 | 0.04 | 94.6 | 0 | 23.5 | |
| 30/08/2024 20:00 | 34.09 | 0.03 | 94.71 | 0 | 23.4 | |
| 30/08/2024 21:00 | 34.28 | 0.03 | 94.96 | 0 | 23.3 | |
| 30/08/2024 22:00 | 37.42 | 0.02 | 96.56 | 0 | 25 | |
| 30/08/2024 23:00 | 32.03 | 0.01 | 95.68 | 0 | 35.7 | |
| 31/08/2024 00:00 | 28.18 | 0 | 92.93 | 0 | 42.9 | |
| Minimum | 0 | --- | 94.25 | 0 | 20.5 | |
| MinDate | 30/05/2024 01:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 09:00 | 30/05/2024 19:00 | |
| Maximum | 39.65 | --- | 96.1 | 0 | 39.7 | |
| MaxDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 22.18 | --- | 95.12 | 0 | 24.5 | |
| Num | 25 | 0 | 16 | 16 | 16 | |
| Data[%] | 100 | --- | 64 | 64 | 64 | |
| STD | 16.1 | --- | 0.5 | 0 | 6.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/08/2024 00:00 | 28.24 | 0.21 | 92.55 | 0 | 46.9 | |
| 31/08/2024 01:00 | 28.57 | 0.19 | 92.61 | 0 | 45.6 | |
| 31/08/2024 02:00 | 28.49 | 0.19 | 92.65 | 0 | 45.1 | |
| 31/08/2024 03:00 | 28.37 | 0.28 | 92.51 | 0 | 45.6 | |
| 31/08/2024 04:00 | 28.1 | 0.35 | 92.39 | 0 | 46.4 | |
| 31/08/2024 05:00 | 27.97 | 0.23 | 92.38 | 0 | 47.5 | |
| 31/08/2024 06:00 | 27.8 | 0.7 | 92.24 | 0 | 48 | |
| 31/08/2024 07:00 | 27.54 | 0.31 | 92.36 | 0 | 48.7 | |
| 31/08/2024 08:00 | 27.43 | 0.34 | 92.44 | 0 | 48.5 | |
| 31/08/2024 09:00 | 38.02 | 0.28 | 96.7 | 0 | 34.1 | |
| 31/08/2024 10:00 | 41.43 | 0.4 | 99.89 | 0 | 29.1 | |
| 31/08/2024 11:00 | 41.45 | 0.39 | 100.28 | 0 | 28.9 | |
| 31/08/2024 12:00 | 30.94 | 0.5 | 96.87 | 0 | 41.1 | |
| 31/08/2024 13:00 | 38.05 | 0.39 | 97.39 | 0 | 34.2 | |
| 31/08/2024 14:00 | 41.43 | 0.38 | 100.05 | 0 | 28.9 | |
| 31/08/2024 15:00 | 41.47 | 0.34 | 99.66 | 0 | 28.7 | |
| 31/08/2024 16:00 | 41.47 | 0.28 | 99.51 | 0 | 28.5 | |
| 31/08/2024 17:00 | 41.49 | 0.23 | 99.33 | 0 | 28.2 | |
| 31/08/2024 18:00 | 41.43 | 0.22 | 99.16 | 0 | 28 | |
| 31/08/2024 19:00 | 41.43 | 0.21 | 99.22 | 0 | 27.8 | |
| 31/08/2024 20:00 | 41.44 | 0.2 | 99.17 | 0 | 27.7 | |
| 31/08/2024 21:00 | 41.4 | 0.23 | 99.47 | 0 | 27.6 | |
| 31/08/2024 22:00 | 41.36 | 0.31 | 99.44 | 0 | 27.3 | |
| 31/08/2024 23:00 | 34.34 | 0.44 | 97.27 | 0 | 34.8 | |
| 01/09/2024 00:00 | 27.46 | 0.46 | 92.85 | 0 | 44.8 | |
| Minimum | 27.43 | 0.19 | 92.24 | 0 | 27.3 | |
| MinDate | 31/08/2024 08:00 | 31/08/2024 01:00 | 31/08/2024 06:00 | 31/08/2024 00:00 | 31/08/2024 22:00 | |
| Maximum | 41.49 | 0.7 | 100.28 | 0 | 48.7 | |
| MaxDate | 31/08/2024 17:00 | 31/08/2024 06:00 | 31/08/2024 11:00 | 31/08/2024 00:00 | 31/08/2024 07:00 | |
| Avg | 35.08 | 0.32 | 96.34 | 0 | 36.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.4 | 0.1 | 3.3 | 0 | 8.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/08/2024 00:00 | 28.18 | 0 | 92.93 | 0 | 42.9 | |
| 31/08/2024 01:00 | 28.5 | 0 | 92.81 | 0 | 41.8 | |
| 31/08/2024 02:00 | 28.43 | 0 | 92.87 | 0 | 41.3 | |
| 31/08/2024 03:00 | 28.32 | 0 | 92.7 | 0 | 41.7 | |
| 31/08/2024 04:00 | 28.03 | 0 | 92.59 | 0 | 42.2 | |
| 31/08/2024 05:00 | 27.91 | 0 | 92.55 | 0 | 43.3 | |
| 31/08/2024 06:00 | 27.74 | 0 | 92.43 | 0 | 43.5 | |
| 31/08/2024 07:00 | 27.48 | 0 | 92.53 | 0 | 44.1 | |
| 31/08/2024 08:00 | 27.37 | 0.01 | 92.59 | 0 | 44 | |
| 31/08/2024 09:00 | 37.96 | 0.04 | 96.86 | 0 | 32.5 | |
| 31/08/2024 10:00 | 41.36 | 0.14 | 99.79 | 0 | 28.2 | |
| 31/08/2024 11:00 | 41.37 | 0.19 | 100.18 | 0 | 28.2 | |
| 31/08/2024 12:00 | 30.87 | 0.2 | 96.56 | 0 | 38.7 | |
| 31/08/2024 13:00 | 38 | 0.18 | 97.21 | 0 | 33.2 | |
| 31/08/2024 14:00 | 41.36 | 0.13 | 99.77 | 0 | 28.5 | |
| 31/08/2024 15:00 | 41.39 | 0.23 | 99.65 | 0 | 28.2 | |
| 31/08/2024 16:00 | 41.4 | 0.02 | 99.59 | 0 | 28 | |
| 31/08/2024 17:00 | 41.41 | 0 | 99.45 | 0 | 27.6 | |
| 31/08/2024 18:00 | 41.36 | 0 | 99.31 | 0 | 27 | |
| 31/08/2024 19:00 | 41.35 | 0 | 99.35 | 0 | 26.6 | |
| 31/08/2024 20:00 | 41.36 | 0 | 99.26 | 0 | 26.5 | |
| 31/08/2024 21:00 | 41.33 | 0 | 99.41 | 0 | 26.1 | |
| 31/08/2024 22:00 | 41.29 | 0 | 99.4 | 0 | 25.6 | |
| 31/08/2024 23:00 | 34.28 | 0 | 97.22 | 0 | 32.7 | |
| 01/09/2024 00:00 | 27.38 | 0 | 93.07 | 0 | 40.7 | |
| Minimum | 27.37 | 0 | 92.43 | 0 | 25.6 | |
| MinDate | 31/08/2024 08:00 | 31/08/2024 00:00 | 31/08/2024 06:00 | 31/08/2024 00:00 | 31/08/2024 22:00 | |
| Maximum | 41.41 | 0.23 | 100.18 | 0 | 44.1 | |
| MaxDate | 31/08/2024 17:00 | 31/08/2024 15:00 | 31/08/2024 11:00 | 31/08/2024 00:00 | 31/08/2024 07:00 | |
| Avg | 35.02 | 0.05 | 96.4 | 0 | 34.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.4 | 0.1 | 3.2 | 0 | 7.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/09/2024 00:00 | 27.46 | 0.46 | 92.85 | 0 | 44.8 | |
| 01/09/2024 01:00 | 27.47 | 0.39 | 92.65 | 0 | 44.3 | |
| 01/09/2024 02:00 | 27.49 | 0.4 | 92.51 | 0 | 44.5 | |
| 01/09/2024 03:00 | 27.45 | 0.3 | 92.34 | 0 | 45.9 | |
| 01/09/2024 04:00 | 27.35 | 0.28 | 92.21 | 0 | 46.7 | |
| 01/09/2024 05:00 | 27.36 | 0.31 | 92.22 | 0 | 46.6 | |
| 01/09/2024 06:00 | 27.31 | 0.57 | 92.22 | 0 | 46.6 | |
| 01/09/2024 07:00 | 27.21 | 0.34 | 92.71 | 0 | 46.2 | |
| 01/09/2024 08:00 | 27.2 | 0.42 | 92.62 | 0 | 46.5 | |
| 01/09/2024 09:00 | 27.27 | 0.41 | 92.54 | 0 | 46.3 | |
| 01/09/2024 10:00 | 27.28 | 0.46 | 92.57 | 0 | 45.6 | |
| 01/09/2024 11:00 | 27.28 | 0.44 | 92.87 | 0 | 45.3 | |
| 01/09/2024 12:00 | 27.31 | 0.39 | 92.82 | 0 | 44.8 | |
| 01/09/2024 13:00 | 27.26 | 0.38 | 92.86 | 0 | 44.9 | |
| 01/09/2024 14:00 | 27.3 | 0.33 | 92.73 | 0 | 44 | |
| 01/09/2024 15:00 | 27.36 | 0.35 | 92.6 | 0 | 42.8 | |
| 01/09/2024 16:00 | 27.36 | 0.35 | 92.6 | 0 | 42.6 | |
| 01/09/2024 17:00 | 27.33 | 0.36 | 92.55 | 0 | 42.5 | |
| 01/09/2024 18:00 | 34.34 | 0.3 | 94.6 | 0 | 35.1 | |
| 01/09/2024 19:00 | 41.12 | 0.28 | 99.2 | 0 | 25.6 | |
| 01/09/2024 20:00 | 41.14 | 0.26 | 99.26 | 0 | 25.4 | |
| 01/09/2024 21:00 | 41.15 | 0.25 | 99.51 | 0 | 25.4 | |
| 01/09/2024 22:00 | 34.08 | 0.2 | 97.07 | 0 | 34.7 | |
| 01/09/2024 23:00 | 27.28 | 0.69 | 91.71 | 0 | 45 | |
| 02/09/2024 00:00 | 27.29 | 1.01 | 91.56 | 0 | 43.8 | |
| Minimum | 27.2 | 0.2 | 91.56 | 0 | 25.4 | |
| MinDate | 01/09/2024 08:00 | 01/09/2024 22:00 | 02/09/2024 00:00 | 01/09/2024 00:00 | 01/09/2024 20:00 | |
| Maximum | 41.15 | 1.01 | 99.51 | 0 | 46.7 | |
| MaxDate | 01/09/2024 21:00 | 02/09/2024 00:00 | 01/09/2024 21:00 | 01/09/2024 00:00 | 01/09/2024 04:00 | |
| Avg | 29.54 | 0.4 | 93.58 | 0 | 41.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.8 | 0.2 | 2.4 | 0 | 6.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/09/2024 00:00 | 27.38 | 0 | 93.07 | 0 | 40.7 | |
| 01/09/2024 01:00 | 27.41 | 0 | 92.82 | 0 | 40.2 | |
| 01/09/2024 02:00 | 27.43 | 0 | 92.66 | 0 | 40.5 | |
| 01/09/2024 03:00 | 27.39 | 0 | 92.53 | 0 | 41.8 | |
| 01/09/2024 04:00 | 27.29 | 0 | 92.41 | 0 | 42.3 | |
| 01/09/2024 05:00 | 27.3 | 0 | 92.41 | 0 | 42 | |
| 01/09/2024 06:00 | 27.25 | 0 | 92.4 | 0 | 42.3 | |
| 01/09/2024 07:00 | 27.15 | 0 | 92.81 | 0 | 42 | |
| 01/09/2024 08:00 | 27.13 | 0.04 | 92.78 | 0 | 42.2 | |
| 01/09/2024 09:00 | 27.21 | 0.05 | 92.7 | 0 | 42.3 | |
| 01/09/2024 10:00 | 27.21 | 0.07 | 92.76 | 0 | 41.8 | |
| 01/09/2024 11:00 | 27.23 | 0.08 | 92.98 | 0 | 41.4 | |
| 01/09/2024 12:00 | 27.25 | 0.05 | 92.92 | 0 | 41 | |
| 01/09/2024 13:00 | 27.2 | 0.04 | 92.96 | 0 | 41.2 | |
| 01/09/2024 14:00 | 27.25 | 0.04 | 92.8 | 0 | 40.6 | |
| 01/09/2024 15:00 | 27.29 | 0.42 | 92.8 | 0 | 39.3 | |
| 01/09/2024 16:00 | 27.29 | 0.04 | 92.89 | 0 | 39.2 | |
| 01/09/2024 17:00 | 27.27 | 0.04 | 92.88 | 0 | 39.2 | |
| 01/09/2024 18:00 | 34.26 | 0.04 | 95.01 | 0 | 33.1 | |
| 01/09/2024 19:00 | 41.05 | 0.03 | 99.31 | 0 | 24.3 | |
| 01/09/2024 20:00 | 41.06 | 0.01 | 99.45 | 0 | 24.1 | |
| 01/09/2024 21:00 | 41.07 | 0.01 | 99.51 | 0 | 24 | |
| 01/09/2024 22:00 | 34.07 | 0 | 96.9 | 0 | 32.9 | |
| 01/09/2024 23:00 | 27.22 | 0 | 75.22 | 0 | 42.1 | |
| 02/09/2024 00:00 | 27.22 | 0 | 92.2 | 0 | 40.5 | |
| Minimum | 27.13 | 0 | 75.22 | 0 | 24 | |
| MinDate | 01/09/2024 08:00 | 01/09/2024 00:00 | 01/09/2024 23:00 | 01/09/2024 00:00 | 01/09/2024 21:00 | |
| Maximum | 41.07 | 0.42 | 99.51 | 0 | 42.3 | |
| MaxDate | 01/09/2024 21:00 | 01/09/2024 15:00 | 01/09/2024 21:00 | 01/09/2024 00:00 | 01/09/2024 04:00 | |
| Avg | 29.48 | 0.04 | 93.09 | 0 | 38.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.8 | 0.1 | 4.4 | 0 | 5.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/09/2024 00:00 | 27.29 | 1.01 | 91.56 | 0 | 43.8 | |
| 02/09/2024 01:00 | 27.33 | 0.31 | 91.65 | 0 | 44.2 | |
| 02/09/2024 02:00 | 27.34 | 0.27 | 91.86 | 0 | 44 | |
| 02/09/2024 03:00 | 27.34 | 0.28 | 91.92 | 0 | 43.8 | |
| 02/09/2024 04:00 | 27.34 | 0.05 | 91.85 | 0 | 43.9 | |
| 02/09/2024 05:00 | 27.37 | 0.09 | 92.08 | 0 | 43.7 | |
| 02/09/2024 06:00 | 27.37 | 1.08 | 92 | 0 | 43.3 | |
| 02/09/2024 07:00 | 27.65 | 0.54 | 92.23 | 0 | 43 | |
| 02/09/2024 08:00 | 30.4 | 0.52 | 93.27 | 0 | 37.1 | |
| 02/09/2024 09:00 | 34.2 | 0.65 | 94.82 | 0 | 21.7 | |
| 02/09/2024 10:00 | 34.28 | 0.76 | 94.91 | 0 | 21.8 | |
| 02/09/2024 11:00 | 34.15 | 0.73 | 94.91 | 0 | 21.6 | |
| 02/09/2024 12:00 | 21.78 | 0.85 | 92.09 | 0 | 51.7 | |
| 02/09/2024 13:00 | 34.53 | 0.63 | 94.54 | 0 | 23.4 | |
| 02/09/2024 14:00 | 34.48 | 0.7 | 94.87 | 0 | 21.4 | |
| 02/09/2024 15:00 | 34.52 | 0.79 | 94.47 | 0 | 21.2 | |
| 02/09/2024 16:00 | 34.42 | 1.06 | 93.95 | 0 | 21.1 | |
| 02/09/2024 17:00 | 34.29 | 0.98 | 93.97 | 0 | 21.1 | |
| 02/09/2024 18:00 | 34.35 | 0.85 | 94.18 | 0 | 21 | |
| 02/09/2024 19:00 | 34.08 | 0.52 | 94.22 | 0 | 20.9 | |
| 02/09/2024 20:00 | 34.24 | 0.35 | 94.08 | 0 | 20.9 | |
| 02/09/2024 21:00 | 34.32 | 0.39 | 94.51 | 0 | 21 | |
| 02/09/2024 22:00 | 34.26 | 0.36 | 94.56 | 0 | 21.2 | |
| 02/09/2024 23:00 | 31.3 | 0.44 | 94.09 | 0 | 28 | |
| 03/09/2024 00:00 | 2.22 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 2.22 | 0.05 | 91.56 | 0 | 20.9 | |
| MinDate | 03/09/2024 00:00 | 02/09/2024 04:00 | 02/09/2024 00:00 | 02/09/2024 00:00 | 02/09/2024 19:00 | |
| Maximum | 34.53 | 1.08 | 94.91 | 0 | 51.7 | |
| MaxDate | 02/09/2024 13:00 | 02/09/2024 06:00 | 02/09/2024 10:00 | 02/09/2024 00:00 | 02/09/2024 12:00 | |
| Avg | 30.03 | 0.58 | 93.44 | 0 | 31 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.9 | 0.3 | 1.3 | 0 | 11.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/09/2024 00:00 | 27.22 | 0 | 92.2 | 0 | 40.5 | |
| 02/09/2024 01:00 | 27.27 | 0 | 92.27 | 0 | 41 | |
| 02/09/2024 02:00 | 27.28 | 0 | 92.64 | 0 | 40.7 | |
| 02/09/2024 03:00 | 27.28 | 0 | 92.66 | 0 | 40.3 | |
| 02/09/2024 04:00 | 27.28 | 0 | 92.15 | 0 | 40.7 | |
| 02/09/2024 05:00 | 27.31 | 0 | 92.11 | 0 | 40.4 | |
| 02/09/2024 06:00 | 27.31 | 0 | 92.12 | 0 | 39.9 | |
| 02/09/2024 07:00 | 27.58 | 0 | 92.32 | 0 | 39.1 | |
| 02/09/2024 08:00 | 30.34 | 0 | 93.34 | 0 | 34.2 | |
| 02/09/2024 09:00 | 34.14 | 0.08 | 94.61 | 0 | 19.8 | |
| 02/09/2024 10:00 | 34.21 | 0.16 | 94.67 | 0 | 19.9 | |
| 02/09/2024 11:00 | 34.09 | 0.15 | 94.72 | 0 | 19.7 | |
| 02/09/2024 12:00 | 21.76 | 0.11 | 92.16 | 0 | 49.3 | |
| 02/09/2024 13:00 | 34.49 | 0.05 | 94.6 | 0 | 21.4 | |
| 02/09/2024 14:00 | 34.41 | 0.03 | 94.91 | 0 | 19.3 | |
| 02/09/2024 15:00 | 34.46 | 0.33 | 94.7 | 0 | 19.2 | |
| 02/09/2024 16:00 | 34.36 | 0.02 | 94.41 | 0 | 19 | |
| 02/09/2024 17:00 | 34.22 | 0 | 94.28 | 0 | 18.9 | |
| 02/09/2024 18:00 | 34.28 | 0 | 94.43 | 0 | 18.8 | |
| 02/09/2024 19:00 | 34.01 | 0 | 94.38 | 0 | 18.7 | |
| 02/09/2024 20:00 | 34.18 | 0 | 94.27 | 0 | 18.9 | |
| 02/09/2024 21:00 | 34.25 | 0 | 94.57 | 0 | 19 | |
| 02/09/2024 22:00 | 34.19 | 0 | 94.55 | 0 | 19 | |
| 02/09/2024 23:00 | 31.3 | 0 | 94.11 | 0 | 25.7 | |
| 03/09/2024 00:00 | 46.89 | 0 | 96.22 | 0 | 34.1 | |
| Minimum | 21.76 | 0 | 92.11 | 0 | 18.7 | |
| MinDate | 02/09/2024 12:00 | 02/09/2024 00:00 | 02/09/2024 05:00 | 02/09/2024 00:00 | 02/09/2024 19:00 | |
| Maximum | 46.89 | 0.33 | 96.22 | 0 | 49.3 | |
| MaxDate | 03/09/2024 00:00 | 02/09/2024 15:00 | 03/09/2024 00:00 | 02/09/2024 00:00 | 02/09/2024 12:00 | |
| Avg | 31.76 | 0.04 | 93.74 | 0 | 28.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.9 | 0.1 | 1.2 | 0 | 10.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/09/2024 00:00 | 2.22 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 01:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 02:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 03:00 | 0 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 04:00 | 0 | 0.96 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 05:00 | 0 | 0.98 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 06:00 | 0 | 0.81 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 07:00 | 0 | 0.54 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 03/09/2024 08:00 | 20.9 | 0.82 | <Samp | <Samp | <Samp | GT11 S/D |
| 03/09/2024 09:00 | 34.45 | 0.34 | 94.55 | 0 | 28.3 | |
| 03/09/2024 10:00 | 34.45 | 0.62 | 94.5 | 0 | 28.3 | |
| 03/09/2024 11:00 | 34.33 | 1.24 | 94.55 | 0 | 28.1 | |
| 03/09/2024 12:00 | 22.03 | 1.23 | 92 | 0 | 55.2 | |
| 03/09/2024 13:00 | 34.67 | 0.71 | 94.68 | 0 | 29.2 | |
| 03/09/2024 14:00 | 34.61 | 0.53 | 95.33 | 0 | 27.7 | |
| 03/09/2024 15:00 | 34.58 | 0.47 | 94.97 | 0 | 28 | |
| 03/09/2024 16:00 | 34.46 | 0.53 | 94.63 | 0 | 27.8 | |
| 03/09/2024 17:00 | 34.35 | 0.52 | 94.41 | 0 | 27.6 | |
| 03/09/2024 18:00 | 34.2 | 0.51 | 94.32 | 0 | 27.5 | |
| 03/09/2024 19:00 | 34.01 | 0.5 | 94.24 | 0 | 27.2 | |
| 03/09/2024 20:00 | 34.07 | 0.42 | 94.27 | 0 | 26.9 | |
| 03/09/2024 21:00 | 34.25 | 0.56 | 94.5 | 0 | 26.9 | |
| 03/09/2024 22:00 | 34.19 | 0.51 | 94.84 | 0 | 26.8 | |
| 03/09/2024 23:00 | 31.38 | 0.55 | 94.41 | 0 | 32.8 | |
| 04/09/2024 00:00 | 46.98 | 0.49 | 95.92 | 0 | 39.3 | |
| Minimum | 0 | 0.25 | 92 | 0 | 26.8 | |
| MinDate | 03/09/2024 01:00 | 03/09/2024 02:00 | 03/09/2024 12:00 | 03/09/2024 09:00 | 03/09/2024 22:00 | |
| Maximum | 46.98 | 1.24 | 95.92 | 0 | 55.2 | |
| MaxDate | 04/09/2024 00:00 | 03/09/2024 11:00 | 04/09/2024 00:00 | 03/09/2024 09:00 | 03/09/2024 12:00 | |
| Avg | 22.81 | 0.61 | 94.51 | 0 | 30.5 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.3 | 0.8 | 0 | 7.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/09/2024 00:00 | 46.89 | 0 | 96.22 | 0 | 34.1 | |
| 03/09/2024 01:00 | 48.83 | 0 | 95.01 | 0 | 36.5 | |
| 03/09/2024 02:00 | 48.92 | 0 | 95.32 | 0 | 36.8 | |
| 03/09/2024 03:00 | 48.94 | 0 | 95.42 | 0 | 36.6 | |
| 03/09/2024 04:00 | 48.85 | 0 | 95.49 | 0 | 35.4 | |
| 03/09/2024 05:00 | 48.9 | 0.05 | 95.68 | 0 | 35.3 | |
| 03/09/2024 06:00 | 48.92 | 0.08 | 96.08 | 0 | 35.4 | |
| 03/09/2024 07:00 | 48.73 | 0.06 | 95.75 | 0 | 34.6 | |
| 03/09/2024 08:00 | 34.66 | 0 | 94.55 | 0 | 32.2 | |
| 03/09/2024 09:00 | 34.39 | 0 | 94.46 | 0 | 18.9 | |
| 03/09/2024 10:00 | 34.38 | 0.04 | 94.37 | 0 | 18.9 | |
| 03/09/2024 11:00 | 34.27 | 0.01 | 94.19 | 0 | 18.9 | |
| 03/09/2024 12:00 | 21.92 | 0.06 | 91.82 | 0 | 49.9 | |
| 03/09/2024 13:00 | 34.62 | 0.11 | 94.35 | 0 | 20.3 | |
| 03/09/2024 14:00 | 34.54 | 0.17 | 94.9 | 0 | 18.6 | |
| 03/09/2024 15:00 | 34.52 | 0.29 | 94.7 | 0 | 18.7 | |
| 03/09/2024 16:00 | 34.39 | 0.06 | 94.45 | 0 | 18.4 | |
| 03/09/2024 17:00 | 34.29 | 0.03 | 94.31 | 0 | 18.4 | |
| 03/09/2024 18:00 | 34.13 | 0 | 94.25 | 0 | 18.3 | |
| 03/09/2024 19:00 | 33.95 | 0 | 94.07 | 0 | 18.2 | |
| 03/09/2024 20:00 | 34 | 0 | 94.17 | 0 | 18.2 | |
| 03/09/2024 21:00 | 34.19 | 0 | 94.35 | 0 | 18.1 | |
| 03/09/2024 22:00 | 34.12 | 0 | 94.53 | 0 | 18.1 | |
| 03/09/2024 23:00 | 31.26 | 0 | 94.06 | 0 | 24.9 | |
| 04/09/2024 00:00 | 1.83 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 1.83 | 0 | 91.82 | 0 | 18.1 | |
| MinDate | 04/09/2024 00:00 | 03/09/2024 00:00 | 03/09/2024 12:00 | 03/09/2024 00:00 | 03/09/2024 21:00 | |
| Maximum | 48.94 | 0.29 | 96.22 | 0 | 49.9 | |
| MaxDate | 03/09/2024 03:00 | 03/09/2024 15:00 | 03/09/2024 00:00 | 03/09/2024 00:00 | 03/09/2024 12:00 | |
| Avg | 36.98 | 0.04 | 94.69 | 0 | 26.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.6 | 0.1 | 0.9 | 0 | 9.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/09/2024 00:00 | 46.98 | 0.49 | 95.92 | 0 | 39.3 | |
| 04/09/2024 01:00 | 48.44 | 0.5 | 95.12 | 0 | 40.1 | |
| 04/09/2024 02:00 | 48.5 | 0.43 | 95.5 | 0 | 39.7 | |
| 04/09/2024 03:00 | 48.57 | 0.39 | 95.55 | 0 | 39.5 | |
| 04/09/2024 04:00 | 48.62 | 0.45 | 95.58 | 0 | 39.4 | |
| 04/09/2024 05:00 | 48.68 | 0.39 | 95.68 | 0 | 39.2 | |
| 04/09/2024 06:00 | 48.72 | 0.62 | 95.9 | 0 | 39.3 | |
| 04/09/2024 07:00 | 48.66 | 0.31 | 95.59 | 0 | 39.4 | |
| 04/09/2024 08:00 | 35.71 | 0.42 | 95.19 | 0 | 38 | |
| 04/09/2024 09:00 | 34.47 | 0.43 | 94.99 | 0 | 26.8 | |
| 04/09/2024 10:00 | 34.54 | 0.32 | 95.41 | 0 | 27.1 | |
| 04/09/2024 11:00 | 34.54 | 0.32 | 95.53 | 0 | 27 | |
| 04/09/2024 12:00 | 21.97 | 0.42 | 92.55 | 0 | 53 | |
| 04/09/2024 13:00 | 34.73 | 0.29 | 94.92 | 0 | 28.7 | |
| 04/09/2024 14:00 | 34.66 | 0.26 | 95.57 | 0 | 26.9 | |
| 04/09/2024 15:00 | 34.63 | 0.25 | 95.25 | 0 | 26.7 | |
| 04/09/2024 16:00 | 34.5 | 0.24 | 95.08 | 0 | 26.6 | |
| 04/09/2024 17:00 | 34.36 | 0.22 | 94.87 | 0 | 26.3 | |
| 04/09/2024 18:00 | 34.34 | 0.23 | 94.77 | 0 | 26.1 | |
| 04/09/2024 19:00 | 34.19 | 0.31 | 94.6 | 0 | 25.8 | |
| 04/09/2024 20:00 | 34.24 | 0.33 | 94.51 | 0 | 25.5 | |
| 04/09/2024 21:00 | 34.41 | 0.34 | 95.08 | 0 | 25.5 | |
| 04/09/2024 22:00 | 34.26 | 0.31 | 95.26 | 0 | 25.4 | |
| 04/09/2024 23:00 | 31.58 | 0.3 | 94.8 | 0 | 31 | |
| 05/09/2024 00:00 | 2.39 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 2.39 | 0.21 | 92.55 | 0 | 25.4 | |
| MinDate | 05/09/2024 00:00 | 05/09/2024 00:00 | 04/09/2024 12:00 | 04/09/2024 00:00 | 04/09/2024 22:00 | |
| Maximum | 48.72 | 0.62 | 95.92 | 0 | 53 | |
| MaxDate | 04/09/2024 06:00 | 04/09/2024 06:00 | 04/09/2024 00:00 | 04/09/2024 00:00 | 04/09/2024 12:00 | |
| Avg | 37.07 | 0.35 | 95.13 | 0 | 32.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.4 | 0.1 | 0.7 | 0 | 7.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/09/2024 00:00 | 1.83 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/09/2024 08:00 | 19.73 | 0 | <Samp | <Samp | <Samp | GT12 S/D |
| 04/09/2024 09:00 | 34.4 | 0.06 | 95.11 | 0 | 25.1 | |
| 04/09/2024 10:00 | 34.47 | 0.08 | 95.04 | 0 | 25.5 | |
| 04/09/2024 11:00 | 34.47 | 0.09 | 95.08 | 0 | 25.4 | |
| 04/09/2024 12:00 | 21.95 | 0.1 | 92.32 | 0 | 51.1 | |
| 04/09/2024 13:00 | 34.66 | 0.09 | 94.87 | 0 | 26.6 | |
| 04/09/2024 14:00 | 34.57 | 0.08 | 95.1 | 0 | 24.7 | |
| 04/09/2024 15:00 | 34.56 | 0.23 | 94.94 | 0 | 24.6 | |
| 04/09/2024 16:00 | 34.43 | 0.05 | 94.83 | 0 | 24.4 | |
| 04/09/2024 17:00 | 34.3 | 0.03 | 94.64 | 0 | 24.1 | |
| 04/09/2024 18:00 | 34.27 | 0.01 | 94.6 | 0 | 23.8 | |
| 04/09/2024 19:00 | 34.12 | 0 | 94.43 | 0 | 23.7 | |
| 04/09/2024 20:00 | 34.17 | 0 | 94.37 | 0 | 23.5 | |
| 04/09/2024 21:00 | 34.34 | 0 | 94.76 | 0 | 23.5 | |
| 04/09/2024 22:00 | 34.19 | 0 | 94.91 | 0 | 23.4 | |
| 04/09/2024 23:00 | 31.55 | 0 | 94.39 | 0 | 28.9 | |
| 05/09/2024 00:00 | 46.34 | 0 | 96.15 | 0 | 41.6 | |
| Minimum | 0 | 0 | 92.32 | 0 | 23.4 | |
| MinDate | 04/09/2024 01:00 | 04/09/2024 00:00 | 04/09/2024 12:00 | 04/09/2024 09:00 | 04/09/2024 22:00 | |
| Maximum | 46.34 | 0.23 | 96.15 | 0 | 51.1 | |
| MaxDate | 05/09/2024 00:00 | 04/09/2024 15:00 | 05/09/2024 00:00 | 04/09/2024 09:00 | 04/09/2024 12:00 | |
| Avg | 22.73 | 0.03 | 94.72 | 0 | 27.5 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.1 | 0.8 | 0 | 7.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/09/2024 00:00 | 2.39 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 01:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 02:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 03:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 04:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 05:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 06:00 | 0 | 0.55 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 07:00 | 0 | 0.37 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/09/2024 08:00 | 20.92 | 0.67 | <Samp | <Samp | <Samp | GT11 S/D |
| 05/09/2024 09:00 | 34.7 | 0.45 | 95.58 | 0 | 28.8 | |
| 05/09/2024 10:00 | 34.71 | 0.48 | 95.61 | 0 | 28.9 | |
| 05/09/2024 11:00 | 34.64 | 0.45 | 95.54 | 0 | 28.9 | |
| 05/09/2024 12:00 | 22.15 | 0.51 | 92.77 | 0 | 53.1 | |
| 05/09/2024 13:00 | 34.82 | 0.41 | 94.6 | 0 | 30.8 | |
| 05/09/2024 14:00 | 34.77 | 0.35 | 94.77 | 0 | 28.3 | |
| 05/09/2024 15:00 | 34.71 | 0.32 | 94.64 | 0 | 28.5 | |
| 05/09/2024 16:00 | 34.59 | 0.3 | 94.39 | 0 | 28.4 | |
| 05/09/2024 17:00 | 34.48 | 0.27 | 94.12 | 0 | 28 | |
| 05/09/2024 18:00 | 34.42 | 0.25 | 93.95 | 0 | 27.8 | |
| 05/09/2024 19:00 | 34.19 | 0.25 | 93.94 | 0 | 27.4 | |
| 05/09/2024 20:00 | 34.25 | 0.25 | 93.9 | 0 | 27.2 | |
| 05/09/2024 21:00 | 34.53 | 0.24 | 94.15 | 0 | 27.1 | |
| 05/09/2024 22:00 | 34.54 | 0.25 | 94.19 | 0 | 27.1 | |
| 05/09/2024 23:00 | 31.73 | 0.27 | 93.77 | 0 | 32.5 | |
| 06/09/2024 00:00 | 46.17 | 0.17 | 95.33 | 0 | 39.6 | |
| Minimum | 0 | 0.11 | 92.77 | 0 | 27.1 | |
| MinDate | 05/09/2024 01:00 | 05/09/2024 01:00 | 05/09/2024 12:00 | 05/09/2024 09:00 | 05/09/2024 21:00 | |
| Maximum | 46.17 | 0.67 | 95.61 | 0 | 53.1 | |
| MaxDate | 06/09/2024 00:00 | 05/09/2024 08:00 | 05/09/2024 10:00 | 05/09/2024 09:00 | 05/09/2024 12:00 | |
| Avg | 22.91 | 0.31 | 94.45 | 0 | 30.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.1 | 0.8 | 0 | 6.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/09/2024 00:00 | 46.34 | 0 | 96.15 | 0 | 41.6 | |
| 05/09/2024 01:00 | 48.14 | 0 | 94.9 | 0 | 43.7 | |
| 05/09/2024 02:00 | 48.2 | 0 | 95.37 | 0 | 43.3 | |
| 05/09/2024 03:00 | 48.35 | 0 | 95.47 | 0 | 42.8 | |
| 05/09/2024 04:00 | 48.44 | 0 | 95.39 | 0 | 42.7 | |
| 05/09/2024 05:00 | 48.45 | 0 | 95.46 | 0 | 42.8 | |
| 05/09/2024 06:00 | 48.34 | 0 | 95.85 | 0 | 42.7 | |
| 05/09/2024 07:00 | 48.04 | 0.03 | 95.7 | 0 | 42.3 | |
| 05/09/2024 08:00 | 35.17 | 0.06 | 95.06 | 0 | 36.3 | |
| 05/09/2024 09:00 | 34.64 | 0.07 | 95.14 | 0 | 23.6 | |
| 05/09/2024 10:00 | 34.64 | 0.09 | 95.19 | 0 | 23.6 | |
| 05/09/2024 11:00 | 34.57 | 0.08 | 95.25 | 0 | 23.7 | |
| 05/09/2024 12:00 | 22.12 | 0.06 | 92.52 | 0 | 49.5 | |
| 05/09/2024 13:00 | 34.77 | 0.07 | 95.21 | 0 | 25.5 | |
| 05/09/2024 14:00 | 34.7 | 0.03 | 95.77 | 0 | 23.3 | |
| 05/09/2024 15:00 | 34.64 | 0.42 | 95.57 | 0 | 23.3 | |
| 05/09/2024 16:00 | 34.53 | 0.05 | 95.34 | 0 | 23.1 | |
| 05/09/2024 17:00 | 34.41 | 0.02 | 95.07 | 0 | 22.8 | |
| 05/09/2024 18:00 | 34.36 | 0 | 94.95 | 0 | 22.6 | |
| 05/09/2024 19:00 | 34.13 | 0 | 94.97 | 0 | 22.3 | |
| 05/09/2024 20:00 | 34.19 | 0 | 94.89 | 0 | 22.2 | |
| 05/09/2024 21:00 | 34.45 | 0 | 95.23 | 0 | 22.2 | |
| 05/09/2024 22:00 | 34.48 | 0 | 95.35 | 0 | 22.2 | |
| 05/09/2024 23:00 | 31.66 | 0 | 94.9 | 0 | 27.7 | |
| 06/09/2024 00:00 | 2.26 | 0 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 2.26 | 0 | 92.52 | 0 | 22.2 | |
| MinDate | 06/09/2024 00:00 | 05/09/2024 00:00 | 05/09/2024 12:00 | 05/09/2024 00:00 | 05/09/2024 20:00 | |
| Maximum | 48.45 | 0.42 | 96.15 | 0 | 49.5 | |
| MaxDate | 05/09/2024 05:00 | 05/09/2024 15:00 | 05/09/2024 00:00 | 05/09/2024 00:00 | 05/09/2024 12:00 | |
| Avg | 36.96 | 0.04 | 95.2 | 0 | 31.5 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.2 | 0.1 | 0.7 | 0 | 10 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/09/2024 00:00 | 46.17 | 0.17 | 95.33 | 0 | 39.6 | |
| 06/09/2024 01:00 | 47.95 | 0.15 | 94.86 | 0 | 39.9 | |
| 06/09/2024 02:00 | 48.03 | 0.15 | 95.45 | 0 | 39.8 | |
| 06/09/2024 03:00 | 48.13 | 0.18 | 95.55 | 0 | 39.5 | |
| 06/09/2024 04:00 | 48.19 | 0.23 | 95.55 | 0 | 39.5 | |
| 06/09/2024 05:00 | 48.25 | 0.31 | 95.67 | 0 | 39.2 | |
| 06/09/2024 06:00 | 48.25 | 0.37 | 96.17 | 0 | 39.1 | |
| 06/09/2024 07:00 | 48.14 | 0.1 | 95.63 | 0 | 38.9 | |
| 06/09/2024 08:00 | 34.87 | 0.32 | 95 | 0 | 38 | |
| 06/09/2024 09:00 | 34.6 | 0.26 | 94.8 | 0 | 26.3 | |
| 06/09/2024 10:00 | 34.69 | 0.26 | 95.13 | 0 | 26.5 | |
| 06/09/2024 11:00 | 34.67 | 0.31 | 95.16 | 0 | 26.5 | |
| 06/09/2024 12:00 | 22.13 | 0.38 | 92.53 | 0 | 50.1 | |
| 06/09/2024 13:00 | 34.81 | 0.24 | 94.76 | 0 | 28.5 | |
| 06/09/2024 14:00 | 34.75 | 0.19 | 95.03 | 0 | 26.3 | |
| 06/09/2024 15:00 | 34.67 | 0.14 | 94.6 | 0 | 26.1 | |
| 06/09/2024 16:00 | 34.67 | 0.14 | 94.57 | 0 | 25.9 | |
| 06/09/2024 17:00 | 34.46 | 0.12 | 94.36 | 0 | 25.7 | |
| 06/09/2024 18:00 | 34.46 | 0.14 | 94.29 | 0 | 25.5 | |
| 06/09/2024 19:00 | 34.22 | 0.18 | 94.12 | 0 | 25.3 | |
| 06/09/2024 20:00 | 34.26 | 0.22 | 94.06 | 0 | 25.1 | |
| 06/09/2024 21:00 | 34.47 | 0.26 | 94.57 | 0 | 25 | |
| 06/09/2024 22:00 | 37.46 | 0.29 | 96.1 | 0 | 26.3 | |
| 06/09/2024 23:00 | 35.57 | 0.34 | 96.57 | 0 | 30.5 | |
| 07/09/2024 00:00 | 28.65 | 0.27 | 93.06 | 0 | 42.7 | |
| Minimum | 22.13 | 0.1 | 92.53 | 0 | 25 | |
| MinDate | 06/09/2024 12:00 | 06/09/2024 07:00 | 06/09/2024 12:00 | 06/09/2024 00:00 | 06/09/2024 21:00 | |
| Maximum | 48.25 | 0.38 | 96.57 | 0 | 50.1 | |
| MaxDate | 06/09/2024 05:00 | 06/09/2024 12:00 | 06/09/2024 23:00 | 06/09/2024 00:00 | 06/09/2024 12:00 | |
| Avg | 38.26 | 0.23 | 94.92 | 0 | 32.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0.1 | 0.9 | 0 | 7.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/09/2024 00:00 | 2.26 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/09/2024 08:00 | 20.96 | 0.01 | <Samp | <Samp | <Samp | GT12 S/D |
| 06/09/2024 09:00 | 34.53 | 0.07 | 95.54 | 0 | 24.8 | |
| 06/09/2024 10:00 | 34.62 | 0.14 | 95.65 | 0 | 24.9 | |
| 06/09/2024 11:00 | 34.6 | 0.19 | 95.69 | 0 | 24.8 | |
| 06/09/2024 12:00 | 22.08 | 0.17 | 93 | 0 | 48.8 | |
| 06/09/2024 13:00 | 34.71 | 0.13 | 95.3 | 0 | 26.4 | |
| 06/09/2024 14:00 | 34.69 | 0.09 | 95.4 | 0 | 24.3 | |
| 06/09/2024 15:00 | 34.61 | 0.35 | 95.17 | 0 | 24 | |
| 06/09/2024 16:00 | 34.59 | 0.05 | 95.2 | 0 | 23.8 | |
| 06/09/2024 17:00 | 34.39 | 0.03 | 94.98 | 0 | 23.5 | |
| 06/09/2024 18:00 | 34.39 | 0.01 | 94.96 | 0 | 23.4 | |
| 06/09/2024 19:00 | 34.15 | 0 | 94.85 | 0 | 23 | |
| 06/09/2024 20:00 | 34.19 | 0 | 94.79 | 0 | 23 | |
| 06/09/2024 21:00 | 34.4 | 0 | 95.13 | 0 | 22.9 | |
| 06/09/2024 22:00 | 37.39 | 0 | 96.71 | 0 | 24.4 | |
| 06/09/2024 23:00 | 35.49 | 0.01 | 97.1 | 0 | 28.5 | |
| 07/09/2024 00:00 | 28.59 | 0 | 93.61 | 0 | 39.1 | |
| Minimum | 0 | 0 | 93 | 0 | 22.9 | |
| MinDate | 06/09/2024 01:00 | 06/09/2024 00:00 | 06/09/2024 12:00 | 06/09/2024 09:00 | 06/09/2024 21:00 | |
| Maximum | 37.39 | 0.35 | 97.1 | 0 | 48.8 | |
| MaxDate | 06/09/2024 22:00 | 06/09/2024 15:00 | 06/09/2024 23:00 | 06/09/2024 09:00 | 06/09/2024 12:00 | |
| Avg | 22.43 | 0.05 | 95.19 | 0 | 26.9 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16 | 0.1 | 1 | 0 | 7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/09/2024 00:00 | 28.65 | 0.27 | 93.06 | 0 | 42.7 | |
| 07/09/2024 01:00 | 28.8 | 0.23 | 92.71 | 0 | 42.4 | |
| 07/09/2024 02:00 | 28.81 | 0.26 | 92.57 | 0 | 42.3 | |
| 07/09/2024 03:00 | 28.76 | 0.33 | 92.5 | 0 | 42.5 | |
| 07/09/2024 04:00 | 28.67 | 0.33 | 92.47 | 0 | 42.5 | |
| 07/09/2024 05:00 | 28.62 | 0.34 | 92.41 | 0 | 43 | |
| 07/09/2024 06:00 | 28.66 | 0.6 | 92.48 | 0 | 42.8 | |
| 07/09/2024 07:00 | 28.62 | 0.39 | 92.58 | 0 | 42.7 | |
| 07/09/2024 08:00 | 32.19 | 0.4 | 93.6 | 0 | 39.8 | |
| 07/09/2024 09:00 | 42.8 | 0.32 | 100.04 | 0 | 28.4 | |
| 07/09/2024 10:00 | 42.91 | 0.38 | 100.8 | 0 | 28.9 | |
| 07/09/2024 11:00 | 42.83 | 0.41 | 101.02 | 0 | 29 | |
| 07/09/2024 12:00 | 28.89 | 0.47 | 95.23 | 0 | 40.7 | |
| 07/09/2024 13:00 | 42.88 | 0.29 | 99.15 | 0 | 30.6 | |
| 07/09/2024 14:00 | 43.07 | 0.2 | 100.9 | 0 | 29.2 | |
| 07/09/2024 15:00 | 42.99 | 0.17 | 100.7 | 0 | 28.9 | |
| 07/09/2024 16:00 | 42.85 | 0.12 | 100.37 | 0 | 28.3 | |
| 07/09/2024 17:00 | 42.64 | 0.09 | 99.82 | 0 | 27.7 | |
| 07/09/2024 18:00 | 42.54 | 0.14 | 99.48 | 0 | 27.5 | |
| 07/09/2024 19:00 | 42.5 | 0.23 | 99.44 | 0 | 27.5 | |
| 07/09/2024 20:00 | 42.74 | 0.27 | 99.61 | 0 | 27.5 | |
| 07/09/2024 21:00 | 42.83 | 0.22 | 99.92 | 0 | 28 | |
| 07/09/2024 22:00 | 42.83 | 0.22 | 99.94 | 0 | 28 | |
| 07/09/2024 23:00 | 39.15 | 0.29 | 98.87 | 0 | 30.9 | |
| 08/09/2024 00:00 | 28.73 | 0.35 | 92.9 | 0 | 42.3 | |
| Minimum | 28.62 | 0.09 | 92.41 | 0 | 27.5 | |
| MinDate | 07/09/2024 05:00 | 07/09/2024 17:00 | 07/09/2024 05:00 | 07/09/2024 00:00 | 07/09/2024 18:00 | |
| Maximum | 43.07 | 0.6 | 101.02 | 0 | 43 | |
| MaxDate | 07/09/2024 14:00 | 07/09/2024 06:00 | 07/09/2024 11:00 | 07/09/2024 00:00 | 07/09/2024 05:00 | |
| Avg | 36.6 | 0.29 | 96.9 | 0 | 34.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.9 | 0.1 | 3.6 | 0 | 6.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/09/2024 00:00 | 28.59 | 0 | 93.61 | 0 | 39.1 | |
| 07/09/2024 01:00 | 28.74 | 0 | 93.25 | 0 | 38.9 | |
| 07/09/2024 02:00 | 28.75 | 0 | 93.07 | 0 | 38.9 | |
| 07/09/2024 03:00 | 28.69 | 0 | 93.04 | 0 | 39 | |
| 07/09/2024 04:00 | 28.61 | 0 | 93.04 | 0 | 0 | 0 |
| 07/09/2024 05:00 | 28.55 | 0 | 92.94 | 0 | 39.3 | |
| 07/09/2024 06:00 | 28.59 | 0 | 93.05 | 0 | 39.2 | |
| 07/09/2024 07:00 | 28.55 | 0 | 93.15 | 0 | 39.1 | |
| 07/09/2024 08:00 | 32.11 | 0.04 | 94.27 | 0 | 37.4 | |
| 07/09/2024 09:00 | 42.74 | 0.09 | 100.59 | 0 | 29 | |
| 07/09/2024 10:00 | 42.83 | 0.16 | 101.36 | 0 | 29.8 | |
| 07/09/2024 11:00 | 42.75 | 0.2 | 101.64 | 0 | 30 | |
| 07/09/2024 12:00 | 28.82 | 0.18 | 95.74 | 0 | 38.1 | |
| 07/09/2024 13:00 | 42.77 | 0.12 | 99.88 | 0 | 32 | |
| 07/09/2024 14:00 | 42.99 | 0.08 | 101.46 | 0 | 30.8 | |
| 07/09/2024 15:00 | 42.91 | 0.31 | 101.34 | 0 | 30.1 | |
| 07/09/2024 16:00 | 42.78 | 0.03 | 101.17 | 0 | 29 | |
| 07/09/2024 17:00 | 42.56 | 0 | 100.74 | 0 | 27.8 | |
| 07/09/2024 18:00 | 42.46 | 0 | 100.36 | 0 | 27.3 | |
| 07/09/2024 19:00 | 42.42 | 0 | 100.25 | 0 | 27.3 | |
| 07/09/2024 20:00 | 42.66 | 0 | 100.42 | 0 | 27.5 | |
| 07/09/2024 21:00 | 42.75 | 0 | 100.55 | 0 | 28.2 | |
| 07/09/2024 22:00 | 42.75 | 0 | 100.52 | 0 | 28.2 | |
| 07/09/2024 23:00 | 39.08 | 0 | 99.35 | 0 | 30.4 | |
| 08/09/2024 00:00 | 28.67 | 0 | 93.5 | 0 | 38.8 | |
| Minimum | 28.55 | 0 | 92.94 | 0 | 27.3 | |
| MinDate | 07/09/2024 05:00 | 07/09/2024 00:00 | 07/09/2024 05:00 | 07/09/2024 00:00 | 07/09/2024 18:00 | |
| Maximum | 42.99 | 0.31 | 101.64 | 0 | 39.3 | |
| MaxDate | 07/09/2024 14:00 | 07/09/2024 15:00 | 07/09/2024 11:00 | 07/09/2024 00:00 | 07/09/2024 05:00 | |
| Avg | 36.52 | 0.05 | 97.53 | 0 | 33.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.9 | 0.1 | 3.7 | 0 | 5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/09/2024 00:00 | 28.73 | 0.35 | 92.9 | 0 | 42.3 | |
| 08/09/2024 01:00 | 28.8 | 0.31 | 92.45 | 0 | 42 | |
| 08/09/2024 02:00 | 28.74 | 0.3 | 92.35 | 0 | 41.9 | |
| 08/09/2024 03:00 | 28.53 | 0.28 | 92.4 | 0 | 42.4 | |
| 08/09/2024 04:00 | 28.18 | 0.34 | 92.18 | 0 | 43.5 | |
| 08/09/2024 05:00 | 27.9 | 0.42 | 92.12 | 0 | 44.6 | |
| 08/09/2024 06:00 | 27.73 | 0.5 | 92.23 | 0 | 44.9 | |
| 08/09/2024 07:00 | 27.47 | 0.33 | 92.18 | 0 | 45.7 | |
| 08/09/2024 08:00 | 27.18 | 0.35 | 92.19 | 0 | 46.5 | |
| 08/09/2024 09:00 | 27.12 | 0.41 | 92.29 | 0 | 46.2 | |
| 08/09/2024 10:00 | 27.08 | 0.45 | 92.4 | 0 | 46.3 | |
| 08/09/2024 11:00 | 27.07 | 0.48 | 92.6 | 0 | 46.1 | |
| 08/09/2024 12:00 | 27.05 | 0.44 | 92.59 | 0 | 46 | |
| 08/09/2024 13:00 | 27.12 | 0.37 | 92.49 | 0 | 45.5 | |
| 08/09/2024 14:00 | 27.12 | 0.36 | 92.48 | 0 | 45.3 | |
| 08/09/2024 15:00 | 27.14 | 0.38 | 92.06 | 0 | 45.2 | |
| 08/09/2024 16:00 | 27.2 | 0.38 | 91.96 | 0 | 44.7 | |
| 08/09/2024 17:00 | 27.17 | 0.76 | 91.07 | 0 | 45.4 | |
| 08/09/2024 18:00 | 37.54 | 0.99 | 95.02 | 0 | 31.1 | |
| 08/09/2024 19:00 | 40.91 | 0.27 | 97.98 | 0 | 25.7 | |
| 08/09/2024 20:00 | 40.86 | 0.18 | 97.82 | 0 | 25.4 | |
| 08/09/2024 21:00 | 40.84 | 0.18 | 98.34 | 0 | 25.2 | |
| 08/09/2024 22:00 | 33.86 | 0.3 | 96.56 | 0 | 34 | |
| 08/09/2024 23:00 | 27.1 | 0.29 | 92.33 | 0 | 44.8 | |
| 09/09/2024 00:00 | 27.04 | 0.42 | 92.07 | 0 | 44.9 | |
| Minimum | 27.04 | 0.18 | 91.07 | 0 | 25.2 | |
| MinDate | 09/09/2024 00:00 | 08/09/2024 20:00 | 08/09/2024 17:00 | 08/09/2024 00:00 | 08/09/2024 21:00 | |
| Maximum | 40.91 | 0.99 | 98.34 | 0 | 46.5 | |
| MaxDate | 08/09/2024 19:00 | 08/09/2024 18:00 | 08/09/2024 21:00 | 08/09/2024 00:00 | 08/09/2024 08:00 | |
| Avg | 29.82 | 0.39 | 93.24 | 0 | 41.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.8 | 0.2 | 2.1 | 0 | 7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/09/2024 00:00 | 28.67 | 0 | 93.5 | 0 | 38.8 | |
| 08/09/2024 01:00 | 28.73 | 0 | 93.06 | 0 | 38.6 | |
| 08/09/2024 02:00 | 28.67 | 0 | 93.04 | 0 | 38.6 | |
| 08/09/2024 03:00 | 28.46 | 0 | 93.05 | 0 | 38.8 | |
| 08/09/2024 04:00 | 28.11 | 0 | 92.82 | 0 | 39.6 | |
| 08/09/2024 05:00 | 27.83 | 0 | 92.77 | 0 | 40.2 | |
| 08/09/2024 06:00 | 27.67 | 0 | 92.92 | 0 | 40.5 | |
| 08/09/2024 07:00 | 27.41 | 0 | 92.84 | 0 | 41.3 | |
| 08/09/2024 08:00 | 27.13 | 0.03 | 92.92 | 0 | 41.9 | |
| 08/09/2024 09:00 | 27.06 | 0.08 | 93 | 0 | 41.6 | |
| 08/09/2024 10:00 | 27.02 | 0.11 | 93.09 | 0 | 41.8 | |
| 08/09/2024 11:00 | 27.01 | 0.16 | 93.29 | 0 | 41.6 | |
| 08/09/2024 12:00 | 26.98 | 0.14 | 93.25 | 0 | 41.6 | |
| 08/09/2024 13:00 | 27.05 | 0.09 | 93.2 | 0 | 41.2 | |
| 08/09/2024 14:00 | 27.06 | 0.08 | 93.16 | 0 | 41 | |
| 08/09/2024 15:00 | 27.07 | 0.22 | 92.85 | 0 | 40.8 | |
| 08/09/2024 16:00 | 27.13 | 0.05 | 92.78 | 0 | 40.4 | |
| 08/09/2024 17:00 | 27.1 | 0.02 | 91.88 | 0 | 41.2 | |
| 08/09/2024 18:00 | 37.47 | 0 | 95.95 | 0 | 29 | |
| 08/09/2024 19:00 | 40.83 | 0 | 98.82 | 0 | 23.6 | |
| 08/09/2024 20:00 | 40.79 | 0 | 98.72 | 0 | 23.5 | |
| 08/09/2024 21:00 | 40.76 | 0 | 99.13 | 0 | 23.3 | |
| 08/09/2024 22:00 | 33.81 | 0 | 97.21 | 0 | 31.5 | |
| 08/09/2024 23:00 | 27.04 | 0 | 93.1 | 0 | 40.9 | |
| 09/09/2024 00:00 | 26.98 | 0 | 92.72 | 0 | 41.3 | |
| Minimum | 26.98 | 0 | 91.88 | 0 | 23.3 | |
| MinDate | 08/09/2024 12:00 | 08/09/2024 00:00 | 08/09/2024 17:00 | 08/09/2024 00:00 | 08/09/2024 21:00 | |
| Maximum | 40.83 | 0.22 | 99.13 | 0 | 41.9 | |
| MaxDate | 08/09/2024 19:00 | 08/09/2024 15:00 | 08/09/2024 21:00 | 08/09/2024 00:00 | 08/09/2024 08:00 | |
| Avg | 29.75 | 0.04 | 93.96 | 0 | 37.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.8 | 0.1 | 2.1 | 0 | 6.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/09/2024 00:00 | 27.04 | 0.42 | 92.07 | 0 | 44.9 | |
| 09/09/2024 01:00 | 27.11 | 0.45 | 92.07 | 0 | 45 | |
| 09/09/2024 02:00 | 27.1 | 0.46 | 92.1 | 0 | 44.9 | |
| 09/09/2024 03:00 | 27.07 | 0.37 | 92.27 | 0 | 44.5 | |
| 09/09/2024 04:00 | 27.08 | 0.33 | 92.38 | 0 | 44.6 | |
| 09/09/2024 05:00 | 27.11 | 0.38 | 92.2 | 0 | 45.1 | |
| 09/09/2024 06:00 | 27.1 | 0.64 | 92.12 | 0 | 45 | |
| 09/09/2024 07:00 | 27.33 | 0.26 | 92.27 | 0 | 44.4 | |
| 09/09/2024 08:00 | 31.19 | 0.17 | 93.44 | 0 | 37.2 | |
| 09/09/2024 09:00 | 34.37 | 0.16 | 94.72 | 0 | 22.2 | |
| 09/09/2024 10:00 | 34.21 | 0.28 | 94.55 | 0 | 22.1 | |
| 09/09/2024 11:00 | 34.25 | 0.34 | 94.92 | 0 | 22.1 | |
| 09/09/2024 12:00 | 21.91 | 0.46 | 92.23 | 0 | 48.6 | |
| 09/09/2024 13:00 | 34.53 | 0.32 | 94.44 | 0 | 23.8 | |
| 09/09/2024 14:00 | 34.46 | 0.29 | 94.9 | 0 | 22.3 | |
| 09/09/2024 15:00 | 34.46 | 0.23 | 94.58 | 0 | 22.3 | |
| 09/09/2024 16:00 | 34.46 | 0.23 | 94.44 | 0 | 22.1 | |
| 09/09/2024 17:00 | 34.38 | 0.22 | 94.33 | 0 | 22 | |
| 09/09/2024 18:00 | 34.33 | 0.22 | 94.15 | 0 | 21.7 | |
| 09/09/2024 19:00 | 34.21 | 0.24 | 94.05 | 0 | 21.8 | |
| 09/09/2024 20:00 | 34.21 | 0.26 | 94.07 | 0 | 21.7 | |
| 09/09/2024 21:00 | 34.4 | 0.17 | 94.44 | 0 | 21.6 | |
| 09/09/2024 22:00 | 34.36 | 0.18 | 94.5 | 0 | 21.5 | |
| 09/09/2024 23:00 | 31.42 | 0.2 | 94.11 | 0 | 27.7 | |
| 10/09/2024 00:00 | 2.16 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 2.16 | 0.16 | 92.07 | 0 | 21.5 | |
| MinDate | 10/09/2024 00:00 | 09/09/2024 09:00 | 09/09/2024 00:00 | 09/09/2024 00:00 | 09/09/2024 22:00 | |
| Maximum | 34.53 | 0.64 | 94.92 | 0 | 48.6 | |
| MaxDate | 09/09/2024 13:00 | 09/09/2024 06:00 | 09/09/2024 11:00 | 09/09/2024 00:00 | 09/09/2024 12:00 | |
| Avg | 30.01 | 0.3 | 93.56 | 0 | 31.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.9 | 0.1 | 1.1 | 0 | 11.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/09/2024 00:00 | 26.98 | 0 | 92.72 | 0 | 41.3 | |
| 09/09/2024 01:00 | 27.05 | 0 | 92.72 | 0 | 40.9 | |
| 09/09/2024 02:00 | 27.03 | 0 | 92.73 | 0 | 40.9 | |
| 09/09/2024 03:00 | 27 | 0 | 92.85 | 0 | 40.8 | |
| 09/09/2024 04:00 | 27.02 | 0 | 92.94 | 0 | 40.8 | |
| 09/09/2024 05:00 | 27.05 | 0 | 92.81 | 0 | 41.1 | |
| 09/09/2024 06:00 | 27.05 | 0 | 92.73 | 0 | 41 | |
| 09/09/2024 07:00 | 27.28 | 0 | 92.85 | 0 | 40 | |
| 09/09/2024 08:00 | 31.18 | 0 | 94.14 | 0 | 34.4 | |
| 09/09/2024 09:00 | 34.29 | 0.01 | 95.42 | 0 | 19.9 | |
| 09/09/2024 10:00 | 34.15 | 0.06 | 95.26 | 0 | 19.7 | |
| 09/09/2024 11:00 | 34.19 | 0.14 | 95.58 | 0 | 19.7 | |
| 09/09/2024 12:00 | 21.87 | 0.19 | 92.97 | 0 | 47.8 | |
| 09/09/2024 13:00 | 34.44 | 0.19 | 95.14 | 0 | 21.5 | |
| 09/09/2024 14:00 | 34.39 | 0.15 | 95.41 | 0 | 20.1 | |
| 09/09/2024 15:00 | 34.39 | 0.36 | 95.16 | 0 | 20.1 | |
| 09/09/2024 16:00 | 34.4 | 0.04 | 95.15 | 0 | 19.8 | |
| 09/09/2024 17:00 | 34.32 | 0.03 | 95.02 | 0 | 19.6 | |
| 09/09/2024 18:00 | 34.26 | 0 | 94.88 | 0 | 19.3 | |
| 09/09/2024 19:00 | 34.14 | 0 | 94.83 | 0 | 19.3 | |
| 09/09/2024 20:00 | 34.14 | 0 | 94.85 | 0 | 19.2 | |
| 09/09/2024 21:00 | 34.33 | 0 | 95.07 | 0 | 19.2 | |
| 09/09/2024 22:00 | 34.29 | 0 | 95.07 | 0 | 18.9 | |
| 09/09/2024 23:00 | 31.44 | 0 | 94.6 | 0 | 25.4 | |
| 10/09/2024 00:00 | 46.47 | 0 | 96.41 | 0 | 34.3 | |
| Minimum | 21.87 | 0 | 92.72 | 0 | 18.9 | |
| MinDate | 09/09/2024 12:00 | 09/09/2024 00:00 | 09/09/2024 00:00 | 09/09/2024 00:00 | 09/09/2024 22:00 | |
| Maximum | 46.47 | 0.36 | 96.41 | 0 | 47.8 | |
| MaxDate | 10/09/2024 00:00 | 09/09/2024 15:00 | 10/09/2024 00:00 | 09/09/2024 00:00 | 09/09/2024 12:00 | |
| Avg | 31.73 | 0.05 | 94.29 | 0 | 29 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.9 | 0.1 | 1.2 | 0 | 10.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/09/2024 00:00 | 2.16 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 01:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 02:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 03:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 04:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 05:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 06:00 | 0 | 0.52 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 07:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/09/2024 08:00 | 20.95 | 0.63 | <Samp | <Samp | <Samp | GT11 S/D |
| 10/09/2024 09:00 | 34.43 | 0.42 | 94.66 | 0 | 28.6 | |
| 10/09/2024 10:00 | 34.4 | 0.43 | 94.87 | 0 | 28.6 | |
| 10/09/2024 11:00 | 34.34 | 0.42 | 95.15 | 0 | 28.8 | |
| 10/09/2024 12:00 | 21.98 | 0.54 | 92.5 | 0 | 52.3 | |
| 10/09/2024 13:00 | 34.6 | 0.45 | 94.46 | 0 | 30.3 | |
| 10/09/2024 14:00 | 34.56 | 0.43 | 95.11 | 0 | 29.2 | |
| 10/09/2024 15:00 | 34.58 | 0.42 | 95.14 | 0 | 29.1 | |
| 10/09/2024 16:00 | 34.54 | 0.36 | 94.96 | 0 | 29 | |
| 10/09/2024 17:00 | 34.46 | 0.34 | 94.76 | 0 | 28.6 | |
| 10/09/2024 18:00 | 34.4 | 0.38 | 94.58 | 0 | 28.3 | |
| 10/09/2024 19:00 | 34.23 | 0.35 | 94.49 | 0 | 27.8 | |
| 10/09/2024 20:00 | 34.25 | 0.31 | 94.73 | 0 | 27.7 | |
| 10/09/2024 21:00 | 34.38 | 0.37 | 94.96 | 0 | 27.4 | |
| 10/09/2024 22:00 | 34.43 | 0.31 | 95.29 | 0 | 27.1 | |
| 10/09/2024 23:00 | 31.51 | 0.16 | 94.94 | 0 | 32.7 | |
| 11/09/2024 00:00 | 46.77 | 0.15 | 96.36 | 0 | 39 | |
| Minimum | 0 | 0.15 | 92.5 | 0 | 27.1 | |
| MinDate | 10/09/2024 01:00 | 11/09/2024 00:00 | 10/09/2024 12:00 | 10/09/2024 09:00 | 10/09/2024 22:00 | |
| Maximum | 46.77 | 0.63 | 96.36 | 0 | 52.3 | |
| MaxDate | 11/09/2024 00:00 | 10/09/2024 08:00 | 11/09/2024 00:00 | 10/09/2024 09:00 | 10/09/2024 12:00 | |
| Avg | 22.84 | 0.34 | 94.81 | 0 | 30.9 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.1 | 0.8 | 0 | 6.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/09/2024 00:00 | 46.47 | 0 | 96.41 | 0 | 34.3 | |
| 10/09/2024 01:00 | 48.02 | 0 | 94.98 | 0 | 36.1 | |
| 10/09/2024 02:00 | 48.12 | 0 | 95.26 | 0 | 36.1 | |
| 10/09/2024 03:00 | 48.18 | 0 | 95.42 | 0 | 36.1 | |
| 10/09/2024 04:00 | 48.17 | 0 | 95.46 | 0 | 35.9 | |
| 10/09/2024 05:00 | 48.14 | 0 | 95.4 | 0 | 35.7 | |
| 10/09/2024 06:00 | 48.2 | 0 | 95.77 | 0 | 35.8 | |
| 10/09/2024 07:00 | 48.04 | 0 | 95.21 | 0 | 35.5 | |
| 10/09/2024 08:00 | 34.8 | 0 | 94.74 | 0 | 31.4 | |
| 10/09/2024 09:00 | 34.36 | 0.01 | 95 | 0 | 18.7 | |
| 10/09/2024 10:00 | 34.33 | 0.03 | 95.36 | 0 | 18.6 | |
| 10/09/2024 11:00 | 34.28 | 0.05 | 95.65 | 0 | 18.7 | |
| 10/09/2024 12:00 | 21.89 | 0.09 | 93.11 | 0 | 46.2 | |
| 10/09/2024 13:00 | 34.53 | 0.1 | 95.17 | 0 | 20.3 | |
| 10/09/2024 14:00 | 34.49 | 0.1 | 95.42 | 0 | 18.9 | |
| 10/09/2024 15:00 | 34.51 | 0.3 | 95.25 | 0 | 19 | |
| 10/09/2024 16:00 | 34.48 | 0.03 | 95.04 | 0 | 18.8 | |
| 10/09/2024 17:00 | 34.39 | 0.02 | 94.93 | 0 | 18.6 | |
| 10/09/2024 18:00 | 34.35 | 0 | 94.82 | 0 | 18.4 | |
| 10/09/2024 19:00 | 34.16 | 0 | 94.67 | 0 | 18.2 | |
| 10/09/2024 20:00 | 34.18 | 0 | 94.69 | 0 | 18.3 | |
| 10/09/2024 21:00 | 34.32 | 0 | 94.9 | 0 | 18.2 | |
| 10/09/2024 22:00 | 34.37 | 0 | 95.03 | 0 | 18.1 | |
| 10/09/2024 23:00 | 31.39 | 0 | 94.64 | 0 | 24.4 | |
| 11/09/2024 00:00 | 1.83 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 1.83 | 0 | 93.11 | 0 | 18.1 | |
| MinDate | 11/09/2024 00:00 | 10/09/2024 00:00 | 10/09/2024 12:00 | 10/09/2024 00:00 | 10/09/2024 22:00 | |
| Maximum | 48.2 | 0.3 | 96.41 | 0 | 46.2 | |
| MaxDate | 10/09/2024 06:00 | 10/09/2024 15:00 | 10/09/2024 00:00 | 10/09/2024 00:00 | 10/09/2024 12:00 | |
| Avg | 36.8 | 0.03 | 95.1 | 0 | 26.3 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.3 | 0.1 | 0.6 | 0 | 9.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/09/2024 00:00 | 46.77 | 0.15 | 96.36 | 0 | 39 | |
| 11/09/2024 01:00 | 48.18 | 0.24 | 95.41 | 0 | 39.9 | |
| 11/09/2024 02:00 | 48.26 | 0.21 | 95.62 | 0 | 40 | |
| 11/09/2024 03:00 | 48.28 | 0.31 | 95.73 | 0 | 39.7 | |
| 11/09/2024 04:00 | 48.36 | 0.32 | 95.83 | 0 | 39.3 | |
| 11/09/2024 05:00 | 48.52 | 0.21 | 95.91 | 0 | 39.1 | |
| 11/09/2024 06:00 | 48.61 | 0.24 | 96.1 | 0 | 39.1 | |
| 11/09/2024 07:00 | 48.2 | 0.18 | 95.96 | 0 | 39.2 | |
| 11/09/2024 08:00 | 34.95 | 0.4 | 95.14 | 0 | 38.2 | |
| 11/09/2024 09:00 | 34.51 | 0.5 | 94.97 | 0 | 27.2 | |
| 11/09/2024 10:00 | 34.57 | 0.52 | 95.33 | 0 | 27.1 | |
| 11/09/2024 11:00 | 34.55 | 0.55 | 95.43 | 0 | 27.1 | |
| 11/09/2024 12:00 | 23.31 | 0.56 | 92.45 | 0 | 49.3 | |
| 11/09/2024 13:00 | 34.48 | 0.36 | 94.4 | 0 | 28.5 | |
| 11/09/2024 14:00 | 34.61 | 0.33 | 94.97 | 0 | 27 | |
| 11/09/2024 15:00 | 34.63 | 0.33 | 94.58 | 0 | 26.4 | |
| 11/09/2024 16:00 | 34.57 | 0.19 | 94.57 | 0 | 26 | |
| 11/09/2024 17:00 | 34.48 | 0.18 | 94.49 | 0 | 25.8 | |
| 11/09/2024 18:00 | 34.44 | 0.14 | 94.55 | 0 | 25.7 | |
| 11/09/2024 19:00 | 34.25 | 0.25 | 94.37 | 0 | 25.5 | |
| 11/09/2024 20:00 | 34.3 | 0.28 | 94.43 | 0 | 25.4 | |
| 11/09/2024 21:00 | 34.45 | 0.23 | 94.99 | 0 | 25.5 | |
| 11/09/2024 22:00 | 34.47 | 0.25 | 94.98 | 0 | 25.6 | |
| 11/09/2024 23:00 | 31.47 | 0.36 | 94.59 | 0 | 31.7 | |
| 12/09/2024 00:00 | 2.2 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 2.2 | 0.14 | 92.45 | 0 | 25.4 | |
| MinDate | 12/09/2024 00:00 | 11/09/2024 18:00 | 11/09/2024 12:00 | 11/09/2024 00:00 | 11/09/2024 20:00 | |
| Maximum | 48.61 | 0.56 | 96.36 | 0 | 49.3 | |
| MaxDate | 11/09/2024 06:00 | 11/09/2024 12:00 | 11/09/2024 00:00 | 11/09/2024 00:00 | 11/09/2024 12:00 | |
| Avg | 37.02 | 0.3 | 95.05 | 0 | 32.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.2 | 0.1 | 0.8 | 0 | 7.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/09/2024 00:00 | 1.83 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/09/2024 08:00 | 20.84 | 0 | <Samp | <Samp | <Samp | GT12 S/D |
| 11/09/2024 09:00 | 34.45 | 0.05 | 95.49 | 0 | 24.9 | |
| 11/09/2024 10:00 | 34.51 | 0.09 | 95.6 | 0 | 24.8 | |
| 11/09/2024 11:00 | 34.47 | 0.14 | 95.73 | 0 | 24.8 | |
| 11/09/2024 12:00 | 23.17 | 0.09 | 92.64 | 0 | 48.5 | |
| 11/09/2024 13:00 | 34.32 | 0.02 | 94.67 | 0 | 26 | |
| 11/09/2024 14:00 | 34.53 | 0 | 95.16 | 0 | 24.3 | |
| 11/09/2024 15:00 | 34.56 | 0.23 | 95.01 | 0 | 23.8 | |
| 11/09/2024 16:00 | 34.51 | 0 | 95.04 | 0 | 23.4 | |
| 11/09/2024 17:00 | 34.42 | 0 | 94.88 | 0 | 23.2 | |
| 11/09/2024 18:00 | 34.38 | 0 | 94.93 | 0 | 23.2 | |
| 11/09/2024 19:00 | 34.19 | 0 | 94.78 | 0 | 23.1 | |
| 11/09/2024 20:00 | 34.24 | 0 | 94.83 | 0 | 23.1 | |
| 11/09/2024 21:00 | 34.38 | 0 | 95.23 | 0 | 23.2 | |
| 11/09/2024 22:00 | 34.4 | 0 | 95.2 | 0 | 23.2 | |
| 11/09/2024 23:00 | 31.49 | 0 | 94.73 | 0 | 29.2 | |
| 12/09/2024 00:00 | 46.59 | 0.01 | 96.64 | 0 | 40.1 | |
| Minimum | 0 | 0 | 92.64 | 0 | 23.1 | |
| MinDate | 11/09/2024 01:00 | 11/09/2024 00:00 | 11/09/2024 12:00 | 11/09/2024 09:00 | 11/09/2024 19:00 | |
| Maximum | 46.59 | 0.23 | 96.64 | 0 | 48.5 | |
| MaxDate | 12/09/2024 00:00 | 11/09/2024 15:00 | 12/09/2024 00:00 | 11/09/2024 09:00 | 11/09/2024 12:00 | |
| Avg | 22.85 | 0.03 | 95.04 | 0 | 26.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.1 | 0.8 | 0 | 7.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/09/2024 00:00 | 2.2 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 01:00 | 0 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 02:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 03:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 05:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 06:00 | 0 | 0.54 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 07:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/09/2024 08:00 | 20.85 | 0.66 | <Samp | <Samp | <Samp | GT11 S/D |
| 12/09/2024 09:00 | 34.51 | 0.54 | 95.6 | 0 | 28.9 | |
| 12/09/2024 10:00 | 34.53 | 0.61 | 95.45 | 0 | 29.2 | |
| 12/09/2024 11:00 | 34.49 | 0.74 | 94.67 | 0 | 28.5 | |
| 12/09/2024 12:00 | 22.54 | 0.58 | 91.51 | 0 | 50.4 | |
| 12/09/2024 13:00 | 31.54 | 0.45 | 93.33 | 0 | 35.1 | |
| 12/09/2024 14:00 | 34.44 | 0.28 | 94.56 | 0 | 27.7 | |
| 12/09/2024 15:00 | 34.21 | 0.16 | 94.1 | 0 | 27.5 | |
| 12/09/2024 16:00 | 34.31 | 0.19 | 94.07 | 0 | 27.4 | |
| 12/09/2024 17:00 | 34.22 | 0.2 | 94.06 | 0 | 27.3 | |
| 12/09/2024 18:00 | 34.23 | 0.37 | 94.07 | 0 | 27.1 | |
| 12/09/2024 19:00 | 34.08 | 0.42 | 94.26 | 0 | 27 | |
| 12/09/2024 20:00 | 34.07 | 0.46 | 94.06 | 0 | 26.9 | |
| 12/09/2024 21:00 | 34.26 | 0.59 | 94.53 | 0 | 27 | |
| 12/09/2024 22:00 | 34.32 | 0.62 | 94.77 | 0 | 26.9 | |
| 12/09/2024 23:00 | 31.43 | 0.52 | 94.38 | 0 | 32.8 | |
| 13/09/2024 00:00 | 47.1 | 0.35 | 96.07 | 0 | 38.9 | |
| Minimum | 0 | 0.05 | 91.51 | 0 | 26.9 | |
| MinDate | 12/09/2024 01:00 | 12/09/2024 01:00 | 12/09/2024 12:00 | 12/09/2024 09:00 | 12/09/2024 20:00 | |
| Maximum | 47.1 | 0.74 | 96.07 | 0 | 50.4 | |
| MaxDate | 13/09/2024 00:00 | 12/09/2024 11:00 | 13/09/2024 00:00 | 12/09/2024 09:00 | 12/09/2024 12:00 | |
| Avg | 22.69 | 0.37 | 94.34 | 0 | 30.5 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.3 | 0.2 | 1 | 0 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/09/2024 00:00 | 46.59 | 0.01 | 96.64 | 0 | 40.1 | |
| 12/09/2024 01:00 | 48.49 | 0 | 95.07 | 0 | 43.3 | |
| 12/09/2024 02:00 | 48.61 | 0.02 | 95.37 | 0 | 43.7 | |
| 12/09/2024 03:00 | 48.72 | 0.04 | 95.58 | 0 | 43.4 | |
| 12/09/2024 04:00 | 48.87 | 0 | 95.67 | 0 | 43.2 | |
| 12/09/2024 05:00 | 48.95 | 0 | 95.77 | 0 | 43 | |
| 12/09/2024 06:00 | 48.82 | 0 | 96.14 | 0 | 43.1 | |
| 12/09/2024 07:00 | 48.49 | 0.04 | 95.93 | 0 | 42.4 | |
| 12/09/2024 08:00 | 34.87 | 0.18 | 95.24 | 0 | 37.2 | |
| 12/09/2024 09:00 | 34.44 | 0.25 | 95.75 | 0 | 23.1 | |
| 12/09/2024 10:00 | 34.47 | 0.31 | 95.86 | 0 | 23.4 | |
| 12/09/2024 11:00 | 34.43 | 0.28 | 95.19 | 0 | 22.7 | |
| 12/09/2024 12:00 | 22.42 | 0.11 | 92.08 | 0 | 46.4 | |
| 12/09/2024 13:00 | 31.38 | 0.08 | 94 | 0 | 30.1 | |
| 12/09/2024 14:00 | 34.37 | 0.01 | 94.94 | 0 | 22.2 | |
| 12/09/2024 15:00 | 34.15 | 0.4 | 94.69 | 0 | 22 | |
| 12/09/2024 16:00 | 34.25 | 0.03 | 94.73 | 0 | 22 | |
| 12/09/2024 17:00 | 34.14 | 0.03 | 94.69 | 0 | 21.9 | |
| 12/09/2024 18:00 | 34.17 | 0.08 | 94.8 | 0 | 21.7 | |
| 12/09/2024 19:00 | 34.01 | 0.13 | 94.93 | 0 | 21.7 | |
| 12/09/2024 20:00 | 34.01 | 0.19 | 94.82 | 0 | 21.7 | |
| 12/09/2024 21:00 | 34.2 | 0.25 | 95.14 | 0 | 21.7 | |
| 12/09/2024 22:00 | 34.26 | 0.3 | 95.34 | 0 | 21.6 | |
| 12/09/2024 23:00 | 31.3 | 0.27 | 94.85 | 0 | 27.6 | |
| 13/09/2024 00:00 | 1.82 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 1.82 | 0 | 92.08 | 0 | 21.6 | |
| MinDate | 13/09/2024 00:00 | 12/09/2024 01:00 | 12/09/2024 12:00 | 12/09/2024 00:00 | 12/09/2024 22:00 | |
| Maximum | 48.95 | 0.4 | 96.64 | 0 | 46.4 | |
| MaxDate | 12/09/2024 05:00 | 12/09/2024 15:00 | 12/09/2024 00:00 | 12/09/2024 00:00 | 12/09/2024 12:00 | |
| Avg | 36.81 | 0.13 | 95.13 | 0 | 31.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.5 | 0.1 | 0.9 | 0 | 10.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/09/2024 00:00 | 47.1 | 0.35 | 96.07 | 0 | 38.9 | |
| 13/09/2024 01:00 | 48.64 | 0.35 | 95.3 | 0 | 39.5 | |
| 13/09/2024 02:00 | 48.66 | 0.3 | 95.48 | 0 | 39.2 | |
| 13/09/2024 03:00 | 48.65 | 0.3 | 95.53 | 0 | 39.1 | |
| 13/09/2024 04:00 | 48.66 | 0.26 | 95.58 | 0 | 39 | |
| 13/09/2024 05:00 | 48.67 | 0.27 | 95.56 | 0 | 38.9 | |
| 13/09/2024 06:00 | 48.72 | 0.39 | 95.85 | 0 | 38.8 | |
| 13/09/2024 07:00 | 48.56 | 0.16 | 95.89 | 0 | 38.5 | |
| 13/09/2024 08:00 | 34.74 | 0.31 | 95.41 | 0 | 38 | |
| 13/09/2024 09:00 | 34.44 | 0.36 | 95.12 | 0 | 26.4 | |
| 13/09/2024 10:00 | 34.42 | 0.43 | 95.25 | 0 | 26.4 | |
| 13/09/2024 11:00 | 34.4 | 0.39 | 95.52 | 0 | 26.5 | |
| 13/09/2024 12:00 | 22.13 | 0.56 | 93.02 | 0 | 50.7 | |
| 13/09/2024 13:00 | 34.58 | 0.44 | 94.95 | 0 | 28.8 | |
| 13/09/2024 14:00 | 34.5 | 0.34 | 95.1 | 0 | 26.9 | |
| 13/09/2024 15:00 | 34.37 | 0.25 | 94.57 | 0 | 26.9 | |
| 13/09/2024 16:00 | 34.37 | 0.21 | 94.56 | 0 | 26.9 | |
| 13/09/2024 17:00 | 34.19 | 0.22 | 94.4 | 0 | 26.8 | |
| 13/09/2024 18:00 | 34.15 | 0.25 | 94.33 | 0 | 26.7 | |
| 13/09/2024 19:00 | 34.03 | 0.27 | 94.2 | 0 | 26.6 | |
| 13/09/2024 20:00 | 34.01 | 0.3 | 93.75 | 0 | 26 | |
| 13/09/2024 21:00 | 34.27 | 0.24 | 94.1 | 0 | 26.1 | |
| 13/09/2024 22:00 | 37.3 | 0.13 | 95.76 | 0 | 28 | |
| 13/09/2024 23:00 | 35.27 | 0.27 | 96.13 | 0 | 32.2 | |
| 14/09/2024 00:00 | 28.41 | 0.44 | 92.78 | 0 | 45.6 | |
| Minimum | 22.13 | 0.13 | 92.78 | 0 | 26 | |
| MinDate | 13/09/2024 12:00 | 13/09/2024 22:00 | 14/09/2024 00:00 | 13/09/2024 00:00 | 13/09/2024 20:00 | |
| Maximum | 48.72 | 0.56 | 96.13 | 0 | 50.7 | |
| MaxDate | 13/09/2024 06:00 | 13/09/2024 12:00 | 13/09/2024 23:00 | 13/09/2024 00:00 | 13/09/2024 12:00 | |
| Avg | 38.29 | 0.31 | 94.97 | 0 | 33.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.6 | 0.1 | 0.9 | 0 | 7.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/09/2024 00:00 | 1.82 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 01:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 02:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 03:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 04:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 05:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 06:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 07:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/09/2024 08:00 | 20.99 | 0.28 | <Samp | <Samp | <Samp | GT12 SD |
| 13/09/2024 09:00 | 34.37 | 0.39 | 95.59 | 0 | 24 | |
| 13/09/2024 10:00 | 34.35 | 0.41 | 95.54 | 0 | 23.9 | |
| 13/09/2024 11:00 | 34.34 | 0.43 | 95.8 | 0 | 24 | |
| 13/09/2024 12:00 | 22.07 | 0.47 | 93.23 | 0 | 48.8 | |
| 13/09/2024 13:00 | 34.52 | 0.46 | 95.21 | 0 | 25.9 | |
| 13/09/2024 14:00 | 34.43 | 0.4 | 95.28 | 0 | 24 | |
| 13/09/2024 15:00 | 34.31 | 0.35 | 94.9 | 0 | 24 | |
| 13/09/2024 16:00 | 34.3 | 0.03 | 94.91 | 0 | 24 | |
| 13/09/2024 17:00 | 34.12 | 0.03 | 94.77 | 0 | 23.9 | |
| 13/09/2024 18:00 | 34.08 | 0.04 | 94.68 | 0 | 23.7 | |
| 13/09/2024 19:00 | 33.96 | 0.03 | 94.56 | 0 | 23.7 | |
| 13/09/2024 20:00 | 33.94 | 0.01 | 94.18 | 0 | 23.2 | |
| 13/09/2024 21:00 | 34.2 | 0 | 94.43 | 0 | 23.4 | |
| 13/09/2024 22:00 | 37.22 | 0 | 96.1 | 0 | 25.4 | |
| 13/09/2024 23:00 | 35.2 | 0 | 96.3 | 0 | 29.5 | |
| 14/09/2024 00:00 | 28.35 | 0 | 92.99 | 0 | 40.9 | |
| Minimum | 0 | 0 | 92.99 | 0 | 23.2 | |
| MinDate | 13/09/2024 01:00 | 13/09/2024 21:00 | 14/09/2024 00:00 | 13/09/2024 09:00 | 13/09/2024 20:00 | |
| Maximum | 37.22 | 0.47 | 96.3 | 0 | 48.8 | |
| MaxDate | 13/09/2024 22:00 | 13/09/2024 12:00 | 13/09/2024 23:00 | 13/09/2024 09:00 | 13/09/2024 12:00 | |
| Avg | 22.26 | 0.19 | 94.9 | 0 | 27 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 15.9 | 0.2 | 0.9 | 0 | 7.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/09/2024 00:00 | 28.41 | 0.44 | 92.78 | 0 | 45.6 | |
| 14/09/2024 01:00 | 28.74 | 0.44 | 92.57 | 0 | 44.5 | |
| 14/09/2024 02:00 | 28.73 | 0.6 | 92.01 | 0 | 46 | |
| 14/09/2024 03:00 | 28.53 | 2.76 | 91.42 | 0 | 47.5 | |
| 14/09/2024 04:00 | 28.33 | 0.42 | 91.98 | 0 | 47.3 | |
| 14/09/2024 05:00 | 28.35 | 0.18 | 92.32 | 0 | 46.9 | |
| 14/09/2024 06:00 | 28.23 | 0.61 | 92.37 | 0 | 46.3 | |
| 14/09/2024 07:00 | 28.11 | 0.57 | 92.65 | 0 | 45.8 | |
| 14/09/2024 08:00 | 31.74 | 0.46 | 93.79 | 0 | 41.9 | |
| 14/09/2024 09:00 | 42.2 | 0.42 | 100.09 | 0 | 28.9 | |
| 14/09/2024 10:00 | 42.29 | 0.44 | 100.75 | 0 | 29.3 | |
| 14/09/2024 11:00 | 42.23 | 0.45 | 100.84 | 0 | 29.4 | |
| 14/09/2024 12:00 | 28.24 | 0.58 | 94.81 | 0 | 43.2 | |
| 14/09/2024 13:00 | 42.31 | 0.42 | 99.04 | 0 | 30.7 | |
| 14/09/2024 14:00 | 42.25 | 0.37 | 100.64 | 0 | 29.5 | |
| 14/09/2024 15:00 | 42.2 | 0.35 | 100.27 | 0 | 29.1 | |
| 14/09/2024 16:00 | 42.28 | 0.34 | 100.08 | 0 | 29 | |
| 14/09/2024 17:00 | 42.24 | 0.32 | 99.99 | 0 | 29.3 | |
| 14/09/2024 18:00 | 42.17 | 0.35 | 99.71 | 0 | 29 | |
| 14/09/2024 19:00 | 41.98 | 0.24 | 99.42 | 0 | 28.7 | |
| 14/09/2024 20:00 | 42.03 | 0.09 | 99.36 | 0 | 28.3 | |
| 14/09/2024 21:00 | 42.16 | 0.17 | 99.8 | 0 | 28.2 | |
| 14/09/2024 22:00 | 42.11 | 2.2 | 98.01 | 0 | 28.8 | |
| 14/09/2024 23:00 | 27.53 | 5.03 | 94.72 | 0 | 45.8 | |
| 15/09/2024 00:00 | 0.08 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0.08 | 0.09 | 91.42 | 0 | 28.2 | |
| MinDate | 15/09/2024 00:00 | 14/09/2024 20:00 | 14/09/2024 03:00 | 14/09/2024 00:00 | 14/09/2024 21:00 | |
| Maximum | 42.31 | 5.03 | 100.84 | 0 | 47.5 | |
| MaxDate | 14/09/2024 13:00 | 14/09/2024 23:00 | 14/09/2024 11:00 | 14/09/2024 00:00 | 14/09/2024 03:00 | |
| Avg | 34.54 | 0.74 | 96.64 | 0 | 36.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.9 | 1.1 | 3.7 | 0 | 8.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/09/2024 00:00 | 28.35 | 0 | 92.99 | 0 | 40.9 | |
| 14/09/2024 01:00 | 28.68 | 0 | 92.8 | 0 | 40.1 | |
| 14/09/2024 02:00 | 28.67 | 0 | 92.17 | 0 | 41.3 | |
| 14/09/2024 03:00 | 28.47 | 0 | 91.5 | 0 | 42.5 | |
| 14/09/2024 04:00 | 28.27 | 0 | 92.12 | 0 | 42.1 | |
| 14/09/2024 05:00 | 28.28 | 0 | 92.43 | 0 | 41.6 | |
| 14/09/2024 06:00 | 28.18 | 0 | 92.39 | 0 | 41 | |
| 14/09/2024 07:00 | 28.04 | 0 | 92.63 | 0 | 40.6 | |
| 14/09/2024 08:00 | 31.68 | 0.04 | 93.93 | 0 | 38 | |
| 14/09/2024 09:00 | 42.13 | 0.08 | 99.94 | 0 | 27.5 | |
| 14/09/2024 10:00 | 42.22 | 0.12 | 100.6 | 0 | 28.1 | |
| 14/09/2024 11:00 | 42.16 | 0.17 | 100.66 | 0 | 28.5 | |
| 14/09/2024 12:00 | 28.22 | 0.18 | 94.87 | 0 | 39.4 | |
| 14/09/2024 13:00 | 42.23 | 0.16 | 99.34 | 0 | 30.3 | |
| 14/09/2024 14:00 | 42.18 | 0.1 | 100.45 | 0 | 28.6 | |
| 14/09/2024 15:00 | 42.12 | 0.31 | 100.27 | 0 | 28.1 | |
| 14/09/2024 16:00 | 42.2 | 0.05 | 100.26 | 0 | 28 | |
| 14/09/2024 17:00 | 42.17 | 0.03 | 100.21 | 0 | 28.3 | |
| 14/09/2024 18:00 | 42.09 | 0.02 | 99.88 | 0 | 27.5 | |
| 14/09/2024 19:00 | 41.9 | 0 | 99.61 | 0 | 26.8 | |
| 14/09/2024 20:00 | 41.95 | 0 | 99.49 | 0 | 26.5 | |
| 14/09/2024 21:00 | 42.08 | 0 | 99.78 | 0 | 26.4 | |
| 14/09/2024 22:00 | 42.05 | 0 | 97.01 | 0 | 26.6 | |
| 14/09/2024 23:00 | 40.96 | 0 | 96.44 | 0 | 32.5 | |
| 15/09/2024 00:00 | 49.08 | 0 | 95.85 | 0 | 41.6 | |
| Minimum | 28.04 | 0 | 91.5 | 0 | 26.4 | |
| MinDate | 14/09/2024 07:00 | 14/09/2024 00:00 | 14/09/2024 03:00 | 14/09/2024 00:00 | 14/09/2024 21:00 | |
| Maximum | 49.08 | 0.31 | 100.66 | 0 | 42.5 | |
| MaxDate | 15/09/2024 00:00 | 14/09/2024 15:00 | 14/09/2024 11:00 | 14/09/2024 00:00 | 14/09/2024 03:00 | |
| Avg | 36.97 | 0.05 | 96.7 | 0 | 33.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.1 | 0.1 | 3.5 | 0 | 6.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/09/2024 00:00 | 0.08 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 01:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 02:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 03:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 04:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 05:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 06:00 | 0 | 0.64 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 07:00 | 0 | 0.46 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 08:00 | 0 | 0.58 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 09:00 | 0 | 0.71 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 10:00 | 0 | 0.77 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 11:00 | 0 | 2.25 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 12:00 | 0 | 0.69 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 13:00 | 0 | 0.53 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 14:00 | 0 | 0.5 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 15:00 | 0 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 16:00 | 0 | 0.42 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 17:00 | 0 | 0.4 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 18:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 19:00 | 0 | 0.92 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 20:00 | 0 | 0.4 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 21:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 22:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/09/2024 23:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 00:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.17 | --- | --- | --- | |
| MinDate | 15/09/2024 01:00 | 15/09/2024 21:00 | 15/09/2024 00:00 | 15/09/2024 00:00 | 15/09/2024 00:00 | |
| Maximum | 0.08 | 2.25 | --- | --- | --- | |
| MaxDate | 15/09/2024 00:00 | 15/09/2024 11:00 | 15/09/2024 00:00 | 15/09/2024 00:00 | 15/09/2024 00:00 | |
| Avg | 0 | 0.51 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.4 | --- | --- | --- | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/09/2024 00:00 | 49.08 | 0 | 95.85 | 0 | 41.6 | |
| 15/09/2024 01:00 | 48.95 | 0 | 95.34 | 0 | 41.8 | |
| 15/09/2024 02:00 | 48.95 | 0 | 95.85 | 0 | 41.7 | |
| 15/09/2024 03:00 | 48.97 | 0 | 96.08 | 0 | 41.3 | |
| 15/09/2024 04:00 | 49 | 0 | 96.11 | 0 | 41.1 | |
| 15/09/2024 05:00 | 48.97 | 0 | 96.11 | 0 | 40.9 | |
| 15/09/2024 06:00 | 48.96 | 0 | 96.13 | 0 | 40.9 | |
| 15/09/2024 07:00 | 48.73 | 0 | 96.16 | 0 | 40 | |
| 15/09/2024 08:00 | 47.9 | 0.05 | 96.04 | 0 | 39.4 | |
| 15/09/2024 09:00 | 47.29 | 0.17 | 95.61 | 0 | 39.8 | |
| 15/09/2024 10:00 | 47.11 | 0.19 | 95.58 | 0 | 39.7 | |
| 15/09/2024 11:00 | 46.96 | 0.17 | 95.53 | 0 | 39.6 | |
| 15/09/2024 12:00 | 46.79 | 0.14 | 95.65 | 0 | 39.2 | |
| 15/09/2024 13:00 | 46.76 | 0.1 | 95.27 | 0 | 39.1 | |
| 15/09/2024 14:00 | 46.54 | 0.07 | 95.25 | 0 | 39 | |
| 15/09/2024 15:00 | 46.52 | 0.26 | 95.09 | 0 | 38.7 | |
| 15/09/2024 16:00 | 46.62 | 0.06 | 95.05 | 0 | 38.4 | |
| 15/09/2024 17:00 | 46.93 | 0.03 | 95.2 | 0 | 38 | |
| 15/09/2024 18:00 | 47.49 | 0 | 95.22 | 0 | 38 | |
| 15/09/2024 19:00 | 48.97 | 0 | 95.02 | 0 | 39.4 | |
| 15/09/2024 20:00 | 49.06 | 0 | 95.57 | 0 | 39.8 | |
| 15/09/2024 21:00 | 48.99 | 0 | 95.91 | 0 | 40.1 | |
| 15/09/2024 22:00 | 48.93 | 0 | 95.93 | 0 | 39.6 | |
| 15/09/2024 23:00 | 48.65 | 0 | 95.7 | 0 | 39.1 | |
| 16/09/2024 00:00 | 48.4 | 0 | 95.76 | 0 | 38.7 | |
| Minimum | 46.52 | 0 | 95.02 | 0 | 38 | |
| MinDate | 15/09/2024 15:00 | 15/09/2024 00:00 | 15/09/2024 19:00 | 15/09/2024 00:00 | 15/09/2024 17:00 | |
| Maximum | 49.08 | 0.26 | 96.16 | 0 | 41.8 | |
| MaxDate | 15/09/2024 00:00 | 15/09/2024 15:00 | 15/09/2024 07:00 | 15/09/2024 00:00 | 15/09/2024 01:00 | |
| Avg | 48.06 | 0.05 | 95.64 | 0 | 39.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 1 | 0.1 | 0.4 | 0 | 1.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/09/2024 00:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 01:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 02:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 03:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 04:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 05:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 06:00 | 0 | 0.52 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 07:00 | 0 | 0.14 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 08:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 09:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 10:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 11:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 12:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 13:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 14:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 15:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 16:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 17:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 18:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 19:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 20:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 21:00 | 0 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 22:00 | 0 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/09/2024 23:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 00:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0.09 | --- | --- | --- | |
| MinDate | 16/09/2024 00:00 | 16/09/2024 20:00 | 16/09/2024 00:00 | 16/09/2024 00:00 | 16/09/2024 00:00 | |
| Maximum | 0 | 0.52 | --- | --- | --- | |
| MaxDate | 16/09/2024 00:00 | 16/09/2024 06:00 | 16/09/2024 00:00 | 16/09/2024 00:00 | 16/09/2024 00:00 | |
| Avg | 0 | 0.27 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/09/2024 00:00 | 48.4 | 0 | 95.76 | 0 | 38.7 | |
| 16/09/2024 01:00 | 48.33 | 0 | 95.8 | 0 | 38.2 | |
| 16/09/2024 02:00 | 48.27 | 0 | 95.84 | 0 | 37.6 | |
| 16/09/2024 03:00 | 48.4 | 0 | 95.95 | 0 | 37.7 | |
| 16/09/2024 04:00 | 48.36 | 0 | 95.93 | 0 | 37.6 | |
| 16/09/2024 05:00 | 48.37 | 0 | 95.91 | 0 | 38 | |
| 16/09/2024 06:00 | 48.32 | 0 | 95.79 | 0 | 37.9 | |
| 16/09/2024 07:00 | 47.97 | 0 | 95.82 | 0 | 37.4 | |
| 16/09/2024 08:00 | 47.61 | 0.07 | 95.62 | 0 | 37.8 | |
| 16/09/2024 09:00 | 47.18 | 0.09 | 95.42 | 0 | 37.9 | |
| 16/09/2024 10:00 | 47.26 | 0.08 | 95.41 | 0 | 37.4 | |
| 16/09/2024 11:00 | 47 | 0.07 | 95.76 | 0 | 37.3 | |
| 16/09/2024 12:00 | 46.71 | 0.09 | 95.53 | 0 | 37 | |
| 16/09/2024 13:00 | 46.8 | 0.09 | 95.36 | 0 | 36.9 | |
| 16/09/2024 14:00 | 46.61 | 0.07 | 95.26 | 0 | 36.7 | |
| 16/09/2024 15:00 | 46.48 | 0.41 | 95.11 | 0 | 36.1 | |
| 16/09/2024 16:00 | 46.45 | 0.07 | 95.07 | 0 | 35.9 | |
| 16/09/2024 17:00 | 46.66 | 0.07 | 95.15 | 0 | 35.8 | |
| 16/09/2024 18:00 | 47.02 | 0.07 | 95.38 | 0 | 35.9 | |
| 16/09/2024 19:00 | 47.47 | 0.01 | 95.24 | 0 | 35.7 | |
| 16/09/2024 20:00 | 47.97 | 0 | 95.27 | 0 | 36.1 | |
| 16/09/2024 21:00 | 48.91 | 0 | 95.47 | 0 | 37.2 | |
| 16/09/2024 22:00 | 48.99 | 0 | 95.64 | 0 | 36.9 | |
| 16/09/2024 23:00 | 48.87 | 0 | 95.66 | 0 | 37 | |
| 17/09/2024 00:00 | 48.76 | 0 | 95.6 | 0 | 36.7 | |
| Minimum | 46.45 | 0 | 95.07 | 0 | 35.7 | |
| MinDate | 16/09/2024 16:00 | 16/09/2024 00:00 | 16/09/2024 16:00 | 16/09/2024 00:00 | 16/09/2024 19:00 | |
| Maximum | 48.99 | 0.41 | 95.95 | 0 | 38.7 | |
| MaxDate | 16/09/2024 22:00 | 16/09/2024 15:00 | 16/09/2024 03:00 | 16/09/2024 00:00 | 16/09/2024 00:00 | |
| Avg | 47.73 | 0.05 | 95.55 | 0 | 37.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 0.8 | 0.1 | 0.3 | 0 | 0.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/09/2024 00:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 01:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 02:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 03:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 04:00 | 0 | 0.29 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 05:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 06:00 | 0 | 0.58 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 07:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 08:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 09:00 | 0 | 0.27 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 10:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 11:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 12:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 13:00 | 0 | 0.39 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 14:00 | 0 | 0.36 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 15:00 | 0 | 0.35 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 16:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 17:00 | 2.89 | 6.84 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 17/09/2024 18:00 | 32.72 | 0.67 | 94.69 | 0 | 41.6 | |
| 17/09/2024 19:00 | 35.56 | 0.74 | 96.54 | 0 | 28.4 | |
| 17/09/2024 20:00 | 34.01 | 0.66 | 94.75 | 0 | 26.6 | |
| 17/09/2024 21:00 | 34.18 | 0.65 | 95.12 | 0 | 26.6 | |
| 17/09/2024 22:00 | 34.19 | 0.72 | 95.36 | 0 | 26.5 | |
| 17/09/2024 23:00 | 31.45 | 0.73 | 94.91 | 0 | 31.5 | |
| 18/09/2024 00:00 | 46.66 | 0.57 | 96.71 | 0 | 36.4 | |
| Minimum | 0 | 0.15 | 94.69 | 0 | 26.5 | |
| MinDate | 17/09/2024 00:00 | 17/09/2024 02:00 | 17/09/2024 18:00 | 17/09/2024 18:00 | 17/09/2024 22:00 | |
| Maximum | 46.66 | 6.84 | 96.71 | 0 | 41.6 | |
| MaxDate | 18/09/2024 00:00 | 17/09/2024 17:00 | 18/09/2024 00:00 | 17/09/2024 18:00 | 17/09/2024 18:00 | |
| Avg | 10.07 | 0.67 | 95.44 | 0 | 31.1 | |
| Num | 25 | 25 | 7 | 7 | 7 | |
| Data[%] | 100 | 100 | 28 | 28 | 28 | |
| STD | 16.4 | 1.3 | 0.8 | 0 | 5.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/09/2024 00:00 | 48.76 | 0 | 95.6 | 0 | 36.7 | |
| 17/09/2024 01:00 | 48.67 | 0 | 95.68 | 0 | 36.5 | |
| 17/09/2024 02:00 | 48.48 | 0 | 95.66 | 0 | 36.2 | |
| 17/09/2024 03:00 | 48.42 | 0.01 | 95.64 | 0 | 35.8 | |
| 17/09/2024 04:00 | 48.34 | 0 | 95.61 | 0 | 35.4 | |
| 17/09/2024 05:00 | 48.38 | 0 | 95.63 | 0 | 35.2 | |
| 17/09/2024 06:00 | 48.19 | 0 | 95.56 | 0 | 35.2 | |
| 17/09/2024 07:00 | 47.98 | 0.01 | 95.38 | 0 | 35 | |
| 17/09/2024 08:00 | 47.7 | 0.07 | 95.21 | 0 | 35.2 | |
| 17/09/2024 09:00 | 47.47 | 0.1 | 94.9 | 0 | 35.4 | |
| 17/09/2024 10:00 | 47.29 | 0.1 | 94.87 | 0 | 34.9 | |
| 17/09/2024 11:00 | 47.1 | 0.11 | 95.3 | 0 | 34.6 | |
| 17/09/2024 12:00 | 46.86 | 0.19 | 95.51 | 0 | 34 | |
| 17/09/2024 13:00 | 46.8 | 0.19 | 95.13 | 0 | 33.8 | |
| 17/09/2024 14:00 | 46.8 | 0.13 | 95.34 | 0 | 33.6 | |
| 17/09/2024 15:00 | 46.8 | 0.34 | 95.44 | 0 | 33.4 | |
| 17/09/2024 16:00 | 46.93 | 0.05 | 95.62 | 0 | 33.4 | |
| 17/09/2024 17:00 | 45.44 | 0.02 | 95.4 | 0 | 31.5 | |
| 17/09/2024 18:00 | 31.62 | 0 | 93.26 | 0 | 30.6 | |
| 17/09/2024 19:00 | 34.76 | 0 | 94.72 | 0 | 18.7 | |
| 17/09/2024 20:00 | 33.95 | 0 | 93.85 | 0 | 18.2 | |
| 17/09/2024 21:00 | 34.11 | 0 | 94.09 | 0 | 18.3 | |
| 17/09/2024 22:00 | 34.12 | 0 | 94.28 | 0 | 18.2 | |
| 17/09/2024 23:00 | 31.26 | 0 | 93.89 | 0 | 24.1 | |
| 18/09/2024 00:00 | 1.62 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 1.62 | 0 | 93.26 | 0 | 18.2 | |
| MinDate | 18/09/2024 00:00 | 17/09/2024 00:00 | 17/09/2024 18:00 | 17/09/2024 00:00 | 17/09/2024 20:00 | |
| Maximum | 48.76 | 0.34 | 95.68 | 0 | 36.7 | |
| MaxDate | 17/09/2024 00:00 | 17/09/2024 15:00 | 17/09/2024 01:00 | 17/09/2024 00:00 | 17/09/2024 00:00 | |
| Avg | 42.31 | 0.05 | 95.07 | 0 | 31.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.5 | 0.1 | 0.7 | 0 | 6.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/09/2024 00:00 | 46.66 | 0.57 | 96.71 | 0 | 36.4 | |
| 18/09/2024 01:00 | 48.5 | 1 | 95.79 | 0 | 37.5 | |
| 18/09/2024 02:00 | 48.64 | 1.06 | 96.38 | 0 | 37.1 | |
| 18/09/2024 03:00 | 48.9 | 1.26 | 96.31 | 0 | 37.6 | |
| 18/09/2024 04:00 | 48.96 | 1.4 | 96.57 | 0 | 37.6 | |
| 18/09/2024 05:00 | 48.85 | 1.52 | 96.62 | 0 | 37.3 | |
| 18/09/2024 06:00 | 48.73 | 1.34 | 96.84 | 0 | 36.9 | |
| 18/09/2024 07:00 | 48.59 | 1.22 | 96.82 | 0 | 36.5 | |
| 18/09/2024 08:00 | 34.97 | 1.34 | 96.33 | 0 | 36.6 | |
| 18/09/2024 09:00 | 34.54 | 0.77 | 95.72 | 0 | 25.3 | |
| 18/09/2024 10:00 | 34.55 | 0.69 | 95.99 | 0 | 25.4 | |
| 18/09/2024 11:00 | 34.46 | 0.63 | 95.99 | 0 | 25.6 | |
| 18/09/2024 12:00 | 21.92 | 0.72 | 93.16 | 0 | 48.8 | |
| 18/09/2024 13:00 | 34.66 | 0.62 | 95.62 | 0 | 26.8 | |
| 18/09/2024 14:00 | 34.57 | 0.61 | 96.05 | 0 | 25.4 | |
| 18/09/2024 15:00 | 34.48 | 0.59 | 95.73 | 0 | 25 | |
| 18/09/2024 16:00 | 34.39 | 0.52 | 95.33 | 0 | 24.7 | |
| 18/09/2024 17:00 | 34.31 | 0.48 | 95.24 | 0 | 24.4 | |
| 18/09/2024 18:00 | 34.29 | 0.39 | 95.37 | 0 | 24.3 | |
| 18/09/2024 19:00 | 34.13 | 0.52 | 95.29 | 0 | 24.3 | |
| 18/09/2024 20:00 | 34.1 | 0.66 | 95.2 | 0 | 24.2 | |
| 18/09/2024 21:00 | 34.32 | 0.71 | 95.59 | 0 | 24.1 | |
| 18/09/2024 22:00 | 34.35 | 0.78 | 95.63 | 0 | 24.1 | |
| 18/09/2024 23:00 | 31.44 | 1.07 | 94.95 | 0 | 30 | |
| 19/09/2024 00:00 | 1.99 | 0.98 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 1.99 | 0.39 | 93.16 | 0 | 24.1 | |
| MinDate | 19/09/2024 00:00 | 18/09/2024 18:00 | 18/09/2024 12:00 | 18/09/2024 00:00 | 18/09/2024 21:00 | |
| Maximum | 48.96 | 1.52 | 96.84 | 0 | 48.8 | |
| MaxDate | 18/09/2024 04:00 | 18/09/2024 05:00 | 18/09/2024 06:00 | 18/09/2024 00:00 | 18/09/2024 12:00 | |
| Avq | 37.01 | 0.86 | 95.8 | 0 | 30.7 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.5 | 0.3 | 0.8 | 0 | 7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/09/2024 00:00 | 1.62 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/09/2024 08:00 | 20.62 | 7.9 | <Samp | <Samp | <Samp | GT12 S/D |
| 18/09/2024 09:00 | 34.47 | 0.01 | 94.59 | 0 | 23.8 | |
| 18/09/2024 10:00 | 34.47 | 0.05 | 94.59 | 0 | 23.8 | |
| 18/09/2024 11:00 | 34.4 | 0.07 | 94.48 | 0 | 23.9 | |
| 18/09/2024 12:00 | 21.88 | 0.09 | 91.89 | 0 | 48.7 | |
| 18/09/2024 13:00 | 34.57 | 0.09 | 94.26 | 0 | 25 | |
| 18/09/2024 14:00 | 34.5 | 0.07 | 94.62 | 0 | 23.6 | |
| 18/09/2024 15:00 | 34.42 | 0.26 | 94.4 | 0 | 23.1 | |
| 18/09/2024 16:00 | 34.32 | 0.01 | 94.02 | 0 | 22.9 | |
| 18/09/2024 17:00 | 34.24 | 0 | 94.01 | 0 | 22.6 | |
| 18/09/2024 18:00 | 34.23 | 0 | 94.21 | 0 | 22.5 | |
| 18/09/2024 19:00 | 34.07 | 0.01 | 94.11 | 0 | 22.5 | |
| 18/09/2024 20:00 | 34.04 | 0.03 | 93.94 | 0 | 22.4 | |
| 18/09/2024 21:00 | 34.25 | 0.02 | 94.23 | 0 | 22.4 | |
| 18/09/2024 22:00 | 34.28 | 0 | 94.34 | 0 | 22.4 | |
| 18/09/2024 23:00 | 31.51 | 0 | 93.63 | 0 | 28.4 | |
| 19/09/2024 00:00 | 47.13 | 0 | 95.68 | 0 | 39.6 | |
| Minimum | 0 | 0 | 91.89 | 0 | 22.4 | |
| MinDate | 18/09/2024 01:00 | 18/09/2024 00:00 | 18/09/2024 12:00 | 18/09/2024 09:00 | 18/09/2024 20:00 | |
| Maximum | 47.13 | 7.9 | 95.68 | 0 | 48.7 | |
| MaxDate | 19/09/2024 00:00 | 18/09/2024 08:00 | 19/09/2024 00:00 | 18/09/2024 09:00 | 18/09/2024 12:00 | |
| Avq | 22.76 | 0.34 | 94.19 | 0 | 26.1 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 1.6 | 0.8 | 0 | 7.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/09/2024 00:00 | 1.99 | 0.98 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 01:00 | 0 | 1.14 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 02:00 | 0 | 1.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 03:00 | 0 | 1.27 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 04:00 | 0 | 1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 05:00 | 0 | 0.93 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 06:00 | 0 | 0.6 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 07:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/09/2024 08:00 | 20.56 | 6.49 | <Samp | <Samp | <Samp | GT11 S/D |
| 19/09/2024 09:00 | 34.43 | 0.7 | 96.18 | 0 | 26.3 | |
| 19/09/2024 10:00 | 34.56 | 0.76 | 96.29 | 0 | 26.2 | |
| 19/09/2024 11:00 | 34.48 | 0.72 | 96.51 | 0 | 26.1 | |
| 19/09/2024 12:00 | 22.62 | 0.81 | 93.3 | 0 | 49.5 | |
| 19/09/2024 13:00 | 34.54 | 0.61 | 95.7 | 0 | 28 | |
| 19/09/2024 14:00 | 34.67 | 0.53 | 96.47 | 0 | 26.4 | |
| 19/09/2024 15:00 | 34.2 | 0.56 | 95.81 | 0 | 25.6 | |
| 19/09/2024 16:00 | 34.5 | 0.55 | 95.79 | 0 | 25.4 | |
| 19/09/2024 17:00 | 34.42 | 0.52 | 95.59 | 0 | 25.7 | |
| 19/09/2024 18:00 | 34.41 | 0.58 | 95.33 | 0 | 25.1 | |
| 19/09/2024 19:00 | 34.18 | 0.63 | 95.18 | 0 | 24.9 | |
| 19/09/2024 20:00 | 34.22 | 0.55 | 95.26 | 0 | 24.8 | |
| 19/09/2024 21:00 | 34.44 | 0.57 | 95.56 | 0 | 24.6 | |
| 19/09/2024 22:00 | 34.45 | 0.53 | 95.72 | 0 | 24.3 | |
| 19/09/2024 23:00 | 31.61 | 0.44 | 95.31 | 0 | 29.9 | |
| 20/09/2024 00:00 | 46.6 | 0.32 | 96.81 | 0 | 34.7 | |
| Minimum | 0 | 0.32 | 93.3 | 0 | 24.3 | |
| MinDate | 19/09/2024 01:00 | 20/09/2024 00:00 | 19/09/2024 12:00 | 19/09/2024 09:00 | 19/09/2024 22:00 | |
| Maximum | 46.6 | 6.49 | 96.81 | 0 | 49.5 | |
| MaxDate | 20/09/2024 00:00 | 19/09/2024 08:00 | 20/09/2024 00:00 | 19/09/2024 09:00 | 19/09/2024 12:00 | |
| Avg | 22.84 | 0.93 | 95.68 | 0 | 28 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 1.2 | 0.8 | 0 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/09/2024 00:00 | 47.13 | 0 | 95.68 | 0 | 39.6 | |
| 19/09/2024 01:00 | 48.7 | 0.01 | 94.78 | 0 | 42.1 | |
| 19/09/2024 02:00 | 48.64 | 0.03 | 95.13 | 0 | 41.8 | |
| 19/09/2024 03:00 | 48.62 | 0.01 | 95.21 | 0 | 41.5 | |
| 19/09/2024 04:00 | 48.66 | 0 | 95.25 | 0 | 41.5 | |
| 19/09/2024 05:00 | 48.66 | 0 | 95.35 | 0 | 41.6 | |
| 19/09/2024 06:00 | 48.6 | 0 | 95.59 | 0 | 41.6 | |
| 19/09/2024 07:00 | 48.47 | 0.01 | 95.48 | 0 | 41.5 | |
| 19/09/2024 08:00 | 35.07 | 0.13 | 95.01 | 0 | 36.1 | |
| 19/09/2024 09:00 | 34.37 | 0.22 | 94.48 | 0 | 22.3 | |
| 19/09/2024 10:00 | 34.49 | 0.25 | 94.58 | 0 | 22.2 | |
| 19/09/2024 11:00 | 34.4 | 0.25 | 94.76 | 0 | 22.1 | |
| 19/09/2024 12:00 | 22.51 | 0.23 | 91.92 | 0 | 47.3 | |
| 19/09/2024 13:00 | 34.42 | 0.19 | 94.14 | 0 | 24 | |
| 19/09/2024 14:00 | 34.61 | 0.15 | 94.82 | 0 | 22.3 | |
| 19/09/2024 15:00 | 34.14 | 0.24 | 94.4 | 0 | 21.5 | |
| 19/09/2024 16:00 | 34.44 | 0.03 | 94.55 | 0 | 21.4 | |
| 19/09/2024 17:00 | 34.36 | 0 | 94.29 | 0 | 21.6 | |
| 19/09/2024 18:00 | 34.35 | 0 | 94.03 | 0 | 21.3 | |
| 19/09/2024 19:00 | 34.12 | 0 | 93.97 | 0 | 21.1 | |
| 19/09/2024 20:00 | 34.16 | 0 | 94 | 0 | 21.2 | |
| 19/09/2024 21:00 | 34.38 | 0 | 94.18 | 0 | 21 | |
| 19/09/2024 22:00 | 34.39 | 0 | 94.2 | 0 | 20.8 | |
| 19/09/2024 23:00 | 31.4 | 0 | 93.78 | 0 | 26.9 | |
| 20/09/2024 00:00 | 1.9 | 0 | ShutDown | ShutDown | ShutDown | |
| Minimum | 1.9 | 0 | 91.92 | 0 | 20.8 | |
| MinDate | 20/09/2024 00:00 | 19/09/2024 00:00 | 19/09/2024 12:00 | 19/09/2024 00:00 | 19/09/2024 22:00 | |
| Maximum | 48.7 | 0.25 | 95.68 | 0 | 47.3 | |
| MaxDate | 19/09/2024 01:00 | 19/09/2024 10:00 | 19/09/2024 00:00 | 19/09/2024 00:00 | 19/09/2024 12:00 | |
| Avg | 37 | 0.07 | 94.57 | 0 | 30.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.4 | 0.1 | 0.8 | 0 | 10 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/09/2024 00:00 | 46.6 | 0.32 | 96.81 | 0 | 34.7 | |
| 20/09/2024 01:00 | 47.92 | 0.42 | 96.16 | 0 | 35.3 | |
| 20/09/2024 02:00 | 47.96 | 0.5 | 96.53 | 0 | 35.1 | |
| 20/09/2024 03:00 | 48.01 | 0.64 | 96.61 | 0 | 35 | |
| 20/09/2024 04:00 | 48.06 | 0.62 | 96.55 | 0 | 35 | |
| 20/09/2024 05:00 | 48.07 | 0.86 | 96.55 | 0 | 35 | |
| 20/09/2024 06:00 | 48.09 | 0.4 | 96.92 | 0 | 35 | |
| 20/09/2024 07:00 | 48.05 | 0.14 | 96.89 | 0 | 34.8 | |
| 20/09/2024 08:00 | 35.18 | 0.22 | 96.12 | 0 | 35.4 | |
| 20/09/2024 09:00 | 34.1 | 0.32 | 95.52 | 0 | 23.9 | |
| 20/09/2024 10:00 | 34.45 | 0.29 | 96 | 0 | 24.1 | |
| 20/09/2024 11:00 | 34.59 | 0.31 | 96.57 | 0 | 24.1 | |
| 20/09/2024 12:00 | 22.47 | 0.38 | 93.65 | 0 | 47.8 | |
| 20/09/2024 13:00 | 34.75 | 0.26 | 95.68 | 0 | 25.7 | |
| 20/09/2024 14:00 | 34.63 | 0.21 | 96.24 | 0 | 24.2 | |
| 20/09/2024 15:00 | 34.61 | 0.15 | 95.8 | 0 | 24 | |
| 20/09/2024 16:00 | 34.54 | 0.18 | 95.58 | 0 | 23.8 | |
| 20/09/2024 17:00 | 34.35 | 0.19 | 95.39 | 0 | 23.6 | |
| 20/09/2024 18:00 | 34.25 | 0.27 | 95.38 | 0 | 23.1 | |
| 20/09/2024 19:00 | 34.24 | 0.14 | 95.44 | 0 | 23 | |
| 20/09/2024 20:00 | 34.27 | 0.14 | 95.32 | 0 | 23 | |
| 20/09/2024 21:00 | 34.47 | 0.12 | 95.65 | 0 | 23.2 | |
| 20/09/2024 22:00 | 37.68 | 0.13 | 97.36 | 0 | 24.3 | |
| 20/09/2024 23:00 | 35.43 | 0.17 | 97.55 | 0 | 28.9 | |
| 21/09/2024 00:00 | 28.65 | 0.34 | 93.72 | 0 | 40.7 | |
| Minimum | 22.47 | 0.12 | 93.65 | 0 | 23 | |
| MinDate | 20/09/2024 12:00 | 20/09/2024 21:00 | 20/09/2024 12:00 | 20/09/2024 00:00 | 20/09/2024 19:00 | |
| Maximum | 48.09 | 0.86 | 97.55 | 0 | 47.8 | |
| MaxDate | 20/09/2024 06:00 | 20/09/2024 05:00 | 20/09/2024 23:00 | 20/09/2024 00:00 | 20/09/2024 12:00 | |
| Avg | 38.22 | 0.31 | 96 | 0 | 29.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0.2 | 0.9 | 0 | 6.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/09/2024 00:00 | 1.9 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/09/2024 08:00 | 20.69 | 0 | <Samp | <Samp | <Samp | GT12 S/D |
| 20/09/2024 09:00 | 34.06 | 0.02 | 94.24 | 0 | 23.9 | |
| 20/09/2024 10:00 | 34.4 | 0.06 | 94.53 | 0 | 24 | |
| 20/09/2024 11:00 | 34.51 | 0.12 | 95.07 | 0 | 23.9 | |
| 20/09/2024 12:00 | 22.39 | 0.15 | 92.34 | 0 | 47.8 | |
| 20/09/2024 13:00 | 34.62 | 0.1 | 94.23 | 0 | 25.2 | |
| 20/09/2024 14:00 | 34.57 | 0.05 | 94.67 | 0 | 23.6 | |
| 20/09/2024 15:00 | 34.54 | 0.37 | 94.44 | 0 | 23.3 | |
| 20/09/2024 16:00 | 34.47 | 0.03 | 94.33 | 0 | 23.1 | |
| 20/09/2024 17:00 | 34.29 | 0.02 | 94.2 | 0 | 22.9 | |
| 20/09/2024 18:00 | 34.19 | 0 | 94.17 | 0 | 22.5 | |
| 20/09/2024 19:00 | 34.18 | 0 | 94.14 | 0 | 22.4 | |
| 20/09/2024 20:00 | 34.21 | 0 | 94.07 | 0 | 22.5 | |
| 20/09/2024 21:00 | 34.4 | 0 | 94.26 | 0 | 22.8 | |
| 20/09/2024 22:00 | 37.59 | 0 | 95.83 | 0 | 24.2 | |
| 20/09/2024 23:00 | 35.3 | 0 | 95.98 | 0 | 28.7 | |
| 21/09/2024 00:00 | 28.59 | 0 | 92.65 | 0 | 39 | |
| Minimum | 0 | 0 | 92.34 | 0 | 22.4 | |
| MinDate | 20/09/2024 01:00 | 20/09/2024 00:00 | 20/09/2024 12:00 | 20/09/2024 09:00 | 20/09/2024 19:00 | |
| Maximum | 37.59 | 0.37 | 95.98 | 0 | 47.8 | |
| MaxDate | 20/09/2024 22:00 | 20/09/2024 15:00 | 20/09/2024 23:00 | 20/09/2024 09:00 | 20/09/2024 12:00 | |
| Avg | 22.36 | 0.04 | 94.32 | 0 | 26.2 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 15.9 | 0.1 | 0.9 | 0 | 7.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/09/2024 00:00 | 28.65 | 0.34 | 93.72 | 0 | 40.7 | |
| 21/09/2024 01:00 | 28.95 | 0.4 | 93.43 | 0 | 39.8 | |
| 21/09/2024 02:00 | 29.03 | 0.39 | 93.31 | 0 | 39.5 | |
| 21/09/2024 03:00 | 28.96 | 0.43 | 93.26 | 0 | 39.4 | |
| 21/09/2024 04:00 | 28.89 | 0.36 | 93.17 | 0 | 40.2 | |
| 21/09/2024 05:00 | 28.81 | 0.62 | 93.17 | 0 | 40.3 | |
| 21/09/2024 06:00 | 28.81 | 0.46 | 93.29 | 0 | 40 | |
| 21/09/2024 07:00 | 28.68 | 0.38 | 93.66 | 0 | 39.9 | |
| 21/09/2024 08:00 | 32.23 | 0.42 | 94.5 | 0 | 37.3 | |
| 21/09/2024 09:00 | 42.92 | 0.3 | 101.39 | 0 | 26.2 | |
| 21/09/2024 10:00 | 43.06 | 0.32 | 102.25 | 0 | 26.6 | |
| 21/09/2024 11:00 | 42.94 | 0.29 | 102.12 | 0 | 26.5 | |
| 21/09/2024 12:00 | 28.86 | 0.37 | 95.81 | 0 | 38.1 | |
| 21/09/2024 13:00 | 42.89 | 0.16 | 100.21 | 0 | 27.3 | |
| 21/09/2024 14:00 | 43.07 | 0.15 | 102.06 | 0 | 26.3 | |
| 21/09/2024 15:00 | 43.06 | 0.16 | 101.68 | 0 | 26.2 | |
| 21/09/2024 16:00 | 42.93 | 0.11 | 101.5 | 0 | 25.9 | |
| 21/09/2024 17:00 | 42.66 | 0.06 | 101.14 | 0 | 25.6 | |
| 21/09/2024 18:00 | 42.65 | 0.08 | 101.01 | 0 | 25.6 | |
| 21/09/2024 19:00 | 42.47 | 0.05 | 100.98 | 0 | 25.2 | |
| 21/09/2024 20:00 | 42.75 | 0.06 | 101.08 | 0 | 25.6 | |
| 21/09/2024 21:00 | 42.93 | 0.06 | 101.43 | 0 | 25.5 | |
| 21/09/2024 22:00 | 42.88 | 0.13 | 101.35 | 0 | 25.6 | |
| 21/09/2024 23:00 | 39.16 | 0.25 | 100.31 | 0 | 28.6 | |
| 22/09/2024 00:00 | 28.59 | 0.35 | 93.67 | 0 | 39.3 | |
| Minimum | 28.59 | 0.05 | 93.17 | 0 | 25.2 | |
| MinDate | 22/09/2024 00:00 | 21/09/2024 19:00 | 21/09/2024 04:00 | 21/09/2024 00:00 | 21/09/2024 19:00 | |
| Maximum | 43.07 | 0.62 | 102.25 | 0 | 40.7 | |
| MaxDate | 21/09/2024 14:00 | 21/09/2024 05:00 | 21/09/2024 10:00 | 21/09/2024 00:00 | 21/09/2024 00:00 | |
| Avg | 36.67 | 0.27 | 97.98 | 0 | 32 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.9 | 0.2 | 3.9 | 0 | 6.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/09/2024 00:00 | 28.59 | 0 | 92.65 | 0 | 39 | |
| 21/09/2024 01:00 | 28.89 | 0 | 92.45 | 0 | 38.5 | |
| 21/09/2024 02:00 | 28.97 | 0 | 92.41 | 0 | 38.2 | |
| 21/09/2024 03:00 | 28.9 | 0 | 92.4 | 0 | 38.1 | |
| 21/09/2024 04:00 | 28.82 | 0 | 92.28 | 0 | 38.9 | |
| 21/09/2024 05:00 | 28.74 | 0 | 92.29 | 0 | 39 | |
| 21/09/2024 06:00 | 28.75 | 0 | 92.41 | 0 | 38.7 | |
| 21/09/2024 07:00 | 28.62 | 0.02 | 92.69 | 0 | 38.5 | |
| 21/09/2024 08:00 | 32.18 | 0.09 | 93.53 | 0 | 37.3 | |
| 21/09/2024 09:00 | 42.84 | 0.13 | 99.86 | 0 | 28.6 | |
| 21/09/2024 10:00 | 42.98 | 0.17 | 100.6 | 0 | 29.3 | |
| 21/09/2024 11:00 | 42.86 | 0.16 | 100.52 | 0 | 29.1 | |
| 21/09/2024 12:00 | 28.8 | 0.11 | 94.51 | 0 | 37.4 | |
| 21/09/2024 13:00 | 42.81 | 0.1 | 98.83 | 0 | 30.3 | |
| 21/09/2024 14:00 | 43 | 0.07 | 100.48 | 0 | 29 | |
| 21/09/2024 15:00 | 42.97 | 0.33 | 100.2 | 0 | 28.7 | |
| 21/09/2024 16:00 | 42.85 | 0.03 | 100.14 | 0 | 28 | |
| 21/09/2024 17:00 | 42.59 | 0 | 99.82 | 0 | 27.1 | |
| 21/09/2024 18:00 | 42.57 | 0 | 99.81 | 0 | 27.1 | |
| 21/09/2024 19:00 | 42.4 | 0 | 99.71 | 0 | 26.4 | |
| 21/09/2024 20:00 | 42.67 | 0 | 99.85 | 0 | 27.2 | |
| 21/09/2024 21:00 | 42.85 | 0 | 100.09 | 0 | 27.1 | |
| 21/09/2024 22:00 | 42.81 | 0 | 100.01 | 0 | 27.3 | |
| 21/09/2024 23:00 | 39.1 | 0 | 98.88 | 0 | 29.5 | |
| 22/09/2024 00:00 | 28.54 | 0 | 92.87 | 0 | 38.3 | |
| Minimum | 28.54 | 0 | 92.28 | 0 | 26.4 | |
| MinDate | 22/09/2024 00:00 | 21/09/2024 00:00 | 21/09/2024 04:00 | 21/09/2024 00:00 | 21/09/2024 19:00 | |
| Maximum | 43 | 0.33 | 100.6 | 0 | 39 | |
| MaxDate | 21/09/2024 14:00 | 21/09/2024 15:00 | 21/09/2024 10:00 | 21/09/2024 00:00 | 21/09/2024 00:00 | |
| Avg | 36.6 | 0.05 | 96.77 | 0 | 32.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.9 | 0.1 | 3.7 | 0 | 5.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/09/2024 00:00 | 28.59 | 0.35 | 93.67 | 0 | 39.3 | GT11 S/D |
| 22/09/2024 01:00 | 28.6 | 0.29 | 93.07 | 0 | 39.2 | GT11 S/D |
| 22/09/2024 02:00 | 28.63 | 0.24 | 93.1 | 0 | 39.3 | GT11 S/D |
| 22/09/2024 03:00 | 28.48 | 0.21 | 92.97 | 0 | 39.8 | GT11 S/D |
| 22/09/2024 04:00 | 28.26 | 0.28 | 92.86 | 0 | 40.4 | GT11 S/D |
| 22/09/2024 05:00 | 27.97 | 0.53 | 92.82 | 0 | 41.2 | GT11 S/D |
| 22/09/2024 06:00 | 27.87 | 0.46 | 92.89 | 0 | 41.4 | GT11 S/D |
| 22/09/2024 07:00 | 27.54 | 0.45 | 92.99 | 0 | 42 | GT11 S/D |
| 22/09/2024 08:00 | 27.27 | 0.39 | 92.88 | 0 | 42.6 | GT11 S/D |
| 22/09/2024 09:00 | 27.07 | 0.37 | 93 | 0 | 43.1 | |
| 22/09/2024 10:00 | 27.11 | 0.37 | 93.13 | 0 | 43.1 | |
| 22/09/2024 11:00 | 27.1 | 0.51 | 93.28 | 0 | 42.5 | |
| 22/09/2024 12:00 | 27.11 | 0.49 | 93.37 | 0 | 42.1 | |
| 22/09/2024 13:00 | 27.12 | 0.45 | 93.18 | 0 | 44.2 | |
| 22/09/2024 14:00 | 27.21 | 0.41 | 93.02 | 0 | 41.2 | |
| 22/09/2024 15:00 | 27.19 | 0.53 | 92.29 | 0 | 41.9 | |
| 22/09/2024 16:00 | 27.29 | 1.41 | 91.89 | 0 | 42.5 | |
| 22/09/2024 17:00 | 27.41 | 1.12 | 92.26 | 0 | 41.6 | |
| 22/09/2024 18:00 | 37.82 | 0.48 | 96.61 | 0 | 29 | |
| 22/09/2024 19:00 | 41.22 | 0.39 | 99.95 | 0 | 23.4 | |
| 22/09/2024 20:00 | 41.21 | 0.35 | 100.13 | 0 | 23.4 | |
| 22/09/2024 21:00 | 41.18 | 0.53 | 100.33 | 0 | 23.2 | |
| 22/09/2024 22:00 | 34.15 | 0.64 | 98.16 | 0 | 31.2 | |
| 22/09/2024 23:00 | 27.32 | 0.64 | 93.6 | 0 | 41.4 | |
| 23/09/2024 00:00 | 27.3 | 0.46 | 93.46 | 0 | 41 | |
| Minimum | 27.07 | 0.21 | 91.89 | 0 | 23.2 | |
| MinDate | 22/09/2024 09:00 | 22/09/2024 03:00 | 22/09/2024 16:00 | 22/09/2024 00:00 | 22/09/2024 21:00 | |
| Maximum | 41.22 | 1.41 | 100.33 | 0 | 44.2 | |
| MaxDate | 22/09/2024 19:00 | 22/09/2024 16:00 | 22/09/2024 21:00 | 22/09/2024 00:00 | 22/09/2024 13:00 | |
| Avg | 29.92 | 0.49 | 94.2 | 0 | 38.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.9 | 0.3 | 2.6 | 0 | 6.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/09/2024 00:00 | 28.54 | 0 | 92.87 | 0 | 38.3 | |
| 22/09/2024 01:00 | 28.54 | 0 | 92.32 | 0 | 38.1 | |
| 22/09/2024 02:00 | 28.57 | 0 | 92.3 | 0 | 38.1 | |
| 22/09/2024 03:00 | 28.42 | 0 | 92.22 | 0 | 38.6 | |
| 22/09/2024 04:00 | 28.2 | 0 | 92.05 | 0 | 39 | |
| 22/09/2024 05:00 | 27.91 | 0 | 92.06 | 0 | 39.2 | |
| 22/09/2024 06:00 | 27.81 | 0 | 92.05 | 0 | 39.5 | |
| 22/09/2024 07:00 | 27.48 | 0 | 92.1 | 0 | 39.7 | |
| 22/09/2024 08:00 | 27.21 | 0 | 92.06 | 0 | 40.2 | |
| 22/09/2024 09:00 | 27.01 | 0.01 | 92.22 | 0 | 40.4 | |
| 22/09/2024 10:00 | 27.05 | 0.04 | 92.27 | 0 | 40.7 | |
| 22/09/2024 11:00 | 27.04 | 0.17 | 92.41 | 0 | 40.4 | |
| 22/09/2024 12:00 | 27.04 | 0.18 | 92.44 | 0 | 40.1 | |
| 22/09/2024 13:00 | 27.06 | 0.16 | 92.24 | 0 | 41.9 | |
| 22/09/2024 14:00 | 27.15 | 0.13 | 92.16 | 0 | 39.5 | |
| 22/09/2024 15:00 | 27.13 | 0.26 | 91.58 | 0 | 40 | |
| 22/09/2024 16:00 | 27.24 | 0 | 91.22 | 0 | 39.9 | |
| 22/09/2024 17:00 | 27.34 | 0 | 91.58 | 0 | 39.2 | |
| 22/09/2024 18:00 | 37.74 | 0 | 95.61 | 0 | 29 | |
| 22/09/2024 19:00 | 41.14 | 0 | 98.41 | 0 | 23.8 | |
| 22/09/2024 20:00 | 41.14 | 0 | 98.59 | 0 | 23.8 | |
| 22/09/2024 21:00 | 41.11 | 0 | 98.71 | 0 | 23.7 | |
| 22/09/2024 22:00 | 34.09 | 0.03 | 96.55 | 0 | 31.1 | |
| 22/09/2024 23:00 | 27.25 | 0.07 | 92.43 | 0 | 39.5 | |
| 23/09/2024 00:00 | 27.25 | 0.07 | 92.32 | 0 | 39.2 | GT12 S/D |
| Minimum | 27.01 | 0 | 91.22 | 0 | 23.7 | |
| MinDate | 22/09/2024 09:00 | 22/09/2024 00:00 | 22/09/2024 16:00 | 22/09/2024 00:00 | 22/09/2024 21:00 | |
| Maximum | 41.14 | 0.26 | 98.71 | 0 | 41.9 | |
| MaxDate | 22/09/2024 19:00 | 22/09/2024 15:00 | 22/09/2024 21:00 | 22/09/2024 00:00 | 22/09/2024 13:00 | |
| Avg | 29.86 | 0.04 | 93.23 | 0 | 36.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.9 | 0.1 | 2.3 | 0 | 5.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/09/2024 00:00 | 27.3 | 0.46 | 93.46 | 0 | 41 | |
| 23/09/2024 01:00 | 27.34 | 0.39 | 93.35 | 0 | 40.8 | |
| 23/09/2024 02:00 | 27.32 | 0.38 | 93.38 | 0 | 41 | |
| 23/09/2024 03:00 | 27.31 | 0.34 | 93.4 | 0 | 41 | |
| 23/09/2024 04:00 | 27.32 | 0.31 | 93.37 | 0 | 41.8 | |
| 23/09/2024 05:00 | 27.3 | 0.63 | 93.11 | 0 | 42 | |
| 23/09/2024 06:00 | 27.33 | 0.37 | 92.95 | 0 | 41.7 | |
| 23/09/2024 07:00 | 27.62 | 0.34 | 93.04 | 0 | 40.5 | |
| 23/09/2024 08:00 | 31.02 | 0.22 | 94.23 | 0 | 34 | |
| 23/09/2024 09:00 | 34.24 | 0.18 | 95.89 | 0 | 20.4 | |
| 23/09/2024 10:00 | 34.31 | 0.14 | 95.99 | 0 | 20.6 | |
| 23/09/2024 11:00 | 34.35 | 0.26 | 96.17 | 0 | 20.8 | |
| 23/09/2024 12:00 | 21.73 | 0.38 | 93.37 | 0 | 47.2 | |
| 23/09/2024 13:00 | 34.54 | 0.2 | 95.8 | 0 | 22.1 | |
| 23/09/2024 14:00 | 34.49 | 0.17 | 96.31 | 0 | 20.5 | |
| 23/09/2024 15:00 | 34.5 | 0.13 | 95.99 | 0 | 20.4 | |
| 23/09/2024 16:00 | 34.47 | 0.07 | 96.1 | 0 | 20.7 | |
| 23/09/2024 17:00 | 34.24 | 0.02 | 95.73 | 0 | 20.6 | |
| 23/09/2024 18:00 | 34.25 | 0 | 95.51 | 0 | 20.2 | |
| 23/09/2024 19:00 | 34.09 | 0.02 | 95.26 | 0 | 20.2 | |
| 23/09/2024 20:00 | 34.17 | 0.06 | 95.27 | 0 | 20.1 | |
| 23/09/2024 21:00 | 34.33 | 0 | 95.86 | 0 | 20.1 | |
| 23/09/2024 22:00 | 34.35 | 0.01 | 96.07 | 0 | 19.9 | |
| 23/09/2024 23:00 | 31.62 | 0.13 | 95.56 | 0 | 25.9 | |
| 24/09/2024 00:00 | 47.06 | 0.22 | 96.98 | 0 | 29.8 | |
| Minimum | 21.73 | 0 | 92.95 | 0 | 19.9 | |
| MinDate | 23/09/2024 12:00 | 23/09/2024 18:00 | 23/09/2024 06:00 | 23/09/2024 00:00 | 23/09/2024 22:00 | |
| Maximum | 47.06 | 0.63 | 96.98 | 0 | 47.2 | |
| MaxDate | 24/09/2024 00:00 | 23/09/2024 05:00 | 24/09/2024 00:00 | 23/09/2024 00:00 | 23/09/2024 12:00 | |
| Avg | 31.86 | 0.22 | 94.89 | 0 | 29.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.9 | 0.2 | 1.3 | 0 | 10.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/09/2024 00:00 | 27.25 | 0.07 | 92.32 | 0 | 39.2 | |
| 23/09/2024 01:00 | 27.26 | 0.03 | 92.25 | 0 | 38.6 | |
| 23/09/2024 02:00 | 27.26 | 0 | 92.14 | 0 | 38.9 | |
| 23/09/2024 03:00 | 27.25 | 0 | 92.24 | 0 | 38.9 | |
| 23/09/2024 04:00 | 27.26 | 0 | 92.23 | 0 | 40 | |
| 23/09/2024 05:00 | 27.25 | 0.06 | 92.01 | 0 | 40.3 | |
| 23/09/2024 06:00 | 27.27 | 0.05 | 91.89 | 0 | 40 | |
| 23/09/2024 07:00 | 27.56 | 0.02 | 92 | 0 | 39 | |
| 23/09/2024 08:00 | 31.02 | 0.02 | 93.23 | 0 | 34.2 | |
| 23/09/2024 09:00 | 34.19 | 0.08 | 94.51 | 0 | 20.5 | |
| 23/09/2024 10:00 | 34.25 | 0.14 | 94.52 | 0 | 20.8 | |
| 23/09/2024 11:00 | 34.29 | 0.23 | 94.67 | 0 | 21.1 | |
| 23/09/2024 12:00 | 21.7 | 0.25 | 92.22 | 0 | 50.7 | |
| 23/09/2024 13:00 | 34.49 | 0.22 | 94.31 | 0 | 22.3 | |
| 23/09/2024 14:00 | 34.42 | 0.19 | 94.41 | 0 | 20.4 | |
| 23/09/2024 15:00 | 34.44 | 0.18 | 94.23 | 0 | 20.4 | |
| 23/09/2024 16:00 | 34.41 | 0.04 | 94.32 | 0 | 20.6 | |
| 23/09/2024 17:00 | 34.18 | 0.01 | 94.01 | 0 | 20.5 | |
| 23/09/2024 18:00 | 34.19 | 0 | 93.82 | 0 | 19.8 | |
| 23/09/2024 19:00 | 34.02 | 0 | 93.67 | 0 | 19.8 | |
| 23/09/2024 20:00 | 34.1 | 0 | 93.57 | 0 | 19.8 | |
| 23/09/2024 21:00 | 34.27 | 0 | 93.95 | 0 | 19.9 | |
| 23/09/2024 22:00 | 34.28 | 0 | 94.06 | 0 | 19.7 | |
| 23/09/2024 23:00 | 31.53 | 0 | 93.62 | 0 | 26 | |
| 24/09/2024 00:00 | 2.01 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 2.01 | 0 | 91.89 | 0 | 19.7 | |
| MinDate | 24/09/2024 00:00 | 23/09/2024 02:00 | 23/09/2024 06:00 | 23/09/2024 00:00 | 23/09/2024 22:00 | |
| Maximum | 34.49 | 0.25 | 94.67 | 0 | 50.7 | |
| MaxDate | 23/09/2024 13:00 | 23/09/2024 12:00 | 23/09/2024 11:00 | 23/09/2024 00:00 | 23/09/2024 12:00 | |
| Avg | 30.01 | 0.06 | 93.34 | 0 | 28.8 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.9 | 0.1 | 1 | 0 | 10.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/09/2024 00:00 | 47.06 | 0.22 | 96.98 | 0 | 29.8 | |
| 24/09/2024 01:00 | 48.79 | 0.02 | 96.44 | 0 | 29.8 | |
| 24/09/2024 02:00 | 48.86 | 0.24 | 96.81 | 0 | 29.9 | |
| 24/09/2024 03:00 | 48.97 | 0.22 | 96.98 | 0 | 29.8 | |
| 24/09/2024 04:00 | 48.9 | 0.01 | 97.05 | 0 | 29.8 | |
| 24/09/2024 05:00 | 48.82 | 0.39 | 97.12 | 0 | 29.4 | |
| 24/09/2024 06:00 | 48.92 | 0.02 | 97.7 | 0 | 29.4 | |
| 24/09/2024 07:00 | 48.73 | 0 | 97.21 | 0 | 29.3 | |
| 24/09/2024 08:00 | 34.76 | 0.09 | 96.22 | 0 | 30 | |
| 24/09/2024 09:00 | 34.34 | 0 | 95.74 | 0 | 19.8 | |
| 24/09/2024 10:00 | 34.37 | 0.03 | 96.08 | 0 | 19.8 | |
| 24/09/2024 11:00 | 34.32 | 0.23 | 96.19 | 0 | 20 | |
| 24/09/2024 12:00 | 21.85 | 0.39 | 92.76 | 0 | 45.8 | |
| 24/09/2024 13:00 | 34.56 | 0.18 | 95.4 | 0 | 21.5 | |
| 24/09/2024 14:00 | 34.44 | 0.18 | 96.07 | 0 | 19.8 | |
| 24/09/2024 15:00 | 34.49 | 0.27 | 95.75 | 0 | 19.7 | |
| 24/09/2024 16:00 | 34.35 | 0.34 | 95.61 | 0 | 19.6 | |
| 24/09/2024 17:00 | 34.21 | 0.23 | 95.39 | 0 | 19.7 | |
| 24/09/2024 18:00 | 34.19 | 0.1 | 95.3 | 0 | 19.7 | |
| 24/09/2024 19:00 | 34.09 | 0.08 | 95.34 | 0 | 19.8 | |
| 24/09/2024 20:00 | 34.1 | 0.12 | 95.39 | 0 | 19.8 | |
| 24/09/2024 21:00 | 34.24 | 0.1 | 95.83 | 0 | 19.7 | |
| 24/09/2024 22:00 | 34.21 | 0.27 | 95.4 | 0 | 19.8 | |
| 24/09/2024 23:00 | 31.46 | 0.51 | 94.85 | 0 | 26.1 | |
| 25/09/2024 00:00 | 2.37 | 0.37 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 2.37 | 0 | 92.76 | 0 | 19.6 | |
| MinDate | 25/09/2024 00:00 | 24/09/2024 07:00 | 24/09/2024 12:00 | 24/09/2024 00:00 | 24/09/2024 16:00 | |
| Maximum | 48.97 | 0.51 | 97.7 | 0 | 45.8 | |
| MaxDate | 24/09/2024 03:00 | 24/09/2024 23:00 | 24/09/2024 06:00 | 24/09/2024 00:00 | 24/09/2024 12:00 | |
| Avg | 37.02 | 0.18 | 95.98 | 0 | 24.9 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.5 | 0.1 | 1 | 0 | 6.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/09/2024 00:00 | 2.01 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 24/09/2024 08:00 | 20.73 | 0 | <Samp | <Samp | <Samp | |
| 24/09/2024 09:00 | 34.27 | 0 | 94.71 | 0 | 24.5 | |
| 24/09/2024 10:00 | 34.31 | 0 | 95.06 | 0 | 24.7 | |
| 24/09/2024 11:00 | 34.25 | 0.11 | 95.14 | 0 | 24.8 | |
| 24/09/2024 12:00 | 21.78 | 0.1 | 91.96 | 0 | 51.6 | |
| 24/09/2024 13:00 | 34.49 | 0.07 | 94.36 | 0 | 26.1 | |
| 24/09/2024 14:00 | 34.37 | 0.29 | 94.55 | 0 | 24.3 | |
| 24/09/2024 15:00 | 34.42 | 0.17 | 94.34 | 0 | 24.1 | |
| 24/09/2024 16:00 | 34.28 | 0.09 | 94.19 | 0 | 23.7 | |
| 24/09/2024 17:00 | 34.15 | 0.03 | 94.02 | 0 | 23.7 | |
| 24/09/2024 18:00 | 34.12 | 0 | 93.88 | 0 | 23.5 | |
| 24/09/2024 19:00 | 34.02 | 0 | 93.91 | 0 | 23.5 | |
| 24/09/2024 20:00 | 34.03 | 0 | 93.93 | 0 | 23.4 | |
| 24/09/2024 21:00 | 34.17 | 0 | 94.2 | 0 | 23.4 | |
| 24/09/2024 22:00 | 34.15 | 0 | 93.68 | 0 | 23.5 | |
| 24/09/2024 23:00 | 31.42 | 0.01 | 93.23 | 0 | 29.6 | |
| 25/09/2024 00:00 | 46.95 | 0 | 95.67 | 0 | 40.7 | |
| Minimum | 0 | 0 | 91.96 | 0 | 23.4 | |
| MinDate | 24/09/2024 01:00 | 24/09/2024 00:00 | 24/09/2024 12:00 | 24/09/2024 09:00 | 24/09/2024 20:00 | |
| Maximum | 46.95 | 0.29 | 95.67 | 0 | 51.6 | |
| MaxDate | 25/09/2024 00:00 | 24/09/2024 14:00 | 25/09/2024 00:00 | 24/09/2024 09:00 | 24/09/2024 12:00 | |
| Avg | 22.72 | 0.03 | 94.18 | 0 | 27.2 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.1 | 0.8 | 0 | 7.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/09/2024 00:00 | 2.37 | 0.37 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 01:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 02:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 03:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 04:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 05:00 | 0 | 0.36 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 06:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 07:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/09/2024 08:00 | 22.67 | 0.38 | <Samp | <Samp | <Samp | GT11 S/D |
| 25/09/2024 09:00 | 34.47 | 0.3 | 96.22 | 0 | 28 | |
| 25/09/2024 10:00 | 34.41 | 0.3 | 96.15 | 0 | 28 | |
| 25/09/2024 11:00 | 34.39 | 0.34 | 96.51 | 0 | 28.1 | |
| 25/09/2024 12:00 | 21.9 | 0.53 | 93.51 | 0 | 53 | |
| 25/09/2024 13:00 | 34.53 | 0.49 | 95.95 | 0 | 29.6 | |
| 25/09/2024 14:00 | 34.47 | 0.45 | 96.3 | 0 | 27.5 | |
| 25/09/2024 15:00 | 34.47 | 0.3 | 94.88 | 0 | 27.3 | |
| 25/09/2024 16:00 | 34.26 | 0.16 | 94.52 | 0 | 27.2 | |
| 25/09/2024 17:00 | 34.09 | 0.09 | 95.05 | 0 | 26.7 | |
| 25/09/2024 18:00 | 34.15 | 0.33 | 95.18 | 0 | 26.5 | |
| 25/09/2024 19:00 | 34.06 | 0.35 | 95.28 | 0 | 26.2 | |
| 25/09/2024 20:00 | 34.09 | 0.33 | 95.27 | 0 | 26.1 | |
| 25/09/2024 21:00 | 34.26 | 0.14 | 95.36 | 0 | 26.2 | |
| 25/09/2024 22:00 | 34.25 | 0.16 | 95.6 | 0 | 26 | |
| 25/09/2024 23:00 | 31.42 | 0.25 | 95.2 | 0 | 31.8 | |
| 26/09/2024 00:00 | 47.21 | 0.09 | 97.04 | 0 | 36.9 | |
| Minimum | 0 | 0.02 | 93.51 | 0 | 26 | |
| MinDate | 25/09/2024 01:00 | 25/09/2024 03:00 | 25/09/2024 12:00 | 25/09/2024 09:00 | 25/09/2024 22:00 | |
| Maximum | 47.21 | 0.53 | 97.04 | 0 | 53 | |
| MaxDate | 26/09/2024 00:00 | 25/09/2024 12:00 | 26/09/2024 00:00 | 25/09/2024 09:00 | 25/09/2024 12:00 | |
| Avg | 22.86 | 0.25 | 95.5 | 0 | 29.7 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.2 | 0.9 | 0 | 6.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/09/2024 00:00 | 46.95 | 0 | 95.67 | 0 | 40.7 | |
| 25/09/2024 01:00 | 48.89 | 0 | 95.27 | 0 | 42.4 | |
| 25/09/2024 02:00 | 48.95 | 0 | 95.9 | 0 | 42.5 | |
| 25/09/2024 03:00 | 48.91 | 0 | 95.69 | 0 | 42.6 | |
| 25/09/2024 04:00 | 48.86 | 0 | 95.78 | 0 | 41.9 | |
| 25/09/2024 05:00 | 48.8 | 0 | 95.98 | 0 | 41.3 | |
| 25/09/2024 06:00 | 48.95 | 0 | 96.36 | 0 | 41.8 | |
| 25/09/2024 07:00 | 48.85 | 0 | 95.83 | 0 | 41.9 | |
| 25/09/2024 08:00 | 33.21 | 0 | 94.55 | 0 | 37.1 | |
| 25/09/2024 09:00 | 34.41 | 0.08 | 94.6 | 0 | 23.3 | |
| 25/09/2024 10:00 | 34.34 | 0.1 | 94.63 | 0 | 23.2 | |
| 25/09/2024 11:00 | 34.32 | 0.15 | 94.95 | 0 | 23.4 | |
| 25/09/2024 12:00 | 21.89 | 0.23 | 92.28 | 0 | 50.6 | |
| 25/09/2024 13:00 | 34.49 | 0.25 | 94.52 | 0 | 24.8 | |
| 25/09/2024 14:00 | 34.41 | 0.42 | 94.72 | 0 | 22.8 | |
| 25/09/2024 15:00 | 34.4 | 0.05 | 93.43 | 0 | 22.6 | |
| 25/09/2024 16:00 | 34.19 | 0 | 93.23 | 0 | 22.6 | |
| 25/09/2024 17:00 | 34.03 | 0 | 93.71 | 0 | 22.1 | |
| 25/09/2024 18:00 | 34.09 | 0 | 93.81 | 0 | 21.9 | |
| 25/09/2024 19:00 | 33.99 | 0 | 93.97 | 0 | 21.7 | |
| 25/09/2024 20:00 | 34.02 | 0.02 | 94.03 | 0 | 21.5 | |
| 25/09/2024 21:00 | 34.19 | 0 | 94.07 | 0 | 21.8 | |
| 25/09/2024 22:00 | 34.19 | 0 | 94.22 | 0 | 21.7 | |
| 25/09/2024 23:00 | 31.26 | 0 | 93.82 | 0 | 27.9 | |
| 26/09/2024 00:00 | 1.73 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 1.73 | 0 | 92.28 | 0 | 21.5 | |
| MinDate | 26/09/2024 00:00 | 25/09/2024 00:00 | 25/09/2024 12:00 | 25/09/2024 00:00 | 25/09/2024 20:00 | |
| Maximum | 48.95 | 0.42 | 96.36 | 0 | 50.6 | |
| MaxDate | 25/09/2024 02:00 | 25/09/2024 14:00 | 25/09/2024 06:00 | 25/09/2024 00:00 | 25/09/2024 12:00 | |
| Avg | 36.89 | 0.05 | 94.63 | 0 | 31 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.6 | 0.1 | 1 | 0 | 10 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/09/2024 00:00 | 47.21 | 0.09 | 97.04 | 0 | 36.9 | |
| 26/09/2024 01:00 | 48.6 | 0.13 | 96.6 | 0 | 37.5 | |
| 26/09/2024 02:00 | 48.66 | 0.11 | 96.9 | 0 | 37.3 | |
| 26/09/2024 03:00 | 48.69 | 0.1 | 97 | 0 | 37.4 | |
| 26/09/2024 04:00 | 48.71 | 0.11 | 96.99 | 0 | 37.3 | |
| 26/09/2024 05:00 | 48.88 | 0.49 | 96.95 | 0 | 37.3 | |
| 26/09/2024 06:00 | 48.86 | 0 | 97.38 | 0 | 37.5 | |
| 26/09/2024 07:00 | 48.78 | 0 | 96.93 | 0 | 37.3 | |
| 26/09/2024 08:00 | 35.11 | 0.07 | 96.8 | 0 | 37.6 | |
| 26/09/2024 09:00 | 34.46 | 0.13 | 96.43 | 0 | 26.3 | |
| 26/09/2024 10:00 | 34.48 | 0.14 | 96.67 | 0 | 26.4 | |
| 26/09/2024 11:00 | 34.44 | 0.2 | 96.83 | 0 | 26.3 | |
| 26/09/2024 12:00 | 21.93 | 0.34 | 93.36 | 0 | 49 | |
| 26/09/2024 13:00 | 34.55 | 0.17 | 95.54 | 0 | 26.9 | |
| 26/09/2024 14:00 | 34.46 | 0.19 | 95.16 | 0 | 25.7 | |
| 26/09/2024 15:00 | 34.39 | 0 | 94.81 | 0 | 25.8 | |
| 26/09/2024 16:00 | 34.29 | 0 | 94.81 | 0 | 25 | |
| 26/09/2024 17:00 | 34.18 | 0 | 95.21 | 0 | 24.7 | |
| 26/09/2024 18:00 | 34.13 | 0 | 95.2 | 0 | 24.6 | |
| 26/09/2024 19:00 | 33.97 | 0 | 95.08 | 0 | 24.7 | |
| 26/09/2024 20:00 | 34.01 | 0 | 95.09 | 0 | 24.6 | |
| 26/09/2024 21:00 | 34.2 | 0 | 95.52 | 0 | 24.4 | |
| 26/09/2024 22:00 | 34.25 | 0 | 95.45 | 0 | 24.3 | |
| 26/09/2024 23:00 | 31.34 | 0 | 94.95 | 0 | 30.5 | |
| 27/09/2024 00:00 | 2.11 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 2.11 | 0 | 93.36 | 0 | 24.3 | |
| MinDate | 27/09/2024 00:00 | 26/09/2024 06:00 | 26/09/2024 12:00 | 26/09/2024 00:00 | 26/09/2024 22:00 | |
| Maximum | 48.88 | 0.49 | 97.38 | 0 | 49 | |
| MaxDate | 26/09/2024 05:00 | 26/09/2024 05:00 | 26/09/2024 06:00 | 26/09/2024 00:00 | 26/09/2024 12:00 | |
| Avg | 36.99 | 0.09 | 95.95 | 0 | 31.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 10.5 | 0.1 | 1 | 0 | 6.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/09/2024 00:00 | 1.73 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/09/2024 08:00 | 20.57 | 0.04 | <Samp | <Samp | <Samp | GT12 S/D |
| 26/09/2024 09:00 | 34.4 | 0.18 | 95.18 | 0 | 24.6 | |
| 26/09/2024 10:00 | 34.42 | 0.22 | 95.15 | 0 | 24.7 | |
| 26/09/2024 11:00 | 34.37 | 0.26 | 95.24 | 0 | 24.6 | |
| 26/09/2024 12:00 | 21.9 | 0.25 | 92.16 | 0 | 48.9 | |
| 26/09/2024 13:00 | 34.49 | 0.18 | 94.52 | 0 | 25 | |
| 26/09/2024 14:00 | 34.4 | 0.25 | 94.19 | 0 | 23.7 | |
| 26/09/2024 15:00 | 34.33 | 0.02 | 93.93 | 0 | 23.9 | |
| 26/09/2024 16:00 | 34.23 | 0 | 93.84 | 0 | 23.2 | |
| 26/09/2024 17:00 | 34.11 | 0 | 94.26 | 0 | 22.8 | |
| 26/09/2024 18:00 | 34.06 | 0 | 94.23 | 0 | 22.7 | |
| 26/09/2024 19:00 | 33.9 | 0 | 94.17 | 0 | 22.9 | |
| 26/09/2024 20:00 | 33.94 | 0 | 94.17 | 0 | 22.8 | |
| 26/09/2024 21:00 | 34.14 | 0 | 94.46 | 0 | 22.6 | |
| 26/09/2024 22:00 | 34.19 | 0 | 94.46 | 0 | 22.5 | |
| 26/09/2024 23:00 | 31.36 | 0 | 94 | 0 | 28.8 | |
| 27/09/2024 00:00 | 47.09 | 0.03 | 95.84 | 0 | 40.3 | |
| Minimum | 0 | 0 | 92.16 | 0 | 22.5 | |
| MinDate | 26/09/2024 01:00 | 26/09/2024 00:00 | 26/09/2024 12:00 | 26/09/2024 09:00 | 26/09/2024 22:00 | |
| Maximum | 47.09 | 0.26 | 95.84 | 0 | 48.9 | |
| MaxDate | 27/09/2024 00:00 | 26/09/2024 11:00 | 27/09/2024 00:00 | 26/09/2024 09:00 | 26/09/2024 12:00 | |
| Avg | 22.71 | 0.06 | 94.36 | 0 | 26.5 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.4 | 0.1 | 0.8 | 0 | 7.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/09/2024 00:00 | 2.11 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 05:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 06:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 07:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/09/2024 08:00 | 21.2 | 0.49 | <Samp | <Samp | <Samp | GT11 S/D |
| 27/09/2024 09:00 | 34.49 | 0.14 | 96.88 | 0 | 27.2 | |
| 27/09/2024 10:00 | 34.43 | 0.21 | 96.96 | 0 | 27.5 | |
| 27/09/2024 11:00 | 34.36 | 0.25 | 96.82 | 0 | 27.4 | |
| 27/09/2024 12:00 | 21.93 | 0.34 | 93.62 | 0 | 49.7 | |
| 27/09/2024 13:00 | 34.4 | 0.27 | 95.71 | 0 | 27.8 | |
| 27/09/2024 14:00 | 34.34 | 0.52 | 94.58 | 0 | 26.6 | |
| 27/09/2024 15:00 | 34.17 | 0.92 | 94.05 | 0 | 26.3 | |
| 27/09/2024 16:00 | 34.13 | 0.18 | 94.61 | 0 | 26.2 | |
| 27/09/2024 17:00 | 34.08 | 0.08 | 94.4 | 0 | 25.8 | |
| 27/09/2024 18:00 | 34.15 | 0.03 | 93.85 | 0 | 25.8 | |
| 27/09/2024 19:00 | 34.05 | 0 | 94.39 | 0 | 25.8 | |
| 27/09/2024 20:00 | 34.09 | 0 | 94.71 | 0 | 25.9 | |
| 27/09/2024 21:00 | 34.25 | 0.04 | 95.18 | 0 | 25.8 | |
| 27/09/2024 22:00 | 37.46 | 0.04 | 96.95 | 0 | 27 | |
| 27/09/2024 23:00 | 35.18 | 0.09 | 97.2 | 0 | 31.8 | |
| 28/09/2024 00:00 | 28.17 | 0.13 | 93.57 | 0 | 46.5 | |
| Minimum | 0 | 0 | 93.57 | 0 | 25.8 | |
| MinDate | 27/09/2024 01:00 | 27/09/2024 01:00 | 28/09/2024 00:00 | 27/09/2024 09:00 | 27/09/2024 17:00 | |
| Maximum | 37.46 | 0.92 | 97.2 | 0 | 49.7 | |
| MaxDate | 27/09/2024 22:00 | 27/09/2024 15:00 | 27/09/2024 23:00 | 27/09/2024 09:00 | 27/09/2024 12:00 | |
| Avg | 22.28 | 0.16 | 95.22 | 0 | 29.6 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 15.9 | 0.2 | 1.3 | 0 | 7.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/09/2024 00:00 | 47.09 | 0.03 | 95.84 | 0 | 40.3 | |
| 27/09/2024 01:00 | 48.8 | 0.06 | 95.23 | 0 | 42.8 | |
| 27/09/2024 02:00 | 48.89 | 0.1 | 95.67 | 0 | 43 | |
| 27/09/2024 03:00 | 48.77 | 0.19 | 95.62 | 0 | 42.8 | |
| 27/09/2024 04:00 | 48.79 | 0.2 | 95.53 | 0 | 42.3 | |
| 27/09/2024 05:00 | 48.79 | 0.17 | 95.76 | 0 | 41.4 | |
| 27/09/2024 06:00 | 48.93 | 0.17 | 96.04 | 0 | 42.1 | |
| 27/09/2024 07:00 | 48.53 | 0.22 | 95.61 | 0 | 41.7 | |
| 27/09/2024 08:00 | 34.48 | 0.31 | 95.18 | 0 | 35.3 | |
| 27/09/2024 09:00 | 34.42 | 0.23 | 95.03 | 0 | 22.4 | |
| 27/09/2024 10:00 | 34.37 | 0.31 | 95.28 | 0 | 22.6 | |
| 27/09/2024 11:00 | 34.29 | 0.36 | 95.08 | 0 | 22.7 | |
| 27/09/2024 12:00 | 21.85 | 0.31 | 92.28 | 0 | 47.6 | |
| 27/09/2024 13:00 | 34.32 | 0.29 | 94.45 | 0 | 23 | |
| 27/09/2024 14:00 | 34.27 | 0.34 | 92.69 | 0 | 21.7 | |
| 27/09/2024 15:00 | 34.11 | 0 | 92.82 | 0 | 21.8 | |
| 27/09/2024 16:00 | 34.06 | 0.01 | 93.51 | 0 | 21.7 | |
| 27/09/2024 17:00 | 34.01 | 0.02 | 93.27 | 0 | 21.3 | |
| 27/09/2024 18:00 | 34.09 | 0 | 92.83 | 0 | 21.5 | |
| 27/09/2024 19:00 | 33.98 | 0 | 93.41 | 0 | 21.9 | |
| 27/09/2024 20:00 | 34.02 | 0 | 93.75 | 0 | 22 | |
| 27/09/2024 21:00 | 34.2 | 0.06 | 94.08 | 0 | 21.5 | |
| 27/09/2024 22:00 | 37.39 | 0.09 | 95.73 | 0 | 23.1 | |
| 27/09/2024 23:00 | 35.12 | 0.09 | 95.91 | 0 | 27.8 | |
| 28/09/2024 00:00 | 28.12 | 0.15 | 92.78 | 0 | 40.8 | |
| Minimum | 21.85 | 0 | 92.28 | 0 | 21.3 | |
| MinDate | 27/09/2024 12:00 | 27/09/2024 15:00 | 27/09/2024 12:00 | 27/09/2024 00:00 | 27/09/2024 17:00 | |
| Maximum | 48.93 | 0.36 | 96.04 | 0 | 47.6 | |
| MaxDate | 27/09/2024 06:00 | 27/09/2024 11:00 | 27/09/2024 06:00 | 27/09/2024 00:00 | 27/09/2024 12:00 | |
| Avg | 38.23 | 0.15 | 94.54 | 0 | 31 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.8 | 0.1 | 1.3 | 0 | 10 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/09/2024 00:00 | 28.17 | 0.13 | 93.57 | 0 | 46.5 | |
| 28/09/2024 01:00 | 27.97 | 0.13 | 93.17 | 0 | 47.1 | |
| 28/09/2024 02:00 | 28 | 0.14 | 93.05 | 0 | 47 | |
| 28/09/2024 03:00 | 27.97 | 0.16 | 93.06 | 0 | 47 | |
| 28/09/2024 04:00 | 27.76 | 0.23 | 93.11 | 0 | 46.9 | |
| 28/09/2024 05:00 | 27.63 | 0.5 | 92.88 | 0 | 47.6 | |
| 28/09/2024 06:00 | 27.51 | 0.08 | 92.96 | 0 | 48.2 | |
| 28/09/2024 07:00 | 27.14 | 0.08 | 93.39 | 0 | 47.4 | |
| 28/09/2024 08:00 | 30.68 | 0.16 | 94.93 | 0 | 42.4 | |
| 28/09/2024 09:00 | 41.14 | 0.15 | 101.15 | 0 | 29.1 | |
| 28/09/2024 10:00 | 41.21 | 0.29 | 101.56 | 0 | 28.9 | |
| 28/09/2024 11:00 | 41.22 | 0.27 | 101 | 0 | 28.2 | |
| 28/09/2024 12:00 | 27.26 | 0.88 | 93.95 | 0 | 45.3 | |
| 28/09/2024 13:00 | 41.32 | 0.91 | 98.73 | 0 | 28.6 | |
| 28/09/2024 14:00 | 41.27 | 0.09 | 100.8 | 0 | 28.2 | |
| 28/09/2024 15:00 | 41.31 | 0.05 | 101 | 0 | 28.5 | |
| 28/09/2024 16:00 | 41.32 | 0.13 | 100.86 | 0 | 28.4 | |
| 28/09/2024 17:00 | 41.29 | 0.16 | 100.82 | 0 | 28.2 | |
| 28/09/2024 18:00 | 41.72 | 0.05 | 100.78 | 0 | 28.1 | |
| 28/09/2024 19:00 | 41.77 | 0 | 100.65 | 0 | 28.1 | |
| 28/09/2024 20:00 | 41.81 | 0 | 100.5 | 0 | 28.1 | |
| 28/09/2024 21:00 | 41.83 | 0 | 100.93 | 0 | 28.1 | |
| 28/09/2024 22:00 | 41.77 | 0 | 101.1 | 0 | 27.9 | |
| 28/09/2024 23:00 | 38.15 | 0.07 | 100.1 | 0 | 30.8 | |
| 29/09/2024 00:00 | 27.83 | 0.18 | 94.01 | 0 | 43.8 | GT11 S/D |
| Minimum | 27.14 | 0 | 92.88 | 0 | 27.9 | |
| MinDate | 28/09/2024 07:00 | 28/09/2024 19:00 | 28/09/2024 05:00 | 28/09/2024 00:00 | 28/09/2024 22:00 | |
| Maximum | 41.83 | 0.91 | 101.56 | 0 | 48.2 | |
| MaxDate | 28/09/2024 21:00 | 28/09/2024 13:00 | 28/09/2024 10:00 | 28/09/2024 00:00 | 28/09/2024 06:00 | |
| Avq | 35.4 | 0.19 | 97.52 | 0 | 36.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.8 | 0.2 | 3.7 | 0 | 9.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/09/2024 00:00 | 28.12 | 0.15 | 92.78 | 0 | 40.8 | |
| 28/09/2024 01:00 | 27.9 | 0.12 | 92.46 | 0 | 41.2 | |
| 28/09/2024 02:00 | 27.94 | 0.13 | 92.33 | 0 | 40.8 | |
| 28/09/2024 03:00 | 27.9 | 0.15 | 92.33 | 0 | 40.9 | |
| 28/09/2024 04:00 | 27.71 | 0.21 | 92.36 | 0 | 40.6 | |
| 28/09/2024 05:00 | 27.58 | 0.18 | 92.22 | 0 | 41.2 | |
| 28/09/2024 06:00 | 27.44 | 0.07 | 92.22 | 0 | 41.6 | |
| 28/09/2024 07:00 | 27.08 | 0.11 | 92.54 | 0 | 41 | |
| 28/09/2024 08:00 | 30.63 | 0.23 | 93.98 | 0 | 36.9 | |
| 28/09/2024 09:00 | 41.06 | 0.34 | 99.7 | 0 | 25.4 | |
| 28/09/2024 10:00 | 41.14 | 0.42 | 100 | 0 | 25.5 | |
| 28/09/2024 11:00 | 41.15 | 0.36 | 99.58 | 0 | 24.6 | |
| 28/09/2024 12:00 | 27.22 | 0.14 | 92.97 | 0 | 39.7 | |
| 28/09/2024 13:00 | 41.23 | 0.01 | 97.45 | 0 | 24.8 | |
| 28/09/2024 14:00 | 41.2 | 0.39 | 99.17 | 0 | 24.3 | |
| 28/09/2024 15:00 | 41.24 | 0.14 | 99.51 | 0 | 25 | |
| 28/09/2024 16:00 | 41.25 | 0.18 | 99.36 | 0 | 24.9 | |
| 28/09/2024 17:00 | 41.23 | 0.19 | 99.38 | 0 | 24.7 | |
| 28/09/2024 18:00 | 41.64 | 0.08 | 99.35 | 0 | 24.9 | |
| 28/09/2024 19:00 | 41.7 | 0 | 99.18 | 0 | 24.7 | |
| 28/09/2024 20:00 | 41.74 | 0 | 99.12 | 0 | 24.6 | |
| 28/09/2024 21:00 | 41.75 | 0 | 99.37 | 0 | 24.5 | |
| 28/09/2024 22:00 | 41.69 | 0 | 99.47 | 0 | 24.3 | |
| 28/09/2024 23:00 | 38.08 | 0 | 98.41 | 0 | 27.1 | |
| 29/09/2024 00:00 | 27.77 | 0 | 92.98 | 0 | 38.2 | |
| Minimum | 27.08 | 0 | 92.22 | 0 | 24.3 | |
| MinDate | 28/09/2024 07:00 | 28/09/2024 19:00 | 28/09/2024 05:00 | 28/09/2024 00:00 | 28/09/2024 14:00 | |
| Maximum | 41.75 | 0.42 | 100 | 0 | 41.6 | |
| MaxDate | 28/09/2024 21:00 | 28/09/2024 10:00 | 28/09/2024 10:00 | 28/09/2024 00:00 | 28/09/2024 06:00 | |
| Avq | 35.34 | 0.14 | 96.33 | 0 | 31.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.8 | 0.1 | 3.4 | 0 | 7.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/09/2024 00:00 | 27.83 | 0.18 | 94.01 | 0 | 43.8 | |
| 29/09/2024 01:00 | 27.88 | 0.23 | 93.43 | 0 | 43.5 | |
| 29/09/2024 02:00 | 27.84 | 0.22 | 93.4 | 0 | 43.8 | |
| 29/09/2024 03:00 | 27.87 | 0.26 | 93.36 | 0 | 43.8 | |
| 29/09/2024 04:00 | 27.75 | 0.27 | 93.36 | 0 | 44.2 | |
| 29/09/2024 05:00 | 27.75 | 0.49 | 93.36 | 0 | 44.1 | |
| 29/09/2024 06:00 | 27.71 | 0.21 | 93.35 | 0 | 44.1 | |
| 29/09/2024 07:00 | 27.69 | 0.27 | 93.7 | 0 | 43.5 | |
| 29/09/2024 08:00 | 27.83 | 0.23 | 94.17 | 0 | 42.8 | |
| 29/09/2024 09:00 | 27.98 | 0.26 | 94.32 | 0 | 42.8 | |
| 29/09/2024 10:00 | 28.01 | 0.34 | 94.33 | 0 | 42.5 | |
| 29/09/2024 11:00 | 28.04 | 0.46 | 94.35 | 0 | 41.7 | |
| 29/09/2024 12:00 | 28.12 | 0.54 | 94.26 | 0 | 40.4 | |
| 29/09/2024 13:00 | 28.2 | 0.45 | 93.92 | 0 | 39.2 | |
| 29/09/2024 14:00 | 28.13 | 0.16 | 93.74 | 0 | 39.4 | |
| 29/09/2024 15:00 | 28.22 | 0.03 | 93.55 | 0 | 39.4 | |
| 29/09/2024 16:00 | 28.21 | 0.01 | 93.49 | 0 | 39.6 | |
| 29/09/2024 17:00 | 28.19 | 0.01 | 93.22 | 0 | 40 | |
| 29/09/2024 18:00 | 38.6 | 0.02 | 97.18 | 0 | 30.8 | |
| 29/09/2024 19:00 | 41.86 | 0.02 | 100.48 | 0 | 26.8 | |
| 29/09/2024 20:00 | 41.85 | 0.02 | 100.79 | 0 | 26 | |
| 29/09/2024 21:00 | 41.99 | 0.05 | 101.23 | 0 | 25.9 | |
| 29/09/2024 22:00 | 35.06 | 0.07 | 98.82 | 0 | 32.5 | |
| 29/09/2024 23:00 | 28.09 | 0.17 | 93.94 | 0 | 40.8 | |
| 30/09/2024 00:00 | 28.08 | 0.26 | 93.56 | 0 | 40.8 | |
| Minimum | 0 | 0 | 93.88 | 1.3 | 26.7 | |
| MinDate | 29/05/2024 01:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 15:00 | 29/05/2024 23:00 | |
| Maximum | 40 | 0.19 | 95.98 | 1.4 | 44.9 | |
| MaxDate | 30/05/2024 00:00 | 29/05/2024 06:00 | 29/05/2024 14:00 | 29/05/2024 09:00 | 29/05/2024 12:00 | |
| Avg | 22.28 | 0.01 | 95.18 | 1.3 | 30.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.1 | 0 | 0.6 | 0.1 | 5.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/09/2024 00:00 | 27.77 | 0 | 92.98 | 0 | 38.2 | |
| 29/09/2024 01:00 | 27.81 | 0 | 92.38 | 0 | 38 | |
| 29/09/2024 02:00 | 27.76 | 0 | 92.35 | 0 | 38.2 | |
| 29/09/2024 03:00 | 27.81 | 0 | 92.34 | 0 | 38 | |
| 29/09/2024 04:00 | 27.68 | 0 | 92.34 | 0 | 38.2 | |
| 29/09/2024 05:00 | 27.69 | 0 | 92.35 | 0 | 38.2 | |
| 29/09/2024 06:00 | 27.64 | 0 | 92.35 | 0 | 38.2 | |
| 29/09/2024 07:00 | 27.63 | 0 | 92.64 | 0 | 37.4 | |
| 29/09/2024 08:00 | 27.77 | 0.05 | 93.03 | 0 | 37.2 | |
| 29/09/2024 09:00 | 27.92 | 0.12 | 93.21 | 0 | 37.9 | |
| 29/09/2024 10:00 | 27.96 | 0.19 | 93.23 | 0 | 37.7 | |
| 29/09/2024 11:00 | 27.98 | 0.27 | 93.36 | 0 | 37.2 | |
| 29/09/2024 12:00 | 28.06 | 0.3 | 93.32 | 0 | 35.9 | |
| 29/09/2024 13:00 | 28.15 | 0.26 | 93.06 | 0 | 34.8 | |
| 29/09/2024 14:00 | 28.07 | 0.33 | 92.88 | 0 | 35 | |
| 29/09/2024 15:00 | 28.15 | 0.03 | 92.76 | 0 | 34.9 | |
| 29/09/2024 16:00 | 28.15 | 0.04 | 92.8 | 0 | 35.1 | |
| 29/09/2024 17:00 | 28.13 | 0.03 | 92.63 | 0 | 35.6 | |
| 29/09/2024 18:00 | 38.53 | 0.01 | 96.29 | 0 | 27.8 | |
| 29/09/2024 19:00 | 41.79 | 0 | 99.07 | 0 | 23.6 | |
| 29/09/2024 20:00 | 41.78 | 0 | 99.26 | 0 | 23 | |
| 29/09/2024 21:00 | 41.92 | 0 | 99.6 | 0 | 23 | |
| 29/09/2024 22:00 | 34.98 | 0 | 97.28 | 0 | 29.1 | |
| 29/09/2024 23:00 | 28.03 | 0.01 | 92.88 | 0 | 36.1 | |
| 30/09/2024 00:00 | 28.02 | 0.05 | 92.52 | 0 | 36 | |
| Minimum | 7.84 | --- | 93.91 | 0 | 18.9 | |
| MinDate | 30/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 00:00 | 29/05/2024 23:00 | |
| Maximum | 47.72 | --- | 95.92 | 0 | 39.8 | |
| MaxDate | 29/05/2024 06:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 04:00 | |
| Avg | 36.95 | --- | 95.16 | 0 | 28.6 | |
| Num | 25 | 0 | 24 | 24 | 24 | |
| Data[%] | 100 | --- | 96 | 96 | 96 | |
| STD | 9 | --- | 0.5 | 0 | 9.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/09/2024 00:00 | 28.08 | 0.26 | 93.56 | 0 | 40.8 | |
| 30/09/2024 01:00 | 28.07 | 0.29 | 93.51 | 0 | 40.6 | |
| 30/09/2024 02:00 | 28.14 | 0.27 | 93.53 | 0 | 40.2 | |
| 30/09/2024 03:00 | 28.09 | 0.21 | 93.55 | 0 | 40.2 | |
| 30/09/2024 04:00 | 28.07 | 0.23 | 93.55 | 0 | 40.2 | |
| 30/09/2024 05:00 | 28.07 | 0.48 | 93.48 | 0 | 40.4 | |
| 30/09/2024 06:00 | 28.1 | 0.1 | 93.59 | 0 | 40.2 | |
| 30/09/2024 07:00 | 28.26 | 0.2 | 93.86 | 0 | 39 | |
| 30/09/2024 08:00 | 30.95 | 0.2 | 94.84 | 0 | 34.3 | |
| 30/09/2024 09:00 | 34.51 | 0.32 | 96.56 | 0 | 22.2 | |
| 30/09/2024 10:00 | 34.62 | 0.4 | 96.65 | 0 | 22.3 | |
| 30/09/2024 11:00 | 34.6 | 0.37 | 96.74 | 0 | 22.3 | |
| 30/09/2024 12:00 | 22.15 | 0.44 | 93.33 | 0 | 45.8 | |
| 30/09/2024 13:00 | 34.84 | 0.25 | 96.15 | 0 | 24.4 | |
| 30/09/2024 14:00 | 34.76 | 0.16 | 96.7 | 0 | 22.8 | |
| 30/09/2024 15:00 | 34.75 | 0.16 | 96.18 | 0 | 22.7 | |
| 30/09/2024 16:00 | 34.66 | 0.18 | 96.06 | 0 | 22.6 | |
| 30/09/2024 17:00 | 34.52 | 0.15 | 95.78 | 0 | 22.3 | |
| 30/09/2024 18:00 | 34.49 | 0 | 95.6 | 0 | 22.1 | |
| 30/09/2024 19:00 | 34.34 | 0 | 95.36 | 0 | 21.7 | |
| 30/09/2024 20:00 | 34.37 | 0 | 95.54 | 0 | 21.6 | |
| 30/09/2024 21:00 | 34.51 | 0 | 96.09 | 0 | 21.5 | |
| 30/09/2024 22:00 | 34.5 | 0 | 96.24 | 0 | 21.4 | |
| 30/09/2024 23:00 | 31.76 | 0.17 | 94.94 | 0 | 27.8 | |
| 01/10/2024 00:00 | 47.18 | 0.07 | 96.59 | 0 | 32.5 | |
| Minimum | 8.32 | 0 | 94.2 | 1.3 | 25.5 | |
| MinDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 00:00 | 30/05/2024 22:00 | |
| Maximum | 48.02 | 0.38 | 96.03 | 1.5 | 43.9 | |
| MaxDate | 30/05/2024 06:00 | 30/05/2024 06:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 37.19 | 0.02 | 95.04 | 1.4 | 32.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.5 | 0.1 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/09/2024 00:00 | 28.02 | 0.05 | 92.52 | 0 | 36 | |
| 30/09/2024 01:00 | 28.01 | 0.02 | 92.47 | 0 | 35.9 | |
| 30/09/2024 02:00 | 28.08 | 0.02 | 92.48 | 0 | 35.6 | |
| 30/09/2024 03:00 | 28.03 | 0 | 92.53 | 0 | 35.3 | |
| 30/09/2024 04:00 | 28 | 0.01 | 92.54 | 0 | 35.3 | |
| 30/09/2024 05:00 | 28.01 | 0.02 | 92.46 | 0 | 35.5 | |
| 30/09/2024 06:00 | 28.04 | 0.03 | 92.58 | 0 | 35.5 | |
| 30/09/2024 07:00 | 28.2 | 0.15 | 92.92 | 0 | 34.5 | |
| 30/09/2024 08:00 | 30.9 | 0.25 | 93.89 | 0 | 30.6 | |
| 30/09/2024 09:00 | 34.44 | 0.35 | 95.16 | 0 | 19 | |
| 30/09/2024 10:00 | 34.55 | 0.39 | 95.28 | 0 | 19 | |
| 30/09/2024 11:00 | 34.53 | 0.39 | 95.25 | 0 | 19 | |
| 30/09/2024 12:00 | 22.09 | 0.36 | 92.34 | 0 | 44.2 | |
| 30/09/2024 13:00 | 34.76 | 0.29 | 94.88 | 0 | 21.1 | |
| 30/09/2024 14:00 | 34.69 | 0.44 | 94.97 | 0 | 19.2 | |
| 30/09/2024 15:00 | 34.68 | 0.06 | 94.62 | 0 | 19.2 | |
| 30/09/2024 16:00 | 34.59 | 0.05 | 94.56 | 0 | 19.1 | |
| 30/09/2024 17:00 | 34.45 | 0.03 | 94.33 | 0 | 18.7 | |
| 30/09/2024 18:00 | 34.42 | 0 | 94.18 | 0 | 18.7 | |
| 30/09/2024 19:00 | 34.27 | 0 | 93.91 | 0 | 18.3 | |
| 30/09/2024 20:00 | 34.31 | 0 | 93.96 | 0 | 18.4 | |
| 30/09/2024 21:00 | 34.44 | 0 | 94.41 | 0 | 18.3 | |
| 30/09/2024 22:00 | 34.43 | 0 | 94.52 | 0 | 18.3 | |
| 30/09/2024 23:00 | 31.65 | 0 | 93.06 | 0 | 25.2 | |
| 01/10/2024 00:00 | 2 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | --- | 94.25 | 0 | 20.5 | |
| MinDate | 30/05/2024 01:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 09:00 | 30/05/2024 19:00 | |
| Maximum | 39.65 | --- | 96.1 | 0 | 39.7 | |
| MaxDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 22.18 | --- | 95.12 | 0 | 24.5 | |
| Num | 25 | 0 | 16 | 16 | 16 | |
| Data[%] | 100 | --- | 64 | 64 | 64 | |
| STD | 16.1 | --- | 0.5 | 0 | 6.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/10/2024 00:00 | 47.18 | 0.07 | 96.59 | 0 | 32.5 | |
| 01/10/2024 01:00 | 48.86 | 0 | 96.37 | 0 | 32.7 | |
| 01/10/2024 02:00 | 48.88 | 0 | 96.97 | 0 | 32.5 | |
| 01/10/2024 03:00 | 48.86 | 0 | 97.06 | 0 | 32.4 | |
| 01/10/2024 04:00 | 48.85 | 0 | 97.01 | 0 | 32.2 | |
| 01/10/2024 05:00 | 48.88 | 0.19 | 97.25 | 0 | 32.4 | |
| 01/10/2024 06:00 | 48.89 | 0 | 97.31 | 0 | 32.3 | |
| 01/10/2024 07:00 | 39.25 | 0.04 | 96.74 | 0 | 35.2 | |
| 01/10/2024 08:00 | 34.46 | 0.09 | 95.81 | 0 | 22.4 | |
| 01/10/2024 09:00 | 34.59 | 0.04 | 96.43 | 0 | 21.1 | |
| 01/10/2024 10:00 | 34.64 | 0.18 | 96.94 | 0 | 21.2 | |
| 01/10/2024 11:00 | 34.59 | 0.25 | 96.91 | 0 | 21.2 | |
| 01/10/2024 12:00 | 22.11 | 0.27 | 92.9 | 0 | 44.7 | |
| 01/10/2024 13:00 | 34.56 | 0.02 | 95.17 | 0 | 23.2 | |
| 01/10/2024 14:00 | 34.58 | 0.02 | 96.74 | 0 | 20.8 | |
| 01/10/2024 15:00 | 34.62 | 0.2 | 96.4 | 0 | 20.9 | |
| 01/10/2024 16:00 | 34.56 | 0.05 | 95.95 | 0 | 21 | |
| 01/10/2024 17:00 | 34.5 | 0 | 95.61 | 0 | 20.8 | |
| 01/10/2024 18:00 | 34.5 | 0 | 95.62 | 0 | 20.8 | |
| 01/10/2024 19:00 | 34.34 | 0 | 95.6 | 0 | 20.7 | |
| 01/10/2024 20:00 | 34.32 | 0 | 95.61 | 0 | 20.6 | |
| 01/10/2024 21:00 | 34.4 | 0.11 | 96.22 | 0 | 20.6 | |
| 01/10/2024 22:00 | 34.48 | 0.13 | 96.2 | 0 | 20.5 | |
| 01/10/2024 23:00 | 34.45 | 0.03 | 96.22 | 0 | 20.6 | |
| 02/10/2024 00:00 | 8.43 | 0.22 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 8.43 | 0 | 92.9 | 0 | 20.5 | |
| MinDate | 02/10/2024 00:00 | 01/10/2024 01:00 | 01/10/2024 12:00 | 01/10/2024 00:00 | 01/10/2024 22:00 | |
| Maximum | 48.89 | 0.27 | 97.31 | 0 | 44.7 | |
| MaxDate | 01/10/2024 06:00 | 01/10/2024 12:00 | 01/10/2024 06:00 | 01/10/2024 00:00 | 01/10/2024 12:00 | |
| Avg | 37.11 | 0.08 | 96.23 | 0 | 26 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.3 | 0.1 | 0.9 | 0 | 6.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/10/2024 00:00 | 2 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 07:00 | 12.27 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/10/2024 08:00 | 34.37 | 0 | 94.88 | 0 | 25.8 | |
| 01/10/2024 09:00 | 34.52 | 0 | 94.79 | 0 | 24.6 | |
| 01/10/2024 10:00 | 34.58 | 0.03 | 95.32 | 0 | 24.7 | |
| 01/10/2024 11:00 | 34.53 | 0.08 | 95.21 | 0 | 24.6 | |
| 01/10/2024 12:00 | 22.07 | 0.03 | 91.69 | 0 | 48.2 | |
| 01/10/2024 13:00 | 34.48 | 0 | 93.79 | 0 | 26.2 | |
| 01/10/2024 14:00 | 34.51 | 0.38 | 94.98 | 0 | 23.9 | |
| 01/10/2024 15:00 | 34.56 | 0.12 | 94.73 | 0 | 23.8 | |
| 01/10/2024 16:00 | 34.49 | 0.01 | 94.28 | 0 | 23.9 | |
| 01/10/2024 17:00 | 34.43 | 0 | 93.88 | 0 | 23.5 | |
| 01/10/2024 18:00 | 34.44 | 0 | 93.9 | 0 | 23.4 | |
| 01/10/2024 19:00 | 34.27 | 0 | 93.91 | 0 | 23.1 | |
| 01/10/2024 20:00 | 34.25 | 0 | 93.93 | 0 | 22.9 | |
| 01/10/2024 21:00 | 34.33 | 0 | 94.44 | 0 | 22.8 | |
| 01/10/2024 22:00 | 34.42 | 0 | 94.41 | 0 | 22.9 | |
| 01/10/2024 23:00 | 34.39 | 0 | 94.39 | 0 | 22.8 | |
| 02/10/2024 00:00 | 40.24 | 0 | 95.21 | 0 | 40.6 | |
| Minimum | 0 | 0 | 91.69 | 0 | 22.8 | |
| MinDate | 01/10/2024 01:00 | 01/10/2024 00:00 | 01/10/2024 12:00 | 01/10/2024 08:00 | 01/10/2024 21:00 | |
| Maximum | 40.24 | 0.38 | 95.32 | 0 | 48.2 | |
| MaxDate | 02/10/2024 00:00 | 01/10/2024 14:00 | 01/10/2024 10:00 | 01/10/2024 08:00 | 01/10/2024 12:00 | |
| Avg | 23.73 | 0.03 | 94.34 | 0 | 26.3 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.8 | 0.1 | 0.9 | 0 | 7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/10/2024 00:00 | 8.43 | 0.22 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 01:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 02:00 | 0 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 03:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 04:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 05:00 | 0 | 0.52 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 07:00 | 12.86 | 0.18 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/10/2024 08:00 | 34.35 | 0 | 96.15 | 0 | 28.4 | |
| 02/10/2024 09:00 | 34.43 | 0.01 | 96.53 | 0 | 26.8 | |
| 02/10/2024 10:00 | 34.51 | 0.02 | 96.76 | 0 | 26.9 | |
| 02/10/2024 11:00 | 34.52 | 0.01 | 96.71 | 0 | 26.9 | |
| 02/10/2024 12:00 | 22.17 | 0.05 | 93.32 | 0 | 49.6 | |
| 02/10/2024 13:00 | 34.76 | 0 | 95.96 | 0 | 29 | |
| 02/10/2024 14:00 | 34.69 | 0 | 96.41 | 0 | 27.2 | |
| 02/10/2024 15:00 | 34.67 | 0 | 96.1 | 0 | 27.3 | |
| 02/10/2024 16:00 | 34.57 | 0 | 95.72 | 0 | 26.9 | |
| 02/10/2024 17:00 | 34.44 | 0 | 95.51 | 0 | 26.5 | |
| 02/10/2024 18:00 | 34.42 | 0 | 95.42 | 0 | 26 | |
| 02/10/2024 19:00 | 34.12 | 0 | 95.3 | 0 | 25.7 | |
| 02/10/2024 20:00 | 34.21 | 0 | 95.29 | 0 | 25.3 | |
| 02/10/2024 21:00 | 34.36 | 0 | 95.76 | 0 | 25.2 | |
| 02/10/2024 22:00 | 34.39 | 0 | 95.9 | 0 | 25.2 | |
| 02/10/2024 23:00 | 34.29 | 0 | 95.96 | 0 | 25.3 | |
| 03/10/2024 00:00 | 40.19 | 0 | 96.43 | 0 | 38.6 | |
| Minimum | 0 | 0 | 93.32 | 0 | 25.2 | |
| MinDate | 02/10/2024 01:00 | 02/10/2024 06:00 | 02/10/2024 12:00 | 02/10/2024 08:00 | 02/10/2024 21:00 | |
| Maximum | 40.19 | 0.52 | 96.76 | 0 | 49.6 | |
| MaxDate | 03/10/2024 00:00 | 02/10/2024 05:00 | 02/10/2024 10:00 | 02/10/2024 08:00 | 02/10/2024 12:00 | |
| Avg | 24.02 | 0.06 | 95.84 | 0 | 28.6 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.4 | 0.1 | 0.8 | 0 | 6.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/10/2024 00:00 | 40.24 | 0 | 95.21 | 0 | 40.6 | |
| 02/10/2024 01:00 | 48.49 | 0 | 95.11 | 0 | 42.6 | |
| 02/10/2024 02:00 | 48.57 | 0 | 95.37 | 0 | 42.8 | |
| 02/10/2024 03:00 | 48.68 | 0 | 95.54 | 0 | 43.3 | |
| 02/10/2024 04:00 | 48.68 | 0.02 | 95.65 | 0 | 43 | |
| 02/10/2024 05:00 | 48.61 | 0.04 | 95.95 | 0 | 42.8 | |
| 02/10/2024 06:00 | 48.71 | 0.01 | 95.91 | 0 | 42.5 | |
| 02/10/2024 07:00 | 37.1 | 0 | 94.92 | 0 | 39.9 | |
| 02/10/2024 08:00 | 34.28 | 0.01 | 94.35 | 0 | 24.7 | |
| 02/10/2024 09:00 | 34.37 | 0.04 | 94.72 | 0 | 22.9 | |
| 02/10/2024 10:00 | 34.45 | 0.09 | 95.02 | 0 | 23 | |
| 02/10/2024 11:00 | 34.46 | 0.11 | 95.05 | 0 | 22.9 | |
| 02/10/2024 12:00 | 22.12 | 0.1 | 92.13 | 0 | 46.8 | |
| 02/10/2024 13:00 | 34.69 | 0.09 | 94.73 | 0 | 24.9 | |
| 02/10/2024 14:00 | 34.63 | 0.38 | 94.95 | 0 | 22.8 | |
| 02/10/2024 15:00 | 34.6 | 0.11 | 94.8 | 0 | 22.8 | |
| 02/10/2024 16:00 | 34.51 | 0.09 | 94.54 | 0 | 22.7 | |
| 02/10/2024 17:00 | 34.37 | 0.04 | 94.3 | 0 | 22.4 | |
| 02/10/2024 18:00 | 34.35 | 0 | 94.16 | 0 | 22.1 | |
| 02/10/2024 19:00 | 34.05 | 0 | 94.05 | 0 | 22 | |
| 02/10/2024 20:00 | 34.13 | 0 | 94.07 | 0 | 21.8 | |
| 02/10/2024 21:00 | 34.29 | 0 | 94.41 | 0 | 21.8 | |
| 02/10/2024 22:00 | 34.33 | 0 | 94.54 | 0 | 21.7 | |
| 02/10/2024 23:00 | 34.23 | 0 | 94.64 | 0 | 21.5 | |
| 03/10/2024 00:00 | 8.28 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 8.28 | 0 | 92.13 | 0 | 21.5 | |
| MinDate | 03/10/2024 00:00 | 02/10/2024 00:00 | 02/10/2024 12:00 | 02/10/2024 00:00 | 02/10/2024 23:00 | |
| Maximum | 48.71 | 0.38 | 95.95 | 0 | 46.8 | |
| MaxDate | 02/10/2024 06:00 | 02/10/2024 14:00 | 02/10/2024 05:00 | 02/10/2024 00:00 | 02/10/2024 12:00 | |
| Avg | 36.61 | 0.05 | 94.76 | 0 | 30.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0 | 10 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/10/2024 00:00 | 40.19 | 0 | 96.43 | 0 | 38.6 | |
| 03/10/2024 01:00 | 48.29 | 0 | 96.34 | 0 | 36.4 | |
| 03/10/2024 02:00 | 48.38 | 0 | 96.66 | 0 | 36.3 | |
| 03/10/2024 03:00 | 48.52 | 0 | 96.94 | 0 | 36.2 | |
| 03/10/2024 04:00 | 48.51 | 0 | 96.83 | 0 | 36.1 | |
| 03/10/2024 05:00 | 48.59 | 0.32 | 96.83 | 0 | 36 | |
| 03/10/2024 06:00 | 48.59 | 0 | 97.31 | 0 | 36 | |
| 03/10/2024 07:00 | 38.52 | 0 | 96.8 | 0 | 37.6 | |
| 03/10/2024 08:00 | 34.59 | 0 | 96.04 | 0 | 26.9 | |
| 03/10/2024 09:00 | 34.64 | 0 | 96.24 | 0 | 25.1 | |
| 03/10/2024 10:00 | 34.64 | 0 | 96.02 | 0 | 25.1 | |
| 03/10/2024 11:00 | 34.62 | 0 | 96.58 | 0 | 24.9 | |
| 03/10/2024 12:00 | 21.92 | 0.02 | 93.11 | 0 | 49 | |
| 03/10/2024 13:00 | 34.61 | 0 | 95.71 | 0 | 26.7 | |
| 03/10/2024 14:00 | 34.74 | 0 | 96.64 | 0 | 25.1 | |
| 03/10/2024 15:00 | 34.73 | 0 | 96.44 | 0 | 25.2 | |
| 03/10/2024 16:00 | 34.69 | 0 | 96.33 | 0 | 25.1 | |
| 03/10/2024 17:00 | 34.6 | 0 | 96.01 | 0 | 25 | |
| 03/10/2024 18:00 | 34.51 | 0 | 95.59 | 0 | 24.6 | |
| 03/10/2024 19:00 | 34.24 | 0 | 95.39 | 0 | 24.2 | |
| 03/10/2024 20:00 | 34.25 | 0 | 95.43 | 0 | 23.9 | |
| 03/10/2024 21:00 | 34.42 | 0 | 95.95 | 0 | 23.7 | |
| 03/10/2024 22:00 | 34.47 | 0 | 96.01 | 0 | 23.6 | |
| 03/10/2024 23:00 | 34.45 | 0 | 95.97 | 0 | 23.5 | |
| 04/10/2024 00:00 | 7.78 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.78 | 0 | 93.11 | 0 | 23.5 | |
| MinDate | 04/10/2024 00:00 | 03/10/2024 00:00 | 03/10/2024 12:00 | 03/10/2024 00:00 | 03/10/2024 23:00 | |
| Maximum | 48.59 | 0.32 | 97.31 | 0 | 49 | |
| MaxDate | 03/10/2024 05:00 | 03/10/2024 05:00 | 03/10/2024 06:00 | 03/10/2024 00:00 | 03/10/2024 12:00 | |
| Avg | 36.7 | 0.02 | 96.15 | 0 | 29.8 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0 | 7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/10/2024 00:00 | 8.28 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 04:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 05:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 06:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 07:00 | 11.95 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/10/2024 08:00 | 34.5 | 0.02 | 95.18 | 0 | 25.8 | |
| 03/10/2024 09:00 | 34.58 | 0.06 | 94.95 | 0 | 24.1 | |
| 03/10/2024 10:00 | 34.58 | 0.01 | 94.65 | 0 | 24 | |
| 03/10/2024 11:00 | 34.55 | 0.04 | 95.16 | 0 | 23.8 | |
| 03/10/2024 12:00 | 21.9 | 0.09 | 91.93 | 0 | 49.1 | |
| 03/10/2024 13:00 | 34.52 | 0.05 | 94.57 | 0 | 25.4 | |
| 03/10/2024 14:00 | 34.67 | 0.33 | 95.31 | 0 | 23.9 | |
| 03/10/2024 15:00 | 34.66 | 0.06 | 95.22 | 0 | 23.9 | |
| 03/10/2024 16:00 | 34.62 | 0.06 | 95.12 | 0 | 23.8 | |
| 03/10/2024 17:00 | 34.53 | 0.04 | 94.84 | 0 | 23.6 | |
| 03/10/2024 18:00 | 34.44 | 0.01 | 94.53 | 0 | 23.3 | |
| 03/10/2024 19:00 | 34.18 | 0 | 94.32 | 0 | 23 | |
| 03/10/2024 20:00 | 34.18 | 0 | 94.34 | 0 | 22.8 | |
| 03/10/2024 21:00 | 34.36 | 0 | 94.79 | 0 | 22.7 | |
| 03/10/2024 22:00 | 34.42 | 0 | 94.84 | 0 | 22.6 | |
| 03/10/2024 23:00 | 34.39 | 0 | 94.78 | 0 | 22.5 | |
| 04/10/2024 00:00 | 40.47 | 0 | 95.43 | 0 | 40.7 | |
| Minimum | 0 | 0 | 91.93 | 0 | 22.5 | |
| MinDate | 03/10/2024 01:00 | 03/10/2024 00:00 | 03/10/2024 12:00 | 03/10/2024 08:00 | 03/10/2024 23:00 | |
| Maximum | 40.47 | 0.33 | 95.43 | 0 | 49.1 | |
| MaxDate | 04/10/2024 00:00 | 03/10/2024 14:00 | 04/10/2024 00:00 | 03/10/2024 08:00 | 03/10/2024 12:00 | |
| Avg | 23.99 | 0.03 | 94.7 | 0 | 26.2 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 0.8 | 0 | 7.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/10/2024 00:00 | 7.78 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 05:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 07:00 | 13.1 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/10/2024 08:00 | 34.36 | 0.01 | 95.92 | 0 | 27.6 | |
| 04/10/2024 09:00 | 34.57 | 0.02 | 96.24 | 0 | 26.6 | |
| 04/10/2024 10:00 | 34.63 | 0 | 95.87 | 0 | 26.8 | |
| 04/10/2024 11:00 | 34.53 | 0 | 95.99 | 0 | 26.6 | |
| 04/10/2024 12:00 | 21.96 | 0 | 92.93 | 0 | 50.6 | |
| 04/10/2024 13:00 | 34.76 | 0 | 95.74 | 0 | 28.3 | |
| 04/10/2024 14:00 | 34.65 | 0 | 95.77 | 0 | 27 | |
| 04/10/2024 15:00 | 34.6 | 0 | 95.15 | 0 | 26.6 | |
| 04/10/2024 16:00 | 34.52 | 0 | 94.87 | 0 | 26.3 | |
| 04/10/2024 17:00 | 34.39 | 0 | 94.85 | 0 | 26.1 | |
| 04/10/2024 18:00 | 34.42 | 0 | 95.04 | 0 | 25.7 | |
| 04/10/2024 19:00 | 34.2 | 0 | 94.95 | 0 | 25.6 | |
| 04/10/2024 20:00 | 34.23 | 0 | 94.92 | 0 | 25.5 | |
| 04/10/2024 21:00 | 34.46 | 0 | 95.41 | 0 | 25.6 | |
| 04/10/2024 22:00 | 37.6 | 0 | 97.3 | 0 | 27.1 | |
| 04/10/2024 23:00 | 39.29 | 0 | 98.7 | 0 | 28.1 | |
| 05/10/2024 00:00 | 28.66 | 0.03 | 94.8 | 0 | 44.5 | |
| Minimum | 0 | 0 | 92.93 | 0 | 25.5 | |
| MinDate | 04/10/2024 01:00 | 04/10/2024 01:00 | 04/10/2024 12:00 | 04/10/2024 08:00 | 04/10/2024 20:00 | |
| Maximum | 39.29 | 0.26 | 98.7 | 0 | 50.6 | |
| MaxDate | 04/10/2024 23:00 | 04/10/2024 05:00 | 04/10/2024 23:00 | 04/10/2024 08:00 | 04/10/2024 12:00 | |
| Avg | 23.87 | 0.02 | 95.56 | 0 | 29.1 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.4 | 0.1 | 1.2 | 0 | 7.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/10/2024 00:00 | 40.47 | 0 | 95.43 | 0 | 40.7 | |
| 04/10/2024 01:00 | 48.44 | 0 | 95.2 | 0 | 41.9 | |
| 04/10/2024 02:00 | 48.48 | 0 | 95.42 | 0 | 41.7 | |
| 04/10/2024 03:00 | 48.51 | 0 | 95.5 | 0 | 41.9 | |
| 04/10/2024 04:00 | 48.64 | 0.03 | 95.52 | 0 | 41.8 | |
| 04/10/2024 05:00 | 48.74 | 0.06 | 95.49 | 0 | 41.7 | |
| 04/10/2024 06:00 | 48.84 | 0.07 | 95.68 | 0 | 41.9 | |
| 04/10/2024 07:00 | 37.64 | 0.07 | 95.03 | 0 | 39.7 | |
| 04/10/2024 08:00 | 34.3 | 0.09 | 94.34 | 0 | 23.5 | |
| 04/10/2024 09:00 | 34.51 | 0.15 | 94.94 | 0 | 22.4 | |
| 04/10/2024 10:00 | 34.58 | 0.12 | 94.56 | 0 | 22.8 | |
| 04/10/2024 11:00 | 34.46 | 0.07 | 94.53 | 0 | 22.5 | |
| 04/10/2024 12:00 | 21.91 | 0.08 | 91.82 | 0 | 47.9 | |
| 04/10/2024 13:00 | 34.69 | 0.11 | 94.46 | 0 | 24 | |
| 04/10/2024 14:00 | 34.58 | 0.23 | 94.42 | 0 | 22.5 | |
| 04/10/2024 15:00 | 34.53 | 0.11 | 94.05 | 0 | 22.3 | |
| 04/10/2024 16:00 | 34.45 | 0.04 | 93.71 | 0 | 22.1 | |
| 04/10/2024 17:00 | 34.33 | 0 | 93.74 | 0 | 21.9 | |
| 04/10/2024 18:00 | 34.36 | 0 | 93.92 | 0 | 21.6 | |
| 04/10/2024 19:00 | 34.13 | 0.01 | 93.81 | 0 | 21.6 | |
| 04/10/2024 20:00 | 34.16 | 0.02 | 93.85 | 0 | 21.6 | |
| 04/10/2024 21:00 | 34.4 | 0.05 | 94.19 | 0 | 21.7 | |
| 04/10/2024 22:00 | 37.52 | 0.14 | 95.97 | 0 | 23.4 | |
| 04/10/2024 23:00 | 39.21 | 0.2 | 97.28 | 0 | 24.4 | |
| 05/10/2024 00:00 | 28.59 | 0.27 | 93.72 | 0 | 39.2 | |
| Minimum | 21.91 | 0 | 91.82 | 0 | 21.6 | |
| MinDate | 04/10/2024 12:00 | 04/10/2024 00:00 | 04/10/2024 12:00 | 04/10/2024 00:00 | 04/10/2024 18:00 | |
| Maximum | 48.84 | 0.27 | 97.28 | 0 | 47.9 | |
| MaxDate | 04/10/2024 06:00 | 05/10/2024 00:00 | 04/10/2024 23:00 | 04/10/2024 00:00 | 04/10/2024 12:00 | |
| Avg | 37.78 | 0.08 | 94.66 | 0 | 30.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.1 | 0.1 | 1.1 | 0 | 9.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/10/2024 00:00 | 28.66 | 0.03 | 94.8 | 0 | 44.5 | |
| 05/10/2024 01:00 | 31.31 | 0 | 93.8 | 0 | 37.1 | |
| 05/10/2024 02:00 | 31.78 | 0 | 93.99 | 0 | 35.1 | |
| 05/10/2024 03:00 | 31.65 | 0 | 93.84 | 0 | 35.4 | |
| 05/10/2024 04:00 | 31.6 | 0 | 93.46 | 0 | 35.2 | |
| 05/10/2024 05:00 | 31.58 | 0.19 | 93.61 | 0 | 35.4 | |
| 05/10/2024 06:00 | 32.05 | 0 | 93.91 | 0 | 33.3 | |
| 05/10/2024 07:00 | 32.17 | 0 | 93.91 | 0 | 30.6 | |
| 05/10/2024 08:00 | 45.89 | 0 | 100.89 | 0 | 32.9 | |
| 05/10/2024 09:00 | 46.26 | 0 | 102.84 | 0 | 33.8 | |
| 05/10/2024 10:00 | 46.27 | 0 | 102.77 | 0 | 34.6 | |
| 05/10/2024 11:00 | 46.13 | 0.03 | 102.65 | 0 | 35.6 | |
| 05/10/2024 12:00 | 33.18 | 0.09 | 96.53 | 0 | 27.7 | |
| 05/10/2024 13:00 | 46.43 | 0.09 | 101.64 | 0 | 37.4 | |
| 05/10/2024 14:00 | 46.12 | 0.07 | 102.51 | 0 | 36.1 | |
| 05/10/2024 15:00 | 46.18 | 0.03 | 102.36 | 0 | 35.8 | |
| 05/10/2024 16:00 | 46.03 | 0.03 | 102.06 | 0 | 34.8 | |
| 05/10/2024 17:00 | 46.34 | 0 | 102.77 | 0 | 29.5 | |
| 05/10/2024 18:00 | 46.24 | 0 | 103.11 | 0 | 29.2 | |
| 05/10/2024 19:00 | 46.07 | 0 | 102.93 | 0 | 29.1 | |
| 05/10/2024 20:00 | 46.23 | 0 | 103.17 | 0 | 29.1 | |
| 05/10/2024 21:00 | 46.4 | 0 | 103.81 | 0 | 28.9 | |
| 05/10/2024 22:00 | 46.47 | 0 | 104.06 | 0 | 28.7 | |
| 05/10/2024 23:00 | 46.51 | 0 | 104.11 | 0 | 28.6 | |
| 06/10/2024 00:00 | 32.23 | 0.1 | 96.35 | 0 | 30.9 | |
| Minimum | 28.66 | 0 | 93.46 | 0 | 27.7 | |
| MinDate | 05/10/2024 00:00 | 05/10/2024 01:00 | 05/10/2024 04:00 | 05/10/2024 00:00 | 05/10/2024 12:00 | |
| Maximum | 46.51 | 0.19 | 104.11 | 0 | 44.5 | |
| MaxDate | 05/10/2024 23:00 | 05/10/2024 05:00 | 05/10/2024 23:00 | 05/10/2024 00:00 | 05/10/2024 00:00 | |
| Avg | 40.39 | 0.03 | 99.44 | 0 | 33.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0 | 4.3 | 0 | 3.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/10/2024 00:00 | 28.59 | 0.27 | 93.72 | 0 | 39.2 | |
| 05/10/2024 01:00 | 31.22 | 0.22 | 92.84 | 0 | 33.4 | |
| 05/10/2024 02:00 | 31.71 | 0.18 | 93.06 | 0 | 31.7 | |
| 05/10/2024 03:00 | 31.59 | 0.2 | 92.9 | 0 | 31.8 | |
| 05/10/2024 04:00 | 31.53 | 0.11 | 92.68 | 0 | 31.7 | |
| 05/10/2024 05:00 | 31.51 | 0.06 | 92.66 | 0 | 32 | |
| 05/10/2024 06:00 | 31.98 | 0.08 | 92.93 | 0 | 30.3 | |
| 05/10/2024 07:00 | 32.11 | 0.13 | 92.96 | 0 | 28.5 | |
| 05/10/2024 08:00 | 45.84 | 0.18 | 99.91 | 0 | 33.8 | |
| 05/10/2024 09:00 | 46.18 | 0.2 | 101.78 | 0 | 35.3 | |
| 05/10/2024 10:00 | 46.2 | 0.25 | 101.77 | 0 | 36.4 | |
| 05/10/2024 11:00 | 46.05 | 0.29 | 101.6 | 0 | 37.7 | |
| 05/10/2024 12:00 | 33.17 | 0.31 | 95.46 | 0 | 25.2 | |
| 05/10/2024 13:00 | 46.63 | 0.35 | 100.5 | 0 | 41.2 | |
| 05/10/2024 14:00 | 46.05 | 0.67 | 101.4 | 0 | 38.2 | |
| 05/10/2024 15:00 | 46.1 | 0.06 | 101.46 | 0 | 37.7 | |
| 05/10/2024 16:00 | 45.96 | 0.05 | 101.14 | 0 | 36.6 | |
| 05/10/2024 17:00 | 46.26 | 0 | 101.83 | 0 | 30.3 | |
| 05/10/2024 18:00 | 46.16 | 0 | 101.97 | 0 | 29.9 | |
| 05/10/2024 19:00 | 45.99 | 0 | 101.76 | 0 | 29.6 | |
| 05/10/2024 20:00 | 46.16 | 0 | 101.99 | 0 | 29.7 | |
| 05/10/2024 21:00 | 46.32 | 0 | 102.56 | 0 | 29.8 | |
| 05/10/2024 22:00 | 46.39 | 0 | 102.76 | 0 | 29.7 | |
| 05/10/2024 23:00 | 46.42 | 0 | 102.81 | 0 | 29.4 | |
| 06/10/2024 00:00 | 32.17 | 0 | 95.27 | 0 | 28.3 | |
| Minimum | 28.59 | 0 | 92.66 | 0 | 25.2 | |
| MinDate | 05/10/2024 00:00 | 05/10/2024 17:00 | 05/10/2024 05:00 | 05/10/2024 00:00 | 05/10/2024 12:00 | |
| Maximum | 46.63 | 0.67 | 102.81 | 0 | 41.2 | |
| MaxDate | 05/10/2024 13:00 | 05/10/2024 14:00 | 05/10/2024 23:00 | 05/10/2024 00:00 | 05/10/2024 13:00 | |
| Avg | 40.33 | 0.14 | 98.39 | 0 | 32.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0.2 | 4.2 | 0 | 4.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/10/2024 00:00 | 32.23 | 0.1 | 96.35 | 0 | 30.9 | |
| 06/10/2024 01:00 | 32.24 | 0.04 | 94.32 | 0 | 29.7 | |
| 06/10/2024 02:00 | 32.24 | 0.03 | 94.06 | 0 | 29.4 | |
| 06/10/2024 03:00 | 32.06 | 0.05 | 94.06 | 0 | 30.4 | |
| 06/10/2024 04:00 | 31.86 | 0.03 | 93.9 | 0 | 31.1 | |
| 06/10/2024 05:00 | 31.67 | 0.42 | 93.89 | 0 | 32.2 | |
| 06/10/2024 06:00 | 31.37 | 0.02 | 93.93 | 0 | 33 | |
| 06/10/2024 07:00 | 30.94 | 0.01 | 93.89 | 0 | 34.4 | |
| 06/10/2024 08:00 | 30.72 | 0 | 93.92 | 0 | 34.5 | |
| 06/10/2024 09:00 | 30.63 | 0 | 93.6 | 0 | 33.4 | |
| 06/10/2024 10:00 | 30.64 | 0 | 93.48 | 0 | 32.3 | |
| 06/10/2024 11:00 | 30.67 | 0 | 93.79 | 0 | 31.5 | |
| 06/10/2024 12:00 | 30.64 | 0 | 93.89 | 0 | 31.6 | |
| 06/10/2024 13:00 | 30.69 | 0.01 | 94.03 | 0 | 30.6 | |
| 06/10/2024 14:00 | 30.69 | 0.03 | 94.13 | 0 | 30 | |
| 06/10/2024 15:00 | 30.75 | 0 | 93.47 | 0 | 29.8 | |
| 06/10/2024 16:00 | 30.71 | 0 | 93.04 | 0 | 33.8 | |
| 06/10/2024 17:00 | 30.69 | 0 | 93.34 | 0 | 33.7 | |
| 06/10/2024 18:00 | 44.54 | 0 | 100.43 | 0 | 26.6 | |
| 06/10/2024 19:00 | 44.72 | 0 | 102.47 | 0 | 26.6 | |
| 06/10/2024 20:00 | 44.75 | 0 | 102.55 | 0 | 26.5 | |
| 06/10/2024 21:00 | 44.74 | 0 | 102.8 | 0 | 26.4 | |
| 06/10/2024 22:00 | 44.77 | 0 | 102.94 | 0 | 26.2 | |
| 06/10/2024 23:00 | 30.7 | 0.01 | 95.79 | 0 | 34.2 | |
| 07/10/2024 00:00 | 30.63 | 0 | 93.6 | 0 | 34.4 | |
| Minimum | 30.63 | 0 | 93.04 | 0 | 26.2 | |
| MinDate | 06/10/2024 09:00 | 06/10/2024 08:00 | 06/10/2024 16:00 | 06/10/2024 00:00 | 06/10/2024 22:00 | |
| Maximum | 44.77 | 0.42 | 102.94 | 0 | 34.5 | |
| MaxDate | 06/10/2024 22:00 | 06/10/2024 05:00 | 06/10/2024 22:00 | 06/10/2024 00:00 | 06/10/2024 08:00 | |
| Avg | 33.85 | 0.03 | 95.67 | 0 | 30.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.6 | 0.1 | 3.4 | 0 | 2.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/10/2024 00:00 | 32.17 | 0 | 95.27 | 0 | 28.3 | |
| 06/10/2024 01:00 | 32.17 | 0 | 93.48 | 0 | 27.3 | |
| 06/10/2024 02:00 | 32.18 | 0 | 93.3 | 0 | 27.1 | |
| 06/10/2024 03:00 | 31.99 | 0 | 93.25 | 0 | 27.9 | |
| 06/10/2024 04:00 | 31.8 | 0 | 93.03 | 0 | 28.4 | |
| 06/10/2024 05:00 | 31.6 | 0 | 93 | 0 | 29.3 | |
| 06/10/2024 06:00 | 31.31 | 0 | 93.07 | 0 | 29.9 | |
| 06/10/2024 07:00 | 30.88 | 0.01 | 93.04 | 0 | 30.9 | |
| 06/10/2024 08:00 | 30.66 | 0.06 | 93.01 | 0 | 30.8 | |
| 06/10/2024 09:00 | 30.56 | 0.06 | 92.74 | 0 | 30.2 | |
| 06/10/2024 10:00 | 30.58 | 0.04 | 92.66 | 0 | 29.4 | |
| 06/10/2024 11:00 | 30.62 | 0.04 | 92.94 | 0 | 28.7 | |
| 06/10/2024 12:00 | 30.58 | 0.05 | 93.01 | 0 | 28.8 | |
| 06/10/2024 13:00 | 30.63 | 0.06 | 93.18 | 0 | 27.8 | |
| 06/10/2024 14:00 | 30.63 | 0.39 | 93.25 | 0 | 27.4 | |
| 06/10/2024 15:00 | 30.68 | 0.04 | 92.69 | 0 | 27.3 | |
| 06/10/2024 16:00 | 30.65 | 0 | 92.36 | 0 | 30.3 | |
| 06/10/2024 17:00 | 30.64 | 0 | 92.69 | 0 | 30 | |
| 06/10/2024 18:00 | 44.5 | 0 | 99.55 | 0 | 26 | |
| 06/10/2024 19:00 | 44.64 | 0 | 101.37 | 0 | 25.7 | |
| 06/10/2024 20:00 | 44.67 | 0 | 101.46 | 0 | 25.7 | |
| 06/10/2024 21:00 | 44.66 | 0 | 101.62 | 0 | 25.4 | |
| 06/10/2024 22:00 | 44.7 | 0 | 101.69 | 0 | 25.4 | |
| 06/10/2024 23:00 | 30.63 | 0 | 94.81 | 0 | 30.5 | |
| 07/10/2024 00:00 | 30.56 | 0 | 92.74 | 0 | 30.8 | |
| Minimum | 30.56 | 0 | 92.36 | 0 | 25.4 | |
| MinDate | 06/10/2024 09:00 | 06/10/2024 00:00 | 06/10/2024 16:00 | 06/10/2024 00:00 | 06/10/2024 21:00 | |
| Maximum | 44.7 | 0.39 | 101.69 | 0 | 30.9 | |
| MaxDate | 06/10/2024 22:00 | 06/10/2024 14:00 | 06/10/2024 22:00 | 06/10/2024 00:00 | 06/10/2024 07:00 | |
| Avg | 33.79 | 0.03 | 94.77 | 0 | 28.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.6 | 0.1 | 3.3 | 0 | 1.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/10/2024 00:00 | 30.63 | 0 | 93.6 | 0 | 34.4 | |
| 07/10/2024 01:00 | 30.65 | 0 | 93.56 | 0 | 34.3 | |
| 07/10/2024 02:00 | 30.6 | 0.01 | 93.61 | 0 | 34.5 | |
| 07/10/2024 03:00 | 30.61 | 0.01 | 93.43 | 0 | 34.7 | |
| 07/10/2024 04:00 | 30.62 | 0.06 | 93.44 | 0 | 35 | |
| 07/10/2024 05:00 | 30.63 | 0.32 | 93.34 | 0 | 35.2 | |
| 07/10/2024 06:00 | 30.61 | 0 | 92.96 | 0 | 34.6 | |
| 07/10/2024 07:00 | 30.84 | 0 | 93.36 | 0 | 33.1 | |
| 07/10/2024 08:00 | 42.63 | 0 | 99.94 | 0 | 27.5 | |
| 07/10/2024 09:00 | 34.18 | 0 | 96.01 | 0 | 22.2 | |
| 07/10/2024 10:00 | 34.24 | 0 | 95.74 | 0 | 22.1 | |
| 07/10/2024 11:00 | 34.45 | 0.01 | 96.05 | 0 | 22.1 | |
| 07/10/2024 12:00 | 22.22 | 0.1 | 92.91 | 0 | 48.1 | |
| 07/10/2024 13:00 | 34.67 | 0 | 95.7 | 0 | 24.2 | |
| 07/10/2024 14:00 | 34.57 | 0 | 96.47 | 0 | 22.2 | |
| 07/10/2024 15:00 | 34.61 | 0 | 96.16 | 0 | 22.2 | |
| 07/10/2024 16:00 | 34.57 | 0.05 | 95.91 | 0 | 21.5 | |
| 07/10/2024 17:00 | 34.47 | 0.12 | 95.77 | 0 | 21.1 | |
| 07/10/2024 18:00 | 34.42 | 0 | 95.72 | 0 | 20.9 | |
| 07/10/2024 19:00 | 34.21 | 0 | 95.56 | 0 | 20.9 | |
| 07/10/2024 20:00 | 34.31 | 0 | 95.62 | 0 | 20.8 | |
| 07/10/2024 21:00 | 34.52 | 0 | 95.82 | 0 | 20.8 | |
| 07/10/2024 22:00 | 34.48 | 0.05 | 95.86 | 0 | 20.8 | |
| 07/10/2024 23:00 | 34.46 | 0.02 | 95.82 | 0 | 21.1 | |
| 08/10/2024 00:00 | 40.37 | 0.01 | 95.93 | 0 | 35.1 | |
| Minimum | 22.22 | 0 | 92.91 | 0 | 20.8 | |
| MinDate | 07/10/2024 12:00 | 07/10/2024 00:00 | 07/10/2024 12:00 | 07/10/2024 00:00 | 07/10/2024 20:00 | |
| Maximum | 42.63 | 0.32 | 99.94 | 0 | 48.1 | |
| MaxDate | 07/10/2024 08:00 | 07/10/2024 05:00 | 07/10/2024 08:00 | 07/10/2024 00:00 | 07/10/2024 12:00 | |
| Avg | 33.3 | 0.03 | 95.13 | 0 | 27.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 3.7 | 0.1 | 1.6 | 0 | 7.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/10/2024 00:00 | 30.56 | 0 | 92.74 | 0 | 30.8 | |
| 07/10/2024 01:00 | 30.59 | 0 | 92.75 | 0 | 30.6 | |
| 07/10/2024 02:00 | 30.53 | 0 | 92.79 | 0 | 30.8 | |
| 07/10/2024 03:00 | 30.54 | 0 | 92.58 | 0 | 31.1 | |
| 07/10/2024 04:00 | 30.56 | 0 | 92.51 | 0 | 31.4 | |
| 07/10/2024 05:00 | 30.58 | 0 | 92.51 | 0 | 31.2 | |
| 07/10/2024 06:00 | 30.54 | 0 | 92.13 | 0 | 31.1 | |
| 07/10/2024 07:00 | 30.77 | 0 | 92.5 | 0 | 29.6 | |
| 07/10/2024 08:00 | 42.57 | 0 | 98.89 | 0 | 26.7 | |
| 07/10/2024 09:00 | 34.11 | 0.01 | 94.88 | 0 | 19.1 | |
| 07/10/2024 10:00 | 34.18 | 0.03 | 94.48 | 0 | 19.1 | |
| 07/10/2024 11:00 | 34.39 | 0.04 | 94.78 | 0 | 19.3 | |
| 07/10/2024 12:00 | 22.15 | 0.07 | 92 | 0 | 45.9 | |
| 07/10/2024 13:00 | 34.59 | 0.04 | 94.55 | 0 | 21.3 | |
| 07/10/2024 14:00 | 34.51 | 0.26 | 94.89 | 0 | 19.2 | |
| 07/10/2024 15:00 | 34.55 | 0.09 | 94.72 | 0 | 19.2 | |
| 07/10/2024 16:00 | 34.5 | 0.08 | 94.6 | 0 | 18.4 | |
| 07/10/2024 17:00 | 34.41 | 0.05 | 94.47 | 0 | 18.1 | |
| 07/10/2024 18:00 | 34.36 | 0 | 94.44 | 0 | 18.1 | |
| 07/10/2024 19:00 | 34.15 | 0 | 94.32 | 0 | 18 | |
| 07/10/2024 20:00 | 34.24 | 0 | 94.35 | 0 | 18.1 | |
| 07/10/2024 21:00 | 34.45 | 0 | 94.54 | 0 | 18.1 | |
| 07/10/2024 22:00 | 34.43 | 0.03 | 94.61 | 0 | 18.1 | |
| 07/10/2024 23:00 | 34.39 | 0.08 | 94.45 | 0 | 18.2 | |
| 08/10/2024 00:00 | 7.87 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 7.87 | 0 | 92 | 0 | 18 | |
| MinDate | 08/10/2024 00:00 | 07/10/2024 00:00 | 07/10/2024 12:00 | 07/10/2024 00:00 | 07/10/2024 19:00 | |
| Maximum | 42.57 | 0.26 | 98.89 | 0 | 45.9 | |
| MaxDate | 07/10/2024 08:00 | 07/10/2024 14:00 | 07/10/2024 08:00 | 07/10/2024 00:00 | 07/10/2024 12:00 | |
| Avg | 31.94 | 0.03 | 93.98 | 0 | 24.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.1 | 0.1 | 1.5 | 0 | 7.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/10/2024 00:00 | 40.37 | 0.01 | 95.93 | 0 | 35.1 | |
| 08/10/2024 01:00 | 47.79 | 0 | 95.83 | 0 | 31.9 | |
| 08/10/2024 02:00 | 47.92 | 0 | 96.26 | 0 | 31.8 | |
| 08/10/2024 03:00 | 48.19 | 0 | 96.49 | 0 | 31.8 | |
| 08/10/2024 04:00 | 48.11 | 0 | 96.24 | 0 | 31.6 | |
| 08/10/2024 05:00 | 48.26 | 0.26 | 96.58 | 0 | 31.8 | |
| 08/10/2024 06:00 | 48.52 | 0 | 96.75 | 0 | 31.7 | |
| 08/10/2024 07:00 | 38.22 | 0 | 96.31 | 0 | 34.8 | |
| 08/10/2024 08:00 | 34.45 | 0 | 94.95 | 0 | 22.4 | |
| 08/10/2024 09:00 | 34.56 | 0 | 95.54 | 0 | 20.9 | |
| 08/10/2024 10:00 | 34.57 | 0 | 95.79 | 0 | 20.8 | |
| 08/10/2024 11:00 | 34.56 | 0 | 95.93 | 0 | 20.8 | |
| 08/10/2024 12:00 | 22.17 | 0 | 92.66 | 0 | 46.9 | |
| 08/10/2024 13:00 | 34.73 | 0 | 95.48 | 0 | 22.7 | |
| 08/10/2024 14:00 | 34.68 | 0 | 96.25 | 0 | 20.7 | |
| 08/10/2024 15:00 | 34.71 | 0 | 96.22 | 0 | 20.6 | |
| 08/10/2024 16:00 | 34.68 | 0 | 96.02 | 0 | 20.6 | |
| 08/10/2024 17:00 | 34.54 | 0 | 96.02 | 0 | 20.5 | |
| 08/10/2024 18:00 | 34.37 | 0 | 95.95 | 0 | 20.4 | |
| 08/10/2024 19:00 | 34.26 | 0 | 95.78 | 0 | 20.2 | |
| 08/10/2024 20:00 | 34.24 | 0 | 95.66 | 0 | 20.2 | |
| 08/10/2024 21:00 | 34.41 | 0 | 95.98 | 0 | 20.1 | |
| 08/10/2024 22:00 | 34.42 | 0 | 95.85 | 0 | 20.2 | |
| 08/10/2024 23:00 | 34.38 | 0 | 96.05 | 0 | 20.2 | |
| 09/10/2024 00:00 | 8.32 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 SD |
| Minimum | 8.32 | 0 | 92.66 | 0 | 20.1 | |
| MinDate | 09/10/2024 00:00 | 08/10/2024 01:00 | 08/10/2024 12:00 | 08/10/2024 00:00 | 08/10/2024 21:00 | |
| Maximum | 48.52 | 0.26 | 96.75 | 0 | 46.9 | |
| MaxDate | 08/10/2024 06:00 | 08/10/2024 05:00 | 08/10/2024 06:00 | 08/10/2024 00:00 | 08/10/2024 12:00 | |
| Avg | 36.62 | 0.01 | 95.86 | 0 | 25.8 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 8.9 | 0.1 | 0.8 | 0 | 7.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/10/2024 00:00 | 7.87 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 07:00 | 12.37 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/10/2024 08:00 | 34.37 | 0 | 94.15 | 0 | 26.7 | |
| 08/10/2024 09:00 | 34.49 | 0 | 94.41 | 0 | 25.4 | |
| 08/10/2024 10:00 | 34.5 | 0.03 | 94.66 | 0 | 25.2 | |
| 08/10/2024 11:00 | 34.49 | 0.03 | 94.68 | 0 | 25.1 | |
| 08/10/2024 12:00 | 22.12 | 0.04 | 91.78 | 0 | 49.4 | |
| 08/10/2024 13:00 | 34.66 | 0.04 | 94.32 | 0 | 26.6 | |
| 08/10/2024 14:00 | 34.62 | 0.24 | 94.96 | 0 | 24.6 | |
| 08/10/2024 15:00 | 34.64 | 0.08 | 94.8 | 0 | 24.4 | |
| 08/10/2024 16:00 | 34.61 | 0.03 | 94.63 | 0 | 24.1 | |
| 08/10/2024 17:00 | 34.48 | 0 | 94.56 | 0 | 23.9 | |
| 08/10/2024 18:00 | 34.31 | 0 | 94.53 | 0 | 23.6 | |
| 08/10/2024 19:00 | 34.19 | 0 | 94.35 | 0 | 23.4 | |
| 08/10/2024 20:00 | 34.17 | 0 | 94.29 | 0 | 23.2 | |
| 08/10/2024 21:00 | 34.34 | 0 | 94.48 | 0 | 23.1 | |
| 08/10/2024 22:00 | 34.36 | 0 | 94.34 | 0 | 23.2 | |
| 08/10/2024 23:00 | 34.31 | 0 | 94.51 | 0 | 23.1 | |
| 09/10/2024 00:00 | 40.42 | 0 | 95.25 | 0 | 41.6 | |
| Minimum | 0 | 0 | 91.78 | 0 | 23.1 | |
| MinDate | 08/10/2024 01:00 | 08/10/2024 01:00 | 08/10/2024 12:00 | 08/10/2024 08:00 | 08/10/2024 21:00 | |
| Maximum | 40.42 | 0.24 | 95.25 | 0 | 49.4 | |
| MaxDate | 09/10/2024 00:00 | 08/10/2024 14:00 | 09/10/2024 00:00 | 08/10/2024 08:00 | 08/10/2024 12:00 | |
| Avg | 23.97 | 0.02 | 94.39 | 0 | 26.9 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 0.7 | 0 | 7.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/10/2024 00:00 | 8.32 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 05:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 06:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 07:00 | 11.91 | 0.25 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/10/2024 08:00 | 34.31 | 0 | 94.91 | 0 | 29.4 | |
| 09/10/2024 09:00 | 34.5 | 0.09 | 95.67 | 0 | 28.3 | |
| 09/10/2024 10:00 | 34.54 | 0.15 | 96.04 | 0 | 28 | |
| 09/10/2024 11:00 | 34.57 | 0.42 | 96.52 | 0 | 27.8 | |
| 09/10/2024 12:00 | 21.87 | 0.63 | 92.97 | 0 | 52.6 | |
| 09/10/2024 13:00 | 34.73 | 0.48 | 95.09 | 0 | 28.7 | |
| 09/10/2024 14:00 | 34.7 | 0.4 | 95.87 | 0 | 26.9 | |
| 09/10/2024 15:00 | 34.63 | 0.55 | 95.08 | 0 | 26.5 | |
| 09/10/2024 16:00 | 34.57 | 0.32 | 95.56 | 0 | 26.4 | |
| 09/10/2024 17:00 | 34.48 | 0.38 | 95.6 | 0 | 26.4 | |
| 09/10/2024 18:00 | 34.51 | 0.34 | 95.62 | 0 | 26.2 | |
| 09/10/2024 19:00 | 34.39 | 0.09 | 95.27 | 0 | 26.3 | |
| 09/10/2024 20:00 | 34.33 | 0 | 95 | 0 | 26.6 | |
| 09/10/2024 21:00 | 34.43 | 0 | 95.01 | 0 | 26.6 | |
| 09/10/2024 22:00 | 34.45 | 0 | 95.15 | 0 | 26.6 | |
| 09/10/2024 23:00 | 34.53 | 0 | 95.51 | 0 | 26.4 | |
| 10/10/2024 00:00 | 40.86 | 0.03 | 96.11 | 0 | 40.8 | |
| Minimum | 0 | 0 | 92.97 | 0 | 26.2 | |
| MinDate | 09/10/2024 01:00 | 09/10/2024 01:00 | 09/10/2024 12:00 | 09/10/2024 08:00 | 09/10/2024 18:00 | |
| Maximum | 40.86 | 0.63 | 96.52 | 0 | 52.6 | |
| MaxDate | 10/10/2024 00:00 | 09/10/2024 12:00 | 09/10/2024 11:00 | 09/10/2024 08:00 | 09/10/2024 12:00 | |
| Avg | 24.03 | 0.18 | 95.35 | 0 | 29.4 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.2 | 0.8 | 0 | 6.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/10/2024 00:00 | 40.42 | 0 | 95.25 | 0 | 41.6 | |
| 09/10/2024 01:00 | 48.52 | 0 | 95.07 | 0 | 42.8 | |
| 09/10/2024 02:00 | 48.43 | 0 | 95.43 | 0 | 42.6 | |
| 09/10/2024 03:00 | 48.41 | 0 | 95.43 | 0 | 42.5 | |
| 09/10/2024 04:00 | 48.65 | 0 | 95.11 | 0 | 43.2 | |
| 09/10/2024 05:00 | 48.8 | 0 | 95.26 | 0 | 43.2 | |
| 09/10/2024 06:00 | 48.91 | 0 | 95.43 | 0 | 44.3 | |
| 09/10/2024 07:00 | 38.49 | 0 | 94.82 | 0 | 42 | |
| 09/10/2024 08:00 | 34.23 | 0 | 93.28 | 0 | 24.9 | |
| 09/10/2024 09:00 | 34.43 | 0 | 94.17 | 0 | 23.8 | |
| 09/10/2024 10:00 | 34.48 | 0.03 | 94.53 | 0 | 23.5 | |
| 09/10/2024 11:00 | 34.51 | 0.19 | 95.06 | 0 | 23.3 | |
| 09/10/2024 12:00 | 21.82 | 0.23 | 92.04 | 0 | 50.9 | |
| 09/10/2024 13:00 | 34.66 | 0.14 | 94.07 | 0 | 24.2 | |
| 09/10/2024 14:00 | 34.63 | 0.39 | 94.39 | 0 | 22.2 | |
| 09/10/2024 15:00 | 34.57 | 0.03 | 93.71 | 0 | 22 | |
| 09/10/2024 16:00 | 34.51 | 0.01 | 94.13 | 0 | 22 | |
| 09/10/2024 17:00 | 34.41 | 0.06 | 94.13 | 0 | 21.9 | |
| 09/10/2024 18:00 | 34.45 | 0.05 | 94.07 | 0 | 21.7 | |
| 09/10/2024 19:00 | 34.33 | 0 | 93.91 | 0 | 21.9 | |
| 09/10/2024 20:00 | 34.27 | 0 | 93.69 | 0 | 22.2 | |
| 09/10/2024 21:00 | 34.36 | 0 | 93.62 | 0 | 22.3 | |
| 09/10/2024 22:00 | 34.38 | 0 | 93.67 | 0 | 22.3 | |
| 09/10/2024 23:00 | 34.47 | 0 | 94.05 | 0 | 22.1 | |
| 10/10/2024 00:00 | 7.86 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.86 | 0 | 92.04 | 0 | 21.7 | |
| MinDate | 10/10/2024 00:00 | 09/10/2024 00:00 | 09/10/2024 12:00 | 09/10/2024 00:00 | 09/10/2024 18:00 | |
| Maximum | 48.91 | 0.39 | 95.43 | 0 | 50.9 | |
| MaxDate | 09/10/2024 06:00 | 09/10/2024 14:00 | 09/10/2024 02:00 | 09/10/2024 00:00 | 09/10/2024 12:00 | |
| Avg | 36.68 | 0.05 | 94.35 | 0 | 30.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.8 | 0 | 10.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/10/2024 00:00 | 40.86 | 0.03 | 96.11 | 0 | 40.8 | |
| 10/10/2024 01:00 | 48.77 | 0 | 96.3 | 0 | 38.4 | |
| 10/10/2024 02:00 | 48.76 | 0 | 96.75 | 0 | 38.3 | |
| 10/10/2024 03:00 | 48.87 | 0 | 96.91 | 0 | 38.2 | |
| 10/10/2024 04:00 | 48.74 | 0 | 96.94 | 0 | 38.3 | |
| 10/10/2024 05:00 | 48.66 | 0.38 | 96.81 | 0 | 38.2 | |
| 10/10/2024 06:00 | 48.38 | 0 | 96.93 | 0 | 38.4 | |
| 10/10/2024 07:00 | 38.02 | 0 | 96.22 | 0 | 40.4 | |
| 10/10/2024 08:00 | 34.45 | 0 | 95.1 | 0 | 27.2 | |
| 10/10/2024 09:00 | 34.52 | 0 | 95.69 | 0 | 26.2 | |
| 10/10/2024 10:00 | 34.63 | 0 | 96.17 | 0 | 26.1 | |
| 10/10/2024 11:00 | 34.69 | 0.02 | 96.5 | 0 | 26.2 | |
| 10/10/2024 12:00 | 21.82 | 0.13 | 93.02 | 0 | 49.6 | |
| 10/10/2024 13:00 | 34.91 | 0.09 | 94.31 | 0 | 27.3 | |
| 10/10/2024 14:00 | 34.65 | 5.93 | 93.15 | 0 | 25.3 | |
| 10/10/2024 15:00 | 34.59 | 0.08 | 94.77 | 0 | 25 | |
| 10/10/2024 16:00 | 34.53 | 0 | 94.74 | 0 | 24.8 | |
| 10/10/2024 17:00 | 34.45 | 0 | 94.78 | 0 | 24.5 | |
| 10/10/2024 18:00 | 34.42 | 0 | 95.07 | 0 | 24.4 | |
| 10/10/2024 19:00 | 34.17 | 0 | 95.18 | 0 | 24.4 | |
| 10/10/2024 20:00 | 34.22 | 0 | 94.99 | 0 | 24.3 | |
| 10/10/2024 21:00 | 34.45 | 0 | 95.43 | 0 | 24.4 | |
| 10/10/2024 22:00 | 34.41 | 0 | 95.6 | 0 | 24.3 | |
| 10/10/2024 23:00 | 34.42 | 0 | 95.63 | 0 | 24.3 | |
| 11/10/2024 00:00 | 8.19 | 0.1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 8.19 | 0 | 93.02 | 0 | 24.3 | |
| MinDate | 11/10/2024 00:00 | 10/10/2024 01:00 | 10/10/2024 12:00 | 10/10/2024 00:00 | 10/10/2024 20:00 | |
| Maximum | 48.87 | 5.93 | 96.94 | 0 | 49.6 | |
| MaxDate | 10/10/2024 03:00 | 10/10/2024 14:00 | 10/10/2024 04:00 | 10/10/2024 00:00 | 10/10/2024 12:00 | |
| Avg | 36.74 | 0.27 | 95.55 | 0 | 30.8 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 1.2 | 1.1 | 0 | 7.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/10/2024 00:00 | 7.86 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 07:00 | 12.47 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 10/10/2024 08:00 | 34.37 | 0.01 | 94.56 | 0 | 25.9 | |
| 10/10/2024 09:00 | 34.46 | 0.07 | 94.85 | 0 | 24.8 | |
| 10/10/2024 10:00 | 34.56 | 0.13 | 95.22 | 0 | 24.7 | |
| 10/10/2024 11:00 | 34.62 | 0.16 | 95.49 | 0 | 24.7 | |
| 10/10/2024 12:00 | 21.77 | 0.16 | 92.32 | 0 | 49.2 | |
| 10/10/2024 13:00 | 34.86 | 0.11 | 93.7 | 0 | 25.6 | |
| 10/10/2024 14:00 | 34.59 | 0.48 | 91.74 | 0 | 23.9 | |
| 10/10/2024 15:00 | 34.53 | 0.1 | 93.4 | 0 | 23.5 | |
| 10/10/2024 16:00 | 34.47 | 0.18 | 93.5 | 0 | 23.3 | |
| 10/10/2024 17:00 | 34.38 | 0.18 | 93.49 | 0 | 23 | |
| 10/10/2024 18:00 | 34.35 | 0.22 | 93.79 | 0 | 23 | |
| 10/10/2024 19:00 | 34.1 | 0.25 | 93.88 | 0 | 22.9 | |
| 10/10/2024 20:00 | 34.15 | 0.29 | 93.63 | 0 | 22.9 | |
| 10/10/2024 21:00 | 34.38 | 0.31 | 94.08 | 0 | 23.1 | |
| 10/10/2024 22:00 | 34.35 | 0.34 | 94.18 | 0 | 23 | |
| 10/10/2024 23:00 | 34.36 | 0.36 | 94.18 | 0 | 23 | |
| 11/10/2024 00:00 | 40.69 | 0.39 | 95.03 | 0 | 42.6 | |
| Minimum | 0 | 0 | 91.74 | 0 | 22.9 | |
| MinDate | 10/10/2024 01:00 | 10/10/2024 00:00 | 10/10/2024 14:00 | 10/10/2024 08:00 | 10/10/2024 19:00 | |
| Maximum | 40.69 | 0.48 | 95.49 | 0 | 49.2 | |
| MaxDate | 11/10/2024 00:00 | 10/10/2024 14:00 | 10/10/2024 11:00 | 10/10/2024 08:00 | 10/10/2024 12:00 | |
| Avg | 23.97 | 0.15 | 93.94 | 0 | 26.4 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 1 | 0 | 7.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/10/2024 00:00 | 8.19 | 0.1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 01:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 02:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 03:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 05:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 07:00 | 10.97 | 0.24 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/10/2024 08:00 | 34.36 | 0.13 | 96.35 | 0 | 28.8 | |
| 11/10/2024 09:00 | 34.54 | 0.06 | 96.24 | 0 | 27.6 | |
| 11/10/2024 10:00 | 34.6 | 0.03 | 96.2 | 0 | 27.5 | |
| 11/10/2024 11:00 | 34.57 | 0.06 | 96.43 | 0 | 27.5 | |
| 11/10/2024 12:00 | 21.93 | 0.18 | 93.22 | 0 | 51.9 | |
| 11/10/2024 13:00 | 34.73 | 0.13 | 96.23 | 0 | 29.5 | |
| 11/10/2024 14:00 | 34.72 | 0.14 | 96.96 | 0 | 27.8 | |
| 11/10/2024 15:00 | 34.71 | 0.11 | 96.09 | 0 | 26.7 | |
| 11/10/2024 16:00 | 34.62 | 0.22 | 95.82 | 0 | 26.4 | |
| 11/10/2024 17:00 | 34.49 | 0.26 | 95.65 | 0 | 26 | |
| 11/10/2024 18:00 | 34.46 | 0.02 | 94.74 | 0 | 26.3 | |
| 11/10/2024 19:00 | 34.29 | 0 | 94.71 | 0 | 26 | |
| 11/10/2024 20:00 | 34.23 | 0 | 94.89 | 0 | 25.9 | |
| 11/10/2024 21:00 | 34.45 | 0.01 | 95.4 | 0 | 25.8 | |
| 11/10/2024 22:00 | 37.43 | 0 | 97.11 | 0 | 27 | |
| 11/10/2024 23:00 | 38.83 | 0.05 | 98.42 | 0 | 27.7 | |
| 12/10/2024 00:00 | 28.53 | 0.12 | 94.9 | 0 | 43.7 | |
| Minimum | 0 | 0 | 93.22 | 0 | 25.8 | |
| MinDate | 11/10/2024 01:00 | 11/10/2024 04:00 | 11/10/2024 12:00 | 11/10/2024 08:00 | 11/10/2024 21:00 | |
| Maximum | 38.83 | 0.33 | 98.42 | 0 | 51.9 | |
| MaxDate | 11/10/2024 23:00 | 11/10/2024 05:00 | 11/10/2024 23:00 | 11/10/2024 08:00 | 11/10/2024 12:00 | |
| Avg | 23.79 | 0.09 | 95.84 | 0 | 29.5 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 1.2 | 0 | 7.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/10/2024 00:00 | 40.69 | 0.39 | 95.03 | 0 | 42.6 | |
| 11/10/2024 01:00 | 48.86 | 0.43 | 95.57 | 0 | 42.9 | |
| 11/10/2024 02:00 | 48.97 | 0.45 | 95.92 | 0 | 43.4 | |
| 11/10/2024 03:00 | 48.99 | 0.43 | 96.01 | 0 | 42.9 | |
| 11/10/2024 04:00 | 48.98 | 0.43 | 95.96 | 0 | 42.9 | |
| 11/10/2024 05:00 | 48.95 | 0.47 | 95.92 | 0 | 42.9 | |
| 11/10/2024 06:00 | 48.95 | 0.45 | 96.22 | 0 | 43.6 | |
| 11/10/2024 07:00 | 39.44 | 0.51 | 95.95 | 0 | 39.5 | |
| 11/10/2024 08:00 | 34.28 | 0.54 | 94.71 | 0 | 24.2 | |
| 11/10/2024 09:00 | 34.47 | 0.49 | 94.89 | 0 | 23 | |
| 11/10/2024 10:00 | 34.54 | 0.49 | 94.87 | 0 | 22.9 | |
| 11/10/2024 11:00 | 34.51 | 0.53 | 95.08 | 0 | 22.9 | |
| 11/10/2024 12:00 | 21.9 | 0.55 | 92.27 | 0 | 48.4 | |
| 11/10/2024 13:00 | 34.64 | 0.57 | 95 | 0 | 24.6 | |
| 11/10/2024 14:00 | 34.65 | 0.76 | 95.43 | 0 | 23 | |
| 11/10/2024 15:00 | 34.65 | 0.06 | 94.83 | 0 | 21.8 | |
| 11/10/2024 16:00 | 34.56 | 0.04 | 94.72 | 0 | 21.6 | |
| 11/10/2024 17:00 | 34.42 | 0.01 | 94.62 | 0 | 21.2 | |
| 11/10/2024 18:00 | 34.4 | 0 | 93.63 | 0 | 21.7 | |
| 11/10/2024 19:00 | 34.22 | 0 | 93.69 | 0 | 21.6 | |
| 11/10/2024 20:00 | 34.17 | 0 | 93.89 | 0 | 21.6 | |
| 11/10/2024 21:00 | 34.39 | 0 | 94.27 | 0 | 21.5 | |
| 11/10/2024 22:00 | 37.36 | 0 | 95.88 | 0 | 22.9 | |
| 11/10/2024 23:00 | 38.77 | 0 | 97.18 | 0 | 23.5 | |
| 12/10/2024 00:00 | 28.48 | 0 | 93.88 | 0 | 38.3 | |
| Minimum | 21.9 | 0 | 92.27 | 0 | 21.2 | |
| MinDate | 11/10/2024 12:00 | 11/10/2024 18:00 | 11/10/2024 12:00 | 11/10/2024 00:00 | 11/10/2024 17:00 | |
| Maximum | 48.99 | 0.76 | 97.18 | 0 | 48.4 | |
| MaxDate | 11/10/2024 03:00 | 11/10/2024 14:00 | 11/10/2024 23:00 | 11/10/2024 00:00 | 11/10/2024 12:00 | |
| Avg | 37.93 | 0.3 | 95.02 | 0 | 30.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.2 | 0.3 | 1.1 | 0 | 10.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/10/2024 00:00 | 28.53 | 0.12 | 94.9 | 0 | 43.7 | |
| 12/10/2024 01:00 | 30.83 | 0.12 | 94.04 | 0 | 37.6 | |
| 12/10/2024 02:00 | 31.77 | 0.24 | 94.15 | 0 | 34.2 | |
| 12/10/2024 03:00 | 32.19 | 0.25 | 94.35 | 0 | 31.8 | |
| 12/10/2024 04:00 | 32.19 | 0.24 | 94.4 | 0 | 31.4 | |
| 12/10/2024 05:00 | 32.14 | 0.41 | 94.42 | 0 | 32.1 | |
| 12/10/2024 06:00 | 31.94 | 0.05 | 94.43 | 0 | 33 | |
| 12/10/2024 07:00 | 31.74 | 0.06 | 94.66 | 0 | 33.1 | |
| 12/10/2024 08:00 | 45.79 | 0.14 | 102.12 | 0 | 32.4 | |
| 12/10/2024 09:00 | 45.92 | 0.06 | 103.25 | 0 | 34.3 | |
| 12/10/2024 10:00 | 45.94 | 0.02 | 103.01 | 0 | 34.9 | |
| 12/10/2024 11:00 | 45.84 | 0.03 | 103 | 0 | 34.6 | |
| 12/10/2024 12:00 | 32.06 | 0.04 | 96.6 | 0 | 28.1 | |
| 12/10/2024 13:00 | 45.52 | 0 | 101.01 | 0 | 35.1 | |
| 12/10/2024 14:00 | 45.95 | 0 | 102.9 | 0 | 32.9 | |
| 12/10/2024 15:00 | 46.25 | 0.18 | 103.2 | 0 | 29.7 | |
| 12/10/2024 16:00 | 46.15 | 0.06 | 103.25 | 0 | 29.8 | |
| 12/10/2024 17:00 | 46.12 | 0 | 103.19 | 0 | 29.7 | |
| 12/10/2024 18:00 | 46.06 | 0 | 103.49 | 0 | 29.5 | |
| 12/10/2024 19:00 | 45.94 | 0 | 103.26 | 0 | 29.5 | |
| 12/10/2024 20:00 | 46.06 | 0 | 103.32 | 0 | 29.3 | |
| 12/10/2024 21:00 | 46.2 | 0 | 103.83 | 0 | 29.2 | |
| 12/10/2024 22:00 | 46.24 | 0 | 104.06 | 0 | 29 | |
| 12/10/2024 23:00 | 46.15 | 0 | 104.19 | 0 | 28.9 | |
| 13/10/2024 00:00 | 31.97 | 0.13 | 96.64 | 0 | 32.3 | |
| Minimum | 28.53 | 0 | 94.04 | 0 | 28.1 | |
| MinDate | 12/10/2024 00:00 | 12/10/2024 13:00 | 12/10/2024 01:00 | 12/10/2024 00:00 | 12/10/2024 12:00 | |
| Maximum | 46.25 | 0.41 | 104.19 | 0 | 43.7 | |
| MaxDate | 12/10/2024 15:00 | 12/10/2024 05:00 | 12/10/2024 23:00 | 12/10/2024 00:00 | 12/10/2024 00:00 | |
| Avg | 40.22 | 0.09 | 99.83 | 0 | 32.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0.1 | 4.2 | 0 | 3.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/10/2024 00:00 | 28.48 | 0 | 93.88 | 0 | 38.3 | |
| 12/10/2024 01:00 | 30.76 | 0 | 93.15 | 0 | 33.2 | |
| 12/10/2024 02:00 | 31.7 | 0 | 93.2 | 0 | 30.5 | |
| 12/10/2024 03:00 | 32.13 | 0 | 93.46 | 0 | 28.9 | |
| 12/10/2024 04:00 | 32.13 | 0 | 93.52 | 0 | 28.4 | |
| 12/10/2024 05:00 | 32.08 | 0 | 93.62 | 0 | 28.9 | |
| 12/10/2024 06:00 | 31.88 | 0 | 93.56 | 0 | 29.6 | |
| 12/10/2024 07:00 | 31.68 | 0.01 | 93.74 | 0 | 29.6 | |
| 12/10/2024 08:00 | 45.73 | 0.09 | 101.18 | 0 | 32.7 | |
| 12/10/2024 09:00 | 45.84 | 0.08 | 102.25 | 0 | 35.1 | |
| 12/10/2024 10:00 | 45.86 | 0.07 | 101.99 | 0 | 36.2 | |
| 12/10/2024 11:00 | 45.76 | 0.06 | 102.11 | 0 | 35.6 | |
| 12/10/2024 12:00 | 32.04 | 0.04 | 95.59 | 0 | 25.1 | |
| 12/10/2024 13:00 | 45.5 | 0.02 | 100.16 | 0 | 35.8 | |
| 12/10/2024 14:00 | 45.88 | 0.18 | 102.14 | 0 | 33.2 | |
| 12/10/2024 15:00 | 46.18 | 0.01 | 102.31 | 0 | 30.2 | |
| 12/10/2024 16:00 | 46.07 | 0 | 102.25 | 0 | 30.4 | |
| 12/10/2024 17:00 | 46.05 | 0 | 101.97 | 0 | 30 | |
| 12/10/2024 18:00 | 45.99 | 0 | 102.35 | 0 | 30 | |
| 12/10/2024 19:00 | 45.87 | 0 | 102.19 | 0 | 29.7 | |
| 12/10/2024 20:00 | 45.98 | 0 | 102.16 | 0 | 29.7 | |
| 12/10/2024 21:00 | 46.11 | 0 | 102.63 | 0 | 29.9 | |
| 12/10/2024 22:00 | 46.16 | 0 | 102.83 | 0 | 29.7 | |
| 12/10/2024 23:00 | 46.06 | 0.01 | 102.85 | 0 | 29.2 | |
| 13/10/2024 00:00 | 31.91 | 0.08 | 95.55 | 0 | 28.8 | |
| Minimum | 28.48 | 0 | 93.15 | 0 | 25.1 | |
| MinDate | 12/10/2024 00:00 | 12/10/2024 00:00 | 12/10/2024 01:00 | 12/10/2024 00:00 | 12/10/2024 12:00 | |
| Maximum | 46.18 | 0.18 | 102.85 | 0 | 38.3 | |
| MaxDate | 12/10/2024 15:00 | 12/10/2024 14:00 | 12/10/2024 23:00 | 12/10/2024 00:00 | 12/10/2024 00:00 | |
| Avg | 40.15 | 0.03 | 98.83 | 0 | 31.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0 | 4.1 | 0 | 3.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/10/2024 00:00 | 31.97 | 0.13 | 96.64 | 0 | 32.3 | |
| 13/10/2024 01:00 | 31.96 | 0.14 | 94.46 | 0 | 30.7 | |
| 13/10/2024 02:00 | 32.03 | 0.04 | 94.34 | 0 | 30.3 | |
| 13/10/2024 03:00 | 32.04 | 0.07 | 94.34 | 0 | 30.3 | |
| 13/10/2024 04:00 | 31.88 | 0.12 | 94.27 | 0 | 31.1 | |
| 13/10/2024 05:00 | 31.86 | 0.26 | 94.12 | 0 | 31.4 | |
| 13/10/2024 06:00 | 31.71 | 0 | 94.13 | 0 | 32 | |
| 13/10/2024 07:00 | 31.42 | 0 | 94.23 | 0 | 32.9 | |
| 13/10/2024 08:00 | 31.44 | 0.01 | 94.18 | 0 | 31.1 | |
| 13/10/2024 09:00 | 31.52 | 0 | 94.1 | 0 | 28.8 | |
| 13/10/2024 10:00 | 31.58 | 0 | 94.33 | 0 | 27.8 | |
| 13/10/2024 11:00 | 31.59 | 0 | 94.52 | 0 | 27.7 | |
| 13/10/2024 12:00 | 31.48 | 0.03 | 94.48 | 0 | 26.9 | |
| 13/10/2024 13:00 | 31.47 | 0 | 94.41 | 0 | 26.5 | |
| 13/10/2024 14:00 | 31.45 | 0 | 94.35 | 0 | 26.2 | |
| 13/10/2024 15:00 | 31.5 | 0 | 94.17 | 0 | 26.8 | |
| 13/10/2024 16:00 | 31.5 | 0.05 | 94.05 | 0 | 28 | |
| 13/10/2024 17:00 | 31.45 | 0.1 | 93.75 | 0 | 29.4 | |
| 13/10/2024 18:00 | 45.42 | 0.1 | 101.14 | 0 | 27.1 | |
| 13/10/2024 19:00 | 45.54 | 0.05 | 103.48 | 0 | 26.8 | |
| 13/10/2024 20:00 | 45.6 | 0.01 | 103.53 | 0 | 26.8 | |
| 13/10/2024 21:00 | 45.65 | 0.04 | 103.76 | 0 | 26.9 | |
| 13/10/2024 22:00 | 45.66 | 0 | 103.78 | 0 | 26.9 | |
| 13/10/2024 23:00 | 43.85 | 0 | 99.21 | 0 | 33.9 | |
| 14/10/2024 00:00 | 48.59 | 0 | 96.34 | 0 | 33.5 | |
| Minimum | 31.42 | 0 | 93.75 | 0 | 26.2 | |
| MinDate | 13/10/2024 07:00 | 13/10/2024 06:00 | 13/10/2024 17:00 | 13/10/2024 00:00 | 13/10/2024 14:00 | |
| Maximum | 48.59 | 0.26 | 103.78 | 0 | 33.9 | |
| MaxDate | 14/10/2024 00:00 | 13/10/2024 05:00 | 13/10/2024 22:00 | 13/10/2024 00:00 | 13/10/2024 23:00 | |
| Avg | 35.61 | 0.05 | 96.4 | 0 | 29.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.5 | 0.1 | 3.6 | 0 | 2.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/10/2024 00:00 | 31.91 | 0.08 | 95.55 | 0 | 28.8 | |
| 13/10/2024 01:00 | 31.9 | 0.1 | 93.64 | 0 | 27.3 | |
| 13/10/2024 02:00 | 31.97 | 0.04 | 93.54 | 0 | 27.2 | |
| 13/10/2024 03:00 | 31.98 | 0.07 | 93.53 | 0 | 27.2 | |
| 13/10/2024 04:00 | 31.81 | 0.08 | 93.42 | 0 | 27.8 | |
| 13/10/2024 05:00 | 31.8 | 0.05 | 93.28 | 0 | 27.9 | |
| 13/10/2024 06:00 | 31.65 | 0 | 93.23 | 0 | 28.5 | |
| 13/10/2024 07:00 | 31.36 | 0 | 93.35 | 0 | 29.1 | |
| 13/10/2024 08:00 | 31.37 | 0.06 | 93.45 | 0 | 27.4 | |
| 13/10/2024 09:00 | 31.53 | 0.11 | 93.4 | 0 | 25.7 | |
| 13/10/2024 10:00 | 31.51 | 0.17 | 93.57 | 0 | 25.1 | |
| 13/10/2024 11:00 | 31.52 | 0.11 | 93.76 | 0 | 24.4 | |
| 13/10/2024 12:00 | 31.41 | 0.18 | 93.66 | 0 | 23.9 | |
| 13/10/2024 13:00 | 31.4 | 0.16 | 93.58 | 0 | 23.4 | |
| 13/10/2024 14:00 | 31.38 | 0.51 | 93.58 | 0 | 23.4 | |
| 13/10/2024 15:00 | 31.44 | 0.06 | 93.51 | 0 | 24 | |
| 13/10/2024 16:00 | 31.43 | 0.06 | 93.35 | 0 | 25.2 | |
| 13/10/2024 17:00 | 31.38 | 0.02 | 93.11 | 0 | 26.2 | |
| 13/10/2024 18:00 | 45.36 | 0 | 100.25 | 0 | 27.1 | |
| 13/10/2024 19:00 | 45.47 | 0 | 102.3 | 0 | 26.6 | |
| 13/10/2024 20:00 | 45.52 | 0.02 | 102.31 | 0 | 26.4 | |
| 13/10/2024 21:00 | 45.57 | 0.01 | 102.44 | 0 | 26.7 | |
| 13/10/2024 22:00 | 45.6 | 0 | 102.58 | 0 | 27.1 | |
| 13/10/2024 23:00 | 9.3 | 0 | ShutDown | ShutDown | ShutDown | GT12_SD |
| 14/10/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12_SD |
| Minimum | 0 | 0 | 93.11 | 0 | 23.4 | |
| MinDate | 14/10/2024 00:00 | 13/10/2024 06:00 | 13/10/2024 17:00 | 13/10/2024 00:00 | 13/10/2024 13:00 | |
| Maximum | 45.6 | 0.51 | 102.58 | 0 | 29.1 | |
| MaxDate | 13/10/2024 22:00 | 13/10/2024 14:00 | 13/10/2024 22:00 | 13/10/2024 00:00 | 13/10/2024 07:00 | |
| Avg | 32.22 | 0.08 | 95.41 | 0 | 26.4 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 10.1 | 0.1 | 3.6 | 0 | 1.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/10/2024 00:00 | 48.59 | 0 | 96.34 | 0 | 33.5 | |
| 14/10/2024 01:00 | 48.65 | 0 | 96.72 | 0 | 33.4 | |
| 14/10/2024 02:00 | 48.64 | 0 | 96.67 | 0 | 33.2 | |
| 14/10/2024 03:00 | 48.67 | 0 | 97.01 | 0 | 33.2 | |
| 14/10/2024 04:00 | 48.69 | 0 | 97.04 | 0 | 33.2 | |
| 14/10/2024 05:00 | 48.81 | 0.38 | 96.99 | 0 | 33.1 | |
| 14/10/2024 06:00 | 48.84 | 0 | 97.07 | 0 | 33.2 | |
| 14/10/2024 07:00 | 48.71 | 0 | 97.27 | 0 | 32.9 | |
| 14/10/2024 08:00 | 45.84 | 0.01 | 96.78 | 0 | 31 | |
| 14/10/2024 09:00 | 35.69 | 0.05 | 93.24 | 0 | 22.9 | |
| 14/10/2024 10:00 | 38.23 | 0.05 | 93.26 | 0 | 24.8 | |
| 14/10/2024 11:00 | 46.54 | 0 | 96.37 | 0 | 32.8 | |
| 14/10/2024 12:00 | 46.31 | 0.01 | 96.29 | 0 | 33 | |
| 14/10/2024 13:00 | 46.87 | 0.01 | 96.31 | 0 | 29.6 | |
| 14/10/2024 14:00 | 47.01 | 0.8 | 96.9 | 0 | 26.8 | |
| 14/10/2024 15:00 | 46.96 | 0.23 | 97.5 | 0 | 26.6 | |
| 14/10/2024 16:00 | 46.95 | 0 | 97.59 | 0 | 27 | |
| 14/10/2024 17:00 | 46.82 | 0 | 97.38 | 0 | 27 | |
| 14/10/2024 18:00 | 46.83 | 0 | 97.66 | 0 | 26.6 | |
| 14/10/2024 19:00 | 46.88 | 0 | 97.72 | 0 | 26.8 | |
| 14/10/2024 20:00 | 46.8 | 0 | 97.51 | 0 | 26.5 | |
| 14/10/2024 21:00 | 46.86 | 0 | 97.97 | 0 | 26.2 | |
| 14/10/2024 22:00 | 46.88 | 0 | 98.26 | 0 | 26.4 | |
| 14/10/2024 23:00 | 46.82 | 0 | 98.3 | 0 | 26.2 | |
| 15/10/2024 00:00 | 46.83 | 0 | 98.29 | 0 | 26.1 | |
| Minimum | 35.69 | 0 | 93.24 | 0 | 22.9 | |
| MinDate | 14/10/2024 09:00 | 14/10/2024 00:00 | 14/10/2024 09:00 | 14/10/2024 00:00 | 14/10/2024 09:00 | |
| Maximum | 48.84 | 0.8 | 98.3 | 0 | 33.5 | |
| MaxDate | 14/10/2024 06:00 | 14/10/2024 14:00 | 14/10/2024 23:00 | 14/10/2024 00:00 | 14/10/2024 00:00 | |
| Avg | 46.59 | 0.06 | 96.9 | 0 | 29.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 3.1 | 0.2 | 1.3 | 0 | 3.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/10/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 09:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 10:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 11:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 12:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 13:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 14:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 15:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 16:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 17:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 18:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 19:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 20:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 21:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 22:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/10/2024 23:00 | 0 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 00:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0 | --- | --- | --- | |
| MinDate | 14/10/2024 00:00 | 14/10/2024 00:00 | 14/10/2024 00:00 | 14/10/2024 00:00 | 14/10/2024 00:00 | |
| Maximum | 0 | 0.28 | --- | --- | --- | |
| MaxDate | 14/10/2024 00:00 | 14/10/2024 14:00 | 14/10/2024 00:00 | 14/10/2024 00:00 | 14/10/2024 00:00 | |
| Avg | 0 | 0.11 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/10/2024 00:00 | 46.83 | 0 | 98.29 | 0 | 26.1 | |
| 15/10/2024 01:00 | 46.85 | 0 | 98.24 | 0 | 26.1 | |
| 15/10/2024 02:00 | 46.86 | 0 | 98.18 | 0 | 26.3 | |
| 15/10/2024 03:00 | 46.83 | 0 | 98.23 | 0 | 25.7 | |
| 15/10/2024 04:00 | 46.79 | 0 | 98.24 | 0 | 25.7 | |
| 15/10/2024 05:00 | 46.98 | 0.32 | 98.35 | 0 | 26.6 | |
| 15/10/2024 06:00 | 46.69 | 0 | 98.01 | 0 | 26.4 | |
| 15/10/2024 07:00 | 34.53 | 0.06 | 95.73 | 0 | 32.8 | |
| 15/10/2024 08:00 | 34.16 | 0.02 | 95.95 | 0 | 22.1 | |
| 15/10/2024 09:00 | 34.26 | 0.05 | 96.53 | 0 | 21.1 | |
| 15/10/2024 10:00 | 34.39 | 0.08 | 96.65 | 0 | 21.2 | |
| 15/10/2024 11:00 | 34.49 | 0.05 | 96.66 | 0 | 21.3 | |
| 15/10/2024 12:00 | 22.28 | 0.02 | 92.96 | 0 | 45.3 | |
| 15/10/2024 13:00 | 34.54 | 0 | 94.45 | 0 | 23.4 | |
| 15/10/2024 14:00 | 34.53 | 0 | 95.66 | 0 | 21.4 | |
| 15/10/2024 15:00 | 34.63 | 0 | 96.1 | 0 | 21.4 | |
| 15/10/2024 16:00 | 34.61 | 0 | 96.28 | 0 | 21.3 | |
| 15/10/2024 17:00 | 34.43 | 0 | 96.1 | 0 | 21 | |
| 15/10/2024 18:00 | 34.48 | 0 | 95.95 | 0 | 20.8 | |
| 15/10/2024 19:00 | 34.43 | 0 | 95.83 | 0 | 20.8 | |
| 15/10/2024 20:00 | 34.45 | 0 | 95.76 | 0 | 20.7 | |
| 15/10/2024 21:00 | 34.67 | 0 | 96.22 | 0 | 20.8 | |
| 15/10/2024 22:00 | 34.71 | 0 | 96.22 | 0 | 20.7 | |
| 15/10/2024 23:00 | 34.5 | 0 | 96.25 | 0 | 20.7 | |
| 16/10/2024 00:00 | 8.28 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 8.28 | 0 | 92.96 | 0 | 20.7 | |
| MinDate | 16/10/2024 00:00 | 15/10/2024 00:00 | 15/10/2024 12:00 | 15/10/2024 00:00 | 15/10/2024 20:00 | |
| Maximum | 46.98 | 0.32 | 98.35 | 0 | 45.3 | |
| MaxDate | 15/10/2024 05:00 | 15/10/2024 05:00 | 15/10/2024 05:00 | 15/10/2024 00:00 | 15/10/2024 12:00 | |
| Avg | 36.41 | 0.03 | 96.54 | 0 | 24.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 8.7 | 0.1 | 1.3 | 0 | 5.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/10/2024 00:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 01:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 02:00 | 0 | 0.32 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 03:00 | 0 | 0.35 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 04:00 | 0 | 0.37 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 05:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 06:00 | 0.52 | 0.39 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 07:00 | 15.28 | 0.45 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 15/10/2024 08:00 | 34.07 | 0.59 | 94.93 | 0 | 25.1 | |
| 15/10/2024 09:00 | 34.2 | 0.66 | 95.27 | 0 | 24.3 | |
| 15/10/2024 10:00 | 34.34 | 0.67 | 95.43 | 0 | 24.3 | |
| 15/10/2024 11:00 | 34.43 | 0.63 | 95.43 | 0 | 24.4 | |
| 15/10/2024 12:00 | 22.26 | 0.56 | 92.09 | 0 | 47.7 | |
| 15/10/2024 13:00 | 34.47 | 0.32 | 93.46 | 0 | 26.3 | |
| 15/10/2024 14:00 | 34.46 | 0.43 | 94.08 | 0 | 24.3 | |
| 15/10/2024 15:00 | 34.56 | 0.2 | 94.57 | 0 | 24 | |
| 15/10/2024 16:00 | 34.54 | 0.27 | 94.78 | 0 | 23.8 | |
| 15/10/2024 17:00 | 34.37 | 0.26 | 94.59 | 0 | 23.5 | |
| 15/10/2024 18:00 | 34.41 | 0.25 | 94.45 | 0 | 23 | |
| 15/10/2024 19:00 | 34.37 | 0.07 | 94.34 | 0 | 22.9 | |
| 15/10/2024 20:00 | 34.39 | 0.03 | 94.21 | 0 | 22.8 | |
| 15/10/2024 21:00 | 34.61 | 0 | 94.59 | 0 | 23 | |
| 15/10/2024 22:00 | 34.64 | 0 | 94.51 | 0 | 22.9 | |
| 15/10/2024 23:00 | 34.43 | 0.04 | 94.59 | 0 | 22.8 | |
| 16/10/2024 00:00 | 40.58 | 0.13 | 95.2 | 0 | 41 | |
| Minimum | 0 | 0 | 92.09 | 0 | 22.8 | |
| MinDate | 15/10/2024 00:00 | 15/10/2024 21:00 | 15/10/2024 12:00 | 15/10/2024 08:00 | 15/10/2024 20:00 | |
| Maximum | 40.58 | 0.67 | 95.43 | 0 | 47.7 | |
| MaxDate | 16/10/2024 00:00 | 15/10/2024 10:00 | 15/10/2024 10:00 | 15/10/2024 08:00 | 15/10/2024 12:00 | |
| Avg | 23.8 | 0.32 | 94.5 | 0 | 26.2 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.8 | 0.2 | 0.8 | 0 | 7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/10/2024 00:00 | 8.28 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 05:00 | 0 | 0.26 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 07:00 | 12 | 0.22 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/10/2024 08:00 | 34.54 | 0.11 | 96.63 | 0 | 27.8 | |
| 16/10/2024 09:00 | 34.65 | 0.2 | 97.07 | 0 | 26.7 | |
| 16/10/2024 10:00 | 34.67 | 0.35 | 96.74 | 0 | 26.6 | |
| 16/10/2024 11:00 | 34.62 | 0.37 | 95.45 | 0 | 26.8 | |
| 16/10/2024 12:00 | 22.1 | 0.19 | 91.15 | 0 | 57 | |
| 16/10/2024 13:00 | 34.55 | 0.01 | 94.45 | 0 | 29.2 | |
| 16/10/2024 14:00 | 34.49 | 0 | 95.27 | 0 | 26.6 | |
| 16/10/2024 15:00 | 34.48 | 0.02 | 95.16 | 0 | 26.4 | |
| 16/10/2024 16:00 | 34.45 | 0.05 | 95.05 | 0 | 26.3 | |
| 16/10/2024 17:00 | 34.37 | 0 | 94.95 | 0 | 26.2 | |
| 16/10/2024 18:00 | 34.28 | 0 | 94.91 | 0 | 26.2 | |
| 16/10/2024 19:00 | 34.22 | 0 | 94.65 | 0 | 26.2 | |
| 16/10/2024 20:00 | 34.24 | 0 | 94.54 | 0 | 26.2 | |
| 16/10/2024 21:00 | 34.41 | 0 | 94.89 | 0 | 26.5 | |
| 16/10/2024 22:00 | 34.47 | 0 | 95.16 | 0 | 26.3 | |
| 16/10/2024 23:00 | 34.33 | 0 | 95.37 | 0 | 26.2 | |
| 17/10/2024 00:00 | 41.01 | 0.02 | 96.04 | 0 | 41.3 | |
| Minimum | 0 | 0 | 91.15 | 0 | 26.2 | |
| MinDate | 16/10/2024 01:00 | 16/10/2024 01:00 | 16/10/2024 12:00 | 16/10/2024 08:00 | 16/10/2024 17:00 | |
| Maximum | 41.01 | 0.37 | 97.07 | 0 | 57 | |
| MaxDate | 17/10/2024 00:00 | 16/10/2024 11:00 | 16/10/2024 09:00 | 16/10/2024 08:00 | 16/10/2024 12:00 | |
| Avq | 24.01 | 0.07 | 95.15 | 0 | 29.3 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 1.3 | 0 | 8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/10/2024 00:00 | 40.58 | 0.13 | 95.2 | 0 | 41 | |
| 16/10/2024 01:00 | 48.75 | 0.18 | 95.22 | 0 | 42.6 | |
| 16/10/2024 02:00 | 48.83 | 0.16 | 95.58 | 0 | 43.4 | |
| 16/10/2024 03:00 | 48.82 | 0.16 | 95.68 | 0 | 43.1 | |
| 16/10/2024 04:00 | 48.92 | 0.15 | 95.68 | 0 | 42.8 | |
| 16/10/2024 05:00 | 48.88 | 0.17 | 95.86 | 0 | 42.7 | |
| 16/10/2024 06:00 | 48.9 | 0.17 | 96.1 | 0 | 42.6 | |
| 16/10/2024 07:00 | 38.46 | 0.13 | 95.44 | 0 | 39.3 | |
| 16/10/2024 08:00 | 34.46 | 0.18 | 94.88 | 0 | 23.8 | |
| 16/10/2024 09:00 | 34.59 | 0.3 | 95.65 | 0 | 22.4 | |
| 16/10/2024 10:00 | 34.61 | 0.39 | 95.36 | 0 | 22.3 | |
| 16/10/2024 11:00 | 34.56 | 0.23 | 94.17 | 0 | 22.4 | |
| 16/10/2024 12:00 | 22.06 | 0.01 | 90.3 | 0 | 54.4 | |
| 16/10/2024 13:00 | 34.49 | 0 | 93.59 | 0 | 25 | |
| 16/10/2024 14:00 | 34.43 | 0.16 | 93.88 | 0 | 22.4 | |
| 16/10/2024 15:00 | 34.41 | 0.09 | 93.83 | 0 | 22.1 | |
| 16/10/2024 16:00 | 34.39 | 0.15 | 93.79 | 0 | 22.1 | |
| 16/10/2024 17:00 | 34.3 | 0.05 | 93.7 | 0 | 22.2 | |
| 16/10/2024 18:00 | 34.22 | 0.03 | 93.74 | 0 | 22.1 | |
| 16/10/2024 19:00 | 34.15 | 0.05 | 93.46 | 0 | 22.2 | |
| 16/10/2024 20:00 | 34.18 | 0.09 | 93.3 | 0 | 22.3 | |
| 16/10/2024 21:00 | 34.35 | 0.1 | 93.5 | 0 | 22.4 | |
| 16/10/2024 22:00 | 34.4 | 0.13 | 93.76 | 0 | 22.3 | |
| 16/10/2024 23:00 | 34.26 | 0.19 | 94.04 | 0 | 22.1 | |
| 17/10/2024 00:00 | 7.82 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.82 | 0 | 90.3 | 0 | 22.1 | |
| MinDate | 17/10/2024 00:00 | 16/10/2024 13:00 | 16/10/2024 12:00 | 16/10/2024 00:00 | 16/10/2024 15:00 | |
| Maximum | 48.92 | 0.39 | 96.1 | 0 | 54.4 | |
| MaxDate | 16/10/2024 04:00 | 16/10/2024 10:00 | 16/10/2024 06:00 | 16/10/2024 00:00 | 16/10/2024 12:00 | |
| Avq | 36.71 | 0.14 | 94.4 | 0 | 30.4 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.2 | 0.1 | 1.3 | 0 | 10.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/10/2024 00:00 | 41.01 | 0.02 | 96.04 | 0 | 41.3 | |
| 17/10/2024 01:00 | 48.97 | 0 | 96.37 | 0 | 38.7 | |
| 17/10/2024 02:00 | 48.92 | 0 | 96.96 | 0 | 38.4 | |
| 17/10/2024 03:00 | 49.03 | 0 | 96.9 | 0 | 38.1 | |
| 17/10/2024 04:00 | 49.17 | 0 | 96.78 | 0 | 37.7 | |
| 17/10/2024 05:00 | 49.19 | 0.19 | 96.96 | 0 | 37.7 | |
| 17/10/2024 06:00 | 49.14 | 0 | 97.49 | 0 | 37.7 | |
| 17/10/2024 07:00 | 38.79 | 0.2 | 97.39 | 0 | 38.6 | |
| 17/10/2024 08:00 | 34.54 | 0.28 | 96.34 | 0 | 26.4 | |
| 17/10/2024 09:00 | 34.71 | 0.4 | 96.93 | 0 | 25.5 | |
| 17/10/2024 10:00 | 34.72 | 0.53 | 96.98 | 0 | 26.1 | |
| 17/10/2024 11:00 | 34.68 | 0.54 | 97.08 | 0 | 26.4 | |
| 17/10/2024 12:00 | 21.78 | 0.6 | 93.73 | 0 | 50.7 | |
| 17/10/2024 13:00 | 34.76 | 0.46 | 96.28 | 0 | 27.3 | |
| 17/10/2024 14:00 | 34.51 | 0.44 | 95.38 | 0 | 25.5 | |
| 17/10/2024 15:00 | 34.53 | 0.67 | 94.39 | 0 | 24.9 | |
| 17/10/2024 16:00 | 34.46 | 0.21 | 95.46 | 0 | 24.5 | |
| 17/10/2024 17:00 | 34.2 | 0.15 | 95.63 | 0 | 24.2 | |
| 17/10/2024 18:00 | 34.12 | 0.11 | 95.67 | 0 | 24 | |
| 17/10/2024 19:00 | 34.14 | 0.12 | 95.59 | 0 | 24 | |
| 17/10/2024 20:00 | 34.16 | 0.07 | 95.55 | 0 | 23.9 | |
| 17/10/2024 21:00 | 34.33 | 0.06 | 96.07 | 0 | 24 | |
| 17/10/2024 22:00 | 34.33 | 0.09 | 96.01 | 0 | 23.9 | |
| 17/10/2024 23:00 | 34.28 | 0.05 | 96.01 | 0 | 23.8 | |
| 18/10/2024 00:00 | 8.21 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 8.21 | 0 | 93.73 | 0 | 23.8 | |
| MinDate | 18/10/2024 00:00 | 17/10/2024 01:00 | 17/10/2024 12:00 | 17/10/2024 00:00 | 17/10/2024 23:00 | |
| Maximum | 49.19 | 0.67 | 97.49 | 0 | 50.7 | |
| MaxDate | 17/10/2024 05:00 | 17/10/2024 15:00 | 17/10/2024 06:00 | 17/10/2024 00:00 | 17/10/2024 12:00 | |
| Avg | 36.83 | 0.21 | 96.17 | 0 | 30.6 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.2 | 0.2 | 0.9 | 0 | 7.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/10/2024 00:00 | 7.82 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 01:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 02:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 03:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 04:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 05:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 06:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 07:00 | 11.88 | 0.25 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/10/2024 08:00 | 34.46 | 0.39 | 95.43 | 0 | 25.1 | |
| 17/10/2024 09:00 | 34.64 | 0.54 | 95.49 | 0 | 24.3 | |
| 17/10/2024 10:00 | 34.66 | 0.58 | 95.5 | 0 | 24.7 | |
| 17/10/2024 11:00 | 34.61 | 0.55 | 95.54 | 0 | 24.8 | |
| 17/10/2024 12:00 | 21.69 | 0.54 | 92.48 | 0 | 51.6 | |
| 17/10/2024 13:00 | 34.7 | 0.48 | 94.74 | 0 | 25.5 | |
| 17/10/2024 14:00 | 34.44 | 0.67 | 93.81 | 0 | 23.5 | |
| 17/10/2024 15:00 | 34.47 | 0 | 92.99 | 0 | 23.1 | |
| 17/10/2024 16:00 | 34.4 | 0 | 94.06 | 0 | 22.8 | |
| 17/10/2024 17:00 | 34.14 | 0 | 94.28 | 0 | 22.5 | |
| 17/10/2024 18:00 | 34.06 | 0 | 94.28 | 0 | 22.4 | |
| 17/10/2024 19:00 | 34.07 | 0 | 94.2 | 0 | 22.4 | |
| 17/10/2024 20:00 | 34.09 | 0 | 94.15 | 0 | 22.3 | |
| 17/10/2024 21:00 | 34.27 | 0 | 94.54 | 0 | 22.4 | |
| 17/10/2024 22:00 | 34.27 | 0 | 94.46 | 0 | 22.2 | |
| 17/10/2024 23:00 | 34.21 | 0 | 94.45 | 0 | 22.3 | |
| 18/10/2024 00:00 | 40.44 | 0 | 95.21 | 0 | 41.2 | |
| Minimum | 0 | 0 | 92.48 | 0 | 22.2 | |
| MinDate | 17/10/2024 01:00 | 17/10/2024 15:00 | 17/10/2024 12:00 | 17/10/2024 08:00 | 17/10/2024 22:00 | |
| Maximum | 40.44 | 0.67 | 95.54 | 0 | 51.6 | |
| MaxDate | 18/10/2024 00:00 | 17/10/2024 14:00 | 17/10/2024 11:00 | 17/10/2024 08:00 | 17/10/2024 12:00 | |
| Avg | 23.89 | 0.21 | 94.45 | 0 | 26.1 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.2 | 0.9 | 0 | 8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/10/2024 00:00 | 8.21 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 02:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 03:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 04:00 | 0 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 05:00 | 0 | 0.41 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 06:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 07:00 | 10.77 | 0.39 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/10/2024 08:00 | 34.39 | 0.18 | 96.06 | 0 | 28.2 | |
| 18/10/2024 09:00 | 34.61 | 0.2 | 96.6 | 0 | 26.6 | |
| 18/10/2024 10:00 | 34.75 | 0.4 | 97.05 | 0 | 26.9 | |
| 18/10/2024 11:00 | 34.64 | 0.46 | 96.31 | 0 | 27.1 | |
| 18/10/2024 12:00 | 21.83 | 0.55 | 91.85 | 0 | 55.4 | |
| 18/10/2024 13:00 | 34.61 | 0.53 | 94.15 | 0 | 28.5 | |
| 18/10/2024 14:00 | 34.61 | 0.35 | 95.25 | 0 | 26.5 | |
| 18/10/2024 15:00 | 34.59 | 0.08 | 95.41 | 0 | 26.4 | |
| 18/10/2024 16:00 | 34.42 | 0.03 | 94.98 | 0 | 26.2 | |
| 18/10/2024 17:00 | 34.24 | 0 | 94.66 | 0 | 25.9 | |
| 18/10/2024 18:00 | 34.17 | 0 | 94.93 | 0 | 25.9 | |
| 18/10/2024 19:00 | 34.09 | 0.08 | 95.06 | 0 | 26 | |
| 18/10/2024 20:00 | 34.22 | 0.1 | 95.07 | 0 | 25.8 | |
| 18/10/2024 21:00 | 34.43 | 0.01 | 95.59 | 0 | 25.7 | |
| 18/10/2024 22:00 | 37.53 | 0.03 | 97.26 | 0 | 27 | |
| 18/10/2024 23:00 | 38.41 | 0.08 | 98.25 | 0 | 27.5 | |
| 19/10/2024 00:00 | 28.15 | 0.14 | 94.32 | 0 | 45.1 | |
| Minimum | 0 | 0 | 91.85 | 0 | 25.7 | |
| MinDate | 18/10/2024 01:00 | 18/10/2024 01:00 | 18/10/2024 12:00 | 18/10/2024 08:00 | 18/10/2024 21:00 | |
| Maximum | 38.41 | 0.55 | 98.25 | 0 | 55.4 | |
| MaxDate | 18/10/2024 23:00 | 18/10/2024 12:00 | 18/10/2024 23:00 | 18/10/2024 08:00 | 18/10/2024 12:00 | |
| Avg | 23.71 | 0.17 | 95.46 | 0 | 29.5 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.4 | 0.2 | 1.4 | 0 | 8.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/10/2024 00:00 | 40.44 | 0 | 95.21 | 0 | 41.2 | |
| 18/10/2024 01:00 | 48.75 | 0.02 | 95.32 | 0 | 42.7 | |
| 18/10/2024 02:00 | 48.77 | 0.05 | 95.58 | 0 | 42.7 | |
| 18/10/2024 03:00 | 48.87 | 0.07 | 95.63 | 0 | 43.2 | |
| 18/10/2024 04:00 | 48.87 | 0.08 | 95.65 | 0 | 42.8 | |
| 18/10/2024 05:00 | 48.83 | 0.05 | 95.82 | 0 | 41.8 | |
| 18/10/2024 06:00 | 48.92 | 0.09 | 96.21 | 0 | 42.2 | |
| 18/10/2024 07:00 | 39.64 | 0.21 | 95.74 | 0 | 39.6 | |
| 18/10/2024 08:00 | 34.33 | 0.28 | 94.64 | 0 | 23.9 | |
| 18/10/2024 09:00 | 34.55 | 0.39 | 95.12 | 0 | 22.2 | |
| 18/10/2024 10:00 | 34.68 | 0.55 | 95.64 | 0 | 22.4 | |
| 18/10/2024 11:00 | 34.58 | 0.52 | 94.95 | 0 | 22.4 | |
| 18/10/2024 12:00 | 21.8 | 0.32 | 90.92 | 0 | 52.5 | |
| 18/10/2024 13:00 | 34.57 | 0.11 | 93.26 | 0 | 24.3 | |
| 18/10/2024 14:00 | 34.54 | 0.3 | 93.9 | 0 | 22.2 | |
| 18/10/2024 15:00 | 34.52 | 0.19 | 94.07 | 0 | 22.1 | |
| 18/10/2024 16:00 | 34.36 | 0.1 | 93.58 | 0 | 21.8 | |
| 18/10/2024 17:00 | 34.18 | 0.01 | 93.38 | 0 | 21.7 | |
| 18/10/2024 18:00 | 34.11 | 0.02 | 93.59 | 0 | 21.9 | |
| 18/10/2024 19:00 | 34.03 | 0.15 | 93.77 | 0 | 22.2 | |
| 18/10/2024 20:00 | 34.16 | 0.21 | 93.73 | 0 | 21.6 | |
| 18/10/2024 21:00 | 34.37 | 0.11 | 94.14 | 0 | 21.5 | |
| 18/10/2024 22:00 | 37.45 | 0.15 | 95.76 | 0 | 22.8 | |
| 18/10/2024 23:00 | 38.34 | 0.2 | 96.61 | 0 | 23.2 | |
| 19/10/2024 00:00 | 28.09 | 0.16 | 93.08 | 0 | 39.4 | |
| Minimum | 21.8 | 0 | 90.92 | 0 | 21.5 | |
| MinDate | 18/10/2024 12:00 | 18/10/2024 00:00 | 18/10/2024 12:00 | 18/10/2024 00:00 | 18/10/2024 21:00 | |
| Maximum | 48.92 | 0.55 | 96.61 | 0 | 52.5 | |
| MaxDate | 18/10/2024 06:00 | 18/10/2024 10:00 | 18/10/2024 23:00 | 18/10/2024 00:00 | 18/10/2024 12:00 | |
| Avg | 37.83 | 0.17 | 94.61 | 0 | 30.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.2 | 0.1 | 1.3 | 0 | 10.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/10/2024 00:00 | 28.15 | 0.14 | 94.32 | 0 | 45.1 | |
| 19/10/2024 01:00 | 28.74 | 0.11 | 93.56 | 0 | 44.7 | |
| 19/10/2024 02:00 | 28.86 | 0.1 | 93.5 | 0 | 44.2 | |
| 19/10/2024 03:00 | 28.82 | 0.11 | 93.35 | 0 | 44.5 | |
| 19/10/2024 04:00 | 28.65 | 0.16 | 93.34 | 0 | 44.9 | |
| 19/10/2024 05:00 | 28.58 | 0.49 | 93.31 | 0 | 45.4 | |
| 19/10/2024 06:00 | 28.49 | 0.05 | 93.11 | 0 | 45.8 | |
| 19/10/2024 07:00 | 28.48 | 0.02 | 92.8 | 0 | 45.2 | |
| 19/10/2024 08:00 | 42.62 | 0 | 99.31 | 0 | 29.6 | |
| 19/10/2024 09:00 | 42.83 | 0 | 101.24 | 0 | 29.8 | |
| 19/10/2024 10:00 | 42.97 | 0 | 101.85 | 0 | 29.8 | |
| 19/10/2024 11:00 | 42.89 | 0.03 | 102.21 | 0 | 29.7 | |
| 19/10/2024 12:00 | 28.81 | 0.11 | 95.58 | 0 | 41.2 | |
| 19/10/2024 13:00 | 42.9 | 0.09 | 100.75 | 0 | 30.2 | |
| 19/10/2024 14:00 | 43.02 | 0.03 | 102.21 | 0 | 29.1 | |
| 19/10/2024 15:00 | 42.88 | 0 | 100.68 | 0 | 29.1 | |
| 19/10/2024 16:00 | 42.55 | 0.01 | 100.38 | 0 | 28.8 | |
| 19/10/2024 17:00 | 42.14 | 0 | 100.42 | 0 | 28.6 | |
| 19/10/2024 18:00 | 42.12 | 0.01 | 100.64 | 0 | 28.4 | |
| 19/10/2024 19:00 | 42.07 | 0.01 | 100.6 | 0 | 28.1 | |
| 19/10/2024 20:00 | 42.43 | 0 | 100.47 | 0 | 28.3 | |
| 19/10/2024 21:00 | 42.73 | 0 | 100.67 | 0 | 28.5 | |
| 19/10/2024 22:00 | 42.71 | 0 | 100.59 | 0 | 28.4 | |
| 19/10/2024 23:00 | 42.57 | 0 | 100.64 | 0 | 28.3 | |
| 20/10/2024 00:00 | 28.37 | 0 | 94.52 | 0 | 43.1 | |
| Minimum | 28.15 | 0 | 92.8 | 0 | 28.1 | |
| MinDate | 19/10/2024 00:00 | 19/10/2024 08:00 | 19/10/2024 07:00 | 19/10/2024 00:00 | 19/10/2024 19:00 | |
| Maximum | 43.02 | 0.49 | 102.21 | 0 | 45.8 | |
| MaxDate | 19/10/2024 14:00 | 19/10/2024 05:00 | 19/10/2024 11:00 | 19/10/2024 00:00 | 19/10/2024 06:00 | |
| Avg | 37.02 | 0.06 | 98 | 0 | 35.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7 | 0.1 | 3.6 | 0 | 7.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/10/2024 00:00 | 28.09 | 0.16 | 93.08 | 0 | 39.4 | |
| 19/10/2024 01:00 | 28.68 | 0.1 | 92.48 | 0 | 39.2 | |
| 19/10/2024 02:00 | 28.79 | 0.18 | 92.44 | 0 | 38.8 | |
| 19/10/2024 03:00 | 28.75 | 0.21 | 92.34 | 0 | 39.1 | |
| 19/10/2024 04:00 | 28.59 | 0.25 | 92.33 | 0 | 39.5 | |
| 19/10/2024 05:00 | 28.51 | 0.27 | 92.26 | 0 | 39.8 | |
| 19/10/2024 06:00 | 28.43 | 0.27 | 92.07 | 0 | 40 | |
| 19/10/2024 07:00 | 28.41 | 0.22 | 91.85 | 0 | 39.3 | |
| 19/10/2024 08:00 | 42.52 | 0.22 | 97.92 | 0 | 26.9 | |
| 19/10/2024 09:00 | 42.76 | 0.3 | 99.69 | 0 | 27.3 | |
| 19/10/2024 10:00 | 42.9 | 0.41 | 100.23 | 0 | 27.6 | |
| 19/10/2024 11:00 | 42.81 | 0.45 | 100.51 | 0 | 27.5 | |
| 19/10/2024 12:00 | 28.75 | 0.44 | 94.31 | 0 | 36.3 | |
| 19/10/2024 13:00 | 42.85 | 0.42 | 99.22 | 0 | 28.8 | |
| 19/10/2024 14:00 | 42.96 | 0.58 | 100.51 | 0 | 26.8 | |
| 19/10/2024 15:00 | 42.81 | 0.01 | 99.16 | 0 | 26 | |
| 19/10/2024 16:00 | 42.47 | 0 | 98.86 | 0 | 25.4 | |
| 19/10/2024 17:00 | 42.07 | 0 | 98.89 | 0 | 24.8 | |
| 19/10/2024 18:00 | 42.05 | 0 | 99.06 | 0 | 24.7 | |
| 19/10/2024 19:00 | 41.99 | 0 | 99.08 | 0 | 24.3 | |
| 19/10/2024 20:00 | 42.35 | 0 | 99 | 0 | 25.1 | |
| 19/10/2024 21:00 | 42.65 | 0 | 99.22 | 0 | 25.5 | |
| 19/10/2024 22:00 | 42.63 | 0 | 99.09 | 0 | 25.1 | |
| 19/10/2024 23:00 | 42.48 | 0 | 99.03 | 0 | 24.9 | |
| 20/10/2024 00:00 | 28.33 | 0 | 93.19 | 0 | 37.8 | |
| Minimum | 28.09 | 0 | 91.85 | 0 | 24.3 | |
| MinDate | 19/10/2024 00:00 | 19/10/2024 16:00 | 19/10/2024 07:00 | 19/10/2024 00:00 | 19/10/2024 19:00 | |
| Maximum | 42.96 | 0.58 | 100.51 | 0 | 40 | |
| MaxDate | 19/10/2024 14:00 | 19/10/2024 14:00 | 19/10/2024 11:00 | 19/10/2024 00:00 | 19/10/2024 06:00 | |
| Avg | 36.95 | 0.18 | 96.63 | 0 | 31.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7 | 0.2 | 3.4 | 0 | 6.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/10/2024 00:00 | 28.37 | 0 | 94.52 | 0 | 43.1 | |
| 20/10/2024 01:00 | 28.52 | 0 | 93.04 | 0 | 43.9 | |
| 20/10/2024 02:00 | 28.47 | 0.03 | 93.16 | 0 | 44.1 | |
| 20/10/2024 03:00 | 28.16 | 0.02 | 93.08 | 0 | 45 | |
| 20/10/2024 04:00 | 27.75 | 0 | 92.83 | 0 | 45.7 | |
| 20/10/2024 05:00 | 27.4 | 0.28 | 92.51 | 0 | 46.6 | |
| 20/10/2024 06:00 | 27.3 | 0.03 | 92.54 | 0 | 46.9 | |
| 20/10/2024 07:00 | 27.1 | 0.03 | 92.82 | 0 | 46.8 | |
| 20/10/2024 08:00 | 27.02 | 0.15 | 93.06 | 0 | 46.3 | |
| 20/10/2024 09:00 | 27.07 | 0.21 | 93.26 | 0 | 46.2 | |
| 20/10/2024 10:00 | 27.1 | 0.19 | 93.55 | 0 | 46 | |
| 20/10/2024 11:00 | 27.12 | 0.08 | 93.68 | 0 | 46.3 | |
| 20/10/2024 12:00 | 27.07 | 0.12 | 93.86 | 0 | 46.9 | |
| 20/10/2024 13:00 | 27.06 | 0.15 | 93.59 | 0 | 45.7 | |
| 20/10/2024 14:00 | 27.13 | 0.14 | 93.42 | 0 | 45.6 | |
| 20/10/2024 15:00 | 27.13 | 0.13 | 93.26 | 0 | 45.8 | |
| 20/10/2024 16:00 | 27.12 | 0.09 | 92.92 | 0 | 46.6 | |
| 20/10/2024 17:00 | 27.14 | 0.14 | 92.98 | 0 | 46 | |
| 20/10/2024 18:00 | 41.03 | 0.07 | 98.83 | 0 | 27.2 | |
| 20/10/2024 19:00 | 40.96 | 0.17 | 100.05 | 0 | 26.5 | |
| 20/10/2024 20:00 | 40.91 | 0.11 | 100.15 | 0 | 26.5 | |
| 20/10/2024 21:00 | 40.89 | 0.06 | 100.44 | 0 | 26.3 | |
| 20/10/2024 22:00 | 40.88 | 0.08 | 100.53 | 0 | 26.1 | |
| 20/10/2024 23:00 | 26.99 | 0.22 | 94.93 | 0 | 44 | |
| 21/10/2024 00:00 | 27.07 | 0.22 | 93.52 | 0 | 44.8 | |
| Minimum | 26.99 | 0 | 92.51 | 0 | 26.1 | |
| MinDate | 20/10/2024 23:00 | 20/10/2024 00:00 | 20/10/2024 05:00 | 20/10/2024 00:00 | 20/10/2024 22:00 | |
| Maximum | 41.03 | 0.28 | 100.53 | 0 | 46.9 | |
| MaxDate | 20/10/2024 18:00 | 20/10/2024 05:00 | 20/10/2024 22:00 | 20/10/2024 00:00 | 20/10/2024 06:00 | |
| Avq | 30.11 | 0.11 | 94.66 | 0 | 41.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.5 | 0.1 | 2.8 | 0 | 7.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/10/2024 00:00 | 28.33 | 0 | 93.19 | 0 | 37.8 | |
| 20/10/2024 01:00 | 28.45 | 0 | 91.93 | 0 | 38.1 | |
| 20/10/2024 02:00 | 28.41 | 0 | 92.02 | 0 | 38.4 | |
| 20/10/2024 03:00 | 28.1 | 0 | 91.87 | 0 | 38.8 | |
| 20/10/2024 04:00 | 27.7 | 0 | 91.73 | 0 | 39.3 | |
| 20/10/2024 05:00 | 27.34 | 0 | 91.42 | 0 | 40.2 | |
| 20/10/2024 06:00 | 27.23 | 0 | 91.41 | 0 | 40.5 | |
| 20/10/2024 07:00 | 27.03 | 0 | 91.66 | 0 | 40.6 | |
| 20/10/2024 08:00 | 26.96 | 0 | 91.87 | 0 | 40.2 | |
| 20/10/2024 09:00 | 26.94 | 0.02 | 92.03 | 0 | 39.8 | |
| 20/10/2024 10:00 | 27 | 0.01 | 92.25 | 0 | 39.7 | |
| 20/10/2024 11:00 | 27.06 | 0.01 | 92.38 | 0 | 39.8 | |
| 20/10/2024 12:00 | 27 | 0.03 | 92.58 | 0 | 40.5 | |
| 20/10/2024 13:00 | 26.99 | 0.06 | 92.36 | 0 | 39.5 | |
| 20/10/2024 14:00 | 27.07 | 0.18 | 92.37 | 0 | 39.2 | |
| 20/10/2024 15:00 | 27.06 | 0.13 | 92.25 | 0 | 39.4 | |
| 20/10/2024 16:00 | 27.06 | 0.1 | 92.06 | 0 | 40.3 | |
| 20/10/2024 17:00 | 27.07 | 0.09 | 92.06 | 0 | 39.7 | |
| 20/10/2024 18:00 | 40.92 | 0.08 | 97.53 | 0 | 23.3 | |
| 20/10/2024 19:00 | 40.88 | 0.06 | 98.57 | 0 | 22.2 | |
| 20/10/2024 20:00 | 40.84 | 0.01 | 98.62 | 0 | 22.2 | |
| 20/10/2024 21:00 | 40.82 | 0 | 98.81 | 0 | 22.1 | |
| 20/10/2024 22:00 | 40.81 | 0.01 | 98.91 | 0 | 21.9 | |
| 20/10/2024 23:00 | 26.93 | 0.03 | 93.61 | 0 | 38.4 | |
| 21/10/2024 00:00 | 27.01 | 0.02 | 92.41 | 0 | 38.8 | |
| Minimum | 26.93 | 0 | 91.41 | 0 | 21.9 | |
| MinDate | 20/10/2024 23:00 | 20/10/2024 00:00 | 20/10/2024 06:00 | 20/10/2024 00:00 | 20/10/2024 22:00 | |
| Maximum | 40.92 | 0.18 | 98.91 | 0 | 40.6 | |
| MaxDate | 20/10/2024 18:00 | 20/10/2024 14:00 | 20/10/2024 22:00 | 20/10/2024 00:00 | 20/10/2024 07:00 | |
| Avq | 30.04 | 0.03 | 93.44 | 0 | 36 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.5 | 0 | 2.6 | 0 | 7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/10/2024 00:00 | 27.07 | 0.22 | 93.52 | 0 | 44.8 | |
| 21/10/2024 01:00 | 27.03 | 0.23 | 93.42 | 0 | 44.5 | |
| 21/10/2024 02:00 | 27.1 | 0.26 | 93.52 | 0 | 44.6 | |
| 21/10/2024 03:00 | 27.06 | 0.25 | 93.41 | 0 | 44.5 | |
| 21/10/2024 04:00 | 27.08 | 0.26 | 93.42 | 0 | 44.5 | |
| 21/10/2024 05:00 | 27.1 | 0.47 | 93.42 | 0 | 44.8 | |
| 21/10/2024 06:00 | 27.09 | 0.02 | 93.44 | 0 | 44.8 | |
| 21/10/2024 07:00 | 27.47 | 0.02 | 93.78 | 0 | 44.1 | |
| 21/10/2024 08:00 | 41.57 | 0 | 99.87 | 0 | 26.7 | |
| 21/10/2024 09:00 | 33.96 | 0 | 96.21 | 0 | 23 | |
| 21/10/2024 10:00 | 34.16 | 0.01 | 95.74 | 0 | 22.7 | |
| 21/10/2024 11:00 | 34.21 | 0 | 95.75 | 0 | 22.5 | |
| 21/10/2024 12:00 | 22.49 | 0.01 | 93.38 | 0 | 48.1 | |
| 21/10/2024 13:00 | 34.57 | 0.02 | 95.79 | 0 | 23.9 | |
| 21/10/2024 14:00 | 34.64 | 0 | 96.22 | 0 | 22.3 | |
| 21/10/2024 15:00 | 34.62 | 0 | 95.9 | 0 | 22.1 | |
| 21/10/2024 16:00 | 34.49 | 0 | 95.75 | 0 | 22.1 | |
| 21/10/2024 17:00 | 34 | 0 | 95.43 | 0 | 22.1 | |
| 21/10/2024 18:00 | 33.99 | 0 | 95.32 | 0 | 22 | |
| 21/10/2024 19:00 | 33.91 | 0 | 95.37 | 0 | 21.7 | |
| 21/10/2024 20:00 | 34.14 | 0 | 95.49 | 0 | 21.7 | |
| 21/10/2024 21:00 | 34.29 | 0 | 95.69 | 0 | 21.6 | |
| 21/10/2024 22:00 | 34.32 | 0 | 95.88 | 0 | 21.5 | |
| 21/10/2024 23:00 | 34.2 | 0 | 95.72 | 0 | 21.5 | |
| 22/10/2024 00:00 | 7.73 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.73 | 0 | 93.38 | 0 | 21.5 | |
| MinDate | 22/10/2024 00:00 | 21/10/2024 08:00 | 21/10/2024 12:00 | 21/10/2024 00:00 | 21/10/2024 22:00 | |
| Maximum | 41.57 | 0.47 | 99.87 | 0 | 48.1 | |
| MaxDate | 21/10/2024 08:00 | 21/10/2024 05:00 | 21/10/2024 08:00 | 21/10/2024 00:00 | 21/10/2024 12:00 | |
| Avg | 30.73 | 0.07 | 95.06 | 0 | 30.9 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.4 | 0.1 | 1.5 | 0 | 11.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/10/2024 00:00 | 27.01 | 0.02 | 92.41 | 0 | 38.8 | |
| 21/10/2024 01:00 | 26.97 | 0.03 | 92.34 | 0 | 38.9 | |
| 21/10/2024 02:00 | 27.03 | 0.06 | 92.42 | 0 | 38.7 | |
| 21/10/2024 03:00 | 26.99 | 0.09 | 92.34 | 0 | 38.7 | |
| 21/10/2024 04:00 | 27.02 | 0.13 | 92.31 | 0 | 38.7 | |
| 21/10/2024 05:00 | 27.04 | 0.18 | 92.3 | 0 | 38.9 | |
| 21/10/2024 06:00 | 27.03 | 0.18 | 92.36 | 0 | 38.8 | |
| 21/10/2024 07:00 | 27.4 | 0.22 | 92.83 | 0 | 37.9 | |
| 21/10/2024 08:00 | 41.53 | 0.25 | 98.34 | 0 | 24 | |
| 21/10/2024 09:00 | 33.91 | 0.21 | 94.61 | 0 | 19.7 | |
| 21/10/2024 10:00 | 34.1 | 0.32 | 94.2 | 0 | 19.2 | |
| 21/10/2024 11:00 | 34.14 | 0.21 | 94.39 | 0 | 19.2 | |
| 21/10/2024 12:00 | 22.38 | 0.27 | 92.2 | 0 | 47 | |
| 21/10/2024 13:00 | 34.48 | 0.38 | 94.35 | 0 | 20.5 | |
| 21/10/2024 14:00 | 34.57 | 0.57 | 94.76 | 0 | 18.8 | |
| 21/10/2024 15:00 | 34.55 | 0.05 | 94.63 | 0 | 18.6 | |
| 21/10/2024 16:00 | 34.42 | 0.01 | 94.42 | 0 | 18.7 | |
| 21/10/2024 17:00 | 33.93 | 0 | 94.04 | 0 | 18.8 | |
| 21/10/2024 18:00 | 33.92 | 0.01 | 94.07 | 0 | 18.7 | |
| 21/10/2024 19:00 | 33.84 | 0.03 | 94.05 | 0 | 18.6 | |
| 21/10/2024 20:00 | 34.07 | 0.02 | 94.12 | 0 | 18.5 | |
| 21/10/2024 21:00 | 34.23 | 0 | 94.24 | 0 | 18.5 | |
| 21/10/2024 22:00 | 34.26 | 0 | 94.44 | 0 | 18.3 | |
| 21/10/2024 23:00 | 34.14 | 0 | 94.18 | 0 | 18.4 | |
| 22/10/2024 00:00 | 40.65 | 0 | 95.19 | 0 | 37.5 | |
| Minimum | 22.38 | 0 | 92.2 | 0 | 18.3 | |
| MinDate | 21/10/2024 12:00 | 21/10/2024 17:00 | 21/10/2024 12:00 | 21/10/2024 00:00 | 21/10/2024 22:00 | |
| Maximum | 41.53 | 0.57 | 98.34 | 0 | 47 | |
| MaxDate | 21/10/2024 08:00 | 21/10/2024 14:00 | 21/10/2024 08:00 | 21/10/2024 00:00 | 21/10/2024 12:00 | |
| Avg | 31.98 | 0.13 | 93.82 | 0 | 27.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.7 | 0.1 | 1.4 | 0 | 10.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/10/2024 00:00 | 7.73 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 05:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 07:00 | 10.9 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 22/10/2024 08:00 | 34.36 | 0.16 | 96.43 | 0 | 28.4 | |
| 22/10/2024 09:00 | 34.64 | 0.22 | 96.57 | 0 | 27.6 | |
| 22/10/2024 10:00 | 34.73 | 0.36 | 96.95 | 0 | 27.7 | |
| 22/10/2024 11:00 | 34.67 | 0.33 | 96.95 | 0 | 27.5 | |
| 22/10/2024 12:00 | 22.42 | 0.34 | 93.62 | 0 | 49.9 | |
| 22/10/2024 13:00 | 34.72 | 0.16 | 95.41 | 0 | 28.4 | |
| 22/10/2024 14:00 | 34.74 | 0.12 | 96.34 | 0 | 27.6 | |
| 22/10/2024 15:00 | 34.67 | 0 | 94.92 | 0 | 27.3 | |
| 22/10/2024 16:00 | 34.38 | 0 | 95 | 0 | 26.9 | |
| 22/10/2024 17:00 | 34.16 | 0 | 95.12 | 0 | 26.9 | |
| 22/10/2024 18:00 | 34.05 | 0.01 | 95.06 | 0 | 26.8 | |
| 22/10/2024 19:00 | 33.96 | 0.04 | 95.06 | 0 | 26.7 | |
| 22/10/2024 20:00 | 34.07 | 0.12 | 95.22 | 0 | 26.7 | |
| 22/10/2024 21:00 | 34.27 | 0.08 | 95.58 | 0 | 26.5 | |
| 22/10/2024 22:00 | 37.21 | 0.06 | 97.07 | 0 | 27.7 | |
| 22/10/2024 23:00 | 39.87 | 0.11 | 99.04 | 0 | 29.1 | |
| 23/10/2024 00:00 | 28.43 | 0.31 | 95.14 | 0 | 43.6 | |
| Minimum | 0 | 0 | 93.62 | 0 | 26.5 | |
| MinDate | 22/10/2024 01:00 | 22/10/2024 01:00 | 22/10/2024 12:00 | 22/10/2024 08:00 | 22/10/2024 21:00 | |
| Maximum | 39.87 | 0.38 | 99.04 | 0 | 49.9 | |
| MaxDate | 22/10/2024 23:00 | 22/10/2024 05:00 | 22/10/2024 23:00 | 22/10/2024 08:00 | 22/10/2024 12:00 | |
| Avg | 23.76 | 0.12 | 95.85 | 0 | 29.7 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.5 | 0.1 | 1.2 | 0 | 6.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/10/2024 00:00 | 40.65 | 0 | 95.19 | 0 | 37.5 | |
| 22/10/2024 01:00 | 48.81 | 0 | 95.53 | 0 | 36 | |
| 22/10/2024 02:00 | 48.93 | 0 | 95.85 | 0 | 36.3 | |
| 22/10/2024 03:00 | 48.95 | 0 | 96.03 | 0 | 35.1 | |
| 22/10/2024 04:00 | 48.86 | 0 | 96.07 | 0 | 35.1 | |
| 22/10/2024 05:00 | 48.5 | 0 | 96.2 | 0 | 33 | |
| 22/10/2024 06:00 | 48.52 | 0 | 96.6 | 0 | 33.3 | |
| 22/10/2024 07:00 | 39.31 | 0.06 | 95.81 | 0 | 33.3 | |
| 22/10/2024 08:00 | 34.29 | 0.07 | 94.67 | 0 | 19.3 | |
| 22/10/2024 09:00 | 34.57 | 0.14 | 95.1 | 0 | 18.3 | |
| 22/10/2024 10:00 | 34.66 | 0.22 | 95.44 | 0 | 18.4 | |
| 22/10/2024 11:00 | 34.61 | 0.2 | 95.44 | 0 | 18.1 | |
| 22/10/2024 12:00 | 22.39 | 0.14 | 92.45 | 0 | 43.6 | |
| 22/10/2024 13:00 | 34.62 | 0.07 | 94.03 | 0 | 19.5 | |
| 22/10/2024 14:00 | 34.67 | 0.29 | 94.81 | 0 | 18.2 | |
| 22/10/2024 15:00 | 34.61 | 0 | 93.89 | 0 | 18.2 | |
| 22/10/2024 16:00 | 34.31 | 0 | 93.95 | 0 | 18 | |
| 22/10/2024 17:00 | 34.09 | 0 | 94.07 | 0 | 18 | |
| 22/10/2024 18:00 | 33.98 | 0 | 94.03 | 0 | 18 | |
| 22/10/2024 19:00 | 33.89 | 0 | 94.02 | 0 | 17.9 | |
| 22/10/2024 20:00 | 34 | 0 | 94.16 | 0 | 17.9 | |
| 22/10/2024 21:00 | 34.21 | 0 | 94.41 | 0 | 17.9 | |
| 22/10/2024 22:00 | 37.14 | 0 | 95.69 | 0 | 19 | |
| 22/10/2024 23:00 | 39.81 | 0 | 97.61 | 0 | 20.2 | |
| 23/10/2024 00:00 | 28.35 | 0 | 93.97 | 0 | 33.5 | |
| Minimum | 22.39 | 0 | 92.45 | 0 | 17.9 | |
| MinDate | 22/10/2024 12:00 | 22/10/2024 00:00 | 22/10/2024 12:00 | 22/10/2024 00:00 | 22/10/2024 19:00 | |
| Maximum | 48.95 | 0.29 | 97.61 | 0 | 43.6 | |
| MaxDate | 22/10/2024 03:00 | 22/10/2024 14:00 | 22/10/2024 23:00 | 22/10/2024 00:00 | 22/10/2024 12:00 | |
| Avg | 37.87 | 0.05 | 95 | 0 | 25.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.1 | 0.1 | 1.1 | 0 | 8.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/10/2024 00:00 | 28.43 | 0.31 | 95.14 | 0 | 43.6 | |
| 23/10/2024 01:00 | 28.7 | 0.28 | 93.59 | 0 | 43.3 | |
| 23/10/2024 02:00 | 28.74 | 0 | 93.38 | 0 | 44.4 | |
| 23/10/2024 03:00 | 28.6 | 0.18 | 93.05 | 0 | 45.5 | |
| 23/10/2024 04:00 | 28.43 | 0.34 | 92.95 | 0 | 46.1 | |
| 23/10/2024 05:00 | 28.28 | 0.44 | 93.02 | 0 | 46.2 | |
| 23/10/2024 06:00 | 28.06 | 0.17 | 92.95 | 0 | 47.4 | |
| 23/10/2024 07:00 | 27.52 | 0.31 | 93.28 | 0 | 48.7 | |
| 23/10/2024 08:00 | 41.19 | 0.24 | 99.37 | 0 | 30.7 | |
| 23/10/2024 09:00 | 41.23 | 0.03 | 100.28 | 0 | 29.8 | |
| 23/10/2024 10:00 | 41.29 | 0.01 | 100.53 | 0 | 29.5 | |
| 23/10/2024 11:00 | 41.27 | 0.08 | 101 | 0 | 29.4 | |
| 23/10/2024 12:00 | 27.35 | 0.37 | 95.67 | 0 | 45 | |
| 23/10/2024 13:00 | 41.33 | 0.35 | 99.96 | 0 | 30.2 | |
| 23/10/2024 14:00 | 41.32 | 0.31 | 100.64 | 0 | 28.7 | |
| 23/10/2024 15:00 | 41.32 | 0.22 | 100.69 | 0 | 29 | |
| 23/10/2024 16:00 | 41.17 | 0.21 | 100.17 | 0 | 28.9 | |
| 23/10/2024 17:00 | 41.09 | 0.27 | 100.17 | 0 | 28.4 | |
| 23/10/2024 18:00 | 41.06 | 0.32 | 100.15 | 0 | 28 | |
| 23/10/2024 19:00 | 41.07 | 0.29 | 100.2 | 0 | 27.8 | |
| 23/10/2024 20:00 | 41.04 | 0.26 | 100.14 | 0 | 28 | |
| 23/10/2024 21:00 | 41.05 | 0.28 | 100.38 | 0 | 28.2 | |
| 23/10/2024 22:00 | 41.05 | 0.25 | 100.35 | 0 | 28.3 | |
| 23/10/2024 23:00 | 41.03 | 0.26 | 100.25 | 0 | 28.3 | |
| 24/10/2024 00:00 | 27.03 | 0.28 | 94.58 | 0 | 46.5 | |
| Minimum | 27.03 | 0 | 92.95 | 0 | 27.8 | |
| MinDate | 24/10/2024 00:00 | 23/10/2024 02:00 | 23/10/2024 04:00 | 23/10/2024 00:00 | 23/10/2024 19:00 | |
| Maximum | 41.33 | 0.44 | 101 | 0 | 48.7 | |
| MaxDate | 23/10/2024 13:00 | 23/10/2024 05:00 | 23/10/2024 11:00 | 23/10/2024 00:00 | 23/10/2024 07:00 | |
| Avg | 35.95 | 0.24 | 97.68 | 0 | 35.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.5 | 0.1 | 3.3 | 0 | 8.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/10/2024 00:00 | 28.35 | 0 | 93.97 | 0 | 33.5 | |
| 23/10/2024 01:00 | 28.64 | 0 | 92.77 | 0 | 32.9 | |
| 23/10/2024 02:00 | 28.67 | 0 | 92.6 | 0 | 33.7 | |
| 23/10/2024 03:00 | 28.55 | 0 | 92.19 | 0 | 34.5 | |
| 23/10/2024 04:00 | 28.36 | 0 | 92.01 | 0 | 34.9 | |
| 23/10/2024 05:00 | 28.22 | 0 | 92.14 | 0 | 34.9 | |
| 23/10/2024 06:00 | 28 | 0 | 92 | 0 | 36 | |
| 23/10/2024 07:00 | 27.46 | 0 | 92.37 | 0 | 36.9 | |
| 23/10/2024 08:00 | 41.1 | 0.04 | 98.22 | 0 | 21.7 | |
| 23/10/2024 09:00 | 41.16 | 0 | 98.89 | 0 | 20.6 | |
| 23/10/2024 10:00 | 41.23 | 0 | 99.23 | 0 | 20.7 | |
| 23/10/2024 11:00 | 41.2 | 0 | 99.57 | 0 | 20.6 | |
| 23/10/2024 12:00 | 27.3 | 0.04 | 94.6 | 0 | 34.8 | |
| 23/10/2024 13:00 | 41.26 | 0.09 | 98.71 | 0 | 22 | |
| 23/10/2024 14:00 | 41.24 | 0.25 | 99.15 | 0 | 20 | |
| 23/10/2024 15:00 | 41.25 | 0.07 | 99.37 | 0 | 20.2 | |
| 23/10/2024 16:00 | 41.09 | 0.06 | 98.87 | 0 | 19.9 | |
| 23/10/2024 17:00 | 41.01 | 0.06 | 98.91 | 0 | 19.5 | |
| 23/10/2024 18:00 | 41 | 0.04 | 98.98 | 0 | 19.2 | |
| 23/10/2024 19:00 | 41 | 0.03 | 98.98 | 0 | 18.9 | |
| 23/10/2024 20:00 | 40.97 | 0.02 | 98.88 | 0 | 19.1 | |
| 23/10/2024 21:00 | 40.98 | 0.04 | 98.94 | 0 | 19.4 | |
| 23/10/2024 22:00 | 40.98 | 0.04 | 98.87 | 0 | 19.3 | |
| 23/10/2024 23:00 | 40.96 | 0.05 | 98.77 | 0 | 19.3 | |
| 24/10/2024 00:00 | 26.99 | 0.01 | 93.43 | 0 | 36.3 | |
| Minimum | 26.99 | 0 | 92 | 0 | 18.9 | |
| MinDate | 24/10/2024 00:00 | 23/10/2024 00:00 | 23/10/2024 06:00 | 23/10/2024 00:00 | 23/10/2024 19:00 | |
| Maximum | 41.26 | 0.25 | 99.57 | 0 | 36.9 | |
| MaxDate | 23/10/2024 13:00 | 23/10/2024 14:00 | 23/10/2024 11:00 | 23/10/2024 00:00 | 23/10/2024 07:00 | |
| Avg | 35.88 | 0.03 | 96.5 | 0 | 26 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.5 | 0.1 | 3.1 | 0 | 7.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/10/2024 00:00 | 27.03 | 0.28 | 94.58 | 0 | 46.5 | |
| 24/10/2024 01:00 | 27.17 | 0.17 | 93.2 | 0 | 47.7 | |
| 24/10/2024 02:00 | 27.16 | 0.17 | 93.33 | 0 | 47.3 | |
| 24/10/2024 03:00 | 27.18 | 0.15 | 93.47 | 0 | 47.5 | |
| 24/10/2024 04:00 | 27.15 | 0.26 | 93.43 | 0 | 47.7 | |
| 24/10/2024 05:00 | 27.18 | 0.46 | 93.22 | 0 | 47.9 | |
| 24/10/2024 06:00 | 27.21 | 0 | 92.69 | 0 | 48.3 | |
| 24/10/2024 07:00 | 27.52 | 0 | 92.93 | 0 | 46.8 | |
| 24/10/2024 08:00 | 41.45 | 0 | 99.28 | 0 | 29.2 | |
| 24/10/2024 09:00 | 34.23 | 0 | 95.96 | 0 | 25.7 | |
| 24/10/2024 10:00 | 34.28 | 0 | 95.25 | 0 | 25.2 | |
| 24/10/2024 11:00 | 34.32 | 0 | 95.68 | 0 | 25.4 | |
| 24/10/2024 12:00 | 22.17 | 0.13 | 92.76 | 0 | 51.6 | |
| 24/10/2024 13:00 | 34.6 | 0.2 | 95.95 | 0 | 27.2 | |
| 24/10/2024 14:00 | 34.61 | 0.23 | 96.48 | 0 | 24.5 | |
| 24/10/2024 15:00 | 34.64 | 0.13 | 96.07 | 0 | 24.2 | |
| 24/10/2024 16:00 | 34.61 | 0.12 | 96.14 | 0 | 24.3 | |
| 24/10/2024 17:00 | 34.35 | 0.05 | 95.79 | 0 | 24.2 | |
| 24/10/2024 18:00 | 34.28 | 0 | 95.7 | 0 | 23.8 | |
| 24/10/2024 19:00 | 34.06 | 0.07 | 95.45 | 0 | 23.9 | |
| 24/10/2024 20:00 | 34.01 | 0.03 | 95.19 | 0 | 23.8 | |
| 24/10/2024 21:00 | 34.15 | 0 | 95.54 | 0 | 23.7 | |
| 24/10/2024 22:00 | 34.2 | 0.08 | 95.65 | 0 | 23.5 | |
| 24/10/2024 23:00 | 34.16 | 0.02 | 95.63 | 0 | 23.3 | |
| 25/10/2024 00:00 | 40.52 | 0.05 | 96.16 | 0 | 37.7 | |
| Minimum | 22.17 | 0 | 92.69 | 0 | 23.3 | |
| MinDate | 24/10/2024 12:00 | 24/10/2024 06:00 | 24/10/2024 06:00 | 24/10/2024 00:00 | 24/10/2024 23:00 | |
| Maximum | 41.45 | 0.46 | 99.28 | 0 | 51.6 | |
| MaxDate | 24/10/2024 08:00 | 24/10/2024 05:00 | 24/10/2024 08:00 | 24/10/2024 00:00 | 24/10/2024 12:00 | |
| Avg | 32.09 | 0.1 | 95.02 | 0 | 33.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.6 | 0.1 | 1.6 | 0 | 11.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/10/2024 00:00 | 26.99 | 0.01 | 93.43 | 0 | 36.3 | |
| 24/10/2024 01:00 | 27.11 | 0 | 92.3 | 0 | 36.4 | |
| 24/10/2024 02:00 | 27.1 | 0 | 92.51 | 0 | 36.3 | |
| 24/10/2024 03:00 | 27.12 | 0 | 92.58 | 0 | 36.5 | |
| 24/10/2024 04:00 | 27.08 | 0 | 92.55 | 0 | 36.8 | |
| 24/10/2024 05:00 | 27.12 | 0 | 92.38 | 0 | 36.6 | |
| 24/10/2024 06:00 | 27.15 | 0 | 91.73 | 0 | 36.9 | |
| 24/10/2024 07:00 | 27.46 | 0 | 92.07 | 0 | 35.4 | |
| 24/10/2024 08:00 | 41.41 | 0 | 98.11 | 0 | 21.9 | |
| 24/10/2024 09:00 | 34.18 | 0.01 | 94.82 | 0 | 18.4 | |
| 24/10/2024 10:00 | 34.21 | 0.03 | 94.11 | 0 | 18.1 | |
| 24/10/2024 11:00 | 34.26 | 0.07 | 94.43 | 0 | 18.1 | |
| 24/10/2024 12:00 | 22.14 | 0.13 | 91.83 | 0 | 46.9 | |
| 24/10/2024 13:00 | 34.53 | 0.23 | 94.76 | 0 | 20 | |
| 24/10/2024 14:00 | 34.55 | 0.6 | 95.13 | 0 | 19.5 | |
| 24/10/2024 15:00 | 34.57 | 0.01 | 94.83 | 0 | 17.6 | |
| 24/10/2024 16:00 | 34.54 | 0.02 | 94.83 | 0 | 17.7 | |
| 24/10/2024 17:00 | 34.29 | 0 | 94.51 | 0 | 17.7 | |
| 24/10/2024 18:00 | 34.21 | 0 | 94.47 | 0 | 17.5 | |
| 24/10/2024 19:00 | 34 | 0 | 94.3 | 0 | 17.6 | |
| 24/10/2024 20:00 | 33.95 | 0 | 94.01 | 0 | 17.5 | |
| 24/10/2024 21:00 | 34.09 | 0 | 94.29 | 0 | 17.6 | |
| 24/10/2024 22:00 | 34.14 | 0 | 94.43 | 0 | 17.7 | |
| 24/10/2024 23:00 | 34.1 | 0 | 94.39 | 0 | 17.5 | |
| 25/10/2024 00:00 | 7.87 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.87 | 0 | 91.73 | 0 | 17.5 | |
| MinDate | 25/10/2024 00:00 | 24/10/2024 01:00 | 24/10/2024 06:00 | 24/10/2024 00:00 | 24/10/2024 18:00 | |
| Maximum | 41.41 | 0.6 | 98.11 | 0 | 46.9 | |
| MaxDate | 24/10/2024 08:00 | 24/10/2024 14:00 | 24/10/2024 08:00 | 24/10/2024 00:00 | 24/10/2024 12:00 | |
| Avg | 30.73 | 0.04 | 93.87 | 0 | 25.5 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.4 | 0.1 | 1.4 | 0 | 9.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/10/2024 00:00 | 40.52 | 0.05 | 96.16 | 0 | 37.7 | |
| 25/10/2024 01:00 | 48.48 | 0 | 96.24 | 0 | 34.8 | |
| 25/10/2024 02:00 | 48.66 | 0 | 96.8 | 0 | 34.8 | |
| 25/10/2024 03:00 | 48.69 | 0 | 97 | 0 | 34.5 | |
| 25/10/2024 04:00 | 48.66 | 0 | 96.94 | 0 | 34.4 | |
| 25/10/2024 05:00 | 48.76 | 0.21 | 97.16 | 0 | 34 | |
| 25/10/2024 06:00 | 48.89 | 0 | 97 | 0 | 33.9 | |
| 25/10/2024 07:00 | 37.94 | 0.1 | 97.02 | 0 | 35.9 | |
| 25/10/2024 08:00 | 34.33 | 0.17 | 95.98 | 0 | 23.6 | |
| 25/10/2024 09:00 | 34.49 | 0.28 | 96.39 | 0 | 22.5 | |
| 25/10/2024 10:00 | 34.57 | 0.38 | 96.56 | 0 | 22.6 | |
| 25/10/2024 11:00 | 34.56 | 0.45 | 96.74 | 0 | 22.7 | |
| 25/10/2024 12:00 | 21.72 | 0.48 | 93.33 | 0 | 49 | |
| 25/10/2024 13:00 | 34.72 | 0.34 | 96.05 | 0 | 24.2 | |
| 25/10/2024 14:00 | 34.58 | 0.31 | 96.65 | 0 | 22.6 | |
| 25/10/2024 15:00 | 34.56 | 0.31 | 96.32 | 0 | 22.2 | |
| 25/10/2024 16:00 | 34.57 | 0.22 | 96.09 | 0 | 21.8 | |
| 25/10/2024 17:00 | 34.44 | 0.11 | 95.88 | 0 | 21.6 | |
| 25/10/2024 18:00 | 34.33 | 0.07 | 95.72 | 0 | 21.5 | |
| 25/10/2024 19:00 | 34.13 | 0.04 | 95.6 | 0 | 21.4 | |
| 25/10/2024 20:00 | 34.16 | 0.11 | 95.56 | 0 | 21.4 | |
| 25/10/2024 21:00 | 34.36 | 0.12 | 95.97 | 0 | 21.3 | |
| 25/10/2024 22:00 | 37.42 | 0.09 | 97.67 | 0 | 22.4 | |
| 25/10/2024 23:00 | 39.07 | 0.1 | 98.98 | 0 | 23 | |
| 26/10/2024 00:00 | 28.42 | 0.24 | 95.28 | 0 | 38.1 | |
| Minimum | 21.72 | 0 | 93.33 | 0 | 21.3 | |
| MinDate | 25/10/2024 12:00 | 25/10/2024 01:00 | 25/10/2024 12:00 | 25/10/2024 00:00 | 25/10/2024 21:00 | |
| Maximum | 48.89 | 0.48 | 98.98 | 0 | 49 | |
| MaxDate | 25/10/2024 06:00 | 25/10/2024 12:00 | 25/10/2024 23:00 | 25/10/2024 00:00 | 25/10/2024 12:00 | |
| Avg | 37.8 | 0.17 | 96.36 | 0 | 28.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.1 | 0.1 | 1 | 0 | 7.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/10/2024 00:00 | 7.87 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 05:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 07:00 | 12.64 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/10/2024 08:00 | 34.26 | 0 | 94.95 | 0 | 26.1 | |
| 25/10/2024 09:00 | 34.42 | 0.05 | 94.98 | 0 | 25.2 | |
| 25/10/2024 10:00 | 34.51 | 0.13 | 95.1 | 0 | 25.1 | |
| 25/10/2024 11:00 | 34.49 | 0 | 95.23 | 0 | 25.1 | |
| 25/10/2024 12:00 | 21.69 | 0 | 92.19 | 0 | 51.7 | |
| 25/10/2024 13:00 | 34.66 | 0 | 94.98 | 0 | 26.4 | |
| 25/10/2024 14:00 | 34.52 | 0.33 | 95.46 | 0 | 24.9 | |
| 25/10/2024 15:00 | 34.49 | 0.09 | 95.21 | 0 | 24.3 | |
| 25/10/2024 16:00 | 34.5 | 0.02 | 95.14 | 0 | 23.7 | |
| 25/10/2024 17:00 | 34.37 | 0 | 94.98 | 0 | 23.4 | |
| 25/10/2024 18:00 | 34.27 | 0 | 94.84 | 0 | 23.2 | |
| 25/10/2024 19:00 | 34.07 | 0 | 94.68 | 0 | 23.1 | |
| 25/10/2024 20:00 | 34.09 | 0 | 94.57 | 0 | 22.9 | |
| 25/10/2024 21:00 | 34.29 | 0 | 94.92 | 0 | 22.8 | |
| 25/10/2024 22:00 | 37.36 | 0 | 96.64 | 0 | 24.4 | |
| 25/10/2024 23:00 | 39 | 0 | 97.93 | 0 | 25.2 | |
| 26/10/2024 00:00 | 28.38 | 0 | 94.41 | 0 | 38.8 | |
| Minimum | 0 | 0 | 92.19 | 0 | 22.8 | |
| MinDate | 25/10/2024 01:00 | 25/10/2024 00:00 | 25/10/2024 12:00 | 25/10/2024 08:00 | 25/10/2024 21:00 | |
| Maximum | 39 | 0.33 | 97.93 | 0 | 51.7 | |
| MaxDate | 25/10/2024 23:00 | 25/10/2024 14:00 | 25/10/2024 23:00 | 25/10/2024 08:00 | 25/10/2024 12:00 | |
| Avg | 23.76 | 0.02 | 95.07 | 0 | 26.8 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.4 | 0.1 | 1.1 | 0 | 7.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/10/2024 00:00 | 28.42 | 0.24 | 95.28 | 0 | 38.1 | |
| 26/10/2024 01:00 | 28.65 | 0.11 | 93.88 | 0 | 38.2 | |
| 26/10/2024 02:00 | 28.71 | 0.07 | 93.79 | 0 | 37.8 | |
| 26/10/2024 03:00 | 28.55 | 0.02 | 93.46 | 0 | 39.9 | |
| 26/10/2024 04:00 | 28.47 | 0.04 | 93.14 | 0 | 40.9 | |
| 26/10/2024 05:00 | 28.2 | 0.19 | 93.09 | 0 | 41.7 | |
| 26/10/2024 06:00 | 28.03 | 0.07 | 93.1 | 0 | 41.6 | |
| 26/10/2024 07:00 | 27.78 | 0.21 | 93.28 | 0 | 40.7 | |
| 26/10/2024 08:00 | 41.56 | 0.17 | 99.71 | 0 | 24.3 | |
| 26/10/2024 09:00 | 41.52 | 0.23 | 101.29 | 0 | 23.8 | |
| 26/10/2024 10:00 | 41.58 | 0.27 | 101.48 | 0 | 23.6 | |
| 26/10/2024 11:00 | 41.62 | 0.33 | 101.83 | 0 | 23.5 | |
| 26/10/2024 12:00 | 27.73 | 0.46 | 95.67 | 0 | 37.5 | |
| 26/10/2024 13:00 | 41.68 | 0.27 | 100.35 | 0 | 24.2 | |
| 26/10/2024 14:00 | 41.6 | 0.22 | 101.98 | 0 | 23.5 | |
| 26/10/2024 15:00 | 41.65 | 0.21 | 101.76 | 0 | 23.4 | |
| 26/10/2024 16:00 | 41.67 | 0.2 | 101.58 | 0 | 23.2 | |
| 26/10/2024 17:00 | 41.62 | 0.11 | 101.3 | 0 | 23.1 | |
| 26/10/2024 18:00 | 41.54 | 0.06 | 101 | 0 | 23.2 | |
| 26/10/2024 19:00 | 41.53 | 0.06 | 100.97 | 0 | 23.1 | |
| 26/10/2024 20:00 | 41.57 | 0.09 | 101.11 | 0 | 23.1 | |
| 26/10/2024 21:00 | 41.6 | 0.11 | 101.3 | 0 | 22.9 | |
| 26/10/2024 22:00 | 41.62 | 0.21 | 101.17 | 0 | 22.5 | |
| 26/10/2024 23:00 | 41.56 | 0.26 | 101.09 | 0 | 22.3 | |
| 27/10/2024 00:00 | 27.61 | 0.31 | 95.21 | 0 | 37.4 | |
| Minimum | 27.61 | 0.02 | 93.09 | 0 | 22.3 | |
| MinDate | 27/10/2024 00:00 | 26/10/2024 03:00 | 26/10/2024 05:00 | 26/10/2024 00:00 | 26/10/2024 23:00 | |
| Maximum | 41.68 | 0.46 | 101.98 | 0 | 41.7 | |
| MaxDate | 26/10/2024 13:00 | 26/10/2024 12:00 | 26/10/2024 14:00 | 26/10/2024 00:00 | 26/10/2024 05:00 | |
| Avg | 36.24 | 0.18 | 98.31 | 0 | 29.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.7 | 0 | 8.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/10/2024 00:00 | 28.38 | 0 | 94.41 | 0 | 38.8 | |
| 26/10/2024 01:00 | 28.59 | 0 | 93.17 | 0 | 38.5 | |
| 26/10/2024 02:00 | 28.65 | 0 | 93.08 | 0 | 38.3 | |
| 26/10/2024 03:00 | 28.49 | 0 | 92.76 | 0 | 40.4 | |
| 26/10/2024 04:00 | 28.4 | 0 | 92.45 | 0 | 41.4 | |
| 26/10/2024 05:00 | 28.14 | 0 | 92.35 | 0 | 41.8 | |
| 26/10/2024 06:00 | 27.97 | 0 | 92.3 | 0 | 41.6 | |
| 26/10/2024 07:00 | 27.72 | 0.05 | 92.42 | 0 | 40.5 | |
| 26/10/2024 08:00 | 41.51 | 0.19 | 98.45 | 0 | 27.5 | |
| 26/10/2024 09:00 | 41.46 | 0.24 | 99.83 | 0 | 27 | |
| 26/10/2024 10:00 | 41.51 | 0.27 | 100.04 | 0 | 27.1 | |
| 26/10/2024 11:00 | 41.56 | 0.31 | 100.33 | 0 | 27.1 | |
| 26/10/2024 12:00 | 27.67 | 0.3 | 94.62 | 0 | 38.8 | |
| 26/10/2024 13:00 | 41.62 | 0.27 | 98.92 | 0 | 28.5 | |
| 26/10/2024 14:00 | 41.53 | 0.46 | 100.1 | 0 | 27.6 | |
| 26/10/2024 15:00 | 41.58 | 0.09 | 99.97 | 0 | 27.6 | |
| 26/10/2024 16:00 | 41.6 | 0.06 | 99.84 | 0 | 27 | |
| 26/10/2024 17:00 | 41.55 | 0.01 | 99.7 | 0 | 26.4 | |
| 26/10/2024 18:00 | 41.47 | 0 | 99.44 | 0 | 26 | |
| 26/10/2024 19:00 | 41.46 | 0 | 99.42 | 0 | 26 | |
| 26/10/2024 20:00 | 41.5 | 0 | 99.53 | 0 | 25.9 | |
| 26/10/2024 21:00 | 41.53 | 0 | 99.6 | 0 | 25.5 | |
| 26/10/2024 22:00 | 41.55 | 0 | 99.43 | 0 | 24.9 | |
| 26/10/2024 23:00 | 41.5 | 0 | 99.43 | 0 | 24.6 | |
| 27/10/2024 00:00 | 27.54 | 0 | 94.12 | 0 | 37.6 | |
| Minimum | 27.54 | 0 | 92.3 | 0 | 24.6 | |
| MinDate | 27/10/2024 00:00 | 26/10/2024 00:00 | 26/10/2024 06:00 | 26/10/2024 00:00 | 26/10/2024 23:00 | |
| Maximum | 41.62 | 0.46 | 100.33 | 0 | 41.8 | |
| MaxDate | 26/10/2024 13:00 | 26/10/2024 14:00 | 26/10/2024 11:00 | 26/10/2024 00:00 | 26/10/2024 05:00 | |
| Avg | 36.18 | 0.09 | 97.03 | 0 | 31.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.3 | 0 | 6.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/10/2024 00:00 | 27.61 | 0.31 | 95.21 | 0 | 37.4 | |
| 27/10/2024 01:00 | 27.73 | 0.24 | 93.56 | 0 | 37.9 | |
| 27/10/2024 02:00 | 27.64 | 0.19 | 91.4 | 0 | 40.8 | |
| 27/10/2024 03:00 | 27.63 | 0.09 | 92.8 | 0 | 39 | |
| 27/10/2024 04:00 | 27.59 | 0.21 | 93.03 | 0 | 37.7 | |
| 27/10/2024 05:00 | 27.59 | 0.48 | 93.03 | 0 | 38.3 | |
| 27/10/2024 06:00 | 27.5 | 0.1 | 92.76 | 0 | 39.3 | |
| 27/10/2024 07:00 | 27.39 | 0.06 | 93.02 | 0 | 39.3 | |
| 27/10/2024 08:00 | 27.5 | 0.14 | 93.3 | 0 | 38.8 | |
| 27/10/2024 09:00 | 27.63 | 0.18 | 93.35 | 0 | 38.1 | |
| 27/10/2024 10:00 | 27.63 | 0.28 | 93.59 | 0 | 37.5 | |
| 27/10/2024 11:00 | 27.62 | 0.28 | 93.76 | 0 | 37 | |
| 27/10/2024 12:00 | 27.64 | 0.28 | 93.77 | 0 | 36.7 | |
| 27/10/2024 13:00 | 27.69 | 0.27 | 93.78 | 0 | 36.6 | |
| 27/10/2024 14:00 | 27.67 | 0.21 | 93.83 | 0 | 35.8 | |
| 27/10/2024 15:00 | 27.74 | 0.13 | 93.58 | 0 | 35.5 | |
| 27/10/2024 16:00 | 27.68 | 0.12 | 93.5 | 0 | 35.3 | |
| 27/10/2024 17:00 | 27.67 | 0.12 | 93.52 | 0 | 35.7 | |
| 27/10/2024 18:00 | 41.56 | 0.02 | 99.7 | 0 | 22 | |
| 27/10/2024 19:00 | 41.51 | 0.08 | 101.25 | 0 | 21.4 | |
| 27/10/2024 20:00 | 41.46 | 0.04 | 101.19 | 0 | 21.3 | |
| 27/10/2024 21:00 | 41.45 | 0.03 | 101.23 | 0 | 21.3 | |
| 27/10/2024 22:00 | 41.5 | 0.02 | 101.35 | 0 | 20.9 | |
| 27/10/2024 23:00 | 27.58 | 0.16 | 95.22 | 0 | 35.4 | |
| 28/10/2024 00:00 | 27.59 | 0.1 | 93.69 | 0 | 36.3 | |
| Minimum | 27.39 | 0.02 | 91.4 | 0 | 20.9 | |
| MinDate | 27/10/2024 07:00 | 27/10/2024 18:00 | 27/10/2024 02:00 | 27/10/2024 00:00 | 27/10/2024 22:00 | |
| Maximum | 41.56 | 0.48 | 101.35 | 0 | 40.8 | |
| MaxDate | 27/10/2024 18:00 | 27/10/2024 05:00 | 27/10/2024 22:00 | 27/10/2024 00:00 | 27/10/2024 02:00 | |
| Avg | 30.39 | 0.17 | 94.98 | 0 | 34.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.7 | 0.1 | 3.1 | 0 | 6.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/10/2024 00:00 | 27.54 | 0 | 94.12 | 0 | 37.6 | |
| 27/10/2024 01:00 | 27.67 | 0 | 93.08 | 0 | 37.9 | |
| 27/10/2024 02:00 | 27.57 | 0.84 | 91.02 | 0 | 40.9 | |
| 27/10/2024 03:00 | 27.58 | 0 | 92.37 | 0 | 39.1 | |
| 27/10/2024 04:00 | 27.52 | 0 | 92.55 | 0 | 37.8 | |
| 27/10/2024 05:00 | 27.53 | 0 | 92.41 | 0 | 38.8 | |
| 27/10/2024 06:00 | 27.43 | 0 | 92.17 | 0 | 39.9 | |
| 27/10/2024 07:00 | 27.32 | 0 | 92.36 | 0 | 39.8 | |
| 27/10/2024 08:00 | 27.44 | 0 | 92.6 | 0 | 39.6 | |
| 27/10/2024 09:00 | 27.55 | 0 | 92.62 | 0 | 39.2 | |
| 27/10/2024 10:00 | 27.56 | 0 | 92.92 | 0 | 38.7 | |
| 27/10/2024 11:00 | 27.56 | 0.11 | 93.17 | 0 | 38.4 | |
| 27/10/2024 12:00 | 27.58 | 0 | 93.13 | 0 | 38 | |
| 27/10/2024 13:00 | 27.62 | 0.67 | 93.16 | 0 | 37.6 | |
| 27/10/2024 14:00 | 27.61 | 0.8 | 93.3 | 0 | 36.7 | |
| 27/10/2024 15:00 | 27.68 | 0 | 93.2 | 0 | 36.4 | |
| 27/10/2024 16:00 | 27.63 | 0 | 93.16 | 0 | 36.2 | |
| 27/10/2024 17:00 | 27.61 | 0 | 93.22 | 0 | 36.3 | |
| 27/10/2024 18:00 | 41.52 | 0 | 98.77 | 0 | 24.8 | |
| 27/10/2024 19:00 | 41.44 | 0 | 99.72 | 0 | 24 | |
| 27/10/2024 20:00 | 41.39 | 0 | 99.6 | 0 | 23.6 | |
| 27/10/2024 21:00 | 41.38 | 0 | 99.6 | 0 | 23.7 | |
| 27/10/2024 22:00 | 41.42 | 0 | 99.66 | 0 | 23.1 | |
| 27/10/2024 23:00 | 27.52 | 0 | 94.06 | 0 | 35.8 | |
| 28/10/2024 00:00 | 27.53 | 0 | 92.65 | 0 | 36.6 | |
| Minimum | 27.32 | 0 | 91.02 | 0 | 23.1 | |
| MinDate | 27/10/2024 07:00 | 27/10/2024 00:00 | 27/10/2024 02:00 | 27/10/2024 00:00 | 27/10/2024 22:00 | |
| Maximum | 41.52 | 0.84 | 99.72 | 0 | 40.9 | |
| MaxDate | 27/10/2024 18:00 | 27/10/2024 02:00 | 27/10/2024 19:00 | 27/10/2024 00:00 | 27/10/2024 02:00 | |
| Avg | 30.33 | 0.1 | 94.18 | 0 | 35.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.7 | 0.3 | 2.8 | 0 | 6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/10/2024 00:00 | 27.59 | 0.1 | 93.69 | 0 | 36.3 | |
| 28/10/2024 01:00 | 27.63 | 0.18 | 93.49 | 0 | 35.8 | |
| 28/10/2024 02:00 | 27.6 | 0.41 | 92.24 | 0 | 39 | |
| 28/10/2024 03:00 | 27.55 | 0.02 | 92.86 | 0 | 38.3 | |
| 28/10/2024 04:00 | 27.59 | 0 | 93.05 | 0 | 38.2 | |
| 28/10/2024 05:00 | 27.61 | 0.26 | 92.95 | 0 | 37.9 | |
| 28/10/2024 06:00 | 27.61 | 0.01 | 92.46 | 0 | 38.5 | |
| 28/10/2024 07:00 | 27.84 | 0 | 92.48 | 0 | 38.5 | |
| 28/10/2024 08:00 | 40.56 | 0 | 98.55 | 0 | 22 | |
| 28/10/2024 09:00 | 34.2 | 0 | 95.44 | 0 | 20 | |
| 28/10/2024 10:00 | 34.31 | 0 | 95.47 | 0 | 20 | |
| 28/10/2024 11:00 | 34.32 | 0.05 | 95.96 | 0 | 20.1 | |
| 28/10/2024 12:00 | 21.93 | 0.23 | 92.88 | 0 | 45.3 | |
| 28/10/2024 13:00 | 34.62 | 0.16 | 95.8 | 0 | 21.8 | |
| 28/10/2024 14:00 | 34.59 | 0.23 | 96.55 | 0 | 20.4 | |
| 28/10/2024 15:00 | 34.55 | 0.11 | 95.81 | 0 | 20.4 | |
| 28/10/2024 16:00 | 34.45 | 0.04 | 95.77 | 0 | 20.4 | |
| 28/10/2024 17:00 | 34.3 | 0.05 | 95.51 | 0 | 20.3 | |
| 28/10/2024 18:00 | 34.25 | 0.05 | 95.5 | 0 | 20.3 | |
| 28/10/2024 19:00 | 34.04 | 0.03 | 95.31 | 0 | 20.3 | |
| 28/10/2024 20:00 | 34.08 | 0 | 95.19 | 0 | 20.1 | |
| 28/10/2024 21:00 | 34.26 | 0 | 95.74 | 0 | 19.8 | |
| 28/10/2024 22:00 | 34.24 | 0.01 | 95.84 | 0 | 19.8 | |
| 28/10/2024 23:00 | 34.27 | 0.05 | 95.82 | 0 | 19.7 | |
| 29/10/2024 00:00 | 7.72 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 7.72 | 0 | 92.24 | 0 | 19.7 | |
| MinDate | 29/10/2024 00:00 | 28/10/2024 04:00 | 28/10/2024 02:00 | 28/10/2024 00:00 | 28/10/2024 23:00 | |
| Maximum | 40.56 | 0.41 | 98.55 | 0 | 45.3 | |
| MaxDate | 28/10/2024 08:00 | 28/10/2024 02:00 | 28/10/2024 08:00 | 28/10/2024 00:00 | 28/10/2024 12:00 | |
| Avg | 30.87 | 0.08 | 94.77 | 0 | 27.2 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 6.3 | 0.1 | 1.6 | 0 | 9.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/10/2024 00:00 | 27.53 | 0 | 92.65 | 0 | 36.6 | |
| 28/10/2024 01:00 | 27.57 | 0 | 92.35 | 0 | 36.1 | |
| 28/10/2024 02:00 | 27.53 | 0 | 90.81 | 0 | 39.4 | |
| 28/10/2024 03:00 | 27.49 | 0 | 91.89 | 0 | 38.4 | |
| 28/10/2024 04:00 | 27.52 | 0 | 92.05 | 0 | 38.2 | |
| 28/10/2024 05:00 | 27.55 | 0 | 92.01 | 0 | 38 | |
| 28/10/2024 06:00 | 27.54 | 0 | 91.51 | 0 | 38.6 | |
| 28/10/2024 07:00 | 27.78 | 0 | 91.46 | 0 | 38.7 | |
| 28/10/2024 08:00 | 40.51 | 0 | 97.07 | 0 | 24.5 | |
| 28/10/2024 09:00 | 34.14 | 0 | 94.04 | 0 | 20.4 | |
| 28/10/2024 10:00 | 34.25 | 0 | 93.99 | 0 | 20.5 | |
| 28/10/2024 11:00 | 34.25 | 0 | 94.42 | 0 | 20.6 | |
| 28/10/2024 12:00 | 21.91 | 0 | 91.74 | 0 | 47.2 | |
| 28/10/2024 13:00 | 34.55 | 0 | 94.47 | 0 | 22.4 | |
| 28/10/2024 14:00 | 34.52 | 0.36 | 95.01 | 0 | 20.8 | |
| 28/10/2024 15:00 | 34.48 | 0 | 94.52 | 0 | 20.6 | |
| 28/10/2024 16:00 | 34.38 | 0 | 94.46 | 0 | 20.6 | |
| 28/10/2024 17:00 | 34.23 | 0 | 94.21 | 0 | 20.3 | |
| 28/10/2024 18:00 | 34.19 | 0 | 94.13 | 0 | 20.1 | |
| 28/10/2024 19:00 | 33.97 | 0 | 93.95 | 0 | 20.1 | |
| 28/10/2024 20:00 | 34.01 | 0 | 93.81 | 0 | 19.9 | |
| 28/10/2024 21:00 | 34.2 | 0 | 94.29 | 0 | 19.6 | |
| 28/10/2024 22:00 | 34.18 | 0 | 94.46 | 0 | 19.5 | |
| 28/10/2024 23:00 | 34.2 | 0 | 94.45 | 0 | 19.4 | |
| 29/10/2024 00:00 | 40.73 | 0 | 95.24 | 0 | 37.2 | |
| Minimum | 21.91 | 0 | 90.81 | 0 | 19.4 | |
| MinDate | 28/10/2024 12:00 | 28/10/2024 00:00 | 28/10/2024 02:00 | 28/10/2024 00:00 | 28/10/2024 23:00 | |
| Maximum | 40.73 | 0.36 | 97.07 | 0 | 47.2 | |
| MaxDate | 29/10/2024 00:00 | 28/10/2024 14:00 | 28/10/2024 08:00 | 28/10/2024 00:00 | 28/10/2024 12:00 | |
| Avg | 32.13 | 0.01 | 93.56 | 0 | 27.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 4.5 | 0.1 | 1.5 | 0 | 9.4 | |

| Date & Time | 11GT_LOAD MW | 11HRSG_DUST mg/m3 | 11HRSG_TEMP Degree C. | 11HRSG_SO2@7%O2 ppm | 11HRSG_NOx@7%O2 ppm | Remark |
|------------------|------------------|----------------------|--------------------------|------------------------|------------------------|----------|
| 29/10/2024 00:00 | 7.72 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 04:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 05:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 07:00 | 10.82 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/10/2024 08:00 | 34.31 | 0.05 | 96.2 | 0 | 30.2 | |
| 29/10/2024 09:00 | 34.51 | 0.25 | 96.53 | 0 | 29.2 | |
| 29/10/2024 10:00 | 34.5 | 0.41 | 96.57 | 0 | 29.4 | |
| 29/10/2024 11:00 | 34.45 | 0.27 | 96.43 | 0 | 29.4 | |
| 29/10/2024 12:00 | 22.86 | 0.35 | 93.45 | 0 | 53.3 | |
| 29/10/2024 13:00 | 34.57 | 0.35 | 96 | 0 | 30.1 | |
| 29/10/2024 14:00 | 34.63 | 0.36 | 96.71 | 0 | 28.4 | |
| 29/10/2024 15:00 | 34.63 | 0.25 | 96.38 | 0 | 28.2 | |
| 29/10/2024 16:00 | 34.47 | 0.19 | 96.08 | 0 | 28.3 | |
| 29/10/2024 17:00 | 34.31 | 0.04 | 95.68 | 0 | 26.9 | |
| 29/10/2024 18:00 | 34.3 | 0 | 95.4 | 0 | 27.1 | |
| 29/10/2024 19:00 | 34.05 | 0 | 95.23 | 0 | 26.8 | |
| 29/10/2024 20:00 | 34.12 | 0.01 | 95.28 | 0 | 26.8 | |
| 29/10/2024 21:00 | 34.28 | 0 | 95.74 | 0 | 26.8 | |
| 29/10/2024 22:00 | 34.26 | 0 | 95.79 | 0 | 26.7 | |
| 29/10/2024 23:00 | 34.19 | 0.02 | 95.81 | 0 | 26.6 | |
| 30/10/2024 00:00 | 40.69 | 0.05 | 96.41 | 0 | 40.8 | |
| Minimum | 0 | 0 | 93.88 | 1.3 | 26.7 | |
| MinDate | 29/05/2024 01:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 15:00 | 29/05/2024 23:00 | |
| Maximum | 40 | 0.19 | 95.98 | 1.4 | 44.9 | |
| MaxDate | 30/05/2024 00:00 | 29/05/2024 06:00 | 29/05/2024 14:00 | 29/05/2024 09:00 | 29/05/2024 12:00 | |
| Avg | 22.28 | 0.01 | 95.18 | 1.3 | 30.8 | |
| Num | 25 | 25 | 16 | 16 | 16 | |
| Data[%] | 100 | 100 | 64 | 64 | 64 | |
| STD | 16.1 | 0 | 0.6 | 0.1 | 5.2 | |

| Date & Time | 12GT_LOAD MW | 12HRSG_DUST mg/m3 | 12HRSG_TEMP Degree C. | 12HRSG_SO2@7%O2 ppm | 12HRSG_NOx@7%O2 ppm | Remark |
|------------------|------------------|----------------------|--------------------------|------------------------|------------------------|----------|
| 29/10/2024 00:00 | 40.73 | 0 | 95.24 | 0 | 37.2 | |
| 29/10/2024 01:00 | 48.82 | 0 | 95.26 | 0 | 36.8 | |
| 29/10/2024 02:00 | 48.85 | 0 | 95.62 | 0 | 37.4 | |
| 29/10/2024 03:00 | 48.89 | 0 | 95.8 | 0 | 37.5 | |
| 29/10/2024 04:00 | 48.82 | 0 | 95.86 | 0 | 37 | |
| 29/10/2024 05:00 | 48.81 | 0 | 95.96 | 0 | 36.2 | |
| 29/10/2024 06:00 | 48.97 | 0 | 96.15 | 0 | 36.6 | |
| 29/10/2024 07:00 | 39.5 | 0 | 95.65 | 0 | 35.1 | |
| 29/10/2024 08:00 | 34.18 | 0 | 94.68 | 0 | 21.5 | |
| 29/10/2024 09:00 | 34.45 | 0.22 | 95.05 | 0 | 20.1 | |
| 29/10/2024 10:00 | 34.43 | 0.03 | 94.98 | 0 | 20.2 | |
| 29/10/2024 11:00 | 34.37 | 0.07 | 94.93 | 0 | 20.1 | |
| 29/10/2024 12:00 | 22.77 | 0.08 | 92.27 | 0 | 47.4 | |
| 29/10/2024 13:00 | 34.48 | 0.01 | 94.7 | 0 | 21 | |
| 29/10/2024 14:00 | 34.57 | 0.3 | 95.25 | 0 | 19.2 | |
| 29/10/2024 15:00 | 34.56 | 0.05 | 95.1 | 0 | 19.3 | |
| 29/10/2024 16:00 | 34.4 | 0.05 | 94.85 | 0 | 19.2 | |
| 29/10/2024 17:00 | 34.25 | 0.1 | 94.47 | 0 | 18.4 | |
| 29/10/2024 18:00 | 34.24 | 0.08 | 94.33 | 0 | 18.8 | |
| 29/10/2024 19:00 | 33.98 | 0.08 | 94.16 | 0 | 18.6 | |
| 29/10/2024 20:00 | 34.06 | 0.08 | 94.22 | 0 | 18.7 | |
| 29/10/2024 21:00 | 34.22 | 0.08 | 94.46 | 0 | 18.8 | |
| 29/10/2024 22:00 | 34.2 | 0.08 | 94.48 | 0 | 18.8 | |
| 29/10/2024 23:00 | 34.12 | 0.08 | 94.55 | 0 | 18.7 | |
| 30/10/2024 00:00 | 7.33 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 7.84 | --- | 93.91 | 0 | 18.9 | |
| MinDate | 30/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 12:00 | 29/05/2024 00:00 | 29/05/2024 23:00 | |
| Maximum | 47.72 | --- | 95.92 | 0 | 39.8 | |
| MaxDate | 29/05/2024 06:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 00:00 | 29/05/2024 04:00 | |
| Avg | 36.95 | --- | 95.16 | 0 | 28.6 | |
| Num | 25 | 0 | 24 | 24 | 24 | |
| Data[%] | 100 | --- | 96 | 96 | 96 | |
| STD | 9 | --- | 0.5 | 0 | 9.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/10/2024 00:00 | 40.69 | 0.05 | 96.41 | 0 | 40.8 | |
| 30/10/2024 01:00 | 48.42 | 0 | 96.48 | 0 | 38.5 | |
| 30/10/2024 02:00 | 48.52 | 0.01 | 96.83 | 0 | 38.1 | |
| 30/10/2024 03:00 | 48.65 | 0 | 96.8 | 0 | 38.1 | |
| 30/10/2024 04:00 | 48.76 | 0.02 | 96.88 | 0 | 38 | |
| 30/10/2024 05:00 | 48.98 | 0.41 | 96.91 | 0 | 37.9 | |
| 30/10/2024 06:00 | 49 | 0 | 97.27 | 0 | 37.8 | |
| 30/10/2024 07:00 | 38.94 | 0.03 | 97.04 | 0 | 38.8 | |
| 30/10/2024 08:00 | 34.22 | 0 | 95.5 | 0 | 27.4 | |
| 30/10/2024 09:00 | 34.42 | 0.05 | 96.23 | 0 | 26.1 | |
| 30/10/2024 10:00 | 34.46 | 0.13 | 96.42 | 0 | 26.6 | |
| 30/10/2024 11:00 | 34.4 | 0.16 | 96.55 | 0 | 26.3 | |
| 30/10/2024 12:00 | 23.15 | 0.42 | 93.54 | 0 | 50 | |
| 30/10/2024 13:00 | 34.61 | 0.36 | 96.06 | 0 | 27.9 | |
| 30/10/2024 14:00 | 34.56 | 0.29 | 96.65 | 0 | 26.4 | |
| 30/10/2024 15:00 | 34.54 | 0.2 | 96.07 | 0 | 25.8 | |
| 30/10/2024 16:00 | 34.44 | 0 | 95.21 | 0 | 25.5 | |
| 30/10/2024 17:00 | 34.23 | 0 | 95.04 | 0 | 25.5 | |
| 30/10/2024 18:00 | 34.17 | 0 | 95.07 | 0 | 25.1 | |
| 30/10/2024 19:00 | 34.06 | 0 | 94.92 | 0 | 25.1 | |
| 30/10/2024 20:00 | 34.13 | 0 | 94.98 | 0 | 25 | |
| 30/10/2024 21:00 | 34.25 | 0 | 95.38 | 0 | 25.1 | |
| 30/10/2024 22:00 | 34.22 | 0 | 95.52 | 0 | 25.1 | |
| 30/10/2024 23:00 | 34.22 | 0 | 95.55 | 0 | 25 | |
| 31/10/2024 00:00 | 7.66 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 8.32 | 0 | 94.2 | 1.3 | 25.5 | |
| MinDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 00:00 | 30/05/2024 22:00 | |
| Maximum | 48.02 | 0.38 | 96.03 | 1.5 | 43.9 | |
| MaxDate | 30/05/2024 06:00 | 30/05/2024 06:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 37.19 | 0.02 | 95.04 | 1.4 | 32.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.5 | 0.1 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/10/2024 00:00 | 7.33 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 07:00 | 11.69 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 30/10/2024 08:00 | 34.13 | 0.08 | 94.65 | 0 | 26.2 | |
| 30/10/2024 09:00 | 34.36 | 0.08 | 94.98 | 0 | 24.7 | |
| 30/10/2024 10:00 | 34.4 | 0.08 | 94.99 | 0 | 25.2 | |
| 30/10/2024 11:00 | 34.35 | 0.08 | 95.19 | 0 | 24.8 | |
| 30/10/2024 12:00 | 23.12 | 0.08 | 92.55 | 0 | 49 | |
| 30/10/2024 13:00 | 34.55 | 0.08 | 94.85 | 0 | 26.1 | |
| 30/10/2024 14:00 | 34.5 | 0.31 | 95.17 | 0 | 24.4 | |
| 30/10/2024 15:00 | 34.47 | 0.08 | 94.72 | 0 | 23.9 | |
| 30/10/2024 16:00 | 34.38 | 0.08 | 94.08 | 0 | 23.8 | |
| 30/10/2024 17:00 | 34.17 | 0.08 | 93.75 | 0 | 23.7 | |
| 30/10/2024 18:00 | 34.1 | 0.08 | 93.79 | 0 | 23.3 | |
| 30/10/2024 19:00 | 34 | 0.08 | 93.53 | 0 | 23.4 | |
| 30/10/2024 20:00 | 34.06 | 0.08 | 93.62 | 0 | 23.4 | |
| 30/10/2024 21:00 | 34.18 | 0.08 | 93.91 | 0 | 23.5 | |
| 30/10/2024 22:00 | 34.15 | 0.08 | 94.04 | 0 | 23.5 | |
| 30/10/2024 23:00 | 34.16 | 0.08 | 94.07 | 0 | 23.5 | |
| 31/10/2024 00:00 | 40.9 | 0.08 | 94.99 | 0 | 43.2 | |
| Minimum | 0 | --- | 94.25 | 0 | 20.5 | |
| MinDate | 30/05/2024 01:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 09:00 | 30/05/2024 19:00 | |
| Maximum | 39.65 | --- | 96.1 | 0 | 39.7 | |
| MaxDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 22.18 | --- | 95.12 | 0 | 24.5 | |
| Num | 25 | 0 | 16 | 16 | 16 | |
| Data[%] | 100 | --- | 64 | 64 | 64 | |
| STD | 16.1 | --- | 0.5 | 0 | 6.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/10/2024 00:00 | 7.66 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 05:00 | 0 | 0.37 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 07:00 | 10.71 | 0.41 | ShutDown | ShutDown | ShutDown | GT11 SD |
| 31/10/2024 08:00 | 34.41 | 0.26 | 96.29 | 0 | 29.3 | |
| 31/10/2024 09:00 | 34.61 | 0.38 | 96.55 | 0 | 27.6 | |
| 31/10/2024 10:00 | 34.62 | 0.46 | 96.58 | 0 | 27.5 | |
| 31/10/2024 11:00 | 34.56 | 0.37 | 96.6 | 0 | 27.6 | |
| 31/10/2024 12:00 | 22.12 | 0.49 | 93.4 | 0 | 51.4 | |
| 31/10/2024 13:00 | 34.75 | 0.43 | 96.16 | 0 | 29.8 | |
| 31/10/2024 14:00 | 34.54 | 0.35 | 96.55 | 0 | 28.1 | |
| 31/10/2024 15:00 | 34.64 | 0.33 | 96.25 | 0 | 27.4 | |
| 31/10/2024 16:00 | 34.51 | 0.03 | 95.93 | 0 | 27.1 | |
| 31/10/2024 17:00 | 34.34 | 0.01 | 95.74 | 0 | 26.7 | |
| 31/10/2024 18:00 | 34.3 | 0.13 | 95.58 | 0 | 26.6 | |
| 31/10/2024 19:00 | 34.16 | 0.15 | 95.52 | 0 | 26.5 | |
| 31/10/2024 20:00 | 34.27 | 0.15 | 95.65 | 0 | 26.2 | |
| 31/10/2024 21:00 | 34.42 | 0.08 | 95.93 | 0 | 26.2 | |
| 31/10/2024 22:00 | 34.46 | 0.13 | 96 | 0 | 26 | |
| 31/10/2024 23:00 | 34.41 | 0.08 | 95.82 | 0 | 25.7 | |
| 01/11/2024 00:00 | 40.45 | 0.09 | 96.3 | 0 | 40.1 | |
| Minimum | 0 | 0 | 93.4 | 0 | 25.7 | |
| MinDate | 31/10/2024 01:00 | 31/10/2024 01:00 | 31/10/2024 12:00 | 31/10/2024 08:00 | 31/10/2024 23:00 | |
| Maximum | 40.45 | 0.49 | 96.6 | 0 | 51.4 | |
| MaxDate | 01/11/2024 00:00 | 31/10/2024 12:00 | 31/10/2024 11:00 | 31/10/2024 08:00 | 31/10/2024 12:00 | |
| Avg | 23.92 | 0.19 | 95.93 | 0 | 29.4 | |
| Num | 25 | 25 | 17 | 17 | 17 | |
| Data[%] | 100 | 100 | 68 | 68 | 68 | |
| STD | 15.6 | 0.2 | 0.7 | 0 | 6.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/10/2024 00:00 | 40.9 | 0.08 | 94.99 | 0 | 43.2 | |
| 31/10/2024 01:00 | 48.96 | 0.08 | 95.48 | 0 | 43.5 | |
| 31/10/2024 02:00 | 48.92 | 0.08 | 95.92 | 0 | 43.4 | |
| 31/10/2024 03:00 | 48.98 | 0.08 | 96.13 | 0 | 42.5 | |
| 31/10/2024 04:00 | 48.92 | 0.08 | 96.24 | 0 | 42.5 | |
| 31/10/2024 05:00 | 48.89 | 0.08 | 96.24 | 0 | 41.3 | |
| 31/10/2024 06:00 | 48.96 | 0.08 | 96.58 | 0 | 42.3 | |
| 31/10/2024 07:00 | 39.79 | 0.08 | 95.82 | 0 | 39.6 | |
| 31/10/2024 08:00 | 34.3 | 0.08 | 94.79 | 0 | 24.6 | |
| 31/10/2024 09:00 | 34.54 | 0.08 | 95.21 | 0 | 22.8 | |
| 31/10/2024 10:00 | 34.55 | 0.08 | 95.26 | 0 | 22.8 | |
| 31/10/2024 11:00 | 34.51 | 0.08 | 95.23 | 0 | 22.8 | |
| 31/10/2024 12:00 | 22.11 | 0.08 | 92.28 | 0 | 48 | |
| 31/10/2024 13:00 | 34.68 | 0.08 | 94.9 | 0 | 24.8 | |
| 31/10/2024 14:00 | 34.52 | 0.25 | 95.25 | 0 | 22.9 | |
| 31/10/2024 15:00 | 34.57 | 0.08 | 95.03 | 0 | 22.3 | |
| 31/10/2024 16:00 | 34.44 | 0.08 | 94.75 | 0 | 22.2 | |
| 31/10/2024 17:00 | 34.28 | 0.08 | 94.69 | 0 | 21.9 | |
| 31/10/2024 18:00 | 34.24 | 0.08 | 94.57 | 0 | 21.8 | |
| 31/10/2024 19:00 | 34.1 | 0.08 | 94.49 | 0 | 21.7 | |
| 31/10/2024 20:00 | 34.21 | 0.08 | 94.6 | 0 | 21.6 | |
| 31/10/2024 21:00 | 34.36 | 0.08 | 94.8 | 0 | 21.6 | |
| 31/10/2024 22:00 | 34.4 | 0.08 | 94.84 | 0 | 21.4 | |
| 31/10/2024 23:00 | 34.34 | 0.08 | 94.61 | 0 | 21 | |
| 01/11/2024 00:00 | 7.86 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 7.86 | 0.08 | 92.28 | 0 | 21 | |
| MinDate | 01/11/2024 00:00 | 31/10/2024 00:00 | 31/10/2024 12:00 | 31/10/2024 00:00 | 31/10/2024 23:00 | |
| Maximum | 48.98 | 0.25 | 96.58 | 0 | 48 | |
| MaxDate | 31/10/2024 03:00 | 31/10/2024 14:00 | 31/10/2024 06:00 | 31/10/2024 00:00 | 31/10/2024 12:00 | |
| Avg | 36.81 | 0.09 | 95.11 | 0 | 30.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.2 | 0 | 0.9 | 0 | 10.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/11/2024 00:00 | 40.45 | 0.09 | 96.3 | 0 | 40.1 | |
| 01/11/2024 01:00 | 48.32 | 0.03 | 96.3 | 0 | 38.3 | |
| 01/11/2024 02:00 | 48.44 | 0.03 | 96.65 | 0 | 38.2 | |
| 01/11/2024 03:00 | 48.45 | 0.03 | 96.82 | 0 | 38 | |
| 01/11/2024 04:00 | 48.45 | 0.04 | 96.75 | 0 | 37.6 | |
| 01/11/2024 05:00 | 48.57 | 0.29 | 96.82 | 0 | 37.8 | |
| 01/11/2024 06:00 | 48.64 | 0 | 96.88 | 0 | 37.6 | |
| 01/11/2024 07:00 | 48.33 | 0 | 97 | 0 | 37.3 | |
| 01/11/2024 08:00 | 47.88 | 0 | 96.9 | 0 | 37.1 | |
| 01/11/2024 09:00 | 47.5 | 0.06 | 96.74 | 0 | 37.7 | |
| 01/11/2024 10:00 | 47.13 | 0.13 | 96.81 | 0 | 38 | |
| 01/11/2024 11:00 | 47.3 | 0.04 | 96.77 | 0 | 37.8 | |
| 01/11/2024 12:00 | 42.73 | 0.07 | 97.46 | 0 | 37.2 | |
| 01/11/2024 13:00 | 32.46 | 0.06 | 95.48 | 0 | 32.6 | |
| 01/11/2024 14:00 | 34.45 | 0.06 | 94.95 | 0 | 24.8 | |
| 01/11/2024 15:00 | 34.28 | 0 | 95.03 | 0 | 24.4 | |
| 01/11/2024 16:00 | 33.75 | 0 | 94.74 | 0 | 24.5 | |
| 01/11/2024 17:00 | 33.19 | 0 | 94.76 | 0 | 24.3 | |
| 01/11/2024 18:00 | 33.1 | 0 | 94.69 | 0 | 24.5 | |
| 01/11/2024 19:00 | 33.11 | 0 | 94.09 | 0 | 25.1 | |
| 01/11/2024 20:00 | 33.84 | 0 | 94.63 | 0 | 24.2 | |
| 01/11/2024 21:00 | 34.15 | 0 | 95.4 | 0 | 24.2 | |
| 01/11/2024 22:00 | 31.48 | 0 | 95.15 | 0 | 30.2 | |
| 01/11/2024 23:00 | 2.39 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.09 | 0 | 24.2 | |
| MinDate | 02/11/2024 00:00 | 01/11/2024 06:00 | 01/11/2024 19:00 | 01/11/2024 00:00 | 01/11/2024 20:00 | |
| Maximum | 48.64 | 0.29 | 97.46 | 0 | 40.1 | |
| MaxDate | 01/11/2024 06:00 | 01/11/2024 05:00 | 01/11/2024 12:00 | 01/11/2024 00:00 | 01/11/2024 00:00 | |
| Avg | 37.94 | 0.04 | 95.96 | 0 | 32.7 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13 | 0.1 | 1 | 0 | 6.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/11/2024 00:00 | 7.86 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 12:00 | 6.79 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 01/11/2024 13:00 | 32.32 | 0.08 | 94.03 | 0 | 31.2 | |
| 01/11/2024 14:00 | 34.39 | 0.44 | 93.53 | 0 | 24 | |
| 01/11/2024 15:00 | 34.21 | 0.08 | 93.76 | 0 | 23.6 | |
| 01/11/2024 16:00 | 33.68 | 0.08 | 93.44 | 0 | 24.2 | |
| 01/11/2024 17:00 | 33.13 | 0.08 | 93.48 | 0 | 25.9 | |
| 01/11/2024 18:00 | 33.04 | 0.08 | 93.49 | 0 | 25.8 | |
| 01/11/2024 19:00 | 33.04 | 0.08 | 93.03 | 0 | 26.7 | |
| 01/11/2024 20:00 | 33.77 | 0.08 | 93.34 | 0 | 23.6 | |
| 01/11/2024 21:00 | 34.08 | 0.08 | 93.95 | 0 | 23.3 | |
| 01/11/2024 22:00 | 31.45 | 0.08 | 93.71 | 0 | 29.3 | |
| 01/11/2024 23:00 | 46.71 | 0.08 | 95.93 | 0 | 42.3 | |
| 02/11/2024 00:00 | 48.38 | 0.08 | 95.47 | 0 | 41.6 | |
| Minimum | 0 | 0.08 | 93.03 | 0 | 23.3 | |
| MinDate | 01/11/2024 01:00 | 01/11/2024 00:00 | 01/11/2024 19:00 | 01/11/2024 13:00 | 01/11/2024 21:00 | |
| Maximum | 48.38 | 0.44 | 95.93 | 0 | 42.3 | |
| MaxDate | 02/11/2024 00:00 | 01/11/2024 14:00 | 01/11/2024 23:00 | 01/11/2024 13:00 | 01/11/2024 23:00 | |
| Avg | 17.71 | 0.09 | 93.93 | 0 | 28.5 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.1 | 0.1 | 0.9 | 0 | 6.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 05:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 11:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 12:00 | 4.99 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/11/2024 13:00 | 37.11 | 0 | 97.97 | 0 | 42 | |
| 02/11/2024 14:00 | 40.89 | 0 | 100.08 | 0 | 34.7 | |
| 02/11/2024 15:00 | 40.93 | 0 | 99.84 | 0 | 34.2 | |
| 02/11/2024 16:00 | 40.94 | 0 | 99.71 | 0 | 33.8 | |
| 02/11/2024 17:00 | 40.95 | 0 | 99.67 | 0 | 33.6 | |
| 02/11/2024 18:00 | 40.95 | 0 | 99.44 | 0 | 33.3 | |
| 02/11/2024 19:00 | 40.92 | 0 | 99.27 | 0 | 33.1 | |
| 02/11/2024 20:00 | 40.94 | 0 | 99.11 | 0 | 32.9 | |
| 02/11/2024 21:00 | 40.89 | 0 | 99.41 | 0 | 32.7 | |
| 02/11/2024 22:00 | 37.28 | 0 | 98.5 | 0 | 36.3 | |
| 02/11/2024 23:00 | 26.93 | 0 | 92.87 | 0 | 53 | |
| 03/11/2024 00:00 | 26.9 | 0 | 92.16 | 0 | 53.3 | |
| Minimum | 0 | 0 | 92.16 | 0 | 32.7 | |
| MinDate | 02/11/2024 00:00 | 02/11/2024 00:00 | 03/11/2024 00:00 | 02/11/2024 13:00 | 02/11/2024 21:00 | |
| Maximum | 40.95 | 0.34 | 100.08 | 0 | 53.3 | |
| MaxDate | 02/11/2024 17:00 | 02/11/2024 12:00 | 02/11/2024 14:00 | 02/11/2024 13:00 | 03/11/2024 00:00 | |
| Avg | 18.42 | 0.02 | 98.17 | 0 | 37.7 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 19.5 | 0.1 | 2.7 | 0 | 7.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/11/2024 00:00 | 48.38 | 0.08 | 95.47 | 0 | 41.6 | |
| 02/11/2024 01:00 | 48.29 | 0.08 | 95.92 | 0 | 41.2 | |
| 02/11/2024 02:00 | 48.11 | 0.08 | 96.18 | 0 | 39.8 | |
| 02/11/2024 03:00 | 47.59 | 0.08 | 96.6 | 0 | 37.3 | |
| 02/11/2024 04:00 | 46.83 | 0.08 | 96.84 | 0 | 35.4 | |
| 02/11/2024 05:00 | 46.41 | 0.08 | 97.02 | 0 | 33.4 | |
| 02/11/2024 06:00 | 46.33 | 0.08 | 96.83 | 0 | 33.1 | |
| 02/11/2024 07:00 | 46.28 | 0.08 | 96.7 | 0 | 34.2 | |
| 02/11/2024 08:00 | 47.72 | 0.08 | 95.6 | 0 | 44.2 | |
| 02/11/2024 09:00 | 47.59 | 0.08 | 94.75 | 0 | 47.8 | |
| 02/11/2024 10:00 | 47.35 | 0.08 | 94.9 | 0 | 47.9 | |
| 02/11/2024 11:00 | 47.25 | 0.08 | 95.13 | 0 | 47.6 | |
| 02/11/2024 12:00 | 44.9 | 0.08 | 95.45 | 0 | 45.5 | |
| 02/11/2024 13:00 | 37.07 | 0.08 | 95.6 | 0 | 37.1 | |
| 02/11/2024 14:00 | 40.81 | 0.38 | 98.22 | 0 | 29.5 | |
| 02/11/2024 15:00 | 40.85 | 0.08 | 98.19 | 0 | 29.1 | |
| 02/11/2024 16:00 | 40.87 | 0.08 | 98.09 | 0 | 28.6 | |
| 02/11/2024 17:00 | 40.87 | 0.08 | 98.05 | 0 | 28 | |
| 02/11/2024 18:00 | 40.88 | 0.08 | 97.87 | 0 | 27.5 | |
| 02/11/2024 19:00 | 40.85 | 0.08 | 97.77 | 0 | 27.2 | |
| 02/11/2024 20:00 | 40.86 | 0.08 | 97.66 | 0 | 27 | |
| 02/11/2024 21:00 | 40.82 | 0.08 | 97.94 | 0 | 26.7 | |
| 02/11/2024 22:00 | 37.21 | 0.08 | 97.02 | 0 | 30.5 | |
| 02/11/2024 23:00 | 26.86 | 0.08 | 91.92 | 0 | 45.9 | |
| 03/11/2024 00:00 | 26.85 | 0.08 | 91.17 | 0 | 46.1 | |
| Minimum | 26.85 | 0.08 | 91.17 | 0 | 26.7 | |
| MinDate | 03/11/2024 00:00 | 02/11/2024 00:00 | 03/11/2024 00:00 | 02/11/2024 00:00 | 02/11/2024 21:00 | |
| Maximum | 48.38 | 0.38 | 98.22 | 0 | 47.9 | |
| MaxDate | 02/11/2024 00:00 | 02/11/2024 14:00 | 02/11/2024 14:00 | 02/11/2024 00:00 | 02/11/2024 10:00 | |
| Avg | 42.71 | 0.09 | 96.28 | 0 | 36.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6 | 0.1 | 1.8 | 0 | 7.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/11/2024 00:00 | 26.9 | 0 | 92.16 | 0 | 53.3 | |
| 03/11/2024 01:00 | 26.92 | 0 | 91.98 | 0 | 53.6 | |
| 03/11/2024 02:00 | 26.92 | 0 | 91.85 | 0 | 52.9 | |
| 03/11/2024 03:00 | 26.91 | 0 | 91.79 | 0 | 52.9 | |
| 03/11/2024 04:00 | 26.93 | 0 | 91.63 | 0 | 53.3 | |
| 03/11/2024 05:00 | 26.87 | 0.15 | 91.31 | 0 | 53.4 | |
| 03/11/2024 06:00 | 26.82 | 0 | 91.44 | 0 | 54.1 | |
| 03/11/2024 07:00 | 26.82 | 0.01 | 91.71 | 0 | 54.2 | |
| 03/11/2024 08:00 | 26.81 | 0.05 | 91.79 | 0 | 53.8 | |
| 03/11/2024 09:00 | 26.85 | 0.1 | 92.01 | 0 | 53.3 | |
| 03/11/2024 10:00 | 26.86 | 0.17 | 92.43 | 0 | 52.9 | |
| 03/11/2024 11:00 | 26.9 | 0.23 | 92.7 | 0 | 51.7 | |
| 03/11/2024 12:00 | 26.92 | 0.27 | 92.72 | 0 | 50.9 | |
| 03/11/2024 13:00 | 26.95 | 0.24 | 92.81 | 0 | 50.5 | |
| 03/11/2024 14:00 | 27.01 | 0.19 | 92.86 | 0 | 50.2 | |
| 03/11/2024 15:00 | 27.07 | 0.22 | 92.58 | 0 | 49.9 | |
| 03/11/2024 16:00 | 27.09 | 0.18 | 92.43 | 0 | 49.9 | |
| 03/11/2024 17:00 | 30.63 | 0.17 | 93.3 | 0 | 46 | |
| 03/11/2024 18:00 | 40.9 | 0.12 | 99.13 | 0 | 31.3 | |
| 03/11/2024 19:00 | 40.84 | 0.1 | 99.47 | 0 | 31.3 | |
| 03/11/2024 20:00 | 40.79 | 0.06 | 99.36 | 0 | 31.1 | |
| 03/11/2024 21:00 | 41.02 | 0.07 | 98.11 | 0 | 37.1 | |
| 03/11/2024 22:00 | 48.21 | 0 | 96.16 | 0 | 39.8 | |
| 03/11/2024 23:00 | 48.39 | 0 | 96.31 | 0 | 39.6 | |
| 04/11/2024 00:00 | 48.45 | 0 | 96.55 | 0 | 39.4 | |
| Minimum | 26.81 | 0 | 91.31 | 0 | 31.1 | |
| MinDate | 03/11/2024 08:00 | 03/11/2024 00:00 | 03/11/2024 05:00 | 03/11/2024 00:00 | 03/11/2024 20:00 | |
| Maximum | 48.45 | 0.27 | 99.47 | 0 | 54.2 | |
| MaxDate | 04/11/2024 00:00 | 03/11/2024 12:00 | 03/11/2024 19:00 | 03/11/2024 00:00 | 03/11/2024 07:00 | |
| Avg | 31.87 | 0.09 | 93.78 | 0 | 47.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8.1 | 0.1 | 2.7 | 0 | 8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | | |
| 03/11/2024 00:00 | 26.85 | 0.08 | 91.17 | 0 | 46.1 | |
| 03/11/2024 01:00 | 26.87 | 0.08 | 90.89 | 0 | 46.4 | |
| 03/11/2024 02:00 | 26.86 | 0.08 | 90.8 | 0 | 46 | |
| 03/11/2024 03:00 | 26.85 | 0.08 | 90.76 | 0 | 46.1 | |
| 03/11/2024 04:00 | 26.87 | 0.08 | 90.58 | 0 | 46.6 | |
| 03/11/2024 05:00 | 26.8 | 0.08 | 90.44 | 0 | 47 | |
| 03/11/2024 06:00 | 26.76 | 0.08 | 90.42 | 0 | 47.8 | |
| 03/11/2024 07:00 | 26.76 | 0.08 | 90.65 | 0 | 47.7 | |
| 03/11/2024 08:00 | 26.75 | 0.08 | 90.8 | 0 | 47.1 | |
| 03/11/2024 09:00 | 26.77 | 0.08 | 91.11 | 0 | 46.2 | |
| 03/11/2024 10:00 | 26.81 | 0.08 | 91.47 | 0 | 45.4 | |
| 03/11/2024 11:00 | 26.84 | 0.08 | 91.67 | 0 | 44.6 | |
| 03/11/2024 12:00 | 26.86 | 0.08 | 91.68 | 0 | 44.1 | |
| 03/11/2024 13:00 | 26.89 | 0.08 | 91.76 | 0 | 43.6 | |
| 03/11/2024 14:00 | 26.95 | 0.31 | 91.86 | 0 | 43.2 | |
| 03/11/2024 15:00 | 27.01 | 0.08 | 91.64 | 0 | 43 | |
| 03/11/2024 16:00 | 27.03 | 0.08 | 91.48 | 0 | 43 | |
| 03/11/2024 17:00 | 30.56 | 0.08 | 92.47 | 0 | 39.8 | |
| 03/11/2024 18:00 | 40.83 | 0.08 | 97.64 | 0 | 25.5 | |
| 03/11/2024 19:00 | 40.77 | 0.08 | 97.98 | 0 | 25.2 | |
| 03/11/2024 20:00 | 40.72 | 0.08 | 97.88 | 0 | 25.1 | |
| 03/11/2024 21:00 | 19.48 | 0.08 | <Samp | <Samp | <Samp | GT12 S/D |
| 03/11/2024 22:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/11/2024 23:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 90.42 | 0 | 25.1 | |
| MinDate | 03/11/2024 22:00 | 03/11/2024 00:00 | 03/11/2024 06:00 | 03/11/2024 00:00 | 03/11/2024 20:00 | |
| Maximum | 40.83 | 0.31 | 97.98 | 0 | 47.8 | |
| MaxDate | 03/11/2024 18:00 | 03/11/2024 14:00 | 03/11/2024 19:00 | 03/11/2024 00:00 | 03/11/2024 06:00 | |
| Avg | 25.16 | 0.09 | 92.15 | 0 | 42.4 | |
| Num | 25 | 25 | 21 | 21 | 21 | |
| Data[%] | 100 | 100 | 84 | 84 | 84 | |
| STD | 10.7 | 0 | 2.4 | 0 | 7.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/11/2024 00:00 | 48.45 | 0 | 96.55 | 0 | 39.4 | |
| 04/11/2024 01:00 | 48.47 | 0 | 96.45 | 0 | 39.6 | |
| 04/11/2024 02:00 | 48.53 | 0 | 96.44 | 0 | 39.6 | |
| 04/11/2024 03:00 | 48.47 | 0 | 96.43 | 0 | 39.4 | |
| 04/11/2024 04:00 | 48.45 | 0 | 96.39 | 0 | 39.3 | |
| 04/11/2024 05:00 | 48.51 | 0.32 | 96.39 | 0 | 39.2 | |
| 04/11/2024 06:00 | 48.63 | 0 | 96.61 | 0 | 39.4 | |
| 04/11/2024 07:00 | 48.29 | 0 | 96.57 | 0 | 39.2 | |
| 04/11/2024 08:00 | 47.95 | 0 | 96.42 | 0 | 38.9 | |
| 04/11/2024 09:00 | 47.63 | 0 | 96.29 | 0 | 38.6 | |
| 04/11/2024 10:00 | 47.48 | 0 | 96.33 | 0 | 38.5 | |
| 04/11/2024 11:00 | 47.33 | 0 | 96.47 | 0 | 38.2 | |
| 04/11/2024 12:00 | 45.25 | 0.01 | 96.94 | 0 | 36.9 | |
| 04/11/2024 13:00 | 32.38 | 0.08 | 95.2 | 0 | 35.7 | |
| 04/11/2024 14:00 | 34.7 | 0.05 | 95.75 | 0 | 26.3 | |
| 04/11/2024 15:00 | 34.62 | 0.03 | 95.45 | 0 | 26 | |
| 04/11/2024 16:00 | 34.57 | 0.01 | 95.48 | 0 | 25.7 | |
| 04/11/2024 17:00 | 34.44 | 0.05 | 95.49 | 0 | 25.4 | |
| 04/11/2024 18:00 | 34.37 | 0.13 | 95.7 | 0 | 25.4 | |
| 04/11/2024 19:00 | 34.28 | 0.18 | 95.6 | 0 | 25.3 | |
| 04/11/2024 20:00 | 34.37 | 0.22 | 95.61 | 0 | 24.8 | |
| 04/11/2024 21:00 | 34.56 | 0.15 | 95.81 | 0 | 24.9 | |
| 04/11/2024 22:00 | 31.5 | 0.02 | 94.89 | 0 | 31.6 | |
| 04/11/2024 23:00 | 2.19 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 00:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.89 | 0 | 24.8 | |
| MinDate | 05/11/2024 00:00 | 04/11/2024 00:00 | 04/11/2024 22:00 | 04/11/2024 00:00 | 04/11/2024 20:00 | |
| Maximum | 48.63 | 0.32 | 96.94 | 0 | 39.6 | |
| MaxDate | 04/11/2024 06:00 | 04/11/2024 05:00 | 04/11/2024 12:00 | 04/11/2024 00:00 | 04/11/2024 01:00 | |
| Avg | 38.62 | 0.05 | 96.05 | 0 | 33.8 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.2 | 0.1 | 0.5 | 0 | 6.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 12:00 | 4.43 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 04/11/2024 13:00 | 32.32 | 0.08 | 93.37 | 0 | 35.7 | |
| 04/11/2024 14:00 | 34.64 | 0.23 | 94.24 | 0 | 26.2 | |
| 04/11/2024 15:00 | 34.55 | 0.08 | 94.06 | 0 | 25.6 | |
| 04/11/2024 16:00 | 34.5 | 0.08 | 94.09 | 0 | 25.2 | |
| 04/11/2024 17:00 | 34.37 | 0.08 | 94.16 | 0 | 24.9 | |
| 04/11/2024 18:00 | 34.31 | 0.08 | 94.35 | 0 | 24.7 | |
| 04/11/2024 19:00 | 34.2 | 0.08 | 94.28 | 0 | 24.6 | |
| 04/11/2024 20:00 | 34.3 | 0.08 | 94.22 | 0 | 24.1 | |
| 04/11/2024 21:00 | 34.49 | 0.08 | 94.33 | 0 | 24.4 | |
| 04/11/2024 22:00 | 31.52 | 0.08 | 93.4 | 0 | 31.3 | |
| 04/11/2024 23:00 | 46.83 | 0.08 | 94.97 | 0 | 42.9 | |
| 05/11/2024 00:00 | 48.93 | 0.08 | 94.88 | 0 | 43 | |
| Minimum | 0 | 0.08 | 93.37 | 0 | 24.1 | |
| MinDate | 04/11/2024 00:00 | 04/11/2024 00:00 | 04/11/2024 13:00 | 04/11/2024 13:00 | 04/11/2024 20:00 | |
| Maximum | 48.93 | 0.23 | 94.97 | 0 | 43 | |
| MaxDate | 05/11/2024 00:00 | 04/11/2024 14:00 | 04/11/2024 23:00 | 04/11/2024 13:00 | 05/11/2024 00:00 | |
| Avg | 17.58 | 0.09 | 94.2 | 0 | 29.4 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.7 | 0 | 0.5 | 0 | 7.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/11/2024 00:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 05:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 11:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 12:00 | 5.66 | 0.5 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 05/11/2024 13:00 | 32.49 | 0.1 | 94.93 | 0 | 36.4 | |
| 05/11/2024 14:00 | 34.63 | 0.06 | 95.76 | 0 | 29.1 | |
| 05/11/2024 15:00 | 34.58 | 0.03 | 95.08 | 0 | 28.6 | |
| 05/11/2024 16:00 | 34.44 | 0.01 | 95.01 | 0 | 28.2 | |
| 05/11/2024 17:00 | 34.31 | 0.02 | 95.03 | 0 | 28.1 | |
| 05/11/2024 18:00 | 34.23 | 0.03 | 95.03 | 0 | 27.9 | |
| 05/11/2024 19:00 | 34.17 | 0.01 | 94.82 | 0 | 27.8 | |
| 05/11/2024 20:00 | 34.15 | 0 | 94.72 | 0 | 27.8 | |
| 05/11/2024 21:00 | 34.32 | 0 | 95.03 | 0 | 27.8 | |
| 05/11/2024 22:00 | 31.52 | 0.02 | 94.72 | 0 | 34.6 | |
| 05/11/2024 23:00 | 46.97 | 0 | 96.72 | 0 | 40.2 | |
| 06/11/2024 00:00 | 48.51 | 0 | 96.11 | 0 | 40.7 | |
| Minimum | 0 | 0 | 94.72 | 0 | 27.8 | |
| MinDate | 05/11/2024 00:00 | 05/11/2024 01:00 | 05/11/2024 20:00 | 05/11/2024 13:00 | 05/11/2024 19:00 | |
| Maximum | 48.51 | 0.5 | 96.72 | 0 | 40.7 | |
| MaxDate | 06/11/2024 00:00 | 05/11/2024 12:00 | 05/11/2024 23:00 | 05/11/2024 13:00 | 06/11/2024 00:00 | |
| Avg | 17.6 | 0.04 | 95.25 | 0 | 31.4 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.6 | 0 | 5.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/11/2024 00:00 | 48.93 | 0.08 | 94.88 | 0 | 43 | |
| 05/11/2024 01:00 | 49.02 | 0.08 | 95.58 | 0 | 43.7 | |
| 05/11/2024 02:00 | 48.96 | 0.08 | 95.55 | 0 | 44.5 | |
| 05/11/2024 03:00 | 48.95 | 0.08 | 95.49 | 0 | 44.4 | |
| 05/11/2024 04:00 | 48.92 | 0.08 | 95.39 | 0 | 44.9 | |
| 05/11/2024 05:00 | 48.89 | 0.08 | 95.33 | 0 | 44.3 | |
| 05/11/2024 06:00 | 48.92 | 0.08 | 95.44 | 0 | 44.4 | |
| 05/11/2024 07:00 | 48.87 | 0.08 | 95.1 | 0 | 44 | |
| 05/11/2024 08:00 | 48.9 | 0.08 | 95.05 | 0 | 44 | |
| 05/11/2024 09:00 | 48.96 | 0.08 | 95.19 | 0 | 45.1 | |
| 05/11/2024 10:00 | 48.49 | 0.08 | 94.99 | 0 | 45.2 | |
| 05/11/2024 11:00 | 47.68 | 0.08 | 95.09 | 0 | 44.4 | |
| 05/11/2024 12:00 | 44.13 | 0.08 | 95.27 | 0 | 40.6 | |
| 05/11/2024 13:00 | 32.42 | 0.08 | 93.72 | 0 | 31 | |
| 05/11/2024 14:00 | 34.57 | 0.42 | 94.18 | 0 | 23.8 | |
| 05/11/2024 15:00 | 34.51 | 0.08 | 93.7 | 0 | 23.5 | |
| 05/11/2024 16:00 | 34.36 | 0.08 | 93.82 | 0 | 23.2 | |
| 05/11/2024 17:00 | 34.25 | 0.08 | 93.78 | 0 | 23.1 | |
| 05/11/2024 18:00 | 34.16 | 0.08 | 93.66 | 0 | 22.9 | |
| 05/11/2024 19:00 | 34.1 | 0.08 | 93.5 | 0 | 22.9 | |
| 05/11/2024 20:00 | 34.09 | 0.08 | 93.38 | 0 | 22.9 | |
| 05/11/2024 21:00 | 34.26 | 0.08 | 93.56 | 0 | 23 | |
| 05/11/2024 22:00 | 31.37 | 0.08 | 93.19 | 0 | 30.2 | |
| 05/11/2024 23:00 | 2.05 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 93.19 | 0 | 22.9 | |
| MinDate | 06/11/2024 00:00 | 05/11/2024 00:00 | 05/11/2024 22:00 | 05/11/2024 00:00 | 05/11/2024 18:00 | |
| Maximum | 49.02 | 0.42 | 95.58 | 0 | 45.2 | |
| MaxDate | 05/11/2024 01:00 | 05/11/2024 14:00 | 05/11/2024 01:00 | 05/11/2024 00:00 | 05/11/2024 10:00 | |
| Avg | 38.79 | 0.09 | 94.56 | 0 | 35.6 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.5 | 0.1 | 0.9 | 0 | 10.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/11/2024 00:00 | 48.51 | 0 | 96.11 | 0 | 40.7 | |
| 06/11/2024 01:00 | 48.57 | 0.01 | 96.84 | 0 | 40.5 | |
| 06/11/2024 02:00 | 48.84 | 0.07 | 97.04 | 0 | 40.2 | |
| 06/11/2024 03:00 | 48.95 | 0.07 | 97.02 | 0 | 39.9 | |
| 06/11/2024 04:00 | 48.9 | 0.02 | 96.87 | 0 | 40 | |
| 06/11/2024 05:00 | 48.95 | 0.21 | 96.52 | 0 | 40 | |
| 06/11/2024 06:00 | 48.96 | 0 | 96.47 | 0 | 40.2 | |
| 06/11/2024 07:00 | 48.85 | 0 | 96.44 | 0 | 40.3 | |
| 06/11/2024 08:00 | 48.7 | 0 | 96.43 | 0 | 39.8 | |
| 06/11/2024 09:00 | 48.46 | 0 | 96.32 | 0 | 39.9 | |
| 06/11/2024 10:00 | 48.02 | 0 | 96.55 | 0 | 39.7 | |
| 06/11/2024 11:00 | 47.61 | 0 | 96.66 | 0 | 39.4 | |
| 06/11/2024 12:00 | 44.9 | 0.02 | 97.51 | 0 | 37.4 | |
| 06/11/2024 13:00 | 32.46 | 0.08 | 95.36 | 0 | 35.3 | |
| 06/11/2024 14:00 | 34.6 | 0.02 | 96 | 0 | 27 | |
| 06/11/2024 15:00 | 34.61 | 0.04 | 95.66 | 0 | 27 | |
| 06/11/2024 16:00 | 34.5 | 0.01 | 95.44 | 0 | 27 | |
| 06/11/2024 17:00 | 34.32 | 0.01 | 95.34 | 0 | 26.7 | |
| 06/11/2024 18:00 | 34.33 | 0.02 | 95.33 | 0 | 26.4 | |
| 06/11/2024 19:00 | 34.14 | 0.01 | 95.23 | 0 | 26.3 | |
| 06/11/2024 20:00 | 34.29 | 0 | 95.36 | 0 | 26.3 | |
| 06/11/2024 21:00 | 34.43 | 0.1 | 95.78 | 0 | 26 | |
| 06/11/2024 22:00 | 31.46 | 0.05 | 95.09 | 0 | 32.6 | |
| 06/11/2024 23:00 | 2.07 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 95.09 | 0 | 26 | |
| MinDate | 07/11/2024 00:00 | 06/11/2024 00:00 | 06/11/2024 22:00 | 06/11/2024 00:00 | 06/11/2024 21:00 | |
| Maximum | 48.96 | 0.21 | 97.51 | 0 | 40.7 | |
| MaxDate | 06/11/2024 06:00 | 06/11/2024 05:00 | 06/11/2024 12:00 | 06/11/2024 00:00 | 06/11/2024 00:00 | |
| Avg | 38.78 | 0.03 | 96.15 | 0 | 34.7 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.4 | 0 | 0.7 | 0 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 12:00 | 5.09 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/11/2024 13:00 | 32.22 | 0.08 | 93.16 | 0 | 33.9 | |
| 06/11/2024 14:00 | 34.53 | 0.35 | 94.41 | 0 | 25.1 | |
| 06/11/2024 15:00 | 34.55 | 0.08 | 94.22 | 0 | 25.1 | |
| 06/11/2024 16:00 | 34.43 | 0.08 | 93.98 | 0 | 24.9 | |
| 06/11/2024 17:00 | 34.26 | 0.08 | 93.83 | 0 | 24.5 | |
| 06/11/2024 18:00 | 34.26 | 0.08 | 93.8 | 0 | 24.3 | |
| 06/11/2024 19:00 | 34.08 | 0.08 | 93.73 | 0 | 24.1 | |
| 06/11/2024 20:00 | 34.23 | 0.08 | 93.83 | 0 | 24.1 | |
| 06/11/2024 21:00 | 34.37 | 0.08 | 94.07 | 0 | 23.8 | |
| 06/11/2024 22:00 | 31.5 | 0.08 | 93.47 | 0 | 30.6 | |
| 06/11/2024 23:00 | 47.03 | 0.08 | 95.14 | 0 | 43 | |
| 07/11/2024 00:00 | 48.66 | 0.08 | 94.49 | 0 | 45.8 | |
| Minimum | 0 | 0.08 | 93.16 | 0 | 23.8 | |
| MinDate | 06/11/2024 00:00 | 06/11/2024 00:00 | 06/11/2024 13:00 | 06/11/2024 13:00 | 06/11/2024 21:00 | |
| Maximum | 48.66 | 0.35 | 95.14 | 0 | 45.8 | |
| MaxDate | 07/11/2024 00:00 | 06/11/2024 14:00 | 06/11/2024 23:00 | 06/11/2024 13:00 | 07/11/2024 00:00 | |
| Avg | 17.57 | 0.09 | 94.01 | 0 | 29.1 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.7 | 0.1 | 0.5 | 0 | 7.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 05:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 10:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 11:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 12:00 | 6.13 | 0.62 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 07/11/2024 13:00 | 32.53 | 0.23 | 94.64 | 0 | 36.6 | |
| 07/11/2024 14:00 | 34.72 | 0.13 | 96.01 | 0 | 29.3 | |
| 07/11/2024 15:00 | 34.6 | 0.16 | 95.65 | 0 | 29.1 | |
| 07/11/2024 16:00 | 34.15 | 0.16 | 95.2 | 0 | 28.9 | |
| 07/11/2024 17:00 | 33.62 | 0.09 | 94.63 | 0 | 28.3 | |
| 07/11/2024 18:00 | 33.53 | 0.05 | 94.61 | 0 | 28 | |
| 07/11/2024 19:00 | 33.47 | 0.06 | 94.43 | 0 | 27.9 | |
| 07/11/2024 20:00 | 34.03 | 0.02 | 94.54 | 0 | 27.9 | |
| 07/11/2024 21:00 | 34.41 | 0.01 | 95.12 | 0 | 28.1 | |
| 07/11/2024 22:00 | 31.63 | 0.04 | 94.83 | 0 | 34.6 | |
| 07/11/2024 23:00 | 46.63 | 0 | 96.42 | 0 | 40.3 | |
| 08/11/2024 00:00 | 48.18 | 0 | 95.93 | 0 | 41.1 | |
| Minimum | 0 | 0 | 94.43 | 0 | 27.9 | |
| MinDate | 07/11/2024 00:00 | 07/11/2024 00:00 | 07/11/2024 19:00 | 07/11/2024 13:00 | 07/11/2024 19:00 | |
| Maximum | 48.18 | 0.62 | 96.42 | 0 | 41.1 | |
| MaxDate | 08/11/2024 00:00 | 07/11/2024 12:00 | 07/11/2024 23:00 | 07/11/2024 13:00 | 08/11/2024 00:00 | |
| Avg | 17.51 | 0.07 | 95.17 | 0 | 31.7 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.5 | 0.1 | 0.7 | 0 | 5.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/11/2024 00:00 | 48.66 | 0.08 | 94.49 | 0 | 45.8 | |
| 07/11/2024 01:00 | 48.9 | 0.08 | 95.13 | 0 | 45.4 | |
| 07/11/2024 02:00 | 48.91 | 0.08 | 95.18 | 0 | 45.6 | |
| 07/11/2024 03:00 | 48.92 | 0.08 | 95.2 | 0 | 45.8 | |
| 07/11/2024 04:00 | 48.94 | 0.08 | 95.46 | 0 | 45 | |
| 07/11/2024 05:00 | 48.9 | 0.08 | 95.27 | 0 | 45.3 | |
| 07/11/2024 06:00 | 48.92 | 0.08 | 95.19 | 0 | 45.4 | |
| 07/11/2024 07:00 | 48.89 | 0.08 | 95.25 | 0 | 45.2 | |
| 07/11/2024 08:00 | 48.68 | 0.08 | 95.28 | 0 | 45.2 | |
| 07/11/2024 09:00 | 48.4 | 0.08 | 95.1 | 0 | 45.8 | |
| 07/11/2024 10:00 | 47.98 | 0.08 | 95.18 | 0 | 45.2 | |
| 07/11/2024 11:00 | 47.56 | 0.08 | 95.45 | 0 | 44.6 | |
| 07/11/2024 12:00 | 43.58 | 0.08 | 95.35 | 0 | 41.4 | |
| 07/11/2024 13:00 | 32.44 | 0.08 | 93.56 | 0 | 30.6 | |
| 07/11/2024 14:00 | 34.65 | 0.29 | 94.3 | 0 | 23.6 | |
| 07/11/2024 15:00 | 34.53 | 0.08 | 94.1 | 0 | 23.4 | |
| 07/11/2024 16:00 | 34.09 | 0.08 | 93.73 | 0 | 23.2 | |
| 07/11/2024 17:00 | 33.56 | 0.08 | 93.21 | 0 | 22.7 | |
| 07/11/2024 18:00 | 33.46 | 0.08 | 93.16 | 0 | 22.8 | |
| 07/11/2024 19:00 | 33.41 | 0.08 | 93.01 | 0 | 23.2 | |
| 07/11/2024 20:00 | 33.97 | 0.08 | 93.16 | 0 | 22.6 | |
| 07/11/2024 21:00 | 34.35 | 0.08 | 93.64 | 0 | 22.7 | |
| 07/11/2024 22:00 | 31.49 | 0.08 | 93.34 | 0 | 29.9 | |
| 07/11/2024 23:00 | 2.22 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 08/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 0 | 0.08 | 93.01 | 0 | 22.6 | |
| MinDate | 08/11/2024 00:00 | 07/11/2024 00:00 | 07/11/2024 19:00 | 07/11/2024 00:00 | 07/11/2024 20:00 | |
| Maximum | 48.94 | 0.29 | 95.46 | 0 | 45.8 | |
| MaxDate | 07/11/2024 04:00 | 07/11/2024 14:00 | 07/11/2024 04:00 | 07/11/2024 00:00 | 07/11/2024 00:00 | |
| Avg | 38.62 | 0.09 | 94.47 | 0 | 36.1 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.4 | 0 | 0.9 | 0 | 10.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/11/2024 00:00 | 48.18 | 0 | 95.93 | 0 | 41.1 | |
| 08/11/2024 01:00 | 48.32 | 0 | 96.42 | 0 | 40.6 | |
| 08/11/2024 02:00 | 48.6 | 0 | 96.47 | 0 | 40.1 | |
| 08/11/2024 03:00 | 48.74 | 0 | 96.5 | 0 | 40 | |
| 08/11/2024 04:00 | 48.68 | 0 | 96.44 | 0 | 40.4 | |
| 08/11/2024 05:00 | 48.7 | 0.34 | 96.33 | 0 | 40.7 | |
| 08/11/2024 06:00 | 48.87 | 0 | 96.4 | 0 | 40.7 | |
| 08/11/2024 07:00 | 48.85 | 0 | 96.32 | 0 | 40.6 | |
| 08/11/2024 08:00 | 48.37 | 0 | 96.22 | 0 | 40.3 | |
| 08/11/2024 09:00 | 47.97 | 0 | 96.19 | 0 | 40.2 | |
| 08/11/2024 10:00 | 47.66 | 0 | 96.41 | 0 | 40 | |
| 08/11/2024 11:00 | 47.28 | 0.02 | 96.77 | 0 | 39.8 | |
| 08/11/2024 12:00 | 42.73 | 0.09 | 97.38 | 0 | 39.9 | |
| 08/11/2024 13:00 | 32.54 | 0.2 | 95.7 | 0 | 35.5 | |
| 08/11/2024 14:00 | 34.72 | 0.15 | 96.35 | 0 | 27.3 | |
| 08/11/2024 15:00 | 34.69 | 0.11 | 95.89 | 0 | 27.1 | |
| 08/11/2024 16:00 | 34.62 | 0.08 | 95.66 | 0 | 27 | |
| 08/11/2024 17:00 | 34.37 | 0.07 | 95.42 | 0 | 26.6 | |
| 08/11/2024 18:00 | 34.35 | 0.02 | 95.46 | 0 | 26.4 | |
| 08/11/2024 19:00 | 34.22 | 0.01 | 95.19 | 0 | 26.3 | |
| 08/11/2024 20:00 | 34.31 | 0.02 | 95.09 | 0 | 26.2 | |
| 08/11/2024 21:00 | 34.53 | 0 | 95.51 | 0 | 26.2 | |
| 08/11/2024 22:00 | 34.25 | 0.02 | 96.6 | 0 | 32.3 | |
| 08/11/2024 23:00 | 25.96 | 0.05 | 92.87 | 0 | 49.7 | |
| 09/11/2024 00:00 | 28.87 | 0.01 | 93.22 | 0 | 45.3 | |
| Minimum | 25.96 | 0 | 92.87 | 0 | 26.2 | |
| MinDate | 08/11/2024 23:00 | 08/11/2024 00:00 | 08/11/2024 23:00 | 08/11/2024 00:00 | 08/11/2024 20:00 | |
| Maximum | 48.87 | 0.34 | 97.38 | 0 | 49.7 | |
| MaxDate | 08/11/2024 06:00 | 08/11/2024 05:00 | 08/11/2024 12:00 | 08/11/2024 00:00 | 08/11/2024 23:00 | |
| Avg | 40.82 | 0.05 | 95.87 | 0 | 36 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.9 | 0.1 | 1 | 0 | 7.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 12:00 | 7.39 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 08/11/2024 13:00 | 32.44 | 0.08 | 93.79 | 0 | 33.8 | |
| 08/11/2024 14:00 | 34.65 | 0.23 | 94.62 | 0 | 26 | |
| 08/11/2024 15:00 | 34.63 | 0.08 | 94.19 | 0 | 25.7 | |
| 08/11/2024 16:00 | 34.55 | 0.08 | 94 | 0 | 25.5 | |
| 08/11/2024 17:00 | 34.31 | 0.08 | 93.82 | 0 | 25.1 | |
| 08/11/2024 18:00 | 34.29 | 0.08 | 93.78 | 0 | 24.9 | |
| 08/11/2024 19:00 | 34.16 | 0.08 | 93.65 | 0 | 24.8 | |
| 08/11/2024 20:00 | 34.25 | 0.08 | 93.56 | 0 | 24.9 | |
| 08/11/2024 21:00 | 34.46 | 0.08 | 93.7 | 0 | 24.8 | |
| 08/11/2024 22:00 | 34.18 | 0.08 | 94.72 | 0 | 30.9 | |
| 08/11/2024 23:00 | 25.9 | 0.08 | 91.57 | 0 | 48.1 | |
| 09/11/2024 00:00 | 28.81 | 0.08 | 91.75 | 0 | 42.4 | |
| Minimum | 0 | 0.08 | 91.57 | 0 | 24.8 | |
| MinDate | 08/11/2024 00:00 | 08/11/2024 00:00 | 08/11/2024 23:00 | 08/11/2024 13:00 | 08/11/2024 19:00 | |
| Maximum | 34.65 | 0.23 | 94.72 | 0 | 48.1 | |
| MaxDate | 08/11/2024 14:00 | 08/11/2024 14:00 | 08/11/2024 22:00 | 08/11/2024 13:00 | 08/11/2024 23:00 | |
| Avg | 16.16 | 0.09 | 93.6 | 0 | 29.7 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.7 | 0 | 1 | 0 | 7.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/11/2024 00:00 | 28.87 | 0.01 | 93.22 | 0 | 45.3 | |
| 09/11/2024 01:00 | 28.98 | 0 | 93.11 | 0 | 45.2 | |
| 09/11/2024 02:00 | 29.08 | 0 | 92.92 | 0 | 44.8 | |
| 09/11/2024 03:00 | 28.91 | 0 | 92.83 | 0 | 45.5 | |
| 09/11/2024 04:00 | 28.74 | 0 | 92.75 | 0 | 46.3 | |
| 09/11/2024 05:00 | 28.64 | 0.28 | 92.8 | 0 | 47.5 | |
| 09/11/2024 06:00 | 28.68 | 0 | 92.88 | 0 | 47.6 | |
| 09/11/2024 07:00 | 28.58 | 0 | 92.95 | 0 | 47.4 | |
| 09/11/2024 08:00 | 28.69 | 0.01 | 93.22 | 0 | 47 | |
| 09/11/2024 09:00 | 28.91 | 0.04 | 93.38 | 0 | 45.2 | |
| 09/11/2024 10:00 | 28.9 | 0.12 | 93.52 | 0 | 44.6 | |
| 09/11/2024 11:00 | 28.94 | 0.13 | 93.56 | 0 | 43.7 | |
| 09/11/2024 12:00 | 28.84 | 0.14 | 93.63 | 0 | 43.4 | |
| 09/11/2024 13:00 | 39.37 | 0.03 | 98.17 | 0 | 34.9 | |
| 09/11/2024 14:00 | 42.9 | 0.02 | 102.18 | 0 | 30.4 | |
| 09/11/2024 15:00 | 42.9 | 0.01 | 101.86 | 0 | 30.4 | |
| 09/11/2024 16:00 | 42.85 | 0.02 | 101.58 | 0 | 30.2 | |
| 09/11/2024 17:00 | 42.82 | 0.04 | 101.38 | 0 | 30.1 | |
| 09/11/2024 18:00 | 42.78 | 0.02 | 101.24 | 0 | 29.9 | |
| 09/11/2024 19:00 | 42.62 | 0.04 | 101.16 | 0 | 29.7 | |
| 09/11/2024 20:00 | 42.58 | 0.02 | 100.92 | 0 | 29.7 | |
| 09/11/2024 21:00 | 42.74 | 0 | 101.34 | 0 | 29.6 | |
| 09/11/2024 22:00 | 39.18 | 0.01 | 100.39 | 0 | 33.2 | |
| 09/11/2024 23:00 | 28.75 | 0.02 | 93.78 | 0 | 45.3 | |
| 10/11/2024 00:00 | 28.65 | 0.02 | 93.06 | 0 | 46 | |
| Minimum | 28.58 | 0 | 92.75 | 0 | 29.6 | |
| MinDate | 09/11/2024 07:00 | 09/11/2024 01:00 | 09/11/2024 04:00 | 09/11/2024 00:00 | 09/11/2024 21:00 | |
| Maximum | 42.9 | 0.28 | 102.18 | 0 | 47.6 | |
| MaxDate | 09/11/2024 14:00 | 09/11/2024 05:00 | 09/11/2024 14:00 | 09/11/2024 00:00 | 09/11/2024 06:00 | |
| Avg | 34.12 | 0.04 | 96.31 | 0 | 39.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 4 | 0 | 7.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/11/2024 00:00 | 28.81 | 0.08 | 91.75 | 0 | 42.4 | |
| 09/11/2024 01:00 | 28.93 | 0.08 | 91.57 | 0 | 42.4 | |
| 09/11/2024 02:00 | 29.02 | 0.08 | 91.33 | 0 | 42.2 | |
| 09/11/2024 03:00 | 28.84 | 0.08 | 91.27 | 0 | 42.8 | |
| 09/11/2024 04:00 | 28.69 | 0.08 | 91.33 | 0 | 43.3 | |
| 09/11/2024 05:00 | 28.57 | 0.08 | 91.27 | 0 | 44.3 | |
| 09/11/2024 06:00 | 28.62 | 0.08 | 91.4 | 0 | 44.4 | |
| 09/11/2024 07:00 | 28.52 | 0.08 | 91.47 | 0 | 44.2 | |
| 09/11/2024 08:00 | 28.63 | 0.08 | 91.76 | 0 | 44 | |
| 09/11/2024 09:00 | 28.84 | 0.08 | 91.85 | 0 | 42.5 | |
| 09/11/2024 10:00 | 28.84 | 0.08 | 92 | 0 | 42 | |
| 09/11/2024 11:00 | 28.88 | 0.08 | 92.07 | 0 | 41.5 | |
| 09/11/2024 12:00 | 28.78 | 0.08 | 92.14 | 0 | 41.3 | |
| 09/11/2024 13:00 | 39.33 | 0.08 | 96.38 | 0 | 36.2 | |
| 09/11/2024 14:00 | 42.82 | 0.42 | 99.97 | 0 | 32.4 | |
| 09/11/2024 15:00 | 42.82 | 0.08 | 99.74 | 0 | 32.2 | |
| 09/11/2024 16:00 | 42.77 | 0.08 | 99.58 | 0 | 31.9 | |
| 09/11/2024 17:00 | 42.75 | 0.08 | 99.5 | 0 | 31.4 | |
| 09/11/2024 18:00 | 42.7 | 0.08 | 99.28 | 0 | 30.7 | |
| 09/11/2024 19:00 | 42.54 | 0.08 | 99.21 | 0 | 30.2 | |
| 09/11/2024 20:00 | 42.51 | 0.08 | 99.02 | 0 | 30 | |
| 09/11/2024 21:00 | 42.66 | 0.08 | 99.35 | 0 | 30.2 | |
| 09/11/2024 22:00 | 39.12 | 0.08 | 98.28 | 0 | 32.8 | |
| 09/11/2024 23:00 | 28.69 | 0.08 | 92.23 | 0 | 42.7 | |
| 10/11/2024 00:00 | 28.58 | 0.08 | 91.65 | 0 | 42.9 | |
| Minimum | 28.52 | 0.08 | 91.27 | 0 | 30 | |
| MinDate | 09/11/2024 07:00 | 09/11/2024 00:00 | 09/11/2024 03:00 | 09/11/2024 00:00 | 09/11/2024 20:00 | |
| Maximum | 42.82 | 0.42 | 99.97 | 0 | 44.4 | |
| MaxDate | 09/11/2024 14:00 | 09/11/2024 14:00 | 09/11/2024 14:00 | 09/11/2024 00:00 | 09/11/2024 06:00 | |
| Avg | 34.05 | 0.09 | 94.62 | 0 | 38.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.7 | 0 | 5.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/11/2024 00:00 | 28.65 | 0.02 | 93.06 | 0 | 46 | |
| 10/11/2024 01:00 | 28.73 | 0.01 | 93.1 | 0 | 46.2 | |
| 10/11/2024 02:00 | 28.77 | 0.02 | 92.96 | 0 | 46.5 | |
| 10/11/2024 03:00 | 28.72 | 0.02 | 92.93 | 0 | 47.4 | |
| 10/11/2024 04:00 | 28.47 | 0.01 | 92.72 | 0 | 49.2 | |
| 10/11/2024 05:00 | 28.37 | 0.24 | 92.66 | 0 | 49.7 | |
| 10/11/2024 06:00 | 28.23 | 0 | 92.69 | 0 | 50.8 | |
| 10/11/2024 07:00 | 28.05 | 0 | 93.02 | 0 | 50.6 | |
| 10/11/2024 08:00 | 28 | 0.14 | 93.2 | 0 | 50.3 | |
| 10/11/2024 09:00 | 28.21 | 0.08 | 92.78 | 0 | 48.2 | |
| 10/11/2024 10:00 | 28.25 | 0.12 | 93 | 0 | 46.2 | |
| 10/11/2024 11:00 | 28.2 | 0.18 | 93.34 | 0 | 45.4 | |
| 10/11/2024 12:00 | 28.02 | 0.24 | 93.58 | 0 | 44.9 | |
| 10/11/2024 13:00 | 28.1 | 0.3 | 93.81 | 0 | 43.7 | |
| 10/11/2024 14:00 | 28.15 | 0.24 | 93.76 | 0 | 43.4 | |
| 10/11/2024 15:00 | 28.24 | 0.08 | 93.2 | 0 | 43 | |
| 10/11/2024 16:00 | 28.29 | 0 | 92.93 | 0 | 42.8 | |
| 10/11/2024 17:00 | 31.79 | 0 | 93.67 | 0 | 40.3 | |
| 10/11/2024 18:00 | 42.19 | 0 | 100.16 | 0 | 28.1 | |
| 10/11/2024 19:00 | 42.1 | 0 | 100.63 | 0 | 28 | |
| 10/11/2024 20:00 | 42.11 | 0 | 100.77 | 0 | 27.8 | |
| 10/11/2024 21:00 | 20.24 | 0.1 | <Samp | <Samp | <Samp | |
| 10/11/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 10/11/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 92.66 | 0 | 27.8 | |
| MinDate | 10/11/2024 22:00 | 10/11/2024 06:00 | 10/11/2024 05:00 | 10/11/2024 00:00 | 10/11/2024 20:00 | |
| Maximum | 42.19 | 0.3 | 100.77 | 0 | 50.8 | |
| MaxDate | 10/11/2024 18:00 | 10/11/2024 13:00 | 10/11/2024 20:00 | 10/11/2024 00:00 | 10/11/2024 06:00 | |
| Avg | 26.4 | 0.07 | 94.19 | 0 | 43.7 | |
| Num | 25 | 25 | 21 | 21 | 21 | |
| Data[%] | 100 | 100 | 84 | 84 | 84 | |
| STD | 11.1 | 0.1 | 2.7 | 0 | 7.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | | |
| 10/11/2024 00:00 | 28.58 | 0.08 | 91.65 | 0 | 42.9 | |
| 10/11/2024 01:00 | 28.66 | 0.08 | 91.71 | 0 | 43.2 | |
| 10/11/2024 02:00 | 28.71 | 0.08 | 91.48 | 0 | 43.9 | |
| 10/11/2024 03:00 | 28.66 | 0.08 | 91.47 | 0 | 44.6 | |
| 10/11/2024 04:00 | 28.41 | 0.08 | 91.18 | 0 | 46.3 | |
| 10/11/2024 05:00 | 28.31 | 0.08 | 91.16 | 0 | 46.8 | |
| 10/11/2024 06:00 | 28.17 | 0.08 | 91.13 | 0 | 47.4 | |
| 10/11/2024 07:00 | 27.99 | 0.08 | 91.49 | 0 | 46.8 | |
| 10/11/2024 08:00 | 27.94 | 0.08 | 91.68 | 0 | 46.9 | |
| 10/11/2024 09:00 | 28.14 | 0.08 | 91.24 | 0 | 45.7 | |
| 10/11/2024 10:00 | 28.19 | 0.08 | 91.54 | 0 | 44 | |
| 10/11/2024 11:00 | 28.14 | 0.08 | 91.83 | 0 | 43.3 | |
| 10/11/2024 12:00 | 27.95 | 0.08 | 92.1 | 0 | 42.7 | |
| 10/11/2024 13:00 | 28.03 | 0.08 | 92.34 | 0 | 41.8 | |
| 10/11/2024 14:00 | 28.09 | 0.35 | 92.25 | 0 | 41.4 | |
| 10/11/2024 15:00 | 28.18 | 0.08 | 91.8 | 0 | 41.1 | |
| 10/11/2024 16:00 | 28.23 | 0.08 | 91.53 | 0 | 41.1 | |
| 10/11/2024 17:00 | 31.73 | 0.08 | 92.33 | 0 | 39.3 | |
| 10/11/2024 18:00 | 42.12 | 0.08 | 98.21 | 0 | 28.4 | |
| 10/11/2024 19:00 | 42.02 | 0.08 | 98.68 | 0 | 28.1 | |
| 10/11/2024 20:00 | 42.03 | 0.08 | 98.85 | 0 | 27.7 | |
| 10/11/2024 21:00 | 41.94 | 0.08 | 97.5 | 0 | 36.5 | |
| 10/11/2024 22:00 | 48.69 | 0.08 | 95.38 | 0 | 42.5 | |
| 10/11/2024 23:00 | 48.65 | 0.08 | 95.16 | 0 | 42.8 | |
| 11/11/2024 00:00 | 48.48 | 0.08 | 95.18 | 0 | 43.3 | |
| Minimum | 27.94 | 0.08 | 91.13 | 0 | 27.7 | |
| MinDate | 10/11/2024 08:00 | 10/11/2024 00:00 | 10/11/2024 06:00 | 10/11/2024 00:00 | 10/11/2024 20:00 | |
| Maximum | 48.69 | 0.35 | 98.85 | 0 | 47.4 | |
| MaxDate | 10/11/2024 22:00 | 10/11/2024 14:00 | 10/11/2024 20:00 | 10/11/2024 00:00 | 10/11/2024 06:00 | |
| Avg | 33.04 | 0.09 | 93.15 | 0 | 41.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.8 | 0.1 | 2.6 | 0 | 5.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 05:00 | 0 | 0.4 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 09:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 10:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 11:00 | 0 | 0.14 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 12:00 | 5.21 | 0.74 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 11/11/2024 13:00 | 32.52 | 0.37 | 95.36 | 0 | 38.8 | |
| 11/11/2024 14:00 | 34.68 | 0.3 | 96.17 | 0 | 31.1 | |
| 11/11/2024 15:00 | 34.84 | 0.19 | 95.88 | 0 | 31.1 | |
| 11/11/2024 16:00 | 34.61 | 0.14 | 95.58 | 0 | 30.8 | |
| 11/11/2024 17:00 | 34.43 | 0.15 | 95.28 | 0 | 30.4 | |
| 11/11/2024 18:00 | 34.31 | 0.11 | 95.03 | 0 | 30.1 | |
| 11/11/2024 19:00 | 34.22 | 0.14 | 95.03 | 0 | 29.6 | |
| 11/11/2024 20:00 | 34.16 | 0.14 | 94.93 | 0 | 29.3 | |
| 11/11/2024 21:00 | 34.42 | 0.1 | 95.26 | 0 | 29.2 | |
| 11/11/2024 22:00 | 31.69 | 0.19 | 94.96 | 0 | 35.1 | |
| 11/11/2024 23:00 | 2.35 | 0.14 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 00:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.93 | 0 | 29.2 | |
| MinDate | 11/11/2024 00:00 | 11/11/2024 00:00 | 11/11/2024 20:00 | 11/11/2024 13:00 | 11/11/2024 21:00 | |
| Maximum | 34.84 | 0.74 | 96.17 | 0 | 38.8 | |
| MaxDate | 11/11/2024 15:00 | 11/11/2024 12:00 | 11/11/2024 14:00 | 11/11/2024 13:00 | 11/11/2024 13:00 | |
| Avg | 13.9 | 0.14 | 95.35 | 0 | 31.6 | |
| Num | 25 | 25 | 10 | 10 | 10 | |
| Data[%] | 100 | 100 | 40 | 40 | 40 | |
| STD | 16.8 | 0.2 | 0.4 | 0 | 3.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/11/2024 00:00 | 48.48 | 0.08 | 95.18 | 0 | 43.3 | |
| 11/11/2024 01:00 | 48.46 | 0.08 | 95.3 | 0 | 43.4 | |
| 11/11/2024 02:00 | 48.61 | 0.08 | 95.28 | 0 | 43.3 | |
| 11/11/2024 03:00 | 48.63 | 0.08 | 95.19 | 0 | 43.2 | |
| 11/11/2024 04:00 | 48.59 | 0.08 | 95.18 | 0 | 43 | |
| 11/11/2024 05:00 | 48.75 | 0.08 | 95.22 | 0 | 42.9 | |
| 11/11/2024 06:00 | 48.81 | 0.08 | 95.25 | 0 | 43.1 | |
| 11/11/2024 07:00 | 48.68 | 0.08 | 95.34 | 0 | 42.6 | |
| 11/11/2024 08:00 | 48.3 | 0.08 | 95.02 | 0 | 42 | |
| 11/11/2024 09:00 | 47.78 | 0.08 | 94.95 | 0 | 41.3 | |
| 11/11/2024 10:00 | 47.26 | 0.08 | 94.93 | 0 | 40.9 | |
| 11/11/2024 11:00 | 46.89 | 0.08 | 94.87 | 0 | 40.4 | |
| 11/11/2024 12:00 | 44.33 | 0.08 | 95.53 | 0 | 38.7 | |
| 11/11/2024 13:00 | 32.47 | 0.08 | 94 | 0 | 29.1 | |
| 11/11/2024 14:00 | 34.62 | 0.27 | 94.78 | 0 | 21.6 | |
| 11/11/2024 15:00 | 34.51 | 0.08 | 94.52 | 0 | 21.5 | |
| 11/11/2024 16:00 | 34.54 | 0.08 | 94.35 | 0 | 21.5 | |
| 11/11/2024 17:00 | 34.37 | 0.08 | 94.17 | 0 | 21.2 | |
| 11/11/2024 18:00 | 34.25 | 0.08 | 93.96 | 0 | 20.9 | |
| 11/11/2024 19:00 | 34.16 | 0.08 | 94.05 | 0 | 20.7 | |
| 11/11/2024 20:00 | 34.09 | 0.08 | 94.03 | 0 | 20.6 | |
| 11/11/2024 21:00 | 34.35 | 0.08 | 94.26 | 0 | 20.5 | |
| 11/11/2024 22:00 | 31.67 | 0.08 | 93.88 | 0 | 27.4 | |
| 11/11/2024 23:00 | 46.65 | 0.08 | 95.66 | 0 | 37.7 | |
| 12/11/2024 00:00 | 48.6 | 0.08 | 95.18 | 0 | 39.5 | |
| Minimum | 31.67 | 0.08 | 93.88 | 0 | 20.5 | |
| MinDate | 11/11/2024 22:00 | 11/11/2024 00:00 | 11/11/2024 22:00 | 11/11/2024 00:00 | 11/11/2024 21:00 | |
| Maximum | 48.81 | 0.27 | 95.66 | 0 | 43.4 | |
| MaxDate | 11/11/2024 06:00 | 11/11/2024 14:00 | 11/11/2024 23:00 | 11/11/2024 00:00 | 11/11/2024 01:00 | |
| Avg | 42.31 | 0.09 | 94.8 | 0 | 34 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.1 | 0 | 0.6 | 0 | 9.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/11/2024 00:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 01:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 02:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 03:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 04:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 05:00 | 0 | 0.38 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 09:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 10:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 11:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 12:00 | 6.4 | 0.43 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/11/2024 13:00 | 32.54 | 0.1 | 94.95 | 0 | 38.1 | |
| 12/11/2024 14:00 | 34.67 | 0.09 | 96.08 | 0 | 30.7 | |
| 12/11/2024 15:00 | 34.84 | 0.08 | 95.88 | 0 | 30.4 | |
| 12/11/2024 16:00 | 34.66 | 0.08 | 95.65 | 0 | 30.2 | |
| 12/11/2024 17:00 | 34.54 | 0.09 | 95.31 | 0 | 30 | |
| 12/11/2024 18:00 | 34.44 | 0.05 | 95.09 | 0 | 29.6 | |
| 12/11/2024 19:00 | 34.27 | 0.01 | 95.07 | 0 | 29.2 | |
| 12/11/2024 20:00 | 34.25 | 0.01 | 94.93 | 0 | 28.9 | |
| 12/11/2024 21:00 | 34.4 | 0 | 95.29 | 0 | 28.7 | |
| 12/11/2024 22:00 | 31.62 | 0.02 | 94.85 | 0 | 34.9 | |
| 12/11/2024 23:00 | 47.2 | 0 | 96.56 | 0 | 40.6 | |
| 13/11/2024 00:00 | 48.23 | 0 | 96.26 | 0 | 41.3 | |
| Minimum | 0 | 0 | 94.85 | 0 | 28.7 | |
| MinDate | 12/11/2024 00:00 | 12/11/2024 06:00 | 12/11/2024 22:00 | 12/11/2024 13:00 | 12/11/2024 21:00 | |
| Maximum | 48.23 | 0.43 | 96.56 | 0 | 41.3 | |
| MaxDate | 13/11/2024 00:00 | 12/11/2024 12:00 | 12/11/2024 23:00 | 12/11/2024 13:00 | 13/11/2024 00:00 | |
| Avg | 17.68 | 0.07 | 95.49 | 0 | 32.7 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.7 | 0.1 | 0.6 | 0 | 4.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/11/2024 00:00 | 48.6 | 0.08 | 95.18 | 0 | 39.5 | |
| 12/11/2024 01:00 | 48.59 | 0.08 | 95.64 | 0 | 39.4 | |
| 12/11/2024 02:00 | 48.67 | 0.08 | 95.58 | 0 | 39.3 | |
| 12/11/2024 03:00 | 48.58 | 0.08 | 95.3 | 0 | 39.4 | |
| 12/11/2024 04:00 | 48.57 | 0.08 | 95.34 | 0 | 39.4 | |
| 12/11/2024 05:00 | 48.67 | 0.08 | 95.39 | 0 | 39.3 | |
| 12/11/2024 06:00 | 48.73 | 0.08 | 95.47 | 0 | 39.6 | |
| 12/11/2024 07:00 | 48.45 | 0.08 | 95.32 | 0 | 39.2 | |
| 12/11/2024 08:00 | 48.04 | 0.08 | 95.21 | 0 | 38.6 | |
| 12/11/2024 09:00 | 47.58 | 0.08 | 95.03 | 0 | 38.4 | |
| 12/11/2024 10:00 | 47.19 | 0.08 | 94.98 | 0 | 38.1 | |
| 12/11/2024 11:00 | 47.05 | 0.08 | 94.86 | 0 | 37.9 | |
| 12/11/2024 12:00 | 43.17 | 0.08 | 94.89 | 0 | 36.3 | |
| 12/11/2024 13:00 | 32.46 | 0.08 | 93.94 | 0 | 27.6 | |
| 12/11/2024 14:00 | 34.6 | 0.46 | 94.51 | 0 | 20.4 | |
| 12/11/2024 15:00 | 34.44 | 0.08 | 94.31 | 0 | 20.1 | |
| 12/11/2024 16:00 | 34.59 | 0.08 | 94.31 | 0 | 20 | |
| 12/11/2024 17:00 | 34.47 | 0.08 | 94.07 | 0 | 19.8 | |
| 12/11/2024 18:00 | 34.37 | 0.08 | 93.92 | 0 | 19.7 | |
| 12/11/2024 19:00 | 34.2 | 0.08 | 93.79 | 0 | 19.3 | |
| 12/11/2024 20:00 | 34.18 | 0.08 | 93.56 | 0 | 19 | |
| 12/11/2024 21:00 | 34.33 | 0.08 | 93.78 | 0 | 19.1 | |
| 12/11/2024 22:00 | 31.39 | 0.08 | 93.37 | 0 | 26.2 | |
| 12/11/2024 23:00 | 1.59 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 13/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 93.37 | 0 | 19 | |
| MinDate | 13/11/2024 00:00 | 12/11/2024 00:00 | 12/11/2024 22:00 | 12/11/2024 00:00 | 12/11/2024 20:00 | |
| Maximum | 48.73 | 0.46 | 95.64 | 0 | 39.6 | |
| MaxDate | 12/11/2024 06:00 | 12/11/2024 14:00 | 12/11/2024 01:00 | 12/11/2024 00:00 | 12/11/2024 06:00 | |
| Avg | 38.5 | 0.1 | 94.68 | 0 | 31.1 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.3 | 0.1 | 0.7 | 0 | 9.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/11/2024 00:00 | 48.23 | 0 | 96.26 | 0 | 41.3 | |
| 13/11/2024 01:00 | 48.21 | 0.01 | 96.68 | 0 | 41.1 | |
| 13/11/2024 02:00 | 48.44 | 0.1 | 96.86 | 0 | 40.5 | |
| 13/11/2024 03:00 | 48.51 | 0.16 | 96.91 | 0 | 40.3 | |
| 13/11/2024 04:00 | 48.69 | 0.15 | 96.92 | 0 | 40.1 | |
| 13/11/2024 05:00 | 48.7 | 0.4 | 96.9 | 0 | 40.4 | |
| 13/11/2024 06:00 | 48.92 | 0 | 97 | 0 | 40.6 | |
| 13/11/2024 07:00 | 48.38 | 0 | 97.18 | 0 | 40.2 | |
| 13/11/2024 08:00 | 47.63 | 0 | 96.92 | 0 | 40.2 | |
| 13/11/2024 09:00 | 47.02 | 0 | 96.35 | 0 | 40.2 | |
| 13/11/2024 10:00 | 46.64 | 0 | 96.24 | 0 | 40 | |
| 13/11/2024 11:00 | 46.3 | 0 | 96.48 | 0 | 39.7 | |
| 13/11/2024 12:00 | 45.2 | 0 | 97.08 | 0 | 39.3 | |
| 13/11/2024 13:00 | 31.29 | 0 | 95.52 | 0 | 38.3 | |
| 13/11/2024 14:00 | 34.64 | 0 | 96.58 | 0 | 28.1 | |
| 13/11/2024 15:00 | 34.67 | 0 | 96.29 | 0 | 27.9 | |
| 13/11/2024 16:00 | 34.24 | 0 | 96 | 0 | 27.7 | |
| 13/11/2024 17:00 | 33.61 | 0 | 95.31 | 0 | 27.2 | |
| 13/11/2024 18:00 | 33.42 | 0 | 95.09 | 0 | 26.6 | |
| 13/11/2024 19:00 | 33.43 | 0 | 95.08 | 0 | 25.9 | |
| 13/11/2024 20:00 | 34.07 | 0 | 95.47 | 0 | 25.7 | |
| 13/11/2024 21:00 | 34.35 | 0.01 | 96.13 | 0 | 25.7 | |
| 13/11/2024 22:00 | 31.61 | 0.01 | 95.81 | 0 | 31 | |
| 13/11/2024 23:00 | 46.53 | 0 | 97.07 | 0 | 36.6 | |
| 14/11/2024 00:00 | 47.92 | 0 | 96.37 | 0 | 37.3 | |
| Minimum | 31.29 | 0 | 95.08 | 0 | 25.7 | |
| MinDate | 13/11/2024 13:00 | 13/11/2024 00:00 | 13/11/2024 19:00 | 13/11/2024 00:00 | 13/11/2024 20:00 | |
| Maximum | 48.92 | 0.4 | 97.18 | 0 | 41.3 | |
| MaxDate | 13/11/2024 06:00 | 13/11/2024 05:00 | 13/11/2024 07:00 | 13/11/2024 00:00 | 13/11/2024 00:00 | |
| Avg | 42.03 | 0.03 | 96.34 | 0 | 35.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.2 | 0.1 | 0.6 | 0 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 12:00 | 3.12 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/11/2024 13:00 | 31.01 | 0.08 | 92.99 | 0 | 37.5 | |
| 13/11/2024 14:00 | 34.58 | 0.4 | 94.58 | 0 | 26.3 | |
| 13/11/2024 15:00 | 34.6 | 0.08 | 94.44 | 0 | 26.1 | |
| 13/11/2024 16:00 | 34.17 | 0.08 | 94.29 | 0 | 25.6 | |
| 13/11/2024 17:00 | 33.54 | 0.08 | 93.71 | 0 | 25.2 | |
| 13/11/2024 18:00 | 33.36 | 0.08 | 93.69 | 0 | 24.7 | |
| 13/11/2024 19:00 | 33.37 | 0.08 | 93.76 | 0 | 23.8 | |
| 13/11/2024 20:00 | 34 | 0.08 | 94.14 | 0 | 23.8 | |
| 13/11/2024 21:00 | 34.28 | 0.08 | 94.55 | 0 | 23.7 | |
| 13/11/2024 22:00 | 31.46 | 0.08 | 94.26 | 0 | 29.2 | |
| 13/11/2024 23:00 | 1.82 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 14/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| Minimum | 0 | 0.08 | 92.99 | 0 | 23.7 | |
| MinDate | 13/11/2024 00:00 | 13/11/2024 00:00 | 13/11/2024 13:00 | 13/11/2024 13:00 | 13/11/2024 21:00 | |
| Maximum | 34.6 | 0.4 | 94.58 | 0 | 37.5 | |
| MaxDate | 13/11/2024 15:00 | 13/11/2024 14:00 | 13/11/2024 14:00 | 13/11/2024 13:00 | 13/11/2024 13:00 | |
| Avg | 13.57 | 0.09 | 94.04 | 0 | 26.6 | |
| Num | 25 | 25 | 10 | 10 | 10 | |
| Data[%] | 100 | 100 | 40 | 40 | 40 | |
| STD | 16.6 | 0.1 | 0.5 | 0 | 4.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/11/2024 00:00 | 47.92 | 0 | 96.37 | 0 | 37.3 | |
| 14/11/2024 01:00 | 48 | 0 | 96.87 | 0 | 37.2 | |
| 14/11/2024 02:00 | 48.09 | 0 | 96.83 | 0 | 37.3 | |
| 14/11/2024 03:00 | 48.04 | 0 | 96.88 | 0 | 37.3 | |
| 14/11/2024 04:00 | 48.09 | 0 | 96.92 | 0 | 37.1 | |
| 14/11/2024 05:00 | 48.15 | 0.21 | 96.92 | 0 | 37.1 | |
| 14/11/2024 06:00 | 48.43 | 0 | 97.03 | 0 | 36.8 | |
| 14/11/2024 07:00 | 48.3 | 0 | 97.1 | 0 | 36.8 | |
| 14/11/2024 08:00 | 47.81 | 0 | 97.08 | 0 | 36.7 | |
| 14/11/2024 09:00 | 47.45 | 0 | 96.46 | 0 | 36.6 | |
| 14/11/2024 10:00 | 47.33 | 0 | 96.69 | 0 | 36.3 | |
| 14/11/2024 11:00 | 47.23 | 0 | 96.94 | 0 | 36.3 | |
| 14/11/2024 12:00 | 43.65 | 0.01 | 97.7 | 0 | 36.1 | |
| 14/11/2024 13:00 | 32.63 | 0.01 | 96.14 | 0 | 32.6 | |
| 14/11/2024 14:00 | 34.53 | 0.01 | 96.97 | 0 | 25.4 | |
| 14/11/2024 15:00 | 34.76 | 0.11 | 95.73 | 0 | 24.9 | |
| 14/11/2024 16:00 | 34.6 | 0.01 | 93.72 | 0 | 24.4 | |
| 14/11/2024 17:00 | 34.42 | 0.03 | 94.86 | 0 | 24.2 | |
| 14/11/2024 18:00 | 34.39 | 0 | 95.33 | 0 | 24 | |
| 14/11/2024 19:00 | 34.27 | 0 | 95.42 | 0 | 23.9 | |
| 14/11/2024 20:00 | 34.32 | 0 | 95.41 | 0 | 23.7 | |
| 14/11/2024 21:00 | 34.51 | 0 | 95.8 | 0 | 23.7 | |
| 14/11/2024 22:00 | 31.52 | 0 | 95.21 | 0 | 30 | |
| 14/11/2024 23:00 | 2.05 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 93.72 | 0 | 23.7 | |
| MinDate | 15/11/2024 00:00 | 14/11/2024 00:00 | 14/11/2024 16:00 | 14/11/2024 00:00 | 14/11/2024 20:00 | |
| Maximum | 48.43 | 0.21 | 97.7 | 0 | 37.3 | |
| MaxDate | 14/11/2024 06:00 | 14/11/2024 05:00 | 14/11/2024 12:00 | 14/11/2024 00:00 | 14/11/2024 00:00 | |
| Avg | 38.42 | 0.02 | 96.28 | 0 | 32 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.1 | 0 | 0.9 | 0 | 6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 12:00 | 6.49 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 14/11/2024 13:00 | 32.53 | 0.08 | 94.49 | 0 | 32.2 | |
| 14/11/2024 14:00 | 34.46 | 0.33 | 95.27 | 0 | 25.6 | |
| 14/11/2024 15:00 | 34.7 | 0.08 | 94.07 | 0 | 24.8 | |
| 14/11/2024 16:00 | 34.53 | 0.08 | 92.26 | 0 | 24.2 | |
| 14/11/2024 17:00 | 34.36 | 0.08 | 93.4 | 0 | 24 | |
| 14/11/2024 18:00 | 34.34 | 0.08 | 93.81 | 0 | 23.8 | |
| 14/11/2024 19:00 | 34.2 | 0.08 | 93.9 | 0 | 23.5 | |
| 14/11/2024 20:00 | 34.25 | 0.08 | 93.94 | 0 | 23.3 | |
| 14/11/2024 21:00 | 34.44 | 0.08 | 94.12 | 0 | 23.4 | |
| 14/11/2024 22:00 | 31.57 | 0.08 | 93.54 | 0 | 29.4 | |
| 14/11/2024 23:00 | 47.28 | 0.08 | 95.64 | 0 | 40.9 | |
| 15/11/2024 00:00 | 48.77 | 0.08 | 95.16 | 0 | 43.2 | |
| Minimum | 0 | 0.08 | 92.26 | 0 | 23.3 | |
| MinDate | 14/11/2024 00:00 | 14/11/2024 00:00 | 14/11/2024 16:00 | 14/11/2024 13:00 | 14/11/2024 20:00 | |
| Maximum | 48.77 | 0.33 | 95.64 | 0 | 43.2 | |
| MaxDate | 15/11/2024 00:00 | 14/11/2024 14:00 | 14/11/2024 23:00 | 14/11/2024 13:00 | 15/11/2024 00:00 | |
| Avg | 17.68 | 0.09 | 94.13 | 0 | 28.2 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.7 | 0.1 | 0.9 | 0 | 7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 05:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 09:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 10:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 11:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 12:00 | 6.24 | 0.66 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/11/2024 13:00 | 32.63 | 0.23 | 93.1 | 0 | 34 | |
| 15/11/2024 14:00 | 34.61 | 0.18 | 95.11 | 0 | 27.9 | |
| 15/11/2024 15:00 | 34.62 | 0.08 | 95.36 | 0 | 27.6 | |
| 15/11/2024 16:00 | 34.57 | 0.13 | 95.49 | 0 | 27.5 | |
| 15/11/2024 17:00 | 34.44 | 0.23 | 95.65 | 0 | 27.4 | |
| 15/11/2024 18:00 | 34.38 | 0.17 | 95.67 | 0 | 27.3 | |
| 15/11/2024 19:00 | 34.25 | 0.18 | 95.62 | 0 | 27 | |
| 15/11/2024 20:00 | 34.19 | 0.09 | 95.49 | 0 | 27 | |
| 15/11/2024 21:00 | 34.44 | 0.12 | 95.91 | 0 | 27 | |
| 15/11/2024 22:00 | 34.07 | 0.15 | 96.9 | 0 | 33.6 | |
| 15/11/2024 23:00 | 25.26 | 0.25 | 93.2 | 0 | 48.3 | |
| 16/11/2024 00:00 | 28.7 | 0.21 | 93.51 | 0 | 45 | |
| Minimum | 0 | 0 | 93.1 | 0 | 27 | |
| MinDate | 15/11/2024 00:00 | 15/11/2024 00:00 | 15/11/2024 13:00 | 15/11/2024 13:00 | 15/11/2024 19:00 | |
| Maximum | 34.62 | 0.66 | 96.9 | 0 | 48.3 | |
| MaxDate | 15/11/2024 15:00 | 15/11/2024 12:00 | 15/11/2024 22:00 | 15/11/2024 13:00 | 15/11/2024 23:00 | |
| Avg | 16.1 | 0.12 | 95.08 | 0 | 31.6 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.8 | 0.1 | 1.2 | 0 | 7.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/11/2024 00:00 | 48.77 | 0.08 | 95.16 | 0 | 43.2 | |
| 15/11/2024 01:00 | 48.85 | 0.08 | 95.46 | 0 | 43.2 | |
| 15/11/2024 02:00 | 48.83 | 0.08 | 95.51 | 0 | 43.3 | |
| 15/11/2024 03:00 | 48.83 | 0.08 | 95.5 | 0 | 43.1 | |
| 15/11/2024 04:00 | 48.89 | 0.08 | 95.47 | 0 | 42.9 | |
| 15/11/2024 05:00 | 48.89 | 0.08 | 95.43 | 0 | 42.9 | |
| 15/11/2024 06:00 | 48.87 | 0.08 | 95.32 | 0 | 42.9 | |
| 15/11/2024 07:00 | 48.73 | 0.08 | 95.41 | 0 | 42.8 | |
| 15/11/2024 08:00 | 48.58 | 0.08 | 95.55 | 0 | 42.5 | |
| 15/11/2024 09:00 | 48.2 | 0.08 | 95.53 | 0 | 42.2 | |
| 15/11/2024 10:00 | 47.75 | 0.08 | 95.74 | 0 | 42.3 | |
| 15/11/2024 11:00 | 47.78 | 0.08 | 95.56 | 0 | 42.2 | |
| 15/11/2024 12:00 | 43.79 | 0.08 | 95.31 | 0 | 38.8 | |
| 15/11/2024 13:00 | 32.49 | 0.08 | 91.59 | 0 | 29 | |
| 15/11/2024 14:00 | 34.54 | 0.27 | 93.44 | 0 | 22.9 | |
| 15/11/2024 15:00 | 34.54 | 0.08 | 93.87 | 0 | 22.7 | |
| 15/11/2024 16:00 | 34.5 | 0.08 | 94.09 | 0 | 22.5 | |
| 15/11/2024 17:00 | 34.38 | 0.08 | 94.23 | 0 | 22.4 | |
| 15/11/2024 18:00 | 34.31 | 0.08 | 94.28 | 0 | 22.1 | |
| 15/11/2024 19:00 | 34.18 | 0.08 | 94.24 | 0 | 22 | |
| 15/11/2024 20:00 | 34.12 | 0.08 | 94.14 | 0 | 22 | |
| 15/11/2024 21:00 | 34.37 | 0.08 | 94.42 | 0 | 22.1 | |
| 15/11/2024 22:00 | 34.03 | 0.08 | 95.24 | 0 | 28.8 | |
| 15/11/2024 23:00 | 25.2 | 0.08 | 92.38 | 0 | 44.8 | |
| 16/11/2024 00:00 | 28.64 | 0.08 | 93.01 | 0 | 38.3 | |
| Minimum | 25.2 | 0.08 | 91.59 | 0 | 22 | |
| MinDate | 15/11/2024 23:00 | 15/11/2024 00:00 | 15/11/2024 13:00 | 15/11/2024 00:00 | 15/11/2024 19:00 | |
| Maximum | 48.89 | 0.27 | 95.74 | 0 | 44.8 | |
| MaxDate | 15/11/2024 04:00 | 15/11/2024 14:00 | 15/11/2024 10:00 | 15/11/2024 00:00 | 15/11/2024 23:00 | |
| Avg | 40.88 | 0.09 | 94.64 | 0 | 34.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8.1 | 0 | 1.1 | 0 | 9.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/11/2024 00:00 | 28.7 | 0.21 | 93.51 | 0 | 45 | |
| 16/11/2024 01:00 | 29.08 | 0.18 | 93.68 | 0 | 44 | |
| 16/11/2024 02:00 | 29.11 | 0.17 | 93.62 | 0 | 44.1 | |
| 16/11/2024 03:00 | 29.03 | 0.12 | 93.56 | 0 | 44.4 | |
| 16/11/2024 04:00 | 28.92 | 0.11 | 93.38 | 0 | 44.8 | |
| 16/11/2024 05:00 | 28.92 | 0.44 | 93.39 | 0 | 45 | |
| 16/11/2024 06:00 | 28.93 | 0.01 | 93.31 | 0 | 45.1 | |
| 16/11/2024 07:00 | 28.88 | 0.05 | 93.64 | 0 | 44.8 | |
| 16/11/2024 08:00 | 28.98 | 0.14 | 94.09 | 0 | 43.7 | |
| 16/11/2024 09:00 | 29.14 | 0.3 | 94.3 | 0 | 43 | |
| 16/11/2024 10:00 | 29.28 | 0.3 | 94.44 | 0 | 42.6 | |
| 16/11/2024 11:00 | 29.23 | 0.31 | 94.54 | 0 | 42.5 | |
| 16/11/2024 12:00 | 29.18 | 0.31 | 94.54 | 0 | 41.9 | |
| 16/11/2024 13:00 | 39.67 | 0.29 | 99.14 | 0 | 34.8 | |
| 16/11/2024 14:00 | 43.13 | 0.18 | 102.92 | 0 | 31.4 | |
| 16/11/2024 15:00 | 43.18 | 0.09 | 102.43 | 0 | 30.9 | |
| 16/11/2024 16:00 | 43.03 | 0.01 | 101.92 | 0 | 30.5 | |
| 16/11/2024 17:00 | 42.88 | 0 | 101.75 | 0 | 30.7 | |
| 16/11/2024 18:00 | 42.84 | 0 | 101.43 | 0 | 30.6 | |
| 16/11/2024 19:00 | 42.58 | 0 | 101.2 | 0 | 30.3 | |
| 16/11/2024 20:00 | 42.79 | 0 | 101.29 | 0 | 30.3 | |
| 16/11/2024 21:00 | 42.91 | 0 | 101.84 | 0 | 30.2 | |
| 16/11/2024 22:00 | 39.37 | 0.03 | 100.96 | 0 | 32.9 | |
| 16/11/2024 23:00 | 28.92 | 0.07 | 94.47 | 0 | 42.6 | |
| 17/11/2024 00:00 | 28.86 | 0.02 | 93.84 | 0 | 42.7 | |
| Minimum | 28.7 | 0 | 93.31 | 0 | 30.2 | |
| MinDate | 16/11/2024 00:00 | 16/11/2024 17:00 | 16/11/2024 06:00 | 16/11/2024 00:00 | 16/11/2024 21:00 | |
| Maximum | 43.18 | 0.44 | 102.92 | 0 | 45.1 | |
| MaxDate | 16/11/2024 15:00 | 16/11/2024 05:00 | 16/11/2024 14:00 | 16/11/2024 00:00 | 16/11/2024 06:00 | |
| Avg | 34.3 | 0.13 | 96.93 | 0 | 38.8 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.9 | 0 | 6.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/11/2024 00:00 | 28.64 | 0.08 | 93.01 | 0 | 38.3 | |
| 16/11/2024 01:00 | 29.02 | 0.08 | 93.18 | 0 | 37.6 | |
| 16/11/2024 02:00 | 29.04 | 0.08 | 93.1 | 0 | 37.9 | |
| 16/11/2024 03:00 | 28.97 | 0.08 | 93.11 | 0 | 37.9 | |
| 16/11/2024 04:00 | 28.86 | 0.08 | 92.94 | 0 | 38.4 | |
| 16/11/2024 05:00 | 28.86 | 0.08 | 92.95 | 0 | 38.5 | |
| 16/11/2024 06:00 | 28.87 | 0.08 | 92.9 | 0 | 38.5 | |
| 16/11/2024 07:00 | 28.82 | 0.08 | 93.25 | 0 | 38.2 | |
| 16/11/2024 08:00 | 28.92 | 0.08 | 93.71 | 0 | 37.3 | |
| 16/11/2024 09:00 | 29.07 | 0.08 | 93.92 | 0 | 36.6 | |
| 16/11/2024 10:00 | 29.22 | 0.08 | 93.96 | 0 | 36.5 | |
| 16/11/2024 11:00 | 29.16 | 0.08 | 94.05 | 0 | 36.3 | |
| 16/11/2024 12:00 | 29.11 | 0.08 | 94.05 | 0 | 35.7 | |
| 16/11/2024 13:00 | 39.59 | 0.08 | 98.2 | 0 | 31.4 | |
| 16/11/2024 14:00 | 43.06 | 0.45 | 101.17 | 0 | 28.6 | |
| 16/11/2024 15:00 | 43.11 | 0.08 | 100.78 | 0 | 28.2 | |
| 16/11/2024 16:00 | 42.95 | 0.08 | 100.37 | 0 | 27.3 | |
| 16/11/2024 17:00 | 42.8 | 0.08 | 100.18 | 0 | 27.1 | |
| 16/11/2024 18:00 | 42.76 | 0.08 | 99.88 | 0 | 26.9 | |
| 16/11/2024 19:00 | 42.5 | 0.08 | 99.71 | 0 | 26.2 | |
| 16/11/2024 20:00 | 42.71 | 0.08 | 99.83 | 0 | 26.6 | |
| 16/11/2024 21:00 | 42.83 | 0.08 | 100.15 | 0 | 26.6 | |
| 16/11/2024 22:00 | 39.3 | 0.08 | 99.22 | 0 | 28.9 | |
| 16/11/2024 23:00 | 28.86 | 0.08 | 93.33 | 0 | 36.4 | |
| 17/11/2024 00:00 | 28.8 | 0.08 | 92.7 | 0 | 36.1 | |
| Minimum | 28.64 | 0.08 | 92.7 | 0 | 26.2 | |
| MinDate | 16/11/2024 00:00 | 16/11/2024 00:00 | 17/11/2024 00:00 | 16/11/2024 00:00 | 16/11/2024 19:00 | |
| Maximum | 43.11 | 0.45 | 101.17 | 0 | 38.5 | |
| MaxDate | 16/11/2024 15:00 | 16/11/2024 14:00 | 16/11/2024 14:00 | 16/11/2024 00:00 | 16/11/2024 05:00 | |
| Avg | 34.23 | 0.09 | 95.99 | 0 | 33.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.4 | 0 | 4.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/11/2024 00:00 | 28.86 | 0.02 | 93.84 | 0 | 42.7 | |
| 17/11/2024 01:00 | 28.87 | 0.06 | 93.77 | 0 | 42.7 | |
| 17/11/2024 02:00 | 28.84 | 0.03 | 93.76 | 0 | 42.5 | |
| 17/11/2024 03:00 | 28.51 | 0.01 | 93.6 | 0 | 43.4 | |
| 17/11/2024 04:00 | 28.07 | 0.01 | 93.44 | 0 | 44.6 | |
| 17/11/2024 05:00 | 27.83 | 0.32 | 93.4 | 0 | 45.8 | |
| 17/11/2024 06:00 | 27.67 | 0.01 | 93.34 | 0 | 46.1 | |
| 17/11/2024 07:00 | 27.45 | 0.01 | 93.56 | 0 | 46 | |
| 17/11/2024 08:00 | 27.32 | 0.15 | 93.97 | 0 | 45.6 | |
| 17/11/2024 09:00 | 27.33 | 0.28 | 94.23 | 0 | 45.5 | |
| 17/11/2024 10:00 | 27.28 | 0.37 | 94.31 | 0 | 45.3 | |
| 17/11/2024 11:00 | 27.26 | 0.26 | 94.28 | 0 | 45 | |
| 17/11/2024 12:00 | 27.32 | 0.2 | 94.07 | 0 | 44.8 | |
| 17/11/2024 13:00 | 27.38 | 0.09 | 93.9 | 0 | 43.7 | |
| 17/11/2024 14:00 | 27.37 | 0.12 | 93.36 | 0 | 43.8 | |
| 17/11/2024 15:00 | 27.29 | 0.46 | 91.27 | 0 | 47.3 | |
| 17/11/2024 16:00 | 27.24 | 0.02 | 91.91 | 0 | 47.6 | |
| 17/11/2024 17:00 | 30.61 | 0 | 92.64 | 0 | 44 | |
| 17/11/2024 18:00 | 41.06 | 0 | 98.87 | 0 | 28.1 | |
| 17/11/2024 19:00 | 41.05 | 0 | 99.58 | 0 | 28 | |
| 17/11/2024 20:00 | 41.16 | 0 | 99.77 | 0 | 27.9 | |
| 17/11/2024 21:00 | 41.64 | 0.01 | 98.74 | 0 | 34.1 | |
| 17/11/2024 22:00 | 48.93 | 0 | 96.76 | 0 | 35.8 | |
| 17/11/2024 23:00 | 48.9 | 0 | 96.86 | 0 | 35.7 | |
| 18/11/2024 00:00 | 48.88 | 0 | 96.89 | 0 | 35.5 | |
| Minimum | 27.24 | 0 | 91.27 | 0 | 27.9 | |
| MinDate | 17/11/2024 16:00 | 17/11/2024 17:00 | 17/11/2024 15:00 | 17/11/2024 00:00 | 17/11/2024 20:00 | |
| Maximum | 48.93 | 0.46 | 99.77 | 0 | 47.6 | |
| MaxDate | 17/11/2024 22:00 | 17/11/2024 15:00 | 17/11/2024 20:00 | 17/11/2024 00:00 | 17/11/2024 16:00 | |
| Avg | 32.56 | 0.1 | 94.8 | 0 | 41.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.9 | 0.1 | 2.4 | 0 | 6.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/11/2024 00:00 | 28.8 | 0.08 | 92.7 | 0 | 36.1 | |
| 17/11/2024 01:00 | 28.8 | 0.08 | 92.67 | 0 | 36.3 | |
| 17/11/2024 02:00 | 28.78 | 0.08 | 92.68 | 0 | 36.3 | |
| 17/11/2024 03:00 | 28.44 | 0.08 | 92.49 | 0 | 36.9 | |
| 17/11/2024 04:00 | 28 | 0.08 | 92.36 | 0 | 37.9 | |
| 17/11/2024 05:00 | 27.77 | 0.08 | 92.28 | 0 | 38.6 | |
| 17/11/2024 06:00 | 27.61 | 0.08 | 92.24 | 0 | 39 | |
| 17/11/2024 07:00 | 27.39 | 0.08 | 92.48 | 0 | 38.7 | |
| 17/11/2024 08:00 | 27.25 | 0.08 | 92.81 | 0 | 38.6 | |
| 17/11/2024 09:00 | 27.26 | 0.08 | 93.07 | 0 | 38.5 | |
| 17/11/2024 10:00 | 27.22 | 0.08 | 93.15 | 0 | 38.5 | |
| 17/11/2024 11:00 | 27.2 | 0.08 | 93.04 | 0 | 38.3 | |
| 17/11/2024 12:00 | 27.25 | 0.08 | 92.81 | 0 | 38.2 | |
| 17/11/2024 13:00 | 27.32 | 0.08 | 92.7 | 0 | 37.2 | |
| 17/11/2024 14:00 | 27.32 | 0.4 | 91.19 | 0 | 37.3 | |
| 17/11/2024 15:00 | 27.22 | 0.08 | 89.8 | 0 | 40.1 | |
| 17/11/2024 16:00 | 27.18 | 0.08 | 90.84 | 0 | 40.3 | |
| 17/11/2024 17:00 | 30.56 | 0.08 | 91.61 | 0 | 37.7 | |
| 17/11/2024 18:00 | 40.98 | 0.08 | 97.32 | 0 | 23.2 | |
| 17/11/2024 19:00 | 40.97 | 0.08 | 98.04 | 0 | 23.1 | |
| 17/11/2024 20:00 | 41.08 | 0.08 | 98.22 | 0 | 23 | |
| 17/11/2024 21:00 | 18.7 | 0.08 | <Samp | <Samp | <Samp | GT12 S/D |
| 17/11/2024 22:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/11/2024 23:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 89.8 | 0 | 23 | |
| MinDate | 17/11/2024 22:00 | 17/11/2024 00:00 | 17/11/2024 15:00 | 17/11/2024 00:00 | 17/11/2024 20:00 | |
| Maximum | 41.08 | 0.4 | 98.22 | 0 | 40.3 | |
| MaxDate | 17/11/2024 20:00 | 17/11/2024 14:00 | 17/11/2024 20:00 | 17/11/2024 00:00 | 17/11/2024 16:00 | |
| Avg | 25.72 | 0.09 | 93.07 | 0 | 35.9 | |
| Num | 25 | 25 | 21 | 21 | 21 | |
| Data[%] | 100 | 100 | 84 | 84 | 84 | |
| STD | 10.9 | 0.1 | 2.2 | 0 | 5.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/11/2024 00:00 | 48.88 | 0 | 96.89 | 0 | 35.5 | |
| 18/11/2024 01:00 | 48.63 | 0 | 96.63 | 0 | 35.5 | |
| 18/11/2024 02:00 | 48.53 | 0 | 96.68 | 0 | 35.3 | |
| 18/11/2024 03:00 | 48.55 | 0 | 96.63 | 0 | 35.4 | |
| 18/11/2024 04:00 | 48.53 | 0 | 96.6 | 0 | 35.6 | |
| 18/11/2024 05:00 | 48.64 | 0.21 | 96.45 | 0 | 35.8 | |
| 18/11/2024 06:00 | 48.79 | 0 | 96.67 | 0 | 36.1 | |
| 18/11/2024 07:00 | 48.67 | 0 | 96.68 | 0 | 36.3 | |
| 18/11/2024 08:00 | 48.39 | 0 | 96.61 | 0 | 36.8 | |
| 18/11/2024 09:00 | 48.08 | 0 | 96.43 | 0 | 37 | |
| 18/11/2024 10:00 | 47.81 | 0 | 96.65 | 0 | 36.6 | |
| 18/11/2024 11:00 | 47.45 | 0 | 96.81 | 0 | 35.8 | |
| 18/11/2024 12:00 | 43.09 | 0.04 | 97.06 | 0 | 35.6 | |
| 18/11/2024 13:00 | 32.52 | 0.14 | 95.31 | 0 | 31.5 | |
| 18/11/2024 14:00 | 34.65 | 0.06 | 96.02 | 0 | 24.4 | |
| 18/11/2024 15:00 | 34.6 | 0.09 | 95.59 | 0 | 24.5 | |
| 18/11/2024 16:00 | 34.52 | 0.06 | 95.43 | 0 | 24.4 | |
| 18/11/2024 17:00 | 34.32 | 0.08 | 95.21 | 0 | 24.2 | |
| 18/11/2024 18:00 | 34.32 | 0.05 | 95.05 | 0 | 24.1 | |
| 18/11/2024 19:00 | 34.1 | 0.02 | 94.84 | 0 | 24 | |
| 18/11/2024 20:00 | 34.15 | 0.02 | 94.87 | 0 | 24 | |
| 18/11/2024 21:00 | 34.23 | 0.05 | 95.25 | 0 | 24 | |
| 18/11/2024 22:00 | 31.53 | 0.07 | 94.81 | 0 | 30.4 | |
| 18/11/2024 23:00 | 2.37 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 00:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.81 | 0 | 24 | |
| MinDate | 19/11/2024 00:00 | 18/11/2024 00:00 | 18/11/2024 22:00 | 18/11/2024 00:00 | 18/11/2024 19:00 | |
| Maximum | 48.88 | 0.21 | 97.06 | 0 | 37 | |
| MaxDate | 18/11/2024 00:00 | 18/11/2024 05:00 | 18/11/2024 12:00 | 18/11/2024 00:00 | 18/11/2024 09:00 | |
| Avg | 38.61 | 0.04 | 96.05 | 0 | 31.4 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.2 | 0.1 | 0.8 | 0 | 5.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 12:00 | 6.92 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 18/11/2024 13:00 | 32.45 | 0.08 | 93.38 | 0 | 33.2 | |
| 18/11/2024 14:00 | 34.58 | 0.31 | 94.22 | 0 | 26.4 | |
| 18/11/2024 15:00 | 34.53 | 0.08 | 93.91 | 0 | 26.4 | |
| 18/11/2024 16:00 | 34.45 | 0.08 | 93.78 | 0 | 26.2 | |
| 18/11/2024 17:00 | 34.26 | 0.08 | 93.51 | 0 | 25.9 | |
| 18/11/2024 18:00 | 34.26 | 0.08 | 93.42 | 0 | 25.6 | |
| 18/11/2024 19:00 | 34.03 | 0.08 | 93.25 | 0 | 25.5 | |
| 18/11/2024 20:00 | 34.08 | 0.08 | 93.26 | 0 | 25.5 | |
| 18/11/2024 21:00 | 34.16 | 0.08 | 93.48 | 0 | 25.6 | |
| 18/11/2024 22:00 | 31.5 | 0.08 | 93.1 | 0 | 32 | |
| 18/11/2024 23:00 | 46.61 | 0.08 | 95.2 | 0 | 45.5 | |
| 19/11/2024 00:00 | 48.7 | 0.08 | 94.96 | 0 | 47.2 | |
| Minimum | 0 | 0.08 | 93.1 | 0 | 25.5 | |
| MinDate | 18/11/2024 00:00 | 18/11/2024 00:00 | 18/11/2024 22:00 | 18/11/2024 13:00 | 18/11/2024 19:00 | |
| Maximum | 48.7 | 0.31 | 95.2 | 0 | 47.2 | |
| MaxDate | 19/11/2024 00:00 | 18/11/2024 14:00 | 18/11/2024 23:00 | 18/11/2024 13:00 | 19/11/2024 00:00 | |
| Avg | 17.62 | 0.09 | 93.79 | 0 | 30.4 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0 | 0.7 | 0 | 7.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/11/2024 00:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 05:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 09:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 10:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 11:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 12:00 | 6.33 | 0.63 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 19/11/2024 13:00 | 32.62 | 0.25 | 95.24 | 0 | 37.5 | |
| 19/11/2024 14:00 | 34.72 | 0.24 | 96.29 | 0 | 30.3 | |
| 19/11/2024 15:00 | 34.69 | 0.21 | 95.81 | 0 | 30.1 | |
| 19/11/2024 16:00 | 34.66 | 0.23 | 95.55 | 0 | 30 | |
| 19/11/2024 17:00 | 34.52 | 0.21 | 95.42 | 0 | 29.6 | |
| 19/11/2024 18:00 | 34.51 | 0.18 | 95.42 | 0 | 29.1 | |
| 19/11/2024 19:00 | 34.33 | 0.17 | 95.25 | 0 | 28.7 | |
| 19/11/2024 20:00 | 34.26 | 0.12 | 94.96 | 0 | 28.7 | |
| 19/11/2024 21:00 | 34.46 | 0.13 | 95.24 | 0 | 28.8 | |
| 19/11/2024 22:00 | 31.73 | 0.14 | 94.97 | 0 | 34.6 | |
| 19/11/2024 23:00 | 46.59 | 0.04 | 96.46 | 0 | 41.1 | |
| 20/11/2024 00:00 | 48.12 | 0.1 | 96.25 | 0 | 41.4 | |
| Minimum | 0 | 0 | 94.96 | 0 | 28.7 | |
| MinDate | 19/11/2024 00:00 | 19/11/2024 01:00 | 19/11/2024 20:00 | 19/11/2024 13:00 | 19/11/2024 19:00 | |
| Maximum | 48.12 | 0.63 | 96.46 | 0 | 41.4 | |
| MaxDate | 20/11/2024 00:00 | 19/11/2024 12:00 | 19/11/2024 23:00 | 19/11/2024 13:00 | 20/11/2024 00:00 | |
| Avg | 17.66 | 0.12 | 95.57 | 0 | 32.5 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.5 | 0 | 4.9 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/11/2024 00:00 | 48.7 | 0.08 | 94.96 | 0 | 47.2 | |
| 19/11/2024 01:00 | 48.7 | 0.08 | 95.46 | 0 | 47.7 | |
| 19/11/2024 02:00 | 48.68 | 0.08 | 95.42 | 0 | 47.8 | |
| 19/11/2024 03:00 | 48.81 | 0.08 | 95.2 | 0 | 47.5 | |
| 19/11/2024 04:00 | 48.79 | 0.08 | 95.06 | 0 | 47.3 | |
| 19/11/2024 05:00 | 48.82 | 0.08 | 94.92 | 0 | 47.3 | |
| 19/11/2024 06:00 | 48.84 | 0.08 | 94.98 | 0 | 47.1 | |
| 19/11/2024 07:00 | 48.67 | 0.08 | 95.04 | 0 | 47.1 | |
| 19/11/2024 08:00 | 48.43 | 0.08 | 94.95 | 0 | 46.7 | |
| 19/11/2024 09:00 | 48.07 | 0.08 | 94.94 | 0 | 45.9 | |
| 19/11/2024 10:00 | 47.71 | 0.08 | 95.02 | 0 | 45.3 | |
| 19/11/2024 11:00 | 47.31 | 0.08 | 94.93 | 0 | 44.9 | |
| 19/11/2024 12:00 | 43.39 | 0.08 | 95.06 | 0 | 42.6 | |
| 19/11/2024 13:00 | 32.54 | 0.08 | 93.82 | 0 | 31.6 | |
| 19/11/2024 14:00 | 34.66 | 0.25 | 94.47 | 0 | 24.6 | |
| 19/11/2024 15:00 | 34.62 | 0.08 | 94.16 | 0 | 24.4 | |
| 19/11/2024 16:00 | 34.59 | 0.08 | 94.08 | 0 | 24.4 | |
| 19/11/2024 17:00 | 34.45 | 0.08 | 93.96 | 0 | 23.9 | |
| 19/11/2024 18:00 | 34.44 | 0.08 | 93.96 | 0 | 23.5 | |
| 19/11/2024 19:00 | 34.26 | 0.08 | 93.75 | 0 | 23.1 | |
| 19/11/2024 20:00 | 34.2 | 0.08 | 93.54 | 0 | 23.3 | |
| 19/11/2024 21:00 | 34.39 | 0.08 | 93.83 | 0 | 23.4 | |
| 19/11/2024 22:00 | 31.62 | 0.08 | 93.43 | 0 | 29.9 | |
| 19/11/2024 23:00 | 1.99 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 93.43 | 0 | 23.1 | |
| MinDate | 20/11/2024 00:00 | 19/11/2024 00:00 | 19/11/2024 22:00 | 19/11/2024 00:00 | 19/11/2024 19:00 | |
| Maximum | 48.84 | 0.25 | 95.46 | 0 | 47.8 | |
| MaxDate | 19/11/2024 06:00 | 19/11/2024 14:00 | 19/11/2024 01:00 | 19/11/2024 00:00 | 19/11/2024 02:00 | |
| Avg | 38.67 | 0.09 | 94.56 | 0 | 37.2 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.3 | 0 | 0.6 | 0 | 11 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/11/2024 00:00 | 48.12 | 0.1 | 96.25 | 0 | 41.4 | |
| 20/11/2024 01:00 | 48.6 | 0.08 | 96.78 | 0 | 40.9 | |
| 20/11/2024 02:00 | 48.39 | 0 | 96.51 | 0 | 40.8 | |
| 20/11/2024 03:00 | 48.54 | 0 | 96.42 | 0 | 40.8 | |
| 20/11/2024 04:00 | 48.66 | 0 | 96.45 | 0 | 40.9 | |
| 20/11/2024 05:00 | 48.7 | 0.34 | 96.43 | 0 | 41.1 | |
| 20/11/2024 06:00 | 48.84 | 0 | 96.41 | 0 | 41.1 | |
| 20/11/2024 07:00 | 48.8 | 0 | 96.46 | 0 | 41.1 | |
| 20/11/2024 08:00 | 48.64 | 0 | 96.37 | 0 | 41 | |
| 20/11/2024 09:00 | 48.3 | 0 | 96.33 | 0 | 40.6 | |
| 20/11/2024 10:00 | 48.02 | 0 | 96.4 | 0 | 40.3 | |
| 20/11/2024 11:00 | 47.73 | 0 | 96.67 | 0 | 39.8 | |
| 20/11/2024 12:00 | 44.58 | 0.01 | 97.44 | 0 | 38.5 | |
| 20/11/2024 13:00 | 32.48 | 0.12 | 95.29 | 0 | 36 | |
| 20/11/2024 14:00 | 34.64 | 0.17 | 95.79 | 0 | 27.7 | |
| 20/11/2024 15:00 | 34.65 | 0.13 | 95.57 | 0 | 27.5 | |
| 20/11/2024 16:00 | 34.65 | 0.15 | 95.51 | 0 | 27.5 | |
| 20/11/2024 17:00 | 34.44 | 0.12 | 95.25 | 0 | 27.1 | |
| 20/11/2024 18:00 | 34.43 | 0.11 | 95.31 | 0 | 26.9 | |
| 20/11/2024 19:00 | 34.22 | 0.09 | 95 | 0 | 26.6 | |
| 20/11/2024 20:00 | 34.2 | 0.09 | 95.01 | 0 | 26.5 | |
| 20/11/2024 21:00 | 34.33 | 0.05 | 95.24 | 0 | 26.5 | |
| 20/11/2024 22:00 | 31.43 | 0.09 | 94.83 | 0 | 33.2 | |
| 20/11/2024 23:00 | 2.04 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 00:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.83 | 0 | 26.5 | |
| MinDate | 21/11/2024 00:00 | 20/11/2024 02:00 | 20/11/2024 22:00 | 20/11/2024 00:00 | 20/11/2024 20:00 | |
| Maximum | 48.84 | 0.34 | 97.44 | 0 | 41.4 | |
| MaxDate | 20/11/2024 06:00 | 20/11/2024 05:00 | 20/11/2024 12:00 | 20/11/2024 00:00 | 20/11/2024 00:00 | |
| Avg | 38.7 | 0.07 | 95.99 | 0 | 35.4 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.3 | 0.1 | 0.7 | 0 | 6.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 12:00 | 5.28 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 20/11/2024 13:00 | 32.39 | 0.08 | 93.48 | 0 | 33.7 | |
| 20/11/2024 14:00 | 34.58 | 0.44 | 94.41 | 0 | 25.5 | |
| 20/11/2024 15:00 | 34.53 | 0.08 | 94.18 | 0 | 25.2 | |
| 20/11/2024 16:00 | 34.47 | 0.08 | 94.02 | 0 | 25 | |
| 20/11/2024 17:00 | 34.37 | 0.08 | 93.82 | 0 | 24.7 | |
| 20/11/2024 18:00 | 34.37 | 0.08 | 93.93 | 0 | 24.5 | |
| 20/11/2024 19:00 | 34.17 | 0.08 | 93.71 | 0 | 24.2 | |
| 20/11/2024 20:00 | 34.13 | 0.08 | 93.73 | 0 | 24.1 | |
| 20/11/2024 21:00 | 34.26 | 0.08 | 93.82 | 0 | 24.1 | |
| 20/11/2024 22:00 | 31.49 | 0.08 | 93.36 | 0 | 31 | |
| 20/11/2024 23:00 | 46.84 | 0.08 | 95.4 | 0 | 43.4 | |
| 21/11/2024 00:00 | 48.39 | 0.08 | 94.76 | 0 | 45.8 | |
| Minimum | 0 | 0.08 | 93.36 | 0 | 24.1 | |
| MinDate | 20/11/2024 00:00 | 20/11/2024 00:00 | 20/11/2024 22:00 | 20/11/2024 13:00 | 20/11/2024 20:00 | |
| Maximum | 48.39 | 0.44 | 95.4 | 0 | 45.8 | |
| MaxDate | 21/11/2024 00:00 | 20/11/2024 14:00 | 20/11/2024 23:00 | 20/11/2024 13:00 | 21/11/2024 00:00 | |
| Avg | 17.57 | 0.09 | 94.05 | 0 | 29.3 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.6 | 0 | 7.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/11/2024 00:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 01:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 05:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 10:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 11:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 12:00 | 5.82 | 0.56 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/11/2024 13:00 | 32.54 | 0.23 | 94.9 | 0 | 37.2 | |
| 21/11/2024 14:00 | 34.66 | 0.26 | 96.04 | 0 | 29.4 | |
| 21/11/2024 15:00 | 34.63 | 0.29 | 96.01 | 0 | 29.4 | |
| 21/11/2024 16:00 | 34.51 | 0.29 | 95.4 | 0 | 29.2 | |
| 21/11/2024 17:00 | 34.38 | 0.29 | 95.19 | 0 | 28.9 | |
| 21/11/2024 18:00 | 34.45 | 0.26 | 95.29 | 0 | 28.6 | |
| 21/11/2024 19:00 | 34.29 | 0.21 | 95.08 | 0 | 28.4 | |
| 21/11/2024 20:00 | 34.21 | 0.13 | 94.93 | 0 | 28.2 | |
| 21/11/2024 21:00 | 34.37 | 0.12 | 95.29 | 0 | 28.3 | |
| 21/11/2024 22:00 | 31.53 | 0.23 | 94.89 | 0 | 34.9 | |
| 21/11/2024 23:00 | 46.93 | 0.19 | 96.48 | 0 | 40.5 | |
| 22/11/2024 00:00 | 48.07 | 0.11 | 95.91 | 0 | 41.1 | |
| Minimum | 0 | 0 | 94.89 | 0 | 28.2 | |
| MinDate | 21/11/2024 00:00 | 21/11/2024 02:00 | 21/11/2024 22:00 | 21/11/2024 13:00 | 21/11/2024 20:00 | |
| Maximum | 48.07 | 0.56 | 96.48 | 0 | 41.1 | |
| MaxDate | 22/11/2024 00:00 | 21/11/2024 12:00 | 21/11/2024 23:00 | 21/11/2024 13:00 | 22/11/2024 00:00 | |
| Avg | 17.62 | 0.14 | 95.45 | 0 | 32 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.5 | 0 | 5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/11/2024 00:00 | 48.39 | 0.08 | 94.76 | 0 | 45.8 | |
| 21/11/2024 01:00 | 48.47 | 0.08 | 94.81 | 0 | 45.7 | |
| 21/11/2024 02:00 | 48.66 | 0.08 | 95 | 0 | 46 | |
| 21/11/2024 03:00 | 48.77 | 0.08 | 94.96 | 0 | 46.4 | |
| 21/11/2024 04:00 | 48.88 | 0.08 | 94.89 | 0 | 47.1 | |
| 21/11/2024 05:00 | 48.87 | 0.08 | 95.04 | 0 | 46.8 | |
| 21/11/2024 06:00 | 48.92 | 0.08 | 95.2 | 0 | 46.4 | |
| 21/11/2024 07:00 | 48.89 | 0.08 | 95.22 | 0 | 46.4 | |
| 21/11/2024 08:00 | 48.79 | 0.08 | 95.12 | 0 | 46.5 | |
| 21/11/2024 09:00 | 48.59 | 0.08 | 94.97 | 0 | 46.5 | |
| 21/11/2024 10:00 | 48.38 | 0.08 | 94.86 | 0 | 45.9 | |
| 21/11/2024 11:00 | 48.02 | 0.08 | 94.8 | 0 | 45.5 | |
| 21/11/2024 12:00 | 44.08 | 0.08 | 95.06 | 0 | 41.5 | |
| 21/11/2024 13:00 | 32.5 | 0.08 | 93.32 | 0 | 31.1 | |
| 21/11/2024 14:00 | 34.59 | 0.38 | 94.27 | 0 | 23.5 | |
| 21/11/2024 15:00 | 34.56 | 0.08 | 94.33 | 0 | 23.3 | |
| 21/11/2024 16:00 | 34.45 | 0.08 | 94.08 | 0 | 23.2 | |
| 21/11/2024 17:00 | 34.31 | 0.08 | 93.95 | 0 | 22.9 | |
| 21/11/2024 18:00 | 34.38 | 0.08 | 94 | 0 | 22.8 | |
| 21/11/2024 19:00 | 34.22 | 0.08 | 93.76 | 0 | 22.6 | |
| 21/11/2024 20:00 | 34.14 | 0.08 | 93.47 | 0 | 22.4 | |
| 21/11/2024 21:00 | 34.3 | 0.08 | 93.72 | 0 | 22.6 | |
| 21/11/2024 22:00 | 31.37 | 0.08 | 93.34 | 0 | 29.8 | |
| 21/11/2024 23:00 | 1.69 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 93.32 | 0 | 22.4 | |
| MinDate | 22/11/2024 00:00 | 21/11/2024 00:00 | 21/11/2024 13:00 | 21/11/2024 00:00 | 21/11/2024 20:00 | |
| Maximum | 48.92 | 0.38 | 95.22 | 0 | 47.1 | |
| MaxDate | 21/11/2024 06:00 | 21/11/2024 14:00 | 21/11/2024 07:00 | 21/11/2024 00:00 | 21/11/2024 04:00 | |
| Avg | 38.73 | 0.09 | 94.48 | 0 | 36.6 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.4 | 0.1 | 0.6 | 0 | 11.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/11/2024 00:00 | 48.07 | 0.11 | 95.91 | 0 | 41.1 | |
| 22/11/2024 01:00 | 48.23 | 0.01 | 96.4 | 0 | 41 | |
| 22/11/2024 02:00 | 48.36 | 0.01 | 96.46 | 0 | 41.1 | |
| 22/11/2024 03:00 | 48.5 | 0.01 | 96.46 | 0 | 41.1 | |
| 22/11/2024 04:00 | 48.58 | 0 | 96.39 | 0 | 41.2 | |
| 22/11/2024 05:00 | 48.72 | 0.21 | 96.49 | 0 | 41.2 | |
| 22/11/2024 06:00 | 48.78 | 0 | 96.55 | 0 | 41.3 | |
| 22/11/2024 07:00 | 48.61 | 0 | 96.51 | 0 | 41.3 | |
| 22/11/2024 08:00 | 48.38 | 0 | 96.48 | 0 | 41 | |
| 22/11/2024 09:00 | 47.97 | 0 | 96.33 | 0 | 40.6 | |
| 22/11/2024 10:00 | 47.49 | 0 | 96.45 | 0 | 40.2 | |
| 22/11/2024 11:00 | 47.14 | 0 | 96.71 | 0 | 39.7 | |
| 22/11/2024 12:00 | 43.89 | 0.03 | 96.81 | 0 | 39.2 | |
| 22/11/2024 13:00 | 32.35 | 0.1 | 94.91 | 0 | 36.4 | |
| 22/11/2024 14:00 | 34.72 | 0.09 | 95.92 | 0 | 27.3 | |
| 22/11/2024 15:00 | 34.65 | 0.11 | 95.7 | 0 | 27.2 | |
| 22/11/2024 16:00 | 34.41 | 0.09 | 95.29 | 0 | 26.9 | |
| 22/11/2024 17:00 | 34.11 | 0.08 | 95.1 | 0 | 26.5 | |
| 22/11/2024 18:00 | 34.13 | 0.07 | 95.07 | 0 | 26.4 | |
| 22/11/2024 19:00 | 33.92 | 0.06 | 94.86 | 0 | 26.3 | |
| 22/11/2024 20:00 | 34.23 | 0.03 | 95.04 | 0 | 26.2 | |
| 22/11/2024 21:00 | 34.41 | 0.03 | 95.37 | 0 | 26.2 | |
| 22/11/2024 22:00 | 34.2 | 0.05 | 96.43 | 0 | 33.4 | |
| 22/11/2024 23:00 | 24.75 | 0.11 | 92.6 | 0 | 51.6 | |
| 23/11/2024 00:00 | 28.54 | 0.05 | 92.68 | 0 | 47.1 | |
| Minimum | 24.75 | 0 | 92.6 | 0 | 26.2 | |
| MinDate | 22/11/2024 23:00 | 22/11/2024 04:00 | 22/11/2024 23:00 | 22/11/2024 00:00 | 22/11/2024 20:00 | |
| Maximum | 48.78 | 0.21 | 96.81 | 0 | 51.6 | |
| MaxDate | 22/11/2024 06:00 | 22/11/2024 05:00 | 22/11/2024 12:00 | 22/11/2024 00:00 | 22/11/2024 23:00 | |
| Avg | 40.69 | 0.05 | 95.72 | 0 | 36.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8 | 0.1 | 1.1 | 0 | 7.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 12:00 | 5.83 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/11/2024 13:00 | 32.2 | 0.08 | 93.6 | 0 | 34.7 | |
| 22/11/2024 14:00 | 34.65 | 0.31 | 94.49 | 0 | 26.3 | |
| 22/11/2024 15:00 | 34.58 | 0.08 | 94.49 | 0 | 26.1 | |
| 22/11/2024 16:00 | 34.34 | 0.08 | 94.15 | 0 | 25.7 | |
| 22/11/2024 17:00 | 34.04 | 0.08 | 93.92 | 0 | 25.3 | |
| 22/11/2024 18:00 | 34.06 | 0.08 | 93.87 | 0 | 25.2 | |
| 22/11/2024 19:00 | 33.85 | 0.08 | 93.66 | 0 | 25 | |
| 22/11/2024 20:00 | 34.16 | 0.08 | 93.84 | 0 | 25 | |
| 22/11/2024 21:00 | 34.35 | 0.08 | 94.02 | 0 | 25.1 | |
| 22/11/2024 22:00 | 34.08 | 0.08 | 95.02 | 0 | 32.5 | |
| 22/11/2024 23:00 | 24.69 | 0.08 | 91.69 | 0 | 51 | |
| 23/11/2024 00:00 | 28.49 | 0.08 | 91.71 | 0 | 44 | |
| Minimum | 0 | 0.08 | 91.69 | 0 | 25 | |
| MinDate | 22/11/2024 00:00 | 22/11/2024 00:00 | 22/11/2024 23:00 | 22/11/2024 13:00 | 22/11/2024 19:00 | |
| Maximum | 34.65 | 0.31 | 95.02 | 0 | 51 | |
| MaxDate | 22/11/2024 14:00 | 22/11/2024 14:00 | 22/11/2024 22:00 | 22/11/2024 13:00 | 22/11/2024 23:00 | |
| Avg | 15.97 | 0.09 | 93.7 | 0 | 30.5 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.7 | 0 | 1 | 0 | 8.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/11/2024 00:00 | 28.54 | 0.05 | 92.68 | 0 | 47.1 | |
| 23/11/2024 01:00 | 28.92 | 0.01 | 92.75 | 0 | 45.6 | |
| 23/11/2024 02:00 | 28.93 | 0 | 92.68 | 0 | 45.6 | |
| 23/11/2024 03:00 | 28.78 | 0 | 92.47 | 0 | 46.6 | |
| 23/11/2024 04:00 | 28.73 | 0 | 92.32 | 0 | 47 | |
| 23/11/2024 05:00 | 28.52 | 0.17 | 92.19 | 0 | 48 | |
| 23/11/2024 06:00 | 28.48 | 0 | 92.13 | 0 | 48.4 | |
| 23/11/2024 07:00 | 28.15 | 0 | 92.26 | 0 | 49.2 | |
| 23/11/2024 08:00 | 28.04 | 0.04 | 92.42 | 0 | 49.2 | |
| 23/11/2024 09:00 | 28.21 | 0.11 | 92.58 | 0 | 47.6 | |
| 23/11/2024 10:00 | 28.24 | 0.16 | 92.85 | 0 | 46.4 | |
| 23/11/2024 11:00 | 28.29 | 0.2 | 93.13 | 0 | 45.2 | |
| 23/11/2024 12:00 | 28.32 | 0.2 | 93.43 | 0 | 44.4 | |
| 23/11/2024 13:00 | 38.7 | 0.17 | 97.91 | 0 | 33.5 | |
| 23/11/2024 14:00 | 42.18 | 0.13 | 101.57 | 0 | 29.2 | |
| 23/11/2024 15:00 | 42.2 | 0.09 | 101.49 | 0 | 29.1 | |
| 23/11/2024 16:00 | 42.17 | 0.1 | 101.11 | 0 | 29 | |
| 23/11/2024 17:00 | 42.13 | 0.1 | 100.95 | 0 | 28.7 | |
| 23/11/2024 18:00 | 42.04 | 0.09 | 100.75 | 0 | 28.7 | |
| 23/11/2024 19:00 | 41.95 | 0.08 | 100.64 | 0 | 28.6 | |
| 23/11/2024 20:00 | 41.97 | 0.06 | 100.57 | 0 | 28.7 | |
| 23/11/2024 21:00 | 41.99 | 0.07 | 101.02 | 0 | 28.8 | |
| 23/11/2024 22:00 | 38.37 | 0.19 | 100.12 | 0 | 32.6 | |
| 23/11/2024 23:00 | 28.09 | 0.2 | 93.66 | 0 | 47.1 | |
| 24/11/2024 00:00 | 28.07 | 0.08 | 92.68 | 0 | 46.8 | |
| Minimum | 28.04 | 0 | 92.13 | 0 | 28.6 | |
| MinDate | 23/11/2024 08:00 | 23/11/2024 02:00 | 23/11/2024 06:00 | 23/11/2024 00:00 | 23/11/2024 19:00 | |
| Maximum | 42.2 | 0.2 | 101.57 | 0 | 49.2 | |
| MaxDate | 23/11/2024 15:00 | 23/11/2024 11:00 | 23/11/2024 14:00 | 23/11/2024 00:00 | 23/11/2024 07:00 | |
| Avg | 33.6 | 0.09 | 95.85 | 0 | 40 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.5 | 0.1 | 4 | 0 | 8.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/11/2024 00:00 | 28.49 | 0.08 | 91.71 | 0 | 44 | |
| 23/11/2024 01:00 | 28.86 | 0.08 | 91.76 | 0 | 43 | |
| 23/11/2024 02:00 | 28.87 | 0.08 | 91.73 | 0 | 43.1 | |
| 23/11/2024 03:00 | 28.71 | 0.08 | 91.55 | 0 | 43.8 | |
| 23/11/2024 04:00 | 28.67 | 0.08 | 91.36 | 0 | 44.1 | |
| 23/11/2024 05:00 | 28.47 | 0.08 | 91.13 | 0 | 44.8 | |
| 23/11/2024 06:00 | 28.42 | 0.08 | 91.06 | 0 | 45.1 | |
| 23/11/2024 07:00 | 28.08 | 0.08 | 91.36 | 0 | 45.7 | |
| 23/11/2024 08:00 | 27.98 | 0.08 | 91.68 | 0 | 45.4 | |
| 23/11/2024 09:00 | 28.16 | 0.08 | 91.77 | 0 | 44.2 | |
| 23/11/2024 10:00 | 28.17 | 0.08 | 91.96 | 0 | 43.4 | |
| 23/11/2024 11:00 | 28.23 | 0.08 | 92.22 | 0 | 42.7 | |
| 23/11/2024 12:00 | 28.25 | 0.08 | 92.4 | 0 | 42 | |
| 23/11/2024 13:00 | 38.66 | 0.08 | 96.59 | 0 | 34.2 | |
| 23/11/2024 14:00 | 42.1 | 0.25 | 99.5 | 0 | 30.5 | |
| 23/11/2024 15:00 | 42.11 | 0.08 | 99.32 | 0 | 30.3 | |
| 23/11/2024 16:00 | 42.09 | 0.08 | 99.06 | 0 | 29.7 | |
| 23/11/2024 17:00 | 42.05 | 0.08 | 98.96 | 0 | 29.1 | |
| 23/11/2024 18:00 | 41.96 | 0.08 | 98.87 | 0 | 28.8 | |
| 23/11/2024 19:00 | 41.89 | 0.08 | 98.71 | 0 | 28.3 | |
| 23/11/2024 20:00 | 41.89 | 0.08 | 98.67 | 0 | 28.5 | |
| 23/11/2024 21:00 | 41.92 | 0.08 | 98.87 | 0 | 28.6 | |
| 23/11/2024 22:00 | 38.3 | 0.08 | 97.98 | 0 | 32 | |
| 23/11/2024 23:00 | 28.02 | 0.08 | 92.21 | 0 | 43.5 | |
| 24/11/2024 00:00 | 28.01 | 0.08 | 91.24 | 0 | 43.4 | |
| Minimum | 27.98 | 0.08 | 91.06 | 0 | 28.3 | |
| MinDate | 23/11/2024 08:00 | 23/11/2024 00:00 | 23/11/2024 06:00 | 23/11/2024 00:00 | 23/11/2024 19:00 | |
| Maximum | 42.11 | 0.25 | 99.5 | 0 | 45.7 | |
| MaxDate | 23/11/2024 15:00 | 23/11/2024 14:00 | 23/11/2024 14:00 | 23/11/2024 00:00 | 23/11/2024 07:00 | |
| Avg | 33.53 | 0.09 | 94.47 | 0 | 38.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.5 | 0 | 3.5 | 0 | 7.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|-----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/11/2024 00:00 | 28.07 | 0.08 | 92.68 | 0 | 46.8 | |
| 24/11/2024 01:00 | 28.09 | 0.04 | 92.74 | 0 | 46.7 | |
| 24/11/2024 02:00 | 28.11 | 0.01 | 92.78 | 0 | 47 | |
| 24/11/2024 03:00 | 28.06 | 0.02 | 92.64 | 0 | 47.3 | |
| 24/11/2024 04:00 | 27.99 | 0 | 92.46 | 0 | 47.7 | |
| 24/11/2024 05:00 | 27.91 | 0.4 | 92.44 | 0 | 48.2 | |
| 24/11/2024 06:00 | 27.68 | 0 | 92.27 | 0 | 48.9 | |
| 24/11/2024 07:00 | 27.27 | 0 | 92.22 | 0 | 49.9 | |
| 24/11/2024 08:00 | 27.11 | 0 | 92.41 | 0 | 49.8 | |
| 24/11/2024 09:00 | 27.16 | 0.02 | 92.62 | 0 | 49 | |
| 24/11/2024 10:00 | 27.17 | 0.1 | 92.77 | 0 | 48.1 | |
| 24/11/2024 11:00 | 27.21 | 0.1 | 93.05 | 0 | 47.3 | |
| 24/11/2024 12:00 | 27.26 | 0.19 | 93.28 | 0 | 45.7 | |
| 24/11/2024 13:00 | 27.27 | 0.23 | 93.3 | 0 | 44.5 | |
| 24/11/2024 14:00 | 27.29 | 0.22 | 93.23 | 0 | 44.4 | |
| 24/11/2024 15:00 | 27.27 | 0.18 | 92.89 | 0 | 44.7 | |
| 24/11/2024 16:00 | 27.24 | 0.2 | 92.73 | 0 | 44.6 | |
| 24/11/2024 17:00 | 30.72 | 0.15 | 93.43 | 0 | 42.2 | |
| 24/11/2024 18:00 | 41.03 | 0.04 | 99.62 | 0 | 26.7 | |
| 24/11/2024 19:00 | 41.05 | 0.05 | 100.11 | 0 | 26.8 | |
| 24/11/2024 20:00 | 41.15 | 0.04 | 100.13 | 0 | 26.7 | |
| 24/11/2024 21:00 | 19.83 | 0.12 | <Samp | <Samp | <Samp | GT 11 S/D |
| 24/11/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/11/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 25/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| Minimum | 0 | 0 | 92.22 | 0 | 26.7 | |
| MinDate | 24/11/2024 22:00 | 24/11/2024 04:00 | 24/11/2024 07:00 | 24/11/2024 00:00 | 24/11/2024 18:00 | |
| Maximum | 41.15 | 0.4 | 100.13 | 0 | 49.9 | |
| MaxDate | 24/11/2024 20:00 | 24/11/2024 05:00 | 24/11/2024 20:00 | 24/11/2024 00:00 | 24/11/2024 07:00 | |
| Avg | 25.68 | 0.09 | 93.8 | 0 | 44 | |
| Num | 25 | 25 | 21 | 21 | 21 | |
| Data[%] | 100 | 100 | 84 | 84 | 84 | |
| STD | 10.8 | 0.1 | 2.6 | 0 | 7.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/11/2024 00:00 | 28.01 | 0.08 | 91.24 | 0 | 43.4 | |
| 24/11/2024 01:00 | 28.03 | 0.08 | 91.32 | 0 | 43.4 | |
| 24/11/2024 02:00 | 28.05 | 0.08 | 91.36 | 0 | 43.5 | |
| 24/11/2024 03:00 | 28.01 | 0.08 | 91.22 | 0 | 43.8 | |
| 24/11/2024 04:00 | 27.92 | 0.08 | 91.06 | 0 | 44.2 | |
| 24/11/2024 05:00 | 27.86 | 0.08 | 90.99 | 0 | 44.7 | |
| 24/11/2024 06:00 | 27.62 | 0.08 | 90.87 | 0 | 45.1 | |
| 24/11/2024 07:00 | 27.2 | 0.08 | 90.8 | 0 | 46 | |
| 24/11/2024 08:00 | 27.05 | 0.08 | 91.08 | 0 | 45.7 | |
| 24/11/2024 09:00 | 27.09 | 0.08 | 91.24 | 0 | 44.8 | |
| 24/11/2024 10:00 | 27.1 | 0.08 | 91.4 | 0 | 44.2 | |
| 24/11/2024 11:00 | 27.15 | 0.08 | 91.62 | 0 | 43.4 | |
| 24/11/2024 12:00 | 27.2 | 0.08 | 91.79 | 0 | 42.5 | |
| 24/11/2024 13:00 | 27.21 | 0.08 | 91.87 | 0 | 41.9 | |
| 24/11/2024 14:00 | 27.22 | 0.44 | 91.85 | 0 | 41.7 | |
| 24/11/2024 15:00 | 27.2 | 0.08 | 91.65 | 0 | 41.9 | |
| 24/11/2024 16:00 | 27.18 | 0.08 | 91.58 | 0 | 41.9 | |
| 24/11/2024 17:00 | 30.66 | 0.08 | 92.34 | 0 | 40 | |
| 24/11/2024 18:00 | 40.95 | 0.08 | 97.87 | 0 | 25.9 | |
| 24/11/2024 19:00 | 40.97 | 0.08 | 98.32 | 0 | 25.7 | |
| 24/11/2024 20:00 | 41.07 | 0.08 | 98.29 | 0 | 25.6 | |
| 24/11/2024 21:00 | 41.14 | 0.08 | 97.09 | 0 | 34.7 | |
| 24/11/2024 22:00 | 48.15 | 0.08 | 95.12 | 0 | 40.8 | |
| 24/11/2024 23:00 | 48.3 | 0.08 | 95.27 | 0 | 41 | |
| 25/11/2024 00:00 | 48.3 | 0.08 | 95.58 | 0 | 41.1 | |
| Minimum | 27.05 | 0.08 | 90.8 | 0 | 25.6 | |
| MinDate | 24/11/2024 08:00 | 24/11/2024 00:00 | 24/11/2024 07:00 | 24/11/2024 00:00 | 24/11/2024 20:00 | |
| Maximum | 48.3 | 0.44 | 98.32 | 0 | 46 | |
| MaxDate | 24/11/2024 23:00 | 24/11/2024 14:00 | 24/11/2024 19:00 | 24/11/2024 00:00 | 24/11/2024 07:00 | |
| Avg | 32.27 | 0.09 | 92.91 | 0 | 40.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.8 | 0.1 | 2.6 | 0 | 6.1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/11/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 05:00 | 0 | 0.28 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 09:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 11:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 12:00 | 4.47 | 0.64 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 25/11/2024 13:00 | 32.39 | 0.16 | 94.69 | 0 | 37.2 | |
| 25/11/2024 14:00 | 34.44 | 0.15 | 95.79 | 0 | 29.4 | |
| 25/11/2024 15:00 | 34.43 | 0.11 | 95.8 | 0 | 29.2 | |
| 25/11/2024 16:00 | 34.42 | 0.09 | 95.34 | 0 | 28.9 | |
| 25/11/2024 17:00 | 34.26 | 0.07 | 95.11 | 0 | 28.7 | |
| 25/11/2024 18:00 | 34.24 | 0.07 | 95.07 | 0 | 28.5 | |
| 25/11/2024 19:00 | 34.17 | 0.05 | 94.98 | 0 | 28.5 | |
| 25/11/2024 20:00 | 34.2 | 0.05 | 94.9 | 0 | 28.3 | |
| 25/11/2024 21:00 | 34.31 | 0.05 | 95.09 | 0 | 28.3 | |
| 25/11/2024 22:00 | 31.65 | 0.09 | 95.02 | 0 | 33.9 | |
| 25/11/2024 23:00 | 46.25 | 0.01 | 96.36 | 0 | 40.1 | |
| 26/11/2024 00:00 | 47.97 | 0 | 95.81 | 0 | 40.6 | |
| Minimum | 0 | 0 | 94.69 | 0 | 28.3 | |
| MinDate | 25/11/2024 00:00 | 25/11/2024 00:00 | 25/11/2024 13:00 | 25/11/2024 13:00 | 25/11/2024 20:00 | |
| Maximum | 47.97 | 0.64 | 96.36 | 0 | 40.6 | |
| MaxDate | 26/11/2024 00:00 | 25/11/2024 12:00 | 25/11/2024 23:00 | 25/11/2024 13:00 | 26/11/2024 00:00 | |
| Avg | 17.49 | 0.08 | 95.33 | 0 | 31.8 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.5 | 0 | 4.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/11/2024 00:00 | 48.3 | 0.08 | 95.58 | 0 | 41.1 | |
| 25/11/2024 01:00 | 48.29 | 0.08 | 95.51 | 0 | 41.1 | |
| 25/11/2024 02:00 | 48.25 | 0.08 | 95.25 | 0 | 41.1 | |
| 25/11/2024 03:00 | 48.39 | 0.08 | 95.23 | 0 | 41.2 | |
| 25/11/2024 04:00 | 48.59 | 0.08 | 95.4 | 0 | 41.4 | |
| 25/11/2024 05:00 | 48.61 | 0.08 | 95.43 | 0 | 41.4 | |
| 25/11/2024 06:00 | 48.7 | 0.08 | 95.41 | 0 | 41.4 | |
| 25/11/2024 07:00 | 48.6 | 0.08 | 95.45 | 0 | 41.4 | |
| 25/11/2024 08:00 | 48.21 | 0.08 | 95.26 | 0 | 40.8 | |
| 25/11/2024 09:00 | 47.66 | 0.08 | 95.14 | 0 | 40.1 | |
| 25/11/2024 10:00 | 47.32 | 0.08 | 95.22 | 0 | 39.2 | |
| 25/11/2024 11:00 | 47.05 | 0.08 | 95.01 | 0 | 38.8 | |
| 25/11/2024 12:00 | 44.91 | 0.08 | 95.68 | 0 | 35.5 | |
| 25/11/2024 13:00 | 32.3 | 0.08 | 93.62 | 0 | 28.1 | |
| 25/11/2024 14:00 | 34.37 | 0.35 | 94.1 | 0 | 20.7 | |
| 25/11/2024 15:00 | 34.36 | 0.08 | 94.1 | 0 | 20.6 | |
| 25/11/2024 16:00 | 34.36 | 0.08 | 93.7 | 0 | 20.4 | |
| 25/11/2024 17:00 | 34.19 | 0.08 | 93.6 | 0 | 20.3 | |
| 25/11/2024 18:00 | 34.18 | 0.08 | 93.64 | 0 | 20.2 | |
| 25/11/2024 19:00 | 34.1 | 0.08 | 93.51 | 0 | 20.3 | |
| 25/11/2024 20:00 | 34.13 | 0.08 | 93.56 | 0 | 20.2 | |
| 25/11/2024 21:00 | 34.26 | 0.08 | 93.69 | 0 | 20.2 | |
| 25/11/2024 22:00 | 31.55 | 0.08 | 93.4 | 0 | 26.6 | |
| 25/11/2024 23:00 | 2.38 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 93.4 | 0 | 20.2 | |
| MinDate | 26/11/2024 00:00 | 25/11/2024 00:00 | 25/11/2024 22:00 | 25/11/2024 00:00 | 25/11/2024 18:00 | |
| Maximum | 48.7 | 0.35 | 95.68 | 0 | 41.4 | |
| MaxDate | 25/11/2024 06:00 | 25/11/2024 14:00 | 25/11/2024 12:00 | 25/11/2024 00:00 | 25/11/2024 04:00 | |
| Avg | 38.52 | 0.09 | 94.63 | 0 | 32.3 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.2 | 0.1 | 0.9 | 0 | 9.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/11/2024 00:00 | 47.97 | 0 | 95.81 | 0 | 40.6 | |
| 26/11/2024 01:00 | 48.01 | 0 | 96.48 | 0 | 40.5 | |
| 26/11/2024 02:00 | 48.17 | 0 | 96.47 | 0 | 40.2 | |
| 26/11/2024 03:00 | 48.31 | 0 | 96.42 | 0 | 40 | |
| 26/11/2024 04:00 | 48.4 | 0 | 96.46 | 0 | 39.9 | |
| 26/11/2024 05:00 | 48.47 | 0.21 | 96.35 | 0 | 39.8 | |
| 26/11/2024 06:00 | 48.52 | 0 | 96.39 | 0 | 40 | |
| 26/11/2024 07:00 | 48.26 | 0 | 96.4 | 0 | 40 | |
| 26/11/2024 08:00 | 48.32 | 0 | 96.38 | 0 | 39.9 | |
| 26/11/2024 09:00 | 47.93 | 0 | 96.4 | 0 | 39.5 | |
| 26/11/2024 10:00 | 47.09 | 0 | 96.33 | 0 | 39.2 | |
| 26/11/2024 11:00 | 46.29 | 0.1 | 96.35 | 0 | 40 | |
| 26/11/2024 12:00 | 42.91 | 0.14 | 96.99 | 0 | 40.3 | |
| 26/11/2024 13:00 | 32.49 | 0.2 | 95.23 | 0 | 36.6 | |
| 26/11/2024 14:00 | 34.6 | 0.18 | 96.21 | 0 | 28.4 | |
| 26/11/2024 15:00 | 34.65 | 0.15 | 95.81 | 0 | 28.6 | |
| 26/11/2024 16:00 | 34.59 | 0.1 | 95.63 | 0 | 28.4 | |
| 26/11/2024 17:00 | 34.42 | 0.09 | 95.34 | 0 | 28.2 | |
| 26/11/2024 18:00 | 34.39 | 0.07 | 95.2 | 0 | 28 | |
| 26/11/2024 19:00 | 34.18 | 0.07 | 95.09 | 0 | 27.5 | |
| 26/11/2024 20:00 | 34.23 | 0.05 | 95.13 | 0 | 27.3 | |
| 26/11/2024 21:00 | 34.44 | 0.01 | 95.58 | 0 | 27.1 | |
| 26/11/2024 22:00 | 31.58 | 0.03 | 95.17 | 0 | 33 | |
| 26/11/2024 23:00 | 2.4 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 00:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 95.09 | 0 | 27.1 | |
| MinDate | 27/11/2024 00:00 | 26/11/2024 00:00 | 26/11/2024 19:00 | 26/11/2024 00:00 | 26/11/2024 21:00 | |
| Maximum | 48.52 | 0.21 | 96.99 | 0 | 40.6 | |
| MaxDate | 26/11/2024 06:00 | 26/11/2024 05:00 | 26/11/2024 12:00 | 26/11/2024 00:00 | 26/11/2024 00:00 | |
| Avg | 38.42 | 0.06 | 95.98 | 0 | 35.3 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.1 | 0.1 | 0.6 | 0 | 5.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 11:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 12:00 | 6.13 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 26/11/2024 13:00 | 32.42 | 0.06 | 93.58 | 0 | 35 | |
| 26/11/2024 14:00 | 34.53 | 0.29 | 94.74 | 0 | 27.1 | |
| 26/11/2024 15:00 | 34.58 | 0.05 | 94.33 | 0 | 27.1 | |
| 26/11/2024 16:00 | 34.52 | 0.03 | 94.15 | 0 | 26.9 | |
| 26/11/2024 17:00 | 34.35 | 0.05 | 93.87 | 0 | 26.7 | |
| 26/11/2024 18:00 | 34.33 | 0.07 | 93.94 | 0 | 26.5 | |
| 26/11/2024 19:00 | 34.11 | 0.08 | 93.73 | 0 | 26 | |
| 26/11/2024 20:00 | 34.17 | 0.08 | 93.68 | 0 | 25.8 | |
| 26/11/2024 21:00 | 34.37 | 0.07 | 93.93 | 0 | 25.7 | |
| 26/11/2024 22:00 | 31.55 | 0.07 | 93.54 | 0 | 31.7 | |
| 26/11/2024 23:00 | 46.38 | 0.07 | 95.44 | 0 | 44.8 | |
| 27/11/2024 00:00 | 48.59 | 0.08 | 95.18 | 0 | 46.8 | |
| Minimum | 0 | 0.03 | 93.54 | 0 | 25.7 | |
| MinDate | 26/11/2024 00:00 | 26/11/2024 16:00 | 26/11/2024 22:00 | 26/11/2024 13:00 | 26/11/2024 21:00 | |
| Maximum | 48.59 | 0.29 | 95.44 | 0 | 46.8 | |
| MaxDate | 27/11/2024 00:00 | 26/11/2024 14:00 | 26/11/2024 23:00 | 26/11/2024 13:00 | 27/11/2024 00:00 | |
| Avg | 17.6 | 0.08 | 94.18 | 0 | 30.8 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0 | 0.6 | 0 | 7.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/11/2024 00:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 01:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 05:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 10:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 11:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 12:00 | 5.6 | 0.56 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/11/2024 13:00 | 32.51 | 0.18 | 95.1 | 0 | 36.8 | |
| 27/11/2024 14:00 | 34.66 | 0.21 | 96.2 | 0 | 29.7 | |
| 27/11/2024 15:00 | 34.67 | 0.19 | 95.59 | 0 | 29.9 | |
| 27/11/2024 16:00 | 34.57 | 0.15 | 95.17 | 0 | 29.9 | |
| 27/11/2024 17:00 | 34.45 | 0.1 | 94.92 | 0 | 29.4 | |
| 27/11/2024 18:00 | 34.4 | 0.06 | 94.97 | 0 | 29.1 | |
| 27/11/2024 19:00 | 34.18 | 0.05 | 94.8 | 0 | 28.7 | |
| 27/11/2024 20:00 | 34.18 | 0.02 | 94.81 | 0 | 28.3 | |
| 27/11/2024 21:00 | 34.32 | 0.01 | 95.05 | 0 | 28 | |
| 27/11/2024 22:00 | 31.59 | 0.07 | 94.99 | 0 | 34 | |
| 27/11/2024 23:00 | 46.26 | 0.01 | 96.39 | 0 | 40.1 | |
| 28/11/2024 00:00 | 48.16 | 0 | 96.04 | 0 | 40.6 | |
| Minimum | 0 | 0 | 94.8 | 0 | 28 | |
| MinDate | 27/11/2024 00:00 | 27/11/2024 02:00 | 27/11/2024 19:00 | 27/11/2024 13:00 | 27/11/2024 21:00 | |
| Maximum | 48.16 | 0.56 | 96.39 | 0 | 40.6 | |
| MaxDate | 28/11/2024 00:00 | 27/11/2024 12:00 | 27/11/2024 23:00 | 27/11/2024 13:00 | 28/11/2024 00:00 | |
| Avg | 17.58 | 0.07 | 95.34 | 0 | 32 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.6 | 0 | 4.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/11/2024 00:00 | 48.59 | 0.08 | 95.18 | 0 | 46.8 | |
| 27/11/2024 01:00 | 48.47 | 0.08 | 95.55 | 0 | 46.9 | |
| 27/11/2024 02:00 | 48.53 | 0.08 | 95.55 | 0 | 46.8 | |
| 27/11/2024 03:00 | 48.52 | 0.08 | 95.44 | 0 | 46.4 | |
| 27/11/2024 04:00 | 48.51 | 0.08 | 95.23 | 0 | 46.3 | |
| 27/11/2024 05:00 | 48.62 | 0.08 | 95.11 | 0 | 46.8 | |
| 27/11/2024 06:00 | 48.77 | 0.07 | 94.99 | 0 | 47 | |
| 27/11/2024 07:00 | 48.75 | 0.05 | 95.15 | 0 | 46.8 | |
| 27/11/2024 08:00 | 48.62 | 0.07 | 95.34 | 0 | 46.8 | |
| 27/11/2024 09:00 | 48.26 | 0.08 | 95.16 | 0 | 46.3 | |
| 27/11/2024 10:00 | 47.9 | 0.08 | 95.18 | 0 | 45.7 | |
| 27/11/2024 11:00 | 47.36 | 0.08 | 95.12 | 0 | 45.1 | |
| 27/11/2024 12:00 | 43.96 | 0.08 | 95.57 | 0 | 42.3 | |
| 27/11/2024 13:00 | 32.44 | 0.08 | 93.61 | 0 | 31.6 | |
| 27/11/2024 14:00 | 34.59 | 0.23 | 94.45 | 0 | 24.8 | |
| 27/11/2024 15:00 | 34.6 | 0.08 | 94.08 | 0 | 24.9 | |
| 27/11/2024 16:00 | 34.5 | 0.08 | 93.64 | 0 | 24.7 | |
| 27/11/2024 17:00 | 34.38 | 0.08 | 93.45 | 0 | 24.5 | |
| 27/11/2024 18:00 | 34.34 | 0.08 | 93.5 | 0 | 24.3 | |
| 27/11/2024 19:00 | 34.11 | 0.08 | 93.45 | 0 | 24 | |
| 27/11/2024 20:00 | 34.11 | 0.08 | 93.39 | 0 | 23.8 | |
| 27/11/2024 21:00 | 34.25 | 0.08 | 93.48 | 0 | 23.6 | |
| 27/11/2024 22:00 | 31.5 | 0.08 | 93.35 | 0 | 29.8 | |
| 27/11/2024 23:00 | 2.4 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.05 | 93.35 | 0 | 23.6 | |
| MinDate | 28/11/2024 00:00 | 27/11/2024 07:00 | 27/11/2024 22:00 | 27/11/2024 00:00 | 27/11/2024 21:00 | |
| Maximum | 48.77 | 0.23 | 95.57 | 0 | 47 | |
| MaxDate | 27/11/2024 06:00 | 27/11/2024 14:00 | 27/11/2024 12:00 | 27/11/2024 00:00 | 27/11/2024 06:00 | |
| Avg | 38.64 | 0.08 | 94.56 | 0 | 37.2 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.3 | 0 | 0.9 | 0 | 10.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/11/2024 00:00 | 48.16 | 0 | 96.04 | 0 | 40.6 | |
| 28/11/2024 01:00 | 48.21 | 0 | 96.29 | 0 | 40.6 | |
| 28/11/2024 02:00 | 48.4 | 0 | 96.27 | 0 | 41 | |
| 28/11/2024 03:00 | 48.66 | 0 | 96.29 | 0 | 41.2 | |
| 28/11/2024 04:00 | 48.8 | 0 | 96.25 | 0 | 41.4 | |
| 28/11/2024 05:00 | 48.87 | 0.34 | 96.33 | 0 | 41.2 | |
| 28/11/2024 06:00 | 48.9 | 0 | 96.43 | 0 | 40.5 | |
| 28/11/2024 07:00 | 48.81 | 0 | 96.39 | 0 | 40.1 | |
| 28/11/2024 08:00 | 48.79 | 0 | 96.25 | 0 | 40.4 | |
| 28/11/2024 09:00 | 48.6 | 0 | 96.2 | 0 | 40.9 | |
| 28/11/2024 10:00 | 48.1 | 0 | 96.32 | 0 | 40.6 | |
| 28/11/2024 11:00 | 47.46 | 0.03 | 96.45 | 0 | 39.9 | |
| 28/11/2024 12:00 | 44.57 | 0.07 | 97.08 | 0 | 38.4 | |
| 28/11/2024 13:00 | 32.46 | 0.22 | 94.92 | 0 | 37.5 | |
| 28/11/2024 14:00 | 34.57 | 0.17 | 95.48 | 0 | 27.7 | |
| 28/11/2024 15:00 | 34.47 | 0.2 | 95.04 | 0 | 27.6 | |
| 28/11/2024 16:00 | 34.4 | 0.2 | 94.88 | 0 | 27.4 | |
| 28/11/2024 17:00 | 34.21 | 0.19 | 94.61 | 0 | 27.2 | |
| 28/11/2024 18:00 | 34.14 | 0.18 | 94.52 | 0 | 27.2 | |
| 28/11/2024 19:00 | 33.94 | 0.16 | 94.34 | 0 | 27.1 | |
| 28/11/2024 20:00 | 34.06 | 0.12 | 94.32 | 0 | 27.1 | |
| 28/11/2024 21:00 | 34.21 | 0.08 | 94.49 | 0 | 27.2 | |
| 28/11/2024 22:00 | 31.36 | 0.07 | 93.84 | 0 | 34.8 | |
| 28/11/2024 23:00 | 47.21 | 0 | 95.62 | 0 | 39.7 | |
| 29/11/2024 00:00 | 48.91 | 0 | 95.61 | 0 | 40.1 | |
| Minimum | 31.36 | 0 | 93.84 | 0 | 27.1 | |
| MinDate | 28/11/2024 22:00 | 28/11/2024 00:00 | 28/11/2024 22:00 | 28/11/2024 00:00 | 28/11/2024 19:00 | |
| Maximum | 48.91 | 0.34 | 97.08 | 0 | 41.4 | |
| MaxDate | 29/11/2024 00:00 | 28/11/2024 05:00 | 28/11/2024 12:00 | 28/11/2024 00:00 | 28/11/2024 04:00 | |
| Avg | 42.41 | 0.08 | 95.61 | 0 | 35.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.3 | 0.1 | 0.9 | 0 | 6.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 12:00 | 5.01 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 28/11/2024 13:00 | 32.39 | 0.08 | 92.89 | 0 | 36.4 | |
| 28/11/2024 14:00 | 34.5 | 0.42 | 93.79 | 0 | 26.7 | |
| 28/11/2024 15:00 | 34.41 | 0.08 | 93.47 | 0 | 26.5 | |
| 28/11/2024 16:00 | 34.33 | 0.08 | 93.3 | 0 | 26.2 | |
| 28/11/2024 17:00 | 34.15 | 0.08 | 93.13 | 0 | 26 | |
| 28/11/2024 18:00 | 34.07 | 0.08 | 93.08 | 0 | 25.9 | |
| 28/11/2024 19:00 | 33.87 | 0.08 | 92.89 | 0 | 25.9 | |
| 28/11/2024 20:00 | 33.99 | 0.08 | 92.76 | 0 | 25.8 | |
| 28/11/2024 21:00 | 34.15 | 0.08 | 92.75 | 0 | 26.1 | |
| 28/11/2024 22:00 | 31.19 | 0.08 | 92.09 | 0 | 33.8 | |
| 28/11/2024 23:00 | 2.04 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 92.09 | 0 | 25.8 | |
| MinDate | 28/11/2024 00:00 | 28/11/2024 00:00 | 28/11/2024 22:00 | 28/11/2024 13:00 | 28/11/2024 20:00 | |
| Maximum | 34.5 | 0.42 | 93.79 | 0 | 36.4 | |
| MaxDate | 28/11/2024 14:00 | 28/11/2024 14:00 | 28/11/2024 14:00 | 28/11/2024 13:00 | 28/11/2024 13:00 | |
| Avg | 13.76 | 0.09 | 93.02 | 0 | 27.9 | |
| Num | 25 | 25 | 10 | 10 | 10 | |
| Data[%] | 100 | 100 | 40 | 40 | 40 | |
| STD | 16.7 | 0.1 | 0.5 | 0 | 3.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/11/2024 00:00 | 48.91 | 0 | 95.61 | 0 | 40.1 | |
| 29/11/2024 01:00 | 49.09 | 0 | 96.58 | 0 | 40 | |
| 29/11/2024 02:00 | 49.16 | 0 | 96.69 | 0 | 39.3 | |
| 29/11/2024 03:00 | 49.15 | 0 | 96.62 | 0 | 38.7 | |
| 29/11/2024 04:00 | 49.22 | 0 | 96.8 | 0 | 38.4 | |
| 29/11/2024 05:00 | 49.17 | 0.3 | 97.01 | 0 | 37.8 | |
| 29/11/2024 06:00 | 49.19 | 0 | 97.11 | 0 | 37.6 | |
| 29/11/2024 07:00 | 48.97 | 0 | 97.25 | 0 | 36.7 | |
| 29/11/2024 08:00 | 48.98 | 0 | 97.21 | 0 | 37.2 | |
| 29/11/2024 09:00 | 49.18 | 0 | 96.87 | 0 | 39.2 | |
| 29/11/2024 10:00 | 49.12 | 0 | 96.7 | 0 | 39.7 | |
| 29/11/2024 11:00 | 48.58 | 0.01 | 96.88 | 0 | 39.3 | |
| 29/11/2024 12:00 | 45.11 | 0.07 | 97.68 | 0 | 36.7 | |
| 29/11/2024 13:00 | 32.39 | 0.2 | 94.68 | 0 | 37.1 | |
| 29/11/2024 14:00 | 34.52 | 0.23 | 95.38 | 0 | 26.2 | |
| 29/11/2024 15:00 | 34.46 | 0.24 | 95.1 | 0 | 26.1 | |
| 29/11/2024 16:00 | 34.43 | 0.21 | 94.8 | 0 | 26 | |
| 29/11/2024 17:00 | 34.29 | 0.2 | 94.61 | 0 | 25.8 | |
| 29/11/2024 18:00 | 34.21 | 0.2 | 94.6 | 0 | 25.7 | |
| 29/11/2024 19:00 | 34 | 0.18 | 94.31 | 0 | 25.7 | |
| 29/11/2024 20:00 | 34.04 | 0.16 | 94.01 | 0 | 25.7 | |
| 29/11/2024 21:00 | 34.24 | 0.09 | 94.23 | 0 | 25.7 | |
| 29/11/2024 22:00 | 33.89 | 0.08 | 94.92 | 0 | 34.7 | |
| 29/11/2024 23:00 | 25.22 | 0.12 | 91.32 | 0 | 55 | |
| 30/11/2024 00:00 | 28.45 | 0.11 | 91.75 | 0 | 52 | |
| Minimum | 25.22 | 0 | 91.32 | 0 | 25.7 | |
| MinDate | 29/11/2024 23:00 | 29/11/2024 00:00 | 29/11/2024 23:00 | 29/11/2024 00:00 | 29/11/2024 18:00 | |
| Maximum | 49.22 | 0.3 | 97.68 | 0 | 55 | |
| MaxDate | 29/11/2024 04:00 | 29/11/2024 05:00 | 29/11/2024 12:00 | 29/11/2024 00:00 | 29/11/2024 23:00 | |
| Avg | 41.12 | 0.1 | 95.55 | 0 | 35.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8.4 | 0.1 | 1.7 | 0 | 8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/11/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 12:00 | 5.01 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 29/11/2024 13:00 | 32.33 | 0.08 | 92.23 | 0 | 37.7 | |
| 29/11/2024 14:00 | 34.46 | 0.35 | 93.27 | 0 | 27.2 | |
| 29/11/2024 15:00 | 34.39 | 0.08 | 93.04 | 0 | 26.8 | |
| 29/11/2024 16:00 | 34.36 | 0.08 | 92.77 | 0 | 26.4 | |
| 29/11/2024 17:00 | 34.23 | 0.08 | 92.63 | 0 | 26.2 | |
| 29/11/2024 18:00 | 34.14 | 0.08 | 92.52 | 0 | 26.1 | |
| 29/11/2024 19:00 | 33.93 | 0.08 | 92.37 | 0 | 26.6 | |
| 29/11/2024 20:00 | 33.97 | 0.08 | 92.11 | 0 | 26.9 | |
| 29/11/2024 21:00 | 34.18 | 0.08 | 92.16 | 0 | 26.4 | |
| 29/11/2024 22:00 | 33.82 | 0.08 | 92.78 | 0 | 35 | |
| 29/11/2024 23:00 | 25.16 | 0.08 | 89.53 | 0 | 55.7 | |
| 30/11/2024 00:00 | 28.38 | 0.08 | 89.9 | 0 | 49.8 | |
| Minimum | 0 | 0.08 | 89.53 | 0 | 26.1 | |
| MinDate | 29/11/2024 00:00 | 29/11/2024 00:00 | 29/11/2024 23:00 | 29/11/2024 13:00 | 29/11/2024 18:00 | |
| Maximum | 34.46 | 0.35 | 93.27 | 0 | 55.7 | |
| MaxDate | 29/11/2024 14:00 | 29/11/2024 14:00 | 29/11/2024 14:00 | 29/11/2024 13:00 | 29/11/2024 23:00 | |
| Avg | 15.93 | 0.09 | 92.11 | 0 | 32.6 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.7 | 0.1 | 1.2 | 0 | 10.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/11/2024 00:00 | 28.45 | 0.11 | 91.75 | 0 | 52 | |
| 30/11/2024 01:00 | 28.6 | 0.09 | 92.24 | 0 | 51.9 | |
| 30/11/2024 02:00 | 28.57 | 0.1 | 92.28 | 0 | 52.1 | |
| 30/11/2024 03:00 | 28.49 | 0.09 | 92.23 | 0 | 52.6 | |
| 30/11/2024 04:00 | 28.34 | 0.08 | 92.08 | 0 | 53.3 | |
| 30/11/2024 05:00 | 28.22 | 0.27 | 91.96 | 0 | 54.2 | |
| 30/11/2024 06:00 | 28.22 | 0 | 91.89 | 0 | 54.6 | |
| 30/11/2024 07:00 | 28.05 | 0 | 91.97 | 0 | 54.8 | |
| 30/11/2024 08:00 | 28.16 | 0 | 92.14 | 0 | 54.3 | |
| 30/11/2024 09:00 | 28.41 | 0.05 | 92.52 | 0 | 52 | |
| 30/11/2024 10:00 | 28.45 | 0.13 | 92.53 | 0 | 50 | |
| 30/11/2024 11:00 | 28.46 | 0.18 | 92.72 | 0 | 48.4 | |
| 30/11/2024 12:00 | 28.35 | 0.25 | 92.86 | 0 | 47.4 | |
| 30/11/2024 13:00 | 38.81 | 0.18 | 97.46 | 0 | 33.4 | |
| 30/11/2024 14:00 | 42.51 | 0.16 | 101.1 | 0 | 28.9 | |
| 30/11/2024 15:00 | 42.49 | 0.16 | 100.86 | 0 | 28.6 | |
| 30/11/2024 16:00 | 42.42 | 0.17 | 100.77 | 0 | 28.5 | |
| 30/11/2024 17:00 | 41.94 | 0.19 | 100.37 | 0 | 28.2 | |
| 30/11/2024 18:00 | 41.82 | 0.22 | 100.27 | 0 | 28.2 | |
| 30/11/2024 19:00 | 41.81 | 0.22 | 100.23 | 0 | 28.2 | |
| 30/11/2024 20:00 | 42.17 | 0.21 | 100.28 | 0 | 28.3 | |
| 30/11/2024 21:00 | 42.3 | 0.22 | 100.63 | 0 | 28.1 | |
| 30/11/2024 22:00 | 38.73 | 0.37 | 99.74 | 0 | 32.1 | |
| 30/11/2024 23:00 | 28.37 | 0.44 | 93.39 | 0 | 48.9 | |
| 01/12/2024 00:00 | 28.23 | 0.41 | 93 | 0 | 49.6 | |
| Minimum | 8.32 | 0 | 94.2 | 1.3 | 25.5 | |
| MinDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 00:00 | 30/05/2024 22:00 | |
| Maximum | 48.02 | 0.38 | 96.03 | 1.5 | 43.9 | |
| MaxDate | 30/05/2024 06:00 | 30/05/2024 06:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 37.19 | 0.02 | 95.04 | 1.4 | 32.1 | |
| Num | 25 | 25 | 24 | 24 | 24 | |
| Data[%] | 100 | 100 | 96 | 96 | 96 | |
| STD | 9.1 | 0.1 | 0.5 | 0.1 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/11/2024 00:00 | 28.38 | 0.08 | 89.9 | 0 | 49.8 | |
| 30/11/2024 01:00 | 28.54 | 0.08 | 90.52 | 0 | 49.6 | |
| 30/11/2024 02:00 | 28.5 | 0.08 | 90.53 | 0 | 49.7 | |
| 30/11/2024 03:00 | 28.43 | 0.08 | 90.48 | 0 | 50.1 | |
| 30/11/2024 04:00 | 28.28 | 0.08 | 90.33 | 0 | 50.6 | |
| 30/11/2024 05:00 | 28.16 | 0.08 | 90.19 | 0 | 51.1 | |
| 30/11/2024 06:00 | 28.15 | 0.08 | 90.1 | 0 | 51.4 | |
| 30/11/2024 07:00 | 27.99 | 0.08 | 90.16 | 0 | 51.6 | |
| 30/11/2024 08:00 | 28.1 | 0.08 | 90.27 | 0 | 51 | |
| 30/11/2024 09:00 | 28.34 | 0.08 | 90.64 | 0 | 49.1 | |
| 30/11/2024 10:00 | 28.39 | 0.08 | 90.68 | 0 | 47.9 | |
| 30/11/2024 11:00 | 28.4 | 0.08 | 90.86 | 0 | 46.8 | |
| 30/11/2024 12:00 | 28.29 | 0.08 | 91 | 0 | 46.1 | |
| 30/11/2024 13:00 | 38.75 | 0.08 | 95.39 | 0 | 35.5 | |
| 30/11/2024 14:00 | 42.44 | 0.29 | 98.7 | 0 | 32 | |
| 30/11/2024 15:00 | 42.41 | 0.08 | 98.54 | 0 | 31.7 | |
| 30/11/2024 16:00 | 42.34 | 0.08 | 98.46 | 0 | 31.3 | |
| 30/11/2024 17:00 | 41.86 | 0.08 | 98.04 | 0 | 30 | |
| 30/11/2024 18:00 | 41.75 | 0.08 | 97.95 | 0 | 29.5 | |
| 30/11/2024 19:00 | 41.73 | 0.08 | 97.98 | 0 | 29.3 | |
| 30/11/2024 20:00 | 42.09 | 0.08 | 97.89 | 0 | 29.7 | |
| 30/11/2024 21:00 | 42.22 | 0.08 | 98.18 | 0 | 29.5 | |
| 30/11/2024 22:00 | 38.66 | 0.08 | 97.29 | 0 | 33.1 | |
| 30/11/2024 23:00 | 28.31 | 0.08 | 91.41 | 0 | 46.4 | |
| 01/12/2024 00:00 | 28.18 | 0.08 | 91.08 | 0 | 46.8 | |
| Minimum | 0 | --- | 94.25 | 0 | 20.5 | |
| MinDate | 30/05/2024 01:00 | 30/05/2024 00:00 | 30/05/2024 13:00 | 30/05/2024 09:00 | 30/05/2024 19:00 | |
| Maximum | 39.65 | --- | 96.1 | 0 | 39.7 | |
| MaxDate | 31/05/2024 00:00 | 30/05/2024 00:00 | 30/05/2024 11:00 | 30/05/2024 09:00 | 30/05/2024 12:00 | |
| Avg | 22.18 | --- | 95.12 | 0 | 24.5 | |
| Num | 25 | 0 | 16 | 16 | 16 | |
| Data[%] | 100 | --- | 64 | 64 | 64 | |
| STD | 16.1 | --- | 0.5 | 0 | 6.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/12/2024 00:00 | 28.23 | 0.41 | 93 | 0 | 49.6 | |
| 01/12/2024 01:00 | 28.24 | 0.33 | 92.89 | 0 | 49.6 | |
| 01/12/2024 02:00 | 28.14 | 0.39 | 92.92 | 0 | 50.2 | |
| 01/12/2024 03:00 | 27.79 | 0.35 | 92.83 | 0 | 51.3 | |
| 01/12/2024 04:00 | 27.18 | 0.39 | 92.66 | 0 | 51.8 | |
| 01/12/2024 05:00 | 26.92 | 0.41 | 92.52 | 0 | 52.4 | |
| 01/12/2024 06:00 | 26.79 | 0 | 92.53 | 0 | 52.3 | |
| 01/12/2024 07:00 | 26.6 | 0.01 | 92.68 | 0 | 52.6 | |
| 01/12/2024 08:00 | 25.97 | 0.06 | 92.46 | 0 | 52.3 | |
| 01/12/2024 09:00 | 25.85 | 0.02 | 92.23 | 0 | 52.3 | |
| 01/12/2024 10:00 | 25.84 | 0.06 | 92.46 | 0 | 51.6 | |
| 01/12/2024 11:00 | 25.84 | 0.12 | 92.83 | 0 | 51.2 | |
| 01/12/2024 12:00 | 25.91 | 0.18 | 93.19 | 0 | 51.1 | |
| 01/12/2024 13:00 | 25.9 | 0.26 | 93.42 | 0 | 50.7 | |
| 01/12/2024 14:00 | 25.93 | 0.26 | 93.47 | 0 | 50.8 | |
| 01/12/2024 15:00 | 25.91 | 0.2 | 92.96 | 0 | 50.7 | |
| 01/12/2024 16:00 | 25.92 | 0.14 | 92.66 | 0 | 50.5 | |
| 01/12/2024 17:00 | 25.97 | 0.08 | 92.44 | 0 | 50.1 | |
| 01/12/2024 18:00 | 39.94 | 0 | 98.09 | 0 | 26.5 | |
| 01/12/2024 19:00 | 40.57 | 0 | 99.53 | 0 | 25.9 | |
| 01/12/2024 20:00 | 40.76 | 0 | 99.54 | 0 | 25.8 | |
| 01/12/2024 21:00 | 28.99 | 0.1 | 98 | 0 | 35.9 | |
| 01/12/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 01/12/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 92.23 | 0 | 25.8 | |
| MinDate | 01/12/2024 22:00 | 01/12/2024 06:00 | 01/12/2024 09:00 | 01/12/2024 00:00 | 01/12/2024 20:00 | |
| Maximum | 40.76 | 0.41 | 99.54 | 0 | 52.6 | |
| MaxDate | 01/12/2024 20:00 | 01/12/2024 00:00 | 01/12/2024 20:00 | 01/12/2024 00:00 | 01/12/2024 07:00 | |
| Avg | 25.17 | 0.15 | 93.88 | 0 | 47.1 | |
| Num | 25 | 25 | 22 | 22 | 22 | |
| Data[%] | 100 | 100 | 88 | 88 | 88 | |
| STD | 10.5 | 0.2 | 2.4 | 0 | 9.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 01/12/2024 00:00 | 28.18 | 0.08 | 91.08 | 0 | 46.8 | |
| 01/12/2024 01:00 | 28.17 | 0.08 | 91.03 | 0 | 46.9 | |
| 01/12/2024 02:00 | 28.08 | 0.08 | 91.1 | 0 | 47.3 | |
| 01/12/2024 03:00 | 27.73 | 0.08 | 91.04 | 0 | 48.3 | |
| 01/12/2024 04:00 | 27.12 | 0.08 | 90.86 | 0 | 49.5 | |
| 01/12/2024 05:00 | 26.87 | 0.08 | 90.71 | 0 | 50.5 | |
| 01/12/2024 06:00 | 26.73 | 0.08 | 90.73 | 0 | 50.9 | |
| 01/12/2024 07:00 | 26.55 | 0.08 | 90.89 | 0 | 51.3 | |
| 01/12/2024 08:00 | 25.91 | 0.08 | 90.68 | 0 | 52.2 | |
| 01/12/2024 09:00 | 25.8 | 0.08 | 90.39 | 0 | 52 | |
| 01/12/2024 10:00 | 25.79 | 0.08 | 90.56 | 0 | 51.2 | |
| 01/12/2024 11:00 | 25.78 | 0.08 | 91.06 | 0 | 50.5 | |
| 01/12/2024 12:00 | 25.85 | 0.08 | 91.35 | 0 | 49.9 | |
| 01/12/2024 13:00 | 25.85 | 0.08 | 91.6 | 0 | 49.4 | |
| 01/12/2024 14:00 | 25.87 | 0.23 | 91.66 | 0 | 49.1 | |
| 01/12/2024 15:00 | 25.85 | 0.08 | 91.29 | 0 | 49.1 | |
| 01/12/2024 16:00 | 25.86 | 0.08 | 91.01 | 0 | 48.9 | |
| 01/12/2024 17:00 | 25.91 | 0.08 | 90.78 | 0 | 49 | |
| 01/12/2024 18:00 | 39.87 | 0.08 | 95.99 | 0 | 26.5 | |
| 01/12/2024 19:00 | 40.49 | 0.08 | 97.27 | 0 | 25.6 | |
| 01/12/2024 20:00 | 40.68 | 0.08 | 97.28 | 0 | 25.5 | |
| 01/12/2024 21:00 | 39.5 | 0.08 | 96.43 | 0 | 32.1 | |
| 01/12/2024 22:00 | 48.81 | 0.08 | 95.93 | 0 | 43.1 | |
| 01/12/2024 23:00 | 48.92 | 0.08 | 95.26 | 0 | 43.7 | |
| 02/12/2024 00:00 | 48.99 | 0.08 | 95.69 | 0 | 43.3 | |
| Minimum | 25.78 | 0.08 | 90.39 | 0 | 25.5 | |
| MinDate | 01/12/2024 11:00 | 01/12/2024 00:00 | 01/12/2024 09:00 | 01/12/2024 00:00 | 01/12/2024 20:00 | |
| Maximum | 48.99 | 0.23 | 97.28 | 0 | 52.2 | |
| MaxDate | 02/12/2024 00:00 | 01/12/2024 14:00 | 01/12/2024 20:00 | 01/12/2024 00:00 | 01/12/2024 08:00 | |
| Avg | 31.41 | 0.09 | 92.47 | 0 | 45.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8.3 | 0 | 2.5 | 0 | 8.4 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 05:00 | 0 | 0.34 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 09:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 10:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 11:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 12:00 | 5.24 | 0.73 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 02/12/2024 13:00 | 32.37 | 0.39 | 94.74 | 0 | 40.5 | |
| 02/12/2024 14:00 | 34.49 | 0.39 | 96.24 | 0 | 32.2 | |
| 02/12/2024 15:00 | 34.55 | 0.36 | 96.08 | 0 | 31.8 | |
| 02/12/2024 16:00 | 34.26 | 0.36 | 95.72 | 0 | 30.8 | |
| 02/12/2024 17:00 | 33.74 | 0.37 | 95.08 | 0 | 30 | |
| 02/12/2024 18:00 | 33.62 | 0.39 | 94.82 | 0 | 29.8 | |
| 02/12/2024 19:00 | 33.46 | 0.32 | 94.67 | 0 | 29.9 | |
| 02/12/2024 20:00 | 33.93 | 0.18 | 94.73 | 0 | 29.9 | |
| 02/12/2024 21:00 | 34.25 | 0.06 | 95.13 | 0 | 29.9 | |
| 02/12/2024 22:00 | 31.55 | 0.11 | 94.72 | 0 | 36.5 | |
| 02/12/2024 23:00 | 46.84 | 0.01 | 96.34 | 0 | 43.1 | |
| 03/12/2024 00:00 | 48.51 | 0 | 96.26 | 0 | 43.3 | |
| Minimum | 0 | 0 | 94.67 | 0 | 29.8 | |
| MinDate | 02/12/2024 00:00 | 02/12/2024 00:00 | 02/12/2024 19:00 | 02/12/2024 13:00 | 02/12/2024 18:00 | |
| Maximum | 48.51 | 0.73 | 96.34 | 0 | 43.3 | |
| MaxDate | 03/12/2024 00:00 | 02/12/2024 12:00 | 02/12/2024 23:00 | 02/12/2024 13:00 | 03/12/2024 00:00 | |
| Avg | 17.47 | 0.17 | 95.38 | 0 | 34 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.5 | 0.2 | 0.7 | 0 | 5.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 02/12/2024 00:00 | 48.99 | 0.08 | 95.69 | 0 | 43.3 | |
| 02/12/2024 01:00 | 49.03 | 0.08 | 95.91 | 0 | 42.5 | |
| 02/12/2024 02:00 | 49.03 | 0.08 | 95.94 | 0 | 42.5 | |
| 02/12/2024 03:00 | 48.91 | 0.08 | 95.64 | 0 | 43.5 | |
| 02/12/2024 04:00 | 48.98 | 0.08 | 95.81 | 0 | 43.4 | |
| 02/12/2024 05:00 | 49 | 0.08 | 95.74 | 0 | 42.8 | |
| 02/12/2024 06:00 | 49.01 | 0.08 | 95.88 | 0 | 42.8 | |
| 02/12/2024 07:00 | 49 | 0.08 | 95.9 | 0 | 42.7 | |
| 02/12/2024 08:00 | 48.41 | 0.08 | 95.52 | 0 | 43.4 | |
| 02/12/2024 09:00 | 47.8 | 0.08 | 95.13 | 0 | 42.9 | |
| 02/12/2024 10:00 | 47.55 | 0.08 | 95.34 | 0 | 42.3 | |
| 02/12/2024 11:00 | 47.15 | 0.08 | 95.2 | 0 | 41.9 | |
| 02/12/2024 12:00 | 44.03 | 0.08 | 95.51 | 0 | 38.4 | |
| 02/12/2024 13:00 | 32.28 | 0.06 | 93.58 | 0 | 29.9 | |
| 02/12/2024 14:00 | 34.42 | 0.34 | 94.42 | 0 | 22 | |
| 02/12/2024 15:00 | 34.48 | 0.04 | 94.39 | 0 | 21.6 | |
| 02/12/2024 16:00 | 34.19 | 0.05 | 94.09 | 0 | 20.8 | |
| 02/12/2024 17:00 | 33.67 | 0.04 | 93.43 | 0 | 20.3 | |
| 02/12/2024 18:00 | 33.55 | 0.07 | 93.28 | 0 | 20.2 | |
| 02/12/2024 19:00 | 33.4 | 0.08 | 93.18 | 0 | 20.7 | |
| 02/12/2024 20:00 | 33.86 | 0.08 | 93.26 | 0 | 20.5 | |
| 02/12/2024 21:00 | 34.19 | 0.08 | 93.46 | 0 | 20.5 | |
| 02/12/2024 22:00 | 31.44 | 0.08 | 93.03 | 0 | 27.9 | |
| 02/12/2024 23:00 | 1.95 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.04 | 93.03 | 0 | 20.2 | |
| MinDate | 03/12/2024 00:00 | 02/12/2024 15:00 | 02/12/2024 22:00 | 02/12/2024 00:00 | 02/12/2024 18:00 | |
| Maximum | 49.03 | 0.34 | 95.94 | 0 | 43.5 | |
| MaxDate | 02/12/2024 01:00 | 02/12/2024 14:00 | 02/12/2024 02:00 | 02/12/2024 00:00 | 02/12/2024 03:00 | |
| Avg | 38.57 | 0.08 | 94.75 | 0 | 33.8 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.4 | 0.1 | 1.1 | 0 | 10.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/12/2024 00:00 | 48.51 | 0 | 96.26 | 0 | 43.3 | |
| 03/12/2024 01:00 | 48.74 | 0 | 96.98 | 0 | 43.1 | |
| 03/12/2024 02:00 | 48.73 | 0 | 97.09 | 0 | 42.7 | |
| 03/12/2024 03:00 | 48.83 | 0 | 97.1 | 0 | 42.3 | |
| 03/12/2024 04:00 | 48.19 | 0 | 97.34 | 0 | 40 | |
| 03/12/2024 05:00 | 47.64 | 0.28 | 97.91 | 0 | 37.5 | |
| 03/12/2024 06:00 | 47.6 | 0 | 98.19 | 0 | 36.6 | |
| 03/12/2024 07:00 | 47.82 | 0 | 97.75 | 0 | 38.8 | |
| 03/12/2024 08:00 | 48.11 | 0 | 96.73 | 0 | 41.5 | |
| 03/12/2024 09:00 | 47.67 | 0 | 96.67 | 0 | 41.5 | |
| 03/12/2024 10:00 | 46.95 | 0 | 96.56 | 0 | 41.7 | |
| 03/12/2024 11:00 | 46.37 | 0.01 | 96.38 | 0 | 41.6 | |
| 03/12/2024 12:00 | 42.64 | 0.02 | 96.8 | 0 | 42.2 | |
| 03/12/2024 13:00 | 32.37 | 0.05 | 94.98 | 0 | 38.6 | |
| 03/12/2024 14:00 | 34.49 | 0.06 | 95.87 | 0 | 29.8 | |
| 03/12/2024 15:00 | 34.52 | 0.05 | 95.49 | 0 | 29.8 | |
| 03/12/2024 16:00 | 34.21 | 0.06 | 95.27 | 0 | 29.4 | |
| 03/12/2024 17:00 | 33.61 | 0.03 | 94.9 | 0 | 28.7 | |
| 03/12/2024 18:00 | 33.47 | 0.04 | 94.85 | 0 | 28.4 | |
| 03/12/2024 19:00 | 33.36 | 0.08 | 94.87 | 0 | 27.9 | |
| 03/12/2024 20:00 | 33.9 | 0.12 | 95.06 | 0 | 27.8 | |
| 03/12/2024 21:00 | 34.25 | 0.13 | 95.6 | 0 | 27.7 | |
| 03/12/2024 22:00 | 31.53 | 0.17 | 95.22 | 0 | 34 | |
| 03/12/2024 23:00 | 2.35 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.85 | 0 | 27.7 | |
| MinDate | 04/12/2024 00:00 | 03/12/2024 00:00 | 03/12/2024 18:00 | 03/12/2024 00:00 | 03/12/2024 21:00 | |
| Maximum | 48.83 | 0.28 | 98.19 | 0 | 43.3 | |
| MaxDate | 03/12/2024 03:00 | 03/12/2024 05:00 | 03/12/2024 06:00 | 03/12/2024 00:00 | 03/12/2024 00:00 | |
| Avg | 38.23 | 0.05 | 96.26 | 0 | 36.3 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.1 | 0.1 | 1.1 | 0 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 03/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 12:00 | 6.61 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 03/12/2024 13:00 | 32.29 | 0.08 | 93.41 | 0 | 35.2 | |
| 03/12/2024 14:00 | 34.42 | 0.33 | 94.26 | 0 | 27.2 | |
| 03/12/2024 15:00 | 34.46 | 0.08 | 93.99 | 0 | 26.8 | |
| 03/12/2024 16:00 | 34.14 | 0.08 | 93.75 | 0 | 26.4 | |
| 03/12/2024 17:00 | 33.54 | 0.08 | 93.48 | 0 | 25.6 | |
| 03/12/2024 18:00 | 33.4 | 0.08 | 93.27 | 0 | 25.3 | |
| 03/12/2024 19:00 | 33.29 | 0.08 | 93.19 | 0 | 25.3 | |
| 03/12/2024 20:00 | 33.84 | 0.08 | 93.45 | 0 | 24.9 | |
| 03/12/2024 21:00 | 34.18 | 0.08 | 93.87 | 0 | 24.8 | |
| 03/12/2024 22:00 | 31.5 | 0.08 | 93.47 | 0 | 31.1 | |
| 03/12/2024 23:00 | 46.7 | 0.08 | 95.52 | 0 | 44.7 | |
| 04/12/2024 00:00 | 48.69 | 0.08 | 95 | 0 | 46.7 | |
| Minimum | 0 | 0.08 | 93.19 | 0 | 24.8 | |
| MinDate | 03/12/2024 00:00 | 03/12/2024 00:00 | 03/12/2024 19:00 | 03/12/2024 13:00 | 03/12/2024 21:00 | |
| Maximum | 48.69 | 0.33 | 95.52 | 0 | 46.7 | |
| MaxDate | 04/12/2024 00:00 | 03/12/2024 14:00 | 03/12/2024 23:00 | 03/12/2024 13:00 | 04/12/2024 00:00 | |
| Avg | 17.48 | 0.09 | 93.89 | 0 | 30.3 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.5 | 0.1 | 0.7 | 0 | 7.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 05:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 08:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 09:00 | 0 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 10:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 11:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 12:00 | 6.29 | 0.6 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 04/12/2024 13:00 | 32.45 | 0.17 | 94.73 | 0 | 38.6 | |
| 04/12/2024 14:00 | 34.56 | 0.18 | 96 | 0 | 30.5 | |
| 04/12/2024 15:00 | 34.57 | 0.21 | 95.72 | 0 | 30 | |
| 04/12/2024 16:00 | 34.01 | 0.2 | 95.18 | 0 | 29.6 | |
| 04/12/2024 17:00 | 33.37 | 0.21 | 94.5 | 0 | 29.2 | |
| 04/12/2024 18:00 | 33.23 | 0.18 | 94.28 | 0 | 28.9 | |
| 04/12/2024 19:00 | 33.3 | 0.15 | 94.35 | 0 | 28.8 | |
| 04/12/2024 20:00 | 33.86 | 0.15 | 94.58 | 0 | 28.8 | |
| 04/12/2024 21:00 | 34.38 | 0.11 | 95.2 | 0 | 28.8 | |
| 04/12/2024 22:00 | 33.88 | 0.13 | 96.13 | 0 | 35.7 | |
| 04/12/2024 23:00 | 24.87 | 0.18 | 92.43 | 0 | 54.4 | |
| 05/12/2024 00:00 | 28.08 | 0.18 | 92.77 | 0 | 51.7 | |
| Minimum | 0 | 0 | 92.43 | 0 | 28.8 | |
| MinDate | 04/12/2024 00:00 | 04/12/2024 00:00 | 04/12/2024 23:00 | 04/12/2024 13:00 | 04/12/2024 19:00 | |
| Maximum | 34.57 | 0.6 | 96.13 | 0 | 54.4 | |
| MaxDate | 04/12/2024 15:00 | 04/12/2024 12:00 | 04/12/2024 22:00 | 04/12/2024 13:00 | 04/12/2024 23:00 | |
| Avg | 15.87 | 0.12 | 94.66 | 0 | 34.6 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.5 | 0.1 | 1.1 | 0 | 9.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 04/12/2024 00:00 | 48.69 | 0.08 | 95 | 0 | 46.7 | |
| 04/12/2024 01:00 | 48.74 | 0.08 | 95.77 | 0 | 47 | |
| 04/12/2024 02:00 | 48.71 | 0.08 | 95.79 | 0 | 47.1 | |
| 04/12/2024 03:00 | 48.76 | 0.08 | 95.58 | 0 | 46.5 | |
| 04/12/2024 04:00 | 47.96 | 0.08 | 95.97 | 0 | 41.3 | |
| 04/12/2024 05:00 | 47.11 | 0.08 | 96.55 | 0 | 37 | |
| 04/12/2024 06:00 | 47.06 | 0.08 | 96.84 | 0 | 36.2 | |
| 04/12/2024 07:00 | 47.24 | 0.08 | 96.63 | 0 | 38.7 | |
| 04/12/2024 08:00 | 48.17 | 0.08 | 95.38 | 0 | 46.6 | |
| 04/12/2024 09:00 | 47.81 | 0.08 | 95.17 | 0 | 46.3 | |
| 04/12/2024 10:00 | 47.38 | 0.08 | 95.22 | 0 | 46.4 | |
| 04/12/2024 11:00 | 46.97 | 0.08 | 94.78 | 0 | 46.1 | |
| 04/12/2024 12:00 | 43.03 | 0.08 | 94.82 | 0 | 43.8 | |
| 04/12/2024 13:00 | 32.38 | 0.08 | 93.26 | 0 | 32.3 | |
| 04/12/2024 14:00 | 34.49 | 0.27 | 94.13 | 0 | 24.5 | |
| 04/12/2024 15:00 | 34.5 | 0.08 | 94.09 | 0 | 24.2 | |
| 04/12/2024 16:00 | 33.94 | 0.08 | 93.66 | 0 | 23.8 | |
| 04/12/2024 17:00 | 33.31 | 0.08 | 93.15 | 0 | 23.5 | |
| 04/12/2024 18:00 | 33.17 | 0.08 | 92.9 | 0 | 23.4 | |
| 04/12/2024 19:00 | 33.24 | 0.08 | 92.92 | 0 | 23.7 | |
| 04/12/2024 20:00 | 33.79 | 0.08 | 93.25 | 0 | 23.4 | |
| 04/12/2024 21:00 | 34.31 | 0.08 | 93.85 | 0 | 23.5 | |
| 04/12/2024 22:00 | 33.81 | 0.08 | 94.57 | 0 | 30.9 | |
| 04/12/2024 23:00 | 24.83 | 0.08 | 91.54 | 0 | 50.7 | |
| 05/12/2024 00:00 | 28 | 0.08 | 92.12 | 0 | 44.2 | |
| Minimum | 24.83 | 0.08 | 91.54 | 0 | 23.4 | |
| MinDate | 04/12/2024 23:00 | 04/12/2024 00:00 | 04/12/2024 23:00 | 04/12/2024 00:00 | 04/12/2024 18:00 | |
| Maximum | 48.76 | 0.27 | 96.84 | 0 | 50.7 | |
| MaxDate | 04/12/2024 03:00 | 04/12/2024 14:00 | 04/12/2024 06:00 | 04/12/2024 00:00 | 04/12/2024 23:00 | |
| Avg | 40.3 | 0.09 | 94.52 | 0 | 36.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8 | 0 | 1.4 | 0 | 10.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/12/2024 00:00 | 28.08 | 0.18 | 92.77 | 0 | 51.7 | |
| 05/12/2024 01:00 | 28.68 | 0.17 | 92.93 | 0 | 49.6 | |
| 05/12/2024 02:00 | 28.7 | 0.12 | 92.76 | 0 | 49.1 | |
| 05/12/2024 03:00 | 28.46 | 0.08 | 92.59 | 0 | 49.7 | |
| 05/12/2024 04:00 | 27.82 | 0.06 | 92.23 | 0 | 52.2 | |
| 05/12/2024 05:00 | 27.3 | 0.2 | 92.02 | 0 | 54.4 | |
| 05/12/2024 06:00 | 27.18 | 0 | 91.95 | 0 | 54.9 | |
| 05/12/2024 07:00 | 27.2 | 0 | 91.96 | 0 | 55 | |
| 05/12/2024 08:00 | 27.22 | 0 | 92.07 | 0 | 54.7 | |
| 05/12/2024 09:00 | 27.27 | 0.05 | 92.23 | 0 | 53.3 | |
| 05/12/2024 10:00 | 27.35 | 0.14 | 92.72 | 0 | 51.5 | |
| 05/12/2024 11:00 | 27.35 | 0.26 | 93.16 | 0 | 50.7 | |
| 05/12/2024 12:00 | 27.33 | 0.37 | 93.42 | 0 | 49.5 | |
| 05/12/2024 13:00 | 27.39 | 0.33 | 93.56 | 0 | 49.3 | |
| 05/12/2024 14:00 | 27.39 | 0.31 | 93.51 | 0 | 48.8 | |
| 05/12/2024 15:00 | 27.42 | 0.24 | 93.08 | 0 | 48 | |
| 05/12/2024 16:00 | 27.48 | 0.13 | 92.68 | 0 | 48 | |
| 05/12/2024 17:00 | 27.42 | 0.11 | 92.47 | 0 | 48.6 | |
| 05/12/2024 18:00 | 41.25 | 0.01 | 98.56 | 0 | 31.5 | |
| 05/12/2024 19:00 | 41.21 | 0.02 | 100.26 | 0 | 30.2 | |
| 05/12/2024 20:00 | 41.19 | 0 | 100.05 | 0 | 30.7 | |
| 05/12/2024 21:00 | 39.39 | 0.01 | 98.63 | 0 | 35.2 | |
| 05/12/2024 22:00 | 47.69 | 0 | 96.73 | 0 | 39.7 | |
| 05/12/2024 23:00 | 48.15 | 0 | 96.23 | 0 | 39.9 | |
| 06/12/2024 00:00 | 48.33 | 0 | 96.82 | 0 | 40 | |
| Minimum | 27.18 | 0 | 91.95 | 0 | 30.2 | |
| MinDate | 05/12/2024 06:00 | 05/12/2024 06:00 | 05/12/2024 06:00 | 05/12/2024 00:00 | 05/12/2024 19:00 | |
| Maximum | 48.33 | 0.37 | 100.26 | 0 | 55 | |
| MaxDate | 06/12/2024 00:00 | 05/12/2024 12:00 | 05/12/2024 19:00 | 05/12/2024 00:00 | 05/12/2024 07:00 | |
| Avg | 32.17 | 0.11 | 94.22 | 0 | 46.6 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.7 | 0.1 | 2.7 | 0 | 7.8 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 05/12/2024 00:00 | 28 | 0.08 | 92.12 | 0 | 44.2 | |
| 05/12/2024 01:00 | 28.62 | 0.08 | 92.25 | 0 | 42.5 | |
| 05/12/2024 02:00 | 28.63 | 0.08 | 92.16 | 0 | 42.2 | |
| 05/12/2024 03:00 | 28.4 | 0.08 | 91.98 | 0 | 42.7 | |
| 05/12/2024 04:00 | 27.76 | 0.08 | 91.59 | 0 | 44.9 | |
| 05/12/2024 05:00 | 27.24 | 0.08 | 91.47 | 0 | 46.4 | |
| 05/12/2024 06:00 | 27.12 | 0.08 | 91.53 | 0 | 46.7 | |
| 05/12/2024 07:00 | 27.14 | 0.08 | 91.52 | 0 | 46.7 | |
| 05/12/2024 08:00 | 27.16 | 0.08 | 91.44 | 0 | 46.6 | |
| 05/12/2024 09:00 | 27.22 | 0.08 | 91.75 | 0 | 45.3 | |
| 05/12/2024 10:00 | 27.29 | 0.08 | 92.23 | 0 | 44 | |
| 05/12/2024 11:00 | 27.3 | 0.08 | 92.61 | 0 | 43.5 | |
| 05/12/2024 12:00 | 27.27 | 0.08 | 92.88 | 0 | 42.5 | |
| 05/12/2024 13:00 | 27.33 | 0.08 | 92.91 | 0 | 42.4 | |
| 05/12/2024 14:00 | 27.33 | 0.45 | 92.88 | 0 | 41.8 | |
| 05/12/2024 15:00 | 27.37 | 0.08 | 92.62 | 0 | 41.4 | |
| 05/12/2024 16:00 | 27.41 | 0.08 | 92.19 | 0 | 41.3 | |
| 05/12/2024 17:00 | 27.34 | 0.08 | 91.97 | 0 | 41.9 | |
| 05/12/2024 18:00 | 41.17 | 0.08 | 97.49 | 0 | 27.4 | |
| 05/12/2024 19:00 | 41.14 | 0.08 | 98.64 | 0 | 25.5 | |
| 05/12/2024 20:00 | 41.11 | 0.08 | 98.44 | 0 | 25.8 | |
| 05/12/2024 21:00 | 29.43 | 0.08 | 96.48 | 0 | 33.8 | |
| 05/12/2024 22:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 05/12/2024 23:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 91.44 | 0 | 25.5 | |
| MinDate | 05/12/2024 22:00 | 05/12/2024 00:00 | 05/12/2024 08:00 | 05/12/2024 00:00 | 05/12/2024 19:00 | |
| Maximum | 41.17 | 0.45 | 98.64 | 0 | 46.7 | |
| MaxDate | 05/12/2024 18:00 | 05/12/2024 14:00 | 05/12/2024 19:00 | 05/12/2024 00:00 | 05/12/2024 06:00 | |
| Avg | 25.95 | 0.09 | 93.14 | 0 | 40.9 | |
| Num | 25 | 25 | 22 | 22 | 22 | |
| Data[%] | 100 | 100 | 88 | 88 | 88 | |
| STD | 10.8 | 0.1 | 2.3 | 0 | 6.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/12/2024 00:00 | 48.33 | 0 | 96.82 | 0 | 40 | |
| 06/12/2024 01:00 | 48.38 | 0 | 96.67 | 0 | 39.9 | |
| 06/12/2024 02:00 | 48.43 | 0 | 96.59 | 0 | 40 | |
| 06/12/2024 03:00 | 48.58 | 0 | 96.67 | 0 | 40.2 | |
| 06/12/2024 04:00 | 48.65 | 0 | 96.75 | 0 | 40.1 | |
| 06/12/2024 05:00 | 48.72 | 0.4 | 96.61 | 0 | 39.9 | |
| 06/12/2024 06:00 | 48.85 | 0 | 96.6 | 0 | 39.8 | |
| 06/12/2024 07:00 | 48.61 | 0 | 96.49 | 0 | 39.6 | |
| 06/12/2024 08:00 | 48.15 | 0 | 96.4 | 0 | 39.3 | |
| 06/12/2024 09:00 | 47.6 | 0 | 96.3 | 0 | 39.1 | |
| 06/12/2024 10:00 | 46.84 | 0.01 | 96.43 | 0 | 39 | |
| 06/12/2024 11:00 | 46.59 | 0.1 | 96.67 | 0 | 38.7 | |
| 06/12/2024 12:00 | 42.38 | 0.24 | 97.23 | 0 | 39.6 | |
| 06/12/2024 13:00 | 32.39 | 0.34 | 95.52 | 0 | 34.5 | |
| 06/12/2024 14:00 | 34.46 | 0.27 | 96.35 | 0 | 26.6 | |
| 06/12/2024 15:00 | 34.46 | 0.21 | 96 | 0 | 26.4 | |
| 06/12/2024 16:00 | 34.01 | 0.13 | 95.47 | 0 | 26 | |
| 06/12/2024 17:00 | 33.5 | 0.11 | 94.98 | 0 | 25.5 | |
| 06/12/2024 18:00 | 33.36 | 0.11 | 94.76 | 0 | 25.3 | |
| 06/12/2024 19:00 | 33.35 | 0.16 | 94.89 | 0 | 25.2 | |
| 06/12/2024 20:00 | 33.94 | 0.22 | 95.21 | 0 | 25.3 | |
| 06/12/2024 21:00 | 34.3 | 0.3 | 95.8 | 0 | 25.3 | |
| 06/12/2024 22:00 | 34.06 | 0.24 | 96.69 | 0 | 33.4 | |
| 06/12/2024 23:00 | 26.12 | 0.19 | 93.14 | 0 | 49.9 | |
| 07/12/2024 00:00 | 28.63 | 0.09 | 93.32 | 0 | 46.4 | |
| Minimum | 26.12 | 0 | 93.14 | 0 | 25.2 | |
| MinDate | 06/12/2024 23:00 | 06/12/2024 00:00 | 06/12/2024 23:00 | 06/12/2024 00:00 | 06/12/2024 19:00 | |
| Maximum | 48.85 | 0.4 | 97.23 | 0 | 49.9 | |
| MaxDate | 06/12/2024 06:00 | 06/12/2024 05:00 | 06/12/2024 12:00 | 06/12/2024 00:00 | 06/12/2024 23:00 | |
| Avg | 40.51 | 0.12 | 95.93 | 0 | 35.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.9 | 0.1 | 1.1 | 0 | 7.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 06/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 12:00 | 7.26 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 06/12/2024 13:00 | 32.33 | 0.08 | 93.51 | 0 | 34.4 | |
| 06/12/2024 14:00 | 34.4 | 0.4 | 94.39 | 0 | 27 | |
| 06/12/2024 15:00 | 34.39 | 0.08 | 94.12 | 0 | 26.5 | |
| 06/12/2024 16:00 | 33.94 | 0.08 | 93.58 | 0 | 26 | |
| 06/12/2024 17:00 | 33.44 | 0.08 | 93.13 | 0 | 25.4 | |
| 06/12/2024 18:00 | 33.3 | 0.08 | 93 | 0 | 25.1 | |
| 06/12/2024 19:00 | 33.28 | 0.08 | 93.18 | 0 | 25.3 | |
| 06/12/2024 20:00 | 33.87 | 0.08 | 93.42 | 0 | 25.2 | |
| 06/12/2024 21:00 | 34.22 | 0.08 | 93.84 | 0 | 25.1 | |
| 06/12/2024 22:00 | 33.99 | 0.08 | 94.61 | 0 | 33.1 | |
| 06/12/2024 23:00 | 26.06 | 0.08 | 91.45 | 0 | 49.9 | |
| 07/12/2024 00:00 | 28.56 | 0.08 | 91.75 | 0 | 44.8 | |
| Minimum | 0 | 0.08 | 91.45 | 0 | 25.1 | |
| MinDate | 06/12/2024 00:00 | 06/12/2024 00:00 | 06/12/2024 23:00 | 06/12/2024 13:00 | 06/12/2024 18:00 | |
| Maximum | 34.4 | 0.4 | 94.61 | 0 | 49.9 | |
| MaxDate | 06/12/2024 14:00 | 06/12/2024 14:00 | 06/12/2024 22:00 | 06/12/2024 13:00 | 06/12/2024 23:00 | |
| Avg | 15.96 | 0.09 | 93.33 | 0 | 30.7 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.5 | 0.1 | 1 | 0 | 8.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/12/2024 00:00 | 28.63 | 0.09 | 93.32 | 0 | 46.4 | |
| 07/12/2024 01:00 | 28.84 | 0.08 | 93.4 | 0 | 45 | |
| 07/12/2024 02:00 | 28.89 | 0.04 | 93.49 | 0 | 44.5 | |
| 07/12/2024 03:00 | 28.77 | 0.07 | 93.77 | 0 | 44.4 | |
| 07/12/2024 04:00 | 28.18 | 0.1 | 93.64 | 0 | 46.4 | |
| 07/12/2024 05:00 | 27.65 | 0.37 | 93.5 | 0 | 48.7 | |
| 07/12/2024 06:00 | 27.59 | 0 | 93.22 | 0 | 49.1 | |
| 07/12/2024 07:00 | 27.68 | 0 | 93.36 | 0 | 48.7 | |
| 07/12/2024 08:00 | 28.6 | 0 | 93.66 | 0 | 44.1 | |
| 07/12/2024 09:00 | 28.9 | 0.03 | 93.71 | 0 | 41.9 | |
| 07/12/2024 10:00 | 29 | 0.08 | 93.99 | 0 | 40.2 | |
| 07/12/2024 11:00 | 29.03 | 0.14 | 94.29 | 0 | 39.1 | |
| 07/12/2024 12:00 | 28.95 | 0.17 | 94.3 | 0 | 38.9 | |
| 07/12/2024 13:00 | 39.37 | 0.12 | 98.73 | 0 | 31.5 | |
| 07/12/2024 14:00 | 42.96 | 0.08 | 102.8 | 0 | 28.1 | |
| 07/12/2024 15:00 | 42.88 | 0.11 | 102.63 | 0 | 27.9 | |
| 07/12/2024 16:00 | 42.27 | 0.14 | 102.09 | 0 | 27.6 | |
| 07/12/2024 17:00 | 41.66 | 0.12 | 101.32 | 0 | 26.8 | |
| 07/12/2024 18:00 | 41.63 | 0.23 | 101.19 | 0 | 26.6 | |
| 07/12/2024 19:00 | 41.64 | 0.26 | 101.23 | 0 | 26.3 | |
| 07/12/2024 20:00 | 42.46 | 0.14 | 101.64 | 0 | 26.4 | |
| 07/12/2024 21:00 | 42.74 | 0 | 101.97 | 0 | 26.5 | |
| 07/12/2024 22:00 | 39.18 | 0.03 | 101.02 | 0 | 30.1 | |
| 07/12/2024 23:00 | 28.81 | 0.02 | 94.49 | 0 | 41 | |
| 08/12/2024 00:00 | 28.68 | 0.04 | 93.81 | 0 | 41.3 | |
| Minimum | 27.59 | 0 | 93.22 | 0 | 26.3 | |
| MinDate | 07/12/2024 06:00 | 07/12/2024 06:00 | 07/12/2024 06:00 | 07/12/2024 00:00 | 07/12/2024 19:00 | |
| Maximum | 42.96 | 0.37 | 102.8 | 0 | 49.1 | |
| MaxDate | 07/12/2024 14:00 | 07/12/2024 05:00 | 07/12/2024 14:00 | 07/12/2024 00:00 | 07/12/2024 06:00 | |
| Avg | 33.8 | 0.1 | 96.82 | 0 | 37.5 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.6 | 0.1 | 3.9 | 0 | 8.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 07/12/2024 00:00 | 28.56 | 0.08 | 91.75 | 0 | 44.8 | |
| 07/12/2024 01:00 | 28.78 | 0.08 | 91.9 | 0 | 43.5 | |
| 07/12/2024 02:00 | 28.83 | 0.08 | 92.05 | 0 | 43.1 | |
| 07/12/2024 03:00 | 28.71 | 0.08 | 92.21 | 0 | 43.1 | |
| 07/12/2024 04:00 | 28.11 | 0.08 | 92.18 | 0 | 44.3 | |
| 07/12/2024 05:00 | 27.59 | 0.08 | 91.84 | 0 | 46 | |
| 07/12/2024 06:00 | 27.52 | 0.08 | 91.66 | 0 | 46.2 | |
| 07/12/2024 07:00 | 27.62 | 0.08 | 91.7 | 0 | 46.4 | |
| 07/12/2024 08:00 | 28.54 | 0.08 | 92 | 0 | 43.6 | |
| 07/12/2024 09:00 | 28.84 | 0.08 | 92.13 | 0 | 41.6 | |
| 07/12/2024 10:00 | 28.93 | 0.08 | 92.45 | 0 | 40.1 | |
| 07/12/2024 11:00 | 28.97 | 0.08 | 92.64 | 0 | 39.3 | |
| 07/12/2024 12:00 | 28.88 | 0.08 | 92.57 | 0 | 39.1 | |
| 07/12/2024 13:00 | 39.33 | 0.08 | 96.9 | 0 | 35 | |
| 07/12/2024 14:00 | 42.89 | 0.33 | 100.64 | 0 | 32.5 | |
| 07/12/2024 15:00 | 42.81 | 0.08 | 100.62 | 0 | 32.1 | |
| 07/12/2024 16:00 | 42.2 | 0.08 | 100.07 | 0 | 30.5 | |
| 07/12/2024 17:00 | 41.59 | 0.08 | 99.32 | 0 | 28.1 | |
| 07/12/2024 18:00 | 41.55 | 0.08 | 99.21 | 0 | 27.6 | |
| 07/12/2024 19:00 | 41.57 | 0.08 | 99.32 | 0 | 27.1 | |
| 07/12/2024 20:00 | 42.39 | 0.08 | 99.75 | 0 | 28 | |
| 07/12/2024 21:00 | 42.67 | 0.08 | 99.97 | 0 | 28.3 | |
| 07/12/2024 22:00 | 39.11 | 0.08 | 98.98 | 0 | 31.8 | |
| 07/12/2024 23:00 | 28.75 | 0.08 | 92.94 | 0 | 40.5 | |
| 08/12/2024 00:00 | 28.61 | 0.08 | 92.34 | 0 | 40.7 | |
| Minimum | 27.52 | 0.08 | 91.66 | 0 | 27.1 | |
| MinDate | 07/12/2024 06:00 | 07/12/2024 00:00 | 07/12/2024 06:00 | 07/12/2024 00:00 | 07/12/2024 19:00 | |
| Maximum | 42.89 | 0.33 | 100.64 | 0 | 46.4 | |
| MaxDate | 07/12/2024 14:00 | 07/12/2024 14:00 | 07/12/2024 14:00 | 07/12/2024 00:00 | 07/12/2024 07:00 | |
| Avg | 33.73 | 0.09 | 95.09 | 0 | 37.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.6 | 0.1 | 3.7 | 0 | 6.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/12/2024 00:00 | 28.68 | 0.04 | 93.81 | 0 | 41.3 | |
| 08/12/2024 01:00 | 28.74 | 0.03 | 93.8 | 0 | 41 | |
| 08/12/2024 02:00 | 28.63 | 0.01 | 93.74 | 0 | 41 | |
| 08/12/2024 03:00 | 28.45 | 0 | 93.76 | 0 | 41.1 | |
| 08/12/2024 04:00 | 27.79 | 0.03 | 93.55 | 0 | 43.4 | |
| 08/12/2024 05:00 | 27.36 | 0.24 | 93 | 0 | 45.5 | |
| 08/12/2024 06:00 | 27.27 | 0 | 92.82 | 0 | 46.5 | |
| 08/12/2024 07:00 | 27.1 | 0 | 92.74 | 0 | 47.5 | |
| 08/12/2024 08:00 | 27.14 | 0 | 92.62 | 0 | 47.7 | |
| 08/12/2024 09:00 | 27.14 | 0 | 92.53 | 0 | 47.7 | |
| 08/12/2024 10:00 | 27.11 | 0 | 92.54 | 0 | 47.3 | |
| 08/12/2024 11:00 | 27.1 | 0 | 92.66 | 0 | 47.3 | |
| 08/12/2024 12:00 | 27.12 | 0 | 92.83 | 0 | 46.4 | |
| 08/12/2024 13:00 | 27.18 | 0.03 | 92.8 | 0 | 45.3 | |
| 08/12/2024 14:00 | 27.18 | 0 | 92.94 | 0 | 44.6 | |
| 08/12/2024 15:00 | 27.18 | 0.02 | 93.01 | 0 | 44 | |
| 08/12/2024 16:00 | 27.19 | 0.04 | 93.02 | 0 | 44.1 | |
| 08/12/2024 17:00 | 27.16 | 0.06 | 92.96 | 0 | 45 | |
| 08/12/2024 18:00 | 40.98 | 0 | 98.85 | 0 | 26.3 | |
| 08/12/2024 19:00 | 41.01 | 0 | 100.13 | 0 | 25.7 | |
| 08/12/2024 20:00 | 41.06 | 0 | 100.08 | 0 | 25.8 | |
| 08/12/2024 21:00 | 29.2 | 0.07 | 98.48 | 0 | 34.8 | |
| 08/12/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 08/12/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 92.53 | 0 | 25.7 | |
| MinDate | 08/12/2024 22:00 | 08/12/2024 03:00 | 08/12/2024 09:00 | 08/12/2024 00:00 | 08/12/2024 19:00 | |
| Maximum | 41.06 | 0.24 | 100.13 | 0 | 47.7 | |
| MaxDate | 08/12/2024 20:00 | 08/12/2024 05:00 | 08/12/2024 19:00 | 08/12/2024 00:00 | 08/12/2024 08:00 | |
| Avg | 25.91 | 0.02 | 94.21 | 0 | 41.8 | |
| Num | 25 | 25 | 22 | 22 | 22 | |
| Data[%] | 100 | 100 | 88 | 88 | 88 | |
| STD | 10.7 | 0 | 2.5 | 0 | 7.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 08/12/2024 00:00 | 28.61 | 0.08 | 92.34 | 0 | 40.7 | |
| 08/12/2024 01:00 | 28.67 | 0.08 | 92.21 | 0 | 40.3 | |
| 08/12/2024 02:00 | 28.57 | 0.08 | 92.07 | 0 | 40.2 | |
| 08/12/2024 03:00 | 28.39 | 0.08 | 92.14 | 0 | 40.5 | |
| 08/12/2024 04:00 | 27.72 | 0.08 | 91.94 | 0 | 42.1 | |
| 08/12/2024 05:00 | 27.3 | 0.08 | 91.36 | 0 | 43.5 | |
| 08/12/2024 06:00 | 27.2 | 0.08 | 91.39 | 0 | 44.3 | |
| 08/12/2024 07:00 | 27.03 | 0.08 | 91.23 | 0 | 45 | |
| 08/12/2024 08:00 | 27.07 | 0.08 | 91.07 | 0 | 45.3 | |
| 08/12/2024 09:00 | 27.09 | 0.08 | 91.02 | 0 | 45.3 | |
| 08/12/2024 10:00 | 27.05 | 0.08 | 91.17 | 0 | 45.2 | |
| 08/12/2024 11:00 | 27.04 | 0.08 | 91.11 | 0 | 45.1 | |
| 08/12/2024 12:00 | 27.06 | 0.08 | 91.3 | 0 | 44.1 | |
| 08/12/2024 13:00 | 27.11 | 0.08 | 91.31 | 0 | 43.6 | |
| 08/12/2024 14:00 | 27.12 | 0.27 | 91.32 | 0 | 43.1 | |
| 08/12/2024 15:00 | 27.12 | 0.08 | 91.48 | 0 | 42.5 | |
| 08/12/2024 16:00 | 27.12 | 0.08 | 91.45 | 0 | 43 | |
| 08/12/2024 17:00 | 27.1 | 0.08 | 91.46 | 0 | 43.6 | |
| 08/12/2024 18:00 | 40.91 | 0.08 | 97.07 | 0 | 27 | |
| 08/12/2024 19:00 | 40.93 | 0.08 | 98.14 | 0 | 26.2 | |
| 08/12/2024 20:00 | 40.99 | 0.08 | 98.08 | 0 | 26.2 | |
| 08/12/2024 21:00 | 39.48 | 0.08 | 96.95 | 0 | 32 | |
| 08/12/2024 22:00 | 48.57 | 0.08 | 96.09 | 0 | 42.9 | |
| 08/12/2024 23:00 | 48.66 | 0.08 | 95.1 | 0 | 43.2 | |
| 09/12/2024 00:00 | 48.77 | 0.08 | 95.39 | 0 | 43.4 | |
| Minimum | 27.03 | 0.08 | 91.02 | 0 | 26.2 | |
| MinDate | 08/12/2024 07:00 | 08/12/2024 00:00 | 08/12/2024 09:00 | 08/12/2024 00:00 | 08/12/2024 19:00 | |
| Maximum | 48.77 | 0.27 | 98.14 | 0 | 45.3 | |
| MaxDate | 09/12/2024 00:00 | 08/12/2024 14:00 | 08/12/2024 19:00 | 08/12/2024 00:00 | 08/12/2024 08:00 | |
| Avg | 32.11 | 0.09 | 92.97 | 0 | 40.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.9 | 0 | 2.5 | 0 | 6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 05:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 08:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 09:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 10:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 11:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 12:00 | 5.18 | 0.66 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 09/12/2024 13:00 | 32.18 | 0.28 | 94.19 | 0 | 39.5 | |
| 09/12/2024 14:00 | 34.45 | 0.3 | 95.51 | 0 | 30.9 | |
| 09/12/2024 15:00 | 34.42 | 0.3 | 95.24 | 0 | 30.4 | |
| 09/12/2024 16:00 | 33.98 | 0.28 | 94.78 | 0 | 30 | |
| 09/12/2024 17:00 | 33.43 | 0.28 | 94.19 | 0 | 29.3 | |
| 09/12/2024 18:00 | 33.27 | 0.24 | 93.87 | 0 | 29.1 | |
| 09/12/2024 19:00 | 33.24 | 0.2 | 93.87 | 0 | 29 | |
| 09/12/2024 20:00 | 33.92 | 0.15 | 94.14 | 0 | 29.1 | |
| 09/12/2024 21:00 | 34.21 | 0.14 | 94.68 | 0 | 29.1 | |
| 09/12/2024 22:00 | 33.83 | 0.18 | 95.36 | 0 | 37.4 | |
| 09/12/2024 23:00 | 26.05 | 0.2 | 91.82 | 0 | 54.7 | |
| 10/12/2024 00:00 | 28.45 | 0.2 | 92.11 | 0 | 52 | |
| Minimum | 0 | 0 | 91.82 | 0 | 29 | |
| MinDate | 09/12/2024 00:00 | 09/12/2024 00:00 | 09/12/2024 23:00 | 09/12/2024 13:00 | 09/12/2024 19:00 | |
| Maximum | 34.45 | 0.66 | 95.51 | 0 | 54.7 | |
| MaxDate | 09/12/2024 14:00 | 09/12/2024 12:00 | 09/12/2024 14:00 | 09/12/2024 13:00 | 09/12/2024 23:00 | |
| Avg | 15.86 | 0.15 | 94.15 | 0 | 35 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.6 | 0.2 | 1.2 | 0 | 9.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 09/12/2024 00:00 | 48.77 | 0.08 | 95.39 | 0 | 43.4 | |
| 09/12/2024 01:00 | 48.72 | 0.08 | 95.33 | 0 | 43.2 | |
| 09/12/2024 02:00 | 48.88 | 0.08 | 95.24 | 0 | 43.1 | |
| 09/12/2024 03:00 | 48.95 | 0.08 | 95.27 | 0 | 42.7 | |
| 09/12/2024 04:00 | 48.98 | 0.08 | 95.24 | 0 | 42.2 | |
| 09/12/2024 05:00 | 49.01 | 0.08 | 95.33 | 0 | 41.9 | |
| 09/12/2024 06:00 | 49.02 | 0.08 | 95.32 | 0 | 41.6 | |
| 09/12/2024 07:00 | 49.01 | 0.08 | 95.63 | 0 | 41.7 | |
| 09/12/2024 08:00 | 48.94 | 0.08 | 95.62 | 0 | 41.9 | |
| 09/12/2024 09:00 | 48.68 | 0.08 | 95.33 | 0 | 41.2 | |
| 09/12/2024 10:00 | 48.61 | 0.08 | 95.86 | 0 | 42.1 | |
| 09/12/2024 11:00 | 47.88 | 0.08 | 95.28 | 0 | 41.3 | |
| 09/12/2024 12:00 | 44.35 | 0.08 | 95.38 | 0 | 36.9 | |
| 09/12/2024 13:00 | 32.14 | 0.08 | 93.25 | 0 | 29.9 | |
| 09/12/2024 14:00 | 34.39 | 0.44 | 94.1 | 0 | 21.4 | |
| 09/12/2024 15:00 | 34.35 | 0.08 | 94.05 | 0 | 21.1 | |
| 09/12/2024 16:00 | 33.92 | 0.08 | 93.64 | 0 | 20.9 | |
| 09/12/2024 17:00 | 33.36 | 0.08 | 93.15 | 0 | 20.7 | |
| 09/12/2024 18:00 | 33.21 | 0.08 | 92.91 | 0 | 21.9 | |
| 09/12/2024 19:00 | 33.18 | 0.08 | 92.79 | 0 | 22.9 | |
| 09/12/2024 20:00 | 33.86 | 0.08 | 93.05 | 0 | 20.6 | |
| 09/12/2024 21:00 | 34.14 | 0.08 | 93.42 | 0 | 20.5 | |
| 09/12/2024 22:00 | 33.75 | 0.08 | 93.85 | 0 | 29.2 | |
| 09/12/2024 23:00 | 25.99 | 0.08 | 90.86 | 0 | 47.4 | |
| 10/12/2024 00:00 | 28.39 | 0.08 | 91.14 | 0 | 41.2 | |
| Minimum | 25.99 | 0.08 | 90.86 | 0 | 20.5 | |
| MinDate | 09/12/2024 23:00 | 09/12/2024 00:00 | 09/12/2024 23:00 | 09/12/2024 00:00 | 09/12/2024 21:00 | |
| Maximum | 49.02 | 0.44 | 95.86 | 0 | 47.4 | |
| MaxDate | 09/12/2024 06:00 | 09/12/2024 14:00 | 09/12/2024 10:00 | 09/12/2024 00:00 | 09/12/2024 23:00 | |
| Avg | 40.82 | 0.09 | 94.26 | 0 | 34.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8.3 | 0.1 | 1.4 | 0 | 10 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/12/2024 00:00 | 28.45 | 0.2 | 92.11 | 0 | 52 | |
| 10/12/2024 01:00 | 28.69 | 0.2 | 92.51 | 0 | 51.1 | |
| 10/12/2024 02:00 | 28.73 | 0.17 | 92.46 | 0 | 51 | |
| 10/12/2024 03:00 | 28.57 | 0.14 | 92.37 | 0 | 51.9 | |
| 10/12/2024 04:00 | 28.02 | 0.19 | 92.34 | 0 | 53.7 | |
| 10/12/2024 05:00 | 27.57 | 0.43 | 92.16 | 0 | 55.6 | |
| 10/12/2024 06:00 | 27.48 | 0 | 92.08 | 0 | 56.1 | |
| 10/12/2024 07:00 | 27.53 | 0 | 92.14 | 0 | 55.7 | |
| 10/12/2024 08:00 | 28.06 | 0.03 | 92.4 | 0 | 53.5 | |
| 10/12/2024 09:00 | 28.54 | 0.12 | 92.99 | 0 | 51.2 | |
| 10/12/2024 10:00 | 28.82 | 0.23 | 93.48 | 0 | 49.8 | |
| 10/12/2024 11:00 | 28.86 | 0.39 | 93.83 | 0 | 49.1 | |
| 10/12/2024 12:00 | 28.77 | 0.4 | 93.9 | 0 | 48.7 | |
| 10/12/2024 13:00 | 39.26 | 0.29 | 98.25 | 0 | 39 | |
| 10/12/2024 14:00 | 42.83 | 0.28 | 101.98 | 0 | 34.3 | |
| 10/12/2024 15:00 | 42.81 | 0.23 | 102.04 | 0 | 34.1 | |
| 10/12/2024 16:00 | 42.51 | 0.16 | 101.63 | 0 | 33.1 | |
| 10/12/2024 17:00 | 42.06 | 0.26 | 100.72 | 0 | 32.4 | |
| 10/12/2024 18:00 | 41.85 | 0.23 | 100.13 | 0 | 31.6 | |
| 10/12/2024 19:00 | 41.79 | 0.23 | 100.22 | 0 | 31.4 | |
| 10/12/2024 20:00 | 42.39 | 0.21 | 100.69 | 0 | 31.4 | |
| 10/12/2024 21:00 | 42.66 | 0.19 | 101.3 | 0 | 31.5 | |
| 10/12/2024 22:00 | 39.62 | 0.15 | 100.44 | 0 | 35.2 | |
| 10/12/2024 23:00 | 48.02 | 0.06 | 97.83 | 0 | 39.3 | |
| 11/12/2024 00:00 | 48.51 | 0.06 | 96.2 | 0 | 39.9 | |
| Minimum | 27.48 | 0 | 92.08 | 0 | 31.4 | |
| MinDate | 10/12/2024 06:00 | 10/12/2024 06:00 | 10/12/2024 06:00 | 10/12/2024 00:00 | 10/12/2024 19:00 | |
| Maximum | 48.51 | 0.43 | 102.04 | 0 | 56.1 | |
| MaxDate | 11/12/2024 00:00 | 10/12/2024 05:00 | 10/12/2024 15:00 | 10/12/2024 00:00 | 10/12/2024 06:00 | |
| Avg | 35.3 | 0.19 | 96.25 | 0 | 43.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.7 | 0.1 | 4 | 0 | 9.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 10/12/2024 00:00 | 28.39 | 0.08 | 91.14 | 0 | 41.2 | |
| 10/12/2024 01:00 | 28.63 | 0.08 | 91.61 | 0 | 40.4 | |
| 10/12/2024 02:00 | 28.67 | 0.08 | 91.48 | 0 | 40.5 | |
| 10/12/2024 03:00 | 28.51 | 0.08 | 91.47 | 0 | 41.4 | |
| 10/12/2024 04:00 | 27.96 | 0.08 | 91.47 | 0 | 42.9 | |
| 10/12/2024 05:00 | 27.51 | 0.08 | 91.25 | 0 | 44.4 | |
| 10/12/2024 06:00 | 27.42 | 0.08 | 91.19 | 0 | 44.8 | |
| 10/12/2024 07:00 | 27.47 | 0.08 | 91.26 | 0 | 44.4 | |
| 10/12/2024 08:00 | 28 | 0.08 | 91.68 | 0 | 42.2 | |
| 10/12/2024 09:00 | 28.48 | 0.08 | 92.21 | 0 | 39.6 | |
| 10/12/2024 10:00 | 28.75 | 0.08 | 92.6 | 0 | 38.1 | |
| 10/12/2024 11:00 | 28.79 | 0.08 | 92.87 | 0 | 37.7 | |
| 10/12/2024 12:00 | 28.71 | 0.08 | 92.81 | 0 | 37.3 | |
| 10/12/2024 13:00 | 39.22 | 0.08 | 96.97 | 0 | 31.1 | |
| 10/12/2024 14:00 | 42.75 | 0.38 | 100.28 | 0 | 27.2 | |
| 10/12/2024 15:00 | 42.74 | 0.08 | 100.31 | 0 | 26.8 | |
| 10/12/2024 16:00 | 42.44 | 0.08 | 99.73 | 0 | 25.3 | |
| 10/12/2024 17:00 | 41.97 | 0.08 | 98.85 | 0 | 24 | |
| 10/12/2024 18:00 | 41.78 | 0.08 | 98.47 | 0 | 23 | |
| 10/12/2024 19:00 | 41.72 | 0.08 | 98.56 | 0 | 22.8 | |
| 10/12/2024 20:00 | 42.31 | 0.08 | 99.14 | 0 | 23.4 | |
| 10/12/2024 21:00 | 42.59 | 0.08 | 99.64 | 0 | 23.6 | |
| 10/12/2024 22:00 | 38.63 | 0.08 | 98.6 | 0 | 28.7 | |
| 10/12/2024 23:00 | 2.63 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 91.14 | 0 | 22.8 | |
| MinDate | 11/12/2024 00:00 | 10/12/2024 00:00 | 10/12/2024 00:00 | 10/12/2024 00:00 | 10/12/2024 19:00 | |
| Maximum | 42.75 | 0.38 | 100.31 | 0 | 44.8 | |
| MaxDate | 10/12/2024 14:00 | 10/12/2024 14:00 | 10/12/2024 15:00 | 10/12/2024 00:00 | 10/12/2024 06:00 | |
| Avg | 31.44 | 0.09 | 94.94 | 0 | 34.4 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 11.2 | 0.1 | 3.8 | 0 | 8.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/12/2024 00:00 | 48.51 | 0.06 | 96.2 | 0 | 39.9 | |
| 11/12/2024 01:00 | 48.56 | 0.08 | 96.83 | 0 | 39.9 | |
| 11/12/2024 02:00 | 48.6 | 0.05 | 97.12 | 0 | 39.8 | |
| 11/12/2024 03:00 | 48.63 | 0.03 | 97.07 | 0 | 39.6 | |
| 11/12/2024 04:00 | 48.72 | 0.03 | 97.06 | 0 | 39.4 | |
| 11/12/2024 05:00 | 48.81 | 0.32 | 97.11 | 0 | 39.4 | |
| 11/12/2024 06:00 | 48.76 | 0 | 97.11 | 0 | 39.4 | |
| 11/12/2024 07:00 | 48.53 | 0 | 96.97 | 0 | 39.4 | |
| 11/12/2024 08:00 | 47.89 | 0 | 96.58 | 0 | 39.1 | |
| 11/12/2024 09:00 | 47.58 | 0 | 96.46 | 0 | 38.6 | |
| 11/12/2024 10:00 | 47.19 | 0 | 96.57 | 0 | 38.5 | |
| 11/12/2024 11:00 | 46.76 | 0 | 96.46 | 0 | 38.5 | |
| 11/12/2024 12:00 | 42.75 | 0 | 96.99 | 0 | 39.6 | |
| 11/12/2024 13:00 | 32.46 | 0 | 94.96 | 0 | 35.6 | |
| 11/12/2024 14:00 | 34.57 | 0 | 95.9 | 0 | 27.1 | |
| 11/12/2024 15:00 | 34.49 | 0 | 95.71 | 0 | 27 | |
| 11/12/2024 16:00 | 34.11 | 0 | 95.35 | 0 | 26.6 | |
| 11/12/2024 17:00 | 33.66 | 0 | 94.8 | 0 | 26.3 | |
| 11/12/2024 18:00 | 33.5 | 0 | 94.8 | 0 | 26.1 | |
| 11/12/2024 19:00 | 33.56 | 0 | 94.9 | 0 | 26 | |
| 11/12/2024 20:00 | 34.11 | 0 | 95.19 | 0 | 25.8 | |
| 11/12/2024 21:00 | 34.48 | 0 | 95.66 | 0 | 25.8 | |
| 11/12/2024 22:00 | 31.77 | 0 | 95.23 | 0 | 31.7 | |
| 11/12/2024 23:00 | 2.33 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.8 | 0 | 25.8 | |
| MinDate | 12/12/2024 00:00 | 11/12/2024 06:00 | 11/12/2024 17:00 | 11/12/2024 00:00 | 11/12/2024 20:00 | |
| Maximum | 48.81 | 0.32 | 97.12 | 0 | 39.9 | |
| MaxDate | 11/12/2024 05:00 | 11/12/2024 05:00 | 11/12/2024 02:00 | 11/12/2024 00:00 | 11/12/2024 00:00 | |
| Avg | 38.41 | 0.02 | 96.13 | 0 | 34.3 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.2 | 0.1 | 0.9 | 0 | 6.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 11/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 12:00 | 6.82 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 11/12/2024 13:00 | 32.37 | 0.08 | 93.24 | 0 | 35.2 | |
| 11/12/2024 14:00 | 34.5 | 0.31 | 93.98 | 0 | 27.2 | |
| 11/12/2024 15:00 | 34.42 | 0.08 | 93.67 | 0 | 26.9 | |
| 11/12/2024 16:00 | 34.05 | 0.08 | 93.36 | 0 | 26.3 | |
| 11/12/2024 17:00 | 33.59 | 0.08 | 92.93 | 0 | 25.8 | |
| 11/12/2024 18:00 | 33.44 | 0.08 | 92.91 | 0 | 25.5 | |
| 11/12/2024 19:00 | 33.5 | 0.08 | 92.92 | 0 | 25.3 | |
| 11/12/2024 20:00 | 34.04 | 0.08 | 93.15 | 0 | 25.2 | |
| 11/12/2024 21:00 | 34.41 | 0.08 | 93.45 | 0 | 25.4 | |
| 11/12/2024 22:00 | 31.75 | 0.08 | 93.11 | 0 | 31.6 | |
| 11/12/2024 23:00 | 46.1 | 0.08 | 94.85 | 0 | 44.8 | |
| 12/12/2024 00:00 | 47.88 | 0.08 | 94.35 | 0 | 47.2 | |
| Minimum | 0 | 0.08 | 92.91 | 0 | 25.2 | |
| MinDate | 11/12/2024 00:00 | 11/12/2024 00:00 | 11/12/2024 18:00 | 11/12/2024 13:00 | 11/12/2024 20:00 | |
| Maximum | 47.88 | 0.31 | 94.85 | 0 | 47.2 | |
| MaxDate | 12/12/2024 00:00 | 11/12/2024 14:00 | 11/12/2024 23:00 | 11/12/2024 13:00 | 12/12/2024 00:00 | |
| Avg | 17.47 | 0.09 | 93.49 | 0 | 30.5 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.4 | 0 | 0.6 | 0 | 7.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 05:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 11:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 12:00 | 5.74 | 0.46 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 12/12/2024 13:00 | 32.48 | 0.11 | 94.48 | 0 | 37.1 | |
| 12/12/2024 14:00 | 34.64 | 0.05 | 95.76 | 0 | 29.7 | |
| 12/12/2024 15:00 | 34.62 | 0.12 | 95.27 | 0 | 29.4 | |
| 12/12/2024 16:00 | 33.93 | 0.08 | 94.61 | 0 | 28.7 | |
| 12/12/2024 17:00 | 33.61 | 0.04 | 94.4 | 0 | 28.3 | |
| 12/12/2024 18:00 | 33.53 | 0.02 | 94.3 | 0 | 28.2 | |
| 12/12/2024 19:00 | 33.55 | 0.02 | 94.33 | 0 | 28.2 | |
| 12/12/2024 20:00 | 33.94 | 0.05 | 94.59 | 0 | 28.2 | |
| 12/12/2024 21:00 | 34.33 | 0.03 | 95.05 | 0 | 28.3 | |
| 12/12/2024 22:00 | 31.73 | 0.05 | 94.83 | 0 | 34.1 | |
| 12/12/2024 23:00 | 46.11 | 0.01 | 96.42 | 0 | 40.5 | |
| 13/12/2024 00:00 | 47.6 | 0.02 | 95.82 | 0 | 41 | |
| Minimum | 0 | 0 | 94.3 | 0 | 28.2 | |
| MinDate | 12/12/2024 00:00 | 12/12/2024 00:00 | 12/12/2024 18:00 | 12/12/2024 13:00 | 12/12/2024 18:00 | |
| Maximum | 47.6 | 0.46 | 96.42 | 0 | 41 | |
| MaxDate | 13/12/2024 00:00 | 12/12/2024 12:00 | 12/12/2024 23:00 | 12/12/2024 13:00 | 13/12/2024 00:00 | |
| Avg | 17.43 | 0.05 | 94.99 | 0 | 31.8 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.4 | 0.1 | 0.7 | 0 | 5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 12/12/2024 00:00 | 47.88 | 0.08 | 94.35 | 0 | 47.2 | |
| 12/12/2024 01:00 | 47.93 | 0.08 | 94.94 | 0 | 47.2 | |
| 12/12/2024 02:00 | 48.01 | 0.08 | 95.04 | 0 | 46.8 | |
| 12/12/2024 03:00 | 47.93 | 0.08 | 94.85 | 0 | 45.9 | |
| 12/12/2024 04:00 | 48.25 | 0.08 | 94.91 | 0 | 45.9 | |
| 12/12/2024 05:00 | 48.32 | 0.08 | 94.96 | 0 | 45.9 | |
| 12/12/2024 06:00 | 47.58 | 0.08 | 95.21 | 0 | 41.4 | |
| 12/12/2024 07:00 | 47.29 | 0.08 | 95.69 | 0 | 39.7 | |
| 12/12/2024 08:00 | 48.27 | 0.08 | 94.83 | 0 | 45.8 | |
| 12/12/2024 09:00 | 48.03 | 0.08 | 94.53 | 0 | 45.9 | |
| 12/12/2024 10:00 | 47.89 | 0.08 | 94.57 | 0 | 45.6 | |
| 12/12/2024 11:00 | 47.6 | 0.08 | 94.76 | 0 | 45.2 | |
| 12/12/2024 12:00 | 43.92 | 0.08 | 94.88 | 0 | 42 | |
| 12/12/2024 13:00 | 32.41 | 0.08 | 93.18 | 0 | 31.2 | |
| 12/12/2024 14:00 | 34.57 | 0.25 | 93.89 | 0 | 24 | |
| 12/12/2024 15:00 | 34.55 | 0.08 | 93.79 | 0 | 23.7 | |
| 12/12/2024 16:00 | 33.85 | 0.08 | 93.27 | 0 | 23.4 | |
| 12/12/2024 17:00 | 33.54 | 0.08 | 92.96 | 0 | 23.1 | |
| 12/12/2024 18:00 | 33.46 | 0.08 | 92.83 | 0 | 23.1 | |
| 12/12/2024 19:00 | 33.48 | 0.08 | 92.89 | 0 | 23.4 | |
| 12/12/2024 20:00 | 33.88 | 0.08 | 93.19 | 0 | 23 | |
| 12/12/2024 21:00 | 34.26 | 0.08 | 93.54 | 0 | 23.2 | |
| 12/12/2024 22:00 | 31.63 | 0.08 | 93.24 | 0 | 29.5 | |
| 12/12/2024 23:00 | 2.35 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 13/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 92.83 | 0 | 23 | |
| MinDate | 13/12/2024 00:00 | 12/12/2024 00:00 | 12/12/2024 18:00 | 12/12/2024 00:00 | 12/12/2024 20:00 | |
| Maximum | 48.32 | 0.25 | 95.69 | 0 | 47.2 | |
| MaxDate | 12/12/2024 05:00 | 12/12/2024 14:00 | 12/12/2024 07:00 | 12/12/2024 00:00 | 12/12/2024 00:00 | |
| Avg | 38.28 | 0.09 | 94.19 | 0 | 36.2 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.1 | 0 | 0.9 | 0 | 10.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/12/2024 00:00 | 47.6 | 0.02 | 95.82 | 0 | 41 | |
| 13/12/2024 01:00 | 47.74 | 0.01 | 96.33 | 0 | 40.8 | |
| 13/12/2024 02:00 | 47.9 | 0 | 96.23 | 0 | 40.4 | |
| 13/12/2024 03:00 | 48.29 | 0 | 96.21 | 0 | 40.1 | |
| 13/12/2024 04:00 | 48.25 | 0 | 96.33 | 0 | 39.7 | |
| 13/12/2024 05:00 | 47.65 | 0.17 | 96.32 | 0 | 37.2 | |
| 13/12/2024 06:00 | 47.59 | 0 | 96.89 | 0 | 36.1 | |
| 13/12/2024 07:00 | 47.58 | 0 | 97.12 | 0 | 35.5 | |
| 13/12/2024 08:00 | 48.7 | 0 | 96.66 | 0 | 39.5 | |
| 13/12/2024 09:00 | 48.43 | 0 | 96.25 | 0 | 40 | |
| 13/12/2024 10:00 | 48.28 | 0 | 96.19 | 0 | 39.7 | |
| 13/12/2024 11:00 | 48.16 | 0 | 96.54 | 0 | 39.5 | |
| 13/12/2024 12:00 | 45.11 | 0.01 | 97.47 | 0 | 37 | |
| 13/12/2024 13:00 | 32.49 | 0.03 | 95.03 | 0 | 35.7 | |
| 13/12/2024 14:00 | 34.57 | 0.01 | 95.55 | 0 | 26.7 | |
| 13/12/2024 15:00 | 34.55 | 0.01 | 95.24 | 0 | 26.6 | |
| 13/12/2024 16:00 | 34.11 | 0.01 | 94.93 | 0 | 26.3 | |
| 13/12/2024 17:00 | 33.56 | 0.01 | 94.45 | 0 | 25.9 | |
| 13/12/2024 18:00 | 33.56 | 0 | 94.42 | 0 | 25.5 | |
| 13/12/2024 19:00 | 33.52 | 0.01 | 94.67 | 0 | 25.5 | |
| 13/12/2024 20:00 | 34.18 | 0.05 | 95 | 0 | 25.8 | |
| 13/12/2024 21:00 | 34.43 | 0.07 | 95.17 | 0 | 26 | |
| 13/12/2024 22:00 | 34.16 | 0.01 | 95.9 | 0 | 32.9 | |
| 13/12/2024 23:00 | 26.28 | 0.01 | 92.22 | 0 | 49.8 | |
| 14/12/2024 00:00 | 28.51 | 0 | 92.5 | 0 | 48.5 | |
| Minimum | 26.28 | 0 | 92.22 | 0 | 25.5 | |
| MinDate | 13/12/2024 23:00 | 13/12/2024 02:00 | 13/12/2024 23:00 | 13/12/2024 00:00 | 13/12/2024 18:00 | |
| Maximum | 48.7 | 0.17 | 97.47 | 0 | 49.8 | |
| MaxDate | 13/12/2024 08:00 | 13/12/2024 05:00 | 13/12/2024 12:00 | 13/12/2024 00:00 | 13/12/2024 23:00 | |
| Avg | 40.61 | 0.02 | 95.58 | 0 | 35.3 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.9 | 0 | 1.3 | 0 | 7.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|---------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 13/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 12:00 | 4.97 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 SD |
| 13/12/2024 13:00 | 32.42 | 0.08 | 92.62 | 0 | 33.2 | |
| 13/12/2024 14:00 | 34.5 | 0.44 | 93.78 | 0 | 24.5 | |
| 13/12/2024 15:00 | 34.49 | 0.07 | 93.61 | 0 | 24.3 | |
| 13/12/2024 16:00 | 34.04 | 0.08 | 93.25 | 0 | 24 | |
| 13/12/2024 17:00 | 33.5 | 0.08 | 92.81 | 0 | 23.8 | |
| 13/12/2024 18:00 | 33.5 | 0.08 | 92.83 | 0 | 25.6 | |
| 13/12/2024 19:00 | 33.46 | 0.08 | 93.03 | 0 | 26 | |
| 13/12/2024 20:00 | 34.12 | 0.08 | 93.31 | 0 | 23.8 | |
| 13/12/2024 21:00 | 34.37 | 0.08 | 93.49 | 0 | 23.8 | |
| 13/12/2024 22:00 | 34.09 | 0.08 | 94.11 | 0 | 31 | |
| 13/12/2024 23:00 | 26.23 | 0.08 | 90.95 | 0 | 47.4 | |
| 14/12/2024 00:00 | 28.46 | 0.08 | 91.41 | 0 | 44.1 | |
| Minimum | 0 | 0.07 | 90.95 | 0 | 23.8 | |
| MinDate | 13/12/2024 00:00 | 13/12/2024 15:00 | 13/12/2024 23:00 | 13/12/2024 13:00 | 13/12/2024 17:00 | |
| Maximum | 34.5 | 0.44 | 94.11 | 0 | 47.4 | |
| MaxDate | 13/12/2024 14:00 | 13/12/2024 14:00 | 13/12/2024 22:00 | 13/12/2024 13:00 | 13/12/2024 23:00 | |
| Avg | 15.93 | 0.09 | 92.93 | 0 | 29.3 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 16.6 | 0.1 | 0.9 | 0 | 8.3 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/12/2024 00:00 | 28.51 | 0 | 92.5 | 0 | 48.5 | |
| 14/12/2024 01:00 | 28.67 | 0 | 92.61 | 0 | 48 | |
| 14/12/2024 02:00 | 28.77 | 0 | 92.5 | 0 | 47.8 | |
| 14/12/2024 03:00 | 28.61 | 0 | 92.34 | 0 | 48.3 | |
| 14/12/2024 04:00 | 28.02 | 0 | 92.14 | 0 | 50.3 | |
| 14/12/2024 05:00 | 27.55 | 0.36 | 92.04 | 0 | 52.1 | |
| 14/12/2024 06:00 | 27.45 | 0 | 91.91 | 0 | 52.8 | |
| 14/12/2024 07:00 | 27.47 | 0 | 91.73 | 0 | 53 | |
| 14/12/2024 08:00 | 28.27 | 0 | 92.01 | 0 | 50.6 | |
| 14/12/2024 09:00 | 28.53 | 0 | 92.31 | 0 | 49.4 | |
| 14/12/2024 10:00 | 28.55 | 0 | 92.44 | 0 | 49 | |
| 14/12/2024 11:00 | 28.68 | 0 | 92.55 | 0 | 48 | |
| 14/12/2024 12:00 | 28.59 | 0.01 | 92.55 | 0 | 47.3 | |
| 14/12/2024 13:00 | 39.08 | 0 | 97.15 | 0 | 35.1 | |
| 14/12/2024 14:00 | 42.61 | 0 | 100.78 | 0 | 30.4 | |
| 14/12/2024 15:00 | 42.67 | 0 | 100.57 | 0 | 30.4 | |
| 14/12/2024 16:00 | 42.27 | 0 | 100.16 | 0 | 30.1 | |
| 14/12/2024 17:00 | 41.79 | 0 | 99.89 | 0 | 29.8 | |
| 14/12/2024 18:00 | 41.72 | 0 | 100.02 | 0 | 29.8 | |
| 14/12/2024 19:00 | 41.71 | 0 | 99.82 | 0 | 29.7 | |
| 14/12/2024 20:00 | 42.18 | 0 | 99.93 | 0 | 29.9 | |
| 14/12/2024 21:00 | 42.34 | 0 | 100.3 | 0 | 30.2 | |
| 14/12/2024 22:00 | 38.73 | 0.01 | 99.42 | 0 | 34 | |
| 14/12/2024 23:00 | 28.31 | 0.01 | 92.97 | 0 | 50 | |
| 15/12/2024 00:00 | 28.08 | 0 | 92.3 | 0 | 50.8 | |
| Minimum | 27.45 | 0 | 91.73 | 0 | 29.7 | |
| MinDate | 14/12/2024 06:00 | 14/12/2024 00:00 | 14/12/2024 07:00 | 14/12/2024 00:00 | 14/12/2024 19:00 | |
| Maximum | 42.67 | 0.36 | 100.78 | 0 | 53 | |
| MaxDate | 14/12/2024 15:00 | 14/12/2024 05:00 | 14/12/2024 14:00 | 14/12/2024 00:00 | 14/12/2024 07:00 | |
| Avg | 33.57 | 0.02 | 95.32 | 0 | 42.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.8 | 0 | 9.6 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 14/12/2024 00:00 | 28.46 | 0.08 | 91.41 | 0 | 44.1 | |
| 14/12/2024 01:00 | 28.61 | 0.08 | 91.71 | 0 | 43.7 | |
| 14/12/2024 02:00 | 28.7 | 0.08 | 91.55 | 0 | 43.8 | |
| 14/12/2024 03:00 | 28.55 | 0.08 | 91.37 | 0 | 44.2 | |
| 14/12/2024 04:00 | 27.95 | 0.08 | 91.1 | 0 | 45.5 | |
| 14/12/2024 05:00 | 27.48 | 0.08 | 91.05 | 0 | 46.5 | |
| 14/12/2024 06:00 | 27.39 | 0.08 | 90.92 | 0 | 47.1 | |
| 14/12/2024 07:00 | 27.41 | 0.08 | 90.71 | 0 | 47.3 | |
| 14/12/2024 08:00 | 28.2 | 0.08 | 90.92 | 0 | 45.6 | |
| 14/12/2024 09:00 | 28.46 | 0.08 | 91.3 | 0 | 45 | |
| 14/12/2024 10:00 | 28.48 | 0.08 | 91.44 | 0 | 44.9 | |
| 14/12/2024 11:00 | 28.62 | 0.08 | 91.57 | 0 | 44.4 | |
| 14/12/2024 12:00 | 28.53 | 0.08 | 91.56 | 0 | 43.9 | |
| 14/12/2024 13:00 | 39.03 | 0.08 | 95.83 | 0 | 34.4 | |
| 14/12/2024 14:00 | 42.54 | 0.37 | 98.63 | 0 | 30.5 | |
| 14/12/2024 15:00 | 42.59 | 0.08 | 98.5 | 0 | 30.7 | |
| 14/12/2024 16:00 | 42.19 | 0.08 | 98.35 | 0 | 29.8 | |
| 14/12/2024 17:00 | 41.72 | 0.08 | 97.88 | 0 | 28.8 | |
| 14/12/2024 18:00 | 41.65 | 0.08 | 98.01 | 0 | 28.4 | |
| 14/12/2024 19:00 | 41.64 | 0.08 | 97.85 | 0 | 28.3 | |
| 14/12/2024 20:00 | 42.1 | 0.08 | 97.92 | 0 | 29.1 | |
| 14/12/2024 21:00 | 42.27 | 0.08 | 98.11 | 0 | 29.5 | |
| 14/12/2024 22:00 | 38.66 | 0.08 | 97.21 | 0 | 32.8 | |
| 14/12/2024 23:00 | 28.24 | 0.08 | 91.31 | 0 | 45.8 | |
| 15/12/2024 00:00 | 28.02 | 0.08 | 90.67 | 0 | 46.5 | |
| Minimum | 27.39 | 0.08 | 90.67 | 0 | 28.3 | |
| MinDate | 14/12/2024 06:00 | 14/12/2024 00:00 | 15/12/2024 00:00 | 14/12/2024 00:00 | 14/12/2024 19:00 | |
| Maximum | 42.59 | 0.37 | 98.63 | 0 | 47.3 | |
| MaxDate | 14/12/2024 15:00 | 14/12/2024 14:00 | 14/12/2024 14:00 | 14/12/2024 00:00 | 14/12/2024 07:00 | |
| Avg | 33.5 | 0.09 | 93.88 | 0 | 39.2 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 6.7 | 0.1 | 3.3 | 0 | 7.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/12/2024 00:00 | 28.08 | 0 | 92.3 | 0 | 50.8 | |
| 15/12/2024 01:00 | 28.06 | 0 | 92.4 | 0 | 50.9 | |
| 15/12/2024 02:00 | 28.02 | 0 | 92.4 | 0 | 50.9 | |
| 15/12/2024 03:00 | 27.75 | 0 | 92.08 | 0 | 51.6 | |
| 15/12/2024 04:00 | 27.35 | 0 | 91.79 | 0 | 53.1 | |
| 15/12/2024 05:00 | 27.07 | 0.3 | 91.46 | 0 | 54.1 | |
| 15/12/2024 06:00 | 26.95 | 0 | 91.18 | 0 | 54.2 | |
| 15/12/2024 07:00 | 26.85 | 0 | 91.14 | 0 | 54.2 | |
| 15/12/2024 08:00 | 26.9 | 0 | 91.32 | 0 | 54.6 | |
| 15/12/2024 09:00 | 26.91 | 0.01 | 91.83 | 0 | 54.7 | |
| 15/12/2024 10:00 | 26.94 | 0.07 | 92 | 0 | 54.8 | |
| 15/12/2024 11:00 | 26.91 | 0.09 | 92.09 | 0 | 54.5 | |
| 15/12/2024 12:00 | 26.88 | 0.11 | 92.26 | 0 | 54.1 | |
| 15/12/2024 13:00 | 26.96 | 0.15 | 92.43 | 0 | 53.4 | |
| 15/12/2024 14:00 | 26.97 | 0.2 | 92.6 | 0 | 52 | |
| 15/12/2024 15:00 | 27 | 0.26 | 92.42 | 0 | 51.2 | |
| 15/12/2024 16:00 | 27.05 | 0.23 | 92.24 | 0 | 51.4 | |
| 15/12/2024 17:00 | 26.97 | 0.22 | 92.02 | 0 | 52.4 | |
| 15/12/2024 18:00 | 40.87 | 0.08 | 97.84 | 0 | 29.5 | |
| 15/12/2024 19:00 | 40.81 | 0.08 | 98.83 | 0 | 28.9 | |
| 15/12/2024 20:00 | 40.77 | 0.04 | 98.68 | 0 | 29 | |
| 15/12/2024 21:00 | 29.69 | 0.18 | 97.25 | 0 | 39.3 | |
| 15/12/2024 22:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 15/12/2024 23:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 91.14 | 0 | 28.9 | |
| MinDate | 15/12/2024 22:00 | 15/12/2024 00:00 | 15/12/2024 07:00 | 15/12/2024 00:00 | 15/12/2024 19:00 | |
| Maximum | 40.87 | 0.3 | 98.83 | 0 | 54.8 | |
| MaxDate | 15/12/2024 18:00 | 15/12/2024 05:00 | 15/12/2024 19:00 | 15/12/2024 00:00 | 15/12/2024 10:00 | |
| Avg | 25.67 | 0.08 | 93.12 | 0 | 49.1 | |
| Num | 25 | 25 | 22 | 22 | 22 | |
| Data[%] | 100 | 100 | 88 | 88 | 88 | |
| STD | 10.7 | 0.1 | 2.5 | 0 | 8.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 15/12/2024 00:00 | 28.02 | 0.08 | 90.67 | 0 | 46.5 | |
| 15/12/2024 01:00 | 27.98 | 0.08 | 90.79 | 0 | 46.4 | |
| 15/12/2024 02:00 | 27.96 | 0.08 | 90.78 | 0 | 46.5 | |
| 15/12/2024 03:00 | 27.69 | 0.08 | 90.38 | 0 | 46.9 | |
| 15/12/2024 04:00 | 27.29 | 0.08 | 90.09 | 0 | 48.6 | |
| 15/12/2024 05:00 | 27.01 | 0.08 | 89.73 | 0 | 50.5 | |
| 15/12/2024 06:00 | 26.89 | 0.07 | 89.43 | 0 | 51.1 | |
| 15/12/2024 07:00 | 26.79 | 0.03 | 89.42 | 0 | 51.5 | |
| 15/12/2024 08:00 | 26.83 | 0.05 | 89.63 | 0 | 51.5 | |
| 15/12/2024 09:00 | 26.85 | 0.04 | 90.24 | 0 | 51 | |
| 15/12/2024 10:00 | 26.87 | 0.06 | 90.34 | 0 | 50.8 | |
| 15/12/2024 11:00 | 26.85 | 0.08 | 90.42 | 0 | 50.3 | |
| 15/12/2024 12:00 | 26.82 | 0.08 | 90.59 | 0 | 49.5 | |
| 15/12/2024 13:00 | 26.9 | 0.08 | 90.72 | 0 | 48.5 | |
| 15/12/2024 14:00 | 26.91 | 0.29 | 90.93 | 0 | 47.4 | |
| 15/12/2024 15:00 | 26.93 | 0.04 | 90.87 | 0 | 46.7 | |
| 15/12/2024 16:00 | 26.99 | 0 | 90.64 | 0 | 47 | |
| 15/12/2024 17:00 | 26.9 | 0.01 | 90.44 | 0 | 47.8 | |
| 15/12/2024 18:00 | 40.87 | 0.01 | 96.01 | 0 | 27.8 | |
| 15/12/2024 19:00 | 40.73 | 0.01 | 96.79 | 0 | 26.6 | |
| 15/12/2024 20:00 | 40.7 | 0.04 | 96.65 | 0 | 26.7 | |
| 15/12/2024 21:00 | 39.29 | 0.08 | 95.73 | 0 | 33.4 | |
| 15/12/2024 22:00 | 48.82 | 0.07 | 95.07 | 0 | 45 | |
| 15/12/2024 23:00 | 48.92 | 0.02 | 94.71 | 0 | 44.8 | |
| 16/12/2024 00:00 | 48.97 | 0 | 94.94 | 0 | 44.7 | |
| Minimum | 26.79 | 0 | 89.42 | 0 | 26.6 | |
| MinDate | 15/12/2024 07:00 | 15/12/2024 16:00 | 15/12/2024 07:00 | 15/12/2024 00:00 | 15/12/2024 19:00 | |
| Maximum | 48.97 | 0.29 | 96.79 | 0 | 51.5 | |
| MaxDate | 16/12/2024 00:00 | 15/12/2024 14:00 | 15/12/2024 19:00 | 15/12/2024 00:00 | 15/12/2024 07:00 | |
| Avg | 31.87 | 0.06 | 91.84 | 0 | 45.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 8.1 | 0.1 | 2.5 | 0 | 7.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 01:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 04:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 05:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 11:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 12:00 | 4.08 | 0.59 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 16/12/2024 13:00 | 32.08 | 0.17 | 93.23 | 0 | 41.8 | |
| 16/12/2024 14:00 | 34.39 | 0.19 | 94.37 | 0 | 32.1 | |
| 16/12/2024 15:00 | 34.39 | 0.25 | 94.44 | 0 | 31.7 | |
| 16/12/2024 16:00 | 33.93 | 0.25 | 94.07 | 0 | 31.4 | |
| 16/12/2024 17:00 | 33.49 | 0.23 | 93.73 | 0 | 31 | |
| 16/12/2024 18:00 | 33.5 | 0.23 | 93.94 | 0 | 30.7 | |
| 16/12/2024 19:00 | 33.42 | 0.21 | 93.68 | 0 | 30.6 | |
| 16/12/2024 20:00 | 33.95 | 0.15 | 93.7 | 0 | 30.9 | |
| 16/12/2024 21:00 | 33.91 | 0.09 | 93.79 | 0 | 31 | |
| 16/12/2024 22:00 | 31.15 | 0.05 | 93.38 | 0 | 39.3 | |
| 16/12/2024 23:00 | 47.44 | 0 | 95.81 | 0 | 44.4 | |
| 17/12/2024 00:00 | 48.97 | 0 | 96.17 | 0 | 44.4 | |
| Minimum | 0 | 0 | 93.23 | 0 | 30.6 | |
| MinDate | 16/12/2024 00:00 | 16/12/2024 00:00 | 16/12/2024 13:00 | 16/12/2024 13:00 | 16/12/2024 19:00 | |
| Maximum | 48.97 | 0.59 | 96.17 | 0 | 44.4 | |
| MaxDate | 17/12/2024 00:00 | 16/12/2024 12:00 | 17/12/2024 00:00 | 16/12/2024 13:00 | 16/12/2024 23:00 | |
| Avg | 17.39 | 0.11 | 94.19 | 0 | 34.9 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.9 | 0 | 5.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 16/12/2024 00:00 | 48.97 | 0 | 94.94 | 0 | 44.7 | |
| 16/12/2024 01:00 | 48.98 | 0 | 95.14 | 0 | 44.5 | |
| 16/12/2024 02:00 | 49 | 0.01 | 95.28 | 0 | 44.1 | |
| 16/12/2024 03:00 | 49.02 | 0.01 | 95.58 | 0 | 43.4 | |
| 16/12/2024 04:00 | 49.05 | 0.02 | 95.45 | 0 | 43.1 | |
| 16/12/2024 05:00 | 49.08 | 0.03 | 95.36 | 0 | 42.7 | |
| 16/12/2024 06:00 | 49.11 | 0.02 | 95.68 | 0 | 42.2 | |
| 16/12/2024 07:00 | 49.14 | 0.04 | 95.81 | 0 | 41.6 | |
| 16/12/2024 08:00 | 49.08 | 0.05 | 95.68 | 0 | 41.7 | |
| 16/12/2024 09:00 | 48.66 | 0.05 | 95.76 | 0 | 40.8 | |
| 16/12/2024 10:00 | 48.91 | 0.01 | 95.93 | 0 | 42.9 | |
| 16/12/2024 11:00 | 48.9 | 0.04 | 95.54 | 0 | 44.1 | |
| 16/12/2024 12:00 | 45.87 | 0.08 | 95.75 | 0 | 37.4 | |
| 16/12/2024 13:00 | 31.97 | 0.08 | 92.39 | 0 | 31.6 | |
| 16/12/2024 14:00 | 34.33 | 0.23 | 93.02 | 0 | 21.7 | |
| 16/12/2024 15:00 | 34.32 | 0.08 | 92.99 | 0 | 21.5 | |
| 16/12/2024 16:00 | 33.86 | 0.08 | 92.69 | 0 | 21.3 | |
| 16/12/2024 17:00 | 33.43 | 0.08 | 92.36 | 0 | 22.6 | |
| 16/12/2024 18:00 | 33.43 | 0.08 | 92.37 | 0 | 23 | |
| 16/12/2024 19:00 | 33.35 | 0.08 | 92.28 | 0 | 23.8 | |
| 16/12/2024 20:00 | 33.89 | 0.08 | 92.23 | 0 | 21.4 | |
| 16/12/2024 21:00 | 33.85 | 0.08 | 92.11 | 0 | 22 | |
| 16/12/2024 22:00 | 30.97 | 0.08 | 91.69 | 0 | 31.4 | |
| 16/12/2024 23:00 | 1.92 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0 | 91.69 | 0 | 21.3 | |
| MinDate | 17/12/2024 00:00 | 16/12/2024 00:00 | 16/12/2024 22:00 | 16/12/2024 00:00 | 16/12/2024 16:00 | |
| Maximum | 49.14 | 0.23 | 95.93 | 0 | 44.7 | |
| MaxDate | 16/12/2024 07:00 | 16/12/2024 14:00 | 16/12/2024 10:00 | 16/12/2024 00:00 | 16/12/2024 00:00 | |
| Avg | 38.76 | 0.06 | 94.18 | 0 | 34.5 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.6 | 0 | 1.6 | 0 | 9.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/12/2024 00:00 | 48.97 | 0 | 96.17 | 0 | 44.4 | |
| 17/12/2024 01:00 | 49.12 | 0 | 96.65 | 0 | 44.1 | |
| 17/12/2024 02:00 | 49.13 | 0 | 96.85 | 0 | 43.6 | |
| 17/12/2024 03:00 | 48.94 | 0 | 96.88 | 0 | 42.9 | |
| 17/12/2024 04:00 | 48.02 | 0 | 97.19 | 0 | 39.7 | |
| 17/12/2024 05:00 | 47.23 | 0.17 | 97.76 | 0 | 37 | |
| 17/12/2024 06:00 | 47.13 | 0 | 97.68 | 0 | 36.7 | |
| 17/12/2024 07:00 | 47.46 | 0 | 97.89 | 0 | 37.2 | |
| 17/12/2024 08:00 | 48.58 | 0 | 97.42 | 0 | 41.8 | |
| 17/12/2024 09:00 | 48.87 | 0 | 96.68 | 0 | 44.2 | |
| 17/12/2024 10:00 | 48.41 | 0.02 | 96.97 | 0 | 44.1 | |
| 17/12/2024 11:00 | 48.15 | 0.07 | 96.66 | 0 | 43.7 | |
| 17/12/2024 12:00 | 44.12 | 0.14 | 97.31 | 0 | 41.6 | |
| 17/12/2024 13:00 | 32.11 | 0.29 | 94.05 | 0 | 39.9 | |
| 17/12/2024 14:00 | 34.42 | 0.22 | 94.84 | 0 | 30 | |
| 17/12/2024 15:00 | 34.38 | 0.27 | 94.77 | 0 | 29.9 | |
| 17/12/2024 16:00 | 33.95 | 0.23 | 94.34 | 0 | 29.5 | |
| 17/12/2024 17:00 | 33.44 | 0.19 | 93.79 | 0 | 29.1 | |
| 17/12/2024 18:00 | 33.4 | 0.22 | 93.68 | 0 | 28.9 | |
| 17/12/2024 19:00 | 33.41 | 0.2 | 93.73 | 0 | 28.7 | |
| 17/12/2024 20:00 | 33.82 | 0.18 | 94.02 | 0 | 28.6 | |
| 17/12/2024 21:00 | 34.07 | 0.2 | 94.58 | 0 | 28.7 | |
| 17/12/2024 22:00 | 31.19 | 0.13 | 94.03 | 0 | 36.7 | |
| 17/12/2024 23:00 | 2 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 00:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 93.68 | 0 | 28.6 | |
| MinDate | 18/12/2024 00:00 | 17/12/2024 00:00 | 17/12/2024 18:00 | 17/12/2024 00:00 | 17/12/2024 20:00 | |
| Maximum | 49.13 | 0.29 | 97.89 | 0 | 44.4 | |
| MaxDate | 17/12/2024 02:00 | 17/12/2024 13:00 | 17/12/2024 07:00 | 17/12/2024 00:00 | 17/12/2024 00:00 | |
| Avg | 38.41 | 0.11 | 95.82 | 0 | 37 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.4 | 0.1 | 1.5 | 0 | 6.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 17/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 11:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 12:00 | 5.72 | 0.05 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 17/12/2024 13:00 | 32 | 0.07 | 93.01 | 0 | 37.5 | |
| 17/12/2024 14:00 | 34.35 | 0.41 | 93.73 | 0 | 27.6 | |
| 17/12/2024 15:00 | 34.32 | 0.07 | 93.77 | 0 | 27.2 | |
| 17/12/2024 16:00 | 33.88 | 0.06 | 93.32 | 0 | 26.7 | |
| 17/12/2024 17:00 | 33.38 | 0.08 | 92.73 | 0 | 27.1 | |
| 17/12/2024 18:00 | 33.34 | 0.08 | 92.73 | 0 | 28.6 | |
| 17/12/2024 19:00 | 33.34 | 0.08 | 92.7 | 0 | 29.5 | |
| 17/12/2024 20:00 | 33.76 | 0.08 | 93.04 | 0 | 26.9 | |
| 17/12/2024 21:00 | 34.01 | 0.08 | 93.52 | 0 | 25.9 | |
| 17/12/2024 22:00 | 31.24 | 0.08 | 92.86 | 0 | 34.3 | |
| 17/12/2024 23:00 | 47.34 | 0.08 | 95.02 | 0 | 46.9 | |
| 18/12/2024 00:00 | 48.83 | 0.08 | 94.93 | 0 | 48.3 | |
| Minimum | 0 | 0.05 | 92.7 | 0 | 25.9 | |
| MinDate | 17/12/2024 00:00 | 17/12/2024 12:00 | 17/12/2024 19:00 | 17/12/2024 13:00 | 17/12/2024 21:00 | |
| Maximum | 48.83 | 0.41 | 95.02 | 0 | 48.3 | |
| MaxDate | 18/12/2024 00:00 | 17/12/2024 14:00 | 17/12/2024 23:00 | 17/12/2024 13:00 | 18/12/2024 00:00 | |
| Avg | 17.42 | 0.09 | 93.45 | 0 | 32.2 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.5 | 0.1 | 0.8 | 0 | 8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/12/2024 00:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 01:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 02:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 03:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 04:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 05:00 | 0 | 0.41 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 10:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 11:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 12:00 | 5.97 | 0.57 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 18/12/2024 13:00 | 32.35 | 0.14 | 94.15 | 0 | 39.8 | |
| 18/12/2024 14:00 | 34.52 | 0.2 | 95.83 | 0 | 31.3 | |
| 18/12/2024 15:00 | 34.48 | 0.19 | 95.36 | 0 | 31.1 | |
| 18/12/2024 16:00 | 34.08 | 0.15 | 94.87 | 0 | 30.8 | |
| 18/12/2024 17:00 | 33.51 | 0.14 | 94.26 | 0 | 30.4 | |
| 18/12/2024 18:00 | 33.42 | 0.13 | 94.05 | 0 | 30.2 | |
| 18/12/2024 19:00 | 33.33 | 0.11 | 93.94 | 0 | 29.8 | |
| 18/12/2024 20:00 | 33.83 | 0.1 | 94.18 | 0 | 29.8 | |
| 18/12/2024 21:00 | 34 | 0.06 | 94.83 | 0 | 29.7 | |
| 18/12/2024 22:00 | 31.41 | 0.13 | 94.58 | 0 | 36.9 | |
| 18/12/2024 23:00 | 47.06 | 0.01 | 96.38 | 0 | 43.1 | |
| 19/12/2024 00:00 | 48.84 | 0 | 95.72 | 0 | 43.7 | |
| Minimum | 0 | 0 | 93.94 | 0 | 29.7 | |
| MinDate | 18/12/2024 00:00 | 18/12/2024 06:00 | 18/12/2024 19:00 | 18/12/2024 13:00 | 18/12/2024 21:00 | |
| Maximum | 48.84 | 0.57 | 96.38 | 0 | 43.7 | |
| MaxDate | 19/12/2024 00:00 | 18/12/2024 12:00 | 18/12/2024 23:00 | 18/12/2024 13:00 | 19/12/2024 00:00 | |
| Avg | 17.47 | 0.1 | 94.85 | 0 | 33.9 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.5 | 0.1 | 0.8 | 0 | 5.4 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 18/12/2024 00:00 | 48.83 | 0.08 | 94.93 | 0 | 48.3 | |
| 18/12/2024 01:00 | 48.83 | 0.08 | 95.38 | 0 | 49.2 | |
| 18/12/2024 02:00 | 48.89 | 0.08 | 95.3 | 0 | 49.8 | |
| 18/12/2024 03:00 | 48.78 | 0.08 | 95.26 | 0 | 49.3 | |
| 18/12/2024 04:00 | 47.86 | 0.08 | 95.73 | 0 | 44.4 | |
| 18/12/2024 05:00 | 47.07 | 0.08 | 96.3 | 0 | 39.5 | |
| 18/12/2024 06:00 | 46.99 | 0.08 | 96.43 | 0 | 38.9 | |
| 18/12/2024 07:00 | 47.26 | 0.07 | 96.37 | 0 | 39.9 | |
| 18/12/2024 08:00 | 48.46 | 0.07 | 95.79 | 0 | 46.4 | |
| 18/12/2024 09:00 | 48.83 | 0.03 | 95.35 | 0 | 49.5 | |
| 18/12/2024 10:00 | 48.19 | 0.07 | 95.14 | 0 | 48.9 | |
| 18/12/2024 11:00 | 47.77 | 0.05 | 94.8 | 0 | 48.6 | |
| 18/12/2024 12:00 | 43.73 | 0.01 | 95.15 | 0 | 44.4 | |
| 18/12/2024 13:00 | 32.28 | 0.06 | 93.09 | 0 | 33.4 | |
| 18/12/2024 14:00 | 34.45 | 0.3 | 94.03 | 0 | 25.2 | |
| 18/12/2024 15:00 | 34.41 | 0.03 | 93.87 | 0 | 25 | |
| 18/12/2024 16:00 | 34.01 | 0.07 | 93.49 | 0 | 24.8 | |
| 18/12/2024 17:00 | 33.44 | 0.08 | 92.92 | 0 | 24.6 | |
| 18/12/2024 18:00 | 33.35 | 0.08 | 92.78 | 0 | 24.7 | |
| 18/12/2024 19:00 | 33.27 | 0.08 | 92.75 | 0 | 26.9 | |
| 18/12/2024 20:00 | 33.76 | 0.08 | 92.95 | 0 | 24.7 | |
| 18/12/2024 21:00 | 33.93 | 0.08 | 93.35 | 0 | 24.2 | |
| 18/12/2024 22:00 | 31.31 | 0.08 | 93.09 | 0 | 31.5 | |
| 18/12/2024 23:00 | 2.31 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.01 | 92.75 | 0 | 24.2 | |
| MinDate | 19/12/2024 00:00 | 18/12/2024 12:00 | 18/12/2024 19:00 | 18/12/2024 00:00 | 18/12/2024 21:00 | |
| Maximum | 48.89 | 0.3 | 96.43 | 0 | 49.8 | |
| MaxDate | 18/12/2024 02:00 | 18/12/2024 14:00 | 18/12/2024 06:00 | 18/12/2024 00:00 | 18/12/2024 02:00 | |
| Avg | 38.32 | 0.08 | 94.53 | 0 | 37.5 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.2 | 0 | 1.3 | 0 | 10.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/12/2024 00:00 | 48.84 | 0 | 95.72 | 0 | 43.7 | |
| 19/12/2024 01:00 | 49.04 | 0 | 96.36 | 0 | 43.3 | |
| 19/12/2024 02:00 | 49.13 | 0 | 96.58 | 0 | 42.9 | |
| 19/12/2024 03:00 | 49.05 | 0 | 96.73 | 0 | 42.1 | |
| 19/12/2024 04:00 | 48.13 | 0 | 97.13 | 0 | 39 | |
| 19/12/2024 05:00 | 47.47 | 0.3 | 97.62 | 0 | 36.6 | |
| 19/12/2024 06:00 | 47.43 | 0 | 97.82 | 0 | 36.4 | |
| 19/12/2024 07:00 | 47.49 | 0 | 97.93 | 0 | 36.5 | |
| 19/12/2024 08:00 | 48.75 | 0 | 97.45 | 0 | 40.6 | |
| 19/12/2024 09:00 | 49.12 | 0 | 96.69 | 0 | 43.1 | |
| 19/12/2024 10:00 | 48.83 | 0 | 96.54 | 0 | 43.5 | |
| 19/12/2024 11:00 | 48.33 | 0 | 96.61 | 0 | 43.2 | |
| 19/12/2024 12:00 | 45.3 | 0.03 | 97.15 | 0 | 40.1 | |
| 19/12/2024 13:00 | 32.31 | 0.2 | 94.49 | 0 | 39 | |
| 19/12/2024 14:00 | 34.38 | 0.18 | 95.11 | 0 | 29.4 | |
| 19/12/2024 15:00 | 34.32 | 0.18 | 94.91 | 0 | 29.3 | |
| 19/12/2024 16:00 | 34.05 | 0.2 | 94.77 | 0 | 29.1 | |
| 19/12/2024 17:00 | 33.56 | 0.23 | 94.26 | 0 | 28.8 | |
| 19/12/2024 18:00 | 33.53 | 0.22 | 93.97 | 0 | 28.8 | |
| 19/12/2024 19:00 | 33.41 | 0.18 | 93.71 | 0 | 28.7 | |
| 19/12/2024 20:00 | 33.91 | 0.17 | 93.86 | 0 | 28.4 | |
| 19/12/2024 21:00 | 34.02 | 0.11 | 94.13 | 0 | 28.4 | |
| 19/12/2024 22:00 | 31.33 | 0.13 | 93.71 | 0 | 36.6 | |
| 19/12/2024 23:00 | 2.28 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 20/12/2024 00:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 93.71 | 0 | 28.4 | |
| MinDate | 20/12/2024 00:00 | 19/12/2024 00:00 | 19/12/2024 19:00 | 19/12/2024 00:00 | 19/12/2024 20:00 | |
| Maximum | 49.13 | 0.3 | 97.93 | 0 | 43.7 | |
| MaxDate | 19/12/2024 02:00 | 19/12/2024 05:00 | 19/12/2024 07:00 | 19/12/2024 00:00 | 19/12/2024 00:00 | |
| Avg | 38.56 | 0.09 | 95.79 | 0 | 36.4 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.4 | 0.1 | 1.5 | 0 | 6.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 19/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 04:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 05:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 12:00 | 4.39 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 19/12/2024 13:00 | 32.21 | 0.08 | 93.52 | 0 | 36.7 | |
| 19/12/2024 14:00 | 34.31 | 0.29 | 93.37 | 0 | 27.3 | |
| 19/12/2024 15:00 | 34.26 | 0.02 | 93.23 | 0 | 27 | |
| 19/12/2024 16:00 | 33.99 | 0.07 | 93.11 | 0 | 26.6 | |
| 19/12/2024 17:00 | 33.5 | 0.08 | 92.72 | 0 | 26.4 | |
| 19/12/2024 18:00 | 33.47 | 0.08 | 92.49 | 0 | 27.5 | |
| 19/12/2024 19:00 | 33.35 | 0.08 | 92.18 | 0 | 29.3 | |
| 19/12/2024 20:00 | 33.85 | 0.08 | 92.29 | 0 | 26.5 | |
| 19/12/2024 21:00 | 33.96 | 0.08 | 92.51 | 0 | 26.5 | |
| 19/12/2024 22:00 | 31.31 | 0.08 | 92.06 | 0 | 35.2 | |
| 19/12/2024 23:00 | 47.12 | 0.08 | 94.52 | 0 | 48.6 | |
| 20/12/2024 00:00 | 48.66 | 0.08 | 94.58 | 0 | 49.7 | |
| Minimum | 0 | 0.02 | 92.06 | 0 | 26.4 | |
| MinDate | 19/12/2024 00:00 | 19/12/2024 15:00 | 19/12/2024 22:00 | 19/12/2024 13:00 | 19/12/2024 17:00 | |
| Maximum | 48.66 | 0.29 | 94.58 | 0 | 49.7 | |
| MaxDate | 20/12/2024 00:00 | 19/12/2024 14:00 | 20/12/2024 00:00 | 19/12/2024 13:00 | 20/12/2024 00:00 | |
| Avg | 17.38 | 0.08 | 93.05 | 0 | 32.3 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.5 | 0 | 0.8 | 0 | 8.6 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/12/2024 00:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 01:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 03:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 05:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 06:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 09:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 10:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 11:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 12:00 | 4.72 | 0.69 | ShutDown | ShutDown | ShutDown | |
| 20/12/2024 13:00 | 32.3 | 0.24 | 93.6 | 0 | 42.5 | |
| 20/12/2024 14:00 | 34.42 | 0.27 | 95.03 | 0 | 33.2 | |
| 20/12/2024 15:00 | 34.36 | 0.28 | 94.76 | 0 | 33 | |
| 20/12/2024 16:00 | 34.28 | 0.26 | 94.55 | 0 | 32.9 | |
| 20/12/2024 17:00 | 33.97 | 0.29 | 94.08 | 0 | 32.4 | |
| 20/12/2024 18:00 | 33.96 | 0.29 | 94.11 | 0 | 32.2 | |
| 20/12/2024 19:00 | 33.81 | 0.26 | 93.97 | 0 | 31.9 | |
| 20/12/2024 20:00 | 33.89 | 0.26 | 94.01 | 0 | 31.7 | |
| 20/12/2024 21:00 | 34.08 | 0.25 | 94.48 | 0 | 31.6 | |
| 20/12/2024 22:00 | 31.35 | 0.27 | 93.97 | 0 | 39.5 | |
| 20/12/2024 23:00 | 2.15 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 00:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 93.6 | 0 | 31.6 | |
| MinDate | 20/12/2024 00:00 | 20/12/2024 02:00 | 20/12/2024 13:00 | 20/12/2024 13:00 | 20/12/2024 21:00 | |
| Maximum | 34.42 | 0.69 | 95.03 | 0 | 42.5 | |
| MaxDate | 20/12/2024 14:00 | 20/12/2024 12:00 | 20/12/2024 14:00 | 20/12/2024 13:00 | 20/12/2024 13:00 | |
| Avg | 13.73 | 0.16 | 94.26 | 0 | 34.1 | |
| Num | 25 | 25 | 10 | 10 | 10 | |
| Data[%] | 100 | 100 | 40 | 40 | 40 | |
| STD | 16.6 | 0.2 | 0.4 | 0 | 3.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 20/12/2024 00:00 | 48.66 | 0.08 | 94.58 | 0 | 49.7 | |
| 20/12/2024 01:00 | 48.8 | 0.08 | 95.21 | 0 | 49.5 | |
| 20/12/2024 02:00 | 48.97 | 0.08 | 95.43 | 0 | 49 | |
| 20/12/2024 03:00 | 48.9 | 0.08 | 95.59 | 0 | 47.6 | |
| 20/12/2024 04:00 | 48.27 | 0.08 | 95.79 | 0 | 42.6 | |
| 20/12/2024 05:00 | 47.73 | 0.08 | 96.45 | 0 | 39.4 | |
| 20/12/2024 06:00 | 47.63 | 0.08 | 96.8 | 0 | 39.2 | |
| 20/12/2024 07:00 | 47.55 | 0.08 | 96.94 | 0 | 38.7 | |
| 20/12/2024 08:00 | 48.52 | 0.08 | 96.2 | 0 | 43 | |
| 20/12/2024 09:00 | 49.02 | 0.08 | 95.79 | 0 | 46.8 | |
| 20/12/2024 10:00 | 48.97 | 0.08 | 95.57 | 0 | 48.7 | |
| 20/12/2024 11:00 | 48.73 | 0.08 | 94.98 | 0 | 50.2 | |
| 20/12/2024 12:00 | 45.13 | 0.07 | 95.41 | 0 | 43.5 | |
| 20/12/2024 13:00 | 32.23 | 0.07 | 92.53 | 0 | 34.5 | |
| 20/12/2024 14:00 | 34.36 | 0.23 | 93.32 | 0 | 25.1 | |
| 20/12/2024 15:00 | 34.29 | 0.08 | 93.24 | 0 | 24.8 | |
| 20/12/2024 16:00 | 34.22 | 0.08 | 93.06 | 0 | 24.7 | |
| 20/12/2024 17:00 | 33.91 | 0.08 | 92.78 | 0 | 24.3 | |
| 20/12/2024 18:00 | 33.89 | 0.08 | 92.67 | 0 | 24.6 | |
| 20/12/2024 19:00 | 33.75 | 0.08 | 92.58 | 0 | 26 | |
| 20/12/2024 20:00 | 33.83 | 0.08 | 92.58 | 0 | 26 | |
| 20/12/2024 21:00 | 34.01 | 0.08 | 92.89 | 0 | 24.8 | |
| 20/12/2024 22:00 | 31.37 | 0.08 | 92.32 | 0 | 33.7 | |
| 20/12/2024 23:00 | 47.21 | 0.08 | 95.02 | 0 | 42.7 | |
| 21/12/2024 00:00 | 48.79 | 0.07 | 95.71 | 0 | 43 | |
| Minimum | 31.37 | 0.07 | 92.32 | 0 | 24.3 | |
| MinDate | 20/12/2024 22:00 | 20/12/2024 12:00 | 20/12/2024 22:00 | 20/12/2024 00:00 | 20/12/2024 17:00 | |
| Maximum | 49.02 | 0.23 | 96.94 | 0 | 50.2 | |
| MaxDate | 20/12/2024 09:00 | 20/12/2024 14:00 | 20/12/2024 07:00 | 20/12/2024 00:00 | 20/12/2024 11:00 | |
| Avg | 42.35 | 0.08 | 94.54 | 0 | 37.7 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.4 | 0 | 1.6 | 0 | 9.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/12/2024 00:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 01:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 03:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 04:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 05:00 | 0 | 0.18 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 09:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 10:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 11:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 12:00 | 5.1 | 0.74 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 21/12/2024 13:00 | 31.99 | 0.29 | 93.77 | 0 | 41.5 | |
| 21/12/2024 14:00 | 33.99 | 0.31 | 95.26 | 0 | 32.4 | |
| 21/12/2024 15:00 | 34 | 0.26 | 94.79 | 0 | 32.3 | |
| 21/12/2024 16:00 | 33.97 | 0.16 | 94.49 | 0 | 32.2 | |
| 21/12/2024 17:00 | 33.89 | 0.12 | 94.11 | 0 | 32 | |
| 21/12/2024 18:00 | 33.97 | 0.1 | 94.01 | 0 | 31.6 | |
| 21/12/2024 19:00 | 33.72 | 0.12 | 94.16 | 0 | 31.4 | |
| 21/12/2024 20:00 | 33.76 | 0.18 | 94.2 | 0 | 31.2 | |
| 21/12/2024 21:00 | 33.83 | 0.12 | 94.4 | 0 | 31.1 | |
| 21/12/2024 22:00 | 31.18 | 0.1 | 93.89 | 0 | 38.9 | |
| 21/12/2024 23:00 | 46.44 | 0 | 96.27 | 0 | 43.7 | |
| 22/12/2024 00:00 | 48.45 | 0 | 96.59 | 0 | 43 | |
| Minimum | 0 | 0 | 93.77 | 0 | 31.1 | |
| MinDate | 21/12/2024 00:00 | 21/12/2024 06:00 | 21/12/2024 13:00 | 21/12/2024 13:00 | 21/12/2024 21:00 | |
| Maximum | 48.45 | 0.74 | 96.59 | 0 | 43.7 | |
| MaxDate | 22/12/2024 00:00 | 21/12/2024 12:00 | 22/12/2024 00:00 | 21/12/2024 13:00 | 21/12/2024 23:00 | |
| Avg | 17.37 | 0.12 | 94.66 | 0 | 35.1 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.5 | 0.2 | 0.9 | 0 | 5.1 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 21/12/2024 00:00 | 48.79 | 0.07 | 95.71 | 0 | 43 | |
| 21/12/2024 01:00 | 48.93 | 0.08 | 96.35 | 0 | 42.7 | |
| 21/12/2024 02:00 | 49.03 | 0.08 | 96.61 | 0 | 42.1 | |
| 21/12/2024 03:00 | 49.01 | 0.07 | 96.35 | 0 | 42.8 | |
| 21/12/2024 04:00 | 48.87 | 0.08 | 96.19 | 0 | 42.5 | |
| 21/12/2024 05:00 | 48.64 | 0.08 | 96.03 | 0 | 41.4 | |
| 21/12/2024 06:00 | 48.63 | 0.08 | 96.26 | 0 | 40.6 | |
| 21/12/2024 07:00 | 48.39 | 0.08 | 96.53 | 0 | 39.7 | |
| 21/12/2024 08:00 | 48.29 | 0.08 | 96.04 | 0 | 41.3 | |
| 21/12/2024 09:00 | 48.54 | 0.08 | 95.6 | 0 | 44.5 | |
| 21/12/2024 10:00 | 48.46 | 0.08 | 95.26 | 0 | 46 | |
| 21/12/2024 11:00 | 48.14 | 0.08 | 95.16 | 0 | 45.9 | |
| 21/12/2024 12:00 | 44.28 | 0.08 | 95.73 | 0 | 40.1 | |
| 21/12/2024 13:00 | 31.92 | 0.08 | 93.03 | 0 | 31.9 | |
| 21/12/2024 14:00 | 33.92 | 0.42 | 93.79 | 0 | 22.7 | |
| 21/12/2024 15:00 | 33.93 | 0.08 | 93.5 | 0 | 22.6 | |
| 21/12/2024 16:00 | 33.91 | 0.08 | 93.2 | 0 | 22.4 | |
| 21/12/2024 17:00 | 33.81 | 0.08 | 92.88 | 0 | 22.3 | |
| 21/12/2024 18:00 | 33.9 | 0.08 | 92.88 | 0 | 22.2 | |
| 21/12/2024 19:00 | 33.66 | 0.08 | 92.94 | 0 | 23.2 | |
| 21/12/2024 20:00 | 33.71 | 0.08 | 92.97 | 0 | 23.2 | |
| 21/12/2024 21:00 | 33.77 | 0.08 | 93 | 0 | 23.4 | |
| 21/12/2024 22:00 | 31.11 | 0.08 | 92.41 | 0 | 32.1 | |
| 21/12/2024 23:00 | 2.54 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.07 | 92.41 | 0 | 22.2 | |
| MinDate | 22/12/2024 00:00 | 21/12/2024 00:00 | 21/12/2024 22:00 | 21/12/2024 00:00 | 21/12/2024 18:00 | |
| Maximum | 49.03 | 0.42 | 96.61 | 0 | 46 | |
| MaxDate | 21/12/2024 02:00 | 21/12/2024 14:00 | 21/12/2024 02:00 | 21/12/2024 00:00 | 21/12/2024 10:00 | |
| Avg | 38.57 | 0.09 | 94.71 | 0 | 34.7 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.4 | 0.1 | 1.5 | 0 | 9.5 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/12/2024 00:00 | 48.45 | 0 | 96.59 | 0 | 43 | |
| 22/12/2024 01:00 | 48.61 | 0 | 97.03 | 0 | 43.3 | |
| 22/12/2024 02:00 | 48.67 | 0 | 96.98 | 0 | 43.1 | |
| 22/12/2024 03:00 | 48.76 | 0 | 96.9 | 0 | 42.5 | |
| 22/12/2024 04:00 | 48.7 | 0 | 97.21 | 0 | 41.2 | |
| 22/12/2024 05:00 | 48.61 | 0.36 | 97.63 | 0 | 40.5 | |
| 22/12/2024 06:00 | 48.44 | 0 | 97.81 | 0 | 39.8 | |
| 22/12/2024 07:00 | 47.98 | 0 | 98.02 | 0 | 38.6 | |
| 22/12/2024 08:00 | 47.88 | 0 | 97.94 | 0 | 38.5 | |
| 22/12/2024 09:00 | 48.02 | 0 | 97.86 | 0 | 39.4 | |
| 22/12/2024 10:00 | 48.04 | 0 | 97.44 | 0 | 40.3 | |
| 22/12/2024 11:00 | 47.91 | 0 | 97.22 | 0 | 41 | |
| 22/12/2024 12:00 | 47.78 | 0 | 97.03 | 0 | 41.8 | |
| 22/12/2024 13:00 | 47.78 | 0.03 | 96.6 | 0 | 43 | |
| 22/12/2024 14:00 | 47.95 | 0.02 | 96.41 | 0 | 43.6 | |
| 22/12/2024 15:00 | 48.08 | 0.03 | 96.45 | 0 | 43.8 | |
| 22/12/2024 16:00 | 48.03 | 0.03 | 96.1 | 0 | 43.3 | |
| 22/12/2024 17:00 | 38.15 | 0.11 | 95.22 | 0 | 44.3 | |
| 22/12/2024 18:00 | 33.7 | 0.13 | 93.49 | 0 | 34 | |
| 22/12/2024 19:00 | 33.38 | 0.14 | 93.29 | 0 | 32.3 | |
| 22/12/2024 20:00 | 33.33 | 0.09 | 92.99 | 0 | 33.1 | |
| 22/12/2024 21:00 | 32.96 | 0.08 | 92.94 | 0 | 43.1 | |
| 22/12/2024 22:00 | 48.18 | 0 | 96.52 | 0 | 38.9 | |
| 22/12/2024 23:00 | 48.34 | 0 | 96.98 | 0 | 39 | |
| 23/12/2024 00:00 | 48.09 | 0 | 97.6 | 0 | 37.9 | |
| Minimum | 32.96 | 0 | 92.94 | 0 | 32.3 | |
| MinDate | 22/12/2024 21:00 | 22/12/2024 00:00 | 22/12/2024 21:00 | 22/12/2024 00:00 | 22/12/2024 19:00 | |
| Maximum | 48.76 | 0.36 | 98.02 | 0 | 44.3 | |
| MaxDate | 22/12/2024 03:00 | 22/12/2024 05:00 | 22/12/2024 07:00 | 22/12/2024 00:00 | 22/12/2024 17:00 | |
| Avg | 45.43 | 0.04 | 96.41 | 0 | 40.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 5.8 | 0.1 | 1.6 | 0 | 3.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 22/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 05:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 06:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 07:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 08:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 10:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 11:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 12:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 13:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 14:00 | 0 | 0.33 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 15:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 16:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 17:00 | 12.11 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 18:00 | 33.61 | 0.08 | 92.65 | 0 | 33.2 | |
| 22/12/2024 19:00 | 33.31 | 0.04 | 91.98 | 0 | 33.8 | |
| 22/12/2024 20:00 | 33.27 | 0.01 | 91.68 | 0 | 35.1 | |
| 22/12/2024 21:00 | 24.11 | 0.05 | 91.05 | 0 | 45.4 | |
| 22/12/2024 22:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 22/12/2024 23:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0 | 91.05 | 0 | 33.2 | |
| MinDate | 22/12/2024 00:00 | 22/12/2024 09:00 | 22/12/2024 21:00 | 22/12/2024 18:00 | 22/12/2024 18:00 | |
| Maximum | 33.61 | 0.33 | 92.65 | 0 | 45.4 | |
| MaxDate | 22/12/2024 18:00 | 22/12/2024 14:00 | 22/12/2024 18:00 | 22/12/2024 18:00 | 22/12/2024 21:00 | |
| Avg | 5.46 | 0.07 | 91.84 | 0 | 36.9 | |
| Num | 25 | 25 | 4 | 4 | 4 | |
| Data[%] | 100 | 100 | 16 | 16 | 16 | |
| STD | 11.8 | 0.1 | 0.7 | 0 | 5.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/12/2024 00:00 | 48.09 | 0 | 97.6 | 0 | 37.9 | |
| 23/12/2024 01:00 | 48.26 | 0 | 97.76 | 0 | 37.7 | |
| 23/12/2024 02:00 | 48.53 | 0 | 97.61 | 0 | 38.1 | |
| 23/12/2024 03:00 | 48.46 | 0 | 97.82 | 0 | 37.7 | |
| 23/12/2024 04:00 | 48.43 | 0 | 97.79 | 0 | 37.2 | |
| 23/12/2024 05:00 | 48.44 | 0.3 | 98.09 | 0 | 36.7 | |
| 23/12/2024 06:00 | 48.36 | 0 | 98.18 | 0 | 36.3 | |
| 23/12/2024 07:00 | 48.42 | 0 | 98.59 | 0 | 36.3 | |
| 23/12/2024 08:00 | 49.01 | 0.02 | 97.94 | 0 | 39.3 | |
| 23/12/2024 09:00 | 49.25 | 0 | 97.27 | 0 | 41.5 | |
| 23/12/2024 10:00 | 49.14 | 0.03 | 96.98 | 0 | 42.3 | |
| 23/12/2024 11:00 | 48.78 | 0.09 | 96.88 | 0 | 42.4 | |
| 23/12/2024 12:00 | 45.87 | 0.11 | 97.38 | 0 | 38.4 | |
| 23/12/2024 13:00 | 31.92 | 0.33 | 94.42 | 0 | 40.7 | |
| 23/12/2024 14:00 | 34.35 | 0.28 | 94.92 | 0 | 28.4 | |
| 23/12/2024 15:00 | 34.31 | 0.38 | 94.94 | 0 | 28.4 | |
| 23/12/2024 16:00 | 34.23 | 0.35 | 94.81 | 0 | 28.2 | |
| 23/12/2024 17:00 | 34.16 | 0.36 | 94.6 | 0 | 28 | |
| 23/12/2024 18:00 | 34.1 | 0.31 | 94.31 | 0 | 27.6 | |
| 23/12/2024 19:00 | 33.91 | 0.3 | 94.15 | 0 | 27.4 | |
| 23/12/2024 20:00 | 33.88 | 0.2 | 93.91 | 0 | 27.2 | |
| 23/12/2024 21:00 | 34.1 | 0.28 | 94.66 | 0 | 27.2 | |
| 23/12/2024 22:00 | 31.21 | 0.37 | 94.18 | 0 | 36.1 | |
| 23/12/2024 23:00 | 1.8 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 24/12/2024 00:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 93.91 | 0 | 27.2 | |
| MinDate | 24/12/2024 00:00 | 23/12/2024 00:00 | 23/12/2024 20:00 | 23/12/2024 00:00 | 23/12/2024 20:00 | |
| Maximum | 49.25 | 0.38 | 98.59 | 0 | 42.4 | |
| MaxDate | 23/12/2024 09:00 | 23/12/2024 15:00 | 23/12/2024 07:00 | 23/12/2024 00:00 | 23/12/2024 11:00 | |
| Avg | 38.68 | 0.16 | 96.3 | 0 | 34.8 | |
| Nun | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.5 | 0.2 | 1.7 | 0 | 5.5 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 23/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 02:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 03:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 04:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 06:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 12:00 | 4.19 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 23/12/2024 13:00 | 31.86 | 0.08 | 92.59 | 0 | 39.2 | |
| 23/12/2024 14:00 | 34.29 | 0.27 | 93.21 | 0 | 27.4 | |
| 23/12/2024 15:00 | 34.25 | 0.08 | 93.28 | 0 | 27.3 | |
| 23/12/2024 16:00 | 34.17 | 0.08 | 93.24 | 0 | 26.9 | |
| 23/12/2024 17:00 | 34.09 | 0.08 | 93.1 | 0 | 26.6 | |
| 23/12/2024 18:00 | 34.04 | 0.08 | 92.77 | 0 | 26.2 | |
| 23/12/2024 19:00 | 33.84 | 0.08 | 92.63 | 0 | 26.2 | |
| 23/12/2024 20:00 | 33.82 | 0.08 | 92.61 | 0 | 27 | |
| 23/12/2024 21:00 | 34.04 | 0.08 | 93.15 | 0 | 26.6 | |
| 23/12/2024 22:00 | 31.33 | 0.08 | 92.66 | 0 | 35.1 | |
| 23/12/2024 23:00 | 47.49 | 0.08 | 95.06 | 0 | 44.9 | |
| 24/12/2024 00:00 | 48.83 | 0.08 | 95.31 | 0 | 46.5 | |
| Minimum | 0 | 0.01 | 92.59 | 0 | 26.2 | |
| MinDate | 23/12/2024 00:00 | 23/12/2024 03:00 | 23/12/2024 13:00 | 23/12/2024 13:00 | 23/12/2024 18:00 | |
| Maximum | 48.83 | 0.27 | 95.31 | 0 | 46.5 | |
| MaxDate | 24/12/2024 00:00 | 23/12/2024 14:00 | 24/12/2024 00:00 | 23/12/2024 13:00 | 24/12/2024 00:00 | |
| Avg | 17.45 | 0.08 | 93.3 | 0 | 31.7 | |
| Nun | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0 | 0.9 | 0 | 7.7 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|-----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/12/2024 00:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 01:00 | 0 | 0.14 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 02:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 03:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 04:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 05:00 | 0 | 0.31 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 11:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 12:00 | 6.24 | 0.28 | ShutDown | ShutDown | ShutDown | GT 11 S/D |
| 24/12/2024 13:00 | 32.38 | 0 | 94.3 | 0 | 37.6 | |
| 24/12/2024 14:00 | 34.41 | 0 | 95.31 | 0 | 29 | |
| 24/12/2024 15:00 | 34.41 | 0 | 95.1 | 0 | 28.6 | |
| 24/12/2024 16:00 | 34.32 | 0 | 94.91 | 0 | 28.1 | |
| 24/12/2024 17:00 | 34.19 | 0 | 94.62 | 0 | 27.7 | |
| 24/12/2024 18:00 | 34.14 | 0 | 94.82 | 0 | 27.5 | |
| 24/12/2024 19:00 | 33.85 | 0 | 94.57 | 0 | 27.4 | |
| 24/12/2024 20:00 | 33.91 | 0 | 94.54 | 0 | 27.2 | |
| 24/12/2024 21:00 | 34.07 | 0 | 94.79 | 0 | 27 | |
| 24/12/2024 22:00 | 31.3 | 0 | 94.18 | 0 | 34.4 | |
| 24/12/2024 23:00 | 47.18 | 0 | 96.05 | 0 | 39.6 | |
| 25/12/2024 00:00 | 48.83 | 0 | 95.94 | 0 | 40.6 | |
| Minimum | 0 | 0 | 94.18 | 0 | 27 | |
| MinDate | 24/12/2024 00:00 | 24/12/2024 06:00 | 24/12/2024 22:00 | 24/12/2024 13:00 | 24/12/2024 21:00 | |
| Maximum | 48.83 | 0.31 | 96.05 | 0 | 40.6 | |
| MaxDate | 25/12/2024 00:00 | 24/12/2024 05:00 | 24/12/2024 23:00 | 24/12/2024 13:00 | 25/12/2024 00:00 | |
| Avg | 17.57 | 0.05 | 94.93 | 0 | 31.2 | |
| Num | 25 | 25 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.6 | 0 | 5.3 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 24/12/2024 00:00 | 48.83 | 0.08 | 95.31 | 0 | 46.5 | |
| 24/12/2024 01:00 | 48.81 | 0.08 | 96.14 | 0 | 46.7 | |
| 24/12/2024 02:00 | 48.96 | 0.08 | 95.94 | 0 | 47.4 | |
| 24/12/2024 03:00 | 48.9 | 0.08 | 95.72 | 0 | 47.7 | |
| 24/12/2024 04:00 | 48.81 | 0.08 | 95.95 | 0 | 45.8 | |
| 24/12/2024 05:00 | 48.72 | 0.08 | 96.68 | 0 | 43.4 | |
| 24/12/2024 06:00 | 48.7 | 0.08 | 96.18 | 0 | 44.2 | |
| 24/12/2024 07:00 | 48.57 | 0.08 | 96.18 | 0 | 43.7 | |
| 24/12/2024 08:00 | 48.63 | 0.08 | 95.96 | 0 | 46.1 | |
| 24/12/2024 09:00 | 48.76 | 0.08 | 95.44 | 0 | 49.2 | |
| 24/12/2024 10:00 | 48.35 | 0.08 | 95.47 | 0 | 48.3 | |
| 24/12/2024 11:00 | 48.21 | 0.08 | 95.44 | 0 | 47.7 | |
| 24/12/2024 12:00 | 43.63 | 0.08 | 95.16 | 0 | 42.9 | |
| 24/12/2024 13:00 | 32.28 | 0.26 | 93.05 | 0 | 30 | |
| 24/12/2024 14:00 | 34.34 | 0.08 | 93.79 | 129.2 | <Samp | PM CEMs |
| 24/12/2024 15:00 | 34.34 | 0.08 | 93.7 | 0 | 25.4 | |
| 24/12/2024 16:00 | 34.25 | 0.08 | 93.53 | 0 | 25.1 | |
| 24/12/2024 17:00 | 34.13 | 0.08 | 93.24 | 0.1 | 25 | |
| 24/12/2024 18:00 | 34.07 | 0.08 | 93.37 | 0.3 | 24.9 | |
| 24/12/2024 19:00 | 33.79 | 0.08 | 93.13 | 0.5 | 24.6 | |
| 24/12/2024 20:00 | 33.84 | 0.08 | 93.13 | 0.5 | 24.7 | |
| 24/12/2024 21:00 | 34 | 0.08 | 93.26 | 0.4 | 24.6 | |
| 24/12/2024 22:00 | 31.11 | 0.08 | 92.54 | 0.3 | 32.7 | |
| 24/12/2024 23:00 | 1.91 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| Minimum | 0 | 0.08 | 92.54 | 0 | 24.6 | |
| MinDate | 25/12/2024 00:00 | 24/12/2024 00:00 | 24/12/2024 22:00 | 24/12/2024 00:00 | 24/12/2024 19:00 | |
| Maximum | 48.96 | 0.26 | 96.68 | 129.2 | 49.2 | |
| MaxDate | 24/12/2024 02:00 | 24/12/2024 13:00 | 24/12/2024 05:00 | 24/12/2024 14:00 | 24/12/2024 14:00 | |
| Avg | 38.64 | 0.09 | 94.71 | 5.7 | 40.4 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.5 | 0 | 1.3 | 26.9 | 15.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/12/2024 00:00 | 48.83 | 0 | 95.94 | 0 | 40.6 | |
| 25/12/2024 01:00 | 49.06 | 0 | 96.65 | 0 | 39.9 | |
| 25/12/2024 02:00 | 49.09 | 0 | 96.69 | 0 | 40.2 | |
| 25/12/2024 03:00 | 49.06 | 0 | 96.66 | 0 | 39.5 | |
| 25/12/2024 04:00 | 49.08 | 0 | 96.78 | 0 | 38.7 | |
| 25/12/2024 05:00 | 48.96 | 0.17 | 96.91 | 0 | 37.7 | |
| 25/12/2024 06:00 | 48.89 | 0 | 97.32 | 0 | 36.8 | |
| 25/12/2024 07:00 | 48.76 | 0 | 98.01 | 0 | 36.1 | |
| 25/12/2024 08:00 | 48.88 | 0.05 | 97.85 | 0 | 37.5 | |
| 25/12/2024 09:00 | 48.97 | 0.02 | 96.85 | 0 | 39.7 | |
| 25/12/2024 10:00 | 48.34 | 0.05 | 96.95 | 0 | 39.5 | |
| 25/12/2024 11:00 | 47.84 | 0.1 | 96.88 | 0 | 38.9 | |
| 25/12/2024 12:00 | 44.09 | 0.05 | 97.54 | 0 | 37.4 | |
| 25/12/2024 13:00 | 32.17 | 0.13 | 94.81 | 0 | 35.8 | |
| 25/12/2024 14:00 | 34.41 | 0.16 | 95.46 | 0 | 26.5 | |
| 25/12/2024 15:00 | 34.37 | 0.14 | 95.13 | 0 | 26.4 | |
| 25/12/2024 16:00 | 34.29 | 0.12 | 94.96 | 0 | 26.2 | |
| 25/12/2024 17:00 | 34.07 | 0.12 | 94.66 | 0 | 25.9 | |
| 25/12/2024 18:00 | 34.01 | 0.12 | 94.48 | 0 | 25.7 | |
| 25/12/2024 19:00 | 33.82 | 0.1 | 94.53 | 0 | 25.4 | |
| 25/12/2024 20:00 | 33.89 | 0.16 | 94.53 | 0 | 25.2 | |
| 25/12/2024 21:00 | 34.08 | 0.2 | 94.79 | 0 | 25.2 | |
| 25/12/2024 22:00 | 31.17 | 0.11 | 94.1 | 0 | 33.1 | |
| 25/12/2024 23:00 | 1.87 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 00:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.1 | 0 | 25.2 | |
| MinDate | 26/12/2024 00:00 | 25/12/2024 00:00 | 25/12/2024 22:00 | 25/12/2024 00:00 | 25/12/2024 20:00 | |
| Maximum | 49.09 | 0.2 | 98.01 | 0 | 40.6 | |
| MaxDate | 25/12/2024 02:00 | 25/12/2024 21:00 | 25/12/2024 07:00 | 25/12/2024 00:00 | 25/12/2024 00:00 | |
| Avg | 38.72 | 0.08 | 96.02 | 0 | 33.8 | |
| Num | 25 | 25 | 23 | 23 | 23 | |
| Data[%] | 100 | 100 | 92 | 92 | 92 | |
| STD | 13.5 | 0.1 | 1.2 | 0 | 6.2 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 25/12/2024 00:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 01:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 02:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 03:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 04:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 05:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 06:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 07:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 08:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 10:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 11:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 12:00 | 5.74 | 0.08 | ShutDown | ShutDown | ShutDown | GT12 S/D |
| 25/12/2024 13:00 | 32.06 | 0.42 | 92.57 | 0 | 37.1 | |
| 25/12/2024 14:00 | 34.34 | 0.08 | 93.8 | 0 | 27.5 | |
| 25/12/2024 15:00 | 34.31 | 0.08 | 93.41 | 0 | 27.4 | |
| 25/12/2024 16:00 | 34.23 | 0.08 | 93.27 | 0 | 27.2 | |
| 25/12/2024 17:00 | 34 | 0.07 | 93.02 | 0 | 26.9 | |
| 25/12/2024 18:00 | 33.95 | 0.06 | 92.94 | 0 | 26.6 | |
| 25/12/2024 19:00 | 33.75 | 0.01 | 92.88 | 0 | 26.6 | |
| 25/12/2024 20:00 | 33.82 | 0.06 | 92.94 | 0 | 27.1 | |
| 25/12/2024 21:00 | 34.01 | 0.08 | 93.16 | 0 | 26.4 | |
| 25/12/2024 22:00 | 31.27 | 0.08 | 92.48 | 0 | 34.6 | |
| 25/12/2024 23:00 | 47.37 | 0.08 | 95.08 | 0 | 46.8 | |
| 26/12/2024 00:00 | 48.74 | 0.08 | 95.42 | 0 | 46.8 | |
| Minimum | 0 | 0.01 | 92.48 | 0 | 26.4 | |
| MinDate | 25/12/2024 00:00 | 25/12/2024 19:00 | 25/12/2024 22:00 | 25/12/2024 13:00 | 25/12/2024 21:00 | |
| Maximum | 48.74 | 0.42 | 95.42 | 0 | 46.8 | |
| MaxDate | 26/12/2024 00:00 | 25/12/2024 13:00 | 26/12/2024 00:00 | 25/12/2024 13:00 | 25/12/2024 23:00 | |
| Avg | 17.5 | 0.09 | 93.41 | 0 | 31.8 | |
| Num | 25 | 12 | 12 | 12 | 12 | |
| Data[%] | 100 | 100 | 48 | 48 | 48 | |
| STD | 18.6 | 0.1 | 0.9 | 0 | 7.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/12/2024 00:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 01:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 02:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 03:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 04:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 05:00 | 0 | 0.37 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 11:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 12:00 | 5.78 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 26/12/2024 13:00 | 32.35 | 0.1 | 94.21 | 0 | 35.6 | |
| 26/12/2024 14:00 | 34.37 | 0.15 | 95.6 | 0 | 27.1 | |
| 26/12/2024 15:00 | 34.17 | 0.22 | 95.1 | 0 | 26.6 | |
| 26/12/2024 16:00 | 34.14 | 0.16 | 95.01 | 0 | 26.3 | |
| 26/12/2024 17:00 | 33.94 | 0.1 | 94.88 | 0 | 26.2 | |
| 26/12/2024 18:00 | 33.84 | 0.02 | 94.69 | 0 | 26.1 | |
| 26/12/2024 19:00 | 33.67 | 0.04 | 94.62 | 0 | 26.1 | |
| 26/12/2024 20:00 | 33.81 | 0.12 | 94.72 | 0 | 25.9 | |
| 26/12/2024 21:00 | 33.91 | 0.1 | 94.77 | 0 | 25.9 | |
| 26/12/2024 22:00 | 29.5 | 0.12 | 95.43 | 0 | 42.9 | |
| 26/12/2024 23:00 | 0.61 | 0.18 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 00:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | 94.21 | 0 | 25.9 | |
| MinDate | 26/12/2024 00:00 | 26/12/2024 06:00 | 26/12/2024 13:00 | 26/12/2024 13:00 | 26/12/2024 20:00 | |
| Maximum | 34.37 | 0.45 | 95.6 | 0 | 42.9 | |
| MaxDate | 26/12/2024 14:00 | 26/12/2024 12:00 | 26/12/2024 14:00 | 26/12/2024 13:00 | 26/12/2024 22:00 | |
| Avg | 13.6 | 0.09 | 94.9 | 0 | 28.9 | |
| Num | 25 | 25 | 10 | 10 | 10 | |
| Data[%] | 100 | 100 | 40 | 40 | 40 | |
| STD | 16.5 | 0.1 | 0.4 | 0 | 5.7 | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 26/12/2024 00:00 | 48.74 | 0.08 | 95.42 | 0 | 46.8 | |
| 26/12/2024 01:00 | 48.85 | 0.08 | 95.98 | 0 | 46.7 | |
| 26/12/2024 02:00 | 48.95 | 0.08 | 95.77 | 0 | 48.2 | |
| 26/12/2024 03:00 | 48.81 | 0.07 | 95.69 | 0 | 48 | |
| 26/12/2024 04:00 | 48.75 | 0.08 | 95.54 | 0 | 48.6 | |
| 26/12/2024 05:00 | 48.57 | 0.08 | 95.47 | 0 | 47.8 | |
| 26/12/2024 06:00 | 48.51 | 0.08 | 95.52 | 0 | 46.4 | |
| 26/12/2024 07:00 | 48.35 | 0.08 | 95.88 | 0 | 45 | |
| 26/12/2024 08:00 | 48.53 | 0.08 | 95.64 | 0 | 46.3 | |
| 26/12/2024 09:00 | 48.83 | 0.08 | 95.26 | 0 | 49.2 | |
| 26/12/2024 10:00 | 48.85 | 0.08 | 95.13 | 0 | 49.2 | |
| 26/12/2024 11:00 | 48.64 | 0.08 | 95.06 | 0 | 49.3 | |
| 26/12/2024 12:00 | 44.16 | 0.08 | 95.28 | 0 | 42.8 | |
| 26/12/2024 13:00 | 32.33 | 0.38 | 93 | 0 | 33.4 | |
| 26/12/2024 14:00 | 34.3 | 0.08 | 93.78 | 0 | 24.7 | |
| 26/12/2024 15:00 | 34.08 | 0.08 | 93.35 | 0 | 24.3 | |
| 26/12/2024 16:00 | 34.06 | 0.08 | 93.17 | 0 | 24.1 | |
| 26/12/2024 17:00 | 33.87 | 0.08 | 93.07 | 0 | 24 | |
| 26/12/2024 18:00 | 33.78 | 0.08 | 92.9 | 0.1 | 24.1 | |
| 26/12/2024 19:00 | 33.61 | 0.08 | 92.84 | 0.1 | 25 | |
| 26/12/2024 20:00 | 33.75 | 0.08 | 93.1 | 0.1 | 24.3 | |
| 26/12/2024 21:00 | 33.9 | 0.08 | 93.04 | 0.2 | 23.8 | |
| 26/12/2024 22:00 | 28.66 | 0.08 | 92.01 | 0.3 | 43.2 | |
| 26/12/2024 23:00 | 48.08 | 0.08 | 95.4 | 0.3 | 45 | |
| 27/12/2024 00:00 | 48.48 | 0.08 | 94.91 | 0.4 | 45.6 | |
| Minimum | 28.66 | 0.07 | 92.01 | 0 | 23.8 | |
| MinDate | 26/12/2024 22:00 | 26/12/2024 03:00 | 26/12/2024 22:00 | 26/12/2024 00:00 | 26/12/2024 21:00 | |
| Maximum | 48.95 | 0.38 | 95.98 | 0.4 | 49.3 | |
| MaxDate | 26/12/2024 02:00 | 26/12/2024 13:00 | 26/12/2024 01:00 | 27/12/2024 00:00 | 26/12/2024 11:00 | |
| Avg | 42.3 | 0.09 | 94.49 | 0.1 | 39 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 7.7 | 0.1 | 1.3 | 0.1 | 10.8 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/12/2024 00:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 01:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 02:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 03:00 | 0 | 0.2 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 04:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 05:00 | 0 | 0.45 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 06:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 07:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 08:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 09:00 | 0 | 0.08 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 10:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 11:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 12:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 13:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 14:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 15:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 16:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 17:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 18:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 19:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 20:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 21:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 27/12/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | --- | --- | --- | |
| MinDate | 27/12/2024 00:00 | 27/12/2024 19:00 | 27/12/2024 00:00 | 27/12/2024 00:00 | 27/12/2024 00:00 | |
| Maximum | 0 | 0.45 | --- | --- | --- | |
| MaxDate | 27/12/2024 00:00 | 27/12/2024 05:00 | 27/12/2024 00:00 | 27/12/2024 00:00 | 27/12/2024 00:00 | |
| Avg | 0 | 0.12 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|---------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 27/12/2024 00:00 | 48.48 | 0.08 | 94.91 | 0.4 | 45.6 | |
| 27/12/2024 01:00 | 48.38 | 0.08 | 95.58 | 0.3 | 45.4 | |
| 27/12/2024 02:00 | 48.5 | 0.08 | 95.4 | 0.3 | 45.6 | |
| 27/12/2024 03:00 | 48.37 | 0.08 | 95.42 | 0.3 | 44.6 | |
| 27/12/2024 04:00 | 48.17 | 0.08 | 95.57 | 0.3 | 43.2 | |
| 27/12/2024 05:00 | 47.77 | 0.08 | 95.78 | 0.3 | 40.4 | |
| 27/12/2024 06:00 | 47.67 | 0.08 | 96.03 | 0.3 | 39.6 | |
| 27/12/2024 07:00 | 47.63 | 0.08 | 96.65 | 0.3 | 39.2 | |
| 27/12/2024 08:00 | 47.74 | 0.08 | 96.29 | 0.3 | 40.9 | |
| 27/12/2024 09:00 | 47.79 | 0.08 | 96.24 | 0.4 | 41.8 | |
| 27/12/2024 10:00 | 47.51 | 0.08 | 96.35 | 0.4 | 41 | |
| 27/12/2024 11:00 | 47.16 | 0.08 | 96.11 | 0.5 | 42.2 | |
| 27/12/2024 12:00 | 46.83 | 0.08 | 96.35 | 0.5 | 42.5 | |
| 27/12/2024 13:00 | 46.83 | 0.31 | 96.46 | 0.6 | 42.9 | |
| 27/12/2024 14:00 | 46.7 | 0.08 | 96.3 | 0.6 | 43.1 | |
| 27/12/2024 15:00 | 46.66 | 0.08 | 96.1 | 0.6 | 42.7 | |
| 27/12/2024 16:00 | 46.65 | 0.06 | 95.9 | 0.7 | 42.2 | |
| 27/12/2024 17:00 | 46.41 | 0.04 | 96.17 | 0.8 | 39.4 | |
| 27/12/2024 18:00 | 47.52 | 0.08 | 96.28 | 0.8 | 42.7 | |
| 27/12/2024 19:00 | 48.31 | 0.02 | 96.31 | 0.9 | 43.3 | |
| 27/12/2024 20:00 | 48.56 | 0.02 | 96.35 | 1 | 43.4 | |
| 27/12/2024 21:00 u. | 47.7 | 0.04 | 96.72 | 1.1 | 39.3 | |
| 27/12/2024 22:00 | 48.53 | 0.06 | 96.6 | 1.1 | 42.4 | |
| 27/12/2024 23:00 | 48.35 | 0.08 | 96.14 | 1.2 | 43.1 | |
| 28/12/2024 00:00 | 48.33 | 0.08 | 96.07 | 1.2 | 43.2 | |
| Minimum | 46.41 | 0.02 | 94.91 | 0.3 | 39.2 | |
| MinDate | 27/12/2024 17:00 | 27/12/2024 19:00 | 27/12/2024 00:00 | 27/12/2024 01:00 | 27/12/2024 07:00 | |
| Maximum | 48.56 | 0.31 | 96.72 | 1.2 | 45.6 | |
| MaxDate | 27/12/2024 20:00 | 27/12/2024 13:00 | 27/12/2024 21:00 | 27/12/2024 23:00 | 27/12/2024 00:00 | |
| Avg | 47.7 | 0.08 | 96.08 | 0.6 | 42.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 0.7 | 0.1 | 0.4 | 0.3 | 1.9 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 05:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 11:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 12:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 13:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 14:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 15:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 16:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 17:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 18:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 19:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 20:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 21:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 28/12/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | --- | --- | --- | |
| MinDate | 28/12/2024 00:00 | 28/12/2024 00:00 | 28/12/2024 00:00 | 28/12/2024 00:00 | 28/12/2024 00:00 | |
| Maximum | 0 | 0.23 | --- | --- | --- | |
| MaxDate | 28/12/2024 00:00 | 28/12/2024 05:00 | 28/12/2024 00:00 | 28/12/2024 00:00 | 28/12/2024 00:00 | |
| Avg | 0 | 0.03 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 28/12/2024 00:00 | 48.33 | 0.08 | 96.07 | 1.2 | 43.2 | |
| 28/12/2024 01:00 | 48.48 | 0.08 | 96.11 | 1.2 | 43.4 | |
| 28/12/2024 02:00 | 48.57 | 0.08 | 96.04 | 1.1 | 43.6 | |
| 28/12/2024 03:00 | 48.61 | 0.08 | 96.06 | 1.1 | 43.7 | |
| 28/12/2024 04:00 | 48.83 | 0.08 | 96.07 | 1 | 44.1 | |
| 28/12/2024 05:00 | 49.14 | 0.08 | 95.98 | 0.9 | 44.2 | |
| 28/12/2024 06:00 | 49.27 | 0.08 | 96.04 | 0.9 | 44.3 | |
| 28/12/2024 07:00 | 49.28 | 0.08 | 96.1 | 0.9 | 44.1 | |
| 28/12/2024 08:00 | 49.24 | 0.08 | 96.11 | 0.8 | 44 | |
| 28/12/2024 09:00 | 48.96 | 0.08 | 96 | 0.8 | 44.1 | |
| 28/12/2024 10:00 | 48.66 | 0.08 | 95.88 | 0.8 | 43.7 | |
| 28/12/2024 11:00 | 48.39 | 0.08 | 95.92 | 0.8 | 43.2 | |
| 28/12/2024 12:00 | 47.84 | 0.08 | 95.95 | 0.7 | 42.2 | |
| 28/12/2024 13:00 | 47.41 | 0.25 | 95.96 | 0.7 | 41.9 | |
| 28/12/2024 14:00 | 46.97 | 0.08 | 96.09 | 0.7 | 41.2 | |
| 28/12/2024 15:00 | 46.97 | 0.06 | 95.89 | 0.6 | 41.1 | |
| 28/12/2024 16:00 | 47.38 | 0.08 | 95.87 | 0.6 | 41.3 | |
| 28/12/2024 17:00 | 47.7 | 0.08 | 95.94 | 0.6 | 41.4 | |
| 28/12/2024 18:00 | 47.94 | 0.08 | 96.06 | 0.7 | 42 | |
| 28/12/2024 19:00 | 48.13 | 0.08 | 96.05 | 0.6 | 42.2 | |
| 28/12/2024 20:00 | 48.4 | 0.08 | 96.04 | 0.6 | 42.4 | |
| 28/12/2024 21:00 | 48.56 | 0.08 | 96.17 | 0.6 | 42.5 | |
| 28/12/2024 22:00 | 48.61 | 0.08 | 96.16 | 0.5 | 42.8 | |
| 28/12/2024 23:00 | 48.68 | 0.08 | 95.83 | 0.4 | 43.3 | |
| 29/12/2024 00:00 | 48.98 | 0.08 | 95.79 | 0.3 | 43.8 | |
| Minimum | 46.97 | 0.06 | 95.79 | 0.3 | 41.1 | |
| MinDate | 28/12/2024 14:00 | 28/12/2024 15:00 | 29/12/2024 00:00 | 29/12/2024 00:00 | 28/12/2024 15:00 | |
| Maximum | 49.28 | 0.25 | 96.17 | 1.2 | 44.3 | |
| MaxDate | 28/12/2024 07:00 | 28/12/2024 13:00 | 28/12/2024 21:00 | 28/12/2024 00:00 | 28/12/2024 06:00 | |
| Avg | 48.37 | 0.09 | 96.01 | 0.8 | 42.9 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 0.7 | 0 | 0.1 | 0.2 | 1 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 05:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 10:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 11:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 12:00 | 0 | 0.17 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 13:00 | 0 | 0.19 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 14:00 | 0 | 0.24 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 15:00 | 0 | 0.22 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 16:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 17:00 | 0 | 0.21 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 18:00 | 0 | 0.23 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 19:00 | 0 | 0.16 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 20:00 | 0 | 0.12 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 21:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 22:00 | 0 | 0.04 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 29/12/2024 23:00 | 0 | 0.02 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | --- | --- | --- | |
| MinDate | 29/12/2024 00:00 | 29/12/2024 00:00 | 29/12/2024 00:00 | 29/12/2024 00:00 | 29/12/2024 00:00 | |
| Maximum | 0 | 0.24 | --- | --- | --- | |
| MaxDate | 29/12/2024 00:00 | 29/12/2024 14:00 | 29/12/2024 00:00 | 29/12/2024 00:00 | 29/12/2024 00:00 | |
| Avg | 0 | 0.09 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 29/12/2024 00:00 | 48.98 | 0.08 | 95.79 | 0.3 | 43.8 | |
| 29/12/2024 01:00 | 49.16 | 0.08 | 95.5 | 0.2 | 43.9 | |
| 29/12/2024 02:00 | 49.27 | 0.08 | 95.17 | 0.1 | 42.6 | |
| 29/12/2024 03:00 | 49.26 | 0.08 | 95.04 | 0 | 42.9 | |
| 29/12/2024 04:00 | 49.28 | 0.08 | 95.04 | 0 | 41.9 | |
| 29/12/2024 05:00 | 49.28 | 0.07 | 95.26 | 0 | 40.5 | |
| 29/12/2024 06:00 | 49.29 | 0.08 | 95.55 | 0 | 39.6 | |
| 29/12/2024 07:00 | 49.29 | 0.08 | 95.62 | 0 | 41 | |
| 29/12/2024 08:00 | 49.29 | 0.08 | 95.7 | 0 | 41.7 | |
| 29/12/2024 09:00 | 49.26 | 0.08 | 95.47 | 0 | 42.7 | |
| 29/12/2024 10:00 | 48.89 | 0.08 | 95.18 | 0 | 43.2 | |
| 29/12/2024 11:00 | 48.25 | 0.08 | 95.13 | 0 | 42.1 | |
| 29/12/2024 12:00 | 47.74 | 0.08 | 95.15 | 0 | 41.1 | |
| 29/12/2024 13:00 | 47.53 | 0.42 | 95.23 | 0 | 40.8 | |
| 29/12/2024 14:00 | 47.28 | 0.08 | 95.35 | 0 | 40.3 | |
| 29/12/2024 15:00 | 47.27 | 0.08 | 95.31 | 0 | 40.1 | |
| 29/12/2024 16:00 | 47.32 | 0.08 | 95.13 | 0 | 40.1 | |
| 29/12/2024 17:00 | 47.69 | 0.08 | 95.12 | 0 | 40.5 | |
| 29/12/2024 18:00 | 47.98 | 0.08 | 95.39 | 0 | 40.7 | |
| 29/12/2024 19:00 | 48.66 | 0.08 | 95.55 | 0 | 41.2 | |
| 29/12/2024 20:00 | 48.99 | 0.08 | 95.71 | 0 | 41.3 | |
| 29/12/2024 21:00 | 49.26 | 0.08 | 95.79 | 0 | 40.7 | |
| 29/12/2024 22:00 | 49.22 | 0.08 | 95.63 | 0 | 41.3 | |
| 29/12/2024 23:00 | 49.25 | 0.08 | 95.5 | 0 | 41 | |
| 30/12/2024 00:00 | 49.25 | 0.08 | 95.34 | 0 | 41.1 | |
| Minimum | 47.27 | 0.07 | 95.04 | 0 | 39.6 | |
| MinDate | 29/12/2024 15:00 | 29/12/2024 05:00 | 29/12/2024 03:00 | 29/12/2024 03:00 | 29/12/2024 06:00 | |
| Maximum | 49.29 | 0.42 | 95.79 | 0.3 | 43.9 | |
| MaxDate | 29/12/2024 06:00 | 29/12/2024 13:00 | 29/12/2024 00:00 | 29/12/2024 00:00 | 29/12/2024 01:00 | |
| Avg | 48.68 | 0.09 | 95.39 | 0 | 41.4 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 0.8 | 0.1 | 0.2 | 0.1 | 1.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 05:00 | 0 | 0.4 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 10:00 | 0 | 0.01 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 11:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 12:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 13:00 | 0 | 0.11 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 14:00 | 0 | 0.15 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 15:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 16:00 | 0 | 0.1 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 17:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 18:00 | 0 | 0.05 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 19:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 20:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 21:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 30/12/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| Minimum | 0 | 0 | --- | --- | --- | |
| MinDate | 30/12/2024 00:00 | 30/12/2024 00:00 | 30/12/2024 00:00 | 30/12/2024 00:00 | 30/12/2024 00:00 | |
| Maximum | 0 | 0.4 | --- | --- | --- | |
| MaxDate | 30/12/2024 00:00 | 30/12/2024 05:00 | 30/12/2024 00:00 | 30/12/2024 00:00 | 30/12/2024 00:00 | |
| Avg | 0 | 0.05 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 30/12/2024 00:00 | 49.25 | 0.08 | 95.34 | 0 | 41.1 | |
| 30/12/2024 01:00 | 49.26 | 0.08 | 95.27 | 0 | 40.9 | |
| 30/12/2024 02:00 | 49.26 | 0.08 | 95.26 | 0 | 40.6 | |
| 30/12/2024 03:00 | 49.26 | 0.08 | 95.35 | 0 | 40.9 | |
| 30/12/2024 04:00 | 49.26 | 0.08 | 95.55 | 0 | 40.3 | |
| 30/12/2024 05:00 | 49.27 | 0.08 | 95.44 | 0 | 40.2 | |
| 30/12/2024 06:00 | 49.26 | 0.08 | 95.31 | 0 | 40.2 | |
| 30/12/2024 07:00 | 49.25 | 0.08 | 95.42 | 0 | 40.6 | |
| 30/12/2024 08:00 | 48.8 | 0.08 | 95.38 | 0 | 41 | |
| 30/12/2024 09:00 | 44.89 | 0.08 | 95.49 | 0 | 28.3 | |
| 30/12/2024 10:00 | 44.75 | 0.08 | 95.5 | 0 | 28.3 | |
| 30/12/2024 11:00 | 44.81 | 0.08 | 95.72 | 0 | 28.5 | |
| 30/12/2024 12:00 | 44.81 | 0.08 | 95.9 | 0 | 28.6 | |
| 30/12/2024 13:00 | 44.85 | 0.35 | 96.13 | 0 | 28.9 | |
| 30/12/2024 14:00 | 44.82 | 0.08 | 96.08 | 0 | 29.1 | |
| 30/12/2024 15:00 | 44.81 | 0.08 | 96.03 | 0 | 29.2 | |
| 30/12/2024 16:00 | 44.82 | 0.08 | 95.96 | 0 | 28.7 | |
| 30/12/2024 17:00 | 44.66 | 0.08 | 95.36 | 0 | 28 | |
| 30/12/2024 18:00 | 48.24 | 0.08 | 94.31 | 0 | 39.4 | |
| 30/12/2024 19:00 | 48.65 | 0.08 | 94.94 | 0 | 40.1 | |
| 30/12/2024 20:00 | 48.89 | 0.08 | 95.57 | 0 | 38.9 | |
| 30/12/2024 21:00 | 46.5 | 0.08 | 95.65 | 0 | 33.2 | |
| 30/12/2024 22:00 | 44.23 | 0.08 | 95.63 | 0 | 26.2 | |
| 30/12/2024 23:00 | 44.43 | 0.08 | 95.71 | 0 | 26.1 | |
| 31/12/2024 00:00 | 44.45 | 0.08 | 95.49 | 0 | 26.4 | |
| Minimum | 44.23 | 0.08 | 94.31 | 0 | 26.1 | |
| MinDate | 30/12/2024 22:00 | 30/12/2024 00:00 | 30/12/2024 18:00 | 30/12/2024 00:00 | 30/12/2024 23:00 | |
| Maximum | 49.27 | 0.35 | 96.13 | 0 | 41.1 | |
| MaxDate | 30/12/2024 05:00 | 30/12/2024 13:00 | 30/12/2024 13:00 | 30/12/2024 00:00 | 30/12/2024 00:00 | |
| Avg | 46.86 | 0.09 | 95.51 | 0 | 34.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 2.2 | 0.1 | 0.4 | 0 | 6.2 | |

| Date & Time | 11GT_LOAD | 11HRSG_DUST | 11HRSG_TEMP | 11HRSG_SO2@7%O2 | 11HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|----------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/12/2024 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 01:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 02:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 03:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 04:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 05:00 | 0 | 0.3 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 06:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 07:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 08:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 09:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 10:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 11:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 12:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 13:00 | 0 | 0.13 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 14:00 | 0 | 0.14 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 15:00 | 0 | 0.09 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 16:00 | 0 | 0.07 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 17:00 | 0 | 0.06 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 18:00 | 0 | 0.03 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 19:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 20:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 21:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 22:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 31/12/2024 23:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| 01/01/2025 00:00 | 0 | 0 | ShutDown | ShutDown | ShutDown | GT11 S/D |
| MinDate | 31/12/2024 00:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | |
| MinDate | 31/12/2024 00:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | |
| Maximum | 0 | 0.3 | --- | --- | --- | |
| MaxDate | 31/12/2024 00:00 | 31/12/2024 05:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | 31/12/2024 00:00 | |
| Avg | 0 | 0.04 | --- | --- | --- | |
| Num | 25 | 25 | 0 | 0 | 0 | |
| Data[%] | 100 | 100 | --- | --- | --- | |
| STD | 0 | 0.1 | --- | --- | --- | |

| Date & Time | 12GT_LOAD | 12HRSG_DUST | 12HRSG_TEMP | 12HRSG_SO2@7%O2 | 12HRSG_NOx@7%O2 | Remark |
|------------------|------------------|------------------|------------------|------------------|------------------|--------|
| | MW | mg/m3 | Degree C. | ppm | ppm | |
| 31/12/2024 00:00 | 44.45 | 0.08 | 95.49 | 0 | 26.4 | |
| 31/12/2024 01:00 | 44.51 | 0.08 | 95.42 | 0 | 26.6 | |
| 31/12/2024 02:00 | 44.44 | 0.08 | 95.18 | 0 | 26.6 | |
| 31/12/2024 03:00 | 44.43 | 0.08 | 95.12 | 0 | 26.7 | |
| 31/12/2024 04:00 | 44.41 | 0.08 | 95.13 | 0 | 26.6 | |
| 31/12/2024 05:00 | 44.43 | 0.08 | 95.4 | 0 | 26.7 | |
| 31/12/2024 06:00 | 44.39 | 0.08 | 95.02 | 0 | 26.5 | |
| 31/12/2024 07:00 | 44.26 | 0.08 | 94.95 | 0 | 26.1 | |
| 31/12/2024 08:00 | 44.31 | 0.08 | 95.05 | 0 | 26 | |
| 31/12/2024 09:00 | 44.4 | 0.08 | 95.05 | 0 | 26 | |
| 31/12/2024 10:00 | 44.47 | 0.08 | 95.14 | 0 | 26.3 | |
| 31/12/2024 11:00 | 44.57 | 0.08 | 95.38 | 0 | 26.8 | |
| 31/12/2024 12:00 | 44.57 | 0.08 | 95.69 | 0 | 26.7 | |
| 31/12/2024 13:00 | 44.57 | 0.29 | 95.81 | 0 | 27.1 | |
| 31/12/2024 14:00 | 44.59 | 0.08 | 95.97 | 0 | 27.5 | |
| 31/12/2024 15:00 | 44.57 | 0.08 | 95.73 | 0 | 26.9 | |
| 31/12/2024 16:00 | 44.6 | 0.08 | 95.64 | 0 | 26.6 | |
| 31/12/2024 17:00 | 44.58 | 0.08 | 95.34 | 0 | 26.3 | |
| 31/12/2024 18:00 | 48.48 | 0.08 | 95.11 | 0 | 38.4 | |
| 31/12/2024 19:00 | 48.87 | 0.08 | 95.08 | 0 | 39 | |
| 31/12/2024 20:00 | 49.18 | 0.08 | 95.14 | 0 | 38.9 | |
| 31/12/2024 21:00 | 46.79 | 0.08 | 95.15 | 0 | 32.3 | |
| 31/12/2024 22:00 | 44.51 | 0.08 | 95.21 | 0 | 25 | |
| 31/12/2024 23:00 | 44.51 | 0.08 | 95.2 | 0 | 24.8 | |
| 01/01/2025 00:00 | 44.51 | 0.08 | 95.45 | 0 | 24.6 | |
| MinDate | 31/12/2024 07:00 | 31/12/2024 00:00 | 31/12/2024 07:00 | 31/12/2024 00:00 | 01/01/2025 00:00 | |
| MinDate | 31/12/2024 07:00 | 31/12/2024 00:00 | 31/12/2024 07:00 | 31/12/2024 00:00 | 01/01/2025 00:00 | |
| Maximum | 49.18 | 0.29 | 95.97 | 0 | 39 | |
| MaxDate | 31/12/2024 20:00 | 31/12/2024 13:00 | 31/12/2024 14:00 | 31/12/2024 00:00 | 31/12/2024 19:00 | |
| Avg | 45.1 | 0.09 | 95.31 | 0 | 28.1 | |
| Num | 25 | 25 | 25 | 25 | 25 | |
| Data[%] | 100 | 100 | 100 | 100 | 100 | |
| STD | 1.5 | 0 | 0.3 | 0 | 4.3 | |

ภาคผนวก ข.5.2

ระบบเตือน (Alarm) ควบคุมค่าการระบาย NO_x

ภาคผนวก ข.5.3

รายงานการสอบเทียบ CEMs

INSTRUMENT CALIBRATION REPORT

B.Grimm Power (WHA) 1 Company Limited

PROJECT

Calibration Instrument 2024

24 July 2024



B.GRIMM POWER (WHA) 1 COMPANY LIMITED
369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi
20230, Thailand



PROSPEC TECHNOLOGY CO.,LTD.
122/68 Moo.1 Tambol Banchang, Amphur Banchang, Rayong 21130
Tel : 086-527-6075, Fax : 074-801-885 www.prospec-tech.com

PRO
SPEC

PROSPEC TECHNOLOGY CO.,LTD.
122/68 Moo.1 Tambol Banchang, Amphur Banchang, Rayong 21130 Thailand
Tel : 086-527-6075, Fax : 074-801-885
E-mail : info.prospec@gmail.com www.prospec-tech.com

Work Illustration

Customer : B.Grimm Power (WHA) 1 Company Limited

Location : 369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi 20230, Thailand

Project : Calibration Instrument 2024

Date : 24 July 2024

 Calibration Process Flow Transmitter



🔧 Calibration Process Temperature Element & Temperature Transmitter



🔧 Loop Test



**PROSPEC TECHNOLOGY CO.,LTD.**

122/68 Moo.1 Tambol Banchang, Amphur Banchang, Rayong 21130 Thailand
Tel : 086 527-6075, Fax : 074-801-885
E-mail: info.prospec@gmail.com www.prospec-tech.com

REPORT LIST OF FLOW TRANSMITTER

| Item | Tag No. | Certificate No. | Service Detail | Cal Range | Type | Manufacturer | Model | Serial No. | Cal Date | Remark |
|------|--------------|------------------|--------------------------------|-----------------|-----------------------|--------------|-------|----------------|-----------|--------|
| 1 | 11HNE10CF001 | P24-BPWHA-FT-001 | HRSG No.11 FLUE GAS STACK FLOW | 0 to 5 mbar (G) | Differential Pressure | ABB | 2600T | 3K646618043466 | 24/7/2024 | |
| 2 | 12HNE10CF001 | P24-BPWHA-FT-002 | HRSG No.12 FLUE GAS STACK FLOW | 0 to 5 mbar (G) | Differential Pressure | ABB | 2600T | 3K650000259646 | 24/7/2024 | |

CALIBRATION CERTIFICATE**PRO
SPEC**Certificate No. **P24-BPWHA-FT-001**

Page 1 of 1

Instrument : **Flow Transmitter****PROSPEC TECHNOLOGY CO.,LTD.**

122/68 Moo.1 Tambol Banchang, A. Banchang,
Rayong 21130 Thailand www.prospec-tech.com

| | | | |
|-------------------|--------------------------------|-----------------|-------------------------|
| Instr. Tag/ID No. | 11HNE10CF001 | Type | Differential Pressure |
| Manufacturer | ABB | Calibrate range | 0 to 5 mbar (G) |
| Model No. | 2600T | Output Signal | 4.00 to 20.00 mA (SqRt) |
| Serial No. | 3K646618043466 | Resolution | N/A |
| Service Detail | HRSG No.11 FLUE GAS STACK FLOW | Error allowance | ± 0.5 % of span |

Customer : **B.Grimm Power (WHA) 1 Company Limited**
369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi 20230, Thailand


Environment Conditions : Temperature (30 ± 5) °C

Relative Humidity (55 ± 25) %

CALIBRATION

| Desired input (%) | Simulated input mbar (G) | Desired output mA (SqRt) | As Found | | As Left | |
|----------------------|-----------------------------|-----------------------------|---------------------------------|-------------------|---------------------------------|-------------------|
| | | | Actual output (mA) mA (SqRt) | Error [% of span] | Actual output (mA) mA (SqRt) | Error [% of span] |
| 0 | 0.00 | 4.000 | 3.998 | -0.01 | 3.998 | -0.01 |
| 25 | 1.25 | 12.000 | 11.949 | -0.32 | 12.012 | 0.08 |
| 50 | 2.50 | 15.314 | 15.281 | -0.21 | 15.316 | 0.01 |
| 75 | 3.75 | 17.856 | 17.783 | -0.46 | 17.850 | -0.04 |
| 100 | 5.00 | 20.000 | 19.574 | -2.66 | 19.990 | -0.06 |
| 75 | 3.75 | 17.856 | 17.782 | -0.46 | 17.851 | -0.03 |
| 50 | 2.50 | 15.314 | 15.281 | -0.21 | 15.316 | 0.01 |
| 25 | 1.25 | 12.000 | 11.949 | -0.32 | 12.012 | 0.08 |
| 0 | 0.00 | 4.000 | 3.998 | -0.01 | 3.998 | -0.01 |

| | Min | Max | Average | | | | | |
|----------|------|------|---------|-------|-------|-------|-------|---|
| | | | 0 | 25 | 50 | 75 | 100 | % |
| As Found | 0.01 | 2.66 | -0.01 | -0.32 | -0.21 | -0.46 | -2.66 | % |
| As Left | 0.01 | 0.08 | -0.02 | 0.11 | 0.02 | -0.06 | -0.06 | % |



Calibration Method : The Unit Under of Calibration (UUC) was calibrated by comparison with Reference Standard as below .

REFERENCE STANDARD

| Item | Instrument | Model | Serial No. | Certificate No. | Due Date |
|------|------------------------|--------|------------|------------------|-------------|
| 1 | Digital Pressure Gauge | HS 108 | 1501119048 | 5523631030938901 | 20 May 2025 |
| 2 | Process Meter | 789 | 34690021 | RA-2405062-2 | 22 May 2025 |

| | | | |
|--------------------|------------------|---------------|--------------------------|
| Calibrated by : | Ammarat Khaichan | Approved by : | [Pongsathon Charoensong] |
| Calibration Date : | 24 July 2024 | Issue Date : | 26 July 2024 |

CALIBRATION CERTIFICATE

PRO
SPEC

Certificate No. P24-BPWH-A-FT-002

Page 1 of 1

Instrument : **Flow Transmitter**
PROSPEC TECHNOLOGY CO.,LTD.
 122/68 Moo.1 Tambol Banchang, A. Banchang,
 Rayong 21130 Thailand www.prospec-tech.com

| | | | |
|-------------------|--------------------------------|-----------------|-------------------------|
| Instr. Tag/ID No. | 12HNE10CF001 | Type | Differential Pressure |
| Manufacturer | ABB | Calibrate range | 0 to 5 mbar (G) |
| Model No. | 2600T | Output Signal | 4.00 to 20.00 mA (SqRt) |
| Serial No. | 3K650000259646 | Resolution | N/A |
| Service Detail | HRSG No.12 FLUE GAS STACK FLOW | Error allowance | ± 0.5 % of span |


Customer : **B.Grimm Power (WHA) 1 Company Limited**
 369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi 20230, Thailand

Environment Conditions : Temperature (30 ± 5) °C Relative Humidity (55 ± 25) %

CALIBRATION

| Desired input (%) | Simulated input mbar (G) | Desired output mA (SqRt) | As Found | | As Left | |
|----------------------|-----------------------------|-----------------------------|---------------------------------|-------------------|---------------------------------|-------------------|
| | | | Actual output (mA) mA (SqRt) | Error [% of span] | Actual output (mA) mA (SqRt) | Error [% of span] |
| 0 | 0.00 | 4.000 | 4.002 | 0.01 | | |
| 25 | 1.25 | 12.000 | 12.019 | 0.12 | | |
| 50 | 2.50 | 15.314 | 15.325 | 0.07 | | |
| 75 | 3.75 | 17.856 | 17.878 | 0.14 | | |
| 100 | 5.00 | 20.000 | 20.048 | 0.30 | | |
| 75 | 3.75 | 17.856 | 17.877 | 0.13 | | |
| 50 | 2.50 | 15.314 | 15.325 | 0.07 | | |
| 25 | 1.25 | 12.000 | 12.019 | 0.12 | | |
| 0 | 0.00 | 4.000 | 4.001 | 0.01 | | |

| | Min | Max | Average | | | | | |
|----------|------|------|---------|------|------|------|------|---|
| | | | 0 | 25 | 50 | 75 | 100 | % |
| As Found | 0.01 | 0.30 | 0.01 | 0.12 | 0.07 | 0.13 | 0.30 | % |
| As Left | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | % |



Calibration Method : The Unit Under of Calibration (UUC) was calibrated by comparison with Reference Standard as below .

REFERENCE STANDARD

| Item | Instrument | Model | Serial No. | Certificate No. | Due Date |
|------|------------------------|--------|------------|------------------|-------------|
| 1 | Digital Pressure Gauge | HS 108 | 1501119048 | 5523631030938901 | 20 May 2025 |
| 2 | Process Meter | 789 | 34690021 | RA-2405062-2 | 22 May 2025 |

Calibrated by : Ammarat Khaichan Approved by : [Pongsathon Charoensong]

Calibration Date : 24 July 2024 Issue Date : 26 July 2024

PRO
SPEC

PROSPEC TECHNOLOGY CO.,LTD.

122/68 Moo.1 Tambol Banchang, Amphur Banchang, Rayong 21130 Thailand
 Tel : 086 527-6075, Fax : 074-801-885
 E-mail: info.prospec@gmail.com www.prospec-tech.com

REPORT LIST OF TEMPERATURE ELEMENT

| Item | Tag No. | Certificate No. | Service Detail | Cal Range | Type | Manufacturer | Model | Serial No. | Cal Date | Remark |
|------|--------------|-------------------|---------------------------------------|-------------|--------|----------------|----------|------------|-----------|--------|
| 1 | 11HNE10CT003 | T24-BPWH-A-TE-001 | HRSG No.11 FLUE GAS STACK TEMPERATURE | 0 to 200 °C | TC (K) | PR ELECTRONICS | 53343B3B | 182061755 | 24/7/2024 | |
| 2 | 12HNE10CT003 | T24-BPWH-A-TE-002 | HRSG No.12 FLUE GAS STACK TEMPERATURE | 0 to 200 °C | TC (K) | PR ELECTRONICS | 53343B3B | 121355435 | 24/7/2024 | |

CALIBRATION CERTIFICATE

PRO
SPEC

Certificate No. T24-BPWA-TE-001 Page 1 of 1

Instrument : **Temperature Element** **PROSPEC TECHNOLOGY CO.,LTD.**
122/68 Moo.1 Tambol Banchang, A. Banchang,
Rayong 21130 Thailand www.prospec-tech.com

| | | | |
|-------------------|---------------------------------------|-----------------|--------------|
| Instr. Tag/ID No. | 11HNE10CT003 | Type | TC (K) |
| Manufacturer | PR ELECTRONICS | Calibrate range | 0 to 200 °C |
| Model No. | 53343B3B | Output Signal | N/A |
| Serial No. | 182061755 | Resolution | N/A |
| Service Detail | HRSG No.11 FLUE GAS STACK TEMPERATURE | Error allowance | ± 1% of span |


Customer : **B.Grimm Power (WHA) 1 Company Limited**
369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi 20230, Thailand

Environment Conditions : Temperature (30 ± 5) °C Relative Humidity (55 ± 25) %

CALIBRATION

| Temp. Setting (°C) | Std. Reading (°C) | Desired output (mA) | As Found | | As Left | |
|-----------------------|----------------------|------------------------|---------------------|-------------------|---------------------|-------------------|
| | | | Actual Reading (°C) | Error [% of span] | Actual Reading (°C) | Error [% of span] |
| Ambient | 30.80 | - | 31.2 | 0.20 | | |
| 100 | 100.02 | - | 101.6 | 0.79 | | |
| 150 | 150.04 | - | 150.4 | 0.18 | | |
| 200 | 200.06 | - | 200.9 | 0.42 | | |

| | Min | Max | Average | | | |
|----------|------|------|---------|------|------|--------|
| | | | Ambient | 100 | 150 | 200 °C |
| As Found | 0.18 | 0.79 | 0.20 | 0.79 | 0.18 | 0.42 % |



Calibration Method : The Unit Under of Calibration (UUC) was calibrated by comparison with Reference Standard as below .

REFERENCE STANDARD

| Item | Instrument | Model | Serial No. | Certificate No. | Due Date |
|------|----------------------------------|-----------|------------|------------------|------------------|
| 1 | Tecal Calibrator | FDB425HA | 104637-11 | 231109CA29 | 13 November 2024 |
| 2 | Platinum Resistance Thermometer | 1/5 DIN-A | 190.08.15 | SG-T-00466/67 | 21 May 2025 |
| 3 | Multifunction Process Calibrator | 725 | 1157112 | 5523631030524006 | 28 November 2024 |

| | |
|---------------------------------|--|
| Calibrated by : Nawee Tappalak | Approved by : [Pongsathon Charoensong] |
| Calibration Date : 24 July 2024 | Issue Date : 26 July 2024 |

CALIBRATION CERTIFICATE

PRO
SPEC

Certificate No. T24-BPWA-TE-002 Page 1 of 1

Instrument : **Temperature Element** **PROSPEC TECHNOLOGY CO.,LTD.**
122/68 Moo.1 Tambol Banchang, A. Banchang,
Rayong 21130 Thailand www.prospec-tech.com

| | | | |
|-------------------|---------------------------------------|-----------------|--------------|
| Instr. Tag/ID No. | 12HNE10CT003 | Type | TC (K) |
| Manufacturer | PR ELECTRONICS | Calibrate range | 0 to 200 °C |
| Model No. | 53343B3B | Output Signal | N/A |
| Serial No. | 121355435 | Resolution | N/A |
| Service Detail | HRSG No.12 FLUE GAS STACK TEMPERATURE | Error allowance | ± 1% of span |


Customer : **B.Grimm Power (WHA) 1 Company Limited**
369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi 20230, Thailand

Environment Conditions : Temperature (30 ± 5) °C Relative Humidity (55 ± 25) %

CALIBRATION

| Temp. Setting (°C) | Std. Reading (°C) | Desired output (mA) | As Found | | As Left | |
|-----------------------|----------------------|------------------------|---------------------|-------------------|---------------------|-------------------|
| | | | Actual Reading (°C) | Error [% of span] | Actual Reading (°C) | Error [% of span] |
| Ambient | 32.40 | - | 32.2 | -0.10 | | |
| 100 | 99.99 | - | 99.6 | -0.20 | | |
| 150 | 150.02 | - | 149.4 | -0.31 | | |
| 200 | 200.04 | - | 199.5 | -0.27 | | |

| | Min | Max | Average | | | |
|----------|------|------|---------|-------|-------|---------|
| | | | Ambient | 100 | 150 | 200 °C |
| As Found | 0.10 | 0.31 | -0.10 | -0.20 | -0.31 | -0.27 % |



Calibration Method : The Unit Under of Calibration (UUC) was calibrated by comparison with Reference Standard as below .

REFERENCE STANDARD

| Item | Instrument | Model | Serial No. | Certificate No. | Due Date |
|------|----------------------------------|-----------|------------|------------------|------------------|
| 1 | Tecal Calibrator | FDB425HA | 104637-11 | 231109CA29 | 13 November 2024 |
| 2 | Platinum Resistance Thermometer | 1/5 DIN-A | 190.08.15 | SG-T-00466/67 | 21 May 2025 |
| 3 | Multifunction Process Calibrator | 725 | 1157112 | 5523631030524006 | 28 November 2024 |

| | |
|---------------------------------|--|
| Calibrated by : Nawee Tappalak | Approved by : [Pongsathon Charoensong] |
| Calibration Date : 24 July 2024 | Issue Date : 26 July 2024 |

**PROSPEC TECHNOLOGY CO.,LTD.**

122/68 Moo.1 Tambol Banchang, Amphur Banchang, Rayong 21130 Thailand
Tel : 086 527-6075, Fax : 074-801-885
E-mail: info.prospec@gmail.com www.prospec-tech.com

REPORT LIST OF TEMPERATURE TRANSMITTER

| Item | Tag No. | Certificate No. | Service Detail | Cal Range | Type | Manufacturer | Model | Serial No. | Cal Date | Remark |
|------|--------------|------------------|---------------------------------------|-------------|--------|----------------|----------|------------|-----------|--------|
| 1 | 11HNE10CT003 | T24-BPWAH-TT-001 | HRSG No.11 FLUE GAS STACK TEMPERATURE | 0 to 200 °C | TC (K) | PR ELECTRONICS | 53343B3B | 182061755 | 24/7/2024 | |
| 2 | 12HNE10CT003 | T24-BPWAH-TT-002 | HRSG No.12 FLUE GAS STACK TEMPERATURE | 0 to 200 °C | TC (K) | PR ELECTRONICS | 53343B3B | 121355435 | 24/7/2024 | |

CALIBRATION CERTIFICATE**PRO
SPEC**Certificate No. **T24-BPWAH-TT-001**

Page 1 of 1

Instrument : **Temperature Transmitter****PROSPEC TECHNOLOGY CO.,LTD.**

122/68 Moo.1 Tambol Banchang, A. Banchang,
Rayong 21130 Thailand www.prospec-tech.com

| | | | |
|-------------------|---------------------------------------|-----------------|------------------|
| Instr. Tag/ID No. | 11HNE10CT003 | Type | TC (K) |
| Manufacturer | PR ELECTRONICS | Calibrate range | 0 to 200 °C |
| Model No. | 53343B3B | Output Signal | 4.00 to 20.00 mA |
| Serial No. | 182061755 | Resolution | N/A |
| Service Detail | HRSG No.11 FLUE GAS STACK TEMPERATURE | Error allowance | ± 0.5% of span |

Customer : **B.Grimm Power (WHA) 1 Company Limited**
369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi 20230, Thailand


Environment Conditions : Temperature (30 ± 5) °C

Relative Humidity (55 ± 25) %

CALIBRATION

| Setting (°C) | Desired output (mA) | As Found | | As Left | |
|-----------------|------------------------|---------------------|-------------------|---------------------|-------------------|
| | | Actual Reading (mA) | Error [% of span] | Actual Reading (mA) | Error [% of span] |
| 0 | 4.000 | 3.973 | -0.17 | | |
| 50 | 8.000 | 7.972 | -0.17 | | |
| 100 | 12.000 | 11.968 | -0.20 | | |
| 150 | 16.000 | 15.973 | -0.17 | | |
| 200 | 20.000 | 19.970 | -0.19 | | |
| 150 | 16.000 | 15.974 | -0.16 | | |
| 100 | 12.000 | 11.968 | -0.20 | | |
| 50 | 8.000 | 7.973 | -0.17 | | |
| 0 | 4.000 | 3.973 | -0.17 | | |

| | Min | Max | Average | | | | | |
|----------|------|------|---------|-------|-------|-------|-------|----|
| | | | 0 | 50 | 100 | 150 | 200 | °C |
| As Found | 0.16 | 0.20 | -0.17 | -0.17 | -0.20 | -0.17 | -0.19 | % |
| As Left | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | % |



Calibration Method : The Unit Under of Calibration (UUC) was calibrated by comparison with Reference Standard as below .

REFERENCE STANDARD

| Item | Instrument | Model | Serial No. | Certificate No. | Due Date |
|------|---------------------------------|-------|------------|------------------|------------------|
| 1 | Multifuction Process Calibrator | 725 | 1157112 | 5523631030524000 | 28 November 2024 |
| 2 | Process Meter | 789 | 34690021 | RA-2405062-2 | 22 May 2025 |

| | | | |
|--------------------|----------------|---------------|----------------------------|
| Calibrated by : | Nawee Tappalak | Approved by : | [Pongsathon Charoensong] |
| Calibration Date : | 24 July 2024 | Issue Date : | 26 July 2024 |

CALIBRATION CERTIFICATE

PRO
SPEC

Certificate No. T24-BPWHA-TT-002

Page 1 of 1

| | | | |
|--|---------------------------------------|---|------------------|
| Instrument : Temperature Transmitter | | PROSPEC TECHNOLOGY CO.,LTD. 122/68 Moo.1 Tambol Banchang, A. Banchang, Rayong 21130 Thailand www.prospec-tech.com | |
| Instr. Tag/ID No. | 12HNE10CT003 | Type | TC (K) |
| Manufacturer | PR ELECTRONICS | Calibrate range | 0 to 200 °C |
| Model No. | 53343B3B | Output Signal | 4.00 to 20.00 mA |
| Serial No. | 121355435 | Resolution | N/A |
| Service Detail | HRSG No.12 FLUE GAS STACK TEMPERATURE | Error allowance | ± 0.5% of span |
| Customer : B.Grimm Power (WHA) 1 Company Limited 369/27 Moo 6, Tambol Bowin, Amphur Sriracha, Chonburi 20230, Thailand | | | |


Environment Conditions : Temperature (30 ± 5) °C

Relative Humidity (55 ± 25) %

CALIBRATION

| Setting (°C) | Desired output (mA) | As Found | | As Left | |
|-----------------|------------------------|---------------------|-------------------|---------------------|-------------------|
| | | Actual Reading (mA) | Error [% of span] | Actual Reading (mA) | Error [% of span] |
| 0 | 4.000 | 3.967 | -0.21 | | |
| 50 | 8.000 | 7.966 | -0.21 | | |
| 100 | 12.000 | 11.964 | -0.22 | | |
| 150 | 16.000 | 15.961 | -0.24 | | |
| 200 | 20.000 | 19.964 | -0.23 | | |
| 150 | 16.000 | 15.962 | -0.24 | | |
| 100 | 12.000 | 11.964 | -0.22 | | |
| 50 | 8.000 | 7.966 | -0.21 | | |
| 0 | 4.000 | 3.967 | -0.21 | | |

| | Min | Max | Average | | | | | |
|----------|------|------|---------|-------|-------|-------|-------|----|
| | | | 0 | 50 | 100 | 150 | 200 | °C |
| As Found | 0.21 | 0.24 | -0.21 | -0.21 | -0.22 | -0.24 | -0.23 | % |
| As Left | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | % |



Calibration Method : The Unit Under of Calibration (UUC) was calibrated by comparison with Reference Standard as below .

REFERENCE STANDARD

| Item | Instrument | Model | Serial No. | Certificate No. | Due Date |
|------|---------------------------------|-------|------------|------------------|------------------|
| 1 | Multifuction Process Calibrator | 725 | 1157112 | 5523631030524000 | 28 November 2024 |
| 2 | Process Meter | 789 | 34690021 | RA-2405062-2 | 22 May 2025 |

| | |
|---------------------------------|--|
| Calibrated by : Nawee Tappalak | Approved by : [Pongsathon Charoensong] |
| Calibration Date : 24 July 2024 | Issue Date : 26 July 2024 |

PRO
SPEC

PROSPEC TECHNOLOGY CO.,LTD.

122/68 Moo.1 Tambol Banchang, A. Banchang, Rayong 21130 Thailand

Tel: 086-527-6075, Fax : 074-801-885

E-mail : info.prospec@gmail.com www.prospec-tech.com

LOOP TEST REPORT OF TEMPERATURE

| Item | Tag No. | DCS Display | Input Source Point | | | | | Remark |
|------|--------------|-------------|--------------------|----------|-----------|-----------|------------|--------|
| | | | 4 mA 0% | 8 mA 25% | 12 mA 50% | 16 mA 75% | 20 mA 100% | |
| 1 | 11HNE10CT003 | 0 to 200 °C | -0.2 | 49.6 | 99.4 | 149.3 | 199.1 | |
| 2 | 12HNE10CT003 | 0 to 600 °C | -0.2 | 49.5 | 99.4 | 149.3 | 199.1 | |

LOOP TEST REPORT OF FLOW TRANSMITTER

| Item | Tag No. | DCS Display | Input Source Point | | | | | Remark |
|------|--------------|--------------------------------|--------------------|----------|-----------|-----------|------------|--------|
| | | | 4 mA 0% | 8 mA 25% | 12 mA 50% | 16 mA 75% | 20 mA 100% | |
| 1 | 11HNE10CF001 | 0 to 700,000 m ³ /h | 1039 | 106179 | 211753 | 317186 | 418634 | |
| 2 | 12HNE10CF001 | 0 to 700,000 m ³ /h | 2180 | 105874 | 209781 | 313889 | 414092 | |

| | |
|----------------------------|--|
| Test by : Ammarat Khaichan | Approved by : [Pongsathon Charoensong] |
| Date : 24 July 2024 | Date : 26 July 2024 |

Tool Certificate



MICRO PRECISION CALIBRATION LABORATORY (THAILAND) CO., LTD.
413 BONDSTREET ROAD, TAMBOL BANGPOODAMPHOE PAKKRED, NONTHABURI
NONTABURI 11120 THAILAND
66 2 583 9834



Certificate of Calibration

Cert No. 5523631030938901

Date: May 22, 2024

Customer:
PROSPEC TECHNOLOGY CO.,LTD
181/26 MOO.11 T.KLONG HAE A.HATYAI ,
SONGKHLA 90110

Work Order #: THAI-32262897

MPC Control #: 1501119048
Asset ID: PSS-DTG-05
Gage Type: DIGITAL PRESSURE GAUGE
Manufacturer: SINO INSTRUMENTS
Model Number: HS 108
Size: -10 to 10 Kpa
Temp/RH: 20.5°C / 55.0%
Location: Calibration performed at MPC facility

Serial Number: 1501119048
Department: N/A
Performed By: WATTANA TANGCHAROEN
Received Condition: IN TOLERANCE
Returned Condition: IN TOLERANCE
Cal. Date: May 21, 2024
Cal. Interval: 12 MONTHS
Cal. Due Date: May 21, 2025

Calibration Notes:
Please refer to the attached Calibration Report (3 pages)

Standards Used to Calibrate Equipment

| I.D. | Description | Model | Serial | Manufacturer | Cal. Due Date | Traceability # |
|--------|-----------------------------|----------------|--------|------------------------------|---------------|--------------------------|
| CA2488 | DIGITAL PRESSURE CONTROLLER | 7250I | 57280 | RUSKA INSTRUMENT CORPORATION | Oct 5, 2024 | 5523631030393149 / MP-TH |
| AX7440 | DEAD WEIGHT TESTER | 2465-752-68100 | 42022 | RUSKA INSTRUMENT CORPORATION | Apr 24, 2025 | MP-0071-20 / NIMT |

Procedures Used in this Event

| Procedure Name | Description |
|-----------------------|--|
| DKD-R 6-1:2014 Rev. 2 | Calibration of Pressure Gauges, Rev.2, Mar-01-2014 |

Calibrating Technician:

WATTANA TANGCHAROEN

QC Approval:

PADUNG SRASUAY

STATEMENTS OF PASS OR FAIL CONFORMANCE: The uncertainty of measurement has been taken into account when determining compliance with specification. All measurements and test results guard banded to ensure the probability of false-accept does not exceed 2% in compliance with ANSI/NCCL 2542.3-2006.

THE CALIBRATION REPORT STATUS:
PASS: Term used when compliance statement is given, and the measurement result is PASS.
PASS*: Term used when compliance statement is given, and the measurement result is conditional passed or PASS*.
FAIL: Term used when compliance statement is given, and the measurement result is FAIL.
FAIL*: Term used when compliance statement is given, and the measurement result is conditional failed or FAIL*.
REPORT OF VALUE: Term used when reported measurement is not requiring compliance statement in report.
ADJUSTED: When adjustments are made to an instrument which changes the value of measurement from what was measured as found to new value as left.
LIMITED: When an instrument fails calibration but is still functional in a limited manner.

The expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%, unless otherwise stated. This calibration report complies with ISO/IEC 17025:2017, ANSI/NCCL 2542.3-2006 and ANSI/NCCL 2542.1-1984. Calibration cycles and resulting due dates were submitted/approved by the customer. Any number of follow up calibrations before the next scheduled calibration. Recalibration cycles should be based on frequency of use, environmental conditions and customer's measured system accuracy. All standards are traceable to SI through the National Institute of Standards and Technology (NIST) and/or recognized national or international standards laboratories. Services rendered include proper manufacturer's service instruction and are warranted for no less than thirty (30) days. The information on the report pertains only to the instrument identified, this may not be reproduced in part or in a whole without the prior written approval of the issuing MP Calibration Laboratory.



Calibration Report of Sino Instruments HS 108 Digital Pressure Gauge

MPC Control #: 1501119048 Serial Number: 1501119048
Asset ID: PSS-DTG-05 Calibration Date: May 21, 2024

Measurement Results range: 0 to 10 kPa

- As Found of Measurement

| Nominal Value (kPa) | Lower Limit (kPa) | The measured value of the reading from the calibration item (kPa) | | | Upper Limit (kPa) | Result | Uncertainty (kPa) |
|---------------------|-------------------|---|---------|------------|-------------------|--------|-------------------|
| | | Up | Down | Mean Value | | | |
| 0 | -0.0025 | 0.0000 | 0.0000 | 0.0000 | 0.0025 | PASS | ± 0.00042 |
| 1 | 0.9975 | 1.0002 | 1.0003 | 1.0003 | 1.0025 | PASS | ± 0.00042 |
| 2 | 1.9975 | 2.0003 | 2.0004 | 2.0004 | 2.0025 | PASS | ± 0.00042 |
| 3 | 2.9975 | 3.0004 | 3.0005 | 3.0005 | 3.0025 | PASS | ± 0.00042 |
| 4 | 3.9975 | 4.0006 | 4.0007 | 4.0007 | 4.0025 | PASS | ± 0.00042 |
| 5 | 4.9975 | 5.0007 | 5.0008 | 5.0008 | 5.0025 | PASS | ± 0.00042 |
| 6 | 5.9975 | 6.0009 | 6.0010 | 6.0010 | 6.0025 | PASS | ± 0.00042 |
| 7 | 6.9975 | 7.0009 | 7.0011 | 7.0010 | 7.0025 | PASS | ± 0.00042 |
| 8 | 7.9975 | 8.0011 | 8.0013 | 8.0012 | 8.0025 | PASS | ± 0.00042 |
| 9 | 8.9975 | 9.0012 | 9.0014 | 9.0013 | 9.0025 | PASS | ± 0.00042 |
| 10 | 9.9975 | 10.0016 | 10.0017 | 10.0017 | 10.0025 | PASS | ± 0.00042 |

- As Left of Measurement

| Nominal Value (bar) | Lower Limit (bar) | The measured value of the reading from the calibration item (bar) | | | Upper Limit (bar) | Result | Uncertainty (bar) |
|---------------------|-------------------|---|---------|------------|-------------------|--------|-------------------|
| | | Up | Down | Mean Value | | | |
| 0 | -0.0025 | 0.0000 | 0.0000 | 0.0000 | 0.0025 | PASS | ± 0.00042 |
| 1 | 0.9975 | 1.0002 | 1.0003 | 1.0003 | 1.0025 | PASS | ± 0.00042 |
| 2 | 1.9975 | 2.0003 | 2.0004 | 2.0004 | 2.0025 | PASS | ± 0.00042 |
| 3 | 2.9975 | 3.0004 | 3.0005 | 3.0005 | 3.0025 | PASS | ± 0.00042 |
| 4 | 3.9975 | 4.0006 | 4.0007 | 4.0007 | 4.0025 | PASS | ± 0.00042 |
| 5 | 4.9975 | 5.0007 | 5.0008 | 5.0008 | 5.0025 | PASS | ± 0.00042 |
| 6 | 5.9975 | 6.0009 | 6.0010 | 6.0010 | 6.0025 | PASS | ± 0.00042 |
| 7 | 6.9975 | 7.0009 | 7.0011 | 7.0010 | 7.0025 | PASS | ± 0.00042 |
| 8 | 7.9975 | 8.0011 | 8.0013 | 8.0012 | 8.0025 | PASS | ± 0.00042 |
| 9 | 8.9975 | 9.0012 | 9.0014 | 9.0013 | 9.0025 | PASS | ± 0.00042 |
| 10 | 9.9975 | 10.0016 | 10.0017 | 10.0017 | 10.0025 | PASS | ± 0.00042 |



Calibration Report of Sino Instruments HS 108 Digital Pressure Gauge

MPC Control #: 1501119048 Serial Number: 1501119048
Asset ID: PSS-DTG-05 Calibration Date: May 21, 2024

Measurement Results range: -10 to 0 kPa.

- As Found of Measurement

| Nominal Value (kPa) | Lower Limit (kPa) | The measured value of the reading from the calibration item (kPa) | | | Upper Limit (kPa) | Result | Uncertainty (kPa) |
|---------------------|-------------------|---|----------|------------|-------------------|--------|-------------------|
| | | Up | Down | Mean Value | | | |
| 0 | -0.0025 | 0.0000 | 0.0001 | 0.0002 | 0.0025 | PASS | ± 0.00042 |
| -1 | -1.0025 | -1.0005 | -1.0005 | -1.0005 | -0.9975 | PASS | ± 0.00042 |
| -2 | -2.0025 | -2.0006 | -2.0006 | -2.0006 | -1.9975 | PASS | ± 0.00042 |
| -3 | -3.0025 | -3.0007 | -3.0007 | -3.0007 | -2.9975 | PASS | ± 0.00042 |
| -4 | -4.0025 | -4.0010 | -4.0010 | -4.0010 | -3.9975 | PASS | ± 0.00042 |
| -5 | -5.0025 | -5.0012 | -5.0012 | -5.0012 | -4.9975 | PASS | ± 0.00042 |
| -6 | -6.0025 | -6.0013 | -6.0013 | -6.0013 | -5.9975 | PASS | ± 0.00042 |
| -7 | -7.0025 | -7.0015 | -7.0015 | -7.0015 | -6.9975 | PASS | ± 0.00042 |
| -8 | -8.0025 | -8.0015 | -8.0015 | -8.0015 | -7.9975 | PASS | ± 0.00042 |
| -9 | -9.0025 | -9.0017 | -9.0017 | -9.0017 | -8.9975 | PASS | ± 0.00042 |
| -10 | -10.0025 | -10.0017 | -10.0017 | -10.0017 | -9.9975 | PASS | ± 0.00042 |

- As Left of Measurement

| Nominal Value (kPa) | Lower Limit (kPa) | The measured value of the reading from the calibration item (kPa) | | | Upper Limit (kPa) | Result | Uncertainty (kPa) |
|---------------------|-------------------|---|----------|------------|-------------------|--------|-------------------|
| | | Up | Down | Mean Value | | | |
| 0 | -0.0025 | 0.0000 | 0.0001 | 0.0002 | 0.0025 | PASS | ± 0.00042 |
| -1 | -1.0025 | -1.0005 | -1.0005 | -1.0005 | -0.9975 | PASS | ± 0.00042 |
| -2 | -2.0025 | -2.0006 | -2.0006 | -2.0006 | -1.9975 | PASS | ± 0.00042 |
| -3 | -3.0025 | -3.0007 | -3.0007 | -3.0007 | -2.9975 | PASS | ± 0.00042 |
| -4 | -4.0025 | -4.0010 | -4.0010 | -4.0010 | -3.9975 | PASS | ± 0.00042 |
| -5 | -5.0025 | -5.0012 | -5.0012 | -5.0012 | -4.9975 | PASS | ± 0.00042 |
| -6 | -6.0025 | -6.0013 | -6.0013 | -6.0013 | -5.9975 | PASS | ± 0.00042 |
| -7 | -7.0025 | -7.0015 | -7.0015 | -7.0015 | -6.9975 | PASS | ± 0.00042 |
| -8 | -8.0025 | -8.0015 | -8.0015 | -8.0015 | -7.9975 | PASS | ± 0.00042 |
| -9 | -9.0025 | -9.0017 | -9.0017 | -9.0017 | -8.9975 | PASS | ± 0.00042 |
| -10 | -10.0025 | -10.0017 | -10.0017 | -10.0017 | -9.9975 | PASS | ± 0.00042 |

Note: Pressure Accuracy : ± 0.025% of full scale.

Calibration Installed: Vertical Position

Reference Level: Gauge Inlet

Ambient Temperature: 20.5°C

Relative Humidity: 55.0%

Atmospheric Pressure: 1010 mbar

Conversion factor: 1 kPa = 1000 Pa



Calibration Report of Sino Instruments HS 108 Digital Pressure Gauge

MPC Control #: 1501119048
Asset ID: PSS-DTG-05


Serial Number: 1501119048
Calibration Date: May 21, 2024

Statements of Pass or Fail Conformance

The uncertainty of measurement has been taken into account when determining compliance with specification.
All measurements and test results guard banded to ensure the probability of false-accept does not exceed 2% in compliance with ANSI/NCSL Z540.3-2006.

The status of compliance with the acceptance criteria is reported as:

- PASS** — Compliant with specification.
- PASS²** — The measured value is within acceptance limits.
However, a portion of the expanded uncertainty of measurement at 95% exceeds the specified tolerance.
- FAIL³** — The measured value is not within the acceptance limits.
However, a portion of the expanded uncertainty of measurement at 95% is within the specified tolerance.
- FAIL** — Not compliant with specification.



The expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95%, unless otherwise stated.

This calibration report complies with ISO/IEC 17025:2017 and ANSI/NCSL Z540.3-2006, Method 6 — Guard Bands Based on Test Uncertainty Ratio.

End of Calibration Report



MICRO PRECISION CALIBRATION LABORATORY (THAILAND) CO., LTD.
413 BONDSTREET ROAD, TAMBOL BANGPOODAMPHOE PAKKRED, NONTHABURI
NONTABURI 11120 THAILAND
06 2 583 9834



Certificate of Calibration

Cert No. 5523631030524006

Date: Nov 30, 2023

Customer:

PROSPEC TECHNOLOGY CO.,LTD
181/26 MOO.11 T.KLONG HAE A.HATYAI,
SONGKHLA 90110

Work Order #: THAI-32257195

MPC Control #: EN7845
Asset ID: PSS-E-19
Gage Type: MULTIFUNCTION PROCESS CALIBRATOR
Manufacturer: FLUKE
Model Number: 725
Size: N/A
Temp/RH: 22.0°C / 51.0%
Location: Calibration performed at MPC facility

Serial Number: 1157112
Department: N/A
Performed By: CHATCHA NOOMSAMLEE
Received Condition: OUT OF TOLERANCE
Returned Condition: IN TOLERANCE
Cal. Date: November 29, 2023
Cal. Interval: 12 MONTHS
Cal. Due Date: November 29, 2024

Calibration Notes:

Please refer to the attached Calibration Report (3 pages)

Standards Used to Calibrate Equipment

| I.D. | Description | Model | Serial | Manufacturer | Cal. Due Date | Traceability # |
|--------|--------------------------|-------|------------|-----------------|---------------|-------------------|
| DT2674 | MULTI-PRODUCT CALIBRATOR | 5520A | 8225006 | FLUKE | Mar 9, 2025 | EE-0028-23 / NIMT |
| CC2000 | MULTIMETER | 3458A | 2823A26299 | HEWLETT PACKARD | Dec 27, 2023 | EE-0138-21 / NIMT |

Procedures Used in this Event

| Procedure Name | Description |
|------------------|---|
| FLUKE 725 Rev. 3 | Multifunction Process Calibrator, Fluke 725, Rev.3, May-01-2004 |

Calibrating Technician:

Chatcha
CHATCHA NOOMSAMLEE

QC Approval:

S. Padung
PADUNG SRASUAY

STATEMENTS OF PASS OR FAIL CONFORMANCE: The uncertainty of measurement has been taken into account when determining compliance with specification. All measurements and test results guard banded to ensure the probability of false-accept does not exceed 2% in compliance with ANSI/NCSL Z540.3-2006.

THE CALIBRATION REPORT STATUS

PASS - Term used when compliance statement is given, and the measurement result is PASS.

PASS² - Term used when compliance statement is given, and the measurement result is conditional passed or PASS².

FAIL - Term used when compliance statement is given, and the measurement result is FAIL.

FAIL³ - Term used when compliance statement is given, and the measurement result is conditional failed or FAIL³.

REPORT OF VALUE - Term used when reported measurement is not requiring compliance statement in report.

ADJUSTED - When adjustments are made to an instrument which changes the value of measurement from what was measured as found to new value as left.

LIMITED - When an instrument fails calibration but is still functional in a limited manner.

The expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95%, unless otherwise stated.
This calibration report complies with ISO/IEC 17025:2017, ANSI/NCSL Z540.3-2006 and ANSI/NCSL Z540.1-1984. Calibration cycles and resulting due dates were submitted approved by the customer. Any number of factors may cause an instrument to drift out of tolerance before the next scheduled calibration. Recalibration cycles should be based on frequency of use, environmental conditions and customer's established systematic accuracy. All standards are traceable to SI through the National Institute of Standards and Technology (NIST) and/or recognized national or international standards laboratories. Service included include proper manufacturer's service instruction and are warranted for no less than thirty (30) days. The information on this report pertains only to the instrument identified; this may not be reproduced in part or in whole without the prior written approval of the issuing MPC Calibration Laboratory.



Calibration Report of Fluke 725 Multifunction Process Calibrator

| | |
|-----------------------|-------------------------------------|
| MPC Control #: EN7845 | Serial Number: 1157112 |
| Asset ID: PSS-E-19 | Calibration Date: November 29, 2023 |

Section 1 - DC Voltage Accuracy

Upper Display Voltage

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|----------|-------------|----------|----------|-------------|--------|-----------------|
| DC Voltage | 0.000 V | -0.002 V | 0.000 V | 0.000 V | 0.002 V | PASS | 0.00058 V |
| | 15.000 V | 14.996 V | 15.009 V | 15.000 V | 15.004 V | PASS | 0.00058 V |
| | 30.000 V | 29.995 V | 30.020 V | 30.000 V | 30.005 V | PASS | 0.00062 V |

Lower Display Voltage

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|----------|-------------|----------|----------|-------------|--------|-----------------|
| DC Voltage | 0.00 mV | -0.02 mV | 0.00 mV | 0.00 mV | 0.02 mV | PASS | 0.00070 mV |
| | 45.00 mV | 44.97 mV | 45.00 mV | 45.00A | 45.03 mV | PASS | 0.0010 mV |
| | 90.00 mV | 88.96 mV | 89.97 mV | 89.99 mV | 91.04 mV | PASS | 0.0013 mV |
| | 0.000 V | -0.002 V | 0.000 V | 0.000 V | 0.002 V | PASS | 0.00058 V |
| | 10.000 V | 9.996 V | 9.998 V | 10.000 V | 10.004 V | PASS | 0.00058 V |
| | 20.000 V | 19.994 V | 19.996 V | 19.999 V | 20.006 V | PASS | 0.00058 V |

Section 2 - DC Current Accuracy

Upper Display Current

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|-----------|-------------|-----------|-----------|-------------|--------|-----------------|
| DC Current | 4.000 mA | 3.997 mA | 4.006 mA | 4.000 mA | 4.003 mA | PASS | 0.00061 mA |
| | 12.000 mA | 11.995 mA | 12.019 mA | 12.000 mA | 12.005 mA | PASS | 0.00075 mA |
| | 24.000 mA | 23.993 mA | 24.038 mA | 24.000 mA | 24.007 mA | PASS | 0.0019 mA |

Lower Display Current

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|-----------|-------------|-----------|-----------|-------------|--------|-----------------|
| DC Current | 4.000 mA | 3.997 mA | 4.001 mA | 4.000 mA | 4.003 mA | PASS | 0.00061 mA |
| | 12.000 mA | 11.995 mA | 12.003 mA | 12.000 mA | 12.005 mA | PASS | 0.00075 mA |
| | 24.000 mA | 23.993 mA | 23.999 mA | 24.000 mA | 24.007 mA | PASS | 0.0019 mA |

Section 3 - Frequency Accuracy

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|-----------|-----------|-------------|-----------|-----------|-------------|--------|-----------------|
| 1.0 Vp-p | 10.00 kHz | 9.98 kHz | 10.00 kHz | 10.00 kHz | 10.02 kHz | PASS | 0.0058 kHz |

Section 4 - Resistance Measurement Accuracy

Lower Display 4 - Wire

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|----------|-------------|----------|----------|-------------|--------|-----------------|
| Resistance | 15.00 Ω | 14.90 Ω | 14.97 Ω | 14.99 Ω | 15.10 Ω | PASS | 0.0060 Ω |
| | 350.00 Ω | 349.90 Ω | 349.95 Ω | 349.99 Ω | 350.10 Ω | PASS | 0.011 Ω |
| | 500.0 Ω | 499.5 Ω | 499.9 Ω | 500.0 Ω | 500.5 Ω | PASS | 0.059 Ω |
| | 1500.0 Ω | 1499.5 Ω | 1499.9 Ω | 1500.0 Ω | 1500.5 Ω | PASS | 0.078 Ω |
| | 3200.0 Ω | 3199.0 Ω | 3199.6 Ω | 3199.9 Ω | 3201.0 Ω | PASS | 0.11 Ω |
| | | | | | | | |



Calibration Report of Fluke 725 Multifunction Process Calibrator

| | |
|-----------------------|-------------------------------------|
| MPC Control #: EN7845 | Serial Number: 1157112 |
| Asset ID: PSS-E-19 | Calibration Date: November 29, 2023 |

Section 5 - RTD Measurement Accuracy

Lower Display 3 - Wire

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|-----------|----------|-------------|----------|----------|-------------|--------|-----------------|
| RTD | 350.00 Ω | 349.80 Ω | 349.92 Ω | 350.00 Ω | 350.20 Ω | PASS | 0.011 Ω |

Section 6 - Type J Thermocouple Temperature Measurement Accuracy

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|-------------|---------|-------------|----------|---------|-------------|--------|-----------------|
| Temperature | 0.0°C | -0.4°C | 0.2°C | 0.0°C | 0.4°C | PASS | 0.12°C |

Section 7 -Type J Thermocouple Temperature Source Accuracy

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|-------------|---------|-------------|----------|---------|-------------|--------|-----------------|
| Temperature | 0.0°C | -0.4°C | 0.21°C | 0.01°C | 0.4°C | PASS | 0.16°C |

Section 8 - DC Current Source Accuracy

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|-----------|-------------|------------|------------|-------------|--------|-----------------|
| DC Current | 4.000 mA | 3.997 mA | 3.9982 mA | 4.0006 mA | 4.003 mA | PASS | 0.00059 mA |
| | 12.000 mA | 11.996 mA | 11.9946 mA | 12.0000 mA | 12.004 mA | PASS | 0.0011 mA |
| | 24.000 mA | 23.993 mA | 23.9884 mA | 23.9993 mA | 24.007 mA | PASS | 0.0015 mA |

Section 9 - DC Voltage Source Accuracy

| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|-----------|-------------|-----------|------------|-------------|--------|-----------------|
| DC Voltage | 0.00 mV | -0.02 mV | 0.008 mV | 0.000 mV | 0.02 mV | PASS | 0.0058 mV |
| | 45.00 mV | 44.97 mV | 44.987 mV | 44.998 mV | 45.03 mV | PASS | 0.0058 mV |
| | 100.00 mV | 99.96 mV | 99.976 mV | 100.000 mV | 100.04 mV | PASS | 0.0059 mV |
| | 0.000 V | -0.002 V | 0.0006 V | 0.0000 V | 0.002 V | PASS | 0.00058 V |
| | 10.000 V | 9.997 V | 10.0019 V | 9.9999 V | 10.003 V | PASS | 0.00058 V |
| | | | | | | | |



Calibration Report of Fluke 725 Multifunction Process Calibrator

MPC Control #: EN7845

Serial Number: 1157112

Asset ID: PSS-E-19

Calibration Date: November 29, 2023

Section 10 - Resistance Source Accuracy


| Parameter | Nominal | Lower Limit | As Found | As Left | Upper Limit | Result | Uncertainty (±) |
|------------|---------|-------------|------------|------------|-------------|--------|-----------------|
| Resistance | 15.0 Ω | 14.90 Ω | 14.944 Ω | 14.994 Ω | 15.10 Ω | PASS | 0.0058 Ω |
| | 360.0 Ω | 359.90 Ω | 359.956 Ω | 359.967 Ω | 360.10 Ω | PASS | 0.0071 Ω |
| | 500 Ω | 499.50 Ω | 500.035 Ω | 500.002 Ω | 500.50 Ω | PASS | 0.0080 Ω |
| | 1500 Ω | 1499.50 Ω | 1500.377 Ω | 1500.012 Ω | 1500.50 Ω | PASS | 0.021 Ω |
| | 3200 Ω | 3199.00 Ω | 3200.776 Ω | 3200.441 Ω | 3201.00 Ω | PASS | 0.037 Ω |

Statements of Pass or Fail Conformance

The uncertainty of measurement has been taken into account when determining compliance with specification.
All measurements and test results guard banded to ensure the probability of false-accept does not exceed 2% in compliance with ANSI/NCSL Z540.3-2006

The status of compliance with the acceptance criteria is reported as:

- PASS** — Compliant with specification.
PASS? — The measured value is within acceptance limits. However, a portion of the expanded uncertainty of measurement at 95% exceeds the specified tolerance.
FAIL? — The measured value is not within the acceptance limits. However, a portion of the expanded uncertainty of measurement at 95% is within the specified tolerance.
FAIL — Not compliant with specification.



The expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95%, unless otherwise stated.

This calibration report complies with ISO/IEC 17025:2017 and ANSI/NCSL Z540.3-2006, Method 6 — Guard Bands Based on Test Uncertainty Ratio.

End of Calibration Report



ADVANTAGE CENTER CO., LTD.

59/494 M.6, Frakham Road, T.Kukhot, Lumlookkar, Pathumthani 12130 Thailand.

Tel. (66-2) 9873248-50 Fax: (66-2) 9873252 E-mail: info.accl2662@gmail.com

pornsak2008@yahoo.co.th



CALIBRATION LABORATORY

Certificate No. RA-2405062-2

Job No. RA-2405062

Certificate of Calibration

FOR

Equipment Name : PROCESSMETER

Manufacturer : Fluke

Model : 789

Serial Number : 34690021

Customer Code : PSS-E-20

Location of Calibration : In Lab

Customer Name : PROSPEC TECHNOLOGY CO., LTD.

181/26 Moo.11 T.Klong Hae, A.Hat Yai, Songkhla 90110 Thailand

Calibration Procedure : CPE-04-03, CPE-04-08

Received Date : May 20, 2024

Calibration Date : May 23, 2024

Recommended Due Date : N/A

CONDITION AS RECEIVED : Normal

Environmental Conditions

Ambient Temperature : (23 ± 3) °C

Relative Humidity : (50 ± 15) %RH

Result : No Adjustment (See data attached in page 3 to the end of certificate)

- The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95%.
- The Unit Under Calibration (UUC) has been calibrated by using the working standard which is traceable to SI-Units. The calibration procedure documented is intended to implement the requirements of ISO/IEC 17025 : 2017
- The working standard is indicated in page 2 of this certificate.
- This report applies to the item calibrated and shall not be reproduced except in full, without written approval by Calibration Laboratory, Advantage Center Co., Ltd.

Calibrated by : P. Traithep

Approved by :

ACCL
Pornsak Suksawaeng
(Pornsak Suksawaeng)

Date of Issue : May 27, 2024

Laboratory Management



ADVANTAGE CENTER CO., LTD.

59/494 M.6, Frakham Road, T.Kukhot, Lumlookkar, Pathumthani 12130 Thailand.
Tel. (66-2) 9873248-50 Fax: (66-2) 9873252 E-mail: info.accl2662@gmail.com
pornsak2008@yahoo.co.th

Certificate No.: RA-2405062-2

Reference Standards

| Equipment Name | Serial No. | Certificate No. | Due Date | Traceability to |
|--------------------------|------------|-----------------|--------------|-----------------|
| Multi-Product Calibrator | 6300002 | E2U2400034 | Feb 11, 2025 | NA |
| 6.5 Digit Multimeter | US36127537 | E1U2303383 | Nov 9, 2024 | NA |

Traceability

This calibration is traceable to the International System of Unit via :

- NA : NA Caltechnologies Co.,Ltd.



Page 2 of 5



ADVANTAGE CENTER CO., LTD.

59/494 M.6, Frakham Road, T.Kukhot, Lumlookkar, Pathumthani 12130 Thailand.
Tel. (66-2) 9873248-50 Fax: (66-2) 9873252 E-mail: info.accl2662@gmail.com
pornsak2008@yahoo.co.th

Certificate No.: RA-2405062-2

Result of Calibration

Function: DC Volts Measurement Tests

| Range | STD. Setting | UUC. Reading | Correction | Uncertainty (±) |
|----------|--------------|--------------|------------|----------------------|
| 400.0 mV | 100.00 mV | 100.0 mV | 0.0 mV | 0.058 mV |
| | 300.00 mV | 300.0 mV | 0.0 mV | 0.059 mV |
| 4.000 V | 1.000 V | 0.999 V | 0.001 V | 0.00058 V |
| | 3.000 V | 2.999 V | 0.001 V | 0.00059 V |
| 40.00 V | 10.000 V | 10.00 V | 0.00 V | 0.0058 V |
| | 30.000 V | 30.00 V | 0.00 V | 0.0059 V |
| 400.0 V | 100.000 V | 99.9 V | 0.1 V | 0.058 V |
| | 300.000 V | 299.9 V | 0.1 V | 0.059 V |
| 1000 V | 100.000 V | 100 V | 0 V | 0.58 V |
| | 900.000 V | 899 V | 1 V | 0.58 V |

Function: AC Volts Measurement Test

| Range | STD. Setting | UUC. Reading | Correction | Uncertainty (±) |
|----------|-------------------|--------------|------------|----------------------|
| 400.0 mV | 100.00 mV @ 60 Hz | 99.8 mV | 0.2 mV | 0.060 mV |
| | 300.00 mV @ 60 Hz | 299.8 mV | 0.2 mV | 0.11 mV |
| 4.000 V | 1.00 V @ 60 Hz | 0.999 V | 0.001 V | 0.00040 V |
| | 2.00 V @ 60 Hz | 1.998 V | 0.002 V | 0.00070 V |
| | 3.00 V @ 60 Hz | 2.999 V | 0.001 V | 0.0011 V |
| 40.00 V | 10.00 V @ 60 Hz | 9.99 V | 0.01 V | 0.0040 V |
| | 30.00 V @ 60 Hz | 29.99 V | 0.01 V | 0.013 V |
| 400.0 V | 100.00 V @ 60 Hz | 99.8 V | 0.2 V | 0.048 V |
| | 300.00 V @ 60 Hz | 299.9 V | 0.1 V | 0.13 V |
| 1000 V | 100.00 V @ 60 Hz | 100 V | 0 V | 0.048 V |
| | 900.00 V @ 60 Hz | 900 V | 0 V | 0.45 V |



Page 3 of 5



ADVANTAGE CENTER CO., LTD.

59/494 M.6, Frakham Road, T.Kukhot, Lumlookkar, Pathumthani 12130 Thailand.
Tel. (66-2) 9873248-50 Fax: (66-2) 9873252 E-mail: info.accl2662@gmail.com
pomsak2008@yahoo.co.th

Certificate No. : RA-2405062-2

Result of Calibration

Function: DC Current Measurement Test

| Range | STD. Setting | UUC. Reading | Correction | Uncertainty (±) |
|-----------|--------------|--------------|------------|----------------------|
| 30.000 mA | 4.00 mA | 4.000 mA | 0.000 mA | 0.0010 mA |
| | 12.00 mA | 12.000 mA | 0.000 mA | 0.0016 mA |
| | 20.00 mA | 20.000 mA | 0.000 mA | 0.0023 mA |
| 1.000 A | 0.10 A | 0.100 A | 0.000 A | 0.00058 A |
| | 0.40 A | 0.400 A | 0.000 A | 0.00059 A |

Function: AC Current Measurement Test

| Range | STD. Setting | UUC. Reading | Correction | Uncertainty (±) |
|---------|----------------|--------------|------------|----------------------|
| 1.000 A | 0.10 A @ 60 Hz | 0.100 A | 0.000 A | 0.00058 A |
| | 0.40 A @ 60 Hz | 0.401 A | -0.001 A | 0.00070 A |

Function: Resistance Measurement Test

| Range | STD. Setting | UUC. Reading | Correction | Uncertainty (±) |
|----------|--------------|--------------|------------|----------------------|
| 400.0 Ω | 120.0 Ω | 120.2 Ω | -0.2 Ω | 0.059 Ω |
| | 300.0 Ω | 300.1 Ω | -0.1 Ω | 0.063 Ω |
| 4.000 kΩ | 1.20 kΩ | 1.200 kΩ | 0.000 kΩ | 0.00059 kΩ |
| | 3.00 kΩ | 2.999 kΩ | 0.001 kΩ | 0.00062 kΩ |
| 40.00 kΩ | 12.00 kΩ | 12.00 kΩ | 0.00 kΩ | 0.0059 kΩ |
| | 30.00 kΩ | 30.00 kΩ | 0.00 kΩ | 0.0062 kΩ |
| 400.0 kΩ | 120.0 kΩ | 120.0 kΩ | 0.0 kΩ | 0.059 kΩ |
| | 200.0 kΩ | 200.0 kΩ | 0.0 kΩ | 0.061 kΩ |
| | 300.0 kΩ | 300.1 kΩ | -0.1 kΩ | 0.064 kΩ |
| 4.000 MΩ | 1.20 MΩ | 1.200 MΩ | 0.000 MΩ | 0.00060 MΩ |
| | 3.00 MΩ | 3.001 MΩ | -0.001 MΩ | 0.00068 MΩ |
| 40.00 MΩ | 12.00 MΩ | 12.02 MΩ | -0.02 MΩ | 0.011 MΩ |
| | 30.00 MΩ | 30.05 MΩ | -0.05 MΩ | 0.025 MΩ |



Page 4 of 5



ADVANTAGE CENTER CO., LTD.

59/494 M.6, Frakham Road, T.Kukhot, Lumlookkar, Pathumthani 12130 Thailand.
Tel. (66-2) 9873248-50 Fax: (66-2) 9873252 E-mail: info.accl2662@gmail.com
pomsak2008@yahoo.co.th

Certificate No. : RA-2405062-2

Result of Calibration

Function: Frequency Measurement Test

| Range | | STD. Setting | UUC. Reading | Correction | Uncertainty (±) |
|------------|---------|-----------------|--------------|------------|----------------------|
| Frequency | Voltage | | | | |
| 199.99 Hz | 400 mV | 150 mV @ 100 Hz | 100.00 Hz | 0.00 Hz | 0.0079 Hz |
| 1999.9 Hz | 4 V | 1 V @ 1000 Hz | 1000.0 Hz | 0.0 Hz | 0.078 Hz |
| 19.999 kHz | 40 V | 4 V @ 10 kHz | 10.000 kHz | 0.000 kHz | 0.00061 kHz |

Function: DC Current Sourcing Test

| Range | UUC. Setting | STD. Reading | Correction | Uncertainty (±) |
|-------|--------------|--------------|-------------|----------------------|
| 20 mA | 4.00 mA | 3.99960 mA | -0.00040 mA | 0.0049 mA |
| | 12.00 mA | 12.0005 mA | 0.0005 mA | 0.013 mA |
| | 20.00 mA | 20.0008 mA | 0.0008 mA | 0.018 mA |

STD = Standard

UUC = Unit Under Calibration

- End of Certificate -



Page 5 of 5

Customer : Prospec Technology Co., Ltd.

Address : 181/26 Moo 11 Tambol Klong Hae, Amphur Hatyai,
Songkhla 90110 Thailand

Description : Platinum Resistance Thermometer

Manufacturer : Presys

Model : 1/5 DIN-A

Serial No. : 190.08.15

ID No. : PSS-T-04

Location : -

Received Date : May 20, 2024

Measurement Date : May 22, 2024

Issued Date : May 24, 2024

Calibrated by : Mr. Suphamongkol Phaewkasem

Approved By

(Mr. Somkhuang Phaewkasem)

This report's applicability is strictly limited to the sample utilized in this calibration and cannot be extrapolated to any other samples or scenarios beyond the specific context of this calibration.
The Reported uncertainty is based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95 %
This Calibration Certificate may not be reproduced other than in full except with the permission of the Calibration Manager of Success Gateway Co., Ltd.

| Environment | Temperature | Humidity |
|-------------|------------------|---------------------|
| | (23 °C ± 2 °C) | (50 %RH ± 15 %RH) |

Measurement Method

This instrument was calibrated by in house method CP-T-003 comparison with thermometer standard

Uncertainty of Measurement

The uncertainty state is the expanded uncertainty obtained by multiplying the standard Uncertainty by the coverage factor $k=2$. It has been determined in accordance with M3003 "The Expression of Uncertainty and Confidence in Measurement". The value of the measured lies within the assigned range of values with a Probability of 95 %

Traceability

This certification is traceable to the International System of Units (SI Units)

Standard Used

| Item | Description | Model | Serial No. | Traceable through | Certificate No. | Due Date |
|------|--------------------------|-------|------------|-------------------|-----------------|-----------|
| 1 | Secondary PRT | 5628 | 3131 | Fluke (U.S.A.) | 4500028698 | 19-May-25 |
| 2 | Thermometer, Black Stack | 1560 | 843722 | TPA | 24E448 | 05-Feb-25 |
| 3 | Digital Thermometer SPRT | 2560 | 843492 | TPA | 24E448 | 05-Feb-25 |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

Fluke : Fluke Corporation (U.S.A.)
TPA : Technology Promotion Association (Thailand-Japan)

Report of Calibration

Certificate No.

SG-T-00466/67

Page : 3 of 3

Measurement Results : As-Found

This instrument was connected with Dry Block Calibrator ID : PSS-T-02 S/N : 189.08.15

| Standard Reading (°C) | UUC Reading (°C) | Correction (°C) | Uncertainty (±°C) |
|--------------------------|---------------------|--------------------|----------------------|
| -19.9957 | -20.46 | 0.46 | 0.031 |
| -0.0574 | -0.62 | 0.56 | 0.030 |
| 100.0021 | 99.48 | 0.52 | 0.032 |
| 200.0172 | 199.42 | 0.60 | 0.036 |
| 399.9863 | 399.51 | 0.48 | 0.26 |

UUC : Unit Under Calibration

Remark : R0 = 100.00450, A = 03.910606, B = -05.834517, C = -02.871779

----- End of Certificate of Calibration -----



CALIBRATION CERTIFICATE



Certificate No : 231109CA29
Control No : HVN9-CA4325

72, Dongtancheomdansaneop 2-ro, Hwaseong-si, Korea
Tel:82-31-379-5114, Fax:82-31-379-5115

Page 1 of 3

1. Client

Name : PROSPEC TECHNOLOGY CO.,LTD.
Address : 181/26 Moo 11, Khlong Hae, Hat Yai, Songkhla 90110

2. Calibration Subject

Description : TECAL CALIBRATOR
Manufacture & Model Name : TECHNE / FDB425HA
Serial No. : 104637-11

3. Date of Calibration

: 14-Nov-2023

4. Environment Conditions

Temperature : (23.3 ± 0.4) °C Humidity : (50 ± 2) % R.H.
Location : ☐ Permanent Lab. ☐ Mobile Lab. ☒ On Site Calibration

5. Traceability

Calibration method and /or brief description :

The above instrument was calibrated according to the calibration procedure of Temperature generators; oven, furnaces, isothermal liquid baths, dry-block calibrators(SICT-CP-50101), using the below standard instrument which is guaranteed a traceability by National Metrology Institute(NMI).

List of used standards/specifications

| Description | Manufacture and Model | Serial Number | The due date of next Calibration | Calibration Lab. |
|-----------------------------------|-----------------------|---------------|----------------------------------|------------------|
| PRECISION THERMOMETER | ISOTECH / milli K | 38849-6 | 29-Apr-2024 | SICT(KC01-018) |
| PRECISION THERMOMETER(RESISTANCE) | ISOTECH / milli K | 38849-6 | 23-Feb-2024 | SICT(KC01-018) |

6. Calibration Results

: Refer attached file

7. Measurement Uncertainty

: Refer attached file

| | | |
|-------------|--|---|
| Affirmation | Measurements performed by Tel No. : 82-31-379-5168 Name : SEONGGU KANG | Approved by Title : Technical Manager Name : YONG TAE HAM |
|-------------|--|---|

The above calibration certificate is the accredited calibration items by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA

14-Nov-2023

Accredited by KOLAS, Republic of Korea Institute of Calibration & Technology Co., Ltd.

(Note) If any significant instability or other adverse factor(overload, temperature, humidity etc.) manifests itself before, during or after calibration, it is likely to affect the validity of the calibration.

CALIBRATION RESULTS




Certificate No. : 231109CA29
Model : FDB425HA

Date of Calibration : 14-Nov-2023

[1] Temperature Accuracy (Sensor Position : ①, ②)

| Setting Value | Indication | Measured Value | Correction | Measurement Uncertainty |
|---------------|------------|----------------|------------|-------------------------|
| 100.0 °C | 100.0 °C | 97.3 °C | -2.7 °C | 0.2 °C |
| 200.0 °C | 200.0 °C | 193.7 °C | -6.3 °C | 0.2 °C |
| 405.0 °C | 400.0 °C | 391.6 °C | -8.4 °C | 0.2 °C |

[2] Temperature Trend Line



[3] Temperature Stability

| Setting Value | Sensor Position | Division | | Stability (±) |
|---------------|-----------------|-----------|-----------|---------------|
| | | Maximum | Minimum | |
| 100.0 °C | ①, ② | 97.31 °C | 97.30 °C | 0.01 °C |
| 200.0 °C | ①, ② | 193.79 °C | 193.72 °C | 0.05 °C |
| 405.0 °C | ①, ② | 391.57 °C | 391.56 °C | 0.01 °C |

CALIBRATION RESULTS



Certificate No. : 231109CA29
Model : FDB425HA

Date of Calibration : 14-Nov-2023

[4] Temperature Measured Position

| Measured position | Depth |
|-------------------|-----------|
| | a = 40 mm |

※ The above measurement uncertainty is the result of not including temperature Uniformity.

※ Measurement Uncertainty :

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95 %.

The End



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

SERVICE REPORT

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Job No. : | JID2400455 | Customer name : | B.Grimm Power WHA1 |
| Equipment : | CEMS | Unit name : | HRSG 11 |
| Manufacturer : | ABB | Location : | Chonburi (Bowin) |
| Model : | URAS26 / MAGNOS206 | Contact name : | K.Punthep Laosungnean |
| Serial No. : | 3.262355.5/3.262840.5 | Telephone : | 086-258-4194 |
| Working date : | 24 July 2024 | Fax. : | - |
| Traveling hour : | 3 Hrs | Email address : | punthep.l@bgrimmpower.com |
| Mileage : | 240 Km. | Working Hour : | 6 Hrs |

SCOPE OF WORK

Preventive maintenance continuous emission monitoring system (CEMs).

PHYSICAL & FUNCTION CHECK

Sampling system.

- Checked the sampling probe was normal condition.
- Checked the ceramic filter for the sampling probe was clean.
- Checked the heated line was normal condition.
- Checked the sample gas cooler was normal operation.
- Checked the automatic condensate drain was normal operation.
- Checked the acid filter was normal operation.
- Checked the sample gas feed unit was normal operation.
- Checked the NO₂-NOX converter found temp controller was normal operation.

Gas analyzer.

- Checked all diagnostics for both of gas analyzers.
 1. Gas analyzer AO2000 was normal condition.
 2. Gas analyzer EL3020 was normal condition.
- Validation zero and span by supply standard to sampling probe found both of the gas analyzers were normal responses.

Opacity analyzer for HRSG stack.

- Checked all diagnostics was normal.
- The opacity analyzer was normal operation.
- Air hose blower was low performance.

Opacity analyzer for BYPASS stack.

- Off power.

Flow meter & Temperature sensor.

- Checked stack flow meter and temperature sensor were normal operation.

CORRECT ACTION

Sampling system.

- Replaced consumable part 6 month by preventive maintenance plan.
- Leakage check full system after replaced new consumable parts not found leak point.

Gas analyzer.

- Performed basic calibrate zero and span for the gas analyzer by supply standard gas to sampling probe.



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

Opacity analyzer for HRSG stack.

- Cleaned outside for equipment.
- Clean all lenses for measuring head and reflector unit.

Opacity analyzer for BYPASS stack.

- -

Flow meter & Temperature sensor.

- Check DP transmitter and temperature sensor was normal condition.

PART REPLACEMENT

| | | |
|----------------------------|-----------|--------|
| 1. Flexible tube | IT0001934 | 2 ea. |
| 2. Filter membrane | IT0008261 | 1 ea. |
| 3. Catalyst, molybdenum | IT0000715 | 1 set. |
| 4. Filter stone | IT0001141 | 1 ea. |
| 5. Set of gasket FPM | IT0001152 | 1 set. |
| 6. Sealing 25-12 mm | IT0001831 | 2 ea. |
| 7. Sealing 18-8 mm | IT0001830 | 4 ea. |
| 8. Conveying belt | IT0004822 | 2 ea. |
| 9. Diver complete | IT0001823 | 2 ea. |
| 10. O-Ring 60x3.5, FPM 70 | IT0000300 | 1 ea. |
| 11. Diaphragm pump | IT0004608 | 1 ea. |
| 12. Acid filter | IT0007237 | 1 ea. |
| 13. O-Ring 56x3 FPM | IT0000777 | 1 ea. |
| 14. Filter cartridge | IT0008163 | 1 ea. |
| 15. Disposable filter unit | IT0001136 | 2 ea. |

** All consumable parts supply by customer.

RECOMMENDATION

- Should be providing consumable parts air hose for blower unit.

Internal Information Warranty ID

Gas Analyzer (Uras26) : 11524

Gas Analyzer (Magnos206) : 11525

Sampling System : 11526

Opacity Analyzer : 11527

| | | | |
|--------------|---------------|--------|-------------|
| CHECK BY : | | DATE : | 25-Jul-2024 |
| APPROVE BY : | Nadthapong N. | DATE : | 2-Aug-2024 |



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

GENERAL CHECK

| | | | |
|-------------|--------------|------------|--------------------|
| Unit name : | 11CNA10GH001 | Location : | B.Grimm Power WHA1 |
|-------------|--------------|------------|--------------------|

| ITEM | DESCRIPTION | SET-POINT VALUE | STATUS/VALUE | | REMARK |
|------|--|-----------------------------------|---------------------------|---------------------------|-------------|
| | | | BEFORE | AFTER | |
| 1 | Shelter room temperature | 24-30 DegC | 27°C | 27°C | |
| 2 | Heated sampling probe | No condensate water | No condensate water | No condensate water | |
| 3 | Filter probe | Clean | Clean | Clean | |
| 4 | Probe blow back | Function test (OK) | OK | OK | |
| 5 | Heated line temperature(HRSG) | 120-160 DegC | 142°C | 143°C | |
| 6 | Heated line temperature(By pass) | 120-160 DegC | 142°C | 142°C | |
| 7 | SCC-F operate | Run | Run | Run | |
| 8 | SCC-F sample flow (FM1) | No alarm | 100 lph | 100 lph | |
| 9 | Condensate filter | Clean | Clean | Clean | |
| 10 | Gas cooler temperature | 2.8-3.2 DegC | 3.0°C | 3.0°C | |
| 11 | Peristaltic pump A | Run | Run | Run | |
| 12 | Peristaltic pump B | Run | Run | Run | |
| 13 | Acid filter | Clean | Clean | Clean | |
| 14 | Bypass flow (FM2) | 10-15 l/h | 20 l/h | 10 l/h | |
| 15 | CO/SO ₂ /O ₂ flow (FM3) | 30-50 l/h | 30 l/h | 40 l/h | |
| 16 | NO _x flow (FM4) | 30-50 l/h | 40 l/h | 40 l/h | |
| 17 | NO _x converter temperature | 345-355 °C | 350°C | 350°C | |
| 18 | BV1 (To NO _x converter/Bypass) | NO _x converter | NO _x converter | NO _x converter | |
| 19 | Pressure of span gas cylinder | >300 psig | 1,800 psi | 1,700 psi | |
| 20 | Pressure of air zero cylinder(O ₂) | >300 psig | 400 psi | 300 psi | Recommend |
| 21 | PLC Status | Run | Run | Run | |
| 22 | Stack flow meter | 400,000-700,000 m ³ /h | 1,706 m ³ /h | 935 m ³ /h | Calibration |
| 23 | Stack temperature | 90-120 DegC | 0°C | 0 °C | Calibration |

| | |
|------------|---|
| CHECK BY : |  |
| DATE : | 25-Jul-2024 |



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

TEST REPORT

| | | | |
|-------------|--------------|------------|--------------------|
| UNIT NAME : | 11CNA10GH001 | LOCATION : | B.Grimm Power WHA1 |
|-------------|--------------|------------|--------------------|

| STANDARD GAS CONCENTRATION | | | | | | |
|----------------------------|---------------|------|--------------|----------------|-------------|----------------|
| Components | Concentration | Unit | Cylinder NO. | Certified Date | Expire Date | Pressure (psi) |
| CO | 162 | ppm | D636155 | 11 Oct 2023 | 11 Oct 2026 | 1,800 |
| SO ₂ | 19.7 | ppm | D636155 | 11 Oct 2023 | 11 Oct 2026 | 1,800 |
| NO | 163 | ppm | D636155 | 11 Oct 2023 | 11 Oct 2026 | 1,800 |
| O ₂ | 21.1 | %Vol | 812308 | 6 May 2021 | 6 May 2029 | 400 |

| MEASUREMENT RESULT BEFORE CALIBRATE | | | | | | |
|-------------------------------------|-------------------|-------------|------------------------------------|-------------|---------------------------|--------|
| Parameter | Measurement Value | | Status Reactive Calibration Drifts | | Offset&Amplify Acceptance | Note |
| | Reading | Analog (mA) | Offset (%) | Amplify (%) | | |
| CO 0 - 200 ppm | 1.90 | 4.15 | 2.0% | -8.0% | ± 30 % | Passed |
| SO ₂ 0 - 25 ppm | 1.04 | 4.67 | 0.0% | 0.0% | | Passed |
| NO _x 0 - 200 ppm | 13.40 | 5.07 | -1.0% | -1.0% | | Passed |
| NO 0 - 200 ppm | 12.10 | 4.97 | | | | |
| O ₂ 0 - 25 %Vol | 14.16 | 13.06 | 0.0% | 0.0% | | Passed |

| VALIDATION RESULT | | | | | | | | | | | |
|-------------------|-------------|-------|--------|-------|---------|--------|--------|-------|---------|--------------------|--------|
| Parameter | | Zero | | | | Span | | | | % Error Acceptance | Note |
| | | Ideal | Actual | Drift | % Error | Ideal | Actual | Drift | % Error | | |
| CO | 0 - 200 ppm | 0.00 | 2.30 | -2.30 | -1.15 | 162.00 | 160.10 | -1.90 | 0.95 | ±2.0 % | Passed |
| SO ₂ | 0 - 25 ppm | 0.00 | -0.47 | 0.47 | 1.88 | 19.70 | 20.12 | 0.42 | -1.68 | ±2.0 % | Passed |
| NO _x | 0 - 200 ppm | 0.00 | -1.60 | 1.60 | 0.80 | 163.00 | 161.20 | -1.80 | 0.90 | ±2.0 % | Passed |
| O ₂ | 0 - 25 %Vol | 0.00 | -0.02 | 0.02 | 0.02 | 21.10 | 20.78 | 0.32 | 0.32 | ±0.5 % | Passed |

| CALIBRATION RESULT | | | | | | | | | | | |
|--------------------|-------------|-------|--------|-------|---------|--------|--------|-------|---------|--------------------|--------|
| Parameter | | Zero | | | | Span | | | | % Error Acceptance | Note |
| | | Ideal | Actual | Drift | % Error | Ideal | Actual | Drift | % Error | | |
| CO | 0 - 200 ppm | 0.00 | 0.00 | 0.00 | 0.00 | 162.00 | 162.00 | 0.00 | 0.00 | ±2.0 % | Passed |
| SO ₂ | 0 - 25 ppm | 0.00 | 0.00 | 0.00 | 0.00 | 19.70 | 19.70 | 0.00 | 0.00 | ±2.0 % | Passed |
| NO _x | 0 - 200 ppm | 0.00 | -0.02 | -0.02 | 0.01 | 163.00 | 163.00 | 0.00 | 0.00 | ±2.0 % | Passed |
| O ₂ | 0 - 25 %Vol | 0.00 | 0.00 | 0.00 | 0.00 | 21.10 | 21.10 | 0.00 | 0.00 | ±0.5 % | Passed |

| MEASUREMENT RESULT AFTER CALIBRATE | | | | | | | |
|------------------------------------|-------------|-------------------|-------------|------------------------------------|-------------|---------------------------|--------|
| Parameter | | Measurement Value | | Status Reactive Calibration Drifts | | Offset&Amplify Acceptance | Note |
| | | Reading | Analog (mA) | Offset (%) | Amplify (%) | | |
| CO | 0 - 200 ppm | -0.70 | 3.94 | 1.0% | -8.0% | ± 30 % | Passed |
| SO ₂ | 0 - 25 ppm | 0.22 | 4.14 | 0.0% | 0.0% | | Passed |
| NO _x | 0 - 200 ppm | 12.00 | 4.96 | -2.0% | -1.0% | | Passed |
| NO | 0 - 200 ppm | 10.90 | 4.87 | | | | |
| O ₂ | 0 - 25 %Vol | 14.10 | 13.02 | -0.8% | 0.0% | | Passed |

* % Error Calculate from % of Range.

| | |
|------------|---|
| CHECK BY : |  |
| DATE : | 25-Jul-2024 |



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand


TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

OPACITY GENERAL CHECK

| | | | |
|----------------------------|--------------|--------------------------|---------|
| Analyzer type : | Opacity | Manufacturer : | DURAG |
| Model : | D-R 290 | Control unit serial no.: | 1249527 |
| Measuring head serial no.: | 1251258 | Reflector serial no.: | 1251436 |
| Unit Name : | 11CNA10GH001 | Location : | HRSG11 |

| ITEM | DESCRIPTION | SET-POINT VALUE | STATUS/VALUE | | REMARK |
|------|----------------------------------|--------------------|----------------|----------------|------------------|
| | | | BEFORE | AFTER | |
| | Parameter Setting | | | | |
| 1 | Opacity measuring (%) | Up to process | -0.5 | 0.5 | |
| 2 | Set-up mode | 43 S | 43 S | 43 S | |
| 3 | Set-up mg/m ³ , (b) | b=0000 | 0000 | 0000 | |
| 4 | Range 1 OUT 1 | OP 100% | OP 100% | OP 100% | |
| 5 | Range 2 OUT 1 | OP 100% | OP 100% | OP 100% | |
| 6 | INT Time OUT 1 | 0005 Sec | 0005 S | 0005 S | |
| 7 | Range 1 OUT 2 | OP 100 % | OP 100% | OP 100% | |
| 8 | Range 2 OUT 2 | OP 100 % | OP 100% | OP 100% | |
| 9 | INT Time OUT 2 | 0005 Sec | 0005 Sec | 0005 Sec | |
| 10 | Check Cycle | 24.00 HRS | 24.00 HRS | 24.00 HRS | |
| 11 | Window alarm | 9.0 % | 9.0 % | 9.0 % | |
| 12 | Limit Value 1 | 20.00 mA | 20.00 mA | 20.00 mA | |
| 13 | Limit Value 2 | 20.00 mA | 20.00 mA | 20.00 mA | |
| 14 | Filter Audit | OP 0.0 % | OP 0.0 % | OP 0.0 % | |
| 15 | Zero Point | 0.0 % | 0.0 % | 0.0 % | |
| 16 | Window Check | 0.0 % | 0.3 % | 0.0 % | |
| 17 | Span Check | 71.7 % | 71.7 % | 71.7 % | |
| 18 | Stack Cor. Factor | 1.000 | 1.000 | 1.000 | |
| | On stack | | | | |
| 19 | Motor blower | Run | Run | Run | |
| 20 | Filter for blower | Clean | Dirty | Clean | Replace new part |
| 21 | Blower Hose | Normal | Low efficiency | Low efficiency | |

| | |
|------------|---|
| CHECK BY : |  |
| DATE : | 25-Jul-2024 |



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

OPACITY GENERAL CHECK

| | | | |
|----------------------------|--------------|--------------------------|----------|
| Analyzer type : | Opacity | Manufacturer : | DURAG |
| Model : | D-R 290 | Control unit serial no.: | 1250452 |
| Measuring head serial no.: | 12512559 | Reflector serial no.: | 1251438 |
| Unit Name : | 11CNA10GH001 | Location : | BYPASS11 |

| ITEM | DESCRIPTION | SET-POINT VALUE | STATUS/VALUE | | REMARK |
|------|----------------------------------|--------------------|----------------|----------------|--------|
| | | | BEFORE | AFTER | |
| | Parameter Setting | | | | |
| 1 | Opacity measuring (%) | Up to process | - | - | |
| 2 | Set-up mode | 43 S | - | - | |
| 3 | Set-up mg/m ³ , (b) | 0000 | - | - | |
| 4 | Range 1 OUT 1 | OP 100% | - | - | |
| 5 | Range 2 OUT 1 | OP 100% | - | - | |
| 6 | INT Time OUT 1 | 0005 Sec | - | - | |
| 7 | Range 1 OUT 2 | OP 100 % | - | - | |
| 8 | Range 2 OUT 2 | OP 100 % | - | - | |
| 9 | INT Time OUT 2 | 0005 Sec | - | - | |
| 10 | Check Cycle | 24.00 HRS | - | - | |
| 11 | Window alarm | 8.0 % | - | - | |
| 12 | Limit Value 1 | 20.00 mA | - | - | |
| 13 | Limit Value 2 | 20.00 mA | - | - | |
| 14 | Filter Audit | OP 0.0 % | - | - | |
| 15 | Zero Point | 0.0 % | - | - | |
| 16 | Window Check | 0.0 % | - | - | |
| 17 | Span Check | 71.7 % | - | - | |
| 18 | Stack Cor. Factor | 1.000 | - | - | |
| | On stack | | | | |
| 19 | Motor blower | Run | Run | Run | |
| 20 | Filter for blower | Clean | Dirty | Dirty | |
| 21 | Blower Hose | Normal | Low efficiency | Low efficiency | |

| | |
|------------|---|
| CHECK BY : |  |
| DATE : | 25-Jul-2024 |



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak , Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

SERVICE REPORT

| | | | |
|------------------|-----------------------|-----------------|--|
| Job No. : | JID2400455 | Customer name : | B.Grimm Power WHA1 |
| Equipment : | CEMS | Unit name : | HRSG 12 |
| Manufacturer : | ABB | Location : | Chonburi (Bowin) |
| Model : | URAS26 / MAGNOS206 | Contact name : | K.Punthep Laosungnean |
| Serial No. : | 3.262355.5/3.262840.5 | Telephone : | 086-258-4194 |
| Working date : | 25 July 2024 | Fax. : | - |
| Traveling hour : | 3 Hrs | Email address : | punthep.l@bgrimmpower.com |
| Mileage : | 240 Km. | Working Hour : | 6 Hrs |

SCOPE OF WORK

Preventive maintenance continuous emission monitoring system (CEMs).

PHYSICAL & FUNCTION CHECK

Sampling system.

- Checked the sampling probe was normal condition.
- Checked the ceramic filter for the sampling probe was clean.
- Checked the heated line was normal condition.
- Checked the sample gas cooler was normal operation.
- Checked the automatic condensate drain was normal operation.
- Checked the acid filter was clean and normal operation.
- Checked the sample gas feed unit was normal operation.
- Checked the NO₂-NOX converter found temp controller was normal operation.

Gas analyzer.

- Checked all diagnostics for both of gas analyzers.
 1. Gas analyzer AO2000 was normal condition.
 2. Gas analyzer EL3020 was normal condition.
- Validation zero and span by supply standard to sampling probe found both of the gas analyzers were normal responses.

Opacity analyzer for HRSG stack.

- Checked all diagnostics was normal condition.
- Clean all lenses for measuring head and reflector unit.
- Air hose blower was low performance.

Opacity analyzer for BYPASS stack.

- Off power.

Flow meter & Temperature sensor.

- Checked stack flow meter and temperature sensor were normal operation.

CORRECT ACTION

Sampling system.

- Replaced consumable part 6 month by preventive maintenance plan.
- Leakage check full system after replaced new consumable parts not found leak point.

Gas analyzer.

- Performed calibrate zero and span for the gas analyzer by supply standard gas to sampling probe.



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak , Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

Opacity analyzer for HRSG stack.

- Cleaned outside for equipment.
- Clean all lenses for measuring head and reflector unit.

Opacity analyzer for BYPASS stack.

- -

Flow meter & Temperature sensor.

- Checked DP transmitter and temperature sensor was normal condition.

PART REPLACEMENT

| | | |
|-------------------------------------|-----------|--------|
| 1. Flexible tube | IT0001934 | 2 ea. |
| 2. Filter membrane | IT0008261 | 1 ea. |
| 3. Catalyst, molybdenum | IT0000715 | 1 set. |
| 4. Filter stone | IT0001141 | 1 ea. |
| 5. Set of gasket FPM | IT0001152 | 1 set. |
| 6. Sealing 25-12 mm | IT0001831 | 2 ea. |
| 7. Sealing 18-8 mm | IT0001830 | 4 ea. |
| 8. Conveying belt | IT0004822 | 2 ea. |
| 9. Diver complete | IT0001823 | 2 ea. |
| 10. O-Ring 60x3.5, FPM 70 | IT0000300 | 1 ea. |
| 11. Diaphragm pump | IT0004608 | 1 ea. |
| 12. Acid filter | IT0007237 | 1 ea. |
| 13. O-Ring 56x3 FPM | IT0000777 | 1 ea. |
| 14. Filter cartridge | IT0008163 | 1 ea. |
| 15. Disposable filter unit | IT0001136 | 2 ea. |
| 16. Power supply 24 VDC for opacity | IT0008285 | 1 ea. |


** All consumable parts supply by customer.

RECOMMENDATION

- Should be providing consumable parts air hose for blower unit.

Internal Information Warranty ID

| | |
|--------------------------|---------|
| Gas Analyzer (Uras26) | : 11524 |
| Gas Analyzer (Magnos206) | : 11525 |
| Sampling System | : 11526 |
| Opacity Analyzer | : 11527 |

| | | | |
|--------------|---|--------|--------------|
| CHECK BY : |  | DATE : | 25 July 2024 |
| APPROVE BY : | Nadthapong N. | DATE : | 2 Aug 2024 |



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak , Bangkok 10900, Thailand


TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

GENERAL CHECK

| | | | |
|-------------|--------------|------------|--------------------|
| Unit name : | 12CNA10GH001 | Location : | B.Grimm Power WHA1 |
|-------------|--------------|------------|--------------------|

| ITEM | DESCRIPTION | SET-POINT VALUE | STATUS/VALUE | | REMARK |
|------|--|-----------------------------------|---------------------------|---------------------------|-----------|
| | | | BEFORE | AFTER | |
| 1 | Shelter room temperature | 24-30 DegC | 27°C | 26°C | |
| 2 | Heated sampling probe | No condensate water | No condensate water | No condensate water | |
| 3 | Filter probe | Clean | Clean | Clean | |
| 4 | Probe blow back | Function test (OK) | OK | OK | |
| 5 | Heated line temperature(HRSG) | 120-160 DegC | 141°C | 142°C | |
| 6 | Heated line temperature(By pass) | 120-160 DegC | 144°C | 145°C | |
| 7 | SCC-F operate | Run | Run | Run | |
| 8 | SCC-F sample flow (FM1) | No alarm | 100 lph | 100 lph | |
| 9 | Condensate filter | Clean | Clean | Clean | |
| 10 | Gas cooler temperature | 2.8-3.2 DegC | 3.0°C | 3.0°C | |
| 11 | Peristaltic pump A | Run | Run | Run | |
| 12 | Peristaltic pump B | Run | Run | Run | |
| 13 | Acid filter | Clean | Clean | Clean | |
| 14 | Bypass flow (FM2) | 10-15 l/h | 10 l/h | 10 l/h | |
| 15 | CO/SO ₂ /O ₂ flow (FM3) | 30-50 l/h | 40 l/h | 40 l/h | |
| 16 | NO _x flow (FM4) | 30-50 l/h | 40 l/h | 40 l/h | |
| 17 | NO _x converter temperature | 345-355 °C | 350°C | 350°C | |
| 18 | BV1 (To NO _x converter/Bypass) | NO _x converter | NO _x converter | NO _x converter | |
| 19 | Pressure of span gas cylinder | >300 psig | 1,700 psi | 1,700 psi | |
| 20 | Pressure of air zero cylinder(O ₂) | >300 psig | 500 psi | 400 psi | Recommend |
| 21 | PLC Status | Run | Run | Run | |
| 22 | Stack flow meter | 400,000-700,000 m ³ /h | 311,018 m ³ /h | 324,572 m ³ /h | |
| 23 | Stack temperature | 90-120 DegC | 94.9°C | 97.4°C | |

| | |
|------------|---|
| CHECK BY : |  |
| DATE : | 25 Jul 2024 |



บริษัท เพทโร-อินสตรูเมนต์ จำกัด

PETRO-INSTRUMENTS CORP., LTD.

PETRO - INSTRUMENTS CORP., LTD.

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900

7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak , Bangkok 10900, Thailand

TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207

http : // www.pico.co.th E-mail-address : combustion@pico.co.th

TEST REPORT

| | | | |
|-------------|--------------|------------|--------------------|
| UNIT NAME : | 12CNA10GH001 | LOCATION : | B.Grimm Power WHA1 |
|-------------|--------------|------------|--------------------|

| STANDARD GAS CONCENTRATION | | | | | | |
|----------------------------|---------------|------|--------------|----------------|-------------|----------------|
| Components | Concentration | Unit | Cylinder NO. | Certified Date | Expire Date | Pressure (psi) |
| CO | 163 | ppm | D636036 | 11 Oct 2023 | 11 Oct 2026 | 1,700 |
| SO ₂ | 19.3 | ppm | D636036 | 11 Oct 2023 | 11 Oct 2026 | 1,700 |
| NO | 162 | ppm | D636036 | 11 Oct 2023 | 11 Oct 2026 | 1,700 |
| O ₂ | 21.0 | %Vol | 756564 | 06 May 2021 | 06 May 2029 | 500 |

| MEASUREMENT RESULT BEFORE CALIBRATE | | | | | | | |
|-------------------------------------|-------------|-------------------|-------------|------------------------------------|-------------|---------------------------|--------|
| Parameter | | Measurement Value | | Status Reactive Calibration Drifts | | Offset&Amplify Acceptance | Note |
| | | Reading | Analog (mA) | Offset (%) | Amplify (%) | | |
| CO | 0 - 200 ppm | 1.60 | 4.13 | 1.0% | -1.0% | ± 30 % | Passed |
| SO ₂ | 0 - 25 ppm | -0.70 | 3.55 | 4.0% | 6.0% | | Passed |
| NO _x | 0 - 200 ppm | 11.20 | 4.90 | -1.0% | 0.0% | | Passed |
| NO | 0 - 200 ppm | 9.50 | 4.76 | | | | |
| O ₂ | 0 - 25 %Vol | 13.99 | 12.95 | 0.0% | 0.0% | | Passed |

| VALIDATION RESULT | | | | | | | | | | | |
|-------------------|-------------|-------|--------|-------|---------|--------|--------|-------|---------|--------------------|--------|
| Parameter | | Zero | | | | Span | | | | % Error Acceptance | Note |
| | | Ideal | Actual | Drift | % Error | Ideal | Actual | Drift | % Error | | |
| CO | 0 - 200 ppm | 0.00 | 1.30 | -1.30 | -0.65 | 163.00 | 160.10 | -2.90 | 1.45 | ±2.0 % | passed |
| SO ₂ | 0 - 25 ppm | 0.00 | 0.34 | -0.34 | -1.36 | 19.30 | 19.80 | 0.50 | -2.00 | ±2.0 % | Passed |
| NO _x | 0 - 200 ppm | 0.00 | 0.90 | -0.90 | -0.45 | 162.00 | 159.50 | -2.50 | 1.25 | ±2.0 % | Passed |
| O ₂ | 0 - 25 %Vol | 0.00 | 0.07 | -0.07 | -0.07 | 21.00 | 21.18 | -0.18 | -0.18 | ±0.5 % | Passed |

| CALIBRATION RESULT | | | | | | | | | | | |
|--------------------|-------------|-------|--------|-------|---------|--------|--------|-------|---------|--------------------|--------|
| Parameter | | Zero | | | | Span | | | | % Error Acceptance | Note |
| | | Ideal | Actual | Drift | % Error | Ideal | Actual | Drift | % Error | | |
| CO | 0 - 200 ppm | 0.00 | 0.00 | 0.00 | 0.00 | 163.00 | 163.00 | 0.00 | 0.00 | ±2.0 % | Passed |
| SO ₂ | 0 - 25 ppm | 0.00 | 0.00 | 0.00 | 0.00 | 19.30 | 19.30 | 0.00 | 0.00 | ±2.0 % | Passed |
| NO _x | 0 - 200 ppm | 0.00 | 0.10 | 0.10 | -0.05 | 162.00 | 162.00 | 0.00 | 0.00 | ±2.0 % | Passed |
| O ₂ | 0 - 25 %Vol | 0.00 | 0.00 | 0.00 | 0.00 | 21.00 | 21.00 | 0.00 | 0.00 | ±0.5 % | Passed |

| MEASUREMENT RESULT AFTER CALIBRATE | | | | | | | |
|------------------------------------|-------------|-------------------|-------------|------------------------------------|-------------|---------------------------|--------|
| Parameter | | Measurement Value | | Status Reactive Calibration Drifts | | Offset&Amplify Acceptance | Note |
| | | Reading | Analog (mA) | Offset (%) | Amplify (%) | | |
| CO | 0 - 200 ppm | 0.50 | 4.04 | 1.0% | -7.0% | ± 30 % | Passed |
| SO ₂ | 0 - 25 ppm | 0.42 | 4.27 | 0.0% | 0.0% | | Passed |
| NO _x | 0 - 200 ppm | 12.90 | 5.03 | 0.0% | -4.0% | | Passed |
| NO | 0 - 200 ppm | 10.70 | 4.86 | | | | |
| O ₂ | 0 - 25 %Vol | 14.12 | 13.04 | 0.0% | 0.0% | | Passed |


* % Error Calculate from % of Range.

| | |
|------------|---|
| CHECK BY : |  |
| DATE : | 25 Jul 2024 |



7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900
7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand
TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 9575-9 FAX: (662) 513 3730, 939 4207
http:// www.pico.co.th E-mail address: combustion@pico.co.th

| | | | |
|-----------------------------------|--------------|---------------------------------|---------|
| Analyzer type : | Opacity | Manufacturer : | DURAG |
| Model : | D-R 290 | Control unit serial no.: | 1249527 |
| Measuring head serial no.: | 1251258 | Reflector serial no.: | 1251436 |
| Unit Name : | 12CNA10GH001 | Location : | HRS12 |

| | |
|-------------------|---|
| CHECK BY : |  |
| DATE : | 25 Jul 2024 |

7/409 ซ.วิภาวดีรังสิต 36 ถ.วิภาวดีรังสิต แขวงจตุจักร เขตจตุจักร กรุงเทพฯ 10900
7/409 Soi Vibhavadi-Rangsit 36 Vibhavadi-Rangsit Rd., Chatuchak, Bangkok 10900, Thailand
TEL: (662) 939 5711 (12 Lines), 513 2333 (12 Lines), 513 975-9 FAX: (662) 513 3730, 939 4207
http : // www.pico.co.th E-mail-address : combustion@pico.co.th

| | | | |
|-----------------------------------|--------------|---------------------------------|----------|
| Analyzer type : | Opacity | Manufacturer : | DURAG |
| Model : | D-R 290 | Control unit serial no.: | 1250452 |
| Measuring head serial no.: | 12512559 | Reflector serial no.: | 1251438 |
| Unit Name : | 12CNA10GH001 | Location : | BYPASS12 |

| | |
|-------------------|---|
| CHECK BY : |  |
| DATE : | 25 Jul 2024 |