

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WATER NO.67/1663-1664
SAMPLING DATE	: JULY 1, 2024
RECEIVED DATE	: JULY 1, 2024
SAMPLING BY	: [REDACTED]
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. 7-360

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1663	EFFLUENT No.1664	STANDARD
pH at 25°C	-	pH meter	7.1	7.0	5.5-9.0
Temperature	°C	Thermometer	35.2	29.8	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	33	5.2	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	420	400	3,000
BOD ₅	mg/L	Azide Modification Method	3	3	20
COD	mg/L	Closed Reflux Method	38	41	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
TKN	mg/L	Macro-Kjeldahl Method	2	2	100
Conductivity	µmho/cm	Conductivity Meter	562	541	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	2.5	1.2	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	:	WATER NO.67/1663-1664		
SAMPLING DATE	:	JULY 1, 2024	ANALYTICAL DATE	JULY 1-26, 2024
RECEIVED DATE	:	JULY 1, 2024	APPROVED DATE	: JULY 26, 2024
SAMPLING BY	:	[REDACTED]		
ANALYZED BY	:	ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. : REGISTER NO. 2-360		
		* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. 2-029		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1663	EFFLUENT No.1664	STANDARD
Cyanides (CN)*	mg/L	Distill & Colorimetric	0.042	<0.01	0.2
Formaldehyde*	mg/L	Distill & Colorimetric	<0.05	<0.05	1
Arsenic (As)*	mg/L	Inductively Coupled Plasma-Hydride	<0.001	<0.001	0.25
Barium (Ba)*	mg/L	Inductively Coupled Plasma	0.019	0.012	1.0
Cadmium (Cd)*	mg/L	Inductively Coupled Plasma	<0.02	<0.02	0.03
Total Chromium (Cr)*	mg/L	Calculation Method	<0.05	<0.05	-
Chromium (Cr ⁺³)*	mg/L	Inductively Coupled Plasma	<0.05	<0.05	0.75
Chromium (Cr ⁺⁶)*	mg/L	Inductively Coupled Plasma	<0.003	<0.003	0.25
Copper (Cu)*	mg/L	Inductively Coupled Plasma	<0.01	<0.01	2.0
Lead (Pb)*	mg/L	Inductively Coupled Plasma	<0.05	<0.05	0.2
Manganese (Mn)*	mg/L	Inductively Coupled Plasma	0.063	0.066	5.0
Mercury (Hg)*	mg/L	Inductively Coupled Plasma-Hydried	<0.0005	<0.0005	0.005
Nickel (Ni)*	mg/L	Inductively Coupled Plasma	<0.03	<0.03	1.0
Selenium (Se)*	mg/L	Inductively Coupled Plasma -Hydride	<0.001	<0.001	0.02
Zinc (Zn)*	mg/L	Inductively Coupled Plasma	0.16	0.17	5.0

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO. : WATER NO.67/1924-1925
SAMPLING DATE : JULY 17, 2024 **ANALYTICAL DATE** : JULY 18-31, 2024
RECEIVED DATE : JULY 17, 2024 **APPROVED DATE** : JULY 31, 2024
SAMPLING BY : [REDACTED]
ANALYZED BY : ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๓-360

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT No.1924	EFFLUENT No.1925	STANDARD
pH at 25°C	-	pH meter	7.3	7.2	5.5-9.0
Temperature	°C	Thermometer	31.5	30.4	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	5.2	10	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	330	380	3,000
BOD ₅	mg/L	Azide Modification Method	6	2	20
COD	mg/L	Closed Reflux Method	78	40	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	413	433	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	5.1	1.2	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
 Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WW67/1934 - WW67/1935		
SAMPLING DATE	: August 7, 2024	ANALYTICAL DATE	: August 7-28, 2024
RECEIVED DATE	: August 7, 2024	APPROVED DATE	: August 28, 2024
SAMPLING BY	: [REDACTED]		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. 3-360		


PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	7.7	7.3	5.5-9.0
Temperature	°C	Thermometer	33.0	32.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	19	10	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	560	270	3,000
BOD ₅	mg/L	Azide Modification Method	12	<2	20
COD	mg/L	Closed Reflux Method	29	6	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	771	388	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	2.9	2.8	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO. : WW67/2214 - WW67/2215
SAMPLING DATE : August 21, 2024 **ANALYTICAL DATE** : August 21 -September 6, 2024
RECEIVED DATE : August 21, 2024 **APPROVED DATE** : September 6, 2024
SAMPLING BY : 
ANALYZED BY : ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๓-360

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	7.2	7.0	5.5-9.0
Temperature	°C	Thermometer	29.0	27.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	82	3.2	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	200	190	3,000
BOD ₅	mg/L	Azide Modification Method	4	4	20
COD	mg/L	Closed Reflux Method	6	12	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	275	251	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.1	1.9	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.

Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.




The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO. : WW67/2270 - WW67/2271
SAMPLING DATE : September 4, 2024 **ANALYTICAL DATE** : September 4-20, 2024
RECEIVED DATE : September 4, 2024 **APPROVED DATE** : September 20, 2024
SAMPLING BY : 
ANALYZED BY : ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. 2-360

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	7.6	7.4	5.5-9.0
Temperature	°C	Thermometer	32.0	30.0	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	18	3.2	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	200	200	3,000
BOD ₅	mg/L	Azide Modification Method	6	3	20
COD	mg/L	Closed Reflux Method	19	19	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	284	303	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	2.9	3.5	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	:	WW67/2499 - WW67/2500			
SAMPLING DATE	:	September 18, 2024	ANALYTICAL DATE	:	September 18 - October 21, 2024
RECEIVED DATE	:	September 18, 2024	APPROVED DATE	:	October 21, 2024
SAMPLING BY	:	[REDACTED]			
ANALYZED BY	:	ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๓-360			

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	6.9	6.8	5.5-9.0
Temperature	°C	Thermometer	32.6	31.8	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	10	14	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	240	270	3,000
BOD ₅	mg/L	Azide Modification Method	14	7	20
COD	mg/L	Closed Reflux Method	74	41	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	331	482	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	2.1	1.9	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALYTY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	:	WW67/2596 - WW67/2597	
SAMPLING DATE	:	October 4, 2024	ANALYTICAL DATE : October 4-29, 2024
RECEIVED DATE	:	October 4, 2024	APPROVED DATE : October 29, 2024
SAMPLING BY	:	[REDACTED]	
ANALYZED BY	:	ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. 3-360	

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	6.8	6.8	5.5-9.0
Temperature	°C	Thermometer	28.6	30.9	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	30	11	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	110	250	3,000
BOD ₅	mg/L	Azide Modification Method	<2	<2	20
COD	mg/L	Closed Reflux Method	26	20	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
TKN	mg/L	Macro-Kjeldahl Method	<1	<1	100
Conductivity	µmho/cm	Conductivity Meter	167	327	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	6.2	2.7	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO. : WW67/2596 - WW67/2597
SAMPLING DATE : October 4, 2024 **ANALYTICAL DATE** : October 4-29, 2024
RECEIVED DATE : October 4, 2024 **APPROVED DATE** : October 29, 2024
SAMPLING BY : XXXXXXXXXXXXXXXXXXXX
ANALYZED BY : ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. : REGISTER NO. ๓-360
* ENVIRONMENTAL & LABORATORY CO.,LTD. REGISTER : NO. ๓-029

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
Hydrogen Cyanide (HCN)*	mg/L	Distill & Colorimetric	<0.01	<0.01	0.2
Formaldehyde*	mg/L	Distill & Colorimetric	<0.05	<0.05	1
Arsenic (As)*	mg/L	Inductively Coupled Plasma-Hydride	0.012	0.019	0.25
Barium (Ba)*	mg/L	Inductively Coupled Plasma	0.033	0.047	1.0
Cadmium (Cd)*	mg/L	Inductively Coupled Plasma	0.008	<0.03	0.03
Total Chromium (Cr)*	mg/L	Calculation Method	<0.03	<0.03	-
Chromium (Cr ⁺³)*	mg/L	Inductively Coupled Plasma	<0.03	<0.03	0.75
Chromium (Cr ⁺⁶)*	mg/L	Inductively Coupled Plasma	<0.003	<0.003	0.25
Copper (Cu)*	mg/L	Inductively Coupled Plasma	0.048	<0.01	2.0
Lead (Pb)*	mg/L	Inductively Coupled Plasma	<0.03	<0.03	0.2
Manganese (Mn)*	mg/L	Inductively Coupled Plasma	0.20	0.16	5.0
Mercury (Hg)*	mg/L	Inductively Coupled Plasma-Hydried	<0.0005	<0.0005	0.005
Nickel (Ni)*	mg/L	Inductively Coupled Plasma	0.024	0.032	1.0
Selenium (Se)*	mg/L	Inductively Coupled Plasma -Hydride	<0.02	<0.02	0.02
Zinc (Zn)*	mg/L	Inductively Coupled Plasma	1.0	0.31	5.0

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d. published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	: WW67/2757 - WW67/2758		
SAMPLING DATE	: October 16, 2024	ANALYTICAL DATE	: October 16 - November 5, 2024
RECEIVED DATE	: October 16, 2024	APPROVED DATE	: November 6, 2024
SAMPLING BY	: [REDACTED]		
ANALYZED BY	: ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. 3-360		

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	7.1	7.1	5.5-9.0
Temperature	°C	Thermometer	38.2	37.6	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	44	9.6	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	410	230	3,000
BOD ₅	mg/L	Azide Modification Method	<2	6	20
COD	mg/L	Closed Reflux Method	6	38	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	479	294	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	10.8	4.9	-


STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO. : WW67/2815 - WW67/2816
SAMPLING DATE : November 6, 2024 **ANALYTICAL DATE** : November 6-25, 2024
RECEIVED DATE : November 6, 2024 **APPROVED DATE** : November 25, 2024
SAMPLING BY : 
ANALYZED BY : ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๓-360

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	6.5	6.6	5.5-9.0
Temperature	°C	Thermometer	36.5	30.3	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	27	15	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	220	1,950	3,000
BOD ₅	mg/L	Azide Modification Method	4	3	20
COD	mg/L	Closed Reflux Method	16	22	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	301	2,302	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	0	1.4	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME	: BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT	: 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION	: Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO.	:	WW67/3041 - WW67/3042			
SAMPLING DATE	:	November 20, 2024	ANALYTICAL DATE	:	November 20-29, 2024
RECEIVED DATE	:	November 20, 2024	APPROVED DATE	:	November 29, 2024
SAMPLING BY	:	[REDACTED]			
ANALYZED BY	:	ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๓-360			

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	7.3	7.2	5.5-9.0
Temperature	°C	Thermometer	34.6	34.5	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	9.2	9.6	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	220	230	3,000
BOD ₅	mg/L	Azide Modification Method	6	<2	20
COD	mg/L	Closed Reflux Method	12	12	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	346	328	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.7	5.3	-


STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO. : WW67/3225 - WW67/3226
SAMPLING DATE : December 6, 2024 **ANALYTICAL DATE** : December 6-20, 2024
RECEIVED DATE : December 6, 2024 **APPROVED DATE** : December 20, 2024
SAMPLING BY : 
ANALYZED BY : ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. 3-360

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	7.0	7.1	5.5-9.0
Temperature	°C	Thermometer	38.6	32.7	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	130	5.8	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	250	270	3,000
BOD ₅	mg/L	Azide Modification Method	6	5	20
COD	mg/L	Closed Reflux Method	46	20	120
Oil & Grease	mg/L	Partition & Gravimetric Method	6	<5	5
Conductivity	µmho/cm	Conductivity Meter	351	398	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	3.8	7.5	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.

RESULTS OF WASTE WATER QUALITY ANALYSIS

CUSTOMER NAME : BIRLA CARBON (THAILAND) PUBLIC CO., LTD
ADDRESS CONTACT : 44 MOO.1, AYUTHAYA-ANGTHONG HIGHWAY, T. POSA, A. MUNG, ANGTHONG 14000
INFORMATION : Tel. : 0-3567 2150-4 Fax : 0-3567 2148

ANALYSIS REPORT NO. : WW67/3389 - WW67/3390
SAMPLING DATE : December 18, 2024 ANALYTICAL DATE : December 18, 2024-January 14,2025
RECEIVED DATE : December 18, 2024 APPROVED DATE : January 14,2025
SAMPLING BY :
ANALYZED BY : ENVIRONMENTAL & RESOURCE DEVELOPMENT CO.,LTD. REGISTER NO. ๓-360

PARAMETERS	UNIT	METHOD OF ANALYSIS	INFLUENT	EFFLUENT	STANDARD
pH at 25°C	-	pH meter	6.2	6.4	5.5-9.0
Temperature	°C	Thermometer	34.6	32.4	40
Total Suspended Solids (TSS)	mg/L	Dried at 103-105 °C	35	17	50
Total Dissolved Solids (TDS)	mg/L	Dried at 180 °C	240	220	3,000
BOD ₅	mg/L	Azide Modification Method	8	5	20
COD	mg/L	Closed Reflux Method	22	22	120
Oil & Grease	mg/L	Partition & Gravimetric Method	<5	<5	5
Conductivity	µmho/cm	Conductivity Meter	353	319	-
Dissolved Oxygen (DO)	mg/L	Azide Modification Method	5.4	6.4	-

STANDARD = Notification of the Ministry of Industry on setting standards for factory effluent control.
Book 134, Special Chapter 153 d, published in the Royal Gazette, dated 7 June 2017.

The results of this analysis only apply to the samples tested.

No part of this report October be copied or reproduced without the written permission of the laboratory.