

Request No. LA67-R0816

Report No. R6708-3813 - R6708-3816

TEST REPORT

CUSTOMER : Meyer Aluminium (Thailand) Co., Ltd.

ADDRESS : 38/32 Moo 5 Laem Chabang Industrial Estate, Sriracha, Chonburi 20230

SAMPLE SOURCE : Meyer Aluminium (Thailand) Co., Ltd.

MEASURING DATE : 07/08/2024 SAMPLE NO. : 29193-29196

RECEIVED DATE : 07/08/2024 REPORTED DATE : 08/08/2024


SAMPLING INSTRUMENT* : Wind Vane Anemometer

Location	Temperature (°C)	Diameter (m)	Area (m ²)	Velocity (m/s)	Flow Rate (m ³ /s)
1. Hood เต้าพัก No. 1	39.3	1.0	0.785714	12.88	10.11843
2. Hood เต้าหลอม No. 1	50.6	1.0	0.785714	12.93	10.15929
3. Hood เต้าพัก No. 2	32.3	1.0	0.785714	9.19	7.22229
4. Hood เต้าหลอม No. 2	31.6	1.0	0.785714	10.57	8.30186

REMARK :

* Parameter Outside The Scope of The Registration of The Department of Industrial Works

(Measurement By Mr. Metee Sukprasert)



Approved By.....

Thongchai Boonsak

(MR. THONGCHAI BOONSAK)

08/08/2024

บริษัท อีสเทิร์นไทยคอนซัลติ้ง 1992 จำกัด
REPORTED TEST REFER TO SUBMITTED SAMPLES ONLY
THIS REPORT SHALL NOT REPRODUCED EXCEPT IN FULL
WITHOUT THE WRITTEN APPROVAL LABORATORY

COPY