
7.10 ตัวอย่างคู่มือการอนุรักษ์พลังงานให้กับผู้พักอาศัย

FOUR SEASONS
PRIVATE RESIDENCES
BANGKOK AT CHAO PHRAYA RIVER



Energy Efficiency Manual

คู่มืออนุรักษ์พลังงาน

FOUR SEASONS
PRIVATE RESIDENCES
BANGKOK AT CHAO PHRAYA RIVER

คำนำ

โลกกำลังเผชิญสภาวะวิกฤตพลังงานและสภาวะโลกร้อน การใช้พลังงานอย่างฟุ่มเฟือยและไม่ถูกวิธี ก็เป็นสาเหตุหนึ่งที่จะทำให้เกิดสภาพการณ์นี้

ในปี 2551 มีการประเมินว่าปริมาณการใช้ไฟฟ้าจะสูงกว่าปีที่ผ่าน ๆมา โดยคาดว่าจะมีระดับสูงถึง 23,957 เมกะวัตต์ พวกเราต้องแบกภาระค่าใช้จ่ายด้านพลังงานเพิ่มขึ้น

ในขณะที่ประเทศไทยสูญเสียเงินตราในการนำเข้าพลังงาน โดยเฉพาะน้ำมันจากต่างประเทศ ซึ่งคาดว่าจะต้องนำเข้าน้ำมันกว่า 700,000 ล้านลิตร

นับวันวิกฤตการณ์นี้ทวีความรุนแรงหากแต่ละคนแต่ละครอบครัวลงมือประหยัดพลังงานตามคำแนะนำในคู่มือเล่มนี้ก็จะช่วยลดค่าใช้จ่ายของตนเองและช่วยเศรษฐกิจของประเทศ...

FOUR SEASONS
PRIVATE RESIDENCES
BANGKOK AT CHAO PHRAYA RIVER

สารบัญ





หลอดไฟ



เครื่องปรับอากาศ



วิธีประหยัดน้ำ



วิธีประหยัดน้ำมัน



7.11 ตัวอย่างเอกสารการตรวจสอบอุปกรณ์ดับเพลิง และทางหนีไฟ

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: July, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
Roof top floor	ROOFTOP HELIPAD FLOOR	FHB	1					✓			
	FHC - 11 - 01	FHC/FE	1	1				✓			
	FHC - 11 - 02	FHC/FE	1	1				✓			
	FHC - 11 - 03	FHC/FE	1	1				✓			
	EE ROOM	CO2			1			✓			
10th floor	FHC - 10 - 01	FHC/FE	1	1				✓			
	FHC - 10 - 02	FHC/FE	1	1				✓			
	FHC - 10 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 1009-1010	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 1003-1005	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
9th floor	FHC - 9 - 01	FHC/FE	1	1				✓			
	FHC - 9 - 02	FHC/FE	1	1				✓			
	FHC - 9 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 908-909	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 903-905	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
8th floor	FHC - 8 - 01	FHC/FE	1	1				✓			
	FHC - 8 - 02	FHC/FE	1	1				✓			
	FHC - 8 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 808-809	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 802-803	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
7th floor	FHC - 7 - 01	FHC/FE	1	1				✓			
	FHC - 7 - 02	FHC/FE	1	1				✓			
	FHC - 7 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 708-709	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 702-703	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: July, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
6th floor	FHC - 6 - 01	FHC/FE	1	1				✓			
	FHC - 6 - 02	FHC/FE	1	1				✓			
	FHC - 6 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 608-609	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 602-603	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2	-		1			✓			
5th floor	FHC - 5 - 01	FHC/FE	1	1				✓			
	FHC - 5 - 02	FHC/FE	1	1				✓			
	FHC - 5 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 509-510	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 503-505	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
4th floor	FHC - 4 - 01	FHC/FE	1	1				✓			
	FHC - 4 - 02	FHC/FE	1	1				✓			
	FHC - 4 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 409-410	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 403-405	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
3rd floor	FHC - 3 - 01	FHC/FE	1	1				✓			
	FHC - 3 - 02	FHC/FE	1	1				✓			
	FHC - 3 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 309-310	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 303-305	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: July, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
2nd floor	FHC - 2 - 1/6 R210	FHC/FE	1	1				/			
	FHC - 2 - 2/6 R206	FHC/FE	1	1				/			
	FHC - 2 - 3/6 COTE	FHC/FE	1	1				/			
	FHC - 2 - 4/6 TOLIET	FHC/FE	1	1				/			
	FHC - 2 - 5/6 ATELIER 1	FHC/FE	1	1				/			
	HK PANTRY(ZONE ST5)	FIRE EXTINGUISHER		1				/			
	COTE KITCHEN	CLASS K				1		/			
	INFRONT OF COTE KITCHEN	CLASS K				1		/			
	SHAFT ROOM BETWEEN 208-209	FIRE EXTINGUISHER		1				/			
	EE ROOM BOH	CO2			1			/			
	COTE KITCHEN	FIRE BLANKET					1	/			
LOBBY LEVEL	FHC - L - 1/6 SA4	FHC/FE	1	1				/			
	FHC- L - 2/6 POOL AREA	FHC/FE	1	1				/			
	FHC - L -3/6 LIVING ROOM	FHC/FE	1	1				/			
	FHC - L - 4/6 IN FRONT OF FRONT DEPT	FHC/FE	1	1				/			
	FHC - L - 5/6 SA7 STELLA	FHC/FE	1	1				/			
	FHC- L - 6/6 TOILET SA3	FHC/FE	1	1				/			
	SHAFT ROOM BETWEEN 109-110	FIRE EXTINGUISHER		1				/			
	HK PANTRY ZONE ST5	FIRE EXTINGUISHER		1				/			
	EE ROOM BOH	CO2			1			/			
	FO OFFICE	FIRE EXTINGUISHER		1				/			
	FO CORRIDOR	FIRE EXTINGUISHER		1				/			
	FHC - L -06 BQ WASH	FHC/FE	1	1				/			
	FHC - L -07 BQ STORE	FHC/FE	1	1				/			
	FHC - L -08 SALON BALLROOM	FHC/FE	1	1				/			
	BQ KITCHEN	CLASS K				1		/			
	BQ KITCHEN	FIRE BLANKET					1	/			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: July, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
LOWER LOBBY	FHC - LL - 1/12 VILLA 8	FHC/FE	1	1				√			
	FHC - LL - 2/12 IN FRONT FIRE FUMP ROOM	FHC/FE	1	1				√			
	FHC - LL - 3/12 COOLING TOWER AREA	FHC/FE	1	1				√			
	FHC - LL - 4/12 IN FRONT OF VILLA1	FHC/FE	1	1				√			
	FHC - LL - 5/12 IN FRONT OF FINACE ROOM	FHC/FE	1	1				√			
	FHC - LL - 6/12 SA2	FHC/FE	1	1				√			
	FHC - LL - 7/12 IN FRONT UNIFORM ROOM	FHC/FE	1	1				√			
	FHC - LL - 8/12 IN FRONT OF AHU ROOM	FHC/FE	1	1				√			
	FHC - LL - 9/12 GENERATER ROOM	FHC/FE	1	1				√			
	FHC - LL - 10/12 PHRA NAKHORN	FHC/FE	1	1				√			
	FHC - LL - 11/12 MAIN KITCHEN	FHC/FE	1	1				√			
	FHC - LL - 12/12 LOADING AREA	FHC/FE	1	1				√			
	EXECUTIVE OFFICE	FHC/FE	1	1				√			
	AURIGA SPA	FHC/FE	1	1				√			
	FHL - LL- 5 WALK WAY TO LIFT BQ	FHC/FE	1	1				√			
	EXECUTIVE OFFICE	FIRE EXTINGUISHER									
	FB OFFICE	FIRE EXTINGUISHER									
	SALE OFFICE	FIRE EXTINGUISHER									
	ENGINEERING OFFICE	FIRE EXTINGUISHER		1				√			
	FINANCE OFFICE	FIRE EXTINGUISHER									
	HR OFFICE	FIRE EXTINGUISHER									
	IT OFFICE	FIRE EXTINGUISHER									
	SERVER ROOM	FIRE EXTINGUISHER									
	101 KITCHEN	CLASS K			0			√			
	HK OFFICE	FIRE EXTINGUISHER		1				√		Type K was broken = 1 tank	
	COMMUNICATION ROOM	FIRE EXTINGUISHER		5	4	7		√			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: July, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
LOWER LOBBY	LP OFFICE	FIRE EXTINGUISHER		1				✓			
	TRAINING ROOM	FIRE EXTINGUISHER									
	IN FRONT OF IT OFFICE	CO2			1			✓			
	IN FRONT OF EE ROOM	CO2			1			✓			
	IN FRONT OF LP OFFICE	CO2			1			✓			
	MAIN KITCHEN DOOR 05	CLASS K				1		✓			
	MAIN KITCHEN DOOR 05	CO2			1			✓			
	MAIN KITCHEN DOOR 03 (COLD KITCHEN)	CLASS K				1		✓			
	MAIN KITCHEN DOOR 03 (COLD KITCHEN)	CO2			1			✓			
	MAIN KITCHEN DOOR 01 (BEKERY)	CLASS K				1		✓			
	MAIN KITCHEN DOOR 01 (BEKERY)	CO2			1			✓			
	MAIN KITCHEN DOOR 04	CLASS K				1		✓			
	MAIN KITCHE DOOR 04	CO2			1			✓			
	FREEZER CORRIDOR	CLASS K				1		✓			
	PRE VEGETABLE CORRIDOR	CLASS K				1		✓			
	BUTCHER	CLASS K				1		✓			
	BEVERAGE STORE	CLASS K				1		✓			
	DRY STORE	CLASS K				1		✓			
	IN FRONT PURCHASING OFFICE	CLASS K / DRY		1		1		✓			
	IN FRONT OF AHU ROOM	FIRE EXTINGUISHER		1				✓			
	FIRE CART OF CABINET	FIRE EXTINGUISHER		1				✓			
	IN FRONT OF COMMUNICATION ROOM	CO2			1		-	✓			
	101 KITCHEN	FIRE BLANKET					1	✓			
	MAINKITCHEN	FIRE BLANKET			6		1	✓			
	FIRE CART OF CABINET	FIRE BLANKET					3	✓		2 Used	
	Cooling Room	FIRE EXTINGUISHER		2				✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: July, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS YES	STATUS NO	ADDITIONAL & COMMENT	CHECK: BY
BASEMENT 1	FHC - B1 - 1/10 SA4	FHC/FE	1	1				✓			
	FHC - B1 - 2/10 SA1	FHC/FE	1	1				✓			
	FHC - B1 - 3/10 PARKING B8	FHC/FE	1	1				✓			
	FHC - B1 - 4/10 BACK OF NEW DRIVER ROOM	FHC/FE	1	1				✓			
	FHC - B1 - 5/10 IN FRONT EXIT SA2	FHC/FE	1	1				✓			
	FHC - B1 - 6/10 PARKING A3	FHC/FE	1	1				✓			
	FHC - B1 - 7/10 INFRONT TOLIET	FHC/FE	1	1				✓			
	FHC - B1 - 8/10 SA7	FHC/FE	1	1				✓			
	FHC - B1 - 9/10 SA3	FHC/FE	1	1				✓			
	FHC - B1 - 10/10 Fan Room1	FHC/FE	1	1				✓			
	EE ROOM	CO2			1			✓			
	PARKING ZONE B5	FIRE EXTINGUISHER		1				✓			
	PARKING ZONE D3	FIRE EXTINGUISHER		1				✓			
	PARKING ZONE F10	FIRE EXTINGUISHER		1				✓			
	LILLY POND ROOM	FIRE EXTINGUISHER		1				✓			
	Fan Room 1	FIRE EXTINGUISHER		1				✓			
	Fan Room 2	FIRE EXTINGUISHER		1				✓			
	CHILLER PLANT ROOM	FIRE EXTINGUISHER		1				✓			
	AT WALL B1 CHILLER ROOM	FIRE EXTINGUISHER		1				✓			
Total			FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET				
			67	111	21	22	7				

Remark:

1	CO2 Standby at Communication Room & ..... Finish out of service 3.
5	Dry Chemical Stanby Communication Room & ..... Finish out of service 2
7	Type K Standby at Communication Room & ..... Finish out of Service 1

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: July, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		

Checked by:≤ _____And__ _ Date:_____/_____/_____

Senior Loss Prevention Supervisor

11-15/07/24.

Verfied by:__ . Date: 1 / 8 / 2024

N

Director of Loss Prevention

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: September, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
Roof top floor	ROOFTOP HELIPAD FLOOR	FHB	1					✓			
	FHC - 11 - 01	FHC/FE	1	1				✓			
	FHC - 11 - 02	FHC/FE	1	1				✓			
	FHC - 11 - 03	FHC/FE	1	1				✓			
	EE ROOM	CO2			1			✓			
10th floor	FHC - 10 - 01	FHC/FE	1	1				✓			
	FHC - 10 - 02	FHC/FE	1	1				✓			
	FHC - 10 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 1009-1010	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 1003-1005	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
9th floor	FHC - 9 - 01	FHC/FE	1	1				✓			
	FHC - 9 - 02	FHC/FE	1	1				✓			
	FHC - 9 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 908-909	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 903-905	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
8th floor	FHC - 8 - 01	FHC/FE	1	1				✓			
	FHC - 8 - 02	FHC/FE	1	1				✓			
	FHC - 8 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 808-809	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 802-803	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
7th floor	FHC - 7 - 01	FHC/FE	1	1				✓			
	FHC - 7 - 02	FHC/FE	1	1				✓			
	FHC - 7 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 708-709	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 702-703	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: September, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
6th floor	FHC - 6 - 01	FHC/FE	1	1				✓			
	FHC - 6 - 02	FHC/FE	1	1				✓			
	FHC - 6 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 608-609	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 602-603	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
5th floor	FHC - 5 - 01	FHC/FE	1	1				✓			
	FHC - 5 - 02	FHC/FE	1	1				✓			
	FHC - 5 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 509-510	FIRE EXTINGUISHER	1	1				✓			
	SHAFT ROOM BETWEEN 503-505	FIRE EXTINGUISHER	1	1				✓			
	EE ROOM BOH	CO2			1			✓			
4th floor	FHC - 4 - 01	FHC/FE	1	1				✓			
	FHC - 4 - 02	FHC/FE	1	1				✓			
	FHC - 4 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 409-410	FIRE EXTINGUISHER	1	1				✓			
	SHAFT ROOM BETWEEN 403-405	FIRE EXTINGUISHER	1	1				✓			
	EE ROOM BOH	CO2			1			✓			
3rd floor	FHC - 3 - 01	FHC/FE	1	1				✓			
	FHC - 3 - 02	FHC/FE	1	1				✓			
	FHC - 3 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 309-310	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 303-305	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: September, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
2nd floor	FHC - 2 - 1/6 R210	FHC/FE	1	1				✓			
	FHC - 2 - 2/6 R206	FHC/FE	1	1				✓			
	FHC - 2 - 3/6 COTE	FHC/FE	1	1				✓			
	FHC - 2 - 4/6 TOLIET	FHC/FE	1	1				✓			
	FHC - 2 - 5/6 ATELIER 1	FHC/FE	1	1				✓			
	HK PANTRY(ZONE ST5)	FIRE EXTINGUISHER		1				✓			
	COTE KITCHEN	CLASS K				1		✓			
	INFRONT OF COTE KITCHEN	CLASS K				1		✓			
	SHAFT ROOM BETWEEN 208-209	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
	COTE KITCHEN	FIRE BLANKET					1	✓			
LOBBY LEVEL	FHC - L - 1/6 SA4	FHC/FE	1	1				✓			
	FHC- L - 2/6 POOL AREA	FHC/FE	1	1				✓			
	FHC - L -3/6 LIVING ROOM	FHC/FE	1	1				✓			
	FHC - L - 4/6 IN FRONT OF FRONT DEPT	FHC/FE	1	1				✓			
	FHC - L - 5/6 SA7 STELLA	FHC/FE	1	1				✓			
	FHC- L - 6/6 TOILET SA3	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 109-110	FIRE EXTINGUISHER		1				✓			
	HK PANTRY ZONE ST5	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
	FO OFFICE	FIRE EXTINGUISHER		1				✓			
	FO CORRIDOR	FIRE EXTINGUISHER		1				✓			
	FHC - L -06 BQ WASH	FHC/FE	1	1				✓			
	FHC - L -07 BQ STORE	FHC/FE	1	1				✓			
	FHC - L -08 SALON BALLROOM	FHC/FE	1	1				✓			
	BQ KITCHEN	CLASS K				1		✓			
	BQ KITCHEN	FIRE BLANKET					1	✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: September, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
LOWER LOBBY	FHC - LL - 1/12 VILLA 8	FHC/FE	1	1				✓			
	FHC - LL - 2/12 IN FRONT FIRE FUMP ROOM	FHC/FE	1	1				✓			
	FHC - LL - 3/12 COOLING TOWER AREA	FHC/FE	1	1				✓			
	FHC - LL - 4/12 IN FRONT OF VILLA1	FHC/FE	1	1				✓			
	FHC - LL - 5/12 IN FRONT OF FINACE ROOM	FHC/FE	1	1				✓			
	FHC - LL - 6/12 SA2	FHC/FE	1	1				✓			
	FHC - LL - 7/12 IN FRONT UNIFORM ROOM	FHC/FE	1	1				✓			
	FHC - LL - 8/12 IN FRONT OF AHU ROOM	FHC/FE	1	1				✓			
	FHC - LL - 9/12 GENERATER ROOM	FHC/FE	1	1				✓			
	FHC - LL - 10/12 PHRA NAKHORN	FHC/FE	1	1				✓			
	FHC - LL - 11/12 MAIN KITCHEN	FHC/FE	1	1				✓			
	FHC - LL - 12/12 LOADING AREA	FHC/FE	1	1				✓			
	EXECUTIVE OFFICE	FHC/FE	1	1				✓			
	AURIGA SPA	FHC/FE	1	1				✓			
	FHL - LL- 5 WALK WAY TO LIFT BQ	FHC/FE	1	1				✓			
	EXECUTIVE OFFICE	FIRE EXTINGUISHER									
	FB OFFICE	FIRE EXTINGUISHER									
	SALE OFFICE	FIRE EXTINGUISHER									
	ENGINEERING OFFICE	FIRE EXTINGUISHER		1				✓			
	FINANCE OFFICE	FIRE EXTINGUISHER									
	HR OFFICE	FIRE EXTINGUISHER									
	IT OFFICE	FIRE EXTINGUISHER									
	SERVER ROOM	FIRE EXTINGUISHER									
	101 KITCHEN	CLASS K				2		✓			
	HK OFFICE	FIRE EXTINGUISHER		1				✓		Type K was broken = 1 tank	
	COMMUNICATION ROOM	FIRE EXTINGUISHER		5	4	7		√			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: September, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
LOWER LOBBY	LP OFFICE	FIRE EXTINGUISHER		1				✓			
	TRAINING ROOM	FIRE EXTINGUISHER									
	IN FRONT OF IT OFFICE	CO2			1			✓		CO2 used 12/09/24 (T)	
	IN FRONT OF EE ROOM	CO2			1			✓		CO2 used 12/09/24 (T)	
	IN FRONT OF LP OFFICE	CO2			1			✓			
	MAIN KITCHEN DOOR 05	CLASS K				1		✓			
	MAIN KITCHEN DOOR 05	CO2			1			✓			
	MAIN KITCHEN DOOR 03 (COLD KITCHEN)	CLASS K				1		✓			
	MAIN KITCHEN DOOR 03 (COLD KITCHEN)	CO2			1			✓			
	MAIN KITCHEN DOOR 01 (BEKERY)	CLASS K				1		✓			
	MAIN KITCHEN DOOR 01 (BEKERY)	CO2			1			✓			
	MAIN KITCHEN DOOR 04	CLASS K				1		✓			
	MAIN KITCHE DOOR 04	CO2			1			✓			
	FREEZER CORRIDOR	CLASS K				1		✓			
	PRE VEGETABLE CORRIDOR	CLASS K				1		✓			
	BUTCHER	CLASS K		1		1		✓			
	BEVERAGE STORE	CLASS K				1		✓			
	DRY STORE	CLASS K				1		✓			
	IN FRONT PURCHASING OFFICE	CLASS K / DRY		1				✓			
	IN FRONT OF AHU ROOM	FIRE EXTINGUISHER		1				✓			
	FIRE CART OF CABINET	FIRE EXTINGUISHER		1				✓			
	IN FRONT OF COMMUNICATION ROOM	CO2			1			✓			
	101 KITCHEN	FIRE BLANKET					1	✓			
	MAINKITCHEN	FIRE BLANKET			6		1	✓			
	FIRE CART OF CABINET	FIRE BLANKET					3	✓		2 Used	
	Cooling Room	FIRE EXTINGUISHER		2				✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: September, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
BASEMENT 1	FHC - B1 - 1/10 SA4	FHC/FE	1	1				✓			
	FHC - B1 - 2/10 SA1	FHC/FE	1	1				✓			
	FHC - B1 - 3/10 PARKING B8	FHC/FE	1	1				✓			
	FHC - B1 - 4/10 BACK OF NEW DRIVER ROOM	FHC/FE	1	1				✓			
	FHC - B1 - 5/10 IN FRONT EXIT SA2	FHC/FE	1	1				✓			
	FHC - B1 - 6/10 PARKING A3	FHC/FE	1	1				✓			
	FHC - B1 - 7/10 INFRONT TOLIET	FHC/FE	1	1				✓			
	FHC - B1 - 8/10 SA7	FHC/FE	1	1				✓			
	FHC - B1 - 9/10 SA3	FHC/FE	1	1				✓			
	FHC - B1 - 10/10 Fan Room1	FHC/FE	1	1				✓			
	EE ROOM	CO2			1			✓			
	PARKING ZONE B5	FIRE EXTINGUISHER		1				✓			
	PARKING ZONE D3	FIRE EXTINGUISHER		1				✓			
	PARKING ZONE F10	FIRE EXTINGUISHER		1				✓			
	LILLY POND ROOM	FIRE EXTINGUISHER		1				✓			
	Fan Room 1	FIRE EXTINGUISHER		1				✓			
	Fan Room 2	FIRE EXTINGUISHER		1				✓			
	CHILLER PLANT ROOM	FIRE EXTINGUISHER		2				✓			
	AT WALL B1 CHILLER ROOM	FIRE EXTINGUISHER		1				✓			
Total			FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET				
			67	111	24	22	7				

Remark:

6	CO2 Standby at Communication Room & ..... Fully = 2 / Used = 4. .....
4	Dry Chemical Stanby Communication Room & ..... Fully = 5 / Used = 2 .....
8	Type K Standby at Communication Room & ..... Fully = 8 / Used = 1. .....

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: September, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		

Remark: Extinguishers CO2 In front of IT and EE on LL. Used for Evacuation and Fire drill 12/09/24

Checked by: - And ____ Date: 21 / 9 / 24

Senior Loss Prevention Supervisor

11-17/09/24

Verfied by: Date: 26 / 9 / 2024

Director of Loss Prevention

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA

Monthly: November, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
Roof top floor	ROOFTOP HELIPAD FLOOR	FHB	1	1				✓			
	FHC - 11 - 01	FHC/FE	1	1				✓			
	FHC - 11 - 02	FHC/FE	1	1				✓			
	FHC - 11 - 03	FHC/FE	1	1				✓			
	EE ROOM	CO2			1			✓			
10th floor	FHC - 10 - 01	FHC/FE	1	1				✓			
	FHC - 10 - 02	FHC/FE	1	1				✓			
	FHC - 10 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 1009-1010	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 1003-1005	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
9th floor	FHC - 9 - 01	FHC/FE	1	1				✓			
	FHC - 9 - 02	FHC/FE	1	1				✓			
	FHC - 9 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 908-909	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 903-905	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
8th floor	FHC - 8 - 01	FHC/FE	1	1				✓			
	FHC - 8 - 02	FHC/FE	1	1				✓			
	FHC - 8 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 808-809	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 802-803	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
7th floor	FHC - 7 - 01	FHC/FE	1	1				✓			
	FHC - 7 - 02	FHC/FE	1	1				✓			
	FHC - 7 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 708-709	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 702-703	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: November, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
6th floor	FHC - 6 - 01	FHC/FE	1	1				✓			
	FHC - 6 - 02	FHC/FE	1	1				✓			
	FHC - 6 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 608-609	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 602-603	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
5th floor	FHC - 5 - 01	FHC/FE	1	1				✓			
	FHC - 5 - 02	FHC/FE	1	1				✓			
	FHC - 5 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 509-510	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 503-505	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
4th floor	FHC - 4 - 01	FHC/FE	1	1				✓			
	FHC - 4 - 02	FHC/FE	1	1				✓			
	FHC - 4 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 409-410	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 403-405	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
3rd floor	FHC - 3 - 01	FHC/FE	1	1				✓			
	FHC - 3 - 02	FHC/FE	1	1				✓			
	FHC - 3 - 03	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 309-310	FIRE EXTINGUISHER		1				✓			
	SHAFT ROOM BETWEEN 303-305	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA

Monthly: November, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
2nd floor	FHC - 2 - 1/6 R210	FHC/FE	1	1				✓			
	FHC - 2 - 2/6 R206	FHC/FE	1	1				✓			
	FHC - 2 - 3/6 COTE	FHC/FE	1	1				✓			
	FHC - 2 - 4/6 TOLIET	FHC/FE	1	1				✓			
	FHC - 2 - 5/6 ATELIER 1	FHC/FE	1	1				✓			
	HK PANTRY(ZONE ST5)	FIRE EXTINGUISHER		1				✓			
	COTE KITCHEN	CLASS K				1		✓			
	INFRONT OF COTE KITCHEN	CLASS K				1		✓			
	SHAFT ROOM BETWEEN 208-209	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
	COTE KITCHEN	FIRE BLANKET					1	✓			
			-	-	-	-	-				
			-	-	-	-	-				
LOBBY LEVEL	FHC - L - 1/6 SA4	FHC/FE	1	1				✓			
	FHC- L - 2/6 POOL AREA	FHC/FE	1	1				✓			
	FHC - L -3/6 LIVING ROOM	FHC/FE	1	1				✓			
	FHC - L - 4/6 IN FRONT OF FRONT DEPT	FHC/FE	1	1				✓			
	FHC - L - 5/6 SA7 STELLA	FHC/FE	1	1				✓			
	FHC- L - 6/6 TOILET SA3	FHC/FE	1	1				✓			
	SHAFT ROOM BETWEEN 109-110	FIRE EXTINGUISHER		1				✓			
	HK PANTRY ZONE ST5	FIRE EXTINGUISHER		1				✓			
	EE ROOM BOH	CO2			1			✓			
	FO OFFICE	FIRE EXTINGUISHER		1				✓			
	FO CORRIDOR	FIRE EXTINGUISHER		1				✓			
	FHC - L -06 BQ WASH	FHC/FE	1	1				✓			
	FHC - L -07 BQ STORE	FHC/FE	1	1				✓			
	FHC - L -08 SALON BALLROOM	FHC/FE	1	1				✓			
	BQ KITCHEN	CLASS K				1		✓			
	BQ KITCHEN	FIRE BLANKET					1	✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: November, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
LOWER LOBBY	FHC - LL - 1/12 VILLA 8	FHC/FE	1	1				✓			
	FHC - LL - 2/12 IN FRONT FIRE FUMP ROOM	FHC/FE	1	1				✓			
	FHC - LL - 3/12 COOLING TOWER AREA	FHC/FE	1	1				✓			
	FHC - LL - 4/12 IN FRONT OF VILLA1	FHC/FE	1	1				✓			
	FHC - LL - 5/12 IN FRONT OF FINACE ROOM	FHC/FE	1	1				✓			
	FHC - LL - 6/12 SA2	FHC/FE	1	1				✓			
	FHC - LL - 7/12 IN FRONT UNIFORM ROOM	FHC/FE	1	1				✓			
	FHC - LL - 8/12 IN FRONT OF AHU ROOM	FHC/FE	1	1				✓			
	FHC - LL - 9/12 GENERATER ROOM	FHC/FE	1	1				✓			
	FHC - LL - 10/12 PHRA NAKHORN	FHC/FE	1	1				✓			
	FHC - LL - 11/12 MAIN KITCHEN	FHC/FE	1	1				✓			
	FHC - LL - 12/12 LOADING AREA	FHC/FE	1	1				✓			
	EXECUTIVE OFFICE	FHC/FE	1	1				✓			
	AURIGA SPA	FHC/FE	1	1				✓			
	FHL - LL- 5 WALK WAY TO LIFT BQ	FHC/FE	1	1				✓			
	EXECUTIVE OFFICE	FIRE EXTINGUISHER		1				✓			
	FB OFFICE	FIRE EXTINGUISHER		1				✓			
	SALE OFFICE	FIRE EXTINGUISHER		1				✓			
	ENGINEERING OFFICE	FIRE EXTINGUISHER		1				✓			
	FINANCE OFFICE	FIRE EXTINGUISHER		1				✓			
	HR OFFICE	FIRE EXTINGUISHER		1				✓			
	IT OFFICE	FIRE EXTINGUISHER		1				✓			
	SERVER ROOM	FIRE EXTINGUISHER		1				✓			
	101 KITCHEN	CLASS K				1		✓			
	HK OFFICE	FIRE EXTINGUISHER	1	1				✓		Type K was broken = 1 tank	
	COMMUNICATION ROOM	FIRE EXTINGUISHER		5	4	7		√			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA

Monthly: November, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
LOWER LOBBY	LP OFFICE	FIRE EXTINGUISHER		1				✓			
	TRAINING ROOM	FIRE EXTINGUISHER		1							
	IN FRONT OF IT OFFICE	CO2			1			✓			
	IN FRONT OF EE ROOM	CO2			1			✓			
	IN FRONT OF LP OFFICE	CO2			1			✓			
	MAIN KITCHEN DOOR 05	CLASS K				1		✓			
	MAIN KITCHEN DOOR 05	CO2			1			✓			
	MAIN KITCHEN DOOR 03 (COLD KITCHEN)	CLASS K				1		✓			
	MAIN KITCHEN DOOR 03 (COLD KITCHEN)	CO2			1			✓			
	MAIN KITCHEN DOOR 01 (BEKERY)	CLASS K				1		✓			
	MAIN KITCHEN DOOR 01 (BEKERY)	CO2			1			✓			
	MAIN KITCHEN DOOR 04	CLASS K				1		✓			
	MAIN KITCHE DOOR 04	CO2			1			✓			
	FREEZER CORRIDOR	CLASS K				1		✓			
	PRE VEGETABLE CORRIDOR	CLASS K				1		✓			
	BUTCHER	CLASS K		1		1		✓			
	BEVERAGE STORE	CLASS K				1		✓			
	DRY STORE	CLASS K				1		✓			
	IN FRONT PURCHASING OFFICE	CLASS K / DRY		1		1		✓			
	IN FRONT OF AHU ROOM	FIRE EXTINGUISHER		1				✓			
	FIRE CART OF CABINET	FIRE EXTINGUISHER		1				✓			
	IN FRONT OF COMMUNICATION ROOM	CO2			1			✓			
	101 KITCHEN	FIRE BLANKET					1	✓			
	MAINKITCHEN	FIRE BLANKET			6		1	✓			
	FIRE CART OF CABINET	FIRE BLANKET					3	✓		2 Used	
	Cooling Room	FIRE EXTINGUISHER		2				✓			

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA BANGKOK

Monthly: November, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		
BASEMENT 1	FHC - B1 - 1/10 SA4	FHC/FE	1	1				✓			
	FHC - B1 - 2/10 SA1	FHC/FE	1	1				✓			
	FHC - B1 - 3/10 PARKING B8	FHC/FE	1	1				✓			
	FHC - B1 - 4/10 BACK OF NEW DRIVER ROOM	FHC/FE	1	1				✓			
	FHC - B1 - 5/10 IN FRONT EXIT SA2	FHC/FE	1	1				✓			
	FHC - B1 - 6/10 PARKING A3	FHC/FE	1	1				✓			
	FHC - B1 - 7/10 INFRONT TOLIET	FHC/FE	1	1				✓			
	FHC - B1 - 8/10 SA7	FHC/FE	1	1				✓			
	FHC - B1 - 9/10 SA3	FHC/FE	1	1				✓			
	FHC - B1 - 10/10 Fan Room1	FHC/FE	1	1				✓			
	EE ROOM	CO2			1			✓			
	PARKING ZONE B5	FIRE EXTINGUISHER		1				✓			
	PARKING ZONE D3	FIRE EXTINGUISHER		1				✓			
	PARKING ZONE F10	FIRE EXTINGUISHER		1				✓			
	LILLY POND ROOM	FIRE EXTINGUISHER		1				✓			
	Fan Room 1	FIRE EXTINGUISHER		1				✓			
	Fan Room 2	FIRE EXTINGUISHER		1				✓			
	CHILLER PLANT ROOM	FIRE EXTINGUISHER		2				✓			
	AT WALL B1 CHILLER ROOM	FIRE EXTINGUISHER		1				✓			
Total			FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET				

Remark:

CO2 Standby at Communication Room & .....

Dry Chemical Stanby Communication Room & .....

Type K Standby at Communication Room & .....

FIRE PROTECTING AND FIRE EQUIPMENT CHECKLIST

CAPELLA

Monthly: November, 2024

LEVEL	LOCATION	TYPE	FIRE HOSE CABINET	DRY CHEMICAL	CO2	CLASS K	FIRE BLANKET	STATUS		ADDITIONAL & COMMENT	CHECK: BY
								YES	NO		

Remark:_____

Checked b ___and__ ate: 11-18 / 11 / 24

Senior Loss Prevention Supervisor

Verfied _ Date: 27 / 11 / 2024

Director of Loss Prevention

FIRE EXTINGUISHER(GREEN CHEMICAL)

LOCATON	GREEN CHEMICAL	
	AVAILABLE	STATUS
Server room in IT office	1	/
Finances Fire hose reel cabinet.	1	/
S&M Fire hose reel cabinet.	1	/
MDB room	1	/
IRD kitchen	1	/
Main Kitchen	1	/
Soi 64 kitchen	1	/
Fire control room	1	/
Front office	1	/
Lobby area	1	/
Gate 2 (Ballroom)	1	/
Lobby lounge	1	/
YTY kitchen	1	/
BKK kitchen	1	/
RIVA kitchen	1	/
Palmier kitchen	1	/
Art space area	1	/
Chiller room (Electrical control room).	1	/
B1 Residence	1	/
Spare [store Security]	6	/
FHC Ballroom	3	/
FHC Conservatory	2	/
Total	30	

Date 30/07/2024
CHECKED B
DIRECTOR SECURITY ..

FIRE EXTINGUISHER(TYPE K)/FIRE BLANKET

DATE 1/07/2024

LOCATON	WET CHEMICAL		FIRE BLANKET		REMARK
	AVAILABLE	STATUS	AVAILABLE	STATUS	
Ballroom Kitchen	3	/	2	/	
Conservatory Kitchen	3	/	2	/	
B/P Kitchen	3	/	1	/	
RIVA Kitchen	3	/	2	/	
BKK Kitchen	2	/	2	/	
YTY Kitchen	2	/	1	/	
MAIN Kitchen	1	0	0	0	
BAKERRY Kitchen	1	/	0	0	
GRILL ROOM Kitchen	1	/	0	0	
IRD Kitchen	1	/	1	/	
SOI 64 Kitchen	1	/	2	/	
Riverfront Kitchen	3	/	2	/	
e lounge	0	0	1	/	
Fire card No . 1	0	0	1	/	
Fire card No . 2 set up H/S 9,10 B1	0	0	1	/	Fire Blanket For car
SKY LOUNGE FSR	0	0	1	/	
Cabinet of ammunition No.1 (H/S 1/2)	0	0	0	0	
Cabinet of ammunition No.2(H/S 7/8)	0	0	0	0	
Cabinet of ammunition No.3(H/S 9/10)	0	0	0	0	
Cabinet of ammunition No.4 Residence	0	0	0	0	
STOREROOM B2	0	0	3	0	
TOTAL	24		22		

CHECKED BY
DIRECTOR SECURITY .....

FIRE EXTINGUSHER HOTEL CHECKLIST (1. Ballroom Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 7	1	1	1	1	0	
FLOOR 3						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 Near Rest room Guest	1	1	1	1	0	
FHC N0.3 next to fire exit stair 8	1	1	1	1	0	
FHC No.4 In front of BQ Store	1	1	1	1	0	
Floor 2						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 AHU Room	1	1	1	1	0	
FHC N0.3 next to fire exit stair 8	1	1	1	1	0	
FHC No.4 In front of Excome Office	1	1	1	1	0	
Floor L						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 Bar Ballroom Area	1	1	1	1	0	
FHC N0.3 Bar Ballroom Area	1	1	1	1	0	
FHC No.4 next to fire exit stair 3	1	1	1	1	1	
FHC No.5 In front of Terrest Ballroom	1	1	1	1	1	
FHC No.6 In front of Door 2	1	1	1	1	0	
FHC N0.7 F/O Counter	1	1	1	1	0	
Floor LL						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 Carpark (Near CP 4)	1	1	1	1	0	
FHC N0.3 ยังหาตู้ไม่เจอ	1	1	1	1	0	
FHC No.4 ยังหาตู้ไม่เจอ	1	1	1	1	0	
FHC No.5 Door 9 St 19	1	1	1	1	0	
FHC No.6 Art Space (CP 4)	1	1	1	1	0	
FHC N0.7 Art Space (Door 6)	1	1	1	1	0	
FHC N0.8 Art Space (In side St 18)	1	1	1	1	0	
Floor B1						
FHC No.1 In front H/S 9/10	1	1	1	1	0	
FHC No.2 EV CHARGER	1	1	1	0	1	
FHC N0.3 next to fire exit stair 18	1	1	1	1	0	
FHC No.4 next to fire exit stair 19	1	1	1	1	0	
TOTALL	**28**	**28**	**28**	**27**	**3**	

Date 28/07/2024
CHECKED BY
DIRECTOR SI

FIRE EXTINGUSHER HOTEL CHECKLIST (2. Palm Court Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 4	1	0	1	0	0	
FHC on Rooftop St 06	1	0	1	0	0	
FLOOR 3						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	0	
FHC No.2 next to fire exit stair 1	1	1	1	1	0	
FHC N0.3 next to fire exit stair 2	1	1	1	1	0	
FHC No.4 next to fire exit stair 3	1	1	1	1	0	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.6 next to fire exit stair 5	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Floor 2						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	0	
FHC No.2 next to fire exit stair 1	1	1	1	1	0	
FHC N0.3 next to fire exit stair 2	1	1	1	1	0	
FHC No.4 next to fire exit stair 3	1	1	1	1	0	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.6 next to fire exit stair 5	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Floor L						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	0	
FHC No.2 next to fire exit stair 1	1	1	1	1	0	
FHC N0.3 next to fire exit stair 2	1	1	1	1	0	
FHC No.4 next to fire exit stair 3	1	1	1	1	0	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.6 next to fire exit stair 5	1	1	1	1	0	
FHC N0.7 Luggage store	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Floor LL						
FHC No.1 Motorcycer Parking	1	1	1	1	0	
FHC No.2 Florist Room(Soi 2)	1	1	1	1	0	
FHC N0.3 Room 308	1	1	1	1	0	
FHC No.4 next to fire exit stair 1	1	1	1	1	0	
FHC No.5 next to fire exit stair	1	1	1	1	0	
FHC No.6 Salon Area	1	1	1	1	0	
FHC No.7 Reception Area	1	1	1	1	0	
FHC No.8 Male Locker Area	1	1	1	1	0	
FHC No.9 next to fire exit stair 3	1	1	1	1	0	
FHC No.10 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.11 Generetor Room	1	1	1	1	0	
FHC NO.12 Near Restroom Soi 64	1	1	1	1	0	
FHC No13 Luggage store	1	1	1	1	0	
FHC No.14 next to fire exit stair 5	1	1	1	1	0	
FHC No15 next to fire exit stair17	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Novac N0.1 IT Room	0	0	0	0	0	
Novac N0.2 EE Room	0	0	0	0	0	
Novac No.3 Main Power Room	0	0	0	0	0	
Security Office	0	0	0	0	0	
Laundry Area	0	0	0	0	4	
Housekeeping Office	0	0	0	1	0	
Floor B1						
FHC No.1 B1A	1	1	1	1	0	
FHC No.2 next to fire exit stair 6	1	1	1	1	0	
FHC N0.3 Store(Pumproom)(st1) B1E	1	1	1	1	0	
FHC No.4 next to fire exit stair 1	1	1	1	1	1	
FHC No.5 Pillar A4 B1E	1	1	1	1	0	
FHC No.6 next to fire exit stair 3	1	1	1	1	0	
FHC No.7 next to fire exit stair 4	1	1	1	1	0	
FHC No.8 B1D near B1B	1	1	1	1	0	
FHC No.9 Motorcycer Parking	1	1	1	1	0	
FHC No.10 CP 1/2	1	1	1	1	0	
FHC No.11 B1A	1	1	1	1	0	
FHC NO.12 B1A	1	1	1	1	0	
ENG Work shop	0	0	0	6	2	
Floor B2						
FHC No.B2B(Pillar S13)	1	1	1	1	0	
FHC No.2 next to fire exit stair 6	1	1	1	1	0	
FHC N0.3 next to fire exit stair 1	1	1	1	1	0	
FHC No.4 B2 Pillar B4	1	1	1	1	0	
FHC No.5 Pillar A4 B1E Pillar U1	1	1	1	1	0	
FHC No.6 B2B next to fire exit stair 17	1	1	1	1	0	
FHC No.7 B2B Pillar U1	1	1	1	1	0	
FHC No.8 B2B Chiller Room	1	1	1	1	0	
FHC No.9 next to fire exit stair 4	1	1	1	1	0	
FHC No.10 CP 1/2	1	1	1	1	0	
FHC No.11 B2B Pillar T9	1	1	1	1	0	
Store Security	0	0	0	4	1	
Out side						
Gass Station	0	0	0	6	0	
Main Entrance	0	0	0	2	0	
TOTAL	**61**	**61**	**61**	**86**	**15**	

Date 28/07/2024

CHECKED BY

DIRECTOR SECURITY .....

FIRE EXTINGUSHER HOTEL CHECKLIST (3.Cascade Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Rooftop						
FHC on Rooftop	1	0	1	0	0	
Floor 13						
FHC No.1 next to fire exit stair 11	1	1	1	1	0	
FHC No.2 EE Room	1	1	1	1	1	
FHC No.3 next to fire exit stair 12	1	1	1	1	0	
Floor 12						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	0	
FHC No.2 IN front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 Next to Fire Exit Stair 12	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Floor 11						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	0	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	0	
FHC No.4 next to Fire Exit stair 13	1	1	1	1	0	
FHC No.5 In front of AHU Room	1	1	1	1	0	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Floor 10						
FHC No.1 next to Fire exit stair 11	1	1	1	1	0	
FHC No.2 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 next to Fire exit stair 12	1	1	1	1	0	
FHC No.4 next to fire exit stair 13	1	1	1	1	0	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.6 near fire exit stair 15	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
AHU Room	0	0	0	0	1	
Floor 9						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 8						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 7						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 6						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 5						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	

FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 4						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 3						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 2						
C No.1 In front of Lift HS 7,8	1	1	1	1	0	
HC No.2 next ti Fire Exit Stair 12	1	1	1	1	0	
FHC No.3 next ti Fire Exit Stair 13	1	1	1	1	0	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.5 next to Fire Exit stair 15	1	1	1	1	0	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	0	
In Front of Room 202	1	1	1	1	0	
Floor L						
FHC No.1 front of YTY Resterance	1	1	1	1	0	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	0	
FHC No.4 next to Fire exit stair 13	1	1	1	1	0	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.6 in Front of Lift HP.9	1	1	1	1	0	
FHC No.7 In front of stair 20	1	1	1	1	0	
Floor LL						
FHC No.1 Carpark LL[W1]	1	1	1	1	0	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 Office Executive/Sale	1	1	1	1	0	
FHC No.4 Office Reservation	1	1	1	1	0	
FHC No.5 Carpark LL[U1]	1	1	1	1	0	
FHC No.6 next to Fire exit stair 13	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 Door Gate 3	1	1	1	1	0	
FHC No.9In front of stair 20	1	1	1	1	0	
FHC No.10 ยังหาตู้ไม่เจอ	0	0	0	0	0	
Floor B1						
C No.1 Carpark B1C[M4]	1	1	1	1	0	
HC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 Carpark B1C[I4]	1	1	1	1	0	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	0	
TOTAL	**99**	**98**	**100**	**100**	**19**	

Date 26/07/2024
CHECKED BY
DIRECTOR SECURITY .....

FIRE EXTINGUSHER RESIDENCES CHECK LIST

MONTH: JUL,2024

LOCATION	DRY	CO2	NOTE	DATE
ROOFTOP				
FHC	0	2		
FLOOR 69				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	1		
FLOOR 68				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 67				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 66				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 65				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 64				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 63				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 62				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 61				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 60				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 59				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 58				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 57				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 56				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		

FHC No.3 RST.1	1	1		
FLOOR 55				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 54				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 53				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 52				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 51				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 50				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 49				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 48				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 47				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 46				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR45				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 43 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 43				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 42				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 41				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
Fire Pump Room	1	0		
FLOOR 40				

FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 39				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 38				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR37				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 36				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 35				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 34				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 32 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 32				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 31				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 30				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 29				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 28				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 27				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 26				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 25				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		

FLOOR 24				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 22 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 22				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 21				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 20				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 19				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 18				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 17				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 16				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 15				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 14				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 12 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 12				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.3	1	1		
FLOOR 11				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	0	FHC IN GUEST ROOM	
FLOOR 10				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 9				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		

FHC No.3 RST.1	0	0		
FLOOR 8				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 7				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 6				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 5				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 4				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 3				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FHC No.4 Facility Office	1	0		
FLOOR 2				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR L				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FHC No.4 OFFICE AREA	1	1		
FHC No.5 B/Q STORE	1	0		
FLOOR LL				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FHC No.4 Pet Grooming	1	0		
FHC No.5 ยังหาตู้ไม่เจอ	1	0		
FHC No.6 ENG Office	1	0		
FHC No.7 Loading area	2	0		
FLOOR B1				
FHC No.1 RST.2	1	0		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	0		
FHC No.4 Door2	1	0		
FHC No.5 B1C Pillar A13	1	0		
FHC No.6 B1C Pillar F14	1	0		
FHC No.7 B1C Pillar M14	1	0		
FHC No.8 Fanroom	1	0		
Total	214	130		

FHC IN ROOM GUEST	
Room Number	Floor
8	69
11	66-67
26	62-63
27	60-61
28	60-61
324	10-11

total 5 Room

ALL FIRE EXTINGUSHER		
LOCATION	DRY CHEMICAL	CO2
HOTEL	219	40
RESIDENCE	214	130
TOTAL	433	170

Date 28/7/2024
Checked by

DIRECTOR SECURITY.... ....

B/A CONTROL BOARD

FSH

NUMBER	REFILL DATE	EXPIRE DATE	TANK SIZE	BAR	USAGE TIME	REMARK
B/A No.1	29/02/2024	N/A	6.8 L	170	18.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว[Training]
B/A No.2	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
FSR						
B/A No.1	29/02/2024	N/A	6.8 L	240	30.0 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
B/A No.2 ✓	29/02/2024	N/A	6.8 L	0	0	รอเติม
SPARE						
SPARE No.1	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
SPARE No.2	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
SPARE No.3 ✓	29/02/2024	N/A	6.8 L	0	0	รอเติม

Date 28/07/2024
CHECKED BY ,
DIRECTOR SECURITY .....

SUMMARY REPORT

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Ballroom Building	28	28	28	27	3	
Palm court Building	64	64	64	92	14	
Cascade Building	99	98	100	100	19	
Keep in Store	0	0	0	0	2	เก็บไว้ใส่ห้องท่าน ชูติ
Waiting for refill/Broken	0	0	0	0	2	
Total	**191**	**190**	**192**	**219**	**40**	

Discard DRY=4 Pcs[27/07/2023] Discard DRY=1Pcs[26/09/23] Discard DRY=5[23/02/24] Total =10

Date 28/07/2024

CHECKED BY

DIRECTOR SECURITY .....

FIRE EXTINGUISHER(GREEN CHEMICAL)

LOCATON	GREEN CHEMICAL	
	AVAILABLE	STATUS
Server room in IT office	1	/
Finances Fire hose reel cabinet.	1	/
S&M Fire hose reel cabinet.	1	/
MDB room	1	/
IRD kitchen	1	/
Main Kitchen	1	/
Soi 64 kitchen	1	/
Fire control room	1	/
Front office	1	/
Lobby area	1	/
Gate 2 (Ballroom)	1	/
Lobby lounge	1	/
YTY kitchen	1	/
BKK kitchen	1	/
RIVA kitchen	1	/
Palmier kitchen	1	/
Art space area	1	/
Chiller room (Electrical control room).	1	/
B1 Residence	1	/
Spare [store Security]	4	/
FHC Ballroom	3	/
FHC Conservatory	2	/
FSR Sky lounge Fl 64	1	/
FSR SkyFitness Fl 65	1	/
Total	30	

Date 20/08/2024
CHECKED BY /
DIRECTOR SE(

FIRE EXTINGUISHER(TYPE K)/FIRE BLANKET

LOCATON	WET CHEMICAL		FIRE BLANKET		REMARK
	AVAILABLE	STATUS	AVAILABLE	STATUS	
Ballroom Kitchen	3	/	2	/	
Conservatory Kitchen	3	/	2	/	
B/P Kitchen	3	/	1	/	
RIVA Kitchen	3	/	2	/	
BKK Kitchen	2	/	2	/	
YTY Kitchen	2	/	1	/	
MAIN Kitchen	1	0	0	0	
BAKERRY Kitchen	1	/	0	0	
GRILL ROOM Kitchen	1	/	0	0	
IRD Kitchen	1	/	1	/	
SOI 64 Kitchen	0	/	2	/	
Riverfront Kitchen	3	/	2	/	
The lounge	0	0	1	/	
re card No . 1	0	0	1	/	
re card No . 2 set up H/S 9,10 B1	0	0	1	/	Fire Blanket For car
SKY LOUNGE FSR	0	0	1	/	
Cabinet of ammunition No.1 (H/S 1/2)	0	0	0	0	
Cabinet of ammunition No.2(H/S 7/8)	0	0	0	0	
Cabinet of ammunition No.3(H/S 9/10)	0	0	0	0	
Cabinet of ammunition No.4 Residence	0	0	0	0	
STOREROOM B2	1	0	3	0	
TOTAL	24		22		

DATE 20/08/2
CHECKED BY ,
DIRECTOR SEC

FIRE EXTINGUSHER HOTEL CHECKLIST (1. Ballroom Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 7	1	1	1	1	0	
FLOOR 3						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 Near Rest room Guest	1	1	1	1	0	
FHC N0.3 next to fire exit stair 8	1	1	1	1	0	
FHC No.4 In front of BQ Store	1	1	1	1	0	
Floor 2						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 AHU Room	1	1	1	1	0	
FHC N0.3 next to fire exit stair 8	1	1	1	1	0	
FHC No.4 In front of Excome Office	1	1	1	1	0	
Floor L						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 Bar Ballroom Area	1	1	1	1	1	
FHC N0.3 Bar Ballroom Area	1	1	1	1	1	
FHC No.4 next to fire exit stair 3	1	1	1	1	0	
FHC No.5 In front of Terrest Ballroom	1	1	1	1	1	
FHC No.6 In front of Door 2	1	1	1	1	0	
FHC N0.7 F/O Counter	1	1	1	1	0	
Floor LL						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	0	
FHC No.2 Carpark (Near CP 4)	1	1	1	1	0	
FHC N0.3 ยังหาตู้ไม่เจอ	1	1	1	1	0	
FHC No.4 ยังหาตู้ไม่เจอ	1	1	1	1	0	
FHC No.5 Door 9 St 19	1	1	1	1	0	
FHC No.6 Art Space (CP 4)	1	1	1	0	0	
FHC N0.7 Art Space (Door 6)	1	1	1	1	0	
FHC N0.8 Art Space (In side St 18)	1	1	1	1	0	
Floor B1						
FHC No.1 In front H/S 9/10	1	1	1	1	0	
FHC No.2 EV CHARGER	1	1	1	0	1	
FHC N0.3 next to fire exit stair 18	1	1	1	1	0	
FHC No.4 next to fire exit stair 19	1	1	1	1	0	
TOTALL	**28**	**28**	**28**	**26**	**3**	

Date 20/08/
CHECKED BY .
DIRECTOR SE

FIRE EXTINGUSHER HOTEL CHECKLIST (2. Palm Court Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 4	1	0	1	0	0	
FHC on Rooftop St 06	1	0	1	0	0	
FLOOR 3						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	0	
FHC No.2 next to fire exit stair 1	1	1	1	1	0	
FHC N0.3 next to fire exit stair 2	1	1	1	1	0	
FHC No.4 next to fire exit stair 3	1	1	1	1	0	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.6 next to fire exit stair 5	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Floor 2						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	0	
FHC No.2 next to fire exit stair 1	1	1	1	1	0	
FHC N0.3 next to fire exit stair 2	1	1	1	1	0	
FHC No.4 next to fire exit stair 3	1	1	1	1	0	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.6 next to fire exit stair 5	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Floor L						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	0	
FHC No.2 next to fire exit stair 1	1	1	1	1	0	
FHC N0.3 next to fire exit stair 2	1	1	1	1	0	
FHC No.4 next to fire exit stair 3	1	1	1	1	0	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.6 next to fire exit stair 5	1	1	1	1	0	
FHC N0.7 Luggage store	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Floor LL						
FHC No.1 Motorcycer Parking	1	1	1	1	0	
FHC No.2 Florist Room(Soi 2)	1	1	1	1	0	
FHC N0.3 Room 308	1	1	1	1	0	
FHC No.4 next to fire exit stair 1	1	1	1	1	0	
FHC No.5 next to fire exit stair	1	1	1	1	0	
FHC No.6 Salon Area	1	1	1	1	0	
FHC No.7 Reception Area	1	1	1	1	0	
FHC No.8 Male Locker Area	1	1	1	1	0	
FHC No.9 next to fire exit stair 3	1	1	1	1	0	
FHC No.10 In front of Lift H,S 3,4	1	1	1	1	0	
FHC No.11 Generetor Room	1	1	1	1	0	
FHC NO.12 Near Restroom Soi 64	1	1	1	1	0	
FHC No13 Luggage store	1	1	1	1	0	
FHC No.14 next to fire exit stair 5	1	1	1	1	0	
FHC No15 next to fire exit stair17	1	1	1	1	0	
EE Room next to stair 1	0	0	0	0	1	
EE Room next to stair 3	0	0	0	0	1	
Novac N0.1 IT Room	0	0	0	0	0	
Novac N0.2 EE Room	0	0	0	0	0	
Novac No.3 Main Power Room	0	0	0	0	0	
Security Office	0	0	0	0	0	
Laundry Area	0	0	0	0	4	
Housekeeping Office	0	0	0	1	0	
Floor B1						
FHC No.1 B1A	1	1	1	1	0	
FHC No.2 next to fire exit stair 6	1	1	1	1	0	
FHC N0.3 Store(Pumproom)(st1) B1E	1	1	1	1	0	
FHC No.4 next to fire exit stair 1	1	1	1	1	1	
FHC No.5 Pillar A4 B1E	1	1	1	1	0	
FHC No.6 next to fire exit stair 3	1	1	1	1	0	
FHC No.7 next to fire exit stair 4	1	1	1	1	0	
FHC No.8 B1D near B1B	1	1	1	1	0	
FHC No.9 Motorcycer Parking	1	1	1	1	0	
FHC No.10 CP 1/2	1	1	1	1	0	
FHC No.11 B1A	1	1	1	1	0	
FHC NO.12 B1A	1	1	1	1	0	
ENG Work shop	0	0	0	6	2	
Floor B2						
FHC No.B2B(Pillar S13)	1	1	1	1	0	
FHC No.2 next to fire exit stair 6	1	1	1	1	0	
FHC N0.3 next to fire exit stair 1	1	1	1	1	0	
FHC No.4 B2 Pillar B4	1	1	1	1	0	
FHC No.5 Pillar A4 B1E Pillar U1	1	1	1	1	0	
FHC No.6 B2B next to fire exit stair 17	1	1	1	1	0	
FHC No.7 B2B Pillar U1	1	1	1	1	0	
FHC No.8 B2B Chiller Room	1	1	1	1	0	
FHC No.9 next to fire exit stair 4	1	1	1	1	0	
FHC No.10 CP 1/2	1	1	1	1	0	
FHC No.11 B2B Pillar T9	1	1	1	1	0	
Store Security	0	0	0	11	1	
Out side						
Gass Station	0	0	0	6	0	
Main Entrance	0	0	0	0	0	
TOTAL	**61**	**61**	**61**	**91**	**15**	

Date 20/08/

CHECKED BY

DIRECTOR SE

FIRE EXTINGUSHER HOTEL CHECKLIST (3.Cascade Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Rooftop						
FHC on Rooftop	1	0	1	0	0	
Floor 13						
FHC No.1 next to fire exit stair 11	1	1	1	1	0	
FHC No.2 EE Room	1	1	1	1	1	
FHC No.3 next to fire exit stair 12	1	1	1	1	0	
Floor 12						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	0	
FHC No.2 IN front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 Next to Fire Exit Stair 12	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Floor 11						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	0	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	0	
FHC No.4 next to Fire Exit stair 13	1	1	1	1	0	
FHC No.5 In front of AHU Room	1	1	1	1	0	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Floor 10						
FHC No.1 next to Fire exit stair 11	1	1	1	1	0	
FHC No.2 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 next to Fire exit stair 12	1	1	1	1	0	
C No.4 next to fire exit stair 13	1	1	1	1	0	
C No.5 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.6 near fire exit stair 15	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
AHU Room	0	0	0	0	1	
Floor 9						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 8						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 7						
C No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 6						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 5						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1				
FHC No.5 next to fire exit stair 13	1	1				
FHC No.6 near fire exit stair 14	1	1				

FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 4						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 3						
FHC No.1 next to Fire exit stair 10	1	1	1	1	0	
FHC No.2 next to Fire exit stair 11	1	1	1	1	0	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	0	
FHC No.4 next to Fire exit stair 12	1	1	1	1	0	
FHC No.5 next to fire exit stair 13	1	1	1	1	0	
FHC No.6 near fire exit stair 14	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	0	
Maid pantry Lift HS 7,8 (R1)	0	0	0	0	1	
Shaft room	0	0	0	0	1	
Floor 2						
FHC No.1 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.2 next ti Fire Exit Stair 12	1	1	1	1	0	
FHC No.3 next ti Fire Exit Stair 13	1	1	1	1	0	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.5 next to Fire Exit stair 15	1	1	1	1	0	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	0	
In Front of Room 202	1	1	1	1	0	
Floor L						
FHC No.1 front of YTY Resterance	1	1	1	0	0	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	0	
FHC No.4 next to Fire exit stair 13	1	1	1	0	0	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.6 in Front of Lift HP.9	1	1	1	1	0	
FHC No.7 In front of stair 20	1	1	1	1	0	
Floor LL						
FHC No.1 Carpark LL[W1]	1	1	1	1	0	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 Office Executive/Sale	1	1	1	0	0	
FHC No.4 Office Reservation	1	1	1	0	0	
FHC No.5 Carpark LL[U1]	1	1	1	1	0	
FHC No.6 next to Fire exit stair 13	1	1	1	1	0	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	0	
FHC No.8 Door Gate 3	1	1	1	1	0	
FHC No.9In front of stair 20	1	1	1	1	0	
FHC No.10 ยังหาตู้ไม่เจอ	0	0	0	0	0	
Floor B1						
FHC No.1 Carpark B1C[M4]	1	1	1	1	0	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	0	
FHC No.3 Carpark B1C[I4]	1	1	1	1	0	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	0	
TOTAL	**99**	**98**	**100**	**96**	**19**	

Date 20/08/2024
CHECKED BY
DIRECTOR SE

FIRE EXTINGUSHER RESIDENCES CHECK LIST

MONTH: AUG,2024

LOCATION	DRY	CO2	NOTE	DATE
ROOFTOP				
FHC	0	2		
FLOOR 69				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	1		
FLOOR 68				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 67				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 66				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 65				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 64				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 63				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 62				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 61				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 60				
FHC No.1 RST.2	0	0	FHC IN GUEST ROOM	
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 59				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 58				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 57				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 56				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		

FHC No.3 RST.1	1	1		
FLOOR 55				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 54				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 53				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 52				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 51				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 50				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 49				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 48				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 47				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 46				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR45				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 43 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 43				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 42				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 41				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
Fire Pump Room	1	0		
FLOOR 40				

FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 39				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 38				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR37				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 36				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 35				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 34				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 32 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 32				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 31				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 30				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 29				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 28				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 27				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 26				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 25				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		

FLOOR 24				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 22 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 22				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 21				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 20				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 19				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 18				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 17				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 16				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 15				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 14				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 12 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 12				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.3	1	1		
FLOOR 11				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	0	FHC IN GUEST ROOM	
FLOOR 10				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	0	0	FHC IN GUEST ROOM	
FLOOR 9				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		

FHC No.3 RST.1	0	0		
FLOOR 8				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 7				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 6				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 5				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 4				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR 3				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FHC No.4 Facility Office	1	0		
FLOOR 2				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FLOOR L				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FHC No.4 OFFICE AREA	1	1		
FHC No.5 B/Q STORE	1	0		
FLOOR LL				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	1		
FHC No.4 Pet Grooming	1	0		
FHC No.5 ยังหาตู้ไม่เจอ	1	0		
FHC No.6 ENG Office	1	0		
FHC No.7 Loading area	2	0		
FLOOR B1				
FHC No.1 RST.2	1	0		
FHC No.2 FML	1	0		
FHC No.3 RST.1	1	0		
FHC No.4 Door2	1	0		
FHC No.5 B1C Pillar A13	1	0		
FHC No.6 B1C Pillar F14	1	0		
FHC No.7 B1C Pillar M14	1	0		
FHC No.8 Fanroom	1	0		
Total	214	130		

FHC IN ROOM GUEST	
Room Number	Floor
8	69
11	66-67
26	62-63
27	60-61
28	60-61
324	10-11

total 5 Room

ALL FIRE EXTINGUSHER		
LOCATION	DRY CHEMICAL	CO2
HOTEL	213	40
RESIDENCE	214	130
TOTAL	427	170

Date 20/08/2024
Checked by

DIRECTOR SE

B/A CONTROL BOARD

FSH

NUMBER	REFILL DATE	EXPIRE DATE	TANK SIZE	BAR	USAGE TIME	REMARK
B/A No.1	29/02/2024	N/A	6.8 L	170	18.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว[Training]
B/A No.2	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
FSR						
B/A No.1	29/02/2024	N/A	6.8 L	240	30.0 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
B/A No.2	29/02/2024	N/A	6.8 L	0	0	รอเติม
SPARE						
SPARE No.1	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
SPARE No.2	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
SPARE No.3	29/02/2024	N/A	6.8 L	0	0	รอเติม

Date 20/08/[illegible]
CHECKED BY /
DIRECTOR SE(

Date 20/09/2024

FIRE EXTINGUISHER(TYPE K) and FIRE BLANKET

LOCATON	WET CHEMICAL		FIRE BLANKET		REMARK
	AVAILABLE	STATUS	AVAILABLE	STATUS	
Ballroom Kitchen	3	✓	2	✓	
Conservatory Kitchen	3	✓	2	✓	
B/P Kitchen	3	✓	1	✓	
RIVA Kitchen	3	✓	2	✓	
BKK Kitchen	2	✓	2	✓	
YTY Kitchen	2	✓	1	✓	
MAIN Kitchen	1	✓	-	-	
BAKERRY Kitchen	1	✓	-	-	
GRILL ROOM Kitchen	1	✓	-	-	
IRD Kitchen	1	✓	1	✓	
SOI 64 Kitchen	-	-	2	✓	
Riverfront Kitchen	3	✓	2	✓	
The lounge	-	-	1	✓	
Fire cart No.1	-	-	1	✓	
Fire cart No.2 set up H/S 9,10 B1	-	-	1	✓	**Fire blanket for EV vehicles fire protection**
Sky Lounge FSR	-	-	1	✓	
Cabinet of ammunition No.1 (H/S 1/2)	-	-	-	-	
Cabinet of ammunition No.2(H/S 7/8)	-	-	-	-	
Cabinet of ammunition No.3(H/S 9/10)	-	-	-	-	
Cabinet of ammunition No.4 Residence	-	-	-	-	
Store Room B2	1	✓	3	✓	
TOTAL	**24**		**22**		

Checked By /

DIRECTOR S

Date 20/09/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Ballroom Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 7	1	1	1	1	-	
FLOOR 3						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	
FHC No.2 Near Rest room Guest	1	1	1	1	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	
FHC No.4 In front of BQ Store	1	1	1	1	-	
Floor 2						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	
FHC No.2 AHU Room	1	1	1	1	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	
FHC No.4 In front of Excome Office	1	1	1	1	-	
Floor L						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	
FHC No.2 Bar Ballroom Area	1	1	1	1	1	
FHC N0.3 Bar Ballroom Area	1	1	1	1	1	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Terrest Ballroom	1	1	1	1	1	
FHC No.6 In front of Door 2	1	1	1	1	-	
FHC N0.7 F/O Counter	1	1	1	1	-	
Floor LL						
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	
FHC No.2 Carpark (Near CP 4)	1	1	1	1	-	
FHC N0.3 Carpark LL	1	1	1	1	-	
FHC No.4 Carpark LL	1	1	1	1	-	
FHC No.5 Door 9 St 19	1	1	1	1	-	
FHC No.6 Art Space (CP 4)	1	1	1	-	-	
FHC N0.7 Art Space (Door 6)	1	1	1	1	-	
FHC N0.8 Art Space (In side St 18)	1	1	1	1	-	
Floor B1						
FHC No.1 In front H/S 9/10	1	1	1	1	-	
FHC No.2 EV CHARGER	1	1	1	-	1	
FHC N0.3 next to fire exit stair 18	1	1	1	1	-	
FHC No.4 next to fire exit stair 19	1	1	1	1	-	
TOTAL	**28**	**28**	**28**	**26**	**4**	

Checked by

DIRECTOR

Date 20/09/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Palm Court Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 4	1	-	1	-	-	
FHC on Rooftop St 06	1	-	1	-	-	
FLOOR 3						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor L						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
FHC N0.7 Luggage store	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor LL						
FHC No.1 Motorcycer Parking	1	1	1	1	-	
FHC No.2 Florist Room(Soi 2)	1	1	1	1	-	
FHC N0.3 Room 308	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	-	
FHC No.5 next to fire exit stair	1	1	1	1	-	
FHC No.6 Salon Area	1	1	1	1	-	
FHC No.7 Reception Area	1	1	1	1	-	
FHC No.8 Male Locker Area	1	1	1	1	-	
FHC No.9 next to fire exit stair 3	1	1	1	1	-	
FHC No.10 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.11 Generetor Room	1	1	1	1	-	
FHC NO.12 Near Restroom Soi 64	1	1	1	1	-	
FHC No13 Luggage store	1	1	1	1	-	
FHC No.14 next to fire exit stair 5	1	1	1	1	-	
FHC No15 next to fire exit stair17	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Novac N0.1 IT Room	-	-	-	-	-	
Novac N0.2 EE Room	-	-	-	-	-	
Novac No.3 Main Power Room	-	-	-	-	-	
Security Office	-	-	-	-	-	
Laundry Area	-	-	-	-	4	
Housekeeping Office	-	-	-	1	-	
Floor B1						
FHC No.1 B1A	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 Store(Pumproom)(st1) B1E	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	1	
FHC No.5 Pillar A4 B1E	1	1	1	1	-	
FHC No.6 next to fire exit stair 3	1	1	1	1	-	
FHC No.7 next to fire exit stair 4	1	1	1	1	-	
FHC No.8 B1D near B1B	1	1	1	1	-	
FHC No.9 Motorcycer Parking	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B1A	1	1	1	1	-	
FHC NO.12 B1A	1	1	1	1	-	
ENG Work shop	-	-	-	6	2	
Floor B2						
FHC No.B2B(Pillar S13)	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 next to fire exit stair 1	1	1	1	1	-	
FHC No.4 B2 Pillar B4	1	1	1	1	-	
FHC No.5 Pillar A4 B1E Pillar U1	1	1	1	1	-	
FHC No.6 B2B next to fire exit stair 17	1	1	1	1	-	
FHC No.7 B2B Pillar U1	1	1	1	1	-	
FHC No.8 B2B Chiller Room	1	1	1	1	-	
FHC No.9 next to fire exit stair 4	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B2B Pillar T9	1	1	1	1	-	
Store Security	-	-	-	11	1	
Out side						
Gass Station	-	-	-	6	-	
Main Entrance	-	-	-	-	-	
TOTAL	**59**	**57**	**59**	**81**	**16**	

Checked by

DIRECTOR SE(

Date 20/09/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Cascade Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Rooftop						
FHC on Rooftop	1	-	1	-	-	
Floor 13						
FHC No.1 next to fire exit stair 11	1	1	1	1	-	
FHC No.2 EE Room	1	1	1	1	1	
FHC No.3 next to fire exit stair 12	1	1	1	1	-	
Floor 12						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 IN front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Next to Fire Exit Stair 12	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Floor 11						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire Exit stair 13	1	1	1	1	-	
FHC No.5 In front of AHU Room	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-		-	-	1	
Floor 10						
FHC No.1 next to Fire exit stair 11	1	1	1	1	-	
FHC No.2 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next to Fire exit stair 12	1	1	1	1	-	
FHC No.4 next to fire exit stair 13	1	1	1	1	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 near fire exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
AHU Room	-	-	-	-	1	
Floor 9						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 8						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 7						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 6						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 5						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	

FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 4						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 3						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.2 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 13	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.5 next to Fire Exit stair 15	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
In Front of Room 202	1	1	1	1	-	
Floor L						
FHC No.1 front of YTY Resterance	1	1	1	-	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire exit stair 13	1	1	1	-	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 in Front of Lift HP.9	1	1	1	1	-	
FHC No.7 In front of stair 20	1	1	1	1	-	
Floor LL						
FHC No.1 Carpark LL [W1]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Office Executive/Sale	1	1	1	-	-	
FHC No.4 Office Reservation	1	1	1	-	-	
FHC No.5 Carpark LL [U1]	1	1	1	1	-	
FHC No.6 next to Fire exit stair 13	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 Door Gate 3	1	1	1	1	-	
FHC No.9 In front of stair 20	1	1	1	1	-	
FHC No.10 Nearby P&C store	-	-	-	-	-	
Floor B1						
FHC No.1 Carpark B1C[M4]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Carpark B1C[I4]	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
TOTAL	**102**	**101**	**102**	**97**	**19**	

Checked by

DIRECTOR

Date 20/09/2024

FIRE EXTINGUSHER RESIDENCES CHECK LIST

LOCATION	DRY	CO2	NOTE	DATE
ROOFTOP				
FHC	-	2		
FLOOR 69				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	1		
FLOOR 68				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 67				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	-	Embrassy's Unit	
FLOOR 66				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	Embrassy's Unit	
FLOOR 65				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 64				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 63				
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 62				
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 61				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 60				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 59				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 58				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 57				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 56				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		

FLOOR 55				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 54				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 53				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 52				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 51				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 50				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 49				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 48				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 47				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 46				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR45				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 42				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 41				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
Fire Pump Room	1	-		
FLOOR 40				
FHC No.1 RST.2	1	1		

FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 39				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 38				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR37				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 36				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 35				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 34				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 31				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 30				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 29				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 28				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 27				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 26				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 25				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 24				

FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 21				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 20				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 19				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 18				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 17				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 16				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 15				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 14				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.3	1	1		
FLOOR 11				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 10				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 9				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	-		

FLOOR 8				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 7				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 6				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 5				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 4				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 3				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Facility Office	1	-		
FLOOR 2				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR L				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 OFFICE AREA	1	1		
FHC No.5 B/Q STORE	1	-		
FLOOR LL				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Pet Grooming	1	-		
FHC No.5 ยังหาตู้ไม่เจอ	1	-		
FHC No.6 ENG Office	1	-		
FHC No.7 Loading area	2	-		
FLOOR B1				
FHC No.1 RST.2	1	-		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	-		
FHC No.4 Door2	1	-		
FHC No.5 B1C Pillar A13	1	-		
FHC No.6 B1C Pillar F14	1	-		
FHC No.7 B1C Pillar M14	1	-		
FHC No.8 Fanroom	1	-		
Total	**224**	**139**		

FHC IN ROOM GUEST	
Room Number	Floor
8	69
11	66-67
26	62-63
27	60-61
28	60-61

ALL FIRE EXTINGUSHER		
LOCATION	**DRY CHEMICAL**	**CO2**
HOTEL	204	39
RESIDENCE	224	139
Total	428	178

324	10-11
Total 5 Rooms.	

Checked by

DIRECTOR SECURITY...

Date 20/09/2024

SUMMARY REPORT

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Ballroom Building	28	28	28	26	4	
Palm court Building	59	57	59	81	16	
Cascade Building	102	101	102	97	19	
Keep in Store	-	-	-	-	-	
Waiting for refill/Broken	-	-	-	-	-	
Total	**189**	**186**	**189**	**204**	**39**	

Discard Dry = 4 Pcs [27/07/2023]
Discard Dry = 1 Pcs [26/09/2023]
Discard Dry = 5 Pcs [23/02/2024]
Discard Dry = 6 Pcs [19/08/2024]
Total = 16 Pcs.

Checked by ...

Director Security ...

Date 20/09/2024

B/A CONTROL BOARD

NUMBER	REFILL DATE	EXPIRE DATE	TANK SIZE	BAR	USAGE TIME	REMARK
FSH						
B/A No.1	29/02/2024	N/A	6.8 L	170	18.5 Minute	อยู่ระหว่างส่งเติมอากาศใหม่
B/A No.2	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
FSR						
B/A No.1	29/02/2024	N/A	6.8 L	240	30.0 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
B/A No.2	29/02/2024	N/A	6.8 L	0	0	อยู่ระหว่างส่งเติมอากาศใหม่
SPARE						
SPARE No.1	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
SPARE No.2	29/02/2024	N/A	6.8 L	250	32.5 Minute	ลบ 10 นาที เผื่อ Safety Factor แล้ว
SPARE No.3	29/02/2024	N/A	6.8 L	0	0	อยู่ระหว่างส่งเติมอากาศใหม่

Checked by .

DIRECTOR SECURITY ....

Date 31/10/2024

FIRE EXTINGUISHER (GREEN CHEMICAL)

LOCATON	GREEN CHEMICAL	
	AVAILABLE	STATUS
Server room in IT office	1	✓
Finances Fire hose reel cabinet.	1	✓
S&M Fire hose reel cabinet.	1	✓
MDB room	1	✓
IRD kitchen	1	✓
Main Kitchen	1	✓
Soi 64 kitchen	1	✓
Fire control room	1	✓
Front office (ERT Briefing point)	1	✓
Lobby area	1	✓
Door 2 (Ballroom)	1	✓
Lobby lounge	1	✓
YTY kitchen	1	✓
BKK kitchen	1	✓
RIVA kitchen	1	✓
Palmier kitchen	1	✓
Art space area	1	✓
Chiller room (Electrical control room)	1	✓
Counter B1 Residence	1	✓
FHC Ballroom	5	✓
FHC Conservatory	2	✓
FSR Sky loung kitchen Fl 64	1	✓
FSR SkyFitness Fl 65	1	✓
FSR In front Cafe madeleine pantry	1	✓
AV room (Ballroom 2nd floor)	1	✓
Engineer Workshop (Carpark B1)	1	✓
Engineer Chemical store (Carpark B1)	1	✓
In front the Bottled Water Factory (Carpark B2)	1	✓
Waitting for refill	2	✓
Spare (Store Security)	7	✓
Total	**42**	

Checked by

DIRECTOR SECURITY .....

Date 31/10/2024

FIRE EXTINGUISHER (TYPE K) and FIRE BLANKET

LOCATON	WET CHEMICAL		FIRE BLANKET		REMARK
	AVAILABLE	STATUS	AVAILABLE	STATUS	
Ballroom Kitchen	3	✓	2	✓	
Conservatory Kitchen	3	✓	2	✓	
B/P Kitchen	3	✓	1	✓	
RIVA Kitchen	3	✓	2	✓	
BKK Kitchen	2	✓	2	✓	
YTY Kitchen	2	✓	1	✓	
MAIN Kitchen	1	✓	-	-	
BAKERRY Kitchen	1	✓	-	-	
GRILL ROOM Kitchen	1	✓	-	-	
IRD Kitchen	1	✓	1	✓	
SOI 64 Kitchen	-	-	1	✓	
Riverfront Kitchen	3	✓	2	✓	
The lounge	-	-	1	✓	
Fire cart No.1	-	-	-	-	
Fire cart No.2 set up H/S 9,10 (B1)	-	-	1	✓	**Fire blanket for EV vehicles fire protection**
Sky Lounge FSR	-	-	1	✓	
Cabinet of ammunition No.1 (H/S 1/2)	-	-	-	-	
Cabinet of ammunition No.2(H/S 7/8)	-	-	-	-	
Cabinet of ammunition No.3(H/S 9/10)	-	-	-	-	
Cabinet of ammunition No.4 Residence	-	-	-	-	
Store Room B2	-	-	2	✓	
TOTAL	**23**		**19**		

Checked By

DIRECTOR SECURITY

Date 31/10/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Ballroom Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Green	Remark
ROOFTOP							
FHC on Rooftop stair 7	1	1	1	1	-	-	
FLOOR 3							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Near Rest room Guest	1	1	1	1	-	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	1	
FHC No.4 In front of BQ Store	1	1	1	1	-	1	
Floor 2							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 AHU Room	1	1	1	1	-	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	1	
FHC No.4 In front of Excome Office	1	1	1	1	-	-	
Floor L							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Bar Ballroom Area	1	1	1	1	-	1	
FHC N0.3 Bar Ballroom Area	1	1	1	1	-	1	
FHC No.4 next to fire exit stair 8	1	1	1	1	-	2	
FHC No.5 In front of Terrest Ballroom	1	1	1	1	-	1	
FHC No.6 In front of Door 2	1	1	1	1	-	-	
FHC N0.7 F/O Counter	1	1	1	1	-	-	
Floor LL							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Carpark (Near CP 4)	1	1	1	1	-	-	
FHC N0.3 Carpark LL	1	1	1	1	-	-	
FHC No.4 Carpark LL	1	1	1	1	-	-	
FHC No.5 Door 9 St 19	1	1	1	1	-	-	
FHC No.6 Art Space (CP 4)	1	1	1	-	-	1	
FHC N0.7 Art Space (Door 6)	1	1	1	1	-	-	
FHC N0.8 Art Space (In side St 18)	1	1	1	1	-	-	
Floor B1							
FHC No.1 In front H/S 9/10	1	1	1	1	-	-	
FHC No.2 EV CHARGER	1	1	1	-	1	-	
FHC N0.3 next to fire exit stair 18	1	1	1	1	-	-	
FHC No.4 next to fire exit stair 19	1	1	1	1	-	-	
TOTAL	**28**	**28**	**28**	**26**	**1**	**9**	

Checked by

DIRECTOR SECURITY ....

Date 31/10/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Palm Court Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 4	1	-	1	-	-	
FHC on Rooftop St 06	1	-	1	-	-	
FLOOR 3						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor 1						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
FHC N0.7 Luggage store	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor LL						
FHC No.1 Motorcycer Parking	1	1	1	1	-	
FHC No.2 Florist Room(Soi 2)	1	1	1	1	-	
FHC N0.3 Room 308	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	-	
FHC No.5 next to fire exit stair	1	1	1	1	-	
FHC No.6 Salon Area	1	1	1	1	-	
FHC No.7 Reception Area	1	1	1	1	-	
FHC No.8 Male Locker Area	1	1	1	1	-	
FHC No.9 next to fire exit stair 3	1	1	1	1	-	
FHC No.10 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.11 Generetor Room	1	1	1	1	-	
FHC NO.12 Near Restroom Soi 64	1	1	1	1	-	
FHC No13 Luggage store	1	1	1	1	-	
FHC No.14 next to fire exit stair 5	1	1	1	1	-	
FHC No15 next to fire exit stair17	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Novac N0.1 IT Room	-	-	-	-	-	
Novac N0.2 EE Room	-	-	-	-	-	
Novac No.3 Main Power Room	-	-	-	-	-	
Security Office	-	-	-	-	-	
Laundry Area	-	-	-	-	4	
Housekeeping Office	-	-	-	1	-	
Floor B1						
FHC No.1 B1A	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 Store(Pumproom)(st1) B1E	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	1	
FHC No.5 Pillar A4 B1E	1	1	1	1	-	
FHC No.6 next to fire exit stair 3	1	1	1	1	-	
FHC No.7 next to fire exit stair 4	1	1	1	1	-	
FHC No.8 B1D near B1B	1	1	1	1	-	
FHC No.9 Motorcycer Parking	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B1A	1	1	1	1	-	
FHC NO.12 B1A	1	1	1	1	-	
ENG Work shop	-	-	-	6	2	
Floor B2						
FHC No.B2B(Pillar S13)	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 next to fire exit stair 1	1	1	1	1	-	
FHC No.4 B2 Pillar B4	1	1	1	1	-	
FHC No.5 Pillar A4 B1E Pillar U1	1	1	1	1	-	
FHC No.6 B2B next to fire exit stair 17	1	1	1	1	-	
FHC No.7 B2B Pillar U1	1	1	1	1	-	
FHC No.8 B2B Chiller Room	1	1	1	1	-	
FHC No.9 next to fire exit stair 4	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B2B Pillar T9	1	1	1	1	-	
Store Security	-	-	-	11	1	
Out side						
Gass Station	-	-	-	6	-	
Main Entrance	-	-	-	-	-	
TOTAL	59	57	59	81	16	

Checked by

DIRECTOR SECURITY .....

Date 31/10/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Cascade Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Rooftop						
FHC on Rooftop	1	-	1	-	-	
Floor 13						
FHC No.1 next to fire exit stair 11	1	1	1	1	-	
FHC No.2 EE Room	1	1	1	1	1	
FHC No.3 next to fire exit stair 12	1	1	1	1	-	
Floor 12						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 IN front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Next to Fire Exit Stair 12	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Floor 11						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 in front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire Exit stair 13	1	1	1	1	-	
FHC No.5 In front of AHU Room	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-		-	-	1	
Floor 10						
FHC No.1 next to Fire exit stair 11	1	1	1	1	-	
FH .2 In Front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next to Fire exit stair 12	1	1	1	1	-	
FHC No.4 next to fire exit stair 13	1	1	1	1	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 near fire exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
AHU Room	-	-	-	-	1	
Floor 9						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 8						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FH .7 In front of Lift HS 5,6	1	1	1	1	-	
FH .8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 7						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 6						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 5						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	

FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 4						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 3						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.2 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 13	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.5 next to Fire Exit stair 15	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
In Front of Room 202	1	1	1	1	-	
Floor L						
FHC No.1 front of YTY Resterance	1	1	1	-	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire exit stair 13	1	1	1	-	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 in Front of Lift HP.9	1	1	1	1	-	
FHC No.7 In front of stair 20	1	1	1	1	-	
Floor LL						
FHC No.1 Carpark LL [W1]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Office Executive/Sale	1	1	1	-	-	
FHC No.4 Office Reservation	1	1	1	-	-	
FHC No.5 Carpark LL [U1]	1	1	1	1	-	
FHC No.6 next to Fire exit stair 13	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 Door Gate 3	1	1	1	1	-	
FH[illegible].9 In front of stair 20	1	1	1	1	-	
FHC No.10 Nearby P&C store	-	-	-	-	-	
Floor B1						
FHC No.1 Carpark B1C[M4]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Carpark B1C[I4]	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
TOTAL	102	101	102	97	19	

Checked by

DIRECTOR SECURITY .....

Date 31/10/2024

FIRE EXTINGUSHER RESIDENCES CHECK LIST

LOCATION	DRY	CO2	NOTE	DATE
ROOFTOP				
FHC	-	2		
FLOOR 69				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	1		
FLOOR 68				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 67				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	Embrassy's Unit	
FLOOR 66				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	Embrassy's Unit	
FLOOR 65				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 64				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 63				
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 62				
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 61				
FHC No.1 RST.2	1	1	K.Wanfang Su's Unit	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	K.Tommy's Unit	
FLOOR 60				
FHC No.1 RST.2	1	1	K.Wanfang Su's Unit	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	K.Tommy's Unit	
FLOOR 59				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 58				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 57				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 56				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		

FLOOR 55				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 54				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 53				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 52				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 51				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 50				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 49				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 48				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 47				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 46				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR45				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 42				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 41				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
Fire Pump Room	1	-		
FLOOR 40				
FHC No.1 RST.2	1	1		

FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 39				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 38				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR37				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 36				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 35				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 34				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 31				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 30				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 29				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 28				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 27				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 26				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 25				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 24				

FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 21				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 20				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 19				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 18				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 17				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 16				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 15				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 14				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.3	1	1		
FLOOR 11				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	K.Ben's Unit	
FLOOR 10				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	K.Ben's Unit	
FLOOR 9				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	-		

FLOOR 8				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 7				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 6				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 5				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 4				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 3				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Facility Office	1	-		
FLOOR 2				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR L				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 OFFICE AREA	1	1		
FHC No.5 B/Q STORE	1	-		
FLOOR LL				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Pet Grooming	1	-		
FHC No.5 ยังหาตู้ไม่เจอ	1	-		
FHC No.6 ENG Office	1	-		
FHC No.7 Loading area	2	-		
FLOOR B1				
FHC No.1 RST.2	1	-		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	-		
FHC No.4 Door2	1	-		
FHC No.5 B1C Pillar A13	1	-		
FHC No.6 B1C Pillar F14	1	-		
FHC No.7 B1C Pillar M14	1	-		
FHC No.8 Fanroom	1	-		
Total	**225**	**140**		

FHC IN ROOM GUEST	
Unit Number	Floor
5	70-71
11	66-67
26	62-63
27	60-61
28	60-61

ALL FIRE EXTINGUSHER		
LOCATION	**DRY CHEMICAL**	**CO2**
HOTEL	204	39
RESIDENCE	225	140
Total	429	179

324	10-11
Total 5 Rooms.	

Checked by A

DIRECTOR SECURITY.....

Date 31/10/2024

SUMMARY REPORT

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Green Type	Remark
Ballroom Building	28	28	28	26	1	9	
Palm court Building	59	57	59	81	16	-	
Cascade Building	102	101	102	97	19	-	
Keep in Store	-	-	-	2	-	7	
Waiting for refill/Broken	-	-	-	2	-	-	
Total	**189**	**186**	**189**	**208**	**36**	**16**	

Discard Dry = 4 Pcs [27/07/2023]
Discard Dry = 1 Pcs [26/09/2023]
Discard Dry = 5 Pcs [23/02/2024]
Discard Dry = 6 Pcs [19/08/2024]
Total = 16 Pcs.

Checked by .

Director Security .....

Date 30/11/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Cascade Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Rooftop						
FHC on Rooftop	1	-	1	-	-	
Floor 13						
FHC No.1 next to fire exit stair 11	1	1	1	1	-	
FHC No.2 EE Room	1	1	1	1	1	
FHC No.3 next to fire exit stair 12	1	1	1	1	-	
Floor 12						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 IN front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Next to Fire Exit Stair 12	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Floor 11						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire Exit stair 13	1	1	1	1	-	
FHC No.5 In front of AHU Room	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-		-	-	1	
Floor 10						
FHC No.1 next to Fire exit stair 11	1	1	1	1	-	
FHC No.2 In Front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next to Fire exit stair 12	1	1	1	1	-	
FHC No.4 next to fire exit stair 13	1	1	1	1	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 near fire exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
AHU Room	-	-	-	-	1	
Floor 9						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 8						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 7						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 6						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 5						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	

FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 4						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 In Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 3						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 In Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.2 next ti Fire exit Stair 12	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 13	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.5 next to Fire Exit stair 15	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
In Front of Room 202	1	1	1	1	-	
Floor L						
FHC No.1 front of YTY Resterance	1	1	1	-	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire exit stair 13	1	1	1	-	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 In Front of Lift HP.9	1	1	1	1	-	
FHC No.7 In front of stair 20	1	1	1	1	-	
Floor LL						
FHC No.1 Carpark LL [W1]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Office Executive/Sale	1	1	1	-	-	
FHC No.4 Office Reservation	1	1	1	-	-	
FHC No.5 Carpark LL [U1]	1	1	1	1	-	
FHC No.6 next to Fire exit stair 13	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 Door Gate 3	1	1	1	1	-	
FHC No.9 In front of stair 20	1	1	1	1	-	
FHC No.10 Nearby P&C store	-	-	-	-	-	
Floor B1						
FHC No.1 Carpark B1C[M4]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Carpark B1C[I4]	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
TOTAL	102	101	102	97	19	

Checked by /

DIRECTOR SECURITY .....

Date 30/11/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Palm Court Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 4	1	-	1	-	-	
FHC on Rooftop St 06	1	-	1	-	-	
FLOOR 3						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor LL						
FHC No.1 In front of Lift H,S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
FHC N0.7 Luggage store	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor LL						
FHC No.1 Motorcycer Parking	1	1	1	1	-	
FHC No.2 Florist Room(Sol 2)	1	1	1	1	-	
FHC N0.3 Room 308	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	-	
FHC No.5 next to fire exit stair	1	1	1	1	-	
FHC No.6 Salon Area	1	1	1	1	-	
FHC No.7 Reception Area	1	1	1	1	-	
FHC No.8 Male Locker Area	1	1	1	1	-	
FHC No.9 next to fire exit stair 3	1	1	1	1	-	
FHC No.10 In front of Lift H,S 3,4	1	1	1	1	-	
FHC No.11 Generetor Room	1	1	1	1	-	
FHC NO.12 Near Restroom Sol 64	1	1	1	1	-	
FHC No13 Luggage store	1	1	1	1	-	
FHC No.14 next to fire exit stair 5	1	1	1	1	-	
FHC No15 next to fire exit stair17	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Novac N0.1 IT Room	-	-	-	-	-	
Novac N0.2 EE Room	-	-	-	-	-	
Novac No.3 Main Power Room	-	-	-	-	-	
Security Office	-	-	-	-	-	
Laundry Area	-	-	-	-	4	
Housekeeping Office	-	-	-	1	-	
Floor B1						
FHC No.1 B1A	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 Store(Pumproom)(st1) B1E	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	1	
FHC No.5 Pillar A4 B1E	1	1	1	1	-	
FHC No.6 next to fire exit stair 3	1	1	1	1	-	
FHC No.7 next to fire exit stair 4	1	1	1	1	-	
FHC No.8 B1D near B1B	1	1	1	1	-	
FHC No.9 Motorcycer Parking	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B1A	1	1	1	1	-	
FHC NO.12 B1A	1	1	1	1	-	
ENG Work shop	-	-	-	6	2	
Floor B2						
FHC No.B2B(Pillar S13)	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 next to fire exit stair 1	1	1	1	1	-	
FHC No.4 B2 Pillar B4	1	1	1	1	-	
FHC No.5 Pillar A4 B1E Pillar U1	1	1	1	1	-	
FHC No.6 B2B next to fire exit stair 17	1	1	1	1	-	
FHC No.7 B2B Pillar U1	1	1	1	1	-	
FHC No.8 B2B Chiller Room	1	1	1	1	-	
FHC No.9 next to fire exit stair 4	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B2B Pillar T9	1	1	1	1	-	
Store Security	-	-	-	11	1	
Out side						
Gass Station	-	-	-	6	-	
Main Entrance	-	-	-	-	-	
TOTAL	59	57	59	81	16	

Checked by

DIRECTOR SECURITY .....

Date 30/11/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Ballroom Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Green	Remark
ROOFTOP							
FHC on Rooftop stair 7	1	1	1	1	-	-	
FLOOR 3							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Near Rest room Guest	1	1	1	1	-	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	1	
FHC No.4 In front of BQ Store	1	1	1	1	-	1	
Floor 2							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 AHU Room	1	1	1	1	-	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	1	
FHC No.4 In front of Excome Office	1	1	1	1	-	-	
Floor L							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Bar Ballroom Area	1	1	1	1	-	2	
FHC N0.3 Bar Ballroom Area	1	1	1	1	-	2	
FHC No.4 next to fire exit stair 8	1	1	1	1	-	2	
FHC No.5 In front of Terrest Ballroom	1	1	1	1	-	2	
FHC No.6 In front of Door 2	1	1	1	1	-	-	
FHC N0.7 F/O Counter	1	1	1	1	-	-	
Floor LL							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Carpark (Near CP 4)	1	1	1	1	-	-	
FHC N0.3 Carpark LL	1	1	1	1	-	-	
FHC No.4 Carpark LL	1	1	1	1	-	-	
FHC No.5 Door 9 St 19	1	1	1	1	-	-	
FHC No.6 Art Space (CP 4)	1	1	1	-	-	1	
FHC N0.7 Art Space (Door 6)	1	1	1	1	-	-	
FHC N0.8 Art Space (In side St 18)	1	1	1	1	-	-	
Floor B1							
FHC No.1 In front H/S 9/10	1	1	1	1	-	-	
FHC No.2 EV CHARGER	1	1	1	-	1	-	
FHC N0.3 next to fire exit stair 18	1	1	1	1	-	-	
FHC No.4 next to fire exit stair 19	1	1	1	1	-	-	
TOTAL	**28**	**28**	**28**	**26**	**1**	**12**	

Checked by .

DIRECTOR SECURITY .....

Date 30/11/2024

FIRE EXTINGUISHER (GREEN CHEMICAL)

LOCATON	GREEN CHEMICAL	
	AVAILABLE	STATUS
Server room in IT office	1	✓
Finances Fire hose reel cabinet.	1	✓
S&M Fire hose reel cabinet.	1	✓
MDB room	1	✓
IRD kitchen	1	✓
Main Kitchen	1	✓
Soi 64 kitchen	1	✓
Fire control room	1	✓
Front office (ERT Briefing point)	1	✓
Lobby area	1	✓
Door 2 (Ballroom)	1	✓
Lobby lounge	1	✓
YTY kitchen	1	✓
BKK kitchen	1	✓
RIVA kitchen	1	✓
Palmier kitchen	1	✓
Art space area	1	✓
Chiller room (Electrical control room)	1	✓
Counter B1 Residence	1	✓
FHC Ballroom	8	✓
FHC Conservatory	2	✓
FSR Sky loung kitchen Fl 64	1	✓
FSR SkyFitness Fl 65	1	✓
FSR In front Cafe madeleine pantry	1	✓
AV room (Ballroom 2nd floor)	1	✓
Engineer Workshop (Carpark B1)	1	✓
Engineer Chemical store (Carpark B1)	1	✓
In front the Bottled Water Factory (Carpark B2)	1	✓
Water Factory (Carpark B2)	2	✓
Waitting for refill	2	✓
Spare (Store Security)	1	✓
Total	**41**	

Checked by .

DIRECTOR SECURITY .....

Date 30/11/2024

FIRE EXTINGUISHER (TYPE K) and FIRE BLANKET

LOCATON	WET CHEMICAL		FIRE BLANKET		REMARK
	AVAILABLE	STATUS	AVAILABLE	STATUS	
Ballroom Kitchen	3	✓	2	✓	
Conservatory Kitchen	3	✓	2	✓	
B/P Kitchen	3	✓	1	✓	
RIVA Kitchen	3	✓	2	✓	
BKK Kitchen	2	✓	2	✓	
YTY Kitchen	2	✓	1	✓	
MAIN Kitchen	1	✓	-	-	
BAKERRY Kitchen	1	✓	-	-	
GRILL ROOM Kitchen	1	✓	-	-	
IRD Kitchen	1	✓	1	✓	
SOI 64 Kitchen	-	-	1	✓	
Riverfront Kitchen	3	✓	2	✓	
The lounge	-	-	1	✓	
Fire cart No.1	-	-	-	-	
Fire cart No.2 set up H/S 9,10 (B1)	-	-	1	✓	**Fire blanket for EV vehicles fire protection**
Sky Lounge FSR	-	-	1	✓	
Cabinet of ammunition No.1 (H/S 1/2)	-	-	-	-	
Cabinet of ammunition No.2(H/S 7/8)	-	-	-	-	
Cabinet of ammunition No.3(H/S 9/10)	-	-	-	-	
Cabinet of ammunition No.4 Residence	-	-	-	-	
Store Room B2	-	-	2	✓	
TOTAL	**23**		**19**		

Checked By

DIRECTOR SECURITY .....

Date 30/11/2024

FIRE EXTINGUSHER RESIDENCES CHECK LIST

LOCATION	DRY	CO2	NOTE	DATE
ROOFTOP				
FHC	-	2		
FLOOR 69				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	1		
FLOOR 68				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 67				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	Embrassy's Unit	
FLOOR 66				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	Embrassy's Unit	
FLOOR 65				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 64				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 63				
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 62				
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 61				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 60				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 59				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 58				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 57				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 56				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 55				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		

FLOOR 54				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 53				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 52				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 51				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 50				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 49				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 48				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 47				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 46				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR45				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 42				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 41				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
Fire Pump Room	1	-		
FLOOR 40				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 39				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 38				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		

FHC No.3 RST.1	1	1		
FLOOR37				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 36				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 35				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 34				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 31				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 30				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 29				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 28				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 27				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 26				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 25				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 24				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 21				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		

FHC No.3 RST.1	1	1		
FLOOR 20				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 19				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 18				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 17				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 16				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 15				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 14				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.3	1	1		
FLOOR 11				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 10				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 9				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	-		
FLOOR 8				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 7				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 6				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 5				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 4				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		

FHC No.3 RST.1	1	1		
FLOOR 3				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Facility Office	1	-		
FLOOR 2				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR L				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 OFFICE AREA	1	1		
FHC No.5 B/Q STORE	1	-		
FLOOR LL				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Pet Grooming	1	-		
FHC No.5 ยังหาตู้ไม่เจอ	1	-		
FHC No.6 ENG Office	1	-		
FHC No.7 Loading area	2	-		
FLOOR B1				
FHC No.1 RST.2	1	-		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	-		
FHC No.4 Door2	1	-		
FHC No.5 B1C Pillar A13	1	-		
FHC No.6 B1C Pillar F14	1	-		
FHC No.7 B1C Pillar M14	1	-		
FHC No.8 Fanroom	1	-		
Total	**223**	**140**		

FHC IN ROOM GUEST	
Unit Number	Floor
5	70-71
11	66-67
26	62-63
27	60-61
28	60-61
324	10-11
Total 6 Rooms.	

ALL FIRE EXTINGUSHER		
LOCATION	**DRY CHEMICAL**	**CO2**
HOTEL	204	39
RESIDENCE	225	140
Total	429	179

Checked by .

DIRECTOR SECURITY.....

Date 27/12/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Cascade Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
Rooftop						
FHC on Rooftop	1	-	1	-	-	
Floor 13						
FHC No.1 next to fire exit stair 11	1	1	1	1	-	
FHC No.2 EE Room	1	1	1	1	1	
FHC No.3 next to fire exit stair 12	1	1	1	1	-	
Floor 12						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 IN front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Next to Fire Exit Stair 12	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Floor 11						
FHC No.1 Near Fire Exit Stair 11	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire Exit stair 13	1	1	1	1	-	
FHC No.5 In front of AHU Room	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-		-	-	1	
Floor 10						
FHC No.1 next to Fire exit stair 11	1	1	1	1	-	
FHC No.2 In Front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next to Fire exit stair 12	1	1	1	1	-	
FHC No.4 next to fire exit stair 13	1	1	1	1	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 near fire exit stair 15	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
AHU Room	-	-	-	-	1	
Floor 9						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 8						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 7						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 6						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 5						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	

FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 4						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 3						
FHC No.1 next to Fire exit stair 10	1	1	1	1	-	
FHC No.2 next to Fire exit stair 11	1	1	1	1	-	
FHC No.3 in Front of Lift HS 7,8	1	1	1	1	-	
FHC No.4 next to Fire exit stair 12	1	1	1	1	-	
FHC No.5 next to fire exit stair 13	1	1	1	1	-	
FHC No.6 near fire exit stair 14	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 In front of Lift HS 5,6	1	1	1	1	-	
Maid pantry Lift HS 7,8 (R1)	-	-	-	-	1	
Shaft room	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.2 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 13	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.5 next to Fire Exit stair 15	1	1	1	1	-	
FHC No.6 next to Fire Exit stair 15	1	1	1	1	-	
In Front of Room 202	1	1	1	1	-	
Floor L						
FHC No.1 front of YTY Resterance	1	1	1	-	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 next ti Fire Exit Stair 12	1	1	1	1	-	
FHC No.4 next to Fire exit stair 13	1	1	1	-	-	
FHC No.5 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.6 in Front of Lift HP.9	1	1	1	1	-	
FHC No.7 In front of stair 20	1	1	1	1	-	
Floor LL						
FHC No.1 Carpark LL [W1]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Office Executive/Sale	1	1	1	-	-	
FHC No.4 Office Reservation	1	1	1	-	-	
FHC No.5 Carpark LL [U1]	1	1	1	1	-	
FHC No.6 next to Fire exit stair 13	1	1	1	1	-	
FHC No.7 In front of Lift HS 5,6	1	1	1	1	-	
FHC No.8 Door Gate 3	1	1	1	1	-	
FHC No.9 In front of stair 20	1	1	1	1	-	
FHC No.10 Nearby P&C store	-	-	-	-	-	
Floor B1						
FHC No.1 Carpark B1C[M4]	1	1	1	1	-	
FHC No.2 In front of Lift HS 7,8	1	1	1	1	-	
FHC No.3 Carpark B1C[I4]	1	1	1	1	-	
FHC No.4 In front of Lift HS 5,6	1	1	1	1	-	
TOTAL	**102**	**101**	**102**	**97**	**19**	

Checked by

DIRECTOR SECURITY .....

Date 27/12/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Palm Court Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Remark
ROOFTOP						
FHC on Rooftop stair 4	1	-	1	-	-	
FHC on Rooftop St 06	1	-	1	-	-	
FLOOR 3						
FHC No.1 In front of Lift H.S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H.S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor 2						
FHC No.1 In front of Lift H.S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H.S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor L						
FHC No.1 In front of Lift H.S 1,2	1	1	1	1	-	
FHC No.2 next to fire exit stair 1	1	1	1	1	-	
FHC N0.3 next to fire exit stair 2	1	1	1	1	-	
FHC No.4 next to fire exit stair 3	1	1	1	1	-	
FHC No.5 In front of Lift H.S 3,4	1	1	1	1	-	
FHC No.6 next to fire exit stair 5	1	1	1	1	-	
FHC N0.7 Luggage store	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Floor LL						
FHC No.1 Motorcycer Parking	1	1	1	1	-	
FHC No.2 Florist Room(Sal 2)	1	1	1	1	-	
FHC N0.3 Room 308	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	-	
FHC No.5 next to fire exit stair	1	1	1	1	-	
FHC No.6 Salon Area	1	1	1	1	-	
FHC No.7 Reception Area	1	1	1	1	-	
FHC No.8 Male Locker Area	1	1	1	1	-	
FHC No.9 next to fire exit stair 3	1	1	1	1	-	
FHC No.10 In front of Lift H.S 3,4	1	1	1	1	-	
FHC No.11 Generetor Room	1	1	1	1	-	
FHC NO.12 Near Restroom Sal 64	1	1	1	1	-	
FHC No13 Luggage store	1	1	1	1	-	
FHC No.14 next to fire exit stair 5	1	1	1	1	-	
FHC No15 next to fire exit stair17	1	1	1	1	-	
EE Room next to stair 1	-	-	-	-	1	
EE Room next to stair 3	-	-	-	-	1	
Novac N0.1 IT Room	-	-	-	-	-	
Novac N0.2 EE Room	-	-	-	-	-	
Novac No.3 Main Power Room	-	-	-	-	-	
Security Office	-	-	-	-	-	
Laundry Area	-	-	-	-	4	
Housekeeping Office	-	-	-	1	-	
Floor B1						
FHC No.1 B1A	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 Store(Pumproom)(st1) B1E	1	1	1	1	-	
FHC No.4 next to fire exit stair 1	1	1	1	1	1	
FHC No.5 Pillar A4 B1E	1	1	1	1	-	
FHC No.6 next to fire exit stair 3	1	1	1	1	-	
FHC No.7 next to fire exit stair 4	1	1	1	1	-	
FHC No.8 B1D near B1B	1	1	1	1	-	
FHC No.9 Motorcycer Parking	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B1A	1	1	1	1	-	
FHC NO.12 B1A	1	1	1	1	-	
ENG Work shop	-	-	-	6	2	
Floor B2						
FHC No.B2B(Pillar S13)	1	1	1	1	-	
FHC No.2 next to fire exit stair 6	1	1	1	1	-	
FHC N0.3 next to fire exit stair 1	1	1	1	1	-	
FHC No.4 B2 Pillar B4	1	1	1	1	-	
FHC No.5 Pillar A4 B1E Pillar U1	1	1	1	1	-	
FHC No.6 B2B next to fire exit stair 17	1	1	1	1	-	
FHC No.7 B2B Pillar U1	1	1	1	1	-	
FHC No.8 B2B Chiller Room	1	1	1	1	-	
FHC No.9 next to fire exit stair 4	1	1	1	1	-	
FHC No.10 CP 1/2	1	1	1	1	-	
FHC No.11 B2B Pillar T9	1	1	1	1	-	
Store Security	-	-	-	11	1	
Out side						
Gass Station	-	-	-	6	-	
Main Entrance	-	-	-	-	-	
TOTAL	59	57	59	81	16	

Checked by

DIRECTOR SECURITY

Date 27/12/2024

FIRE EXTINGUSHER HOTEL CHECKLIST (Ballroom Building)

Location	Fire Cabinet	Fire Hose Reel	Brass Valve	Dry Chemical	CO2	Green	Remark
ROOFTOP							
FHC on Rooftop stair 7	1	1	1	1	-	-	
FLOOR 3							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Near Rest room Guest	1	1	1	1	-	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	1	
FHC No.4 In front of BQ Store	1	1	1	1	-	1	
Floor 2							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 AHU Room	1	1	1	1	-	-	
FHC N0.3 next to fire exit stair 8	1	1	1	1	-	1	
FHC No.4 In front of Excome Office	1	1	1	1	-	-	
Floor L							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Bar Ballroom Area	1	1	1	1	-	1	
FHC N0.3 Bar Ballroom Area	1	1	1	1	-	1	
FHC No.4 next to fire exit stair 8	1	1	1	1	-	2	
FHC No.5 In front of Terrest Ballroom	1	1	1	1	-	1	
FHC No.6 In front of Door 2	1	1	1	1	-	-	
FHC N0.7 F/O Counter	1	1	1	1	-	-	
Floor LL							
FHC No.1 In front of Lift H,S 9/10	1	1	1	1	-	-	
FHC No.2 Carpark (Near CP 4)	1	1	1	1	-	-	
FHC N0.3 Carpark LL	1	1	1	1	-	-	
FHC No.4 Carpark LL	1	1	1	1	-	-	
FHC No.5 Door 9 St 19	1	1	1	1	-	-	
FHC No.6 Art Space (CP 4)	1	1	1	-	-	1	
FHC N0.7 Art Space (Door 6)	1	1	1	1	-	-	
FHC N0.8 Art Space (In side St 18)	1	1	1	1	-	-	
Floor B1							
FHC No.1 In front H/S 9/10	1	1	1	1	-	-	
FHC No.2 EV CHARGER	1	1	1	-	1	-	
FHC N0.3 next to fire exit stair 18	1	1	1	1	-	-	
FHC No.4 next to fire exit stair 19	1	1	1	1	-	-	
TOTAL	**28**	**28**	**28**	**26**	**1**	**9**	

Checked by

DIRECTOR SECURITY ...

Date 27/12/2024

FIRE EXTINGUISHER (GREEN CHEMICAL)

LOCATON	GREEN CHEMICAL	
	AVAILABLE	STATUS
Server room in IT office	1	✓
Finances Fire hose reel cabinet.	1	✓
S&M Fire hose reel cabinet.	1	✓
MDB room	1	✓
IRD kitchen	1	✓
Main Kitchen	1	✓
Soi 64 kitchen	1	✓
Fire control room	1	✓
Front office (ERT Briefing point)	1	✓
Lobby area	1	✓
Door 2 (Ballroom)	1	✓
Lobby lounge	1	✓
YTY kitchen	1	✓
BKK kitchen	1	✓
RIVA kitchen	1	✓
CPT	1	✓
Palmier kitchen	1	✓
Art space area	1	✓
Chiller room (Electrical control room)	1	✓
Counter B1 Residence	1	✓
FHC Ballroom	8	✓
FHC Conservatory	2	✓
FSR Sky loung kitchen Fl 64	1	✓
FSR SkyFitness Fl 65	1	✓
FSR In front Cafe madeleine pantry	1	✓
AV room (Ballroom 2nd floor)	1	✓
Engineer Workshop (Carpark B1)	1	✓
Engineer Chemical store (Carpark B1)	1	✓
In front the Bottled Water Factory (Carpark B2)	1	✓
Water Factory (Carpark B2)	2	✓
Waitting for refill	2	✓
Spare (Store Security)	-	-
Total	**41**	

Checked by

DIRECTOR SECURITY

Date 27/12/2024

FIRE EXTINGUISHER (TYPE K) and FIRE BLANKET

LOCATON	WET CHEMICAL		FIRE BLANKET		REMARK
	AVAILABLE	STATUS	AVAILABLE	STATUS	
Ballroom Kitchen	3	✓	2	✓	
Conservatory Kitchen	3	✓	2	✓	
B/P Kitchen	3	✓	1	✓	
RIVA Kitchen	3	✓	2	✓	
BKK Kitchen	2	✓	2	✓	
YTY Kitchen	2	✓	1	✓	
MAIN Kitchen	1	✓	-	-	
BAKERRY Kitchen	1	✓	-	-	
GRILL ROOM Kitchen	1	✓	-	-	
IRD Kitchen	1	✓	1	✓	
SOI 64 Kitchen	-	-	1	✓	
Riverfront Kitchen	3	✓	2	✓	
The lounge	-	-	1	✓	
Fire cart No.1	-	-	-	-	
Fire cart No.2 set up H/S 9,10 (B1)	-	-	1	✓	**Fire blanket for EV vehicles fire protection**
Sky Lounge FSR	-	-	1	✓	
Cabinet of ammunition No.1 (H/S 1/2)	-	-	-	-	
Cabinet of ammunition No.2(H/S 7/8)	-	-	-	-	
Cabinet of ammunition No.3(H/S 9/10)	-	-	-	-	
Cabinet of ammunition No.4 Residence	-	-	-	-	
Store Room B2	-	-	2	✓	
TOTAL	**23**		**19**		

Checked By

DIRECTOR SECURITY .....

Date 27/12/2024

FIRE EXTINGUSHER RESIDENCES CHECK LIST

LOCATION	DRY	CO2	NOTE	DATE
		ROOFTOP		
FHC	-	2		
		FLOOR 69		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	1		
		FLOOR 68		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 67		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	Embrassy's Unit	
		FLOOR 66		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1	Embrassy's Unit	
		FLOOR 65		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 64		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 63		
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 62		
FHC No.1 RST.2	-	-	Under construction	
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 61		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 60		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 59		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 58		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 57		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
		FLOOR 56		
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		

FLOOR 55				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 54				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 53				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 52				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 51				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 50				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 49				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 48				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 47				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 46				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR45				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 43				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 42				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 41				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
Fire Pump Room	1	-		
FLOOR 40				
FHC No.1 RST.2	1	1		

FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 39				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 38				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR37				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 36				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 35				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 34				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 32				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 31				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 30				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 29				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 28				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 27				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 26				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 25				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 24				

FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 22				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 21				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 20				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 19				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 18				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 17				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 16				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 15				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 14				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12 A				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 12				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.3	1	1		
FLOOR 11				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 10				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 9				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	-	-		

FLOOR 8				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 7				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 6				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 5				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 4				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR 3				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Facility Office	1	-		
FLOOR 2				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FLOOR L				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 OFFICE AREA	1	1		
FHC No.5 B/Q STORE	1	-		
FLOOR LL				
FHC No.1 RST.2	1	1		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	1		
FHC No.4 Pet Grooming	1	-		
FHC No.5 ยังหาตู้ไม่เจอ	1	-		
FHC No.6 ENG Office	1	-		
FHC No.7 Loading area	2	-		
FLOOR B1				
FHC No.1 RST.2	1	-		
FHC No.2 FML	1	-		
FHC No.3 RST.1	1	-		
FHC No.4 Door2	1	-		
FHC No.5 B1C Pillar A13	1	-		
FHC No.6 B1C Pillar F14	1	-		
FHC No.7 B1C Pillar M14	1	-		
FHC No.8 Fanroom	1	-		
Total	**223**	**140**		

FHC IN ROOM GUEST	
Unit Number	Floor
5	70-71
11	66-67
26	62-63
27	60-61
28	60-61

ALL FIRE EXTINGUSHER		
LOCATION	**DRY CHEMICAL**	**CO2**
HOTEL	204	39
RESIDENCE	225	140
Total	429	179

324	10-11
Total 6 Rooms.	

Checked by .

DIRECTOR SECURITY....