

ภาคผนวก จ

Pool Daily Check List

POOL DAILY CHECK LIST



Travelodge

SUKHUMVIT 11

MONTH/YEAR: 1-31 / 7/2024

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1	3.0	7.2	15	✓	✓	✓	✓	Ni	1.5	7.2	✓	✓	✓	✓	✓	Ni
2	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	Beer
3	3.0	7.2	11	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
4	3.0	7.2	15	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Beer
5	3.0	7.2	11	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Beer
6	3.0	7.2	10	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Beer
7	3.0	7.2	12	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Ni
8	3.0	7.2	15	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	Ni
9	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	Beer
10	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Beer
11	3.0	7.2	12	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
12	3.0	7.2	10	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
13	3.0	7.2	12	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
14	3.0	7.2	11	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Ni
15	3.0	7.2	15	✓	✓	✓	✓	Ni	1.5	7.2	✓	✓	✓	✓	✓	Ni
16	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	Beer
17	3.0	7.2	12	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Beer
18	3.0	7.2	15	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
19	3.0	7.2	12	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
20	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Beer
21	3.0	7.2	11	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Ni
22	3.0	7.2	15	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	Ni
23	3.0	7.2	10	✓	✓	✓	✓	Ni	0.6	7.2	✓	✓	✓	✓	✓	Beer
24	3.0	7.2	13	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
25	3.0	7.2	15	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
26	3.0	7.2	12	✓	✓	✓	✓	Beer	1.0	7.2	✓	✓	✓	✓	✓	Beer
27	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Beer
28	3.0	7.2	10	✓	✓	✓	✓	Beer	1.5	7.2	✓	✓	✓	✓	✓	Ni
29	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	Ni
30	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	Ni
31	3.0	7.2	10	✓	✓	✓	✓	Ni	1.0	7.2	✓	✓	✓	✓	✓	mon

REMARK

Verified by Chief Engineer

Date

31 / 7 / 24

POOL DAILY CHECK LIST




MONTH/YEAR: Aug-24

SUKHUMVIT 11

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1	8.0	7.2	15	✓	✓	✓	✓	mon	0.5	7.2	✓	✓	✓	✓	✓	Bea
2	3.0	7.2	13	✓	✓	✓	✓	Bea	0.5	7.2	✓	✓	✓	✓	✓	Bea
3	3.0	7.2	12	✓	✓	✓	✓	Bea	1.0	7.2	✓	✓	✓	✓	✓	Bea
4	3.0	7.2	13	✓	✓	✓	✓	Bea	1.0	7.2	✓	✓	✓	✓	✓	mon
5	3.0	7.2	13	✓	✓	✓	✓	mon	0.5	7.2	✓	✓	✓	✓	✓	mon
6	3.0	7.2	12	✓	✓	✓	✓	mon	0.5	7.2	✓	✓	✓	✓	✓	mon
7	3.0	7.2	13	✓	✓	✓	✓	mon	0.4	7.2	✓	✓	✓	✓	✓	mon
8	3.0	7.2	13	✓	✓	✓	✓	mon	0.2	7.2	12	✓	✓	✓	✓	To
9	3.0	7.2	12	✓	✓	✓	✓	To	0.2	7.2	10	✓	✓	✓	✓	To
10	3.0	7.2	12	✓	✓	✓	✓	To	0.2	7.2	12	✓	✓	✓	✓	mon
11	3.0	7.2	12	✓	✓	✓	✓	mon	0.5	7.2	10	✓	✓	✓	✓	mon
12	3.0	7.2	13	✓	✓	✓	✓	mon	0.5	7.2	12	✓	✓	✓	✓	mon
13	3.0	7.2	12	✓	✓	✓	✓	mon	0.5	7.2	13	✓	✓	✓	✓	mon
14	3.0	7.2	12	✓	✓	✓	✓	mon	0.5	7.2	12	✓	✓	✓	✓	mon
15	3.0	7.2	12	✓	✓	✓	✓	mon	0.2	7.2	18	✓	✓	✓	✓	To
16	3.0	7.2	12	✓	✓	✓	✓	To	0.2	7.2	12	✓	✓	✓	✓	To
17	3.0	7.2	12	✓	✓	✓	✓	To	0.1	7.2	12	✓	✓	✓	✓	mon
18	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	12	✓	✓	✓	✓	mon
19	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	13	✓	✓	✓	✓	mon
20	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	13	✓	✓	✓	✓	mon
21	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	13	✓	✓	✓	✓	mon
22	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	12	✓	✓	✓	✓	To
23	3.0	7.2	12	✓	✓	✓	✓	To	0.2	7.2	12	✓	✓	✓	✓	To
24	3.0	7.2	12	✓	✓	✓	✓	To	0.1	7.2	12	✓	✓	✓	✓	mon
25	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	12	✓	✓	✓	✓	mon
26	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	12	✓	✓	✓	✓	mon
27	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	12	✓	✓	✓	✓	mon
28	3.0	7.2	12	✓	✓	✓	✓	mon	0.1	7.2	12	✓	✓	✓	✓	mon
29	3.0	7.2	12	✓	✓	✓	✓	mon	0.2	7.2	12	✓	✓	✓	✓	To
30	3.0	7.2	12	✓	✓	✓	✓	To	0.2	7.2	12	✓	✓	✓	✓	To
31	3.0	7.2	12	✓	✓	✓	✓	To	0.1	7.2	12	✓	✓	✓	✓	mon

REMARK _____

Verified by Chief Engineer  Date 31/8/67

POOL DAILY CHECK LIST



Travelodge

SUKHUMVIT 11

MONTH/YEAR:

Sep-24

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1	3.0	7.2	12	✓	✓	✓	✓	MON	0.1	7.2	12	✓	✓	✓	✓	MON
2	3.0	7.2	12	✓	✓	✓	✓	MON	0.1	7.2	10	✓	✓	✓	✓	MON
3	3.0	7.2	12	✓	✓	✓	✓	MON	0.0	7.2	12	✓	✓	✓	✓	To
4	3.0	7.2	12	✓	✓	✓	✓	To	1.5	7.2	12	✓	✓	✓	✓	To
5	3.0	7.2	12	✓	✓	✓	✓	To	1.5	7.2	12	✓	✓	✓	✓	To
6	3.0	7.2	12	✓	✓	✓	✓	To	1.5	7.2	14	✓	✓	✓	✓	To
7	3.0	7.2	12	✓	✓	✓	✓	To	1.0	7.2	14	✓	✓	✓	✓	Change
8	3.0	7.2	12	✓	✓	✓	✓	Change	0.0	7.2	14	✓	✓	✓	✓	Cham
9	3.0	7.2	12	✓	✓	✓	✓	Cham	0.2	7.2	18	✓	✓	✓	✓	Change
10	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	18	✓	✓	✓	✓	Change
11	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	18	✓	✓	✓	✓	Change
12	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	18	✓	✓	✓	✓	To
13	3.0	7.2	12	✓	✓	✓	✓	To	3.0	7.2	18	✓	✓	✓	✓	To
14	3.0	7.2	12	✓	✓	✓	✓	To	0.2	7.2	18	✓	✓	✓	✓	Change
15	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	14	✓	✓	✓	✓	Cham
16	3.0	7.2	12	✓	✓	✓	✓	Change	0.6	7.2	18	✓	✓	✓	✓	Cham
17	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	14	✓	✓	✓	✓	Change
18	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	18	✓	✓	✓	✓	Change
19	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	18	✓	✓	✓	✓	To
20	3.0	7.2	12	✓	✓	✓	✓	To	0.2	7.2	18	✓	✓	✓	✓	To
21	3.0	7.2	12	✓	✓	✓	✓	To	1.0	7.2	18	✓	✓	✓	✓	Change
22	3.0	7.2	12	✓	✓	✓	✓	Change	0.6	7.2	18	✓	✓	✓	✓	Change
23	3.0	7.2	12	✓	✓	✓	✓	Change	1.0	7.2	18	✓	✓	✓	✓	Change
24	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	18	✓	✓	✓	✓	Change
25	3.0	7.2	12	✓	✓	✓	✓	Change	1.0	7.2	18	✓	✓	✓	✓	Change
26	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	14	✓	✓	✓	✓	Cham
27	3.0	7.2	12	✓	✓	✓	✓	Change	0.2	7.2	14	✓	✓	✓	✓	To
28	3.0	7.2	12	✓	✓	✓	✓	To	1.5	7.2	12	✓	✓	✓	✓	To
29	3.0	7.2	12	✓	✓	✓	✓	To	1.5	7.2	18	✓	✓	✓	✓	Change
30	3.0	7.2	12	✓	✓	✓	✓	Change	1.5	7.2	18	✓	✓	✓	✓	Change
31																

REMARK

Verified by Chief Engineer

[Signature]

Date

20/9/69

POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR: Oct-24

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1	3.0	7.2	12	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
2	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
3	3.0	7.2	12	/	/	/	/	Chang	3.0	7.5	14	/	/	/	/	To
4	3.0	7.5	12	/	/	/	/	To	3.0	7.5	14	/	/	/	/	To
5	3.0	7.5	12	/	/	/	/	To	3.0	7.2	15	/	/	/	/	Ni
6	3.0	7.5	15	/	/	/	/	Ni	1.5	7.2	20	/	/	/	/	Ni
7	3.0	7.2	15	/	/	/	/	Ni	0.2	7.2	12	/	/	/	/	To
8	3.0	7.2	12	/	/	/	/	To	3.0	7.2	12	/	/	/	/	To
9	3.0	7.2	12	/	/	/	/	To	3.0	7.2	12	/	/	/	/	To
10	3.0	7.2	12	/	/	/	/	To	3.0	7.5	12	/	/	/	/	To
11	3.0	7.5	14	/	/	/	/	To	3.0	7.2	14	/	/	/	/	To
12	3.0	7.5	12	/	/	/	/	To	3.0	7.2	18	/	/	/	/	Chang
13	3.0	7.2	12	/	/	/	/	Chang	3.0	7.2	18	/	/	/	/	Chang
14	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
15	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
16	3.0	7.2	12	/	/	/	/	Chang	3.0	7.2	18	/	/	/	/	Chang
17	3.0	7.2	12	/	/	/	/	Chang	3.0	7.2	15	/	/	/	/	Ni
18	3.0	7.2	15	/	/	/	/	Ni	1.0	7.2	16	/	/	/	/	Ni
19	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	15	/	/	/	/	Ni
20	3.0	7.2	16	/	/	/	/	Ni	1.5	7.2	18	/	/	/	/	Ni
21	3.0	7.2	15	/	/	/	/	Ni	0.2	7.6	14	/	/	/	/	To
22	3.0	7.2	14	/	/	/	/	To	3.0	7.2	12	/	/	/	/	To
23	3.0	7.2	14	/	/	/	/	To	3.0	7.2	14	/	/	/	/	To
24	3.0	7.2	14	/	/	/	/	To	3.0	7.2	12	/	/	/	/	To
25	3.0	7.2	14	/	/	/	/	To	3.0	7.2	12	/	/	/	/	To
26	3.0	7.2	16	/	/	/	/	To	3.0	7.2	15	/	/	/	/	Ni
27	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	15	/	/	/	/	Ni
28	3.0	7.2	15	/	/	/	/	Ni	1.0	7.2	15	/	/	/	/	Ni
29	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	16	/	/	/	/	To
30	3.0	7.2	15	/	/	/	/	To	1.5	7.2	12	/	/	/	/	To
31	3.0	7.2	12	/	/	/	/	To	3.0	7.2	14	/	/	/	/	To

REMARK

Verified by Chief Engineer Pari

Date 31/10/69

POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

Nov-24

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/11/67	3.0	7.2	14	/	/	/	/	To	3.0	7.2	14	/	/	/	/	To
2/11/67	3.0	7.2	12	/	/	/	/	To	3.0	7.2	15	/	/	/	/	Ni
3/11/67	3.0	7.2	15	/	/	/	/	Ni	1.0	7.2	15	/	/	/	/	Ni
4/11/67	3.0	7.2	12	/	/	/	/	Ni	1.0	7.2	15	/	/	/	/	Ni
5/11/67	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	18	/	/	/	/	Chang
6/11/67	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
7/11/67	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	15	/	/	/	/	Ni
8/11/67	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	15	/	/	/	/	Ni
9/11/67	3.0	7.2	12	/	/	/	/	Ni	1.5	7.2	12	/	/	/	/	Ni
10/11/67	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	15	/	/	/	/	Ni
11/11/67	3.0	7.2	12	/	/	/	/	Ni	1.5	7.2	10	/	/	/	/	Mon
12/11/67	3.0	7.2	12	/	/	/	/	Mon	1.5	7.2	12	/	/	/	/	Mon
13/11/67	3.0	7.2	12	/	/	/	/	Mon	0.5	7.2	13	/	/	/	/	Mon
14/11/67	3.0	7.2	10	/	/	/	/	Mon	0.2	7.2	12	/	/	/	/	To
15/11/67	3.0	7.2	12	/	/	/	/	To	3.0	7.2	15	/	/	/	/	Ni
16/11/67	3.0	7.2	12	/	/	/	/	Ni	1.5	7.2	15	/	/	/	/	Ni
17/11/67	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	15	/	/	/	/	Ni
18/11/67	3.0	7.2	12	/	/	/	/	Ni	1.0	7.2	15	/	/	/	/	Ni
19/11/67	3.0	7.2	15	/	/	/	/	Ni	1.0	7.2	18	/	/	/	/	Chang
20/11/67	3.0	7.2	12	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
21/11/67	3.0	7.2	12	/	/	/	/	Chang	3.0	7.2	16	/	/	/	/	Ni
22/11/67	3.0	7.2	12	/	/	/	/	Ni	1.0	7.2	15	/	/	/	/	Ni
23/11/67	3.0	7.2	15	/	/	/	/	Ni	1.0	7.2	18	/	/	/	/	Ni
24/11/67	3.0	7.2	12	/	/	/	/	Ni	1.0	7.2	15	/	/	/	/	Ni
25/11/67	3.0	7.2	15	/	/	/	/	Ni	1.0	7.2	18	/	/	/	/	Ni
26/11/67	3.0	7.2	12	/	/	/	/	Ni	1.0	7.2	18	/	/	/	/	Chang
27/11/67	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
28/11/67	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	15	/	/	/	/	Ni
29/11/67	3.0	7.2	15	/	/	/	/	Ni	1.5	7.2	12	/	/	/	/	Ni
30/11/67	3.0	7.2	15	/	/	/	/	Ni	1.0	7.2	15	/	/	/	/	Ni
1/12/67																

REMARK

Verified by Chief Engineer

Date

30/11/67

MONTH/YEAR:

Dec 24
Nov-24

POOL DAILY CHECK LIST



Travelodge

SUKHUMVIT II

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/12/67	3.0	7.2	15	✓	✓	✓	✓	Ni	1.0	7.2	18	✓	✓	✓	✓	Ni
2/12/67	3.0	7.2	14	✓	✓	✓	✓	Ni	1.0	7.2	15	✓	✓	✓	✓	Ni
3/12/67	3.0	7.2	15	✓	✓	✓	✓	Ni	1.5	7.2	20	✓	✓	✓	✓	Beer
4/12/67	3.0	7.2	15	✓	✓	✓	✓	Beer	1.5	7.2	15	✓	✓	✓	✓	Beer
5/12/67	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	12	✓	✓	✓	✓	Beer
6/12/67	3.0	7.2	15	✓	✓	✓	✓	Beer	1.5	7.2	15	✓	✓	✓	✓	Beer
7/12/67	3.0	7.2	15	✓	✓	✓	✓	Beer	1.5	7.2	20	✓	✓	✓	✓	Beer
8/12/67	3.0	7.2	14	✓	✓	✓	✓	Beer	3.0	7.2	12	✓	✓	✓	✓	Ni
9/12/67	3.0	7.2	14	✓	✓	✓	✓	Ni	1.0	7.2	16	✓	✓	✓	✓	Ni
10/12/67	3.0	7.2	12	✓	✓	✓	✓	Ni	3.0	7.2	15	✓	✓	✓	✓	Beer
11/12/67	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.3	13	✓	✓	✓	✓	Beer
12/12/67	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	15	✓	✓	✓	✓	Beer
13/12/67	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	20	✓	✓	✓	✓	Beer
14/12/67	3.0	7.2	12	✓	✓	✓	✓	Beer	1.5	7.2	18	✓	✓	✓	✓	Beer
15/12/67	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	15	✓	✓	✓	✓	Ni
16/12/67	3.0	7.2	15	✓	✓	✓	✓	Ni	1.5	7.2	18	✓	✓	✓	✓	Ni
17/12/67	3.0	7.2	13	✓	✓	✓	✓	Ni	1.5	7.2	16	✓	✓	✓	✓	Beer
18/12/67	3.0	7.2	14	✓	✓	✓	✓	Beer	1.5	7.2	19	✓	✓	✓	✓	Beer
19/12/67	3.0	7.2	12	✓	✓	✓	✓	Beer	1.5	7.2	16	✓	✓	✓	✓	Beer
20/12/67	3.0	7.2	14	✓	✓	✓	✓	Beer	1.5	7.2	15	✓	✓	✓	✓	Beer
21/12/67	3.0	7.2	15	✓	✓	✓	✓	Beer	1.5	7.2	16	✓	✓	✓	✓	Beer
22/12/67	3.0	7.2	12	✓	✓	✓	✓	Beer	1.5	7.2	15	✓	✓	✓	✓	Ni
23/12/67	3.0	7.2	15	✓	✓	✓	✓	Ni	1.5	7.2	15	✓	✓	✓	✓	Ni
24/12/67	3.0	7.2	12	✓	✓	✓	✓	Ni	1.5	7.2	15	✓	✓	✓	✓	Beer
25/12/67	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	16	✓	✓	✓	✓	Beer
26/12/67	3.0	7.2	11	✓	✓	✓	✓	Beer	1.5	7.2	12	✓	✓	✓	✓	Beer
27/12/67	3.0	7.2	13	✓	✓	✓	✓	Beer	1.5	7.2	12	✓	✓	✓	✓	Beer
28/12/67	3.0	7.2	13	✓	✓	✓	✓	Beer	3.0	7.2	12	✓	✓	✓	✓	Ni
29/12/67	3.0	7.2	13	✓	✓	✓	✓	Ni	1.0	7.2	20	✓	✓	✓	✓	Ni
30/12/67	3.0	7.2	13	✓	✓	✓	✓	Ni	1.0	7.2	15	✓	✓	✓	✓	Ni
31/12/67	3.0	7.2	15	✓	✓	✓	✓	Ni	0.5	7.2	16	✓	✓	✓	✓	Beer

REMARK

Verified by Chief Engineer

Date

31/12/67