

Report for Sample Analysis

CUSTOMER NAME : นิติบุคคลอาคารชุด ไอดีโอ สุขุมวิท 115

ADDRESS : 234 ม.4 ต.เทพารักษ์ อ.เมืองสมุทรปราการ จ.สมุทรปราการ 10270

CONTACT DETAILS : คุณ สุรัชย์ TEL: 064 983 6659 E-mail: Nitiideo.s115@gmail.com

SAMPLING SOURCE : นิติบุคคลอาคารชุด ไอดีโอ สุขุมวิท 115

SAMPLE TYPE/NAME : Waste Water

REPORT NO. : JEX-Ww-25-J0523

SAMPLING DATE : March 21, 2025

RECEIVED DATE : March 22, 2025

SAMPLING TIME : 10.30 Hour

ANALYTICAL DATE : March 22 – April 1, 2025

SAMPLING METHOD : Sampling by Customer

QUOTATION NO. : QL/24/0689/SW/Pw

SAMPLING BY : Sampling by Customer

WORK NO. : Ww-25-J1144

PARAMETERS	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			Influent	
BOD	mg/l	5-Day BOD Test, Azide Modification Method	102.0	-
Grease and Oil	mg/l	Liquid-Liquid, Partition-Gravimetric Method	<LOQ (5.0)	-
pH	-	Electrometric Method	6.3 (25°C)	-
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105°C	805.0	-
Settleable Solids	mg/l	Imhoff cone	100.0	-
Sulfide	mg/l	Iodometric Method	1.33	-
TKN	mg/l	Semi-Micro Kjeldahl Method	42.3	-
Total Dissolved Solids	mg/l	Total Dissolved Solids Dried at 180°C	305	-
Total Coliform Bacteria*	MPN/100ml	Multiple Tube Fermentation Technique	92,000	-
SAMPLE CONDITION			Sample Color / Turbid : Yellow / Turbid	
			Sediment : Black	

Reference: Base on Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th ed. Washington, 2023

Standard: Notification of the Ministry of Natural Resources and Environment, Subject: Establish control standards Drainage of wastewater from certain types and buildings of certain sizes, dated June 28, 2024, announced in the Government Gazette, Volume 141, Chapter 233 D, dated 27 August 2024.

Definition *: The test was subcontracted to another laboratory

Remark: *Bold-Italic* number meaning the value out of regulatory standard range

Laboratory Manager: _____

(Dr. Angsana Romsaiyud)

ว-295-ค-0002

ห้องปฏิบัติการวิเคราะห์เอกชน : ทะเบียนเลขที่ ว-295

Remark: 1) The above results are valid only for the analyzed / tested sample (s) as indicated in this report only.

2) Do not copy partial of this analysis report without official approval.

Report for Sample Analysis

CUSTOMER NAME : นิติบุคคลอาคารชุด ไอดีโอ สุขุมวิท 115
ADDRESS : 234 ม.4 ต.เทพารักษ์ อ.เมืองสมุทรปราการ จ.สมุทรปราการ 10270
CONTACT DETAILS : คุณ สุรัชย์ TEL: 064 983 6659 E-mail: Nitiideo.s115@gmail.com
SAMPLING SOURCE : นิติบุคคลอาคารชุด ไอดีโอ สุขุมวิท 115
SAMPLE TYPE/NAME : Waste Water REPORT NO. : JEX-Ww-25-J0523
SAMPLING DATE : March 21, 2025 RECEIVED DATE : March 22, 2025
SAMPLING TIME : 10.30 Hour ANALYTICAL DATE : March 22 – April 1, 2025
SAMPLING METHOD : Sampling by Customer QUOTATION NO. : QL/24/0689/SW/Pw
SAMPLING BY : Sampling by Customer WORK NO. : Ww-25-J1145

PARAMETERS	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			Effluent	
BOD	mg/l	5-Day BOD Test, Azide Modification Method	10.2	≤ 20
Grease and Oil	mg/l	Liquid-Liquid, Partition-Gravimetric Method	<LOQ (5.0)	≤ 20.0
pH	-	Electrometric Method	6.6 (025°C)	5.5-9.0
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105°C	11.4	≤ 30
Settleable Solids	mg/l	Imhoff cone	<0.1	-
Sulfide	mg/l	Iodometric Method	<LOQ (1.0)	≤ 1.0
TKN	mg/l	Semi-Micro Kjeldahl Method	<LOQ (4.0)	≤ 35
Total Dissolved Solids	mg/l	Total Dissolved Solids Dried at 180°C	328	≤ 1,000
Total Coliform Bacteria*	MPN/100ml	Multiple Tube Fermentation Technique	13,000	-
SAMPLE CONDITION			Sample Color / Turbid : Yellow / Clear Sediment : Black	


Reference: Base on Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th ed. Washington, 2023

Standard: Notification of the Ministry of Natural Resources and Environment, Subject: Establish control standards Drainage of wastewater from certain types and buildings of certain sizes, dated June 28, 2024, announced in the Government Gazette, Volume 141, Chapter 233 D, dated 27 August 2024.

Definition *: The test was subcontracted to another laboratory

Remark: *Bold-Italic* number meaning the value out of regulatory standard range

Laboratory Manager:


(Dr. Angsana Romsaiyud)
จ-295-ค-0002

ห้องปฏิบัติการวิเคราะห์เอกชน : ทะเบียนเลขที่ จ-295

Remark: 1) The above results are valid only for the analyzed / tested sample (s) as indicated in this report only.
2) Do not copy partial of this analysis report without official approval.

Figure of sample

1. Influent



2. Effluent



Laboratory Manager: _____

(Dr. Angsana Romsaiyud)

ว-295-ค-0002

ห้องปฏิบัติการวิเคราะห์เอกชน : ทะเบียนเลขที่ ว-295

Remark: 1) The above results are valid only for the analyzed / tested sample (s) as indicated in this report only.
2) Do not copy partial of this analysis report without official approval.