

ผลวิเคราะห์คุณภาพน้ำสระว่ายน้ำโครงการ KANTARY HOTEL (บางปะกง)



บริษัท ศูนย์วิเคราะห์น้ำ จำกัด
WATER ANALYSIS CENTER COMPANY LIMITED

1/94 หมู่ 5 ต. คานหาม อ. สุทัย จ. พระนครศรีอยุธยา 13210
 1/94 Moo 5, T.Kanhnam, A.U-Thai, Ayutthaya 13210, Thailand
 Tel : 035-226-383 , 035-800-593 Fax : 035-800-594

ANALYSIS REPORT

Page 1 of 1

Customer Name : KALEIDOSCOPE PROPERTIES CO.,LTD

Address : 828, 828/1-2, 444/4-5 MOO 5 KHLONG TAMRU MUEANG CHONBURI CHONBURI 20000

Contact :- **Phone** :- **E.mail** :-

Sample Type : Water **Sample Site** : KANTARY HOTEL AMATA BANGPAKONG **Sampling Method** : Grab

Sampling Date : 26/02/2025 **Sampling By** : Customer **Receive Date** : 28/02/2025

Analysis Date : 28/02/2025-05/03/2025 **Report Date** : 05/03/2025 **Report No.** : RWS 00603/68

Parameter	Unit	Method	PWS 01230/68 Swimming Pool (deep zone)	PWS 01231/68 Swimming Pool (shallow zone)	Standard *
Total Coliform Bacteria	MPN/100 mL	Standard Total Coliform Fermentation	< 1.1	< 1.1	< 10
Fecal Coliform Bacteria	MPN/100 mL	Thermotolerant (Fecal) Coliform Procedure	Not Detected	Not Detected	Not Detected
Sample Characterization			Observation	Clear	Clear

Remark : * Reference to the Public Health Committee No. 1/2007 regarding the control of swimming pool business, or other businesses in the same way
 Detection Limit : Fecal Coliform Bacteria < 1.1 MPN/100 mL

- End Of Report -

Laboratory Staff สาธิต
 (Miss. Ronnakorn Padungwieng)
 Chemist

Approved By (Signature)
 (Mrs. Neeramol Phadungsong)
 General Manager

The results relate only to the items tested. Test report shall not be reproduced except in full, without written approval of the laboratory
 FO.LAB 7.8.1/1 รายงานผลการทดสอบ

แก้ไขครั้งที่ 0, วันที่บังคับใช้ : 1 ม.ค. 2562 หน้า 1/1



United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

ANALYSIS REPORT

CUSTOMER NAME : KALEIDESCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasernkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS KEWALEE SUKHAREE
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-16, 2025
ISSUE DATE : JUNE 24, 2025
REPORT NO. : 2025-U055320
WORK NO. : 2025-003562
ANALYSIS NO. : T25A0873-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			SWIMMING POOL (SHALLOW ZONE) T25AJ873-0001		
pH ^A	-	ELECTROMETRIC METHOD (SM: PART 4500 -H ⁺ B)	7.3 (25°C)	-	-
AMMONIA	mg/L NH ₃	PHENATE METHOD (SM: PART 4500-NH ₃ F)	0.17	0.04	0.15
NITRATE	mg/L NO ₃ ⁻	CADMIUM REDUCTION METHOD (SM: PART 4500-NO ₃ ⁻ E)	54.9	0.09	0.50
CHLORIDE	mg/L Cl ⁻	ARGENTOMETRIC METHOD (SM: 4500-Cl ⁻ B)	650	0.5	2.0
TOTAL ALKALINITY ^A	mg/L as CaCO ₃	TITRATION METHOD (SM: PART 2320 B)	65.9	-	-
FREE CHLORINE ^A	mg/L Cl ₂	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	1.0	0.1	-
CALCIUM HARDNESS	mg/L as CaCO ₃	EDTA TITRIMETRIC METHOD (SM: PART 3500-Ca B)	295	1.0	4.0
COMBINED CHLORINE ^A	mg/L Cl ₂	DPD FERROUS TITRIMETRIC METHOD (SM: PART 4500-Cl F)	0.4	0.1	0.4
CYANURIC ACID	mg/L	TURBIDIMETRIC METHOD	72	1	5
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -		

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

^A : SAMPLING ON JUNE 4, 2025, ANALYSIS NO. T25AM098-0001 (ANALYTICAL DATE : JUNE 5-12, 2025).

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY NOT SHOWING REGULATORY STANDARD.
SUBSTITUTED REPORT FOR REPORT NO. 2025-U053088, ISSUE DATE JUNE 13, 2025.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR



• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : KALEIDOSCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS CHATTRAPORN RATCHANET
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-13, 2025
ISSUE DATE : JUNE 23, 2025
REPORT NO. : 2025-U05325
WORK NO. : 2025-003562
ANALYSIS NO. : T25AJ873-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AJ873-0001		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NONE*	1.1
<i>E. coli</i> ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C, E AND F)	< 1.1	NOT DETECTED	1.1
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
<i>Staphylococcus aureus</i> ^c	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIKTAL TO HEALTH, B.E. 2530 (1987).

* : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY ADDING *Staphylococcus aureus*.
SUBSTITUTED REPORT FOR REPORT NO. 2025-U053088, ISSUE DATE JUNE 13, 2025.

Chaweevan B.

(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



ISO 9001
Quality
Management
Systems
CERTIFIED

ISO 14001
Environmental
Management
CERTIFIED

ISO 45001
Occupational
Health and Safety
Management
CERTIFIED

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -



United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

ANALYSIS REPORT

CUSTOMER NAME : KALEIDSCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS KEWALEE SUKHAREE
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-16, 2025
ISSUE DATE : JUNE 24, 2025
REPORT NO. : 2025-U055328
WORK NO. : 2025-003562
ANALYSIS NO. : T25A873-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			SWIMMING POOL (DEEP ZONE) T25AJ873-0002		
pH ^A	-	ELECTROMETRIC METHOD (SM: PART 4500 -H+ B)	7.3 (25°C)	-	-
AMMONIA	mg/L NH ₃	PHENATE METHOD (SM: PART 4500-NH ₃ F)	0.15	0.04	0.15
NITRATE	mg/L NO ₃ ⁻	CADMIUM REDUCTION METHOD (SM: PART 4500-NO ₃ ⁻ E)	56.3	0.09	0.50
CHLORIDE	mg/L Cl ⁻	ARGENTOMETRIC METHOD (SM: 4500-Cl ⁻ B)	636	0.5	2.0
TOTAL ALKALINITY ^A	mg/L as CaCO ₃	TITRATION METHOD (SM: PART 2320 B)	67.0	-	-
FREE CHLORINE ^A	mg/L Cl ₂	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	1.0	0.1	-
CALCIUM HARDNESS	mg/L as CaCO ₃	EDTA TITRIMETRIC METHOD (SM: PART 3500-Ca B)	293	1.0	4.0
COMBINED CHLORINE ^A	mg/L Cl ₂	DPD FERROUS TITRIMETRIC METHOD (SM: PART 4500-Cl F)	< 0.4	0.1	0.4
CYANURIC ACID	mg/L	TURBIDIMETRIC METHOD	71	1	5
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -		

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

^A : SAMPLING ON JUNE 4, 2025, ANALYSIS NO. T25AM098-0002 (ANALYTICAL DATE : JUNE 5-12, 2025).

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY NOT SHOWING REGULATORY STANDARD.
SUBSTITUTED REPORT FOR REPORT NO. 2025-U053089, ISSUE DATE JUNE 13, 2025.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR



- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : KALEIDOSCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS CHATRAPORN RATCHANET
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-13, 2025
ISSUE DATE : JUNE 23, 2025
REPORT NO. : 2025-U055331
WORK NO. : 2025-003562
ANALYSIS NO. : T25A3873-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AJ873-0002		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NONE*	1.1
<i>E. coli</i> ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C, E AND F)	< 1.1	NOT DETECTED	1.1
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
<i>Staphylococcus aureus</i> ^c	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

* : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY ADDING *Staphylococcus aureus*.

SUBSTITUTED REPORT FOR REPORT NO. 2025-U053089, ISSUE DATE JUNE 13, 2025.

Chaweevan B.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ISO 9001
Quality
Management
Systems
CERTIFIED

ISO 14001
Environmental
Management
CERTIFIED

ISO 45001
Occupational
Health and Safety
Management
CERTIFIED

- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1

- End of Analysis Report -



ตารางบันทึกค่าคลอรีน / pH

ตารางเติมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ	ปริมาณ	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH		คลอรีน	โซดาอช			
	เช้า	เย็น	เช้า	เย็น	(กรัม)	(กรัม)			
1/1/2568	3.0	3.0	7.4	7.4	-	-	ราชณิณี	✓	
2/1/2568	3.0	3.0	7.4	7.4	-	-	ราชณิณี	✓	
3/1/2568	3.0	2.0	7.4	7.4	-	-	ธีรชน	✓	
4/1/2568	1.5	0.0	7.4	7.4	500 กรัม	-	ธีรชน	✓	
5/1/2568	3.0	3.0	7.2	7.2	-	-	วราพร	✓	
6/1/2568	2.5	1.5	7.2	7.2	300 กรัม	-	ศิริวิมล	✓	
7/1/2568	3.0	3.0	7.2	7.2	-	-	ศิริวิมล	✓	
8/1/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วรวิทย์	✓	
9/1/2568	2.5	2.0	7.4	7.4	-	-	ราชณิณี	✓	
10/1/2568	1.0	0.0	7.4	7.4	500 กรัม	-	ธีรชน	✓	
11/1/2568	3.0	3.0	7.4	7.4	-	-	วราพร	✓	
12/1/2568	3.0	3.0	7.4	7.4	-	-	วราพร	✓	
13/1/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ศิริวิมล	✓	
14/1/2568	3.0	3.0	7.2	7.2	-	-	ศิริวิมล	✓	
15/1/2568	3.0	2.0	7.2	7.2	200 กรัม	-	วรวิทย์	✓	
16/1/2568	3.0	3.0	7.2	7.2	-	-	วรวิทย์	✓	
17/1/2568	3.0	2.5	7.2	7.2	-	-	ราชณิณี	✓	
18/1/2568	2.0	0.5	7.2	7.2	400 กรัม	-	ธีรชน	✓	
19/1/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ธีรชน	✓	
20/1/2568	2.5	2.0	7.4	7.4	-	-	วราพร	✓	
21/1/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ศิริวิมล	✓	
22/1/2568	3.0	3.0	7.4	7.4	-	-	วรวิทย์	✓	
23/1/2568	2.5	1.0	7.4	7.4	300 กรัม	-	วรวิทย์	✓	
24/1/2568	3.0	3.0	7.4	7.4	-	-	ราชณิณี	✓	
25/1/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ราชณิณี	✓	
26/1/2568	3.0	2.5	7.4	7.4	-	-	ธีรชน	✓	
27/1/2568	2.0	0.5	7.4	7.2	400 กรัม	-	ธีรชน	✓	
28/1/2568	3.0	2.5	7.2	7.2	-	2.0 กก.	วราพร	✓	
29/1/2568	3.0	3.0	7.4	7.4	-	-	ศิริวิมล	✓	
30/1/2568	3.0	3.0	7.4	7.4	-	-	ศิริวิมล	✓	
31/1/2568	3.0	2.0	7.4	7.4	-	-	วรวิทย์	✓	

ตารางเติมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ คลอรีน (กรัม)	ปริมาณ โซดาแอช (กรัม)	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH						
	เช้า	เย็น	เช้า	เย็น					
1/2/2568	1.5	0.0	7.4	7.4	500 กรัม	-	วรวิทย์	นันท	
2/2/2568	3.0	3.0	7.2	7.2	-	-	ราชันย์	นันท	
3/2/2568	2.5	1.5	7.2	7.2	300 กรัม	-	ราชันย์	นันท	
4/2/2568	3.0	3.0	7.2	7.2	-	-	วิธณ	นันท	
5/2/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วิธณ	นันท	
6/2/2568	2.5	2.0	7.4	7.4	-	-	วพช	นันท	
7/2/2568	1.0	0.0	7.4	7.4	500 กรัม	-	วพช	นันท	
8/2/2568	3.0	3.0	7.4	7.4	-	-	ศิริวิทย์	นันท	
9/2/2568	3.0	3.0	7.4	7.4	-	-	ศิริวิทย์	นันท	
10/2/2568	3.0	2.0	7.4	7.4	200 กรัม	-	พรณชัย	นันท	
11/2/2568	3.0	3.0	7.2	7.2	-	-	วรวิทย์	นันท	
12/2/2568	3.0	2.0	7.2	7.2	200 กรัม	-	ราชันย์	นันท	
13/2/2568	3.0	3.0	7.2	7.2	-	-	วิธณ	นันท	
14/2/2568	3.0	2.5	7.2	7.2	-	2.0 กก.	วพช	นันท	
15/2/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ศิริวิทย์	นันท	
16/2/2568	3.0	3.0	7.4	7.4	-	-	พรณชัย	นันท	
17/2/2568	2.5	2.0	7.4	7.4	-	-	วรวิทย์	นันท	
18/2/2568	2.0	0.5	7.4	7.4	400 กรัม	-	วรวิทย์	นันท	
19/2/2568	3.0	3.0	7.4	7.4	-	-	ราชันย์	นันท	
20/2/2568	2.5	1.0	7.4	7.4	300 กรัม	-	ราชันย์	นันท	
21/2/2568	3.0	3.0	7.4	7.4	-	-	วิธณ	นันท	
22/2/2568	2.0	0.5	7.4	7.2	400 กรัม	-	วพช	นันท	
23/2/2568	3.0	2.5	7.2	7.2	-	2.0 กก.	วพช	นันท	
24/2/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ศิริวิทย์	นันท	
25/2/2568	3.0	2.5	7.4	7.4	-	-	ศิริวิทย์	นันท	
26/2/2568	2.5	1.0	7.4	7.4	300 กรัม	-	พรณชัย	นันท	
27/2/2568	3.0	3.0	7.4	7.4	-	-	วรวิทย์	นันท	
28/2/2568	3.0	2.5	7.4	7.4	-	-	วรวิทย์	นันท	

ตารางเดิมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ	ปริมาณ	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH		คลอรีน	โซดาแอช			
	เข้า	เย็น	เข้า	เย็น	(กรัม)	(กรัม)			
1/3/2568	3.0	3.0	7.4	7.4	-	-	ราชฉวีพร.	นันท	
2/3/2568	2.5	1.5	7.2	7.2	300 กรัม	-	ราชฉวีพร.	นันท	
3/3/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วิรัช	นันท	
4/3/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
5/3/2568	2.5	2.0	7.4	7.4	-	-	วิรัช	นันท	
6/3/2568	1.0	0.0	7.4	7.4	500 กรัม	-	วิรัช	นันท	
7/3/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
8/3/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
9/3/2568	3.0	2.0	7.4	7.4	200 กรัม	-	วิรัช	นันท	
10/3/2568	3.0	3.0	7.4	7.4	-	-	ราชฉวีพร.	นันท	
11/3/2568	3.0	2.0	7.4	7.4	200 กรัม	-	วิรัช	นันท	
12/3/2568	3.0	3.0	7.2	7.2	-	-	วิรัช	นันท	
13/3/2568	3.0	2.5	7.2	7.2	-	-	วิรัช	นันท	
14/3/2568	2.0	0.5	7.2	7.2	400 กรัม	-	วิรัช	นันท	
15/3/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วิรัช	นันท	
16/3/2568	2.5	2.0	7.4	7.4	-	-	วิรัช	นันท	
17/3/2568	2.0	0.5	7.4	7.4	400 กรัม	-	วิรัช	นันท	
18/3/2568	3.0	3.0	7.4	7.4	-	-	ราชฉวีพร.	นันท	
19/3/2568	2.5	1.0	7.4	7.4	300 กรัม	-	วิรัช	นันท	
20/3/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
21/3/2568	2.0	0.5	7.4	7.4	400 กรัม	-	วิรัช	นันท	
22/3/2568	3.0	2.0	7.2	7.2	-	-	วิรัช	นันท	
23/3/2568	3.0	3.0	7.2	7.2	-	-	วิรัช	นันท	
24/3/2568	3.0	2.5	7.2	7.2	-	-	วิรัช	นันท	
25/3/2568	2.0	1.0	7.2	7.2	300 กรัม	-	วิรัช	นันท	
26/3/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วิรัช	นันท	
27/3/2568	2.0	1.0	7.4	7.4	300 กรัม	-	ราชฉวีพร.	นันท	
28/3/2568	3.0	2.5	7.4	7.4	-	-	วิรัช	นันท	
29/3/2568	2.5	1.0	7.4	7.4	300 กรัม	-	วิรัช	นันท	
30/3/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
31/3/2568	3.0	2.0	7.4	7.4	-	-	วิรัช	นันท	

ตารางเติมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ	ปริมาณ	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH		คลอรีน	โซดาแอซ			
	เช้า	เย็น	เช้า	เย็น	(กรัม)	(กรัม)			
1/4/2568	2.0	1.5	7.4	7.2	-	-	นริศ ชัย.	นริศ	
2/4/2568	1.5	0.0	7.2	7.2	500 กรัม	-	ราชันย์	นริศ	
3/4/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ราชันย์	นริศ	
4/4/2568	3.0	2.0	7.4	7.4	200 กรัม	-	วิรัช	นริศ	
5/4/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นริศ	
6/4/2568	3.0	3.0	7.2	7.2	-	-	นริศ	นริศ	
7/4/2568	2.0	1.0	7.2	7.2	300 กรัม	-	นริศ	นริศ	
8/4/2568	3.0	3.0	7.2	7.2	-	-	นริศ	นริศ	
9/4/2568	1.5	0.0	7.2	7.2	500 กรัม	-	นริศ	นริศ	
10/4/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	นริศ	นริศ	
11/4/2568	3.0	2.5	7.4	7.4	-	-	ราชันย์	นริศ	
12/4/2568	2.5	1.0	7.4	7.4	300 กรัม	-	วิรัช	นริศ	
13/4/2568	3.0	3.0	7.4	7.4	-	-	นริศ	นริศ	
14/4/2568	3.0	2.0	7.4	7.4	200 กรัม	-	นริศ	นริศ	
15/4/2568	3.0	2.0	7.4	7.4	-	-	นริศ	นริศ	
16/4/2568	3.0	2.0	7.4	7.4	-	-	นริศ	นริศ	
17/4/2568	3.0	2.0	7.4	7.2	-	-	นริศ	นริศ	
18/4/2568	3.0	2.0	7.2	7.2	-	2.0 กก.	นริศ	นริศ	
19/4/2568	2.0	1.0	7.4	7.4	300 กรัม	-	ราชันย์	นริศ	
20/4/2568	3.0	2.0	7.4	7.4	-	-	ราชันย์	นริศ	
21/4/2568	2.0	0.0	7.4	7.4	500 กรัม	-	วิรัช	นริศ	
22/4/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นริศ	
23/4/2568	3.0	2.0	7.4	7.4	-	-	วิรัช	นริศ	
24/4/2568	2.5	2.0	7.2	7.2	-	2.0 กก.	วิรัช	นริศ	
25/4/2568	2.0	0.5	7.4	7.4	400 กรัม	-	นริศ	นริศ	
26/4/2568	3.0	3.0	7.4	7.4	-	-	นริศ	นริศ	
27/4/2568	2.5	1.0	7.4	7.4	300 กรัม	-	นริศ	นริศ	
28/4/2568	3.0	3.0	7.4	7.4	-	-	ราชันย์	นริศ	
29/4/2568	2.0	0.5	7.4	7.4	400 กรัม	-	วิรัช	นริศ	
30/4/2568	3.0	2.5	7.2	7.2	-	-	วิรัช	นริศ	

ตารางเดิมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ	ปริมาณ	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH		คลอรีน	โซดาแอช			
	เช้า	เย็น	เช้า	เย็น	(กรัม)	(กรัม)			
1/5/2568	2.0	0.5	7.2	7.2	400 กรัม	-	วชิรณ.	นันท.	
2/5/2568	3.0	2.5	7.2	7.2	-	2.0 กก.	วชิรณ.	นันท.	
3/5/2568	2.5	1.0	7.2	7.2	300 กรัม	-	วชิรณ.	นันท.	
4/5/2568	3.0	3.0	7.4	7.4	-	-	วชิรณ.	นันท.	
5/5/2568	3.0	2.5	7.4	7.4	-	-	วชิรณ.	นันท.	
6/5/2568	2.0	1.5	7.4	7.4	-	-	วชิรณ.	นันท.	
7/5/2568	1.5	0.0	7.4	7.4	500 กรัม	-	วชิรณ.	นันท.	
8/5/2568	3.0	3.0	7.2	7.2	-	-	วชิรณ.	นันท.	
9/5/2568	3.0	3.0	7.2	7.2	-	-	วชิรณ.	นันท.	
10/5/2568	2.5	0.5	7.2	7.2	400 กรัม	-	วชิรณ.	นันท.	
11/5/2568	1.5	0.0	7.2	7.2	500 กรัม	-	วชิรณ.	นันท.	
12/5/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วชิรณ.	นันท.	
13/5/2568	2.5	1.5	7.4	7.4	300 กรัม	-	วชิรณ.	นันท.	
14/5/2568	3.0	3.0	7.4	7.4	-	-	วชิรณ.	นันท.	
15/5/2568	3.0	3.0	7.4	7.4	-	-	วชิรณ.	นันท.	
16/5/2568	2.5	2.0	7.4	7.4	-	-	วชิรณ.	นันท.	
17/5/2568	1.0	0.0	7.4	7.4	500 กรัม	-	วชิรณ.	นันท.	
18/5/2568	3.0	3.0	7.0	7.2	-	2.0 กก.	วชิรณ.	นันท.	
19/5/2568	3.0	3.0	7.4	7.4	-	-	วชิรณ.	นันท.	
20/5/2568	3.0	2.0	7.4	7.4	200 กรัม	-	วชิรณ.	นันท.	
21/5/2568	3.0	3.0	7.4	7.4	-	-	วชิรณ.	นันท.	
22/5/2568	3.0	2.0	7.2	7.2	200 กรัม	-	วชิรณ.	นันท.	
23/5/2568	3.0	3.0	7.2	7.2	-	-	วชิรณ.	นันท.	
24/5/2568	3.0	2.5	7.2	7.2	-	2.0 กก.	วชิรณ.	นันท.	
25/5/2568	2.0	0.5	7.2	7.4	400 กรัม	-	วชิรณ.	นันท.	
26/5/2568	3.0	3.0	7.4	7.4	-	-	วชิรณ.	นันท.	
27/5/2568	1.0	0.0	7.4	7.4	500 กรัม	-	วชิรณ.	นันท.	
28/5/2568	3.0	2.5	7.4	7.4	-	-	วชิรณ.	นันท.	
29/5/2568	1.0	0.0	7.2	7.2	500 กรัม	-	วชิรณ.	นันท.	
30/5/2568	3.0	3.0	7.2	7.2	-	-	วชิรณ.	นันท.	
31/5/2568	3.0	3.0	7.2	7.2	-	-	วชิรณ.	นันท.	

ตารางเดิมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ	ปริมาณ	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH		คลอรีน	โซดาแอช			
	เช้า	เย็น	เช้า	เย็น	(กรัม)	(กรัม)			
1/6/2568	2.5	2.0	7.2	7.2	-	-	สุวิทย์	นันท	
2/6/2568	1.0	0.0	7.2	7.2	500 กรัม	-	สุวิทย์	นันท	
3/6/2568	3.0	3.0	7.2	7.2	-	-	บรรณ	นันท	
4/6/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ราชันย์	นันท	
5/6/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ราชันย์	นันท	
6/6/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
7/6/2568	3.0	2.0	7.4	7.4	200 กรัม	-	วิรัช	นันท	
8/6/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
9/6/2568	3.0	2.5	7.4	7.4	-	-	วิรัช	นันท	
10/6/2568	2.0	0.5	7.4	7.4	400 กรัม	-	สุวิทย์	นันท	
11/6/2568	3.0	3.0	7.2	7.2	-	-	บรรณ	นันท	
12/6/2568	2.5	2.0	7.2	7.2	-	-	ราชันย์	นันท	
13/6/2568	2.0	0.5	7.2	7.2	400 กรัม	-	วิรัช	นันท	
14/6/2568	3.0	3.0	7.2	7.2	-	-	สุวิทย์	นันท	
15/6/2568	2.5	1.0	7.2	7.2	300 กรัม	-	สุวิทย์	นันท	
16/6/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	สุวิทย์	นันท	
17/6/2568	2.0	0.5	7.4	7.4	400 กรัม	-	บรรณ	นันท	
18/6/2568	3.0	2.0	7.2	7.2	-	-	บรรณ	นันท	
19/6/2568	3.0	3.0	7.2	7.2	-	-	ราชันย์	นันท	
20/6/2568	3.0	2.5	7.2	7.2	-	-	ราชันย์	นันท	
21/6/2568	2.0	1.0	7.2	7.2	300 กรัม	-	วิรัช	นันท	
22/6/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วิรัช	นันท	
23/6/2568	2.0	1.0	7.4	7.4	300 กรัม	-	วิรัช	นันท	
24/6/2568	3.0	3.0	7.4	7.4	-	-	สุวิทย์	นันท	
25/6/2568	2.5	2.0	7.2	7.2	-	-	บรรณ	นันท	
26/6/2568	1.0	0.0	7.2	7.2	500 กรัม	-	ราชันย์	นันท	
27/6/2568	3.0	2.0	7.2	7.2	-	-	วิรัช	นันท	
28/6/2568	2.0	0.0	7.2	7.2	500 กรัม	-	วิรัช	นันท	
29/6/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	สุวิทย์	นันท	
30/6/2568	3.0	2.5	7.2	7.2	-	-	วิรัช	นันท	