

Test Report 6110213

Date : 20-Jan-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.0122/68 = Guest room shower : Cold Water No.2611 (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6431956
Sample Condition : Water appears transparent contained in a plastic bottle sealed with a plastic lid and kept at a cool temperature. Sediment is showing at the bottom of the bottle.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-Jan-2025 Date Commenced : 9-Jan-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.



Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

5811926

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liability for the veracity or lack thereof of such information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result of this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.



ISO/IEC 17025
Accreditation No.1007/43

Test Report 6110215

Date : 20-Jan-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.0120/68 = Guest room shower : Hot Water No.1606 (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6431954
Sample Condition : Water appears transparent contained in a plastic bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-Jan-2025 Date Commenced : 9-Jan-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.

Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

SGS (Thailand) Limited | Laboratory Services 10, 10/1-4 and 12 Soi Rama III S.59, Chong Nonsi, Yan Nawa, Bangkok 10120
t +66 (0)2 683 05 41 www.sgs.com

Member of the SGS Group

5811928



ISO/IEC 17025
Accreditation No.1007/43

Test Report 6110212

Date : 20-Jan-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.0123/68 = Main Kitchen Diswashing Sprayer (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6431957
Sample Condition : Water appears transparent contained in a plastic bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-Jan-2025 Date Commenced : 9-Jan-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.

Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

SGS (Thailand) Limited | Laboratory Services 10, 10/1-4 and 12 Soi Rama III S.59, Chong Nonsi, Yan Nawa, Bangkok 10120
t +66 (0)2 683 05 41 www.sgs.com

Member of the SGS Group



ISO/IEC 17025
Accreditation No.1007/43

Test Report 6110214

Date : 20-Jan-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.0121/68 = Guest room shower : Cold Water No.1606 (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6431955
Sample Condition : Water appears transparent contained in a plastic bottle sealed with a plastic lid and kept at a cool temperature. Sediment is showing at the bottom of the bottle.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-Jan-2025 Date Commenced : 9-Jan-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.

Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

SGS (Thailand) Limited | Laboratory Services 10, 10/1-4 and 12 Soi Rama III S.59, Chong Nonsi, Yan Nawa, Bangkok 10120
t +66 (0)2 683 05 41 www.sgs.com

Member of the SGS Group

5811927



ISO/IEC 17025
Accreditation No.1007/43

Test Report 6110217

Date : 20-Jan-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.0118/68 = Hot Water tank (Supply) (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6431952
Sample Condition : Water appears transparent contained in a plastic bottle sealed with a plastic lid and kept at a cool temperature.

Qty.Submitted : 1 bottle x 1 L.

Date Received : 8-Jan-2025 Date Commenced : 9-Jan-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.

Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

SGS (Thailand) Limited | Laboratory Services 10, 10/1-4 and 12 Soi Rama III S.59, Chong Nonsi, Yan Nawa, Bangkok 10120
t +66 (0)2 683 05 41 www.sgs.com

Member of the SGS Group

5811930



ISO/IEC 17025
Accreditation No.1007/43

Test Report 6110211

Date : 20-Jan-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.0124/68 = Main pool shower (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6431958
Sample Condition : Water appears yellowish contained in a plastic bottle sealed with a plastic lid and kept at a cool temperature. Sediment is showing at the bottom of the bottle.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-Jan-2025 Date Commenced : 9-Jan-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.

Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

SGS (Thailand) Limited | Laboratory Services 10, 10/1-4 and 12 Soi Rama III S.59, Chong Nonsi, Yan Nawa, Bangkok 10120
t +66 (0)2 683 05 41 www.sgs.com

Member of the SGS Group

5811924



ISO/IEC 17025
Accreditation No.1007/43

Test Report 6137488

Date : 18-Feb-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.0731/68 = Cooling Water (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6461987
Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature. Sediment is showing at the bottom of the bottle.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 5-Feb-2025 Date Commenced : 6-Feb-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.

Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

Test Report 6226737

Date : 23-May-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.2518/68 = Hot Water tank (Supply) (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6553810
Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-May-2025 Date Commenced : 9-May-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.



Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

Test Report 6226736

Date : 23-May-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.2519/68 = Cooling Water (Bay Tower)

Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6553811

Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature.

Qty.Submitted : 1 bottle x 1 L.

Date Received : 8-May-2025

Date Commenced : 9-May-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.



Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

Test Report 6226734

Date : 23-May-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.2521/68 = Kids Pool (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6553813
Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-May-2025 Date Commenced : 9-May-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.



Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

Test Report 6226735

Date : 23-May-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.2520/68 = Infinity Pool (Main Pool) (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6553812
Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-May-2025 Date Commenced : 9-May-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.



Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such information."

5928448 This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

Test Report 6226733

Date : 23-May-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.2522/68 = Guest room shower : Hot Water No.1616 (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6553814
Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-May-2025 Date Commenced : 9-May-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.



Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

Test Report 6226732

Date : 23-May-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.2523/68 = Guest room shower : Cold Water No.1616 (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6553815
Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-May-2025 Date Commenced : 9-May-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.



Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.



ISO/IEC 17025
Accreditation No.1007/43

Test Report 6226731

Date : 23-May-2025

Page 1 of 1

Client : The Erawan Group Public Co.,Ltd (Holiday Inn Pattaya)
463/68 Pattaya Soi 1, Nongprue,
Banglamung, Chonburi 20150 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : P.2524/68 = main Kitchen dishwashing sprayer (Bay Tower)
Sample Description : Water

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 6553816
Sample Condition : Water appears transparent contained in a glass bottle sealed with a plastic lid and kept at a cool temperature.
Qty.Submitted : 1 bottle x 1 L.
Date Received : 8-May-2025 Date Commenced : 9-May-2025

Test Items	Method	Results	Units
<i>Legionella spp.</i>	ISO 11731 : 2017	Not detected**	Per Liter

Remark: ** Limit of detection = 100 CFU/Liter

Signed for and on behalf of
SGS (Thailand) Ltd.

Jirapan Vilaipol
Microbiology Laboratory Manager

***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) received and such sample(s) are retained for 15 days only.

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

5928444