

ภาคผนวก 7

เอกสารรายงานการตรวจสอบคุณภาพน้ำ

ANALYSIS REPORT

CUSTOMER NAME : SUPALAI PARK ASOKE-RATCHADA JURISTIC PERSON
ADDRESS : 599 ASOKE-DIN DAENG ROAD DIN DAENG DIN DAENG BANGKOK 10400
CONTACT INFORMATION : TEL : 08 2314 1107 e-mail : supalaipark599@gmail.com
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด ศุภาสัย ปาร์ค อโศก-รัชดา
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : JANUARY 31, 2025
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : JANUARY 31, 2025
ANALYTICAL DATE : JANUARY 31 - FEBRUARY 5, 2025
ISSUE DATE : FEBRUARY 10, 2025
REPORT NO. : 2025-U010957
WORK NO. : 2025-000643
ANALYSIS NO. : T25AC021-0001 - T25AC021-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 12:00 HOUR 1/ T25AC021-0001	2 11:50 HOUR 1/ T25AC021-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.0 (29.3°C)	6.9 (31.4°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^c	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	89.2	49.5	≤ 20	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	32.0	62.3	≤ 30	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	343	322	≤ 1,000	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	1.9	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	66.5	30.2	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 12:00 HOUR 1/ T25AC021-0001	2 11:50 HOUR 1/ T25AC021-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	4	3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : INFLUENT

RESULT 2 : EFFLUENT

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141,
PART 233 D, DATED AUGUST 27, 2024.

BIOCHEMICAL OXYGEN DEMAND (T25AC021-0002) : ADDITION OF NITRIFICATION INHIBITION (TCMP) FOLLOW TO THE SM: 5210B,5(e).

Wilailak Srisuk.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
BY BSI GROUP (THAILAND) CO.,LTD.

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

2/2

2025-U010957

- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : SUPALAI PARK ASOKE-RATCHADA JURISTIC PERSON
ADDRESS : 599 ASOKE-DIN DAENG ROAD DIN DAENG DIN DAENG BANGKOK 10400
CONTACT INFORMATION : TEL : 08 2314 1107 e-mail : supalaipark599@gmail.com
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด ศุภาสัย ปาร์ค อโศก-รัชดา
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : FEBRUARY 28, 2025
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR SOMCHART UTHUMRAT
ANALYZED BY : MISS ARIYA THARAROM
RECEIVED DATE : FEBRUARY 28, 2025
ANALYTICAL DATE : FEBRUARY 28 - MARCH 6, 2025
ISSUE DATE : MARCH 10, 2025
REPORT NO. : 2025-U019657
WORK NO. : 2025-000643
ANALYSIS NO. : T25AE333-0001 - T25AE333-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 12:40 HOUR 1/ T25AE333-0001	2 12:30 HOUR 1/ T25AE333-0002			
pH ^P	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.1 (29.5°C)	7.8 (31.9°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^A	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	76.6	93.0	≤ 20	-	2.0
TOTAL SUSPENDED SOLIDS ^A	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	45.9	69.0	≤ 30	-	5.0
TOTAL DISSOLVED SOLIDS ^B	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	276	347	≤ 1,000	-	25
SETTLABLE SOLIDS ^C	mL/L	IMHOFF CONE (SM: PART 2540 F)	0.1	< 0.1	-	0.1	-
SULPHIDE ^D	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	2.5	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^E	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	60.5	45.9	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 12:40 HOUR 1/ T25AE333-0001	2 12:30 HOUR 1/ T25AE333-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	4	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : INFLUENT

RESULT 2 : EFFLUENT

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141,
PART 233 D, DATED AUGUST 27, 2024.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
BY BSI GROUP (THAILAND) CO., LTD.

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

2/2

2025-U019657

- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : SUPALAI PARK ASOKE-RATCHADA JURISTIC PERSON
ADDRESS : 599 ASOKE-DIN DAENG ROAD DIN DAENG DIN DAENG BANGKOK 10400
CONTACT INFORMATION : TEL : 08 2314 1107 e-mail : supalai@uaeconsultant.com
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด สุภาลัย ปาร์ค อโศก-รัชดา
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : MARCH 26, 2025
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR WEERAYUT MOKKAEW
ANALYZED BY : MISS ARIYA THARAROM
RECEIVED DATE : MARCH 26, 2025
ANALYTICAL DATE : MARCH 26-31, 2025
ISSUE DATE : APRIL 3, 2025
REPORT NO. : 2025-U028189
WORK NO. : 2025-000643
ANALYSIS NO. : T25AG518-0001 - T25AG518-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 11:45 HOUR 1/ T25AG518-0001	2 11:35 HOUR 1/ T25AG518-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.9 (30.2°C)	6.8 (31.5°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	93.3	64.0	≤ 20	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	35.8	45.3	≤ 30	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	322	310	≤ 1,000	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	2.3	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	71.3	26.9	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 11:45 HOUR 1/ T2SAGS18-0001	2 11:35 HOUR 1/ T2SAGS18-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	6	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			BROWN/TURBID BROWN	BROWN/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : INFLUENT

RESULT 2 : EFFLUENT

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141,
PART 233 D, DATED AUGUST 27, 2024.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
BY BSI GROUP (THAILAND) CO.,LTD.

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.

• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

2/2

2025-U028189

- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : SUPALAI PARK ASOKE-RATCHADA JURISTIC PERSON
ADDRESS : 599 ASOKE-DIN DAENG ROAD DIN DAENG DIN DAENG BANGKOK 10400
CONTACT INFORMATION : TEL : 08 2314 1107 e-mail : supalaipark599@gmail.com
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด ศุภาสัย ปาร์ค อโศก-รัชดา
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : APRIL 21, 2025
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS ARIYA THARAROM
RECEIVED DATE : APRIL 21, 2025
ANALYTICAL DATE : APRIL 21-28, 2025
ISSUE DATE : APRIL 29, 2025
REPORT NO. : 2025-U037073
WORK NO. : 2025-000643
ANALYSIS NO. : T25AI431-0001 - T25AI431-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 16:10 HOUR 1/ T25AI431-0001	2 16:05 HOUR 1/ T25AI431-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.3 (31.4°C)	7.0 (33.3°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	54.2	39.8	≤ 20	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	32.6	17.2	≤ 30	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	355	398	≤ 1,000	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	1.9	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	58.3	< 5.0	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 16:10 HOUR 1/ T25AI431-0001	2 16:05 HOUR 1/ T25AI431-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	8	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : INFLUENT

RESULT 2 : EFFLUENT

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
BY BSI GROUP (THAILAND) CO.,LTD.

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.

• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

2/2

2025-U037073

- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : SUPALAI PARK ASOKE-RATCHADA JURISTIC PERSON
ADDRESS : 599 ASOKE-DIN DAENG ROAD DIN DAENG DIN DAENG BANGKOK 10400
CONTACT INFORMATION : TEL : 08 2314 1107 e-mail : supalaipark599@gmail.com
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด สุภาลัย ปาร์ค อโศก-รัชดา
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : MAY 19, 2025
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR RONNAYUT PRATHUMKET
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : MAY 19, 2025
ANALYTICAL DATE : MAY 19-26, 2025
ISSUE DATE : MAY 27, 2025
REPORT NO. : 2025-U046768
WORK NO. : 2025-000643
ANALYSIS NO. : T25AK717-0001 - T25AK717-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 11:50 HOUR 1/ T25AK717-0001	2 11:45 HOUR 1/ T25AK717-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.4 (31.0°C)	7.2 (30.9°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	45.3	24.5	≤ 20	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	38.1	38.8	≤ 30	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	362	363	≤ 1,000	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	1.7	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	62.2	27.4	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 11:50 HOUR 1/ T25AK717-0001	2 11:45 HOUR 1/ T25AK717-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	4	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : INFLUENT

RESULT 2 : EFFLUENT

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141,
PART 233 D, DATED AUGUST 27, 2024.

Wilailak Sinuk.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

2/2

2025-U046768

- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : SUPALAI PARK ASOKE-RATCHADA JURISTIC PERSON
ADDRESS : 599 ASOKE-DIN DAENG ROAD DIN DAENG DIN DAENG BANGKOK 10400
CONTACT INFORMATION : TEL : 08 2314 1107 e-mail : supalaipark599@gmail.com
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด สุภาลัย ปาร์ค อโศก-รัชดา
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : JUNE 20, 2025
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : JUNE 20, 2025
ANALYTICAL DATE : JUNE 20-28, 2025
ISSUE DATE : JUNE 30, 2025
REPORT NO. : 2025-U059367
WORK NO. : 2025-000643
ANALYSIS NO. : T25AN617-0001 - T25AN617-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:45 HOUR 1/ T25AN617-0001	2 10:40 HOUR 1/ T25AN617-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.2 (30.9°C)	6.8 (31.8°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	73.2	61.4	≤ 20	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	42.3	29.7	≤ 30	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	298	322	≤ 1,000	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	0.52	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	60.0	15.8	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:45 HOUR 1/ T25AN617-0001	2 10:40 HOUR 1/ T25AN617-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	8	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.


RESULT 1 : INFLUENT

RESULT 2 : EFFLUENT

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Wilailak Srisuk.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

2/2

2025-U059367

- End of Analysis Report -