

DIALY LOG SHEET FIRE PUMP

วันที่	เวลา	DC.Volt#1(13.3V)	DC.Volt#2(13.3V)	AMP # 1	AMP # 2	Enging Speet (RPM)	Fuel Level (Lites) > 700	Pressure(Psi)	Record By	Remark
03 / 01 / 68	15.15	13.3	14.2	2.4	2.4	3000	190	132	ศ.ภก.ท.บ.น.	
10 / 01 / 68	15.15	13.2	13.9	2.4	2.3	3000	190	160	ศ.ภก.ท.บ.น.	
17 / 01 / 68	15.15	13.1	13.5	2.3	2.3	3000	190	159	ศ.ภก.ท.บ.น.	
24 / 01 / 68	15.15	13.2	13.4	2.3	2.4	3000	190	151	ศ.ภก.ท.บ.น.	
31 / 01 / 68	15.15	13.0	13.2	2.3	2.4	3000	190	142	ศ.ภก.ท.บ.น.	
07 / 02 / 68	15.15	13.1	13.0	2.4	2.3	3000	190	148	ศ.ภก.ท.บ.น.	
14 / 02 / 68	15.15	14.1	13.6	2.3	2.3	3000	189	150	ศ.ภก.ท.บ.น.	
21 / 02 / 68	15.15	13.2	13.7	2.4	2.4	3000	189	150	ศ.ภก.ท.บ.น.	
28 / 02 / 68	15.15	13.3	13.2	2.4	2.3	3000	189	148	ศ.ภก.ท.บ.น.	
07 / 03 / 68	15.15	13.1	13.3	2.3	2.4	3000	188	132	ศ.ภก.ท.บ.น.	
14 / 03 / 68	15.15	12.1	13.2	2.3	2.3	3000	188	131	ศ.ภก.ท.บ.น.	
21 / 03 / 68	15.15	14.2	14.0	2.4	2.4	3000	188	152	ศ.ภก.ท.บ.น.	
28 / 03 / 68	15.15	13.2	13.1	2.4	2.4	3000	187	159	ศ.ภก.ท.บ.น.	
04 / 04 / 68	15.15	13.3	13.2	2.4	2.3	3000	187	167	ศ.ภก.ท.บ.น.	
11 / 04 / 68	15.15	13.2	13.3	2.3	2.4	3000	187	160	ศ.ภก.ท.บ.น.	
18 / 04 / 68	15.15	14.1	13.7	2.4	2.3	3000	186	161	ศ.ภก.ท.บ.น.	
25 / 04 / 68	15.15	15.1	14.1	2.3	2.4	3000	186	158	ศ.ภก.ท.บ.น.	

DIALY LOG SHEET FIRE PUMP

[illegible]

DIALY LOG SHEET FIRE PUMP

วันที่	เวลา	DC.Volt#1(13.3V)	DC.Volt#2(13.3V)	AMP # 1	AMP # 2	Enging Speet (RPM)	Fuel Level (Lites) > 700	Pressure(PSI)	Record By	Remark
31/01/64	15:00	14.4	13.4	1.4	2.4	3000	7.41	174	สมเกียรติ	
10/01/64	15:00	14.4	13.4	1.4	2.5	3000	7.40	174	สมเกียรติ	
17/01/64	15:00	14.4	13.4	1.9	2.6	3000	7.40	174	สมเกียรติ	
24/01/64	15:00	14.4	13.6	1.4	2.5	3000	7.40	170	สมเกียรติ	
31/01/64	15:00	14.4	13.6	1.9	2.6	3000	7.39	179	สมเกียรติ	
7/02/64	15:00	14.4	13.1	1.9	2.4	3000	7.39	174	สมเกียรติ	
14/02/64	15:00	14.4	13.4	1.9	2.5	3000	7.34	174	สมเกียรติ	
21/02/64	15:00	14.4	13.4	1.4	2.6	3000	7.34	179	สมเกียรติ	
24/02/64	15:00	14.4	13.5	1.4	2.6	3000	7.34	179	สมเกียรติ	
7/03/64	15:00	14.4	13.7	1.9	2.6	3000	7.34	177	สมเกียรติ	
14/03/64	15:00	14.4	13.4	1.4	2.5	3000	7.37	177	สมเกียรติ	
21/03/64	15:00	14.4	13.6	1.4	2.5	3000	7.37	174	สมเกียรติ	
24/03/64	15:00	14.4	13.5	1.9	2.4	3000	7.36	174	สมเกียรติ	
4/04/64	15:00	14.4	13.4	1.9	2.6	3000	7.36	174	สมเกียรติ	
11/04/64	15:00	14.4	13.4	1.9	2.6	3000	7.36	179	สมเกียรติ	
14/04/64	15:00	14.4	13.4	1.4	2.5	3000	7.35	174	สมเกียรติ	
25/04/64	15:00	14.4	13.4	1.4	2.6	3000	7.35	174	สมเกียรติ	

5

[illegible]

DIALY LOG SHEET GENERATOR ENGINE MODEL

วันที่	เวลา	test	freq.(Hz)	volt (N-L/L-L)			Ampere			Load(KW)	Oil KPA	WaterTemp COOLANT	Oil Temp	D.C.Volt	Engine Speed(RPM)	Fuel Level(Lites)	Customer(Hour)	record by	remark
				A-B	B-C	C-A	A	B	C										
4/1/68	14:30	✓	50	400	400	400	-	-	-	-	512	32/32	30	28.1	1504	1120	258.2	โก	
11/1/68	14:30	✓	50	400	400	400	-	-	-	-	498	30/30	27	28	1504	1110	258.7	โก	
18/1/68	14:30	✓	50.1	400	400	400	-	-	-	-	498	29/30	27	28	1504	1100	259.2	โก	
25/1/68	14:30	✓	50.1	400	400	400	-	-	-	-	512	32/32	32	28.1	1504	1090	232.3	โก	
1/2/68	14:30	✓	50	400	400	400	-	-	-	-	512	35/35	31	28.1	1504	1080	252.3	ชื่อน	
8/2/68	14:30	✓	50.1	400	400	400	-	-	-	-	512	36/36	32	28.1	1501	1070	252.4	ชื่อน	
15/2/68	14:30	✓	50.1	400	400	399	-	-	-	-	498	28/28	30	27.8	1504	1060	252.5	ชื่อน	
22/2/68	14:30	✓	50.1	400	400	400	-	-	-	-	498	27/28	30	27.7	1503	1050	252.8	ชื่อน	
1/3/68	14:30	✓	50.1	400	400	400	-	-	-	-	498	39/39	31	28	1503	1040	2530	ชื่อน	
2/3/68	14:30		50.1	400	400	400					499	75/75	32	28	1504	980	254.4	ชื่อน	
3/3/68	14:30	✓	50.1	400	400	400	-	-	-	-	491	41/42	29	28.1	1501	975	254.4	ชื่อน	รับ Gen เปลี่ยนอุปกรณ์
15/3/68	14:30	✓	50.1	400	400	400	-	-	-	-	512	42/42	38	28.1	1503	950	254.5	ชื่อน	
22/3/68	14:30	✓	50	400	400	400	-	-	-	-	512	45/45	32	28.1	1502	965	254.6	ชื่อน	
29/3/68	14:30	✓	50	399	400	399	-	-	-	-	505	48/48	32	28	1503	960	254.7	ชื่อน	

[illegible][illegible]

DIALY LOG SHEET GENERATOR ENGINE MODEL

วันที่	เวลา	test	freq.(Hz)	volt (N-L/L-L)			Ampere			Load(KW)	Oil KPA	WaterTemp COOLANT	Oil Temp	D.C.Volt	Engine Speed(RPM)	Fuel Level(Lites)	Customer(Hour)	record by	remark
				A-B	B-C	C-A	A	B	C										
4/1/68	15:00	✓	50	399	399	399	-	-	-	-	633	36	-	22.8	1500	1625	53h16m	จ๊อง	
11/1/68	15:00	✓	50	399	399	399	-	-	-	-	645	35	-	22.5	1500	1620	53h26m	จ๊อง	
18/1/68	15:00	✓	50	399	399	399	-	-	-	-	659	35	-	22.7	1500	1615	53h36m	จ๊อง	
25/1/68	15:00	✓	50	399	399	399	-	-	-	-	645	35	-	22.4	1500	1610	53h44m	จ๊อง	
1/2/68	15:00	✓	50	398	399	399	-	-	-	-	639	35	-	22.6	1500	1605	53h52m	จ๊อง	
8/2/68	15:00	✓	50	399	399	399	-	-	-	-	639	35	-	22.6	1500	1600	54h02m	จ๊อง	
15/2/68	15:00	✓	50	399	398	399	-	-	-	-	639	35	-	22.7	1500	1595	54h12m	จ๊อง	
22/2/68	15:00	✓	50	399	399	399	-	-	-	-	627	37	-	22.8	1500	1590	54h22m	จ๊อง	
1/3/68	15:00	✓	50	398	398	399	-	-	-	-	615	41	-	28	1500	1585	54h49m	จ๊อง	
8/3/68	15:00	✓	50	399	399	399	-	-	-	-	609	44	-	28	1500	1580	54h56m	จ๊อง	
15/3/68	15:00	✓	50	398	399	399	-	-	-	-	627	39	-	22.9	1500	1575	55h05m	จ๊อง	
22/3/68	15:00	✓	50	398	399	399	-	-	-	-	633	37	-	22.8	1500	1570	55h14m	จ๊อง	
29/3/68	15:00	✓	50	399	399	399	-	-	-	-	615	46	-	28	1500	1565	55h34m	จ๊อง	
5/4/68	15:00	✓	50	399	399	399	-	-	-	-	627	44	-	28	1500	1560	55h40m	จ๊อง	

[illegible][illegible]