

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : JANUARY 27, 2025
SAMPLING TIME : 14:05 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JANUARY 27, 2025
ANALYTICAL DATE : JANUARY 27 - FEBRUARY 3, 2025
ISSUE DATE : FEBRUARY 4, 2025
REPORT NO. : 2025-U009305
WORK NO. : 2024-012452
ANALYSIS NO. : T25AB646-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			บอตรวจคุณภาพน้ำ T25AB646-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H* B AND 1060 B	7.6 (29.4°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND* ^c	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	6.5	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	40.4	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	865	≤ 1,300	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	0.4	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ² - F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	5.9	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

* : ADDITION OF NITRIFICATION INHIBITION (TCMP) FOLLOW TO THE SM: 5210B,5(e).



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 27, 2025
SAMPLING TIME : 13:50 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JANUARY 27, 2025
ANALYTICAL DATE : JANUARY 27-30, 2025
ISSUE DATE : FEBRUARY 4, 2025
REPORT NO. : 2025-U009306
WORK NO. : 2024-012452
ANALYSIS NO. : T25AB646-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AB646-0002	
MICROBIOLOGY				
COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 27, 2025
SAMPLING TIME : 13:55 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JANUARY 27, 2025
ANALYTICAL DATE : JANUARY 27-30, 2025
ISSUE DATE : FEBRUARY 4, 2025
REPORT NO. : 2025-U009307
WORK NO. : 2024-012452
ANALYSIS NO. : T25AB646-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AB646-0003	
MICROBIOLOGY				
COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : FEBRUARY 21, 2025
SAMPLING TIME : 13:50 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY :
ANALYZED BY :
RECEIVED DATE : FEBRUARY 21, 2025
ANALYTICAL DATE : FEBRUARY 21-28, 2025
ISSUE DATE : MARCH 3, 2025
REPORT NO. : 2025-U017561
WORK NO. : 2024-012452
ANALYSIS NO. : T25AD698-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มาตรฐานคุณภาพน้ำ T25AD698-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.0 (31.0°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^c	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	27.5	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	316	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	421	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	6.6	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			


^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 21, 2025
SAMPLING TIME : 13:35 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : FEBRUARY 21, 2025
ANALYTICAL DATE : FEBRUARY 21-26, 2025
ISSUE DATE : MARCH 3, 2025
REPORT NO. : 2025-U017565
WORK NO. : 2024-012452
ANALYSIS NO. : T25AD698-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AD698-0002	
MICROBIOLOGY				
COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	
			-	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 21, 2025
SAMPLING TIME : 13:40 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : FEBRUARY 21, 2025
ANALYTICAL DATE : FEBRUARY 21-26, 2025
ISSUE DATE : MARCH 3, 2025
REPORT NO. : 2025-U017570
WORK NO. : 2024-012452
ANALYSIS NO. : T25AD698-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AD698-0003	
MICROBIOLOGY				
COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : MARCH 26, 2025
SAMPLING TIME : 11:40 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY :
ANALYZED BY :
RECEIVED DATE : MARCH 26, 2025
ANALYTICAL DATE : MARCH 26 - APRIL 1, 2025
ISSUE DATE : APRIL 3, 2025
REPORT NO. : 2025-U028783
WORK NO. : 2024-012452
ANALYSIS NO. : T25AG535-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			บอตรวจคุณภาพน้ำ T25AG535-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.3 (30.8°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^b	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	19.5	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	8.4	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	418	≤ 1,300	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	11.8	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN			


^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 26, 2025
SAMPLING TIME : 11:30 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c :
ANALYZED BY :
RECEIVED DATE : MARCH 26, 2025
ANALYTICAL DATE : MARCH 26-31, 2025
ISSUE DATE : APRIL 4, 2025
REPORT NO. : 2025-U028785
WORK NO. : 2024-012452
ANALYSIS NO. : T25AG535-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AG535-0003	
MICROBIOLOGY				
COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT


CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 26, 2025
SAMPLING TIME : 11:35 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : MARCH 26, 2025
ANALYTICAL DATE : MARCH 26-31, 2025
ISSUE DATE : APRIL 4, 2025
REPORT NO. : 2025-U028784
WORK NO. : 2024-012452
ANALYSIS NO. : T25AG535-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AG535-0002	
MICROBIOLOGY				
COLIFORM BACTERIA ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : APRIL 30, 2025
SAMPLING TIME : 16:10 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : APRIL 30, 2025
ANALYTICAL DATE : APRIL 30 - MAY 9, 2025
ISSUE DATE : MAY 15, 2025
REPORT NO. : 2025-U041543
WORK NO. : 2024-012452
ANALYSIS NO. : T25A338-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ผลการตรวจภาพน้ำ T25A338-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.6 (32.2°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	19.9	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	55.2	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	448	≤ 1,300	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	5.4	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 30, 2025
SAMPLING TIME : 16:18 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : APRIL 30, 2025
ANALYTICAL DATE : APRIL 30 - MAY 7, 2025
ISSUE DATE : MAY 15, 2025
REPORT NO. : 2025-U041544
WORK NO. : 2024-012452
ANALYSIS NO. : T25AJ338-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AJ338-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 30, 2025
SAMPLING TIME : 16:20 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : APRIL 30, 2025
ANALYTICAL DATE : APRIL 30 - MAY 7, 2025
ISSUE DATE : MAY 15, 2025
REPORT NO. : 2025-U041545
WORK NO. : 2024-012452
ANALYSIS NO. : T25AJ338-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AJ338-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : MAY 27, 2025
SAMPLING TIME : 13:10 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : MAY 27, 2025
ANALYTICAL DATE : MAY 27 - JUNE 5, 2025
ISSUE DATE : JUNE 6, 2025
REPORT NO. : 2025-U050241
WORK NO. : 2024-012452
ANALYSIS NO. : T25AL385-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ผลการตรวจคุณภาพน้ำ T25AL385-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.5 (32.2°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^b	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	9.1	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	34.3	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	502	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 27, 2025
SAMPLING TIME : 13:05 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : MAY 27, 2025
ANALYTICAL DATE : MAY 27 - JUNE 1, 2025
ISSUE DATE : JUNE 9, 2025
REPORT NO. : 2025-U050242
WORK NO. : 2024-012452
ANALYSIS NO. : T25AL385-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AL385-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 27, 2025
SAMPLING TIME : 13:00 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c :
ANALYZED BY :
RECEIVED DATE : MAY 27, 2025
ANALYTICAL DATE : MAY 27 - JUNE 1, 2025
ISSUE DATE : JUNE 9, 2025
REPORT NO. : 2025-U050243
WORK NO. : 2024-012452
ANALYSIS NO. : T25AL385-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AL385-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : JUNE 25, 2025
SAMPLING TIME : 14:55 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JUNE 25, 2025
ANALYTICAL DATE : JUNE 25 - JULY 2, 2025
ISSUE DATE : JULY 3, 2025
REPORT NO. : 2025-U060986
WORK NO. : 2024-012452
ANALYSIS NO. : T25AO105-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ปอดตรวจคุณภาพน้ำ T25AO105-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	5.8 (35.0°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	13.5	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	10.5	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	548	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 25, 2025
SAMPLING TIME : 14:50 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c :
ANALYZED BY :
RECEIVED DATE : JUNE 25, 2025
ANALYTICAL DATE : JUNE 25 - JULY 1, 2025
ISSUE DATE : JULY 4, 2025
REPORT NO. : 2025-U060987
WORK NO. : 2024-012452
ANALYSIS NO. : T25AQ105-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AQ105-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 25, 2025
SAMPLING TIME : 14:45 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : [REDACTED]
ANALYZED BY : [REDACTED]


RECEIVED DATE : JUNE 25, 2025
ANALYTICAL DATE : JUNE 25 - JULY 1, 2025
ISSUE DATE : JULY 4, 2025
REPORT NO. : 2025-U060989
WORK NO. : 2024-012452
ANALYSIS NO. : T25AO105-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AO105-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	
			-	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JULY 30, 2025
SAMPLING TIME : 16:05 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JULY 31, 2025
ANALYTICAL DATE : JULY 31 - AUGUST 4, 2025
ISSUE DATE : AUGUST 8, 2025
REPORT NO. : 2025-U071493
WORK NO. : 2024-012452
ANALYSIS NO. : T25AQ606-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AQ606-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

