



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	January 8-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6801030

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	11.01 AM.
Analysis No.	25680064

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 24.5 °C	-	SM : 4500-H ⁺ B	6.1	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	22.3	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	36.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	504	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	7.0	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.3	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	14.4	≤ 35

Physical Appearance Sample 25680064 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

16/1/๒๕

Aproved By : สาอวพา นุกะว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

16/1/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO.,LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	January 8-15, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat	Report No.	PKT6801030

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	11.01 AM.
Analysis No.	25680064

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.8	-

Physical Appearance Sample 25680064 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

16 / 1 / 68Approved By : สาอวป นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

16 / 1 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	February 7-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๑-0003)	Report No.	PKT6802033

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.41 AM.
Analysis No.	25680536

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	6.8	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	25.2	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	80.2	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	356	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	11.8	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	1.2	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	13.6	≤ 35

Physical Appearance Sample 25680536 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพย์ มิตราก

Miss. Jantip Mittaka (๖-250-๑-0004)

Laboratory Analyst

17/2/๒๕

Aproved By : สาอวพา นุกาอ

Miss. Saowapa Nukaew (๖-250-๑-0002)

Laboratory Manager

17/2/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกสาร
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	February 7-15, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat	Report No.	PKT6802033

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.41 AM.
Analysis No.	25680536

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance	Sample	25680536 : Clear, yellow liquid, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023</p> <p>[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[3] : Information received from customers</p>		

Reported By : จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

17/2/25

Aproved By : สาอวป นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

17/2/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts

**BEST CHOICE**

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	March 7-14, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (จ-250-จ-0003)	Report No.	PKT6803039

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	11.27 AM.
Analysis No.	25680929

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.1 °C	-	SM : 4500-H ⁺ B	6.3	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	16.2	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	28.7	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	513	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	14.4	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.5	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	19.5	≤ 35

Physical Appearance Sample 25680929 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024
published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By :

จันทิพ มิตตะกะ
Miss. Jantip Mittaka (จ-250-จ-0004)

Laboratory Analyst

15 / 3 / 68

Approved By :

สาอวปะ นุกะอว
Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager

15 / 3 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

เลขที่ใบรับ จ-250

The results of analysis are valid for the submitted sample only.

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	March 7-14, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6803039

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	11.27 AM.
Analysis No.	25680929

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.1	-

Physical Appearance Sample 25680929 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

15 / 3 / 68

Aproved By :

สาอวพา นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

15 / 3 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumhur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	April 9-19, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (ว-250-ท-0003)	Report No.	PKT6804073

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.36 AM.
Analysis No.	25681409

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 24.9 °C	-	SM : 4500-H ⁺ B	6.2	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	28.2	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	38.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	526	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	14.3	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.8	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	27.2	≤ 35

Physical Appearance Sample 25681409 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka (ว-250-ท-0004)

Laboratory Analyst

21 / 4 / 68

Aproved By :

Miss. Saowapa Nukaew (ว-250-ท-0002)

Laboratory Manager

21 / 4 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400

**BEST CHOICE**

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	April 9-19, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6804073

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.36 AM.
Analysis No.	25681409

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.1	-

Physical Appearance Sample 25681409 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทริกา มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

21 / 4 / 68

Approved By :

Miss. Saowapa Nukacw

Laboratory Manager

21 / 4 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	May 20-21, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6805113

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.17 AM.
Analysis No.	25681947

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.6 °C	-	SM : 4500-H ⁺ B	6.4	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	24.9	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	38.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	338	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	9.1	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.7	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	8.5	≤ 35

Physical Appearance Sample 25681947 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers

Reported By : จันทิพร มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๘/๕/๒๕

Aproved By : Saowapa Nukaew

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๘/๕/๒๕

ACCREDITED LABORATORY GLN/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	May 20 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	May 20-27, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6805113

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.17 AM.
Analysis No.	25681947

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance	Sample 25681947 : Clear, yellow liquid, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023</p> <p>[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[3] : Information received from customers</p>	

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

28/5/25

Aproved By : สาอวป นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

28/5/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์คุณภาพ

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	June 5-12, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (จ-250-จ-0003)	Report No.	PKT6806026

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.59 AM.
Analysis No.	25682126

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.2 °C	-	SM : 4500-H ⁺ B	6.3	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	28.9	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	37.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	490	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	5.7	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.8	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	13.3	≤ 35

Physical Appearance Sample 25682126 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
 [2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024
 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
 [3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
 [4] : Information received from customers

Reported By :

Miss. Jantip Mittaka (จ-250-จ-0004)

Laboratory Analyst

13 / 6 / 65

Aproved By :

Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager

10 / 6 / 65

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน จ-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	June 5-12, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat	Report No.	PKT6806026

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.59 AM.
Analysis No.	25682126

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25682126 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[3] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

13 / 6 / 68

Aproved By :

Miss. Saowapa Nukacw

Laboratory Manager

13 / 6 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	January 8-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (ว-250-ท-0003)	Report No.	PKT6801030

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.40 AM.
Analysis No.	25680065

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 24.6°C	-	SM : 4500-H ⁺ B	6.1	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	14.7	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	13.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	482	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	2.9	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.1	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	9.3	≤ 35

Physical Appearance Sample 25680065 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
 [2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
 [3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
 [4] : Information received from customers

Reported By :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (ว-250-ท-0004)

Laboratory Analyst

16 / 1 / 68

Aproved By :

สาอวพา นุกาอว
Miss. Saowapa Nukaew (ว-250-ท-0002)

Laboratory Manager

16 / 1 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phukct 83110	Receiving Date	January 8, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	January 8-15 , 2025
Sampling Method ^[3]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat	Report No.	PKT6801030

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.40 AM.
Analysis No.	25680065

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25680065 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
 [2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
 [3] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

16/1/68Approved By : สาอวพา นุกะว

Miss. Saowapa Nukaw

Laboratory Manager

16/1/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts

HEAD OFFICE : 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 300



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	February 7-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๓-250-๓-0003)	Report No.	PKT6802033

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.23 AM.
Analysis No.	25680537

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	6.6	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	12.0	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	13.6	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	456	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	2.0	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	1.2	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	12.0	≤ 35

Physical Appearance Sample 25680537 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers

Reported By : จันทิพย์ มิตราก

Miss. Jantip Mittaka (๓-250-๓-0004)

Laboratory Analyst

17/2/๒๕

Aproved By : สาอวพา นุกาแว

Miss. Saowapa Nukaew (๓-250-๓-0002)

Laboratory Manager

17/2/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
เพื่อปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๓-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

BANGKOK Tel. (028) 230 124, 426 980 HUAHIN Tel. (022) 520 575, 545 173 SAMUI Tel. (077) 419 079-80 PHANONG Tel. (076) 486 100



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	February 7-15, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat	Report No.	PKT6802033

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.23 AM.
Analysis No.	25680537

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance	Sample	25680537 : Clear, yellow liquid, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023</p> <p>[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[3] : Information received from customers</p>		

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

17/2/68

Aproved By :

Miss. Saowapa Nukacw

Laboratory Manager

17/2/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts

**BEST CHOICE**

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	March 7-14, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (ว-250-จ-0003)	Report No.	PKT6803039

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.55 AM.
Analysis No.	25680930

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.2° C	-	SM : 4500-H ⁺ B	6.3	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	11.7	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	11.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	492	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	6.2	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.6	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	15.1	≤ 35

Physical Appearance Sample 25680930 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพ มิตตะ

Miss. Jantip Mittaka (ว-250-จ-0004)

Laboratory Analyst

15 / 3 / 68

Approved By :

Miss. Saowapa Nukaew (ว-250-ก-0002)

Laboratory Manager

15 / 3 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	March 7-14, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat	Report No.	PKT6803039

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.55 AM.
Analysis No.	25680930

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.1	-

Physical Appearance Sample 25680930 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทวิภาณี มิตราก

Miss. Jantip Mittaka

Laboratory Analyst

15/3/25

Aproved By :

Miss. Saowapa Nukacw

Miss. Saowapa Nukacw

Laboratory Manager

15/3/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์คุณภาพ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	April 9-19, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๓-250-๓-0003)	Report No.	PKT6804073

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.29 AM.
Analysis No.	25681410

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	6.5	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	17.1	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	6.6	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	564	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	2.8	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	Not Detected	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	16.4	≤ 35

Physical Appearance Sample 25681410 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka (๓-250-๓-0004)

Laboratory Analyst

๒๑ / ๔ / ๒๕

Aproved By :

Miss. Saowapa Nukaew (๓-250-๓-0002)

Laboratory Manager

๐๙ / ๔ / ๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๓-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	April 9-19, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6804073

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.29 AM.
Analysis No.	25681410

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.1	-

Physical Appearance Sample 25681410 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพร มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

21, 4, 68

Approved By :

Miss. Saowapa Nukacw

Miss. Saowapa Nukacw

Laboratory Manager

21, 4, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10


Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	May 20-27, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6805113

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.07 AM.
Analysis No.	25681948

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.5°C	-	SM : 4500-H ⁺ B	6.7	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	7.2	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	10.3	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	344	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	2.7	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.1	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	4.1	≤ 35

Physical Appearance Sample 25681948 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK
[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers


Reported By : 

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๘/๕/๒๕

Aproved By :



Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๘/๕/๒๕

ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



NSC-TIS-TIS 17025
TESTING 0548

WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	May 20-27, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6805113

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.07 AM.
Analysis No.	25681948

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance	Sample	25681948 : Clear, yellow liquid, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023</p> <p>[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[3] : Information received from customers</p>		

Reported By : จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

28/5/68

Aproved By : Miss. Saowapa Nukacw

Miss. Saowapa Nukacw

Laboratory Manager

28/5/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ตั้งอยู่ที่อาคาร 12 ชั้น 12

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	June 5-12, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (จ-250-ก-0003)	Report No.	PKT6806026

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	09.52 AM.
Analysis No.	25682127

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.1 °C	-	SM : 4500-H ⁺ B	6.5	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	10.5	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	8.8	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	394	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	3.0	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.7	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	7.1	≤ 35

Physical Appearance Sample 25682127 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka (จ-250-ก-0004)

Laboratory Analyst

13 / 6 / 68

Aproved By : [Signature]

Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager

13 / 6 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน จ-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400

**BEST CHOICE**

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	June 5-12, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6806026

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	09.52 AM.
Analysis No.	25682127

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25682127 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[3] : Information received from customers

Reported By :

จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

13 / 6 / 68

Approved By :

Saowapa Nukacw

Miss. Saowapa Nukacw

Laboratory Manager

13 / 6 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	January 8-15, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (ว-250-ก-0003)	Report No.	PKT6801030

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.52 AM.
Analysis No.	25680069

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 24.9°C	-	SM : 4500-H ¹ B	7.3	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	526	-

Physical Appearance Sample 25680069 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Information received from customers

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (ว-250-ก-0004)

Laboratory Analyst

16/1/25

Approved by :

Miss. Saowapa Nukaew (ว-250-ก-0002)

Laboratory Manager

16/1/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
ได้ทะเบียน ว-2550

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124
PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	January 8-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[4]	Miss. Yonlatda Thancerat	Report No.	PKT6801030

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	10.52 AM.
Analysis No.	25680069

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	138	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	230	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	143	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680069 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะนาค

Miss. Jantip Mittaka

Laboratory Analyst

16/1/68

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

16/4/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE**

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	February 7-15, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[3]	Miss Yonlatda Thanecrat (ว-250-จ-0003)	Report No.	PKT6802033

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.30 AM.
Analysis No.	25680541

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.1 °C	-	SM : 4500-H ⁺ B	7.0	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	564	-

Physical Appearance Sample 25680541 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Information received from customers

Rereported by :

จันทิพรณ์ มิตตะกะ
Miss. Jantip Mittaka (ว-250-จ-0004)

Laboratory Analyst

17/2/25

Approved by :

Miss. Saowapa Nukaew (ว-250-ก-0002)

Laboratory Manager

17/2/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขที่ใบอนุญาต ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	February 7-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6802033

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	10.30 AM.
Analysis No.	25680541

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	100	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	264	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	114	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680541 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification. TIS 17025-2017. Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

17/2/25

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

17/2/25



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124
PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



NSC-TISI-TIS 17025
TESTING 0548

WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	March 7-14, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (ว-250-ท-0003)	Report No.	PKT6803039

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	11.03 AM.
Analysis No.	25680934

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.2 °C	-	SM : 4500-H ⁺ B	6.8	7.2-8.4

2.Total Dissolved Solids	mg/L	SM : 2510	632	-
--------------------------	------	-----------	-----	---

Physical Appearance Sample 25680934 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Information received from customers

Reported by : จันทิพ มิตตะกะ
Miss. Jantip Mittaka (ว-250-ท-0004)

Approved by : สมิสา นุกาแ้ว
Miss. Saowapa Nukaew (ว-250-ท-0002)

Laboratory Analyst
15 / 3 / 68

Laboratory Manager
15 / 3 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	March 7-14, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6803039

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	11.03 AM.
Analysis No.	25680934

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	75.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	318	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	100	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680934 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L.PE 2.0 L.G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

15 / 3 / 68

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

15 / 3 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

BANGKOK Tel. (033) 730 434, 426 8660 HUAHIN Tel. (032) 530 573, 515 173 SAMUI Tel. (077) 419 879, 89 PHANGNONG Tel. (076) 486 490



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	April 9-19, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (จ-250-ก-0003)	Report No.	PKT6804073

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.35 AM.
Analysis No.	25681414

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	6.8	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	694	-

Physical Appearance Sample 25681414 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Information received from customers

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (จ-250-ก-0004)

Laboratory Analyst

21 / 4 / 66

Approved by :

สาอวป นุกาอว
Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager

21 / 4 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน จ-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	April 9-19, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6804073

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	10.35 AM.
Analysis No.	25681414

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	73.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	318	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	200	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25681414 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพร มิตตะกา

Miss. Jantip Mittaka

Laboratory Analyst

21/1/25

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

21/1/25



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	May 20-27, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat (๖-250-๖-0003)	Report No.	PKT6805113

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.12 AM.
Analysis No.	25681952

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.4 °C	-	SM : 4500-H ¹ B	6.9	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	392	-

Physical Appearance	Sample	25681952 : Clear liquid, colorlss, no sediment	Container : Normal PE 1.0 L,PE 2.0 L,G 0.5 L
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023</p> <p>[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar</p> <p>[3] : Information received from customers</p>		

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (๖-250-๖-0004)

Approved by :

สาอวพา นุกะว
Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Analyst

๒๘/๕/๒๕

Laboratory Manager

๒๘/๕/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	May 20-27, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[4]	Miss. Yonlatda Thancerat	Report No.	PKT6805113

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	10.12 AM.
Analysis No.	25681952

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	70.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	201	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	133	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25681952 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพร มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

28, 5, 68

Approved by :

สาอวพา นุกาแคว

Miss. Saowapa Nukaew

Laboratory Manager

28, 5, 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
จังหวัดภูเก็ต การวิเคราะห์ทางเคมี

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE : 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 868 HUAHIN Tel. (032) 520 575, 515 173 SAMUI Tel. (077) 449 079, 80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	June 5-12, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (จ-250-ก-0003)	Report No.	PKT6806026

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.07 AM.
Analysis No.	25682131

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.2 °C	-	SM : 4500-H ¹ B	7.0	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	342	-

Physical Appearance Sample 25682131 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
 [2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
 [3] : Information received from customers

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (จ-250-ก-0004)

Laboratory Analyst

13 / 6 / 68

Approved by :

สาอวพา นุกะว
Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager

13 / 6 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกสาร
เลขทะเบียน จ-2550

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Aumthur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079, 80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	June 5-12, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6806026

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	10.07 AM.
Analysis No.	25682131

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	56.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	175	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	125	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682131 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

13 / 6 / 68

Approved by :

สาอวพา นุกาแว

Miss. Saowapa Nukaew

Laboratory Manager

13 / 6 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์คุณภาพ

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124
PATTAYA Tel. (038) 730 434 426 860 HUAHIN Tel. (032) 530 575 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	January 8-15, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6801030

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.43 AM.
Analysis No.	25680068

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 24.7 °C	-	SM : 4500-H ⁺ B	6.9	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	334	≤ 600

Physical Appearance Sample 25680068 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Information received from customers

Reported by :

จันทิพย์ มิตตะทา

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๖/๑/๒๕

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๑๖/๑/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกสาร
เลขทะเบียน ๖-250



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	January 8-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6801030

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.43 AM.
Analysis No.	25680068

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	156	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	108	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	0.1	≤ 0.30
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680068 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะมา

Miss. Jantip Mittaka

Laboratory Analyst

16 / 1 / 68

Approved by :

สาอวพา นุกาแ้ว

Miss. Saowapa Nukaew

Laboratory Manager

16 / 1 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์แอลเชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE**

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	February 7-15, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6802033

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.21 AM.
Analysis No.	25680540

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.1 °C	-	SM : 4500-H ¹ B	7.0	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	302	≤ 600

Physical Appearance Sample 25680540 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Information received from customers

Rreported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๗/๒/๒๕

Approved by :

Saowapa Nukaew

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๑๗/๒/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax: (02) 966 6005, 526 5124
PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	February 7-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6802033

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.21 AM.
Analysis No.	25680540

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	224	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	119	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680540 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater. APHA, AWWA, WEF., 24th Edition 2023

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

17, 2, 68

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

17, 2, 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 03, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATAYA Tel. (038) 230 434, 426 860 HUAIHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400

**BEST CHOICE****CHEMICALS & ENGINEERING CO.,LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	March 7-14, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๓-0003)	Report No.	PKT6803039

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.52 AM.
Analysis No.	25680933

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.3 °C	-	SM : 4500-H ¹ B	6.7	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	343	≤ 600

Physical Appearance Sample 25680933 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Information received from customers

Rreported by :

จันทิภาภรณ์ มิตตะกะ
Miss. Jantip Mittaka (๖-250-๓-0004)

Laboratory Analyst

15, 3, 16

Approved by :

สาอวพา นุกาอว
Miss. Saowapa Nukaew (๖-250-๓-0002)

Laboratory Manager

15, 3, 16

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 473 SAMUI Tel. (077) 419 679-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	March 7-14, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6803039

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.52 AM.
Analysis No.	25680933

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	156	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	121	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680933 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิภากรณ์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

15/3/25

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

15/3/25



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	April 9-19, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6804073

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.28 AM.
Analysis No.	25681413

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.1 °C	-	SM : 4500-H ¹ B	6.8	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	748	≤ 600

Physical Appearance Sample 25681413 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Information received from customers

Reported by :

จันทิพร มิตตะทา

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๑/๔/๒๕

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๑/๔/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124
PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumhur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	April 9-19, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6804073

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.28 AM.
Analysis No.	25681413

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	92.0	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	109	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25681413 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกา

Miss. Jantip Mittaka

Laboratory Analyst

21/4/68

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

21/4/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	May 20-27, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat (๖-250-๖-0003)	Report No.	PKT6805113

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.06 AM.
Analysis No.	25681951

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.5°C	-	SM : 4500-H ⁺ B	7.0	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	180	≤ 600

Physical Appearance	Sample	25681951 : Clear liquid, colorless, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24 th Edition 2023 [2] : According to the water quality standards of the Provincial Waterworks Authority 2024 [3] : Information received from customers		

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๘/๕/๒๕

Approved by :

สาอวพา นุกาอว
Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๘/๕/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
 72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
 E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
 Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	May 20-27, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6805113

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.06AM.
Analysis No.	25681951

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	180	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	110	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25681951 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

Miss. Jantip Mittaka

Laboratory Analyst

28, 5, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

28, 5, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
 พลังปฏิบัติการวิเคราะห์ทดสอบ

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	June 5-12, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (จ-250-ท-0003)	Report No.	PKT6806026

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	09.57 AM.
Analysis No.	25682130

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.2°C	-	SM : 4500-H ⁺ B	7.3	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	344	≤ 600

Physical Appearance Sample 25682130 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK
[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Information received from customers

Reported by : จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (จ-250-ท-0004)

Laboratory Analyst
13 / 6 / 65

Approved by : สาอวป นุกาเว
Miss. Saowapa Nukaew (จ-250-ท-0002)

Laboratory Manager
13 / 6 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน จ-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124
PATTAYA Tel. (038) 730 434, 426 880 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	June 5-12, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6806026

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	09.57 AM.
Analysis No.	25682130

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	212	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	105	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682130 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

13 / 6 / 68

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

13 / 6 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์คุณภาพ

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[4]	Guest room No.235	Analyzed Date	January 8-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6801030

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	11.04 AM.
Analysis No.	25680067

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680067 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

16 / 1 / 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

16 / 1 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[4]	Guest room No.133	Analyzed Date	February 7-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6802033

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.35 AM.
Analysis No.	25680539

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680539 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิภา มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

17 / 2 / 68

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

17 / 2 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE : 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434 426 860 HUAHIN Tel. (032) 530 575 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[4]	Guest room No.943	Analyzed Date	March 7-14, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[4]	Miss. Yonlatda Thanecrat	Report No.	PKT6803039

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	11.22 AM.
Analysis No.	25680932

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance	Sample	25680932 : Clear liquid, colorless, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023</p> <p>[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.</p> <p>[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[4] : Information received from customers</p> <p>[5] : < 1.8 = undetected by means of the Laboratory.</p>		

Reported by : จันทิพร มิตตะ
Miss. Jantip Mittaka
Laboratory Analyst
17/3/68

Approved by : สาอวพา นุกา
Miss. Saowapa Nukaew
Laboratory Manager
15/3/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[4]	Guest room No.535	Analyzed Date	April 9-19, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6804073

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	11.22 AM.
Analysis No.	25681412

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25681412 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

21 / 4 / 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

21 / 4 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[4]	Guest room No.135	Analyzed Date	May 20-27, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[4]	Miss. Yonlatda Thancerat	Report No.	PKT6805113

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.19 AM.
Analysis No.	25681950

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25681950 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

98.5.68

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

98.5.68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[4]	Guest room No.925	Analyzed Date	June 5-12, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6806026

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.43 AM.
Analysis No.	25682129

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682129 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

B, B, BS

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

B, B, BS

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	January 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	January 8, 2025
Sampling Source ^[4]	Ice Machine - Roof Tap	Analyzed Date	January 8-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	January 16, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6801030

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	11.08 AM.
Analysis No.	25680066

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680066 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L. PE 2.0 L. G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Ministry of Public Health No.78 (1984) and No.137 (1991), Ice Melt.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

16/1/25

Approved by :

สาอวพา นุกาแว

Miss. Saowapa Nukaew

Laboratory Manager

16/1/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE**

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	February 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	February 7, 2025
Sampling Source ^[4]	Ice Machine - Block J (New)	Analyzed Date	February 7-15, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	February 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6802033

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	10.44 AM.
Analysis No.	25680538

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680538 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Ministry of Public Health No.78 (1984) and No.137 (1991), Ice Melt.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka

Miss. Jantip Mittaka

Laboratory Analyst

17 / 2 / 68

Approved by :

สาอวพา นุกาอว
Miss. Saowapa Nukaew

Miss. Saowapa Nukaew

Laboratory Manager

17 / 2 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	March 6, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[4]	Ice Machine - Block J (New)	Analyzed Date	March 7-14, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	March 15, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6803039

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	11.25 AM.
Analysis No.	25680931

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25680931 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mitta

Laboratory Analyst

15, 3, 68

Approved by :

Don Nukaew

Miss. Saowapa Nukaew

Laboratory Manager

15, 3, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์คุณภาพ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4824 Fax. (02) 966 6005, 526 5124

PAETAYI Tel. (033) 720 424, 426 960 HUAYIN Tel. (032) 530 575, 545 173 SAMUI Tel. (077) 419 079-80 PHANGNICA Tel. (076) 486 400

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ช้อยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
 E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
 Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	April 9, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	April 9, 2025
Sampling Source ^[4]	Ice Machine - Rooftop	Analyzed Date	April 9-19, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	April 21, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6804073

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	10.40 AM.
Analysis No.	25681411

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25681411 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

21, 4, 68

Approved by :

สาอวพา นุกาแว

Miss. Saowapa Nukaew

Laboratory Manager

21, 4, 68

ACCREDITED LABORATORY GLP/DIW 2550

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



NSC-TISI-TIS 17025
TESTING 0548

WATER ANALYSIS REPORT

Page 5/10

Customer/Code	S.mui Beach Club Owner Limited	Sampling Date ^[4]	May 20, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	May 20, 2025
Sampling Source ^[4]	Ice Machine - Rooftop	Analyzed Date	May 20-27, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	May 28, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6805113

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	10.21 AM.
Analysis No.	25681949

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance	Sample	25681949 : Clear liquid, colorless, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023</p> <p>[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.</p> <p>[3] : Outside the scope of certification, TIS 17025-2017,Testing 0548</p> <p>[4] : Information received from customers</p> <p>[5] : < 1.8 = undetected by means of the Laboratory.</p>		

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

28/5/25

Approved by :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

28/5/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

HEAD OFFICE 16 Phiboonsongkram Rd., Tambol Suanyai Amphur Muangnonthaburi 11000 Tel. (02) 966 6001-4, 527 4524 Fax. (02) 966 6005, 526 5124

PATTAYA Tel. (038) 730 434, 426 860 HUAHIN Tel. (032) 530 575, 515 173 SAMUI Tel. (077) 419 079-80 PHANGNGA Tel. (076) 486 400



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	June 4, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[4]	Ice Machine - Ice Cube	Analyzed Date	June 5-12, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	June 13, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6806026

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	10.31 AM.
Analysis No.	25682128

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682128 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

13 / 6 / 68

Approved by :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

13 / 6 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	March 6, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[5]	Main Pool	Analyzed Date	March 7, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 25, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/03/L002

Sampling Name ^[5]	Swimming Pool Water
Sampling Time ^[5]	11.03 AM.
Analysis No.	L6803002

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6803002 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook. Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

จันทิพย์ มิตราคม

Miss. Jantip Mittak

Laboratory Analyst

25/3/68

Approved By :

สาอวพา นุกาแวง

Miss. Saowapa Nukaew

Laboratory Manager

25/3/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	March 6, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[5]	Guest Room No.943	Analyzed Date	March 7, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 25, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/03/L002

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	11.22 AM.
Analysis No.	L6803003

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6803003 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By : จันทิพร มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

25/3/68

Aproved By :

Miss. Saowapa Nukaew

Laboratory Manager

25/3/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 3/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	March 6, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[5]	Main Kitchen (Taurus Bar)	Analyzed Date	March 7, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 25, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/03/L002

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	11.18 AM.
Analysis No.	L6803004

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6803004 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DourmonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Disceases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Disceases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

จันทิพพร มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

25/3/68

Approved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

25/3/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumprhur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 4/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	March 6, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[5]	Raw Water Tank	Analyzed Date	March 7, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 25, 2025
Sampling By	Miss Yonlatda Thancerat	Report No.	PKT68/03/L002

Sampling Name ^[5]	Raw Water
Sampling Time ^[5]	10.54 AM.
Analysis No.	L6803005

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6803005 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DoumonE, Isolation Of Legionella from Clinical specimens,. In Harrsion TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Discases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Discases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

จันทิพย์ มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

๒๕ / ๓ / ๒๕

Aproved By :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

๒๕ / ๓ / ๒๕



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 5/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	March 6, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	March 7, 2025
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	March 7, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	March 25, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/03/L002

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.52 AM.
Analysis No.	L6803006

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6803006 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens., In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

จันทิพย์ มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

25/3/68

Aproved By :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

25/3/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	June 4, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[5]	Main Pool	Analyzed Date	June 5, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 25, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/06/L003

Sampling Name ^[5]	Swimming Pool Water
Sampling Time ^[5]	10.07 AM.
Analysis No.	L6806008

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6806008 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DourmonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

จันทิพ มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

25 / 6 / 68

Approved By :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

25 / 6 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
หลังปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	June 4, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[5]	Guest Room No.925	Analyzed Date	June 5, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 25, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/06/L003

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.43 AM.
Analysis No.	L6806009

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6806009 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W. and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention. U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

จันทิพ มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

25/6/68

Aproved By :

สาอวพา นุกะว

Miss. Saowapa Nukaw

Laboratory Manager

25/6/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written aproral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 3/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	June 4, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[5]	Main Kitchen	Analyzed Date	June 5, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 25, 2025
Sampling By	Miss Yonlatda Thanecrat	Report No.	PKT68/06/L003

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.33 AM.
Analysis No.	L6806010

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6806010 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark [1] : Pasculle, W. and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14
[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrsion TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.
[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.
[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University
[5] : Information received from customers

Reported By :

จันทิพย์ มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

25 / 6 / 68

Aproved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

25 / 6 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat Rd., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 4/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	June 4, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[5]	Raw Water Tank	Analyzed Date	June 5, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 25, 2025
Sampling By	Miss Yonlatda Thanecrat	Report No.	PKT68/06/L003

Sampling Name ^[5]	Raw Water
Sampling Time ^[5]	10.01 AM.
Analysis No.	L6806011

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6806011 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrsion TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

จันทิพย์ มิตตะ

Miss. Jantip Mittak

Laboratory Analyst

25/6/68

Aproved By :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

25/6/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ที่ตั้ง: 72/12 หมู่ 6 ซากดิดัด ถนนเทศบาลนครภูเก็ต อำเภอเมืองภูเก็ต จังหวัดภูเก็ต

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written aproral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 5/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	June 4, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	June 5, 2025
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	June 5, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	June 25, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/06/L003

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	09.57 AM.
Analysis No.	L6806012

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6806012 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrsion TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :




Miss. Jantip Mittak

Laboratory Analyst

25/6/68

Approved By :



Miss. Saowapa Nukaew

Laboratory Manager

25/6/68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.