



TESTING
NO.0001

Analysis/Test Report

Customer Name : Centara Grand Mirage Beach Resort Pattaya

Address : 277 Moo 5, Naklua, Banglamung, Pattaya, Chonburi 20150, Thailand

Sampling Site : Centara Grand (Pattaya)

Sample Type : Usage Water

Sampling by : Test Tech Co., Ltd.

Sampling Method : Grab

Sampling Date : 19/02/2025

Sampling Time : 10:30 AM


Received Date : 19/02/2025

Analytical Date : 19/02 - 03/03/2025

Report Date : 04/03/2025


Report No. : R04584/68

Parameters	Unit	Method	TW03606 /68	TW03607 /68	TW03608 /68	TW03609 /68
			Point 1 A1	Point 2 A1	Point 3 A2	Point 4 A2
			Head Shower	Head Shower	Head Shower	Head Shower
			Room (1218)	Room (1222)	Room (1224)	Room (1228)
Legionella spp.	/L	ISO 11731 : 2017	not detected	not detected	not detected	not detected
Sample Condition			Clear	Clear	Clear	Clear
Observation						



Analyst

04/03/2025



Technical Manager

04/03/2025

Reported results refer to the sample as received only.

Test report shall not be reproduced except in full, without written approved of the laboratory.

The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025

Analysis/Test Report

Customer Name : Centara Grand Mirage Beach Resort Pattaya

Address : 277 Moo 5, Naklua, Banglamung, Pattaya, Chonburi 20150, Thailand

Sampling Site : Centara Grand (Pattaya)

Sample Type : Usage Water

Sampling by : Test Tech Co., Ltd.

Sampling Method : Grab

Sampling Date : 19/02/2025

Sampling Time : 10:30 AM

Received Date : 19/02/2025

Analytical Date : 19/02 - 03/03/2025

Report Date : 04/03/2025

Report No. : R04585/68

Parameters	Unit	Method	TW03610 /68	TW03611 /68	TW03612 /68	TW03613 /68
			Point 5 A1 Condensate from FCU Room (1218)	Point 6 A1 Condensate from FCU Room (1222)	Point 7 A2 Condensate from FCU Room (1224)	Point 8 A2 Condensate from FCU Room (1228)
Legionella spp.	/L	ISO 11731 : 2017	not detected	not detected	not detected	not detected
Sample Condition		Observation	Clear	Clear	Clear	Clear

Analyst

04/03/2025

Technical Manager

04/03/2025

Reported results refer to the sample as received only.

Test report shall not be reproduced except in full, without written approved of the laboratory.

The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025

Analysis/Test Report

Customer Name : Centara Grand Mirage Beach Resort Pattaya

Address : 277 Moo 5, Naklua, Banglamung, Pattaya, Chonburi 20150, Thailand

Sampling Site : Centara Grand (Pattaya)

Sample Type : Usage Water

Sampling by : Test Tech Co., Ltd.

Sampling Method : Grab

Sampling Date : 19/02/2025

Sampling Time : 10:30 AM

Received Date : 19/02/2025

Analytical Date : 19/02 - 03/03/2025

Report Date : 04/03/2025

Report No. : R04586/68

Parameters	Unit	Method	TW03614 /68	TW03615 /68	TW03616 /68	TW03617 /68
			Point 9 Lazy River	Point 10 Main Pool	Point 11 Lab Pool	Point 12 Water in Storage Tank
Legionella spp.	/L	ISO 11731 : 2017	not detected	not detected	not detected	not detected
Sample Condition			Clear	Clear	Clear	Clear

Analyst

04/03/2025

Technical Manager

04/03/2025

Reported results refer to the sample as received only.

Test report shall not be reproduced except in full, without written approved of the laboratory.

The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025

Analysis/Test Report

Customer Name : Centara Grand Mirage Beach Resort Pattaya

Address : 277 Moo 5, Naklua, Banglamung, Pattaya, Chonburi 20150, Thailand

Sampling Site : Centara Grand (Pattaya)

Sample Type : Usage Water

Sampling by : Test Tech Co., Ltd.

Sampling Method : Grab

Sampling Date : 19/02/2025

Sampling Time : 10:30 AM

Received Date : 19/02/2025

Analytical Date : 19/02 - 03/03/2025

Report Date : 04/03/2025

Report No. : R04587/68

Parameters	Unit	Method	TW03618 /68	TW03619 /68	TW03620 /68
			Point 13 Jacuzzi (Fitness (M))	Point 14 Fitness (Locker M)	Point 18 Restaurant (Oasis)
Legionella spp.	/L	ISO 11731 : 2017	not detected	not detected	not detected
Sample Condition			Clear	Clear	Clear

Analyst

04/03/2025

Technical Manager

04/03/2025

Reported results refer to the sample as received only.

Test report shall not be reproduced except in full, without written approved of the laboratory.

The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025