

เอกสารแนบ 4

เอกสารผลการตรวจวัดคุณภาพสิ่งแวดล้อม



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อเกรอะ
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : ชุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : JANUARY 22, 2025
SAMPLING TIME : 14:00
SAMPLING BY : [REDACTED]

REPORT NO. : RN250110236
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : JANUARY 22, 2025
ANALYTICAL DATE : JANUARY 22-FEBRUARY 03, 2025
REPORT DATE : FEBRUARY 04, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD
pH	-	Electrometric (SM: 4500-H ⁺ B.)	7.4 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	110.0	2.0	-
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	5,330.0	-	-
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	104.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	10.2	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED., 2023 (AWWA, APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)

[REDACTED SIGNATURE]

LABORATORY SUPERVISOR

*** Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. ***

ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อพักน้ำใส
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : เทาขุ่น ไม่มีตะกอน ไม่มีกลิ่น
SAMPLING DATE : JANUARY 22, 2025
SAMPLING TIME : 14:00
SAMPLING BY : [REDACTED]
REPORT NO. : RN250110237
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : JANUARY 22, 2025
ANALYTICAL DATE : JANUARY 22-FEBRUARY 03, 2025
REPORT DATE : FEBRUARY 04, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD
pH	-	Electrometric (SM: 4500-H ⁺ B.)	7.8 at 25°C	-	5.5-9.0
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O ₂ G, 5210 B.)	9.0	2.0	≤20
Total Suspended Solids	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	36.0	-	≤30
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	7.8	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	Not Detected	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	1.1 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)


LABORATORY SUPERVISOR

*** Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory.***



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อเกรอะ
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : ดำขุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : FEBRUARY 13, 2025
SAMPLING TIME : 12:30
SAMPLING BY : [REDACTED]

REPORT NO. : RN250210408
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : FEBRUARY 13, 2025
ANALYTICAL DATE : FEBRUARY 13-25, 2025
REPORT DATE : FEBRUARY 26, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	7.0 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	24.0	2.0	-
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	930.0	-	-
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	12.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	2.4 x 10 ⁵	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. "ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

[REDACTED SIGNATURE]

LABORATORY SUPERVISOR

*** Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. ***




ANALYSIS REPORT

CUSTOMER NAME	: เดอะ ไลน์ พหลโยธิน พาร์ค (อาคาร ซี)	REPORT NO.	: RN250210409
ADDRESS	: ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.	SAMPLING SOURCE	: WASTEWATER
SAMPLING LOCATION	: บ่อพักน้ำใส	RECEIVED DATE	: FEBRUARY 13, 2025
SAMPLING METHOD	: GRAB	ANALYTICAL DATE	: FEBRUARY 13-25, 2025
SAMPLING CONDITION	: NORMAL	REPORT DATE	: FEBRUARY 26, 2025
CHARACTERISTICS OF WATER	: เหลืองขุ่น ไม่มีตะกอน มีกลิ่น		
SAMPLING DATE	: FEBRUARY 13, 2025		
SAMPLING TIME	: 12:30		
SAMPLING BY	: [REDACTED]		

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	8.0 at 25°C	-	5.5-9.0
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O ₂ G, 5210 B.)	21.0	2.0	≤20
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	14.0	-	≤30
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	11.0	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	1.5 x 10 ⁵	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. * Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. [#] ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)



LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อเกรอะ
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : ดำขุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : MARCH 19, 2025
SAMPLING TIME : 14:30
SAMPLING BY : [REDACTED]
REPORT NO. : RN250310644
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : MARCH 19, 2025
ANALYTICAL DATE : MARCH 19-26, 2025
REPORT DATE : MARCH 27, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H ⁺ B.)	7.5 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Azide Modification (SM: 4500-O C, 5210 B.)	32.5	2.0	-
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	7,500.0	-	-
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	24.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. [#] ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

[REDACTED]
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พลอยอิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อพักน้ำใส
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : เหลืองขุ่น ไม่มีตะกอน มีกลิ่น
SAMPLING DATE : MARCH 19, 2025
SAMPLING TIME : 14:30
SAMPLING BY : [REDACTED]

REPORT NO. : RN250310645
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : MARCH 19, 2025
ANALYTICAL DATE : MARCH 19-26, 2025
REPORT DATE : MARCH 27, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH	-	Electrometric (SM: 4500-H ⁺ B.)	8.2 at 25°C	-	5.5-9.0
Biochemical Oxygen Demand	mg/l	Azide Modification (SM: 4500-O C, 5210 B.)	23.5	2.0	≤20
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	28.0	-	≤30
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	10.0	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 × 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. [#]ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

[REDACTED SIGNATURE]

LABORATORY SUPERVISOR




ANALYSIS REPORT

CUSTOMER NAME	: เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)	REPORT NO.	: RN250410921
ADDRESS	: ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.	SAMPLING SOURCE	: WASTEWATER
SAMPLING LOCATION	: บ่อเกรอะ	RECEIVED DATE	: APRIL 17, 2025
SAMPLING METHOD	: GRAB	ANALYTICAL DATE	: APRIL 17-24, 2025
SAMPLING CONDITION	: NORMAL	REPORT DATE	: APRIL 25, 2025
CHARACTERISTICS OF WATER	: ดำขุ่น มีตะกอน มีกลิ่น		
SAMPLING DATE	: APRIL 17, 2025		
SAMPLING TIME	: 11:20		
SAMPLING BY	: [REDACTED]		

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	7.3 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	50.4	2.0	-
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	15,010.0	-	-
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	45.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	8.0	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. [#] ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)



LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อพักน้ำใส
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : เหลืองขุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : APRIL 17, 2025
SAMPLING TIME : 11:20
SAMPLING BY : [REDACTED]
REPORT NO. : RN250410922
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : APRIL 17, 2025
ANALYTICAL DATE : APRIL 17-24, 2025
REPORT DATE : APRIL 25, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	8.0 at 25°C	-	5.5-9.0
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O ₂ G, 5210 B.)	18.6	2.0	≤20
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	34.0	-	≤30
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	11.0	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. [#] ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

[REDACTED SIGNATURE]

LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อเกรอะ
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : ดำขุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : MAY 21, 2025
SAMPLING TIME : 12:00
SAMPLING BY : [REDACTED]
REPORT NO. : RN250511183
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : MAY 21, 2025
ANALYTICAL DATE : MAY 21 - JUNE 02, 2025
REPORT DATE : JUNE 04, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	7.6 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O ₂ G, 5210 B.)	71.0	2.0	-
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	2,660.0	-	-
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	54.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. * Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. [#] ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

[REDACTED]
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พลอยอิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพลอยอิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อพักน้ำใส
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : เหลืองขุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : MAY 21, 2025
SAMPLING TIME : 12:00
SAMPLING BY : [REDACTED]

REPORT NO. : RN250511184
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : MAY 21, 2025
ANALYTICAL DATE : MAY 21 - JUNE 02, 2025
REPORT DATE : JUNE 04, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	7.7 at 25°C	-	5.5-9.0
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O ₂ G, 5210 B.)	14.6	2.0	≤20
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	56.0	-	≤30
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	9.8	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. [#]ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)



LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อเกรอะ
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : น้ำตาลขุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : JUNE 17, 2025
SAMPLING TIME : 13:00
SAMPLING BY : [REDACTED]

REPORT NO. : RN250611336
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : JUNE 17, 2025
ANALYTICAL DATE : JUNE 17-26, 2025
REPORT DATE : JUNE 27, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	7.3 at 25°C	-	-
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	123.0	2.0	-
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	435.0	-	-
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	-
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	76.0	-	-
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	-
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)

2. [#]ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

[REDACTED SIGNATURE]

LABORATORY SUPERVISOR

*** Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. ***



ห้องปฏิบัติการวิเคราะห์บริษัท โอกลา เทสต์ติ้ง แอนด์ คอนซัลติ้ง เซอร์วิส จำกัด

63/13 เพชรเกษม ซอย 7 แขวงวัดท่าพระ เขตบางกอกใหญ่ กรุงเทพฯ 10600

Tel: [REDACTED] www.okla-testing.com J-NAC Group



TESTING
No.0334

ANALYSIS REPORT

CUSTOMER NAME : เดอะ ไกล์ พหลโยธิน พาร์ค (อาคาร ดี)
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.
SAMPLING LOCATION : บ่อพักน้ำใส
SAMPLING METHOD : GRAB
SAMPLING CONDITION : NORMAL
CHARACTERISTICS OF WATER : เหลืองขุ่น มีตะกอน มีกลิ่น
SAMPLING DATE : JUNE 17, 2025
SAMPLING TIME : 13:00
SAMPLING BY : [REDACTED]
REPORT NO. : RN250611337
SAMPLING SOURCE : WASTEWATER
RECEIVED DATE : JUNE 17, 2025
ANALYTICAL DATE : JUNE 17-26, 2025
REPORT DATE : JUNE 27, 2025

PARAMETER	UNIT	METHODS OF ANALYSIS	RESULT	MDL	STANDARD*
pH [#]	-	Electrometric (SM: 4500-H ⁺ B.)	7.7 at 25°C	-	5.5-9.0
Biochemical Oxygen Demand	mg/l	Membrane Electrode (SM: 4500-O G, 5210 B.)	13.0	2.0	≤20
Total Suspended Solids [#]	mg/l	Total Suspended Solids Dried at 103-105°C (SM: 2540 D.)	86.0	-	≤30
Sulfide as H ₂ S	mg/l	Iodometric (SM: 4500-S ²⁻ F.)	<1.0	-	≤1.0
Total Kjeldahl Nitrogen	mg/l	Macro Kjeldahl (SM: 4500-N _{org} B)	9.2	-	≤35
Oil & Grease	mg/l	Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)	<5.0	1.4	≤20
Total Coliform Bacteria	MPN/100 ml	MPN Test	>2.4 x 10 ⁶	-	-

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24th ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)

2. [#]ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

[REDACTED]
LABORATORY SUPERVISOR

*** Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. ***