

ANALYSIS REPORT

Data Provided by Customer


Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อปรับสภาพน้ำเสีย
GPS. Coordinate : 47 P 673076 E 1516635 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/1
Sample Type : Wastewater
Sampling Date : 30 January 2025
Sampling Time : 01.19 p.m.
Received Date : 31 January 2025
Analytical Date : 31 January – 19 February 2025
Report Date : 20 February 2025

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 25 °C	-	Electrometric Method (4500-H ⁺ B)	7.6
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	37.4
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	342
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O ₂ G, 5210 B)	35.1
Fat, Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.1
Total Kjeldahl Nitrogen ^{2/}	mg/L	Based on Standard Methods for Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, part 4500-Norg B and part 4500-NH ₃ C	64.82
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
^{2/} Analyzed by SGS (Thailand) Limited, Environmental Laboratory (Rayong Branch) registration number Wo - 197.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : ปอ๊กก้นน้ำเวียนกลับ
GPS. Coordinate : 47 P 673097 E 1516617 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/2
Sample Type : Wastewater
Sampling Date : 30 January 2025
Sampling Time : 01.24 p.m.
Received Date : 31 January 2025
Analytical Date : 31 January – 19 February 2025
Report Date : 20 February 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 25 °C	-	Electrometric Method (4500-H ⁺ B)	6.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	23.6	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	296	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5- Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	7.5	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	Based on Standard Methods for Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, part 4500-Norg B and part 4500-NH ₃ C	15.33	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by SGS (Thailand) Limited, Environmental Laboratory (Rayong Branch) registration number Wo-197.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อตรวจคุณภาพน้ำทิ้ง
GPS. Coordinate : 47 P 673078 E 1516596 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/3
Sample Type : Wastewater
Sampling Date : 30 January 2025
Sampling Time : 01.28 p.m.
Received Date : 31 January 2025
Analytical Date : 31 January – 19 February 2025
Report Date : 20 February 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 25 °C	-	Electrometric Method (4500-H ⁺ B)	6.3	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	23.7	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	274	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	8.8	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ² F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	Based on Standard Methods for Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, part 4500-Norg B and part 4500 - NH ₃ C	16.14	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A-

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by SGS (Thailand) Limited, Environmental Laboratory (Rayong Branch) registration number Wo-197.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673074 E 1516613 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/4
Sample Type : Swimming pool Water
Sampling Date : 30 January 2025
Sampling Time : 01.14 p.m.
Received Date : 31 January 2025
Analytical Date : 31 January – 11 February 2025
Report Date : 13 February 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อปรับสภาพน้ำเสีย
GPS. Coordinate : 47 P 673079 E 1516637 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68027
Sample No. : W68027/1
Sample Type : Wastewater
Sampling Date : 17 February 2025
Sampling Time : 02.23 p.m.
Received Date : 18 February 2025
Analytical Date : 18 February – 07 March 2025
Report Date : 10 March 2025

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 25.8 °C	-	Electrometric Method (4500-H ⁺ B)	7.3
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	48.9
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	399
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	44.4
Fat, Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.7
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	0.61
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B)	52
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อกักน้ำเวียนกลับ
GPS. Coordinate : 47 P 673100 E 1516626 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/2
Sample Type : Wastewater
Sampling Date : 17 February 2025
Sampling Time : 02.27 p.m.
Received Date : 18 February 2025
Analytical Date : 18 February – 07 March 2025
Report Date : 10 March 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 25.5 °C	-	Electrometric Method (4500-H ⁺ B)	7.0	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	17.9	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	392	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5- Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	16.1	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ² F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B)	13	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อตรวจคุณภาพน้ำทิ้ง
GPS. Coordinate : 47 P 673063 E 1516590 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/3
Sample Type : Wastewater
Sampling Date : 17 February 2025
Sampling Time : 02.35 p.m.
Received Date : 18 February 2025
Analytical Date : 18 February – 07 March 2025
Report Date : 10 March 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 25.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.0	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	16.8	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	380	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	15.7	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B)	12	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	92,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029..

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคผลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673059 E 1516603 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/4
Sample Type : Swimming pool Water
Sampling Date : 17 February 2025
Sampling Time : 02.12 p.m.
Received Date : 18 February 2025
Analytical Date : 18 February – 03 March 2025
Report Date : 04 March 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 673081 E 1516625 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/5
Sample Type : Swimming pool Water
Sampling Date : 17 February 2025
Sampling Time : 02.13 p.m.
Received Date : 18 February 2025
Analytical Date : 18 February – 03 March 2025
Report Date : 04 March 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer


Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อปรับสภาพน้ำเสีย
GPS. Coordinate : 47 P 673069 E 1516630 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/1
Sample Type : Wastewater
Sampling Date : 18 March 2025
Sampling Time : 02.19 p.m.
Received Date : 19 March 2025
Analytical Date : 19 – 31 March 2025
Report Date : 01 April 2025

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 25.6 °C	-	Electrometric Method (4500-H ⁺ B)	7.4
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	27.2
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	349
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O ₂ G, 5210 B)	111
Fat, Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0
Sulfide *	mg/L	Iodometric Method (4500-S ₂ ²⁻ F)	1.81
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	52
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.
^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อกักน้ำเวียนกลับ
GPS. Coordinate : 47 P 673097 E 1516634 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/2
Sample Type : Wastewater
Sampling Date : 18 March 2025
Sampling Time : 02.15 p.m.
Received Date : 19 March 2025
Analytical Date : 19 – 31 March 2025
Report Date : 01 April 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 25.5 °C	-	Electrometric Method (4500-H ⁺ B)	7.2	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	19.1	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	346	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5- Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	11.3	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.2	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	20	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	160,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อตรวจคุณภาพน้ำทิ้ง
GPS. Coordinate : 47 P 673073 E 1516604 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/3
Sample Type : Wastewater
Sampling Date : 18 March 2025
Sampling Time : 02.08 p.m.
Received Date : 19 March 2025
Analytical Date : 19 – 31 March 2025
Report Date : 01 April 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 26.6 °C	-	Electrometric Method (4500-H ⁺ B)	7.2	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	13.7	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	342	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	17.8	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	24	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนเล็ก
GPS. Coordinate : 47 P 673054 E 1516630 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/4
Sample Type : Swimming pool Water
Sampling Date : 18 March 2025
Sampling Time : 02.05 p.m.
Received Date : 19 March 2025
Analytical Date : 19 – 28 March 2025
Report Date : 31 March 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673054 E 1516630 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/4
Sample Type : Swimming pool Water
Sampling Date : 18 March 2025
Sampling Time : 02.05 p.m.
Received Date : 19 March 2025
Analytical Date : 19 – 28 March 2025
Report Date : 31 March 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 673046 E 1516587 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/5
Sample Type : Swimming pool Water
Sampling Date : 18 March 2025
Sampling Time : 02.04 p.m.
Received Date : 19 March 2025
Analytical Date : 19 – 28 March 2025
Report Date : 31 March 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



Analyst

Laboratory Manager

ANALYSIS REPORT

Data Provided by Customer


Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อปรับสภาพน้ำเสีย
GPS. Coordinate : 47 P 673069 E 1516630 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/1
Sample Type : Wastewater
Sampling Date : 22 April 2025
Sampling Time : 03.23 p.m.
Received Date : 23 April 2025
Analytical Date : 23 April – 06 May 2025
Report Date : 07 May 2025

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 22.8 °C	-	Electrometric Method (4500-H ⁺ B)	7.3
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	56.9
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	490
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O ₂ G, 5210 B)	44.6
Fat, Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	3.5
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	0.91
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	30
Total Kjeldahl Nitrogen * ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	62
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.
^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.
 * This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อกักน้ำเวียนกลับ
GPS. Coordinate : 47 P 673097 E 1516634 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/2
Sample Type : Wastewater
Sampling Date : 22 April 2025
Sampling Time : 03.31 p.m.
Received Date : 23 April 2025
Analytical Date : 23 April – 06 May 2025
Report Date : 07 May 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 22.9 °C	-	Electrometric Method (4500-H ⁺ B)	7.1	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	12.8	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	484	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5- Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	< 2.0	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.2	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	13	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อตรวจคุณภาพน้ำทิ้ง
GPS. Coordinate : 47 P 673073 E 1516604 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/3
Sample Type : Wastewater
Sampling Date : 22 April 2025
Sampling Time : 03.36 p.m.
Received Date : 23 April 2025
Analytical Date : 23 April – 06 May 2025
Report Date : 07 May 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 22.2 °C	-	Electrometric Method (4500-H ⁺ B)	7.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	< 5.0	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	236	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	< 2.0	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	2	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	-
Sample Appearance		Clear/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673054 E 1516630 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/4
Sample Type : Swimming pool Water
Sampling Date : 22 April 2025
Sampling Time : 03.43 p.m.
Received Date : 23 April 2025
Analytical Date : 23 April – 06 May 2025
Report Date : 07 May 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.





TNP ENVIRONMENT CO.,LTD.

เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273

E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่



NSC-TISI-TIS 17025

Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 673046 E 1516587 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/5
Sample Type : Swimming pool Water
Sampling Date : 22 April 2025
Sampling Time : 03.44 p.m.
Received Date : 23 April 2025
Analytical Date : 23 April – 06 May 2025
Report Date : 07 May 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตินุศลาคารชุด เตอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อปรับสภาพน้ำเสีย
GPS. Coordinate : 47 P 673089 E 1516648 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/1
Sample Type : Wastewater
Sampling Date : 20 May 2025
Sampling Time : 04.25 p.m.
Received Date : 21 May 2025
Analytical Date : 21 May – 03 June 2025
Report Date : 04 June 2025


Parameter	Unit	Analytical Method ^{1/}	Result
pH at 23.8 °C	-	Electrometric Method (4500-H ⁺ B)	7.4
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	22.2
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	414
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	57.4
Fat, Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.18
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	63
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อกักน้ำเวียนกลับ
GPS. Coordinate : 47 P 673105 E 1516634 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/2
Sample Type : Wastewater
Sampling Date : 20 May 2025
Sampling Time : 04.29 p.m.
Received Date : 21 May 2025
Analytical Date : 21 May – 03 June 2025
Report Date : 04 June 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.1 °C	-	Electrometric Method (4500-H ⁺ B)	7.4	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	12.3	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	360	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	25.1	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	31	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	35,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	28,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตินุศลาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อตรวจคุณภาพน้ำทิ้ง
GPS. Coordinate : 47 P 673075 E 1516607 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/3
Sample Type : Wastewater
Sampling Date : 20 May 2025
Sampling Time : 04.33 p.m.
Received Date : 21 May 2025
Analytical Date : 21 May – 03 June 2025
Report Date : 04 June 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.4	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	11.5	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	310	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	17.7	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	26	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	22,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	17,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673071 E 1516623 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/4
Sample Type : Swimming pool Water
Sampling Date : 20 May 2025
Sampling Time : 04.20 p.m.
Received Date : 21 May 2025
Analytical Date : 21 May – 03 June 2025
Report Date : 04 June 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 673082 E 1516613 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/5
Sample Type : Swimming pool Water
Sampling Date : 20 May 2025
Sampling Time : 04.20 p.m.
Received Date : 21 May 2025
Analytical Date : 21 May – 03 June 2025
Report Date : 04 June 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อปรับสภาพน้ำเสีย
GPS. Coordinate : 47 P 673077 E 1516626 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/1
Sample Type : Wastewater
Sampling Date : 17 June 2025
Sampling Time : 03.13 p.m.
Received Date : 18 June 2025
Analytical Date : 18 June - 02 July 2025
Report Date : 03 July 2025


Parameter	Unit	Analytical Method ^{1/}	Result
pH at 23.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.4
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	36.3
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	328
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	90.3
Fat, Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.9
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	0.81
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.2
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	61
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อกักน้ำเวียนกลับ
GPS. Coordinate : 47 P 673100 E 1516628 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/2
Sample Type : Wastewater
Sampling Date : 17 June 2025
Sampling Time : 03.17 p.m.
Received Date : 18 June 2025
Analytical Date : 18 June - 02 July 2025
Report Date : 03 July 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.4 °C	-	Electrometric Method (4500-H ⁺ B)	7.0	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	25.4	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	350	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	19.6	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	20	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : ป้อมตรวจคุณภาพน้ำทิ้ง
GPS. Coordinate : 47 P 673070 E 1516597 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68027
Sample No. : W68027/3
Sample Type : Wastewater
Sampling Date : 17 June 2025
Sampling Time : 03.22 p.m.
Received Date : 18 June 2025
Analytical Date : 18 June - 02 July 2025
Report Date : 03 July 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.1 °C	-	Electrometric Method (4500-H ⁺ B)	6.9	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	25.5	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	312	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	16.3	≤ 20
Fat, Oil and Grease *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 2.0	≤ 20
Sulfide *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{*2/}	mg/L	APHA:4500-Norg (B) ^{3/}	22	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



Analyst

Laboratory Manager

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673074 E 1516621 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/4
Sample Type : Swimming pool Water
Sampling Date : 17 June 2025
Sampling Time : 03.07 p.m.
Received Date : 18 June 2025
Analytical Date : 18 June - 02 July 2025
Report Date : 03 July 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ เบส พาร์คอีสต์ สุขุมวิท 77
Project Name : โครงการ THE BASE PARK EAST
Address Project : เลขที่ 99 ซอยริมคลองพระโขนง แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 673069 E 1516596 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68027
Sample No : W68027/5
Sample Type : Swimming pool Water
Sampling Date : 17 June 2025
Sampling Time : 03.07 p.m.
Received Date : 18 June 2025
Analytical Date : 18 June - 02 July 2025
Report Date : 03 July 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

