

ภาคผนวก ช-3

---

การตรวจสอบอุปกรณ์ดับเพลิง

Emergency lighting Tower A				Emergency lighting Tower B			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	Po		Exit Stair FL-B1	Y	Po	
Exit Stair FL-B2	Y	Po		Exit Stair FL-B2	Y	Po	
Exit Stair FL-G	Y	Po		Exit Stair FL-G	Y	Po	
Exit Stair FL-2	Y	Po		Exit Stair FL-2	Y	Po	
Exit Stair FL-3	Y	Po		Exit Stair FL-3	Y	Po	5000211125
Exit Stair FL-4	Y	Po		Exit Stair FL-4	Y	Po	
Exit Stair FL-5	Y	Po		Exit Stair FL-5	Y	Po	
Exit Stair FL-6	Y	Po		Exit Stair FL-6	Y	Po	2010/21125
Exit Stair FL-7	Y	Po		Exit Stair FL-7	Y	Po	
Exit Stair FL-8	Y	Po		Exit Stair FL-8	Y	Po	501021125
Main Stair FL-B1 #1	Y	Po		Main Stair FL-B2	Y	Po	
Main Stair FL-B1 #2	Y	Po		Main Stair FL-B1 #1	Y	Po	
Main Stair FL-B2	Y	Po		Main Stair FL-B1 #2	Y	Po	
Main Stair FL-G	Y	Po		Main Stair FL-G	Y	Po	
Main Stair FL-2	Y	Po		Main Stair FL-2	Y	Po	
Main Stair FL-3	Y	Po		Main Stair FL-3	Y	Po	
Main Stair FL-4	Y	Po		Main Stair FL-4	Y	Po	
Main Stair FL-5	Y	Po		Main Stair FL-5	Y	Po	
Main Stair FL-6	Y	Po		Main Stair FL-6	Y	Po	
Main Stair FL-7	Y	Po		Main Stair FL-7	Y	Po	
Main Stair FL-8	Y	Po		Main Stair FL-8	Y	Po	
Hall lift staff FL-B1	Y	Po		Owner Office	Y	Po	
Hall lift staff FL-B2	Y	Po		GM Office	Y	Po	
Lift Hall tower A FL-B1	Y	Po		FC Office	Y	Po	
Lift Hall tower A FL-B2	Y	Po		AC Office	Y	Po	
Lift Hall tower A FL-B1	Y	Po		HK Office	Y	Po	
Lift Hall tower A FL-B2	Y	Po		FO Office	Y	Po	
Fl. pump room	Y	Po		HR Office	Y	Po	
Store Eng.	Y	Po		Canteen	Y	Po	
FB Store	Y	Po		Car park P3 #1	Y	Po	
HK Store	Y	Po		Car park P3 #2	Y	Po	
Kitchen Store	Y	Po		Car park P3 #3	Y	Po	
Server Room	Y	Po		Car park P3 #4	Y	Po	
Main kitchen# 1	Y	Po		Car park P4 (1)	Y	Po	
Main kitchen# 2	Y	Po		Car park P4 #1	Y	Po	
Generator room	Y	Po		Car park P4 #2	Y	Po	
MDB room 1	Y	Po		Car park P4 #3	Y	Po	
MDB room 2	Y	Po					
Checked By Supervisor				Date			
Approve By Chief Engineer				Date			



Emergency lighting Tower A				Emergency lighting Tower B			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	X	[Signature]		Exit Stair FL-B1	X	[Signature]	
Exit Stair FL-B2	X		Exit Stair FL-B2	X			
Exit Stair FL-G	X		Exit Stair FL-G	X			
Exit Stair FL-2	X		Exit Stair FL-2	X			
Exit Stair FL-3	X		Exit Stair FL-3	X	20/12/25 12:07		
Exit Stair FL-4	X		Exit Stair FL-4	X			
Exit Stair FL-5	X		Exit Stair FL-5	X			
Exit Stair FL-6	X		Exit Stair FL-6	X	20/12/25 12:07		
Exit Stair FL-7	X		Exit Stair FL-7	X			
Exit Stair FL-8	X		Exit Stair FL-8	X			
Main Stair FL-B1 #1	X		Main Stair FL- B2	X			
Main Stair FL-B1 #2	X		Main Stair FL-B1 #1	X			
Main Stair FL- B2	X		Main Stair FL-B1 #2	X			
Main Stair FL-G	X		Main Stair FL-G	X			
Main Stair FL-2	X		Main Stair FL-2	X			
Main Stair FL-3	X		Main Stair FL-3	X			
Main Stair FL-4	X		Main Stair FL-4	X			
Main Stair FL-5	X		Main Stair FL-5	X			
Main Stair FL-6	X		Main Stair FL-6	X			
Main Stair FL-7	X		Main Stair FL-7	X			
Main Stair FL-8	X		Main Stair FL-8	X	20/12/25 12:07		
Hall lift staff FL-B1	X		Owner Office	X			
Hall lift staff FL-B2	X		GM Office	X			
Lift Hall tower A FL.B1	X		FC Office	X			
Lift Hall tower A FL.B2	X		AC Office	X			
FL-B1	X		HK Office	X			
FL pump room	X		FO Office	X			
Store Eng.	X		HR Office	X			
FB Store	X		Canteen	X			
HK Store	X		Car park P3 #1	X			
Kitchen Store	X		Car park P3 #2	X			
Server Room	X		Car park P3 #3	X			
Main kitchen# 1	X	Car park P3 #4	X				
Main kitchen# 2	X	Car park P4 (1)	X				
Gennerator room	X	Car park P4 #1	X				
MDB room 1	X	Car park P4 #2	X				
MDB room 2	X	Car park P4 #3	X				

Checked By Supervisor	[Signature]	Date	21/2/25
Approve By Chief Engineer		Date	21/2/25



Emergency lighting Tower A				Emergency lighting Tower B			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	Deer		Exit Stair FL-B1	Y	De	
Exit Stair FL-B2	Y	Deer		Exit Stair FL-B2	Y	De	
Exit Stair FL-G	Y	De		Exit Stair FL-G	Y	De	
Exit Stair FL-2	Y	De		Exit Stair FL-2	Y	De	
Exit Stair FL-3	Y	Deer		Exit Stair FL-3	Y	De	2015 2016
Exit Stair FL-4	Y	Deer		Exit Stair FL-4	Y	De	
Exit Stair FL-5	Y	Deer		Exit Stair FL-5	Y	De	
Exit Stair FL-6	Y	Deer		Exit Stair FL-6	Y	De	2015 2016
Exit Stair FL-7	Y	Deer		Exit Stair FL-7	Y	De	
Exit Stair FL-8	Y	Deer		Exit Stair FL-8	Y	De	
Main Stair FL-B1 #1	Y	Deer		Main Stair FL- B2	Y	De	
Main Stair FL-B1 #2	Y	Deer		Main Stair FL-B1 #1	Y	De	
Main Stair FL- B2	Y	Deer		Main Stair FL-B1 #2	Y	De	
Main Stair FL-G	Y	Deer		Main Stair FL-G	Y	De	
Main Stair FL-2	Y	Deer		Main Stair FL-2	Y	De	
Main Stair FL-3	Y	Deer		Main Stair FL-3	Y	De	
Main Stair FL-4	Y	Deer		Main Stair FL-4	Y	De	
Main Stair FL-5	Y	Deer		Main Stair FL-5	Y	De	
Main Stair FL-6	Y	Deer		Main Stair FL-6	Y	De	
Main Stair FL-7	Y	Deer		Main Stair FL-7	Y	De	
Main Stair FL-8	Y	Deer		Main Stair FL-8	Y	De	
Hall lift staff FL-B1	Y	Deer		Owner Office	Y	De	
Hall lift staff FL-B2	Y	Deer		GM Office	Y	De	
Lift Hall tower A FL.B1	Y	Deer		FC Office	Y	De	
Lift Hall tower A FL.B2	Y	Deer		AC Office	Y	De	
Car lift FL-B1	Y	Deer		HK Office	Y	De	
Fire pump room	Y	Deer		FO Office	Y	De	
Store Eng.	Y	Deer		HR Office	Y	De	
FB Store	Y	Deer		Canteen	Y	De	
HK Store	Y	Deer		Car park P3 #1	Y	De	
Kitchen Store	Y	Deer		Car park P3 #2	Y	De	
Server Room	Y	Deer		Car park P3 #3	Y	De	
Main kitchen# 1	Y	Deer		Car park P3 #4	Y	De	
Main kitchen# 2	Y	Deer		Car park P4 (1)	Y	De	
Generator room	Y	Deer		Car park P4 #1	Y	De	
MDB room 1	Y	Deer		Car park P4 #2	Y	De	
MDB room 2	Y	Deer		Car park P4 #3	Y	De	

Checked By Supervisor		Date	11/3/25
Approve By Chief Engineer		Date	2/3/25

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	Po		Exit Stair FL-B1	Y	Po	
Exit Stair FL-B2	Y	Po		Exit Stair FL-B2	Y	Po	
Exit Stair FL-G	Y	Po		Exit Stair FL-G	Y	Po	
Exit Stair FL-2	Y	Po		Exit Stair FL-2	Y	Po	
Exit Stair FL-3	Y	Po		Exit Stair FL-3	N	Po	2020/12/25
Exit Stair FL-4	Y	Po		Exit Stair FL-4	Y	Po	
Exit Stair FL-5	Y	Po		Exit Stair FL-5	Y	Po	
Exit Stair FL-6	Y	Po		Exit Stair FL-6	N	Po	2020/12/25
Exit Stair FL-7	Y	Po		Exit Stair FL-7	Y	Po	
Exit Stair FL-8	Y	Po		Exit Stair FL-8	N	Po	2020/12/25
Main Stair FL-B1#1	Y	Po		Main Stair FL-B1#1	Y	Po	
Main Stair FL-B1#2	Y	Po		Main Stair FL-B1#2	Y	Po	
Main Stair FL-B2	Y	Po		Main Stair FL-B2	Y	Po	
Main Stair FL-G	Y	Po		Main Stair FL-G	Y	Po	
Main Stair FL-2	Y	Po		Main Stair FL-2	Y	Po	
Main Stair FL-3	Y	Po		Main Stair FL-3	Y	Po	
Main Stair FL-4	Y	Po		Main Stair FL-4	Y	Po	
Main Stair FL-5	Y	Po		Main Stair FL-5	Y	Po	
Main Stair FL-6	Y	Po		Main Stair FL-6	Y	Po	
Main Stair FL-7	Y	Po		Main Stair FL-7	Y	Po	
Main Stair FL-8	Y	Po		Main Stair FL-8	Y	Po	
Hall lift staff FL-B1	Y	Po		Owner Office	Y	Po	
Hall lift staff FL-B2	Y	Po		GM Office	Y	Po	
Lift Hall tower A EL.B1	Y	Po		FC Office	Y	Po	
Lift Hall tower A EL.B2	Y	Po		AC Office	Y	Po	
Car lift FL-B1	Y	Po		HK Office	Y	Po	
Fire pump room	Y	Po		FO Office	Y	Po	
Store Eng.	Y	Po		HR Office	Y	Po	
FB Store	Y	Po		Canteen	Y	Po	
HK Store	Y	Po		Car park P3 #1	Y	Po	
Kitchen Store	Y	Po		Car park P3 #2	Y	Po	
Sever Room	Y	Po		Car park P3 #3	Y	Po	
Main Kitchen#1	Y	Po		Car park P3 #4	Y	Po	
Main Kitchen#2	Y	Po		Car park P4 #1	Y	Po	
Generator room	Y	Po		Car park P4 #2	Y	Po	
MDB room 1	Y	Po		Car park P4 #3	Y	Po	
MDB room 2	Y	Po		Car park P4 #4	Y	Po	

Checked By Supervisor

Date

21/12/25

Approve By Chief Engineer

Date

21/12/25

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	Do		Exit Stair FL-B1	Y	Do	
Exit Stair FL-B2	Y	Do		Exit Stair FL-B2	Y	Do	
Exit Stair FL-G	Y	Do		Exit Stair FL-G	Y	Do	
Exit Stair FL-2	Y	Do		Exit Stair FL-2	Y	Do	
Exit Stair FL-3	Y	Do		Exit Stair FL-3	N	Do	ตรวจสอบ
Exit Stair FL-4	Y	Do		Exit Stair FL-4	Y	Do	
Exit Stair FL-5	Y	Do		Exit Stair FL-5	Y	Do	
Exit Stair FL-6	Y	Do		Exit Stair FL-6	N	Do	ตรวจสอบ
Exit Stair FL-7	Y	Do		Exit Stair FL-7	Y	Do	
Exit Stair FL-8	Y	Do		Exit Stair FL-8	N	Do	ตรวจสอบ
Main Stair FL-B1#1	Y	Do		Main Stair FL-B1#1	Y	Do	
Main Stair FL-B1#2	Y	Do		Main Stair FL-B1#2	Y	Do	
Main Stair FL-B2	Y	Do		Main Stair FL-B2	Y	Do	
Main Stair FL-G	Y	Do		Main Stair FL-G	Y	Do	
Main Stair FL-2	Y	Do		Main Stair FL-2	Y	Do	
Main Stair FL-3	Y	Do		Main Stair FL-3	Y	Do	
Main Stair FL-4	Y	Do		Main Stair FL-4	Y	Do	
Main Stair FL-5	Y	Do		Main Stair FL-5	Y	Do	
Main Stair FL-6	Y	Do		Main Stair FL-6	Y	Do	
Main Stair FL-7	Y	Do		Main Stair FL-7	Y	Do	
Main Stair FL-8	Y	Do		Main Stair FL-8	Y	Do	
Hall lift staff FL-B1	Y	Do		Owner Office	Y	Do	
Hall lift staff FL-B2	Y	Do		GM Office	Y	Do	
Lift Hall tower A EL.B1	Y	Do		FC Office	Y	Do	
Lift Hall tower A EL.B2	Y	Do		AC Office	Y	Do	
Car lift FL-B1	Y	Do		HK Office	Y	Do	
Fire pump room	Y	Do		FO Office	Y	Do	
Store Eng.	Y	Do		HR Office	Y	Do	
FB Store	Y	Do		Canteen	Y	Do	
HK Store	Y	Do		Car park P3 #1	Y	Do	
Kitchen Store	Y	Do		Car park P3 #2	Y	Do	
Sever Room	Y	Do		Car park P3 #3	Y	Do	
Main Kitchen#1	Y	Do		Car park P3 #4	Y	Do	
Main Kitchen#2	Y	Do		Car park P4 #1	Y	Do	
Generator room	Y	Do		Car park P4 #2	Y	Do	
MDB room 1	Y	Do		Car park P4 #3	Y	Do	
MDB room 2	Y	Do		Car park P4 #4	Y	Do	

Checked By Supervisor	Do	Date	2/5/25
Approve By Chief Engineer	Do	Date	2/5/25



Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	Beer		Exit Stair FL-B1	Y	Beer	
Exit Stair FL-B2	Y	Beer		Exit Stair FL-B2	Y	Beer	
Exit Stair FL-G	Y	Beer		Exit Stair FL-G	Y	Beer	
Exit Stair FL-2	Y	Beer		Exit Stair FL-2	Y	Beer	
Exit Stair FL-3	Y	Beer		Exit Stair FL-3	N	Beer	5090362/25
Exit Stair FL-4	Y	Beer		Exit Stair FL-4	Y	Beer	
Exit Stair FL-5	Y	Beer		Exit Stair FL-5	Y	Beer	
Exit Stair FL-6	Y	Beer		Exit Stair FL-6	N	Beer	5090362/25
Exit Stair FL-7	Y	Beer		Exit Stair FL-7	Y	Beer	
Exit Stair FL-8	Y	Beer		Exit Stair FL-8	N	Beer	5090362/25
Main Stair FL-B1#1	Y	Beer		Main Stair FL-B1#1	Y	Beer	
Main Stair FL-B1#2	Y	Beer		Main Stair FL-B1#2	Y	Beer	
Main Stair FL-B2	Y	Beer		Main Stair FL-B2	Y	Beer	
Main Stair FL-G	Y	Beer		Main Stair FL-G	Y	Beer	
Main Stair FL-2	Y	Beer		Main Stair FL-2	Y	Beer	
Main Stair FL-3	Y	Beer		Main Stair FL-3	Y	Beer	
Main Stair FL-4	Y	Beer		Main Stair FL-4	Y	Beer	
Main Stair FL-5	Y	Beer		Main Stair FL-5	Y	Beer	
Main Stair FL-6	Y	Beer		Main Stair FL-6	Y	Beer	
Main Stair FL-7	Y	Beer		Main Stair FL-7	Y	Beer	
Main Stair FL-8	Y	Beer		Main Stair FL-8	Y	Beer	
Hall lift staff FL-B1	Y	Beer		Owner Office	Y	Beer	
Hall lift staff FL-B2	Y	Beer		GM Office	Y	Beer	
Lift Hall tower A EL.B1	Y	Beer		FC Office	Y	Beer	
Lift Hall tower A EL.B2	Y	Beer		AC Office	Y	Beer	
Car lift FL-B1	Y	Beer		HK Office	Y	Beer	
Fire pump room	Y	Beer		FO Office	Y	Beer	
Store Eng.	Y	Beer		HR Office	Y	Beer	
FB Store	Y	Beer		Canteen	N	Beer	
HK Store	Y	Beer		Car park P3 #1	Y	Beer	
Kitchen Store	Y	Beer		Car park P3 #2	Y	Beer	
Sever Room	Y	Beer		Car park P3 #3	Y	Beer	
Main Kitchen#1	Y	Beer		Car park P3 #4	Y	Beer	
Main Kitchen#2	Y	Beer		Car park P4 #1	Y	Beer	
Generator room	Y	Beer		Car park P4 #2	Y	Beer	
MDB room 1	Y	Beer		Car park P4 #3	Y	Beer	
MDB room 2	Y	Beer		Car park P4 #4	Y	Beer	

Checked By Supervisor



Date

2 / 6 / 25

Approve By Chief Engineer



Date


2 / 6 / 25

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	-	1200	Roof FHC (1)	195	
FL.8 FHC	195		Roof FHC (2)	195	
FL.7 corridor	100		FL.8 FHC 2801	195	
FL.7 FHC	195		FL.8 FHC 2821	195	
FL.6 corridor	100		FL.8 staff lift	100	
FL.6 FHC	195		FL.7 FHC 2701	195	
FL.5 corridor	100		FL.7 FHC 2721	195	
FL.5 FHC	195		FL.7 staff lift	100	
FL.4 corridor	100		FL.6 FHC 2601	195	
FL.4 FHC	CO2		FL.6 FHC 2621	195	
FL.3 corridor	100		FL.6 staff lift	100	
FL.3 FHC	195		FL.5 FHC 2501	195	
FL.2 corridor	100		FL.5 FHC 2521	195	
FL.2 FHC	CO2		FL.5 staff lift	100	
FL.G FHC security	195		FL.4 FHC 2401	195	
FL.G FHC restaurant	195		FL.4 FHC 2421	195	
FL.B1 FHC	195		FL.4 staff lift	100	
FL.B1 kitchen (1)	100		FL.3 FHC 2301	195	
FL.B1 kitchen (2)	100		FL.3 FHC 2321	195	
FL.B1 staff lift	100		FL.3 staff lift	100	
FL.B2 staff lift	100		FL.2 FHC 2201	195	
FL.B2 FHC	195		FL.2 FHC 2221	100	
FL.B2 FHC fire pump	195		FL.2 staff lift	100	
Generator room	CO2		FL.G FHC Lobby	195	
MDB Room	CO2		FHC front office	195	
MDB Room	CO2		FL.B1 FHC Car park	195/195	
			FL.B2 FHC Car park	195/195	

Checked By Supervisor	To	Date	4/1/25
Approve By Chief Engineer		Date	4/1/25





Tower A-B			Tower B-A		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	—	CO <sub>2</sub>	Roof FHC (1)	195	
FL.8 FHC	195		Roof FHC (2)	195	
FL.7 corridor	100		FL.8 FHC 2801	195	
FL.7 FHC	195		FL.8 FHC 2821	195	
FL.6 corridor	100		FL.8 staff lift	100	
FL.6 FHC	195		FL.7 FHC 2701	195	
FL.5 corridor	100		FL.7 FHC 2721	195	
FL.5 FHC	195		FL.7 staff lift	100	
FL.4 corridor	100		FL.6 FHC 2601	195	
FL.4 FHC	CO <sub>2</sub>		FL.6 FHC 2621	195	
FL.3 corridor	100		FL.6 staff lift	100	
FL.3 FHC	195		FL.5 FHC 2501	195	
FL.2 corridor	100		FL.5 FHC 2521	195	
FL.2 FHC	CO <sub>2</sub>		FL.5 staff lift	100	
FL.G FHC security	195		FL.4 FHC 2401	195	
FL.G FHC restaurant	195		FL.4 FHC 2421	195	
FL.B1 FHC	195		FL.4 staff lift	100	
FL.B1 kitchen (1)	100		FL.3 FHC 2301	195	
FL.B1 kitchen (2)	100		FL.3 FHC 2321	195	
FL.B1 staff lift	100		FL.3 staff lift	100	
FL.B2 staff lift	100		FL.2 FHC 2201	195	
FL.B2 FHC	195		FL.2 FHC 2221	100	
FL.B2 FHC fire pump	195		FL.2 staff lift	100	
Generator room	CO <sub>2</sub>		FL.G FHC Lobby	195	
MDB Room	CO <sub>2</sub>		FHC front office	195	
MDB Room	CO <sub>2</sub>		FL.B1 FHC Car park	195/195	
			FL.B2 FHC Car park	195/195	

Checked By Supervisor	TO	Date	4/2/25
Approve By Chief Engineer		Date	5/2/25

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
Roof FHC(1)	195		FL.8 FHC Pump room	~	5' 1200
Roof FHC(2)	195		FL.8 FHC	195	
FL.8 FHC 2801	195		FL.7 corridor	180	
FL.8 FHC 2821	195		FL.7 FHC	195	
FL.8 staff lift	180		FL.6 corridor	180	
FL.7 FHC 2701	195		FL.6 FHC	195	
FL.7 FHC 2721	195		FL.5 corridor	180	
FL.7 staff lift	180		FL.5 FHC	190	
FL.6 FHC 2601	185		FL.4 corridor	180	
FL.6 FHC 2621	195		FL.4 FHC	182	
FL.6 staff lift	180		FL.3 corridor	180	
FL.5 FHC 2501	185		FL.3 FHC	185	
FL.5 FHC 2521	185		FL.2 corridor	180	
FL.5 staff lift	180		FL.2 FHC	182	
FL.4 FHC 2401	195		FL.G FHC security	185	
FL.4 FHC 2421	195		FL.G FHC restaurent	185	
FL.4 staff lift	180		FL.B1 FHC	195	
FL.3 FHC 2301	185		FL.B1 kitchen (1)	180	
FL.3 FHC 2321	195		FL.B1 kitchen (2)	180	
FL.3 staff lift	180		FL.B1 staff lift	180	
FL.2 FHC 2201	195		FL.B2 staff lift	180	
FL.2 FHC 2221	180		FL.B2 FHC	185	
FL.2 staff lift	180		FL.B2 FHC fire pump	195	
FL.G FHC lobby	195		Generator room	182	
FHC front office	195		MDB room	182	
FL.B1 FHC car park	195/195		MDB room	182	
FL.B2 FHC car park	195/195				



Checked By Supervisor	To	Date	1/3/25
Approve By Chief Engineer		Date	31/3/25

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
Roof FHC(1)	195		FL.8 FHC Pump room	-	1200
Roof FHC(2)	195		FL.8 FHC	195	
FL.8 FHC 2801	195		FL.7 corridor	100	
FL.8 FHC 2821	195		FL.7 FHC	195	
FL.8 staff lift	100		FL.6 corridor	195	
FL.7 FHC 2701	195		FL.6 FHC	195	
FL.7 FHC 2721	195		FL.5 corridor	100	
FL.7 staff lift	100		FL.5 FHC	195	
FL.6 FHC 2601	195		FL.4 corridor	195	
FL.6 FHC 2621	195		FL.4 FHC	Co2	
FL.6 staff lift	100		FL.3 corridor	100	
FL.5 FHC 2501	195		FL.3 FHC	195	
FL.5 FHC 2521	195		FL.2 corridor	100	
FL.5 staff lift	100		FL.2 FHC	Co2	
FL.4 FHC 2401	195		FL.G FHC security	195	
FL.4 FHC 2421	195		FL.G FHC restaurant	195	
FL.4 staff lift	100		FL.B1 FHC	195	
FL.3 FHC 2301	195		FL.B1 kitchen (1)	100	
FL.3 FHC 2321	195		FL.B1 kitchen (2)	100	
FL.3 staff lift	100		FL.B1 staff lift	100	
FL.2 FHC 2201	195		FL.B2 staff lift	100	
FL.2 FHC 2221	100		FL.B2 FHC	195	
FL.2 staff lift	100		FL.B2 FHC fire pump	195	
FL.G FHC lobby	195		Generator room	Co2	
FHC front office	195		MDB room	Co2	
FL.B1 FHC car park	195 / 195		MDB room	Co2	
FL.B2 FHC car park	195 / 195				


Checked By Supervisor		Date	2/4/25
Approve By Chief Engineer		Date	2/4/25



Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	—	1800	Roof FHC (1)	195	
FL.8 FHC	195		Roof FHC (2)	195	
FL.7 corridor	100		FL.8 FHC 2801	195	
FL.7 FHC	195		FL.8 FHC 2821	195	
FL.6 corridor	195		FL.8 staff lift	100	
FL.6 FHC	195		FL.7 FHC 2701	195	
FL.5 corridor	100		FL.7 FHC 2721	195	
FL.5 FHC	195		FL.7 staff lift	100	
FL.4 corridor	195		FL.6 FHC 2601	195	
FL.4 FHC	100		FL.6 FHC 2621	195	
FL.3 corridor	100		FL.6 staff lift	190	
FL.3 FHC	195		FL.5 FHC 2501	195	
FL.2 corridor	100		FL.5 FHC 2521	195	
FL.2 FHC	195		FL.5 staff lift	100	
FL.G FHC security	195		FL.4 FHC 2401	195	
FL.G FHC restaurant	195		FL.4 FHC 2421	195	
FL.B1 FHC	195		FL.4 staff lift	100	
FL.B1 kitchen (1)	100		FL.3 FHC 2301	195	
FL.B1 kitchen (2)	100		FL.3 FHC 2321	195	
FL.B1 staff lift	100		FL.3 staff lift	100	
FL.B2 staff lift	100		FL.2 FHC 2201	195	
FL.B2 FHC	195		FL.2 FHC 2221	100	
FL.B2 FHC fire pump	195		FL.2 staff lift	100	
Generator room	100		FL.G FHC Lobby	195	
MDB Room	100		FHC front office	195	
	100		FL.B1 FHC Car park	195/195	
			FL.B2 FHC Car park	195/195	

Checked By Supervisor		Date	3/5/25
Approve By Chief Engineer		Date	3/5/25

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
Roof FHC(1)	195		FL.8 FHC Pump room	—	1200
Roof FHC(2)	195		FL.8 FHC	195	
FL.8 FHC 2801	195		FL.7 corridor	100	
FL.8 FHC 2821	195		FL.7 FHC	195	
FL.8 staff lift	100		FL.6 corridor	195	
FL.7 FHC 2701	195		FL.6 FHC	195	
FL.7 FHC 2721	195		FL.5 corridor	100	
FL.7 staff lift	100		FL.5 FHC	195	
FL.6 FHC 2601	195		FL.4 corridor	195	
FL.6 FHC 2621	195		FL.4 FHC	CO2	
FL.6 staff lift	100		FL.3 corridor	100	
FL.5 FHC 2501	195		FL.3 FHC	195	
FL.5 FHC 2521	195		FL.2 corridor	100	
FL.5 staff lift	100		FL.2 FHC	CO2	
FL.4 FHC 2401	195		FL.G FHC security	195	
FL.4 FHC 2421	195		FL.G FHC restaurant	195	
FL.4 staff lift	100		FL.B1 FHC	195	
FL.3 FHC 2301	195		FL.B1 kitchen (1)	100	
FL.3 FHC 2321	195		FL.B1 kitchen (2)	100	
FL.3 staff lift	100		FL.B1 staff lift	100	
FL.2 FHC 2201	195		FL.B2 staff lift	100	
FL.2 FHC 2221	100		FL.B2 FHC	195	
FL.2 staff lift	100		FL.B2 FHC fire pump	195	
FL.G FHC lobby	195		Generator room	CO2	
FHC front office	195		MDB room	CO2	
FL.B1 FHC car park	195 / 199		MDB room	CO2	
FL.B2 FHC car park	195 / 195				

Checked By Supervisor	To	Date	2/6/25
Approve By Chief Engineer		Date	3/6/25