

ภาคผนวก จ

Pool Daily Check List

Date	Time	Room no.	Chlorine 1-3 ppm		Hot Water Temperature (Degree)		Inspector
			Faucet	Shower	Faucet	Shower	
1/1/68	01.00	2606	0.79	0.79	55.9	57.9	Beer
		2720	0.64	0.64	56.0	55.1	
2/1/68	02.05	2703	1.00	0.64	55.6	56.1	Beer
		2201	1.32	1.01	56.9	56.0	
3/1/68	01.51	2919	1.13	1.09	55.1	55.1	Beer
		2217	1.24	1.11	55.2	55.2	
4/1/68	02.20	2720	1.32	1.12	55.9	56.1	Beer
		2305	0.71	1.73	55.1	55.4	
5/1/68	01.45	2714	1.52	1.23	55.9	55.3	Beer
		2304	1.14	1.06	55.6	55.9	
6/1/68	02:07	1608	0.94	0.99	55.4	56.9	MON
		1301	0.68	1.04	55.1	56.2	
7/1/68	01:58	2707	0.99	0.73	55.0	56.6	MON
		2814	0.95	0.92	55.5	56.8	
8/1/68	02:22	2512	0.78	0.92	55.8	56.7	MON
		2101	0.89	0.95	55.2	57.1	
9/1/68	02:35	2718	0.79	0.78	55.4	57.2	MON
		2419	0.96	0.81	55.5	56.8	
10/1/68	02:38	2201	1.33	1.51	56.4	55.2	To
		2805	0.49	0.55	55.9	55.9	
11/1/68	02:42	1414	0.32	0.32	55.9	56.7	To
		2619	1.53	1.30	56.8	56.8	
12/1/68	02:18	2805	0.77	0.98	55.5	56.8	MON
		2814	0.61	0.84	55.8	57.3	
13/1/68	02:27	1309	0.61	0.88	56.3	56.8	MON
		2503	0.76	0.89	55.7	57.5	
14/1/68	02:32	1401	0.77	0.88	56.5	56.9	MON
		2614	0.86	0.83	57.1	57.8	
15/1/68	02:32	2806	0.84	0.74	56.2	57.3	MON
		1304	0.71	0.61	54.9	56.2	
16/1/68	02:23	2201 2801	0.64	0.73	55.2	57.6	MON
		2216	0.38	0.44	55.5	57.4	
17/1/68	03.22	1715	0.67	0.71	56.3	56.9	To
		2207	1.12	1.06	55.3	55.7	
18/1/68	03.20	2517	1.00	1.00	55.7	55.6	To
		2210	0.46	0.38	56.5	56.6	
19/1/68	02:23	2608	1.02	0.87	55.6	57.7	MON
		2103	0.71	0.68	55.3	56.8	
20/1/68	01:58	2701	0.69	0.68	56.4	57.0	MON
		2215	0.72	0.66	55.7	57.2	
21/1/68	02:19	1703	0.62	0.64	54.8	57.2	MON
		1302	0.67	0.82	54.8	56.1	
22/1/68	02:20	2212	0.88	0.72	55.3	56.9	MON
		1611	0.46	0.68	54.5	56.3	
23/1/68	02.53	2214	1.22	1.61	55.4	55.8	To
		2719	2.50	2.50	55.2	55.6	
24/1/68	02.37	2703	0.21	0.19	56.2	56.1	To
		2318	0.20	0.34	58.2	58.3	
25/1/68	02.50	2614	0.43	0.51	56.0	56.0	To
		2215	0.12	0.49	56.0	56.1	
26/1/68	02:30	2510	0.44	0.56	55.6	57.6	MON
		2211	0.21	0.17	55.3	57.4	
27/1/68	02:05	2607	0.61	0.70	54.8	57	MON
		2216	0.60	0.70	55.9	56.9	
28/1/68	02:28	1601	0.38	0.65	54.1	56.9	MON
		1308	0.68	0.68	55.2	56.9	
29/1/68	02:39	2208	0.84	0.82	55.1	57.6	MON
		2808	0.90	0.80	55.7	57.4	
30/1/68	02:50	2807	0.49	0.58	54.1	57.1	MON
		2218	0.77	0.85	55.5	56.5	
31/1/68	02.50	2212	1.03	1.03	56.1	56.3	To
		2601	0.94	0.90	55.4	55.4	

Note:

Verified by:

Date	Time	Room no.	Chlorine 1-3 ppm		Hot Water Temperature (Degree)		Inspector
			Faucet	Shower	Faucet	Shower	
1/2/68	02.20	2619 2205	1.14 1.31	0.99 1.16	56.6 56.6	56.8 56.6	To
2/2/68	02.04	2612 1312	1.04 1.08	0.90 1.05	55.5 55.5	56.1 55.6	Change
3/2/68	02.10	2602 2219	0.94 0.86	1.01 1.06	56.1 55.8	56.6 56.3	Change
4/2/68	02.14	2715 2301	1.32 1.05	1.12 1.35	55.4 55.5	55.7 55.9	Change
5/2/68	02.20	1504 1311	1.24 1.29	1.10 1.24	55.9 55.1	55.7 55.3	Change
6/2/68	02.10	2302 1608	1.25 1.27	1.06 1.11	55.5 55.3	55.8 55.0	Change
7/2/68	02.51	2516 1205	1.19 1.11	1.20 0.85	55.1 55.1	55.1 57.2	To
8/2/68	03.00	1601 1205	0.59 1.02	0.37 1.00	56.5 56.1	56.5 56.3	To
9/2/68	02.07	2712 2402	1.42 1.46	1.38 1.33	55.7 55.9	55.5 56.0	Change
10/2/68	02.05	2720 2304	1.30 1.17	1.49 1.24	55.6 55.3	55.8 55.6	Change
11/2/68	02.20	2804 2401	1.09 1.46	1.19 1.23	55.3 55.5	55.5 55.9	Change
12/2/68	02.28	1607 2316	0.94 1.18	1.15 1.24	55.2 55.4	55.5 55.6	Change
13/2/68	02.46	2502 2310	0.97 1.19	0.91 1.13	55.1 55.8	55.6 56.1	Change
14/2/68	03.12	1715 2317	1.14 1.01	1.12 1.29	58.2 57.0	58.3 57.2	To
15/2/68	03.25	2720 2414	1.33 0.80	1.33 1.04	56.8 55.8	56.8 55.9	To
16/2/68	02.18	2820 2307	1.15 1.45	1.29 1.71	55.1 55.5	55.6 56.1	Change
17/2/68	02.25	2708 2318	1.23 1.19	1.15 1.05	55.3 55.6	55.8 56.2	Change
18/2/68	02.30	1603 1404	1.22 1.32	1.37 1.45	55.9 55.3	56.1 55.6	Change
19/2/68	02.35	2720 2308	1.33 1.39	1.27 1.58	55.8 55.3	56.1 55.5	Change
20/2/68	02.22	1507 2315	1.24 1.78	1.38 1.56	55.3 55.4	55.8 56.2	Change
21/2/68	01.33	2519 2312	0.98 1.40	0.92 1.40	56.5 55.3	56.5 55.3	To
22/2/68	03.00	2509 1204	1.91 1.78	2.43 1.81	55.1 57.8	55.1 57.8	To
23/2/68	02.32	2514 2317	1.35 1.43	1.32 1.34	55.5 55.6	55.3 56.0	Change
24/2/68	02.15	1605 2318	1.28 1.36	1.26 1.37	55.2 55.5	55.9 56.1	Change
25/2/68	02.35	2808 2317	1.19 1.41	1.48 1.45	55.3 55.3	55.5 55.6	Change
26/2/68	02.40	2608 2312	1.29 1.36	1.43 1.40	55.2 55.8	55.9 56.1	Change
27/2/68	02.00	2803 2202	1.37 1.28	1.51 1.01	55.5 55.6	55.8 56.1	Change
28/2/68	03.30	2508 2406	1.04 1.21	1.16 1.12	56.3 56.1	56.3 56.1	To
0					56.1	60.1	
1							
2							

Note:

Verified by:

Date	Time	Room no.	Chlorine 1-3 ppm		Hot Water Temperature (Degree)		Inspector
			Faucet	Shower	Faucet	Shower	
1/3/68	02.50	1503	0.86	0.91	55.4	55.5	To
		1302	1.50	0.68	55.5	55.6	
2/3/68	02:00	2310	1.12	0.35	55.2	55.4	Ni
		2814	0.56	0.51	56.1	56.5	
3/3/68	03:00	1607	1.37	1.37	57.3	57.3	To
		2214	1.25	1.20	56.4	56.3	
4/3/68	02.40	1607	1.37	1.37	57.3	57.3	To
		2402	1.12	1.12	57.8	58.1	
5/3/68	02.30	2216	2.46	2.49	58.5	58.6	To
		2A03	1.88	1.88	56.0	56.1	
6/3/68	03.10	2802	1.66	1.47	56.8	56.9	To
		2206	1.95	1.94	55.8	56.0	
7/3/68	03.00	2603	1.82	1.86	55.6	55.5	To
		2A01	1.76	1.75	57.4	57.6	
8/3/68	03.00	2804	0.87	0.98	56.1	56.1	To
		2308	2.01	1.99	55.7	55.7	
9/3/68	03:30	2404	0.62	0.63	56.9	56.1	Ni
		2714	0.56	0.61	55.5	55.9	
10/3/68	03:30	2801	0.83	0.75	56.5	56.3	Ni
		1402	0.90	0.90	58.1	57.8	
11/3/68	03:30	2605	0.68	0.72	55.9	55.1	Ni
		1302	0.69	0.69	56.1	56.9	
12/3/68	03:30	1610	0.82	0.77	55.2	55.5	Ni
		1305	0.72	0.71	57.4	56.9	
13/3/68	03.50	1503	1.62	1.64	56.3	56.3	To
		2407	1.42	1.49	56.6	56.7	
14/3/68	02.28	2607	1.53	1.52	55.9	56.1	To
		2208	1.57	1.55	55.6	55.1	
15/3/68	02.40	2814	1.39	1.43	57.0	57.1	To
		2209	1.50	1.53	56.9	56.2	
16/3/68	02:30	2803	0.71	0.57	56.5	57.5	Ni
		2410	0.68	0.67	58.9	57.3	
17/3/68	03:00	2514	0.42	0.30	55.1	55.7	Ni
		1407	0.45	0.45	55.9	55.4	
18/3/68	03.30	2719	1.52	1.44	59.4	59.6	To
		1206	1.35	1.42	55.7	55.6	
19/3/68	03.40	2608	0.99	1.01	55.8	55.9	To
		2616	1.30	1.29	56.3	56.4	
20/3/68	03.05	2806	0.91	0.95	56.1	56.6	To
		2412	0.81	0.86	60.0	60.1	
21/3/68	02.50	2703	0.77	0.73	56.2	56.3	To
		2305	0.82	0.79	55.4	55.5	
22/3/68	03.10	2515	0.92	0.96	55.8	55.8	To
		2101	0.80	0.79	56.2	56.2	
23/3/68	02:00	1206	0.59	0.59	56.3	56.8	Ni
		2714	0.66	0.63	56.0	56.5	
24/3/68	02:30	1405	0.54	0.50	56.8	57.0	Ni
		2609	0.49	0.71	55.1	55.7	
25/3/68	02.00	2507	0.80	0.91	55.8	55.5	Change
		2317	1.04	1.26	55.6	56.1	
26/3/68	02.04	2802	0.89	0.96	55.8	56.1	Change
		2410	1.02	0.98	55.7	55.7	
27/3/68	02.12	2615	0.97	0.99	55.4	55.5	Change
		2417	0.84	0.97	55.1	55.5	
28/3/68	02.50	2702	0.47	0.55	56.9	57.0	To
		1201	50	0.52	55.5	55.5	
29/3/68	02.18	2820	0.83	0.82	53.1	56.1	Mon
		2418	0.86	0.85	53	56.5	
30/3/68	01:59	1510	0.66	0.86	57.9	55.5	Mon
		1712	0.69	0.78	59.5	53.4	
31/3/68	01:36	1601	0.63	0.77	56.5	56.2	Mon
		1209	0.79	0.73	56.6	56.9	

Note:

Verified by:

Date	Time	Room no.	Chlorine 1-3 ppm		Hot Water Temperture (Degree)		Inspector
			Faucet	Shower	Faucet	Shower	
1/4/68	01:54	2501	0.76	0.76	66.4	66.8	Mon
		2311	0.85	0.64	65.7	66.2	
2/4/68	03:30	1207	0.43	0.43	65.9	65.5	Ni
		2501	0.41	0.37	65.1	65.3	
3/4/68	02:30	1611	0.99	1.01	55.8	56.0	Changr
		1410	0.92	1.15	55.6	55.9	
4/4/68	03:30	1409	0.50	0.43	67.0	66.6	Ni
		2801	0.48	0.54	67.6	67.2	
5/4/68	03:00	2708	0.56	0.55	65.9	65.6	Ni
		2417	0.56	0.56	66.5	66.3	
6/4/68	03:00	2501	0.48	0.40	65.3	65.2	Ni
		2207	0.44	0.43	57.6	66.6	
7/4/68	03:00	1805	0.55	0.54	66.9	66.4	Ni
		1514	0.61	0.54	66.8	66.9	
8/4/68	02:26	1415	0.78	0.92	55.1	55.8	Changr.
		2506	0.73	0.80	55.0	55.6	
9/4/68	02:32	1706	0.83	0.88	55.1	55.3	Chang.
		1203	0.83	0.75	55.3	55.8	
10/4/68	02:25	2804	0.69	0.63	55.2	55.5	Changr
		2221	0.93	0.79	55.5	56.1	
11/4/68	02:30	1207	0.47	0.40	66.5	68.5	Ni
		1603	0.45	0.45	68.6	67.5	
12/4/68	03:00	2312	0.26	0.25	68.7	67.7	Ni
		2316	0.28	0.31	65.4	66.1	
13/4/68	03:00	2210	0.26	0.24	67.6	68.9	Ni
		2510	0.27	0.26	66.3	66.3	
14/4/68	03:00	2408	0.46	0.41	57.6	68.6	Ni
		2708	0.54	0.53	65.0	66.2	
15/4/68	03:00	2412	0.19	0.30	65.7	65.9	Ni
		2514	0.28	0.29	68.5	67.4	
16/4/68	02:20	2516	0.37	0.45	55.6	56.3	Chang.
		2206	0.41	0.76	55.6	55.5	
17/4/68	02:22	2821	0.73	0.90	55.2	55.8	Changr.
		2302	0.79	0.82	55.2	55.5	
18/4/68	03:00	2214	0.59	0.54	65.4	65.6	Ni
		2307	0.57	0.53	66.7	65.8	
19/4/68	02:39	2516	0.70	0.41	55.5	55.2	Bear
		1201	0.63	0.61	56.4	55.3	
20/4/68	03:20	2818	0.26	0.16	66.3	65.6	Ni
		2316	0.28	0.22	65.3	65.5	
21/4/68	03:00	2516	0.47	0.65	66.8	65.3	Ni
		1408	0.58	0.57	67.4	66.9	
22/4/68	02:30	2421	0.52	0.52	66.2	66.0	Ni
		2612	0.59	0.50	65.2	65.6	
23/4/68	02:28	1303	0.87	0.93	55.3	55.9	Changr
		2520	0.83	0.62	55.5	56.6	
24/4/68	02:10	2817	0.91	0.82	55.6	55.9	Changr
		2317	1.00	0.78	55.3	56.1	
25/4/68	02:30	1707	0.55	0.43	66.6	69.9	Ni
		1312	0.48	0.65	66.1	69.0	
26/4/68	03:00	2518	0.39	0.37	57.4	66.9	Ni
		1302	0.38	0.38	67.6	57.9	
27/4/68	02:00	2809	0.69	0.66	56.5	66.6	Ni
		1201	0.51	0.62	66.1	66.8	
28/4/68	02:00	2518	0.76	0.74	57.8	57.5	Ni
		2312	0.69	0.77	66.3	66.6	
29/4/68	02:00	2702	0.22	0.60	55.1	65.6	Ni
		2420	0.65	0.69	66.5	65.9	
30/4/68	03:21	1605	0.85	0.91	55.7	55.5	Changr
		2105	0.67	0.75	55.2	55.9	
1/5/68							

Note: _____

Verified by: _____

Date	Time	Room no.	Chlorine 1-3 ppm		Hot Water Temperature (Degree)		Inspector
			Faucet	Shower	Faucet	Shower	
1/5/68	02.40	1202 2601	0.66 0.96	0.93 0.78	55.6 55.1	55.9 55.3	Chang
2/5/68	02.16	2602 2214	0.84 0.98	0.84 0.94	55.5 56.2	55.6 55.4	Beer
3/5/68	02.27	2604 1310	0.94 1.00	0.54 0.93	55.4 55.6	55.3 55.06	Beer
4/5/68	02.20	2601 2307	1.07 1.22	1.21 0.94	55.2 55.5	55.1 55.3	Beer
5/5/68	02.08	2801 2207	0.97 0.81	0.10 0.63	55.6 55.1	55.7 55.5	Mon
6/5/68	01:01	2520 2301	0.67 0.69	0.77 0.57	55.3 55.2	55.2 55.6	Ch
7/5/68	03:14	1703 1115	0.59 0.58	0.58 0.80	55.8 55.5	55.9 55.8	Ch
8/5/68	02.12	2609 1304	0.82 0.74	0.69 0.74	55.2 55.8	55.4 55.5	Beer
9/5/68	03.00	1506 2207	0.74 0.66	0.66 0.79	55.3 55.6	55.3 57.2	Beer
10/5/68	02.31	2610 2412	0.81 0.76	0.79 0.81	55.1 55.5	55.4 55.6	Beer
11/5/68	02.37	2201 2607	0.74 0.63	0.70 0.66	55.4 55.6	55.6 55.6	Chang.
12/5/68	02.22	2716 2208	0.64 0.71	0.74 0.73	55.5 55.3	55.9 55.5	Chang.
13/5/68	02.25	1702 2308	0.70 0.75	0.77 0.66	55.1 55.3	55.6 56.3	Chang.
14/5/68	02.37	2615 2616 2103 2103	0.64 0.84	0.61 0.76	55.1 55.3	55.5 55.8	Chang.
15/5/68	03.00	2611 2220	0.70 0.62	0.76 0.54	55.2 55.5	55.9 55.6	Chang.
16/5/68	02.21	2615 2312	0.58 0.74	0.52 0.83	55.1 55.6	55.3 55.4	Beer
17/5/68	02.24	2616 1410	0.84 0.67	0.82 0.81	55.3 56.1	55.2 56.3	Beer
18/5/68	02.21	1610 1903	0.70 0.70	0.59 0.83	55.2 55.2	55.1 55.0	Beer
19/5/68	02.20	2621 1415	0.80 0.73	0.59 0.84	55.2 55.5	55.3 55.6	Beer
20/5/68	02:33	2621 2104	0.83 0.83	0.57 0.83	55.7 55.3	55.9 55.5	Ch
21/5/68	02:28	2717 2211	0.59 0.11	0.39 0.38	55.8 55.3	56.1 55.5	Ch
22/5/68	02.20	2613 2421	0.56 0.86	0.47 0.42	55.4 55.8	55.9 55.2	Beer
23/5/68	02.14	2711 2317	0.60 0.62	0.69 0.66	55.2 55.1	55.4 55.6	Beer
24/5/68	02.20	1506 1314	0.50 0.52	0.66 0.54	55.0 55.3	55.2 55.5	Beer
25/5/68	02.40	1712 2216	0.89 0.95	0.04 0.37	55.1 55.4	55.3 55.3	Beer
26/5/68	02:33	2803 2307	0.39 0.14	0.39 0.41	55.1 55.3	55.8 55.5	Ch
27/5/68	02:19	1704 1204	0.52 0.66	0.49 0.40	55.3 55.5	55.6 55.6	Ch
28/5/68	03.17	2820 2103	0.45 0.64	0.62 0.67	55.1 55.1	55.1 55.4	Beer
29/5/68	02.34	2712 2214	0.64 0.67	0.76 0.67	55.2 55.9	55.5 55.3	Beer
30/5/68	02.43	2702 2402	0.69 0.77	0.96 0.86	55.1 55.3	55.7 55.7	Beer
31/5/68	03.04	2414 2315	0.62 0.80	0.72 0.80	55.0 55.1	55.5 55.5	Beer

Note:

Verified by:

Date	Time	Room no.	Chlorine 1-3 ppm		Hot Water Temperature (Degree)		Inspector
			Faucet	Shower	Faucet	Shower	
1/6/68	03:20	266	0.65	0.90	55.3	55.6	Beer
		2218	1.12	0.54	55.5	55.6	
2/6/68	02:36	2701	0.89	0.87	55.1	55.6	Chang
		2202	0.77	0.82	55.5	55.8	
3/6/68	02:31	2706	0.86	0.89	55.5	55.8	Chang
		2201	0.74	0.72	55.2	55.9	
4/6/68	02:30	2709	0.91	0.92	55.6	56.2	Chang
		2404	0.73	0.79	55.0	55.7	
5/6/68	03:00	2708	0.73	0.90	55.4	55.5	Chang
		2320	0.72	0.88	55.0	55.5	
6/6/68	02:40	2819	0.66	0.62	55.8	56.6	MON
		2202	0.73	0.78	55.6	55.5	
7/6/68	02:17	2707	0.70	0.60	55.3	55.6	MON
		2214	0.76	0.30	55.5	55.6	
8/6/68	02:33	2709	0.47	0.92	55.8	56.1	MON
		2101	0.72	0.44	56	56.2	
9/6/68	02:17	2704	0.68	0.70	55.6	55.9	MON
		2207	0.51	0.69	55.4	55.9	
10/6/68	01:36	2619	0.81	0.83	56.1	56.5	MON
		2210	0.56	0.52	55.3	55.8	
11/6/68	02:09	21601	0.63	0.46	55.2	55.8	MON
		1814	0.62	0.41	55	56.3	
12/6/68	02:40	2211	0.78	0.77	57.3	56.9	To
		2211	0.76	0.69	55.8	55.5	
13/6/68	02:50	2501	1.10	0.78	56	56.1	To
		2201	0.77	0.83	55.6	55.6	
14/6/68	03:00	2712	0.83	0.81	55.8	56.4	To
		1301	0.85	0.74	55.5	55.5	
15/6/68	02:23	2705	0.70	1.06	56	56.2	Chang
		2321	0.65	0.64	55.6	55.8	
16/6/68	02:35	1307	0.67	0.68	55.2	55.6	Chang
		1702	0.60	0.59	55.6	55.9	
17/6/68	02:21	1206	0.52	0.59	55.6	56.5	Chang
		1508	0.68	0.64	55.6	55.6	
18/6/68	02:27	2701	0.68	0.72	55.5	55.9	Chang
		2201	0.42	0.35	55.1	55.6	
19/6/68	03:16	2202	0.78	0.40	55.7	55.8	Chang
		2103	0.55	0.18	55.7	56.2	
20/6/68	02:50	2601	0.54	0.38	55.1	55.1	To
		2401	0.54	0.54	55.1	55.1	
21/6/68	03:20	1703	0.77	0.72	55.2	55.2	To
		1311	0.30	0.40	55.6	55.6	
22/6/68	02:41	2418	0.56	0.33	55.7	56.1	MON
		2217	0.63	0.51	55.8	56.2	
23/6/68	02:51	2715	0.20	0.37	55.3	55.4	MON
		2307	0.28	0.28	55.3	55.1	
24/6/68	02:32	2706	0.57	0.42	54.8	54.8	MON
		2321	0.55	0.53	54.5	55.1	
25/6/68	03:01	2309	0.32	0.28	55.3	55.8	MON
		2906	0.45	0.31	55.8	55.6	
26/6/68	03:11	2801	0.41	0.26	55.0	55.1	MON
		2303	0.36	0.27	54.6	55.5	
27/6/68	03:00	1610	0.63	0.55	55.3	55.9	To
		1204	0.42	0.56	55.6	55.6	
28/6/68	03:30	2804	0.46	0.61	56.6	56.8	To
		2203	0.58	0.47	56.4	56.5	
29/6/68	02:29	2801	0.33	0.25	55.6	55.8	MON
		2915	0.32	0.32	55.3	55.8	
30/6/68	02:47	2812	0.56	0.70	55.7	55.6	MON
		2315	0.35	0.56	55.1	55.1	
1/7/68							

Note:

Verified by: