

ผลวิเคราะห์คุณภาพน้ำสระว่ายน้ำโครงการ KANTARY HOTEL (บางปะกง)



United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

ANALYSIS REPORT

CUSTOMER NAME : KALEIDSCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS KEWALEE SUKHAREE
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-16, 2025
ISSUE DATE : JUNE 24, 2025
REPORT NO. : 2025-U055320
WORK NO. : 2025-003562
ANALYSIS NO. : T25AJ873-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTIFICATION (LOQ)
			SWIMMING POOL (SHALLOW ZONE) T25AJ873-0001		
pH^	-	ELECTROMETRIC METHOD (SM: PART 4500 -H^ B)	7.3 (25°C)	-	-
AMMONIA	mg/L NH ₃	PHENATE METHOD (SM: PART 4500-NH ₃ F)	0.17	0.04	0.15
NITRATE	mg/L NO ₃ ⁻	CADMIUM REDUCTION METHOD (SM: PART 4500-NO ₃ ⁻ E)	54.9	0.09	0.50
CHLORIDE	mg/L Cl ⁻	ARGENTOMETRIC METHOD (SM: 4500-Cl ⁻ B)	650	0.5	2.0
TOTAL ALKALINITY^	mg/L as CaCO ₃	TITRATION METHOD (SM: PART 2320 B)	65.9	-	-
FREE CHLORINE^	mg/L Cl ₂	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	1.0	0.1	-
CALCIUM HARDNESS	mg/L as CaCO ₃	EDTA TITRIMETRIC METHOD (SM: PART 3500-Ca B)	295	1.0	4.0
COMBINED CHLORINE^	mg/L Cl ₂	DPD FERROUS TITRIMETRIC METHOD (SM: PART 4500-Cl F)	0.4	0.1	0.4
CYANURIC ACID	mg/L	TURBIDIMETRIC METHOD	72	1	5
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		
			-		

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

^A : SAMPLING ON JUNE 4, 2025, ANALYSIS NO. T25AM098-0001 (ANALYTICAL DATE : JUNE 5-12, 2025).

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY NOT SHOWING REGULATORY STANDARD. SUBSTITUTED REPORT FOR REPORT NO. 2025-U053088, ISSUE DATE JUNE 13, 2025.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR



- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : KALEIDOSCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS CHATTRAPORN RATCHANET
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-13, 2025
ISSUE DATE : JUNE 23, 2025
REPORT NO. : 2025-U055325
WORK NO. : 2025-003562
ANALYSIS NO. : T25AJ873-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AJ873-0001		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NONE*	1.1
<i>E. coli</i> ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C, E AND F)	< 1.1	NOT DETECTED	1.1
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
<i>Staphylococcus aureus</i> ^c	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/	-
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIKTAL TO HEALTH, B.E. 2530 (1987).

* : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY ADDING *Staphylococcus aureus*.

SUBSTITUTED REPORT FOR REPORT NO. 2025-U053088, ISSUE DATE JUNE 13, 2025.

Chaweevan B.

(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



ISO 9001
Quality
Management
Systems
CERTIFIED

ISO 14001
Environmental
Management
CERTIFIED

ISO 45001
Occupational
Health and Safety
Management
CERTIFIED

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : KALEIDSCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS KEWALEE SUKHAREE
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-16, 2025
ISSUE DATE : JUNE 24, 2025
REPORT NO. : 2025-U055328
WORK NO. : 2025-003562
ANALYSIS NO. : T25AJ873-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			SWIMMING POOL (DEEP ZONE) T25AJ873-0002		
pH ^A	-	ELECTROMETRIC METHOD (SM: PART 4500-H ⁺ B)	7.3 (25°C)	-	-
AMMONIA	mg/L NH ₃	PHENATE METHOD (SM: PART 4500-NH ₃ F)	0.15	0.04	0.15
NITRATE	mg/L NO ₃ ⁻	CADMIUM REDUCTION METHOD (SM: PART 4500-NO ₃ ⁻ E)	56.3	0.09	0.50
CHLORIDE	mg/L Cl ⁻	ARGENTOMETRIC METHOD (SM: 4500-Cl ⁻ B)	636	0.5	2.0
TOTAL ALKALINITY ^A	mg/L as CaCO ₃	TITRATION METHOD (SM: PART 2320 B)	67.0	-	-
FREE CHLORINE ^A	mg/L Cl ₂	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	1.0	0.1	-
CALCIUM HARDNESS	mg/L as CaCO ₃	EDTA TITRIMETRIC METHOD (SM: PART 3500-Ca B)	293	1.0	4.0
COMBINED CHLORINE ^A	mg/L Cl ₂	DPD FERROUS TITRIMETRIC METHOD (SM: PART 4500-Cl F)	< 0.4	0.1	0.4
CYANURIC ACID	mg/L	TURBIDIMETRIC METHOD	71	1	5
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -		

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

^A : SAMPLING ON JUNE 4, 2025, ANALYSIS NO. T25AM098-0002 (ANALYTICAL DATE : JUNE 5-12, 2025).

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY NOT SHOWING REGULATORY STANDARD.
SUBSTITUTED REPORT FOR REPORT NO. 2025-U053089, ISSUE DATE JUNE 13, 2025.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR



- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : KALEIDESCOPE PROPERTIES CO.,LTD (KANTARY HOTEL AMATA BANGPAKONG)
ADDRESS : 828, 828/1-2 MOO 5 KHLONG TAMRU MUEANG CHON BURI CHON BURI 20000
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : KANTARY HOTEL AMATA BANGPAKONG
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2025
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS CHATRAPORN RATCHANET
RECEIVED DATE : MAY 8, 2025
ANALYTICAL DATE : MAY 8-13, 2025
ISSUE DATE : JUNE 23, 2025
REPORT NO. : 2025-U055331
WORK NO. : 2025-003562
ANALYSIS NO. : T25AJ873-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AJ873-0002		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NONE*	1.1
<i>E. coli</i> ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C, E AND F)	< 1.1	NOT DETECTED	1.1
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
<i>Staphylococcus aureus</i> ^c	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRICTIONAL TO HEALTH, B.E. 2530 (1987).


* : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

THE REASON FOR ISSUING THE NEW REPORT IS TO FOLLOW THE CLIENT'S REQUIREMENT BY ADDING *Staphylococcus aureus*.

SUBSTITUTED REPORT FOR REPORT NO. 2025-U053089, ISSUE DATE JUNE 13, 2025.


(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1

- End of Analysis Report -





บริษัท ศูนย์วิเคราะห์น้ำ จำกัด
WATER ANALYSIS CENTER COMPANY LIMITED

1/94 หมู่ 5 ต. คานหาม อ. อุทัย จ. พระนครศรีอยุธยา 13210
1/94 Moo 5, T.Kanham, A.U-Thai, Ayutthaya 13210, Thailand
Tel : 035-226-383 , 035-800-593 Fax : 035-800-594



TESTING
No.0029

ANALYSIS REPORT

Page 1 of 1

Customer Name : KALEIDOSCOPE PROPERTIES CO.,LTD

Address : 828, 828/1-2, 444/4-5 MOO 5 KHLONG TAMRU MUEANG CHONBURI CHONBURI 20000

Contact :-

Phone :-

E.mail :-

Sample Type : Water

Sample Site# : KANTARY HOTEL AMATA
BANGPAKONG

Sampling Method# : Grab

Sampling Date# : 13/08/2025

Sampling By# : Customer

Receive Date : 14/08/2025

Analysis Date : 14-19/08/2025

Report Date : 19/08/2025

Report No. : RWS 02429/68

Parameter	Unit	Method	PWS 04819/68 Swimming Pool (deep zone)	PWS 04820/68 Swimming Pool (shallow zone)	Standard *
Total Coliform Bacteria	MPN/100 mL	APHA, AWWA & WEF, 24 th ed., 2023, part 9221 B	< 1.1 #	< 1.1 #	< 10
Fecal Coliform Bacteria	MPN/100 mL	APHA, AWWA & WEF, 24 th ed., 2023, part 9221 F	Not Detected #	Not Detected #	Not Detected
Sample Characterization	Observation	Clear	Clear		

Remark : * Reference to the Public Health Committee No. 1/2007 regarding the control of swimming pool business, or other businesses in the same way
Detection Limit : Fecal Coliform Bacteria < 1.1 MPN/100 mL

- End Of Report -

Laboratory Staff

(Miss. Ronnakorn Padungwieng)

Chemist

Approved By

(Mrs. Neeramol Phadungsong)

General Manager

The results relate only to the items tested. Test report shall not be reproduced except in full, without written approval of the laboratory
FO.LAB 7.8.1/1 รายงานผลการทดสอบ

แก้ไขครั้งที่ 0, วันที่บังคับใช้ : 1 ม.ค. 2562 หน้า 1/1



บริษัท ศูนย์วิเคราะห์น้ำ จำกัด
WATER ANALYSIS CENTER COMPANY LIMITED
 1/94 หมู่ 5 ต. คานham อ. อุทัย จ. พระนครศรีอยุธยา 13210
 1/94 Moo 5, T.Kanham, A.U-Thai, Ayutthaya 13210, Thailand
 Tel : 035-226-383 , 035-800-593 Fax : 035-800-594



TESTING
 No.0029

ANALYSIS REPORT

Page 1 of 1

Customer Name : KALEIDOSCOPE PROPERTIES CO.,LTD

Address : 828, 828/1-2, 444/4-5 MOO 5 KHLONG TAMRU MUEANG CHONBURI CHONBURI 20000

Contact :- **Phone** :- **E.mail** :-

Sample Type : Water **Sample Site#** : KANTARY HOTEL AMATA BANGPAKONG **Sampling Method#** : Grab

Sampling Date# : 05/11/2025 **Sampling By#** : Customer **Receive Date** : 07/11/2025

Analysis Date : 07-13/11/2025 **Report Date** : 13/11/2025 **Report No.** : RWS 03362/68

Parameter	Unit	Method	PWS 06711/68 Swimming Pool (deep zone)	PWS 06712/68 Swimming Pool (shallow zone)	Standard *
Total Coliform Bacteria	MPN/100 mL	APHA, AWWA & WEF, 24 th ed., 2023, part 9221 B	< 1.1 #	< 1.1 #	< 10
Fecal Coliform Bacteria	MPN/100 mL	APHA, AWWA & WEF, 24 th ed., 2023, part 9221 E	Not Detected #	Not Detected #	Not Detected
Sample Characterization	Observation	Clear	Clear		

Remark : Reference to the Public Health Committee No. 1/2007 regarding the control of swimming pool business, or other businesses in the same way

:- End Of Report :-

Laboratory Staff
 (Miss. Ronnakorn Padungwieng)
 Chemist

Approved By
 (Mrs. Neeramol Phadungsong)
 General Manager

The results relate only to the items tested. Test report shall not be reproduced except in full, without written approval of the laboratory

FO.LAB 7.8.1/1 รายงานผลการทดสอบ

แก้ไขครั้งที่ 0, วันที่บังคับใช้ : 1 ม.ค. 2562 หน้า 1/1

ตารางบันทึกค่าคลอรีน / pH

ตารางเดิมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ คลอรีน (กรัม)	ปริมาณ โซดาแอซ (กรัม)	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH						
	เช้า	เย็น	เช้า	เย็น					
1/7/2568	3.0	3.0	7.4	7.4	-	-	สริฉฉ	นันท	
2/7/2568	2.5	1.5	7.2	7.2	300 กรัม	-	สริฉฉ	นันท	
3/7/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ราชัน	นันท	
4/7/2568	3.0	3.0	7.4	7.4	-	-	ราชัน	นันท	
5/7/2568	2.5	2.0	7.4	7.4	-	-	บรรณ	นันท	
6/7/2568	1.0	0.0	7.4	7.4	500 กรัม	-	จิรณ	นันท	
7/7/2568	3.0	3.0	7.4	7.4	-	-	จิรณ	นันท	
8/7/2568	3.0	3.0	7.4	7.4	-	-	ฉริฉ	นันท	
9/7/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ราชัน	นันท	
10/7/2568	3.0	3.0	7.4	7.4	-	-	สริฉฉ	นันท	
11/7/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ราชัน	นันท	
12/7/2568	3.0	3.0	7.2	7.2	-	-	บรรณ	นันท	
13/7/2568	3.0	2.5	7.2	7.2	-	-	บรรณ	นันท	
14/7/2568	2.0	0.5	7.2	7.2	400 กรัม	-	จิรณ	นันท	
15/7/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ราชัน	นันท	
16/7/2568	2.5	2.0	7.4	7.4	-	-	สริฉฉ	นันท	
17/7/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ราชัน	นันท	
18/7/2568	3.0	3.0	7.4	7.4	-	-	ราชัน	นันท	
19/7/2568	2.5	1.0	7.4	7.4	300 กรัม	-	บรรณ	นันท	
20/7/2568	3.0	3.0	7.4	7.4	-	-	จิรณ	นันท	
21/7/2568	2.0	0.5	7.4	7.4	400 กรัม	-	จิรณ	นันท	
22/7/2568	3.0	2.0	7.2	7.2	-	-	ราชัน	นันท	
23/7/2568	3.0	3.0	7.2	7.2	-	-	ราชัน	นันท	
24/7/2568	3.0	2.5	7.2	7.2	-	-	สริฉฉ	นันท	
25/7/2568	2.0	1.0	7.2	7.2	300 กรัม	-	สริฉฉ	นันท	
26/7/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ราชัน	นันท	
27/7/2568	2.0	1.0	7.4	7.4	300 กรัม	-	บรรณ	นันท	
28/7/2568	3.0	2.5	7.4	7.4	-	-	บรรณ	นันท	
29/7/2568	2.5	1.0	7.4	7.4	300 กรัม	-	จิรณ	นันท	
30/7/2568	3.0	3.0	7.4	7.4	-	-	ราชัน	นันท	
31/7/2568	3.0	2.0	7.4	7.4	-	-	สริฉฉ	นันท	

ตารางเดิมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ คลอรีน	ปริมาณ โซดาแอช	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH						
	เช้า	เย็น	เช้า	เย็น	(กรัม)	(กรัม)			
1/8/2568	2.0	1.5	7.4	7.2	-	-	ธีรฉ.	นันท.	
2/8/2568	1.5	0.0	7.2	7.2	500 กรัม	-	มรรค.	นันท.	
3/8/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	มรรค.	นันท.	
4/8/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ธีรฉ.	นันท.	
5/8/2568	3.0	3.0	7.4	7.4	-	-	ธีรฉ.	นันท.	
6/8/2568	3.0	3.0	7.2	7.2	-	-	ราชน.	นันท.	
7/8/2568	2.0	1.0	7.2	7.2	300 กรัม	-	ราชน.	นันท.	
8/8/2568	3.0	3.0	7.2	7.2	-	-	ธีรฉ.	นันท.	
9/8/2568	1.5	0.0	7.2	7.2	500 กรัม	-	มรรค.	นันท.	
10/8/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	มรรค.	นันท.	
11/8/2568	3.0	2.5	7.4	7.4	-	-	ธีรฉ.	นันท.	
12/8/2568	2.5	1.0	7.4	7.4	300 กรัม	-	ราชน.	นันท.	
13/8/2568	3.0	3.0	7.4	7.4	-	-	ธีรฉ.	นันท.	
14/8/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ธีรฉ.	นันท.	
15/8/2568	3.0	2.0	7.4	7.4	-	-	มรรค.	นันท.	
16/8/2568	3.0	2.0	7.4	7.4	-	-	มรรค.	นันท.	
17/8/2568	3.0	2.0	7.4	7.2	-	-	ธวัช.	นันท.	
18/8/2568	3.0	2.0	7.2	7.2	-	2.0 กก.	ธีรฉ.	นันท.	
19/8/2568	2.0	1.0	7.4	7.4	300 กรัม	-	ธีรฉ.	นันท.	
20/8/2568	3.0	2.0	7.4	7.4	-	-	ราชน.	นันท.	
21/8/2568	2.0	0.0	7.4	7.4	500 กรัม	-	ราชน.	นันท.	
22/8/2568	3.0	3.0	7.4	7.4	-	-	ธีรฉ.	นันท.	
23/8/2568	3.0	2.0	7.4	7.4	-	-	มรรค.	นันท.	
24/8/2568	2.5	2.0	7.2	7.2	-	2.0 กก.	ธวัช.	นันท.	
25/8/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ธวัช.	นันท.	
26/8/2568	3.0	3.0	7.4	7.4	-	-	ธีรฉ.	นันท.	
27/8/2568	2.5	1.0	7.4	7.4	300 กรัม	-	ราชน.	นันท.	
28/8/2568	3.0	3.0	7.4	7.4	-	-	ธีรฉ.	นันท.	
29/8/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ธีรฉ.	นันท.	
30/8/2568	3.0	2.5	7.4	7.4	-	-	มรรค.	นันท.	
31/8/2568	2.5	1.0	7.2	7.2	300 กรัม	-	มรรค.	นันท.	

ตารางเติมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ คลอรีน (กรัม)	ปริมาณ โซดาแอช (กรัม)	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH						
	เช้า	เย็น	เช้า	เย็น					
1/9/2568	3.0	3.0	7.4	7.4	-	-	ลลลล.	นันท.	
2/9/2568	3.0	2.5	7.4	7.4	-	-	ลลลล.	นันท.	
3/9/2568	2.0	1.5	7.4	7.4	-	-	ราชน.	นันท.	
4/9/2568	1.5	0.0	7.4	7.4	500 กรัม	-	วิรัช	นันท.	
5/9/2568	3.0	3.0	7.2	7.2	-	-	ลลลล.	นันท.	
6/9/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	นรรต	นันท.	
7/9/2568	2.5	0.5	7.2	7.2	400 กรัม	-	ธอช.	นันท.	
8/9/2568	1.5	0.0	7.2	7.2	500 กรัม	-	ลลลล.	นันท.	
9/9/2568	3.0	3.0	7.2	7.2	-	-	ราชน.	นันท.	
10/9/2568	2.5	1.5	7.4	7.4	300 กรัม	-	ราชน.	นันท.	
11/9/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท.	
12/9/2568	3.0	3.0	7.4	7.4	-	-	นรรต	นันท.	
13/9/2568	2.5	2.0	7.4	7.4	-	-	นรรต	นันท.	
14/9/2568	1.0	0.0	7.4	7.4	500 กรัม	-	ธอช.	นันท.	
15/9/2568	3.0	3.0	7.0	7.2	-	2.0 กก.	ลลลล.	นันท.	
16/9/2568	3.0	3.0	7.4	7.4	-	-	ลลลล.	นันท.	
17/9/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ราชน.	นันท.	
18/9/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท.	
19/9/2568	3.0	2.0	7.2	7.2	200 กรัม	-	วิรัช	นันท.	
20/9/2568	3.0	3.0	7.2	7.2	-	-	นรรต	นันท.	
21/9/2568	3.0	2.5	7.2	7.2	-	2.0 กก.	ฉ.พินิจ.	นันท.	
22/9/2568	2.0	0.5	7.2	7.4	400 กรัม	-	ลลลล.	นันท.	
23/9/2568	3.0	3.0	7.4	7.4	-	-	ราชน.	นันท.	
24/9/2568	1.0	0.0	7.4	7.4	500 กรัม	-	วิรัช	นันท.	
25/9/2568	3.0	2.5	7.4	7.4	-	-	วิรัช	นันท.	
26/9/2568	1.0	0.0	7.2	7.2	500 กรัม	-	นรรต	นันท.	
27/9/2568	3.0	3.0	7.2	7.2	-	-	นรรต	นันท.	
28/9/2568	3.0	3.0	7.2	7.2	-	-	ฉ.พินิจ.	นันท.	
29/9/2568	2.5	2.0	7.2	7.2	-	-	ลลลล.	นันท.	
30/9/2568	1.0	0.0	7.2	7.2	500 กรัม	-	ลลลล.	นันท.	

ตารางเติมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ	ปริมาณ	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH		คลอรีน	โซดาแอช			
	เช้า	เย็น	เช้า	เย็น	(กรัม)	(กรัม)			
1/10/2568	3.0	3.0	7.2	7.2	-	-	ราชน.	นันท.	
2/10/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ธีรช.	นันท.	
3/10/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ธีรช.	นันท.	
4/10/2568	3.0	3.0	7.4	7.4	-	-	บรรจ.	นันท.	
5/10/2568	3.0	2.0	7.4	7.4	200 กรัม	-	ฉฉ.	นันท.	
6/10/2568	3.0	3.0	7.4	7.4	-	-	สค.	นันท.	
7/10/2568	3.0	2.5	7.4	7.4	-	-	สค.	นันท.	
8/10/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ราชน.	นันท.	
9/10/2568	3.0	3.0	7.2	7.2	-	-	ราชน.	นันท.	
10/10/2568	2.5	2.0	7.2	7.2	-	-	ธีรช.	นันท.	
11/10/2568	2.0	0.5	7.2	7.2	400 กรัม	-	บรรจ.	นันท.	
12/10/2568	3.0	3.0	7.2	7.2	-	-	ฉฉ.	นันท.	
13/10/2568	2.5	1.0	7.2	7.2	300 กรัม	-	สค.	นันท.	
14/10/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ราชน.	นันท.	
15/10/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ธีรช.	นันท.	
16/10/2568	3.0	2.0	7.2	7.2	-	-	ธีรช.	นันท.	
17/10/2568	3.0	3.0	7.2	7.2	-	-	บรรจ.	นันท.	
18/10/2568	3.0	2.5	7.2	7.2	-	-	บรรจ.	นันท.	
19/10/2568	2.0	1.0	7.2	7.2	300 กรัม	-	ฉฉ.	นันท.	
20/10/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ฉฉ.	นันท.	
21/10/2568	2.0	1.0	7.4	7.4	300 กรัม	-	ธีรช.	นันท.	
22/10/2568	3.0	3.0	7.4	7.4	-	-	สค.	นันท.	
23/10/2568	2.5	2.0	7.2	7.2	-	-	ราชน.	นันท.	
24/10/2568	1.0	0.0	7.2	7.2	500 กรัม	-	ราชน.	นันท.	
25/10/2568	3.0	2.0	7.2	7.2	-	-	ธีรช.	นันท.	
26/10/2568	2.0	0.0	7.2	7.2	500 กรัม	-	บรรจ.	นันท.	
27/10/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ฉฉ.	นันท.	
28/10/2568	3.0	2.5	7.2	7.2	-	-	สค.	นันท.	
29/10/2568	2.0	0.5	7.4	7.4	400 กรัม	-	ราชน.	นันท.	
30/10/2568	3.0	2.0	7.2	7.2	-	-	ธีรช.	นันท.	
31/10/2568	3.0	3.0	7.2	7.2	-	-	ธีรช.	นันท.	

ตารางเติมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ คลอรีน (กรัม)	ปริมาณ โซดาแอช (กรัม)	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH						
	เช้า	เย็น	เช้า	เย็น					
1/11/2568	3.0	2.5	7.2	7.2	-	-	มรกต	นันท	
2/11/2568	2.0	1.0	7.2	7.2	300 กรัม	-	ดอช	นันท	
3/11/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	สจจ	นันท	
4/11/2568	2.0	1.0	7.4	7.4	300 กรัม	-	สจจ	นันท	
5/11/2568	3.0	3.0	7.4	7.4	-	-	ราชฟ	นันท	
6/11/2568	2.5	2.0	7.2	7.2	-	-	ราชฟ	นันท	
7/11/2568	1.0	0.0	7.2	7.2	500 กรัม	-	วิรัช	นันท	
8/11/2568	3.0	2.0	7.2	7.2	-	-	มรรค	นันท	
9/11/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	ฉนิฟ	นันท	
10/11/2568	3.0	2.0	7.4	7.4	200 กรัม	-	สจจ	นันท	
11/11/2568	3.0	3.0	7.4	7.4	-	-	ราชฟ	นันท	
12/11/2568	3.0	2.0	7.4	7.4	200 กรัม	-	วิรัช	นันท	
13/11/2568	3.0	3.0	7.4	7.4	-	-	วิรัช	นันท	
14/11/2568	3.0	2.5	7.4	7.4	-	-	มรรค	นันท	
15/11/2568	2.0	0.5	7.4	7.4	400 กรัม	-	มรรค	นันท	
16/11/2568	3.0	3.0	7.2	7.2	-	-	ฉนิฟ	นันท	
17/11/2568	2.5	2.0	7.2	7.2	-	-	สจจ	นันท	
18/11/2568	2.0	0.5	7.2	7.2	400 กรัม	-	สจจ	นันท	
19/11/2568	3.0	3.0	7.2	7.2	-	-	ราชฟ	นันท	
20/11/2568	2.5	1.0	7.2	7.2	300 กรัม	-	ราชฟ	นันท	
21/11/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	วิรัช	นันท	
22/11/2568	2.0	0.5	7.4	7.4	400 กรัม	-	มรกต	นันท	
23/11/2568	3.0	2.0	7.2	7.2	-	-	ดอช	นันท	
24/11/2568	3.0	3.0	7.2	7.2	-	-	ดอช	นันท	
25/11/2568	2.0	0.5	7.4	7.4	-	-	สจจ	นันท	
26/11/2568	1.0	0.0	7.2	7.2	500 กรัม	-	ราชฟ	นันท	
27/11/2568	3.0	2.0	7.2	7.2	-	-	วิรัช	นันท	
28/11/2568	2.0	0.0	7.2	7.2	500 กรัม	-	วิรัช	นันท	
29/11/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	มรรค	นันท	
30/11/2568	3.0	2.5	7.2	7.2	-	-	ดอช	นันท	

ตารางเดิมวัดค่าเคมี (คลอรีน / pH) สระว่ายน้ำ โครงการ KANTARY HOTEL อมตะ บางปะกง

วันที่	ค่าที่วัดได้				ปริมาณ คลอรีน (กรัม)	ปริมาณ โซดาแอช (กรัม)	ผู้ปรับ	ผู้ตรวจสอบ	หมายเหตุ
	คลอรีน		pH						
	เช้า	เย็น	เช้า	เย็น					
1/12/2568	2.0	0.5	7.4	7.4	400 กรัม	-	สจ.พ.	น.พ.	
2/12/2568	3.0	2.0	7.2	7.2	-	-	สจ.พ.	น.พ.	
3/12/2568	3.0	3.0	7.2	7.2	-	-	สจ.พ.	น.พ.	
4/12/2568	3.0	2.5	7.2	7.2	-	-	สจ.พ.	น.พ.	
5/12/2568	2.0	1.0	7.2	7.2	300 กรัม	-	มรรจ.	น.พ.	
6/12/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	สจ.พ.	น.พ.	
7/12/2568	2.0	1.0	7.4	7.4	300 กรัม	-	สจ.พ.	น.พ.	
8/12/2568	3.0	3.0	7.4	7.4	-	-	สจ.พ.	น.พ.	
9/12/2568	2.5	2.0	7.2	7.2	-	-	สจ.พ.	น.พ.	
10/12/2568	1.0	0.0	7.2	7.2	500 กรัม	-	สจ.พ.	น.พ.	
11/12/2568	3.0	2.0	7.2	7.2	-	-	สจ.พ.	น.พ.	
12/12/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	มรรจ.	น.พ.	
13/12/2568	3.0	2.0	7.4	7.4	200 กรัม	-	มรรจ.	น.พ.	
14/12/2568	3.0	3.0	7.4	7.4	-	-	สจ.พ.	น.พ.	
15/12/2568	3.0	2.0	7.4	7.4	200 กรัม	-	สจ.พ.	น.พ.	
16/12/2568	3.0	3.0	7.4	7.4	-	-	สจ.พ.	น.พ.	
17/12/2568	3.0	2.5	7.4	7.4	-	-	สจ.พ.	น.พ.	
18/12/2568	2.0	0.5	7.4	7.4	400 กรัม	-	สจ.พ.	น.พ.	
19/12/2568	3.0	3.0	7.4	7.4	-	-	สจ.พ.	น.พ.	
20/12/2568	2.5	2.0	7.2	7.2	-	-	สจ.พ.	น.พ.	
21/12/2568	1.0	0.0	7.2	7.2	500 กรัม	-	มรรจ.	น.พ.	
22/12/2568	3.0	2.0	7.2	7.2	-	-	สจ.พ.	น.พ.	
23/12/2568	3.0	3.0	7.2	7.2	-	2.0 กก.	สจ.พ.	น.พ.	
24/12/2568	3.0	2.0	7.4	7.4	200 กรัม	-	สจ.พ.	น.พ.	
25/12/2568	3.0	3.0	7.4	7.4	-	-	สจ.พ.	น.พ.	
26/12/2568	3.0	2.0	7.4	7.4	200 กรัม	-	สจ.พ.	น.พ.	
27/12/2568	3.0	3.0	7.4	7.4	-	-	มรรจ.	น.พ.	
28/12/2568	3.0	2.5	7.4	7.4	-	-	สจ.พ.	น.พ.	
29/12/2568	2.0	0.5	7.4	7.4	400 กรัม	-	สจ.พ.	น.พ.	
30/12/2568	3.0	3.0	7.4	7.4	-	-	สจ.พ.	น.พ.	
31/12/2568	2.5	2.0	7.4	7.4	-	-	สจ.พ.	น.พ.	