



บริษัท วิศวกรรมเคมี จำกัด

THAI CHEMICAL & ENGINEERING CO., LTD.

1048/2 ซ.สุขุมวิท 66/1 อ.สุขุมวิท แขวงพระโขนงใต้ เขตพระโขนง กรุงเทพฯ 10260 โทร. 0-2744-9911 แฟกซ์ 0-2393-0165

1048/2 Soi Sukhumvit 66/1, Sukhumvit Rd., Prakanong Tai, Prakanong, Bangkok 10260 TEL. 0-2744-9911 FAX 0-2393-0165

No. 3038/68

WASTE WATER ANALYSIS REPORT

Date : 16/10/68

Analysis Date : 8/10/68-14/10/68

Customer : บริษัท ดี เอราวัณกรุ๊ป จำกัด (มหาชน) สาขาที่ 00009

Sampling Date : 7/10/68

Address : 463/68 , 463/99 หมู่ 9 ถ.พญาสาย 1 ต.หนองปรือ อ.บางละมุง

Sampling Time : 13.30

จ.ชลบุรี 20150

Received Date : 8/10/68

Tel : 099-291-4192

Reference Number	WP/AD 5613/68			
Parameter	Unit	น้ำบ่อ Recycle	Standard Treated	Method of Analysis
Appearance		เหลืองใส		
pH		@ 23.0 °C = 7.4	5.5-9.0	Electrometric (SM 2023:4500-H ⁺ B.)
Biochemical Oxygen Demand	(mg/l)	5	≤ 20	5-Day BOD Test, Azide Modification (SM 2023:5210 B.)
Total Suspended Solids	(mg/l)	8	≤ 30	Dried at 103-105°C (SM 2023:2540 D.)
Oil & Grease	(mg/l)	< 5.00	≤ 20	Soxhlet Extraction (SM 2023:5520 D.)
Total Kjeldahl Nitrogen	(mg/l)	45.02	≤ 35	Macro-Kjeldahl, Titrimetric (SM 2023:4500-N(org) B.)
Sulfide	(mg/l)	Not detected	≤ 1.0	ZnS Precipitation, Iodometric (SM 2023:4500-S ²⁻ F.)
Free Chlorine	(mg/l as Cl ₂)	Not detected	≤ 1.0	Test Kit
Total Coliform	(MPN/100 ml)	9,200	≤ 5000	Multiple tube technique

SM : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th Edition, 2023.

❖ The results relate only to the samples tested and apply to customer's self-drawn samples only.

❖ This analysis report may not be reproduced other than in full, except with the prior written approval of the technical manager.

Approved by ศุภณัฐ วัฒนกรพงศ์
(สัญญารัตน์ พลอยกระจำง)