



บริษัท วิศวกรรมเคมี จำกัด

THAI CHEMICAL & ENGINEERING CO., LTD.

1048/2 ซ.สุขุมวิท 66/1 ถ.สุขุมวิท แขวงพระโขนงใต้ เขตพระโขนง กรุงเทพฯ 10260 โทร. 0-2744-9911 แฟกซ์ 0-2393-0165

1048/2 Soi Sukhumvit 66/1, Sukhumvit Rd., Prakanong Tai, Prakanong, Bangkok 10260 TEL. 0-2744-9911 FAX 0-2393-0165

No. 3748/68

WASTE WATER ANALYSIS REPORT

Date : 16/12/68

Analysis Date : 9/12/68-15/12/68

Customer : บริษัท ดี เอราวิณกรู๊ป จำกัด (มหาชน) สาขาที่ 00009

Sampling Date : 9/12/68

Address : 463/68 , 463/99 หมู่ 9 ถ.พืฒสาสาย 1 ต.หนองปรือ อ.บางละมุง
จ.ชลบุรี 20150

Sampling Time : 12.30

Received Date : 9/12/68

Tel : 099-291-4192

Reference Number	WP/AD 6896/68	WP/AD 6897/68		
Parameter	Unit	น้ำเสียก่อนบำบัด	น้ำบ่อน้ำใส	Standard Treated
Appearance		น้ำตาลขุ่น มีตะกอน	น้ำตาลขุ่น มีตะกอน	
pH		@ 23.7 °C = 7.2	@ 23.6 °C = 7.1	5.5-9.0
Biochemical Oxygen Demand	(mg/l)	29	26	≤ 20
Total Suspended Solids	(mg/l)	180	58	≤ 30
Total Dissolved Solids	(mg/l)	360	406	≤ 1000
Oil & Grease	(mg/l)	10.14	< 5.00	≤ 20
Total Kjeldahl Nitrogen	(mg/l)	48.11	50.35	≤ 35
Sulfide	(mg/l)	Not detected	Not detected	≤ 1.0
Settleable Solids	(ml/l)	15.0	6.0	-
Total Coliform	(MPN/100 ml)	> 16,000	> 16,000	≤ 5000

SM : Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th Edition, 2023.

❖ The results relate only to the samples tested and apply to customer's self-drawn samples only.

❖ This analysis report may not be reproduced other than in full, except with the prior written approval of the technical manager.

Approved by 
(สัญญารัตน์ พงษ์กรกระจำง)