

ที่	รายการ	ทำครั้ง ก่อน	ความถี่	กำหนด เช็ค	พ.ศ. 2568											
					ม.ค.	ก.พ.	มี.ค.	เม.ย.	พ.ค.	มิ.ย.	ก.ค.	ส.ค.	ก.ย.	ต.ค.	พ.ย.	ธ.ค.
A	งานซ่อมบำรุงพื้นที่ส่วนกลาง															
1	ตรวจเช็คห้องเครื่องไฟฟ้า(ตู้ไฟฟ้า,หม้อแปลง,GEN.)		ทุกเดือน	ศุกร์	17	14	14	18	9	13	11	15	12	17	14	19
2	ตรวจเช็คห้องปั้ม (ปั้มน้ำดีและดับเพลิง)		ทุกเดือน	ศุกร์	17	14	14	18	9	13	11	15	12	17	14	19
3	ตรวจเช็คห้องปั้ม (ปั้มน้ำบ่อน้ำดับเพลิง)		ทุกเดือน	ศุกร์	17	14	14	18	9	13	11	15	12	17	14	19
4	ตรวจเช็คห้องปั้สเตอร์ปั้ม		ทุกเดือน	ศุกร์	17	14	14	18	9	13	11	15	12	17	14	19
5	ตรวจเช็คห้องปั้มสรวายน้ำ		ทุกเดือน	ศุกร์	17	14	14	18	9	13	11	15	12	17	14	19
6	ตรวจเช็คปั้มและอุปกรณ์ผนังน้ำตก + บ่อน้ำลิ้น		ทุกเดือน	ศุกร์	17	14	14	18	9	13	11	15	12	17	14	19
7	ตรวจเช็คไฟแสงสว่างส่วนกลาง บันไดหนีไฟ		ทุกเดือน	เสาร์	18	15	15	19	10	14	12	16	13	18	15	13
8	ตรวจเช็คไฟแสงสว่างส่วนกลาง หน้าลิฟท์		ทุกเดือน	อาทิตย์	19	16	16	20	11	15	13	17	14	18	16	17
9	ตรวจเช็คไฟแสงสว่างส่วนกลาง ชั้นจอดรถ		ทุกเดือน	จันทร์	20	17	17	21	12	16	14	18	15	19	17	22
10	ตรวจเช็คไฟแสงสว่างส่วนกลาง Lobbyและห้องต่าง ๆ		ทุกเดือน	จันทร์	20	17	17	21	12	16	14	18	15	19	17	22
11	ตรวจเช็คสัญญาณFire Alarm		ทุกเดือน	อังคาร	21	18	18	22	13	17	15	19	16	20	18	19
12	ตรวจเช็คห้องขาวน่าน		ทุกเดือน	พฤหัสบดี	23	20	20	24	22	19	17	21	18	16	20	18
13	ตรวจเช็คห้องสตรัม		ทุกเดือน	พฤหัสบดี	23	20	20	24	22	19	17	21	18	16	20	18
14	ตรวจเช็คห้องออกกักทางกาย		ทุกเดือน	พฤหัสบดี	23	20	20	24	22	19	17	21	18	16	20	18
15	ตรวจเช็คและสลับการใช้งานPRV ในชาร์ป		ทุกเดือน	พฤหัสบดี	23	20	20	24	22	19	17	21	18	16	20	18
16	ตรวจเช็คตั้งเวลา Timer ตามจุด		ทุกเดือน	พฤหัสบดี	23	20	20	24	22	19	17	21	18	16	20	18
17	ไฟแสงสว่างจากรายอดตึก ชั้นหลังคา		ทุกเดือน	พฤหัสบดี	23	20	20	24	22	19	17	21	18	16	20	18
18	ตรวจเช็คตู้ดับเพลิงและวาล์วดับเพลิง		ทุกเดือน	ศุกร์	24	21	21	25	23	20	18	22	19	24	21	19
19	ตรวจเช็คถังดับเพลิง		ทุกเดือน	ศุกร์	24	21	21	25	23	20	18	22	19	24	21	19
20	ตรวจเช็คไฟแสงสว่าง Emer.Batt.,Fire Exit		ทุกเดือน	เสาร์	25	22	22	26	24	21	19	23	20	25	22	20
22	ตรวจเช็ค กล้องวงจรปิด		ทุกเดือน	อาทิตย์	26	23	23	27	25	22	20	24	21	26	23	21
21	ตรวจเช็ค Key Card Lock "ONITY"		ทุก4เดือน	จันทร์	27				26				22			
23	ตรวจเช็คระบบประกาศ (Sound Speaker)		ทุก4เดือน	จันทร์	27				26				22			
24	ตรวจเช็คตู้ PABX , MDF		ทุก4เดือน	อังคาร	28				27				23			
25	ตรวจเช็คระบบ TV		ทุก4เดือน	อังคาร	28				27				23			
26	ตรวจเช็ค พัฒนาระบบระบายอากาศทั้งหมด		ทุก4เดือน	พฤหัสบดี	30				31				28			
27	ตรวจเช็คตู้ไฟฟ้า ในช่องชาร์ปและห้องเครื่อง		ทุก6เดือน	ศุกร์			27						26			
28	ตรวจเช็คประตูหนีไฟ		ทุก6เดือน	ศุกร์			27						26			
29	เติมน้ำมันเชื้อเพลิง Generator (200 L)		ทุก6เดือน				25						15			
30	เติมน้ำมันเชื้อเพลิงปั้มดับเพลิง (เติมน้ำมัน 1,000 ลิตร)		ทุกปี	-	-	-	-	-	-	-	-	-	-	-	-	-
31	เปลี่ยนแบตเตอรี่ Generator (2)	12/7/2567	ทุก2ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
32	เปลี่ยนแบตเตอรี่ปั้มดับเพลิง (2)	24/3/2568	ทุก2ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
33	เปลี่ยนแบตเตอรี่ตู้ FIRE ALARM (2)	6/6/67	ทุก2ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
34	เปลี่ยนแบตเตอรี่ตู้ PABX (12)	24/5/68	ทุก3ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
	งานซ่อมบำรุงห้องพักลูกค้า															
1	แอร์ ; วัคกระแส,น้ำยา,ท่อน้ำทิ้ง,เปลี่ยน Filter		ทุก3เดือน		←		→	←		→	←		→	←		→
2	แอร์ ; ล้างถาดน้ำทิ้งและท่อน้ำทิ้ง		ทุก6เดือน		←					→	←					→
3	แอร์ ; ทำความสะอาดพัดลมคอยล์เย็น		ทุก6เดือน		←					→	←					→
4	แอร์ ; ล้างคอยล์ร้อนแอร์ด้วยน้ำ		ทุกปี				←		→							
5	แอร์ ; กวดขันน็อตยึดจุดต่อสายและหัวหลักคอมพ์		ทุกปี				←		→							
6	ตรวจเช็คตู้ไฟฟ้า,เครื่องทำน้ำร้อน		ทุกปี										←			→
7	ตรวจเช็คสายแก๊ส,หัวสปาร์ค,หัวเตา		ทุก6เดือน		←					→	←					→
8	ตรวจเช็คเครื่องบดเศษอาหารและท่อน้ำทิ้ง		ทุก6เดือน		←					→	←					→
9	ตรวจเช็คสายอ่อนน้ำดี,น้ำร้อน,สายชำระ		ทุก6เดือน		←					→	←					→
10	ตรวจเช็คกรองก๊อกน้ำและหัวฝักบัว		ทุก6เดือน		←					→	←					→
	งานซ่อมบำรุงโดยบริษัท ฯจากข้างนอก															
1	ตรวจเช็คตู้ไฟฟ้าแรงสูง-แรงต่ำ (ESSI)	22/7/2568	ทุก3ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
2	ตรวจเช็คหม้อแปลงไฟฟ้า	22/7/2568	ทุก3ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
3	ตรวจเช็คGen.เปลี่ยนถ่านน้ำมันเครื่อง	8/7/2568	ทุก 2 ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
4	ตรวจเช็คปั้มน้ำดี	OOQ	ทุก3ปี	-	-	-	-	-	-	-	-	-	-	-	-	-
5	ตรวจเช็คปั้มดับเพลิง	OOQ	ทุก3ปี													
6	ตรวจเช็คปัสเตอร์ปั้ม	OOQ	ทุก3ปี													
7	ตรวจเช็ค PRV โดยสมิธเทค		ทุก2ปี													
8	ตรวจเช็คห้องออกกักทางโดยสปอร์ตแอนด์ลอน	OOQ	ทุก3เดือน													
9	ตรวจเช็คถังดับเพลิงโดย NIPPON	OOQ	ทุก3เดือน													
10	ตรวจเช็คห้องขาวน่านสตรัม โดยวอร์ธนะ	OOQ	ทุก3เดือน													
11	ตรวจเช็คตู้ PABX โดย Infinity Network Solution	OOQ	ทุก 1 ปี													
12	ตรวจเช็คระบบ Fire Alarm โดยดิยะ มาสเตอร์ ฯ	OOQ	ทุก 1 ปี													
13	ตรวจเช็ค KEY CARD LOCK โดย Onity	15/3/2568	ทุก 1 ปี													

LOG TEST FIRE ALAM CONTROL SYSTEM 2025

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/1/68

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR701.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Test Alarm Smoke Detector Bed Room 701 PL.7 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7....../.....1...../.....68.....

DATE:.....7....../.....1...../.....68.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2025

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/2/68

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR302.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Test Alarm Smoke Detector Bed Room 302 PL.3 Bell working Normal

.....

.....

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7....../.....2...../.....68.....

DATE:.....7....../.....2...../.....68.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2025

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 10/3/68

LOCATION TEST FIRE ALARM CONTROL PANEL SYSTEM

SMOKE DETECTOR	408		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL		ABNORMAL	NORMAL		ABNORMAL			

Suggestion / Remark.Test Alarm Smoke Detector living room 408 FL.4 Bell working Normal

.....

.....

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....10...../.....3...../.....68.....

DATE:.....10...../.....3...../.....68.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2025

SYSTEM:FIRE PROTECTION

FREQUENCY : MONTHLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 10/4/68

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR508.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Test Alarm Smoke Detector living room 508 FL5 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....10...../.....4...../.....68.....

DATE:.....10...../.....4...../.....68.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2025

SYSTEM:FIRE PROTECTION

FREQUENCY : MONTHLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 10/5/68

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR501.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Test Alarm Smoke Detector living room 501 FL.5 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....10...../.....5...../.....68.....

DATE:.....10...../.....5...../.....68.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2025

SYSTEM:FIRE PROTECTION

FREQUENCY : MONTHLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/6/68

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR706.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Test Alarm Smoke Detector Bed Room 706 FL.7 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7....../.....6...../.....68.....

DATE:.....7....../.....6...../.....68.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF January 2025

Location	Emergency light			Central Batt	Remark	Check By
	Guest's life Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	
12 th floor	/	/		/	ปกติ	
11 th floor	/	/		/	ปกติ	
10 th floor	/	/		/	ปกติ	
9 th floor	/	/		/	ปกติ	
8 th floor	/	/		/	ปกติ	
7 th floor	/	/		/	ปกติ	
6 th floor	/	/		/	ปกติ	
5 th floor	/	/	/	/	ปกติ	
4 th floor	/	/	/	/	ปกติ	
3 rd floor	/	/	/	/	ปกติ	
2 nd floor	/	/		/	ปกติ	
Ground floor	/	/		/	ปกติ	
Basement floor	/	/			ปกติ	
Carpark	/	/			ปกติ	

Public Area

Location	Emergency light		Central Batt	Remark	Check By
Administration office			/		
Housekeeping office			/		
Engineering office			/		
Laundry room	/				
Canteen	/				
Male locker room	/				
Female locker room	/				
Fitness Center	X			ไม่มี	
In front of guest's lift 14 th floor	X			ไม่มี	

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF February 2025

Location	Emergency light			Central Batt	Remark	Check By
	Guest's life Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	
12 th floor	/	/		/	ปกติ	
11 th floor	/	/		/	ปกติ	
10 th floor	/	/		/	ปกติ	
9 th floor	/	/		/	ปกติ	
8 th floor	/	/		/	ปกติ	
7 th floor	/	/		/	ปกติ	
6 th floor	/	/		/	ปกติ	
5 th floor	/	/	/	/	ปกติ	
4 th floor	/	/	/	/	ปกติ	
3 rd floor	/	/	/	/	ปกติ	
2 nd floor	/	/		/	ปกติ	
Ground floor	/	/		/	ปกติ	
Basement floor	/	/			ปกติ	
Carpark	/	/			ปกติ	

Public Area

Location	Emergency light		Central Batt	Remark	Check By
Administration office			/		
Housekeeping office			/		
Engineering office			/		
Laundry room	/				
Canteen	/				
Male locker room	/				
Female locker room	/				
Fitness Center	X			ไม่มี	
In front of guest's lift 14 th floor	X			ไม่มี	

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF March 2025

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	
12 th floor	/	/		/	ปกติ	
11 th floor	/	/		/	ปกติ	
10 th floor	/	/		/	ปกติ	
9 th floor	/	/		/	ปกติ	
8 th floor	/	/		/	ปกติ	
7 th floor	/	/		/	ปกติ	
6 th floor	/	/		/	ปกติ	
5 th floor	/	X	/	/	เสีย1	
4 th floor	/	/	/	/	ปกติ	
3 rd floor	/	/	/	/	ปกติ	
2 nd floor	/	/		/	ปกติ	
Ground floor	X	/		/	เสีย1	
Basement floor	/	/			ปกติ	
Carpark	/	/			ปกติ	

Public Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		/		
Housekeeping office		/		
Engineering office		/		
Laundry room	/			
Canteen	/			
Male locker room	X		เสีย	
Female locker room	/			
Fitness Center	X		ไม่มี	
In front of guest's lift 14 th floor	X		ไม่มี	

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF April 2025

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	
12 th floor	/	/		/	ปกติ	
11 th floor	/	/		/	ปกติ	
10 th floor	/	/		/	ปกติ	
9 th floor	/	/		/	ปกติ	
8 th floor	/	/		/	ปกติ	
7 th floor	/	/		/	ปกติ	
6 th floor	/	/		/	ปกติ	
5 th floor	/	X	/	/	เสีย1	
4 th floor	/	/	/	/	ปกติ	
3 rd floor	/	/	/	/	ปกติ	
2 nd floor	/	/		/	ปกติ	
Ground floor	X	/		/	เสีย1	
Basement floor	/	/			ปกติ	
Carpark	/	/			ปกติ	

Public Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		/		
Housekeeping office		/		
Engineering office		/		
Laundry room	/			
Canteen	/			
Male locker room	X		เสีย	
Female locker room	/			
Fitness Center	X		ไม่มี	
In front of guest's lift 14 th floor	X		ไม่มี	

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF May 2025

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	
12 th floor	/	/		/	ปกติ	
11 th floor	/	/		/	ปกติ	
10 th floor	/	/		/	ปกติ	
9 th floor	/	/		/	ปกติ	
8 th floor	/	/		/	ปกติ	
7 th floor	/	/		/	ปกติ	
6 th floor	/	/		/	ปกติ	
5 th floor	/	X	/	/	เสีย1	
4 th floor	X	/	/	X	เสีย1	
3 rd floor	/	/	/	/	ปกติ	
2 nd floor	/	/		/	ปกติ	
Ground floor	X	/		/	เสีย1	
Basement floor	/	/			ปกติ	
Carpark	/	/			ปกติ	

Public Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		/		
Housekeeping office		/		
Engineering office		/		
Laundry room	/			
Canteen	/			
Male locker room	X		เสีย	
Female locker room	/			
Fitness Center	X		ไม่มี	
In front of guest's lift 14 th floor	X		ไม่มี	

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF June 2025

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	
12 th floor	/	/		/	ปกติ	
11 th floor	/	/		/	ปกติ	
10 th floor	/	/		/	ปกติ	
9 th floor	/	/		/	ปกติ	
8 th floor	/	/		/	ปกติ	
7 th floor	/	/		/	ปกติ	
6 th floor	/	/		/	ปกติ	
5 th floor	/	/	/	/	ปกติ	
4 th floor	/	/	/	/	ปกติ	
3 rd floor	/	/	/	/	ปกติ	
2 nd floor	/	/		/	ปกติ	
Ground floor	/	/		/	ปกติ	
Basement floor	/	/			ปกติ	
Carpark	/	/			ปกติ	

Public Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		/		
Housekeeping office		/		
Engineering office		/		
Laundry room	/			
Canteen	/			
Male locker room	/			
Female locker room	/			
Fitness Center	X		ไม่มี	
In front of guest's lift 14 th floor	X		ไม่มี	

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF January 2025						
LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/1/68	Remark
	Guest's lift Zone		Staff's lift Zone		CHECK BY XXXXXXXXXX	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF February 2025


LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: XXXXXXXXXX
	Guest's lift Zone		Staff's lift Zone		DATE : 7/2/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF March 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: 
	Guest's lift Zone		Staff's lift Zone		DATE : 10/3/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF April 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: [REDACTED]
	Guest's lift Zone		Staff's lift Zone		DATE : 10/4/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF May 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: XXXXXXXXXX
	Guest's lift Zone		Staff's lift Zone		DATE : 10/5/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....


.....

.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF June 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: 
	Guest's lift Zone		Staff's lift Zone		DATE : 7/6/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF January 2025

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/1/68	Remark
	Guest's lift Zone		Staff's lift Zone		CHECK BY <div></div>	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF February 2025

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/2/68	Remark
	Guest's lift Zone		Staff's lift Zone		CHECK BY <div></div>	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF March 2025

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 10/3/68	Remark
	Guest's lift Zone		Staff's lift Zone		CHECK BY <div></div>	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF April 2025						
LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 10/4/68	Remark
	Guest's lift Zone		Staff's lift Zone		CHECK BY <div></div>	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF May 2025						
LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 10/5/68	Remark
	Guest's lift Zone		Staff's lift Zone		CHECK BY <div></div>	
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE		
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
206 room	/					
Storeroom	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF June2025						
LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/6/68	Remark
	Guest's lift Zone		Staff's lift Zone			
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE	CHECK BY XXXXXXXXXX	
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					
Storeroom	/					

Remark.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...1.../...68.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL :.....460.....LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3 EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5 RECORDED VOLTAGE OF BATTERY : B1.....14.6.....V B2.....12.6.....V	
6 RECORDED ENGINE WATER TEMPERATURE :.....80.....C'	
7 RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8 RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9 RECORDED WORK HOUR OF FIRE PUMP :.....000327.....HOUR	
10 EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] CHA
11 EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] CHA
12 TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] COR
13 TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] COR
14 TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] COR
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] COR
16 CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED:	
18.1 FIRE PUMP:	START :.....220.....PSI
18.2 JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19	TIME :START.....15.00..... TIME :STO
20	

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....

.....

CHECKED BY :.....[REDACTED].....	APPROVED BY :.....[REDACTED].....
(.....)	(.....)
DATE :.....7.../...1.../...68.....	DATE :.....7.../...1.../...68.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...2.../...68.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL :.....455.....LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3 EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5 RECORDED VOLTAGE OF BATTERY : B1.....14.6.....V B2.....12.6.....V	
6 RECORDED ENGINE WATER TEMPERATURE :.....80.....C	
7 RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8 RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9 RECORDED WORK HOUR OF FIRE PUMP :.....000328.....HOUR	
10 EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] CHA
11 EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] CHA
12 TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] COR
13 TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] COR
14 TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] COR
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] CO
16 CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED:	
18.1 FIRE PUMP:	START :.....220.....PSI
18.2 JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19	TIME :START.....15.00..... TIME :STO
20	

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....

.....

CHECKED BY :.....[REDACTED].....	APPROVED BY :.....[REDACTED].....
(.....)	(.....)
DATE :.....7.../.....2.../.....68.....	DATE :.....7.../.....2.../.....68.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :10.../...3.../...68.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL :.....450.....LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3 EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5 RECORDED VOLTAGE OF BATTERY : B1.....14.6.....V B2.....12.6.....V	
6 RECORDED ENGINE WATER TEMPERATURE :.....80.....C	
7 RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8 RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9 RECORDED WORK HOUR OF FIRE PUMP :.....000329.....HOUR	
10 EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] CHA
11 EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] CHA
12 TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] COR
13 TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] COR
14 TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] COR
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] COR
16 CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED:	
18.1 FIRE PUMP:	START :.....220.....PSI
18.2 JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19	TIME :START.....15.00..... TIME :STO
20	

SUGGESTION / REMARKS.....Manual test Running.....

.....ทดสอบแบตเตอรี่ ตัว 2 ไม่ทำงาน แบตแอมป์ต่ำ.....

.....

.....

CHECKED BY :.....[REDACTED].....	APPROVED BY :.....[REDACTED].....
(.....)	(.....)
DATE :.....10.../...3.../...68.....	DATE :.....10.../...3.../...68....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :10.../...4.../...68.....
SYSTEM : FIRE PROTECTION	FREQUENCY : MONTHLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.



1 RECORDED LEVEL OF DIESEL OIL :.....450.....LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3 EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5 RECORDED VOLTAGE OF BATTERY : B1.....14.6.....V B2.....12.6.....V	
6 RECORDED ENGINE WATER TEMPERATURE :.....80.....C	
7 RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8 RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9 RECORDED WORK HOUR OF FIRE PUMP :.....000329.....HOUR	
10 EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] CHA
11 EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] CHA
12 TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] COR
13 TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] COR
14 TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] COR
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] COR
16 CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED:	
18.1 FIRE PUMP:	START :.....220.....PSI
18.2 JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19	TIME :START.....15.00..... TIME :STO
20	

SUGGESTION / REMARKS.....Manual test Running.....

.....ทดสอบแบตเตอรี่ ตัว 2 ไม่ทำงาน แบตเตอรี่ตัว 1.....

.....

.....

CHECKED BY :..... 	APPROVED BY :..... 
(.....)	(.....)
DATE :.....10.../...4.../...68.....	DATE :.....10.../...4.../...68....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :10.../...5...../...68.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL :.....450.....LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3 EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5 RECORDED VOLTAGE OF BATTERY : B1.....14.6.....V B2.....12.6.....V	
6 RECORDED ENGINE WATER TEMPERATURE :.....80.....C	
7 RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8 RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9 RECORDED WORK HOUR OF FIRE PUMP :.....000330.....HOUR	
10 EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] CHA
11 EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] CHA
12 TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] COR
13 TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] COR
14 TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] COR
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] CO
16 CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED:	
18.1 FIRE PUMP:	START :.....220.....PSI
18.2 JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19	TIME :START.....15.00..... TIME :STO
20	

SUGGESTION / REMARKS.....Manual test Running.....

.....ทดสอบแบตเตอรี่ ตัว 2 ไม่ทำงาน แบตแอมป์ต่ำ.....

.....

.....

CHECKED BY :..... [REDACTED]	APPROVED BY :..... [REDACTED]
(.....)	(.....)
DATE :.....10.../...5...../...68.....	DATE :.....10.../...5...../...68....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...6.../...68.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1 RECORDED LEVEL OF DIESEL OIL :.....458.....LITE	
2 EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3 EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4 EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5 RECORDED VOLTAGE OF BATTERY : B1.....14.7.....V B2.....12.5.....V	
6 RECORDED ENGINE WATER TEMPERATURE :.....80.....C	
7 RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8 RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9 RECORDED WORK HOUR OF FIRE PUMP :.....000330.....HOUR	
10 EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] CHA
11 EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] CHA
12 TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] COR
13 TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] COR
14 TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] COR
15 EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] CO
16 CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17 RECORDED PRESSURE OF WATER PIPE :	
17.1 OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2 OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18 RELEASE WATER FOR AUTOMATIC TESTED:	
18.1 FIRE PUMP:	START :.....220.....PSI
18.2 JOCKEY PUMP:	START :.....210.....PSI STOP :.....240.....PSI
19	TIME :START.....15.00..... TIME :STOP.....15.10.....
20	

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....


.....

CHECKED BY :.....[REDACTED].....	APPROVED BY :.....[REDACTED].....
(.....)	(.....)
DATE :.....7.../...6.../...68.....	DATE :.....7.../...6.../...68.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF January 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: 
	Guest's lift Zone		Staff's lift Zone		DATE : 7/1/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF February 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: XXXXXXXXXX
	Guest's lift Zone		Staff's lift Zone		DATE : 7/2/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF March 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: XXXXXXXXXX
	Guest's lift Zone		Staff's lift Zone		DATE : 10/3/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....


.....

.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF April 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: 
	Guest's lift Zone		Staff's lift Zone		DATE : 10/4/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF May 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: XXXXXXXXXX
	Guest's lift Zone		Staff's lift Zone		DATE : 10/5/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

.....

.....

.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT SIGN FOR DETAIL OF June 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				CHECKED BY: [REDACTED]
	Guest's lift Zone		Staff's lift Zone		DATE : 7/6/68
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	FREQUENCY :Monthly
14 th floor	/		/		
12 th floor	/		/		
11 th floor	/		/		
10 th floor	/		/		
9 th floor	/		/		
8 th floor	/		/		
7 th floor	/		/		
6 th floor	/		/		
5 th floor	/		/		
4 th floor	/		/		
3 rd floor	/		/		
2 nd floor	/		/		
Lobby floor	/		/		
Basement floor					

SUGGESTION/REMARKS.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT FOR DETAIL OF January 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				DATE: 7/1/68	Remark
	Guest's lift Zone		Staff's lift Zone			
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CHECK BY XXXXXXXXXX	
14 th floor	/		/			
12 th floor	/		/			
11 th floor	/		/			
10 th floor	/		/			
9 th floor	/		/			
8 th floor	/		/			
7 th floor	/		/			
6 th floor	/		/			
5 th floor	/		/			
4 th floor	/		/			
3 rd floor	/		/			
2 nd floor	/		/			
Lobby floor	/		/			
Remark.....						

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT FOR DETAIL OF February 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				DATE: 7/2/68	Remark
	Guest's lift Zone		Staff's lift Zone			
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CHECK BY <div></div>	
14 th floor	/		/			
12 th floor	/		/			
11 th floor	/		/			
10 th floor	/		/			
9 th floor	/		/			
8 th floor	/		/			
7 th floor	/		/			
6 th floor	/		/			
5 th floor	/		/			
4 th floor	/		/			
3 rd floor	/		/			
2 nd floor	/		/			
Lobby floor	/		/			
Remark.....						

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT FOR DETAIL OF March 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				DATE: 10/3/68	Remark
	Guest's lift Zone		Staff's lift Zone			
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CHECK BY	
14 th floor	/		/			
12 th floor	/		/			
11 th floor	/		/			
10 th floor	/		/			
9 th floor	/		/			
8 th floor	/		/			
7 th floor	/		/			
6 th floor	/		/			
5 th floor	/		/			
4 th floor	/		/			
3 rd floor	/		/			
2 nd floor	/		/			
Lobby floor	/		/			
Remark.....						

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT FOR DETAIL OF April 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				DATE: 10/4/68	Remark
	Guest's lift Zone		Staff's lift Zone			
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CHECK BY XXXXXXXXXX	
14 th floor	/		/			
12 th floor	/		/			
11 th floor	/		/			
10 th floor	/		/			
9 th floor	/		/			
8 th floor	/		/			
7 th floor	/		/			
6 th floor	/		/			
5 th floor	/		/			
4 th floor	/		/			
3 rd floor	/		/			
2 nd floor	/		/			
Lobby floor	/		/			
Remark.....						

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT FOR DETAIL OF May 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				DATE: 10/5/68	Remark
	Guest's lift Zone		Staff's lift Zone			
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CHECK BY XXXXXXXXXX	
14 th floor	/		/			
12 th floor	/		/			
11 th floor	/		/			
10 th floor	/		/			
9 th floor	/		/			
8 th floor	/		/			
7 th floor	/		/			
6 th floor	/		/			
5 th floor	/		/			
4 th floor	/		/			
3 rd floor	/		/			
2 nd floor	/		/			
Lobby floor	/		/			
Remark.....						

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

LOG SHEET FIRE EXIT FOR DETAIL OF June 2025

LOCATION	CHECKING THE FIRE EXIT SIGN				DATE: 7/6/68	Remark
	Guest's lift Zone		Staff's lift Zone			
	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CHECK BY XXXXXXXXXX	
14 th floor	/		/			
12 th floor	/		/			
11 th floor	/		/			
10 th floor	/		/			
9 th floor	/		/			
8 th floor	/		/			
7 th floor	/		/			
6 th floor	/		/			
5 th floor	/		/			
4 th floor	/		/			
3 rd floor	/		/			
2 nd floor	/		/			
Lobby floor	/		/			
Remark.....						