

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร A
GPS. Coordinate : 47 P 663512 E 1517256 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/1
Sample Type : Wastewater
Sampling Date : 02 July 2025
Sampling Time : 11.38 a.m.
Received Date : 03 July 2025
Analytical Date : 03 – 15 July 2025
Report Date : 16 July 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 22.9 °C	-	Electrometric Method (4500-H ⁺ B)	6.3	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	26.8	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	13.3	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	1,600	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตินุศลาอาคารชุด เดอะ ริเวอร์
 Project Name : โครงการ THE RIVER
 Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
 แขวงคลองตันใต้ เขตคลองสาน กรุงเทพมหานคร
 Sampling Point : บ่อพักน้ำสุดท้าย อาคาร B
 GPS. Coordinate : 47 P 663269 E 1517470 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
 Sample No. : W68026/2
 Sample Type : Wastewater
 Sampling Date : 02 July 2025
 Sampling Time : 11.32 a.m.
 Received Date : 03 July 2025
 Analytical Date : 03 – 15 July 2025
 Report Date : 16 July 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.0 °C	-	Electrometric Method (4500-H ⁺ B)	6.3	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	< 5.0	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	8.2	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	920	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร A
GPS. Coordinate : 47 P 663278 E 1517477 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/1
Sample Type : Wastewater
Sampling Date : 06 August 2025
Sampling Time : 02.36 p.m.
Received Date : 07 August 2025
Analytical Date : 07 – 19 August 2025
Report Date : 20 August 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.0 °C	-	Electrometric Method (4500-H ⁺ B)	5.9	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	55.4	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	25.4	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	1,600	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร B
GPS. Coordinate : 47 P 663273 E 1517473 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/2
Sample Type : Wastewater
Sampling Date : 06 August 2025
Sampling Time : 02.30 p.m.
Received Date : 07 August 2025
Analytical Date : 07 – 19 August 2025
Report Date : 20 August 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.7 °C	-	Electrometric Method (4500-H ⁺ B)	5.9	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	27.0	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	17.8	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.2	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	1,600	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร A
GPS. Coordinate : 47 P 663298 E 1517480 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/1
Sample Type : Wastewater
Sampling Date : 26 September 2025
Sampling Time : 10.31 a.m.
Received Date : 27 September 2025
Analytical Date : 27 September – 08 October 2025
Report Date : 09 October 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.0 °C	-	Electrometric Method (4500-H ⁺ B)	5.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	20.0	≤ 30
Biochemical Oxygen Demand [*]	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	2.5	≤ 20
Oil and Grease [*]	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria [*]	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	1,600	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{*} This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร B
GPS. Coordinate : 47 P 663288 E 1517477 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/2
Sample Type : Wastewater
Sampling Date : 26 September 2025
Sampling Time : 10.23 a.m.
Received Date : 27 September 2025
Analytical Date : 27 September – 08 October 2025
Report Date : 09 October 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.1 °C	-	Electrometric Method (4500-H ⁺ B)	5.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	28.5	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	4.6	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	540	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร A
GPS. Coordinate : 47 P 663291 E 1517488 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/1
Sample Type : Wastewater
Sampling Date : 07 October 2025
Sampling Time : 11.01 a.m.
Received Date : 08 October 2025
Analytical Date : 08 – 21 October 2025
Report Date : 22 October 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.8 °C	-	Electrometric Method (4500-H ⁺ B)	5.8	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	29.9	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	14.4	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.2	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	1,600	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร B
GPS. Coordinate : 47 P 663288 E 1517487 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/2
Sample Type : Wastewater
Sampling Date : 07 October 2025
Sampling Time : 10.54 a.m.
Received Date : 08 October 2025
Analytical Date : 08 – 21 October 2025
Report Date : 22 October 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.4 °C	-	Electrometric Method (4500-H ⁺ B)	5.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	28.4	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	4.8	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	540	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร A
GPS. Coordinate : 47 P 663322 E 1517423 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/1
Sample Type : Wastewater
Sampling Date : 07 November 2025
Sampling Time : 05.04 p.m.
Received Date : 08 November 2025
Analytical Date : 08 – 22 November 2025
Report Date : 24 November 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.4 °C	-	Electrometric Method (4500-H ⁺ B)	5.9	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	29.9	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	13.5	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	920	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร B
GPS. Coordinate : 47 P 663291 E 1517481 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/2
Sample Type : Wastewater
Sampling Date : 07 November 2025
Sampling Time : 04.59 p.m.
Received Date : 08 November 2025
Analytical Date : 08 – 22 November 2025
Report Date : 24 November 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.5 °C	-	Electrometric Method (4500-H ⁺ B)	5.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	28.1	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	10.7	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	130	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร A
GPS. Coordinate : 47 P 663297 E 1517455 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W68026
Sample No. : W68026/1
Sample Type : Wastewater
Sampling Date : 09 December 2025
Sampling Time : 11.58 a.m.
Received Date : 10 December 2025
Analytical Date : 10 – 23 December 2025
Report Date : 24 December 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 25.1 °C	-	Electrometric Method (4500-H ⁺ B)	6.1	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	9.5	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	5.7	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวอร์
Project Name : โครงการ THE RIVER
Address Project : เลขที่ 110 ซอยเจริญนคร 13 ถนนเจริญนคร
แขวงคลองตันใหม่ เขตคลองสาน กรุงเทพมหานคร
Sampling Point : บ่อพักน้ำสุดท้าย อาคาร B
GPS. Coordinate : 47 P 663281 E 1517477 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68026
Sample No. : W68026/2
Sample Type : Wastewater
Sampling Date : 09 December 2025
Sampling Time : 11.52 a.m.
Received Date : 10 December 2025
Analytical Date : 10 – 23 December 2025
Report Date : 24 December 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.4 °C	-	Electrometric Method (4500-H ⁺ B)	6.1	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	26.0	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	12.6	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

