เอกสารแนบ 4

เอกสารผลการตรวจวัดคุณภาพสิ่งแวดล้อม

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer			Data Provided by Laboratory		
Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู	Report No.	:	W68030
Project Name	:	โครงการ KHUN by YOO	Sample No.	:	W68030/1
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250	Sample Type	:	Waste Water
			Sampling Date	:	15 July 2025
Sampling Point	:	บ่อพักน้ำใส	Sampling Time	:	03.24 p.m.
GPS. Coordinate	:	47 P 671137 E 1518712 N	Received Date	:	16 July 2025
Sampling By	:	TNP ENVIRONMENT CO., LTD.	Analytical Date	:	16 – 30 July 2025
Sampling Method	:	Grab Sampling	Report Date	:	31 July 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
pH at 23.9 °C	-	Electrometric Method (4500-H^+ B)	6.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	7.6	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	504	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5 Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	3.8	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric method (4500-S^{2-} F)	< 0.60	≤ 1.0
Settleable Solid *	mL/L	Imhoff cone (2540 F)	< 0.1	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	1,600	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	1,600	-
Total Kjeldahl Nitrogen * [2/]	mg/L	APHA:4500-Norg (B) [3/]	< 0.28	≤ 35
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building Type B.

Remark
1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.
3/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.



TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer			Data Provided by Laboratory		
Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู	Report No.	:	W68030
Project Name	:	โครงการ KHUN by YOO	Sample No.	:	W68030/2
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250	Sample Type	:	Swimming pool Water
			Sampling Date	:	15 July 2025
Sampling Point	:	สระว่ายน้ำส่วนลึก	Sampling Time	:	03.17 p.m.
GPS. Coordinate	:	47 P 671288 E 1518746 N	Received Date	:	16 July 2025
Sampling By	:	TNP ENVIRONMENT CO., LTD.	Analytical Date	:	16 – 30 July 2025
Sampling Method	:	Grab Sampling	Report Date	:	31 July 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus * [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa * [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL

REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY
TNP-FM-108 Rev.04/ 30/09/2567

น.4/2

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 671150 E 1518722 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/2
Sample Type	:	Swimming pool Water
Sampling Date	:	15 July 2025
Sampling Time	:	03.16 p.m.
Received Date	:	16 July 2025
Analytical Date	:	16 – 30 July 2025
Report Date	:	31 July 2025

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus * 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa * 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ นาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	บ่อพักน้ำใส
GPS. Coordinate	:	47 P 671159 E 1518713 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/1
Sample Type	:	Waste Water
Sampling Date	:	14 August 2025
Sampling Time	:	12.02 p.m.
Received Date	:	15 August 2025
Analytical Date	:	15 – 26 August 2025
Report Date	:	27 August 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
pH at 23.5 °C	-	Electrometric Method (4500-H^+ B)	6.8	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	12.1	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	326	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	8.6	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric method (4500-S^{2-} F)	< 0.60	≤ 1.0
Settleable Solid *	mL/L	Imhoff cone (2540 F)	0.2	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	1,600	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	920	-
Total Kjeldahl Nitrogen * [2/]	mg/L	APHA:4500-Norg (B) [3/]	3.4	≤ 35
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building Type B.

Remark
1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.
3/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนลึก
GPS. Coordinate	:	47 P 671149 E 1518731 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/2
Sample Type	:	Swimming pool Water
Sampling Date	:	14 August 2025
Sampling Time	:	12.09 p.m.
Received Date	:	15 August 2025
Analytical Date	:	15 – 26 August 2025
Report Date	:	27 August 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus * [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa * [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 671172 E 1518744 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/2
Sample Type	:	Swimming pool Water
Sampling Date	:	14 August 2025
Sampling Time	:	12.08 p.m.
Received Date	:	15 August 2025
Analytical Date	:	15 – 26 August 2025
Report Date	:	27 August 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *[2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *[2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	บ่อพักน้ำใส
GPS. Coordinate	:	47 P 671145 E 1518711 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/1
Sample Type	:	Waste Water
Sampling Date	:	18 September 2025
Sampling Time	:	01.49 p.m.
Received Date	:	19 September 2025
Analytical Date	:	19 September - 01 October 2025
Report Date	:	02 October 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
pH at 23.5 °C	-	Electrometric Method (4500-H^+ B)	6.8	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	9.5	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	252	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	6.5	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric method (4500-S^{2-} F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff cone (2540 F)	0.2	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 1,600	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 1,600	-
Total Kjeldahl Nitrogen *[2/]	mg/L	APHA:4500-Norg (B) [3/]	7.0	≤ 35
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building Type B.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.

3/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

* *This item is out the scope ISO/IEC 17025:2017 Accreditation.*

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer			Data Provided by Laboratory		
Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู	Report No.	:	W68030
Project Name	:	โครงการ KHUN by YOO	Sample No.	:	W68030/2
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250	Sample Type	:	Swimming pool Water
			Sampling Date	:	18 September 2025
Sampling Point	:	สระว่ายน้ำส่วนลึก	Sampling Time	:	01.41 p.m.
GPS. Coordinate	:	47 P 671132 E 1518833 N	Received Date	:	19 September 2025
Sampling By	:	TNP ENVIRONMENT CO., LTD.	Analytical Date	:	19 – 30 September 2025
Sampling Method	:	Grab Sampling	Report Date	:	01 October 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus * [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa * [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 671146 E 1518831 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/3
Sample Type	:	Swimming pool Water
Sampling Date	:	18 September 2025
Sampling Time	:	01.41 p.m.
Received Date	:	19 September 2025
Analytical Date	:	19 – 30 September 2025
Report Date	:	01 October 2025

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus * 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa * 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	บ่อพักน้ำใส
GPS. Coordinate	:	47 P 671151 E 1518720 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/1
Sample Type	:	Wastewater
Sampling Date	:	15 October 2025
Sampling Time	:	01.09 p.m.
Received Date	:	16 October 2025
Analytical Date	:	16 October – 06 November 2025
Report Date	:	07 November 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
pH at 22.3 °C	-	Electrometric Method (4500-H^+ B)	6.2	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	24.5	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	328	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	9.8	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric method (4500-S^{2-} F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff cone (2540 F)	0.2	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	1,600	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	1,600	-
Total Kjeldahl Nitrogen *, [2/]	mg/L	APHA:4500-Norg (B) [3/]	< 0.28	≤ 35
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building Type B.

Remark
1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.
3/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.
* *This item is out the scope ISO/IEC 17025:2017 Accreditation.*

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer			Data Provided by Laboratory		
Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู	Report No.	:	W68030
Project Name	:	โครงการ KHUN by YOO	Sample No.	:	W68030/2
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250	Sample Type	:	Swimming pool Water
			Sampling Date	:	15 October 2025
Sampling Point	:	สระว่ายน้ำส่วนลึก	Sampling Time	:	01.13 p.m.
GPS. Coordinate	:	47 P 671105 E 1519053 N	Received Date	:	16 October 2025
Sampling By	:	TNP ENVIRONMENT CO., LTD.	Analytical Date	:	16 October – 06 November 2025
Sampling Method	:	Grab Sampling	Report Date	:	07 November 2025

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 671105 E 1518729 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/3
Sample Type	:	Swimming pool Water
Sampling Date	:	15 October 2025
Sampling Time	:	01.14 p.m.
Received Date	:	16 October 2025
Analytical Date	:	16 October – 06 November 2025
Report Date	:	07 November 2025

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	บ่อพักน้ำใส
GPS. Coordinate	:	47 P 671148 E 1518713 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/1
Sample Type	:	Wastewater
Sampling Date	:	19 November 2025
Sampling Time	:	11.55 a.m.
Received Date	:	20 November 2025
Analytical Date	:	20 November – 04 December 2025
Report Date	:	08 December 2025

Parameter	Unit	Analytical Method [1/]	Result	Standard
pH at 23.2 °C	-	Electrometric Method (4500-H^+ B)	6.4	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	11.7	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	304	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	6.3	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric method (4500-S^{2-} F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff cone (2540 F)	< 0.1	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	920	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	920	-
Total Kjeldahl Nitrogen *, [2/]	mg/L	APHA:4500-Norg (B) [3/]	< 0.28	≤ 35
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building Type B.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.

3/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

* *This item is out the scope ISO/IEC 17025:2017 Accreditation.*

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนลึก
GPS. Coordinate	:	47 P 671137 E 1518762 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/2
Sample Type	:	Swimming pool Water
Sampling Date	:	19 November 2025
Sampling Time	:	11.48 a.m.
Received Date	:	20 November 2025
Analytical Date	:	20 November – 04 December 2025
Report Date	:	08 December 2025

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 671156 E 1518735 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/3
Sample Type	:	Swimming pool Water
Sampling Date	:	19 November 2025
Sampling Time	:	11.49 a.m.
Received Date	:	20 November 2025
Analytical Date	:	20 November – 04 December 2025
Report Date	:	08 December 2025

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envl@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	บ่อพักน้ำใส
GPS. Coordinate	:	47 P 671151 E 1518720 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/1
Sample Type	:	Wastewater
Sampling Date	:	17 December 2025
Sampling Time	:	02.33 p.m.
Received Date	:	18 December 2025
Analytical Date	:	18 December 2025 – 07 January 2026
Report Date	:	08 January 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
pH at 25.2 °C	-	Electrometric Method (4500-H^+ B)	6.8	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	< 5.0	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	194	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	3.1	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric method (4500-S^{2-} F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff cone (2540 F)	< 0.1	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	1,600	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	920	-
Total Kjeldahl Nitrogen *, [2/]	mg/L	APHA:4500-Norg (B) [3/]	< 0.28	≤ 35
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building Type B.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.

[3/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

* *This item is out the scope ISO/IEC 17025:2017 Accreditation.*

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนลึก
GPS. Coordinate	:	47 P 671105 E 1519053 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/2
Sample Type	:	Swimming pool Water
Sampling Date	:	17 December 2025
Sampling TIme	:	02.25 p.m.
Received Date	:	18 December 2025
Analytical Date	:	18 December 2025 – 07 January 2026
Report Date	:	08 January 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคาร คุณ บาย ยู
Project Name	:	โครงการ KHUN by YOO
Address Project	:	เลขที่ 338 ซอยสุขุมวิท 55 (ทองหล่อ) แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 671105 E 1518729 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Report No.	:	W68030
Sample No.	:	W68030/3
Sample Type	:	Swimming pool Water
Sampling Date	:	17 December 2025
Sampling Time	:	02.26 p.m.
Received Date	:	18 December 2025
Analytical Date	:	18 December 2025 – 07 January 2026
Report Date	:	08 January 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]