

ภาคผนวก จ

---

## Pool Daily Check List

# POOL DAILY CHECK LIST



SUKHUMVIT II

MONTH/YEAR:

Jul-25

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/7/68	3.0	7.2	14	✓	✓	✓	✓	Mon	1.0	7.2	18	✓	✓	✓	✓	Chang
2/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.5	7.2	14	✓	✓	✓	✓	Chang
3/7/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.0	7.2	15	✓	✓	✓	✓	Beer
4/7/68	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	16	✓	✓	✓	✓	Beer
5/7/68	3.0	7.2	13	✓	✓	✓	✓	Beer	0.5	7.2	14	✓	✓	✓	✓	Beer
6/7/68	3.0	7.2	14	✓	✓	✓	✓	Beer	1.0	7.2	18	✓	✓	✓	✓	Chang
7/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.0	7.2	14	✓	✓	✓	✓	Chang
8/7/68	3.0	7.2	16	✓	✓	✓	✓	Chang	0.5	7.2	18	✓	✓	✓	✓	Chang
9/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.5	7.2	16	✓	✓	✓	✓	Chang
10/7/68	3.0	7.2	16	✓	✓	✓	✓	Chang	0.5	7.2	13	✓	✓	✓	✓	Beer
11/7/68	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	15	✓	✓	✓	✓	Beer
12/7/68	3.0	7.2	13	✓	✓	✓	✓	Beer	1.0	7.2	14	✓	✓	✓	✓	Beer
13/7/68	3.0	7.2	14	✓	✓	✓	✓	Beer	1.0	7.2	14	✓	✓	✓	✓	Chang
14/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	0.5	7.2	18	✓	✓	✓	✓	Chang
15/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.0	7.2	14	✓	✓	✓	✓	Chang
16/7/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.0	7.2	18	✓	✓	✓	✓	Chang
17/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	0.5	7.2	13	✓	✓	✓	✓	Beer
18/7/68	3.0	7.2	14	✓	✓	✓	✓	Beer	1.0	7.2	18	✓	✓	✓	✓	Beer
19/7/68	3.0	7.2	13	✓	✓	✓	✓	Beer	1.0	7.2	15	✓	✓	✓	✓	Beer
20/7/68	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	18	✓	✓	✓	✓	Chang
21/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.0	7.2	14	✓	✓	✓	✓	Chang
22/7/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.5	7.2	18	✓	✓	✓	✓	Chang
23/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	0.5	7.2	15	✓	✓	✓	✓	Beer
24/7/68	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	17	✓	✓	✓	✓	Beer
25/7/68	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	12	✓	✓	✓	✓	Beer
26/7/68	3.0	7.2	13	✓	✓	✓	✓	Beer	0.5	7.2	12	✓	✓	✓	✓	Beer
27/7/68	3.0	7.2	14	✓	✓	✓	✓	Beer	0.5	7.2	14	✓	✓	✓	✓	Chang
28/7/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.0	7.2	18	✓	✓	✓	✓	Chang
29/7/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.0	7.2	16	✓	✓	✓	✓	Chang
30/7/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.0	7.2	18	✓	✓	✓	✓	Chang
31/7/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.0	7.2	14	✓	✓	✓	✓	Chang

REMARK

Verified by Chief Engineer [Signature]

Date 31/7/20

# POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

Aug-25

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/8/68	3.0	7.2	14	/	/	/	/	Orange	0.5	7.2	14	/	/	/	/	Beer
2/8/68	3.0	7.2	15	/	/	/	/	Beer	0.5	7.2	11	/	/	/	/	Beer
3/8/68	3.0	7.2	13	/	/	/	/	Beer	0.1	7.2	12	/	/	/	/	mon
4/8/68	3.0	7.2	12	/	/	/	/	mon	0.1	7.2	14	/	/	/	/	mon
5/8/68	3.0	7.2	12	/	/	/	/	mon	0.1	7.2	14	/	/	/	/	mon
6/8/68	3.0	7.2	12	/	/	/	/	mon	0.1	7.2	15	/	/	/	/	Beer
7/8/68	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	15	/	/	/	/	Beer
8/8/68	3.0	7.2	12	/	/	/	/	Beer	1.0	7.2	15	/	/	/	/	Beer
9/8/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	18	/	/	/	/	Beer
10/8/68	3.0	7.2	15	/	/	/	/	Beer	0.5	7.2	18	/	/	/	/	Beer
11/8/68	3.0	7.2	12	/	/	/	/	Beer	0.2	7.2	18	/	/	/	/	mon
12/8/68	3.0	7.2	12	/	/	/	/	mon	0.1	7.2	16	/	/	/	/	mon
13/8/68	3.0	7.2	12	/	/	/	/	mon	0.2	7.2	15	/	/	/	/	Beer
14/8/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	18	/	/	/	/	Beer
15/8/68	3.0	7.2	15	/	/	/	/	Beer	0.2	7.2	15	/	/	/	/	Beer
16/8/68	3.0	7.2	15	/	/	/	/	Beer	1.0	7.2	13	/	/	/	/	Beer
17/8/68	3.0	7.2	12	/	/	/	/	Beer	0.6	7.2	13	/	/	/	/	mon
18/8/68	3.0	7.2	12	/	/	/	/	mon	0.1	7.2	13	/	/	/	/	mon
19/8/68	3.0	7.2	12	/	/	/	/	mon	0.0	7.2	13	/	/	/	/	mon
20/8/68	3.0	7.2	13	/	/	/	/	mon	0.1	7.2	12	/	/	/	/	Pert
21/8/68	3.0	7.2	14	/	/	/	/	Pert	1.0	7.2	14	/	/	/	/	Pert
22/8/68	3.0	7.2	15	/	/	/	/	Beer	0.1	7.2	11	/	/	/	/	Beer
23/8/68	3.0	7.2	14	/	/	/	/	Beer	0.1	7.2	15	/	/	/	/	Beer
24/8/68	3.0	7.2	16	/	/	/	/	Beer	0.1	7.2	18	/	/	/	/	Beer
25/8/68	3.0	7.2	13	/	/	/	/	Beer	0.0	7.2	18	/	/	/	/	mon
26/8/68	3.0	7.2	12	/	/	/	/	mon	0.4	7.2	13	/	/	/	/	mon
27/8/68	3.0	7.2	12	/	/	/	/	mon	0.5	7.2	13	/	/	/	/	Beer
28/8/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	15	/	/	/	/	Beer
29/8/68	3.0	7.2	15	/	/	/	/	Beer	0.1	7.2	11	/	/	/	/	Beer
30/8/68	3.0	7.2	14	/	/	/	/	Beer	0.1	7.2	12	/	/	/	/	Beer
31/8/68	3.0	7.2	16	/	/	/	/	Beer	0.1	7.2	11	/	/	/	/	Beer

REMARK \_\_\_\_\_

Verified by Chief Engineer                      Date 31/8/20



# POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

Sep-25

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water $\sqrt{1X}$	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water $\sqrt{1X}$	Record by
1/9/68	3.0	7.2	14	/	/	/	/	Beer	0.2	7.2	12	/	/	/	/	MON
2/9/68	3.0	7.2	12	/	/	/	/	MON	0.4	7.2	12	/	/	/	/	MON
3/9/68	3.0	7.2	12	/	/	/	/	Pert	0.2	7.2	12	/	/	/	/	Pert
4/9/68	3.0	7.2	12	/	/	/	/	Pert	0.2	7.2	12	/	/	/	/	Pert
5/9/68	3.0	7.2	14	/	/	/	/	MON	0.2	7.2	12	/	/	/	/	MON
6/9/68	3.0	7.2	12	/	/	/	/	MON	2.0	7.2	14	/	/	/	/	MON
7/9/68	3.0	7.2	12	/	/	/	/	MON	2.0	7.2	13	/	/	/	/	MON
8/9/68	3.0	7.2	12	/	/	/	/	MON	0.6	7.2	13	/	/	/	/	MON
9/9/68	2.0	7.2	12	/	/	/	/	MON	0.2	7.2	12	/	/	/	/	Change
10/9/68	3.0	7.2	14	/	/	/	/	Change	1.5	7.2	18	/	/	/	/	Change
11/9/68	3.0	7.2	12	/	/	/	/	Change	0.1	7.2	14	/	/	/	/	MON
12/9/68	3.0	7.2	12	/	/	/	/	MON	2.0	7.2	14	/	/	/	/	MON
13/9/68	3.0	7.2	13	/	/	/	/	MON	0.1	7.2	14	/	/	/	/	MON
14/9/68	3.0	7.2	12	/	/	/	/	MON	2.0	7.2	14	/	/	/	/	MON
15/9/68	3.0	7.2	13	/	/	/	/	MON	0.0	7.2	14	/	/	/	/	MON
16/9/68	3.0	7.2	14	/	/	/	/	MON	0.2	7.2	12	/	/	/	/	Change
17/9/68	3.0	7.2	12	/	/	/	/	Change	1.5	7.2	18	/	/	/	/	Change
18/9/68	3.0	7.2	14	/	/	/	/	Change	0.0	7.2	14	/	/	/	/	MON
19/9/68	3.0	7.2	14	/	/	/	/	MON	0.0	7.2	14	/	/	/	/	MON
20/9/68	3.0	7.2	14	/	/	/	/	MON	0.1	7.2	13	/	/	/	/	MON
21/9/68	3.0	7.2	12	/	/	/	/	MON	0.2	7.2	12	/	/	/	/	MON
22/9/68	3.0	7.2	12	/	/	/	/	MON	0.2	7.2	12	/	/	/	/	MON
23/9/68	3.0	7.2	13	/	/	/	/	MON	0.2	7.2	12	/	/	/	/	Change
24/9/68	3.0	7.2	14	/	/	/	/	Change	1.5	7.2	18	/	/	/	/	Change
25/9/68	3.0	7.2	14	/	/	/	/	Change	1.0	7.2	14	/	/	/	/	MON
26/9/68	3.0	7.2	14	/	/	/	/	MON	1.0	7.2	14	/	/	/	/	MON
27/9/68	3.0	7.2	14	/	/	/	/	MON	1.0	7.2	13	/	/	/	/	MON
28/9/68	3.0	7.2	14	/	/	/	/	MON	1.0	7.2	14	/	/	/	/	MON
29/9/68	3.0	7.2	14	/	/	/	/	MON	1.0	7.2	14	/	/	/	/	MON
30/9/68	3.0	7.2	14	/	/	/	/	MON	1.5	7.2	14	/	/	/	/	MON
1/10/68																

REMARK

Verified by Chief Engineer

*[Signature]*

Date

30/9/25

# POOL DAILY CHECK LIST

MONTH/YEAR:

Oct-25



Travelodge

SUKHUMVIT 11

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/10/68	3.0	7.2	12	/	/	/	/	P	7.5	7.2	12	/	/	/	/	P
2/10/68	3.2	7.2	13	/	/	/	/	P	7.5	6.8	10	/	/	/	/	P
3/10/68	3.0	7.2	15	/	/	/	/	Beer	1.5	7.2	11	/	/	/	/	Beer
4/10/68	3.0	7.2	13	/	/	/	/	Beer	1.5	7.2	13	/	/	/	/	Beer
5/10/68	3.0	7.2	12	/	/	/	/	P	7.5	7.2	12	/	/	/	/	P
6/10/68	3.2	7.2	15	/	/	/	/	P	7.5	7.2	12	/	/	/	/	P
7/10/68	3.0	7.2	15	/	/	/	/	P	0.4	7.2	12	/	/	/	/	P
8/10/68	3.2	7.2	15	/	/	/	/	P	7.5	7.2	12	/	/	/	/	P
9/10/68	3.2	7.2	15	/	/	/	/	P	7.0	7.2	12	/	/	/	/	P
10/10/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	11	/	/	/	/	Beer
11/10/68	3.0	7.2	15	/	/	/	/	Beer	7.5	7.2	13	/	/	/	/	P
12/10/68	3.2	7.2	15	/	/	/	/	P	7.0	6.8	12	/	/	/	/	P
13/10/68	3.2	7.2	7.5	/	/	/	/	P	7.5	7.2	12	/	/	/	/	P
14/10/68	3.2	7.2	14	/	/	/	/	P	7.5	6.8	12	/	/	/	/	P
15/10/68	3.0	7.2	12	/	/	/	/	P	7.5	6.8	12	/	/	/	/	P
16/10/68	3.2	7.2	12	/	/	/	/	P	7.5	6.8	12	/	/	/	/	Beer
17/10/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	Beer
18/10/68	3.0	7.2	16	/	/	/	/	Beer	1.5	6.8	11	/	/	/	/	P
19/10/68	3.2	7.2	15	/	/	/	/	P	0.5	6.8	12	/	/	/	/	P
20/10/68	3.2	7.2	7.5	/	/	/	/	P	0.7	6.8	11	/	/	/	/	P
21/10/68	3.0	7.2	7.6	/	/	/	/	P	0.5	7.2	11	/	/	/	/	P
22/10/68	3.2	7.2	15	/	/	/	/	P	0.5	6.8	11	/	/	/	/	P
23/10/68	3.2	7.2	7.6	/	/	/	/	P	0.5	6.8	11	/	/	/	/	P
24/10/68	3.2	6.8	7.4	/	/	/	/	P	0.5	6.8	11	/	/	/	/	P
25/10/68	3.0	6.8	14	/	/	/	/	Beer	0.5	7.2	11	/	/	/	/	Beer
26/10/68	3.0	6.8	15	/	/	/	/	Beer	0.5	7.2	10	/	/	/	/	P
27/10/68	3.2	7.2	7.5	/	/	/	/	P	0.4	6.8	10	/	/	/	/	P
28/10/68	3.2	7.2	15	/	/	/	/	P	0.5	6.8	11	/	/	/	/	P
29/10/68	3.2	7.2	15	/	/	/	/	P	0.5	6.8	9	/	/	/	/	P
30/10/68	3.2	7.2	7.6	/	/	/	/	P	1.0	6.8	9	/	/	/	/	P
31/10/68	3.2	7.2	7.5	/	/	/	/	P	0.0	7.2	9	/	/	/	/	Beer

REMARK

Verified by Chief Engineer                     

Date 31/10/20



# POOL DAILY CHECK LIST

MONTH/YEAR:

Nov-25



**Travelodge**

SUKHUMVIT II

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/11/68	3.0	7.2	14	✓	✓	✓	✓	Beer	0.5	7.2	9	✓	✓	✓	✓	Beer
2/11/68	3.0	7.2	14	✓	✓	✓	✓	Beer	1.0	7.2	11	✓	✓	✓	✓	Beer
3/11/68	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	11	✓	✓	✓	✓	Chang
4/11/68	3.0	7.2	18	✓	✓	✓	✓	Chang	1.5	7.2	18	✓	✓	✓	✓	Chang
5/11/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.5	7.2	16	✓	✓	✓	✓	Chang
6/11/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.5	7.2	10	✓	✓	✓	✓	Beer
7/11/68	3.0	7.2	14	✓	✓	✓	✓	Beer	1.0	7.2	10	✓	✓	✓	✓	Beer
8/11/68	3.0	7.2	15	✓	✓	✓	✓	Beer	1.0	7.2	12	✓	✓	✓	✓	Chang
9/11/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.0	7.2	18	✓	✓	✓	✓	Chang
10/11/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.5	7.2	14	✓	✓	✓	✓	Chang
11/11/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.0	7.2	18	✓	✓	✓	✓	Chang
12/11/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.5	7.2	16	✓	✓	✓	✓	Chang
13/11/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.5	7.2	10	✓	✓	✓	✓	Beer
14/11/68	3.0	7.2	15	✓	✓	✓	✓	Beer	0.5	7.2	13	✓	✓	✓	✓	Beer
15/11/68	3.0	7.2	16	✓	✓	✓	✓	Beer	0.5	7.2	14	✓	✓	✓	✓	Chang
16/11/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.5	7.2	16	✓	✓	✓	✓	Chang
17/11/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.5	7.2	18	✓	✓	✓	✓	Chang
18/11/68	3.0	7.2	12	✓	✓	✓	✓	Chang	3.0	7.2	14	✓	✓	✓	✓	Chang
19/11/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.5	7.2	18	✓	✓	✓	✓	Chang
20/11/68	3.0	7.2	12	✓	✓	✓	✓	Chang	1.5	7.2	15	✓	✓	✓	✓	Beer
21/11/68	3.0	7.2	14	✓	✓	✓	✓	Beer	1.5	7.2	12	✓	✓	✓	✓	Beer
22/11/68	3.0	7.2	15	✓	✓	✓	✓	Beer	1.5	7.2	14	✓	✓	✓	✓	Beer
23/11/68	3.0	7.2	16	✓	✓	✓	✓	Beer	0.5	7.2	12	✓	✓	✓	✓	Chang
24/11/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.5	7.2	14	✓	✓	✓	✓	Chang
25/11/68	3.0	7.2	16	✓	✓	✓	✓	Chang	1.5	7.2	18	✓	✓	✓	✓	Chang
26/11/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.5	7.2	16	✓	✓	✓	✓	Beer
27/11/68	3.0	7.2	15	✓	✓	✓	✓	Beer	1.5	7.2	14	✓	✓	✓	✓	Beer
28/11/68	3.0	7.2	14	✓	✓	✓	✓	Beer	1.5	7.2	16	✓	✓	✓	✓	Beer
29/11/68	3.0	7.2	16	✓	✓	✓	✓	Beer	1.5	7.2	12	✓	✓	✓	✓	Chang
30/11/68	3.0	7.2	14	✓	✓	✓	✓	Chang	1.5	7.2	14	✓	✓	✓	✓	Chang
1/12/68	3.0	7.2	16	✓	✓	✓	✓	Chang								

REMARK \_\_\_\_\_

Verified by Chief Engineer \_\_\_\_\_ Date 30/11/25

# POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

Dec-25

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water √ / X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water √ / X	Record by
1/12/68	3.0	7.2	16	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
2/12/68	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	16	/	/	/	/	Chang
3/12/68	3.0	7.2	16	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
4/12/68	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	15	/	/	/	/	Beer
5/12/68	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	17	/	/	/	/	Beer
6/12/68	3.0	7.2	15	/	/	/	/	Beer	0.5	7.2	15	/	/	/	/	Beer
7/12/68	3.0	7.2	15	/	/	/	/	Beer	0.2	6.8	12	/	/	/	/	P
8/12/68	3.2	7.2	15	/	/	/	/	P	0.2	7.2	15	/	/	/	/	P
9/12/68	3.0	7.2	12	/	/	/	/	P	1.0	7.2	15	/	/	/	/	Beer
10/12/68	3.0	7.2	13	/	/	/	/	Beer	1.5	7.2	14	/	/	/	/	Beer
11/12/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	16	/	/	/	/	Beer
12/12/68	3.0	7.2	12	/	/	/	/	Beer	1.5	7.2	18	/	/	/	/	Beer
13/12/68	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	16	/	/	/	/	Beer
14/12/68	3.0	7.2	15	/	/	/	/	Beer	0.5	6.8	14	/	/	/	/	P
15/12/68	3.2	7.2	15	/	/	/	/	P	0.5	7.2	15	/	/	/	/	P
16/12/68	3.2	7.2	14	/	/	/	/	P	0.5	7.2	16	/	/	/	/	Beer
17/12/68	3.0	7.2	15	/	/	/	/	Beer	0.5	7.2	15	/	/	/	/	Beer
18/12/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	16	/	/	/	/	Beer
19/12/68	3.0	7.2	11	/	/	/	/	Beer	0.5	7.2	15	/	/	/	/	Beer
20/12/68	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	16	/	/	/	/	Beer
21/12/68	3.0	7.2	15	/	/	/	/	Beer	0.5	6.8	15	/	/	/	/	P
22/12/68	3.0	7.2	12	/	/	/	/	P	1.5	6.8	14	/	/	/	/	P
23/12/68	3.0	7.2	15	/	/	/	/	P	0.5	7.2	13	/	/	/	/	Beer
24/12/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	Beer
25/12/68	3.0	7.2	12	/	/	/	/	Beer	0.5	7.2	16	/	/	/	/	Beer
26/12/68	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	14	/	/	/	/	Beer
27/12/68	3.0	7.2	13	/	/	/	/	Beer	1.0	7.2	15	/	/	/	/	Beer
28/12/68	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	P
29/12/68	3.2	7.2	16	/	/	/	/	P	1.0	7.2	14	/	/	/	/	P
30/12/68	3.2	7.2	15	/	/	/	/	P	0.5	7.2	15	/	/	/	/	P
31/12/68	3.2	7.2	16	/	/	/	/	P	0.2	6.8	14	/	/	/	/	P

REMARK

Verified by Chief Engineer

*[Signature]*

Date

31/12/20