



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	July 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6807109

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	11.09 AM.
Analysis No.	25682822

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.8 °C	-	SM : 4500-H ⁺ B	6.4	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	7.5	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	34.4	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	478	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	12.1	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	1.0	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	7.8	≤ 35

Physical Appearance Sample 25682822 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By :

จันทิพ มิตตะกา

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๔ / ๗ / ๖๘

Aproved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๔ / ๗ / ๖๘

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

เลขทะเบียน ๖-250



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	July 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6807109

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	11.09 AM.
Analysis No.	25682822

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settleable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25682822 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพร มิตตะกา

Miss. Jantip Mittaka

Laboratory Analyst

24, 9, 68

Aproved By :

Miss. Saowapa Nukacw

Laboratory Manager

24, 9, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024


The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Not the Responsibility of Experts

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	August 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[4]	Miss Yonlatda Thancerat (๖-250-๖-0003)	Report No.	PKT6808095

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	11.15 AM.
Analysis No.	25683198

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 26.0 °C ^[3]	-	SM : 4500-H ⁺ B	6.0	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	4.5	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	70.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	461	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	18.1	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	1.0	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	18.6	≤ 35

Physical Appearance Sample 25683198 : Clear liquid, yellow in color with brown sedimer Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024
published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By :

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๖ / ๘ / ๒๕

Approved By :

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๖ / ๘ / ๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	August 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6808095

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	11.15 AM.
Analysis No.	25683198

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settleable Solids ^[2]	ml/L	SM : 2540 F	0.3	-

Physical Appearance Sample 25683198 : Clear liquid, yellow in color with brown sedimen Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[3] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

25 / 8 / 68

Aproved By :

สาอวพา นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

25 / 8 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
สำนักงานปฏิบัติการวิเคราะห์ทดสอบ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	September 9-16, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[4]	Miss Yonlatda Thancerat (๖-250-๖-0003)	Report No.	PKT6809078

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.37 AM.
Analysis No.	25683558

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.7 °C	-	SM : 4500-H ⁺ B	7.6	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	15.3	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	35.6	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	359	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	1.2	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.5	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	5.3	≤ 35

Physical Appearance Sample 25683558 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28 ,2024
published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers

Reported By :

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๗/๙/๒๕

Approved By :

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๑๗/๙/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	September 9-16, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat	Report No.	PKT6809078

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.37 AM.
Analysis No.	25683558

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.1	-

Physical Appearance Sample 25683558 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

17/9/68

Aproved By :

Miss. Saowapa Nukacw

Laboratory Manager

17/9/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
สำนักงานปฏิบัติการวิเคราะห์แลพ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

For the Signature of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	October 14-22, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6810074

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.02 AM.
Analysis No.	25684016

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 26.2°C	-	SM : 4500-H ⁺ B	6.1	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	25.4	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	27.2	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	404	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	7.2	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.4	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	10.4	≤ 35

Physical Appearance Sample 25684016 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By :




Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๖ / ๑๐ / ๒๕

Approved By :



Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๑๖ / ๑๐ / ๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-25๕๐

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	October 14-22, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6810074

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.02 AM.
Analysis No.	25684016

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.1	-

Physical Appearance Sample 25684016 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK
[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

23, 10, 68

Aproved By :

Miss. Saowapa Nukacw

Laboratory Manager

23, 10, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
สำนักงานปฏิบัติการวิเคราะห์ทดสอบ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	November 11-18, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[4]	Miss Yonlatda Thancerat (จ-250-จ-0003)	Report No.	PKT6811073


Sampling Name ^[4]	Effluent
Sampling Time ^[4]	11.12 AM.
Analysis No.	25684461

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.5°C	-	SM : 4500-H ⁺ B	6.3	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	24.5	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	23.2	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	467	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	5.4	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.5	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	31.9	≤ 35

Physical Appearance Sample 25684461 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK


- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers

Reported By : 

Miss. Jantip Mittaka (จ-250-จ-0004)

Laboratory Analyst

19/11/69

Approved By : 

Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager

19/11/69



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน จ-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	November 11-18, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6811073

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	11.12 AM.
Analysis No.	25684461

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25684461 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[3] : Information received from customers

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

19.11.25Approved By : สาอวป นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

11.11.25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



NSC-TISI-TIS 17025
TESTING 0548

WATER ANALYSIS REPORT

Page 1/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Effluent)	Analyzed Date	December 3-11, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6812015

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.36 AM.
Analysis No.	25684737

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.3	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	27.1	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	38.4	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	502	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	4.7	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.4	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	12.3	≤ 35

Physical Appearance Sample 25684737 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By :

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๒ / ๑๒ / ๖๘

Aproved By :

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๑๒ / ๑๒ / ๖๘

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written appraisal.



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Effluent)	Analyzed Date	December 3-11, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6812015

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.36 AM.
Analysis No.	25684737

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.2	-

Physical Appearance Sample 25684737 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK
[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

12 / 12 / 65

Aproved By :

Miss. Saowapa Nukacw

Laboratory Manager

12 / 12 / 65

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	July 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[4]	Miss Yonlatda Thancerat (๖-250-๖-0003)	Report No.	PKT6807109

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.51 AM.
Analysis No.	25682823

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.7 °C	-	SM : 4500-H ⁺ B	6.6	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	0.3	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	3.0	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	308	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	5.2	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.9	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	5.6	≤ 35

Physical Appearance Sample 25682823 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๔ / ๗ / ๒๕

Approved By :

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๔ / ๗ / ๒๕



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-25๕๐

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	July 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat	Report No.	PKT6807109

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.51 AM.
Analysis No.	25682823

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25682823 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิภา มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

24, 7, 68

Approved By :

สาอวพา นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

24, 7, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written appraisal.

The Dependence of Reports



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumhur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	August 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6808095

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.55 AM.
Analysis No.	25683199

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.9 °C ^[3]	-	SM : 4500-H ⁺ B	6.4	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	5.3	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	9.2	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	206	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	5.1	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	1.0	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	8.8	≤ 35

Physical Appearance Sample 25683199 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By : จันทิพ มิตตะกา

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๕/๘/๒๕

Approved By : สาอวพา นุกาเว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๕/๘/๒๕



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO.,LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
 E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
 Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	August 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6808095

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.55 AM.
Analysis No.	25683199

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settleable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25683199 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
 [2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
 [3] : Information received from customers

Reported By :

Miss. Jantip Mittaka

Laboratory Analyst

25/8/25

Approved By :

Miss. Saowapa Nukacw

Laboratory Manager

25/8/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 สำนักงานปฏิบัติการภาคเหนือ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	September 9-16, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6809078

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.01 AM.
Analysis No.	25683559

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.8 °C	-	SM : 4500-H ⁺ B	6.7	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	15.9	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	6.8	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	233	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.6	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	4.1	≤ 35

Physical Appearance Sample 25683559 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported By :

..... จันทิพ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

..... ๗ / ๙ / ๖๘

Approved By :

.....

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

..... ๑๗ / ๙ / ๖๘

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	September 9-16, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6809078

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.01 AM.
Analysis No.	25683559

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25683559 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

17/9/25

Aproved By :

สาอวพา นุกะว

Miss. Saowapa Nukaw

Laboratory Manager

17/9/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
สำนักงานปฏิบัติการวิเคราะห์และทดสอบ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Not the Signature of Expert



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	October 14-22, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6810074

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	09.43 AM.
Analysis No.	25684017

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 26.1 °C	-	SM : 4500-H ⁺ B	6.5	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	13.5	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	5.6	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	235	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	2.4	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.6	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	8.3	≤ 35

Physical Appearance Sample 25684017 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024
published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers

Reported By :

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๓ / ๑๐ / ๒๕

Aproved By :

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๓ / ๑๐ / ๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	October 14-22, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[3]	Miss Yonlatda Thancrat	Report No.	PKT6810074

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	09.43 AM.
Analysis No.	25684017

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	0.1	-

Physical Appearance Sample 25684017 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

23/10/25

Approved By :

Miss. Saowapa Nukaew

Laboratory Manager

23/10/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
พร้อมให้บริการวิเคราะห์คุณภาพ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumhur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	November 11-18, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6811073

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	11.14 AM.
Analysis No.	25684462

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.6 °C	-	SM : 4500-H ⁺ B	7.0	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	13.7	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	2.2	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	208	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	1.3	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.3	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	13.3	≤ 35

Physical Appearance Sample 25684462 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers

Reported By :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๙ / ๑๑ / ๖๘

Approved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๑๙ / ๑๑ / ๖๘

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เฉพาะ
เลขทะเบียน ๖-2550

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	November 11-18, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat	Report No.	PKT6811073

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	11.14 AM.
Analysis No.	25684462

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25684462 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

19/11/25

Aproved By :

สาอวพา นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

19/11/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Dependable



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[4]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	December 3-11, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[4]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6812015

Sampling Name ^[4]	Effluent
Sampling Time ^[4]	10.23 AM.
Analysis No.	25684738


Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 24.9°C	-	SM : 4500-H ⁺ B	6.6	5.5-9.0
2. Biochemical Oxygen Demand ^[3]	mg/L	SM : 5210 B	16.7	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	14.6	≤ 40
4. Total Dissolved Solids	mg/L	SM : 2540 C	214	≤ 1000
5. Oil & Grease ^[3]	mg/L	SM : 5520 B	1.3	≤ 20
6. Sulfide ^[3]	mg/L	SM : 4500-S ²⁻ F	0.1	≤ 1.0
7. Total Kjeldahl Nitrogen ^[3]	mg/L	SM : 4500 N _{org} B	13.4	≤ 35

Physical Appearance Sample 25684738 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated June 28, 2024 published in the Royal Government Gazette (Building Class B), Volume 141, Special Section 233D, dated 27 August 2024.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers

Reported By :




Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

12, 12, 68

Aproved By :



Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

12, 12, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขที่ใบอนุญาต ๖-25๕๐

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



WATER ANALYSIS REPORT

Page 4/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[3]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	December 3-11, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat	Report No.	PKT6812015

Sampling Name ^[3]	Effluent
Sampling Time ^[3]	10.23 AM.
Analysis No.	25684738

Parameter	Unit	Method of Analysis ^[1]	Result	Standard
8. Settlicable Solids ^[2]	ml/L	SM : 2540 F	Not Detected	-

Physical Appearance Sample 25684738 : Clear, yellow liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[3] : Information received from customers

Reported By :

Miss. Jantip Mittaka

Laboratory Analyst

12/12/25

Aproved By :

Miss. Saowapa Nukacw

Laboratory Manager

12/12/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
 E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
 Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	July 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (จ-250-ท-0003)	Report No.	PKT6807109

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.07 AM.
Analysis No.	25682827

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.7°C	-	SM : 4500-H ¹ B	3.8	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	342	-

Physical Appearance Sample 25682827 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
 [2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
 [3] : Information received from customers

Reported by :

Miss. Jantip Mittaka (จ-250-ท-0004)

Laboratory Analyst

24, 7, 68

Approved by :

Miss. Saowapa Nukaew (จ-250-ท-0002)

Laboratory Manager

24, 7, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 ห้องปฏิบัติการวิเคราะห์เอกชน
 เลขทะเบียน จ-250



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	July 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerart	Report No.	PKT6807109

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	11.07 AM.
Analysis No.	25682827

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	Not Detected	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	205	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	159	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682827 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

24, 7, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

24, 7, 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	August 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[3]	Miss Yonlatda Thancerat (จ-250-ก-0003)	Report No.	PKT6808095

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	11.00 AM.
Analysis No.	25683203

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1.Total Dissolved Solids	mg/L	SM : 2510	346	-

Physical Appearance	Sample	25683203 : Clear liquid, colorless, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023 [2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar [3] : Information received from customers		

Reported by :

จันทิพย์ มิตตะกา
Miss. Jantip Mittaka (จ-250-ก-0004)

Laboratory Analyst
25/8/25

Approved by :

สาอวพา นุกาแว
Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager
25/8/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน จ-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	August 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6808095

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	11.00 AM.
Analysis No.	25683203

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
2. pH at 25.9 °C ^[3]	-	SM : 4500-H ⁺ B	6.7	7.2-8.4
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	49.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500-Cl ⁻ B	165	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	138	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683203 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

25/8/68

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

25/8/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
สำนักงานปฏิบัติการวิเคราะห์ทดสอบ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	September 9-16, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (ว-250-ก-0003)	Report No.	PKT6809078

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.12 AM.
Analysis No.	25683563

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.8°C	-	SM : 4500-H ⁺ B	6.2	7.2-8.4
2. Total Dissolved Solids	mg/L	SM : 2510	255	-

Physical Appearance	Sample	25683563 : Clear liquid, colorless, no sediment	Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L
REMARK	[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24 th Edition 2023 [2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar [3] : Information received from customers		

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (ว-250-ก-0004)

Laboratory Analyst

17/9/25

Approved by :

Miss. Saowapa Nukaew (ว-250-ก-0002)

Laboratory Manager

12/9/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	September 9-16, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6809078

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	10.12 AM.
Analysis No.	25683563

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	31.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	132	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	102	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683563 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

17/9/25

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

17/9/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
สำนักงานปฏิบัติการวิเคราะห์ทดสอบ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdiddat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	October 14-22, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (ว-250-จ-0003)	Report No.	PKT6810074

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	09.50 AM.
Analysis No.	25684021

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 26.1 °C	-	SM : 4500-H ⁺ B	6.3	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	271	-

Physical Appearance Sample 25684021 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Information received from customers

Reported by : จันทิพ มิตตะ
Miss. Jantip Mittaka (ว-250-จ-0004)

Laboratory Analyst
23/10/25

Approved by :

สาอวพา นุกาแว
Miss. Saowapa Nukaew (ว-250-ก-0002)

Laboratory Manager
23/10/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	October 14-22, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6810074

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	09.50 AM.
Analysis No.	25684021

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	27.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	158	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	110	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684021 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

Miss. Jantip Mittaka

Laboratory Analyst

23/10/68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

23/10/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์น้ำ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	November 11-18, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6811073

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	11.07 AM.
Analysis No.	25684466

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.6°C	-	SM : 4500-H ⁺ B	6.9	7.2-8.4
2. Total Dissolved Solids	mg/L	SM : 2510	274	-

Physical Appearance Sample 25684466 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Information received from customers

Reported by :

จันทิพ มิตตะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๙/๑๑/๖๘

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๑๙/๑๑/๖๘

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
คณาภิบาลการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	November 11-18, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6811073

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	11.07 AM.
Analysis No.	25684466

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	69.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	175	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	45.0	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684466 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

19/11/68

Approved by :

สาอวพา นุกาแ้ว

Miss. Saowapa Nukaew

Laboratory Manager

19/11/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์ทดสอบ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Our the Experience of Experts

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 9/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[3]	Main Pool	Analyzed Date	December 3-11, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6812015

Sampling Name ^[3]	Swimming Pool Water
Sampling Time ^[3]	10.31 AM.
Analysis No.	25684742

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.1°C	-	SM : 4500-H ⁺ B	7.0	7.2-8.4
2. Total Dissolved Solids	mg/L	SM : 2510	311	-

Physical Appearance Sample 25684742 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
 [2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
 [3] : Information received from customers

Reported by :

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

12, 12, 68

Approved by :

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

12, 12, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 ห้องปฏิบัติการวิเคราะห์เอกชน
 เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 10/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[4]	Main Pool	Analyzed Date	December 3-11, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[4]	Miss. Yonlatda Thancerat	Report No.	PKT6812015

Sampling Name ^[4]	Swimming Pool Water
Sampling Time ^[4]	10.31 AM.
Analysis No.	25684742

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^[3]	mg/L as CaCO ₃	SM : 2320 B	69.0	80-100
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	129	≤ 600
5. Cyanuric Acid ^[3]	mg/L	SM : 4500 - CN-	42.0	30-60
6. Total Coliform Bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684742 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

Miss. Jantip Mittaka

Laboratory Analyst

12, 12, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

12, 12, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	July 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๓-250-๓-0003)	Report No.	PKT6807109

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.49 AM.
Analysis No.	25682826

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.8 °C	-	SM : 4500-H ¹ B	6.9	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	312	≤ 600

Physical Appearance Sample 25682826 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Information received from customers

Reported by :

Miss. Jantip Mittaka (๓-250-๓-0004)

Laboratory Analyst

24/7/25

Approved by :

Miss. Saowapa Nukaew (๓-250-๓-0002)

Laboratory Manager

24/7/25



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกสาร
เลขทะเบียน ๓-250



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	July 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6807109

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.49 AM.
Analysis No.	25682826

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	240	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	106	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682826 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

24, 7, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

24, 7, 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	August 16-23, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6808095

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.48 AM.
Analysis No.	25683202

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1.Total Dissolved Solids	mg/L	SM : 2510	338	≤ 600

Physical Appearance Sample 25683202 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Information received from customers

Reported by :



Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๕/๘/๒๕

Approved by :



Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๕/๘/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	August 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6808095

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.48 AM.
Analysis No.	25683202

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
2. pH at 25.9 °C ^[3]	-	SM : 4500-H ⁺ B	6.5	6.5-8.5
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	200	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	104	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683202 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

25/8/25

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

25/8/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
สำนักงานปฏิบัติการวิเคราะห์

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	September 9-16, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (ว-250-จ-0003)	Report No.	PKT6809078

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	09.51 AM.
Analysis No.	25683562


Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.7°C	-	SM : 4500-H ⁺ B	7.0	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	342	≤ 600

Physical Appearance Sample 25683562 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Information received from customers


Reported by :


Miss. Jantip Mittaka (ว-250-จ-0004)

Laboratory Analyst

17/9/68

Approved by :


Miss. Saowapa Nukaew (ว-250-ก-0002)

Laboratory Manager

17/9/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	September 9-16, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6809078

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	09.51 AM.
Analysis No.	25683562

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	292	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	108	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	0.02	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683562 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

17/9/68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

17/9/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์คุณภาพ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	October 14-22, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6810074

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	09.36 AM.
Analysis No.	25684020

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 26.2°C	-	SM : 4500-H ⁺ B	6.9	6.5-8.5
2. Total Dissolved Solids	mg/L	SM : 2510	338	≤ 600

Physical Appearance Sample 25684020 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Information received from customers

Reported by :

จันทิพ มิตตะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

23/10/๒๕

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒3/10/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	October 14-22, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6810074

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	09.36 AM.
Analysis No.	25684020

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	116	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	115	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684020 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

23, 10, 68

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

23, 10, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
สำนักงานปฏิบัติการมาตรฐานสากล

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	November 11-18, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (จ-250-ก-0003)	Report No.	PKT6811073


Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	11.15 AM.
Analysis No.	25684465

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.6° C	-	SM : 4500-H ⁺ B	7.0	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	338	≤ 600

Physical Appearance Sample 25684465 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK
[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Information received from customers

Reported by :




Miss. Jantip Mittaka (จ-250-ก-0004)

Laboratory Analyst

19/11/25

Approved by :



Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Manager

19/11/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกสาร
เลขทะเบียน จ-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	November 11-18, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6811073

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	11.15 AM.
Analysis No.	25684465

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	184	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	134	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684465 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

19.11.25

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

19.11.25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์แอสเซน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 7/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[3]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	December 3-11, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[3]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6812015

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	10.19 AM.
Analysis No.	25684741

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 24.9°C	-	SM : 4500-H ⁺ B	6.7	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	338	≤ 600

Physical Appearance Sample 25684741 : Clear liquid, colorlss, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Information received from customers

Rreported by :

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

12, 12, 68

Approved by :

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

12, 12, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 8/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	December 3-11, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6812015

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.19 AM.
Analysis No.	25684741

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	180	≤ 300
4. Chloride ^[3]	mg/L	SM : 4500- Cl ⁻ B	110	< 250
5. Iron ^[3]	mg/L	SM : 3500-Fe B	0.02	≤ 0.30
6. Total coliform bacteria ^[3]	MPN/100 mL	SM: 9221 B	< 1.8 ^[5]	Not Detected
7. E.coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684741 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตราก

Miss. Jantip Mittaka

Laboratory Analyst

12, 12, 68

Approved by :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

12, 12, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์แลคซัน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Superior



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[3]	September 8, 2025
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[3]	Cold Water Tank	Analyzed Date	September 9-25, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 26, 2025
Sampling By ^[3]	Miss. Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6809077

Sampling Name ^[3]	Tap Water
Sampling Time ^[3]	09.51 AM.
Analysis No.	25683557

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.8 °C	-	SM : 4500-H ⁺ B	7.2	6.5-8.5

Physical Appearance	Sample 25683557 : Clear, colorless liquid, no sediment	Container Normal : PE 4000 mL,G 1000 mL
REMARK	[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023 [2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011. [3] : Information received from customers	

Rreported by :

จันทิภา มิตตะกา
Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๒๖, ๙, ๖๘

Approved by :

สาอวพา นุกาแ้ว
Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

๒๖, ๙, ๖๘

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 Moo 3 T.Maikhaó A.Thalang Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	September 9-25, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 26, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat (๓-250-๓-0003)	Report No.	PKT6809077

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	09.51 AM.
Analysis No.	25683557

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
2. Residual Chlorine ^[3]	mg/L	SM : 4500-Cl G	Not Detected	> 2.0
3. Turbidity ^[3]	NTU	SM : 2130 B	0.4	≤ 4.0
4. Total Hardness ^[3]	mg/L as CaCO ₃	SM : 2340 C	244	≤ 300
5. Chloride ^[3]	mg/L	SM : 4500-Cl ⁻ B	108	< 250
6. Iron ^[3]	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
7. Color ^[3]	Pt - Co Unit	SM : 2120 B	13.0	≤ 15
8. Manganese ^[3]	mg/L Mn	SM : 3500-Mn B	0.01	≤ 0.3
9. Nitrate ^[3]	mg/L NO ₃ -N	SM : 4500-NO ₃ ⁻ E	14.0	≤ 50.0
10. Sulfate ^[3]	mg/L	SM : 4500-SO ₄ ²⁻ E	17.0	≤ 250
11. Fluoride ^[3]	mg/L F	SM : 4500-F ⁻ D	0.7	≤ 0.7
12. Total Solids ^[3]	mg/L	SM : 2540 B	358	-

Physical Appearance Sample 25683557 : Clear, colorless liquid, no sediment Container Normal : PB 4000 mL, G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

26, 9, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

26, 9, 68

ACCREDITED LABORATORY GLP/DIW 2550



FM-QP-13/01 Rev.02

Date announced for January 02, 2024

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	September 9-25, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 26, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6809077

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	09.51 AM.
Analysis No.	25683557

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
13. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
14. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected
15. Staphylococcus aureus ^[3]	MPN/100 mL	ISO 19250 : 2010	Not Detected	Not Detected
16. Salmonella spp. ^[3]	MPN/100 mL	ISO 19250 : 2011	Not Detected	Not Detected
17. Copper ^[3]	mg/L Cu	SM : 3111 B	Not Detected	≤ 2.0
18. Zinc ^[3]	mg/L Zn	SM : 3111 B	Not Detected	≤ 3.0
19. Aluminum ^[3]	mg/L Al	SM : 3120 B	Not Detected	-
20. Silver ^[3]	mg/L Ag	SM : 3120 B & SM : 3030 F	0.3	-
21. Chromium ^[3]	mg/L Cr	SM : 3111 B	Not Detected	≤ 0.05

Physical Appearance Sample 25683557 : Clear, colorless liquid, no sediment Container Normal : PE 4000 mL, G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

26, 9, 26

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

26, 9, 26

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Cold Water Tank	Analyzed Date	September 9-25, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 26, 2025
Sampling By ^[4]	Miss. Yonlatda Thancerat	Report No.	PKT6809077

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	09.51 AM.
Analysis No.	25683557

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
22. Selenium ^{[3][5]}	mg/L Se	Digestion,Hydride Generation AAS	< 0.0002	≤ 0.01
23. Barium ^{[3][5]}	mg/L Ba	Digestion, Inductively Coupled Plasma	0.06	≤ 0.7
24. Cadmium ^{[3][5]}	mg/L Cd	Digestion, Inductively Coupled Plasma	< 0.003	≤ 0.003
25. Lead ^{[3][5]}	mg/L Pb	Digestion,Hydride Generation AAS	0.005	≤ 0.01
26. Cyanide ^{[3][5]}	mg/L CN ⁻	Distillation and Colorimetric Method	< 0.005	≤ 0.07
27. Alkylbenzene Sulfonates ^{[3][5]}	mg/L MBAS	Anionic Surfactants as MBAS	0.05	-
28. Arsenic ^{[3][5]}	mg/L As	Digestion,Hydride Generation AAS	< 0.0002	≤ 0.01
29. Mercury ^{[3][5]}	mg/L Hg	Digestion,Cold-Vapor AAS	< 0.0005	≤ 0.001
30. Phenols ^{[3][5]}	mg/L	Direct Photometric	< 0.001	-

Physical Appearance Sample 25683557 : Clear, colorless liquid, no sediment Container Normal : PE 4000 mL,G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification, TIS 17025-2017,Testing 0548

[4] : Information received from customers

[5] : Analysis of subcontracting No. 2 -099

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

26, 9, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

26, 9, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

ผลการปฏิบัติการวิเคราะห์เฉพาะ

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

FM-QP-13/01 Rev.02

Date announced for January 02, 2024



BEST CHOICE

CHEMICALS & ENGINEERING CO.,LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[4]	Guest room No.925	Analyzed Date	July 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6807109

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	11.15 AM.
Analysis No.	25682825

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682825 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : According to the water quality standards of the Provincial Waterworks Authority 2024

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

24, 7, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

24, 7, 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[4]	Guest room No134	Analyzed Date	August 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6808095

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	11.12 AM.
Analysis No.	25683201

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683201 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

25/8/25

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

25/8/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 หมู่ 6 ซ.ศกดิлят อ.เมืองภูเก็ต จ.ภูเก็ต 83000



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Guest room No 964	Analyzed Date	September 9-16, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6809078

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.30 AM.
Analysis No.	25683561

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683561 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

17/9/68

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

17/9/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[4]	Guest room No 910	Analyzed Date	October 14-22, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6810074

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.10 AM.
Analysis No.	25684019

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684019 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

23/10/25

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

23/10/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
สำนักงานปฏิบัติการวิเคราะห์

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO.,LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[4]	Guest room No 974	Analyzed Date	November 11-18, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[4]	Miss. Yonlatda Thancerat	Report No.	PKT6811073

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	11.00 AM.
Analysis No.	25684464

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684464 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

Miss. Jantip Mittaka

Laboratory Analyst

19 / 11 / 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

19 / 11 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 6/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[4]	Guest room No 437	Analyzed Date	December 3-11, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6812015

Sampling Name ^[4]	Tap Water
Sampling Time ^[4]	10.46 AM.
Analysis No.	25684740

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total coliform bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	Not Detected
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684740 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : According to the water quality standards of the Provincial Waterworks Authority 2024
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

12, 12, 68

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

12, 12, 65

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

The results of analysis are valid for the submitted sample only.

Date announced for January 02, 2024

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	July 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	July 16, 2025
Sampling Source ^[4]	Ice Machine - Ice Cube	Analyzed Date	July 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	July 24, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6807109

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	11.16 AM.
Analysis No.	25682824

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25682824 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991), Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

24/7/25

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

24/7/25

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	August 15, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	August 16, 2025
Sampling Source ^[4]	Ice Machine - Main Kitchen	Analyzed Date	August 16-23, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	August 25, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6808095

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	11.02 AM.
Analysis No.	25683200

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683200 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพ มิตตะกะ มิตตะกะ ม

Miss. Jantip Mittaka

Laboratory Analyst

25/8/68

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

25/8/68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์คุณภาพ



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	September 8, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[4]	Ice Machine - No.2(big ice) -Block J	Analyzed Date	September 9-16, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	September 17, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6809078

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	10.34 AM.
Analysis No.	25683560

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25683560 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพร มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

17 / 9 / 68

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

17 / 9 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์สภาพ

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

**WATER ANALYSIS REPORT**

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	October 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	October 14, 2025
Sampling Source ^[4]	Ice Machine - Block B	Analyzed Date	October 14-22, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	October 23, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6810074

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	10.06 AM.
Analysis No.	25684018

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684018 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

23, 10, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

23, 10, 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
สำนักงานปฏิบัติการในต่างประเทศ



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	November 10, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	November 11, 2025
Sampling Source ^[4]	Ice Machine - Main Kitchen	Analyzed Date	November 11-18, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	November 19, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6811073

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	11.05 AM.
Analysis No.	25684463

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684463 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023
[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) , Ice Melt.
[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[4] : Information received from customers
[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

19/11/69

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

19/11/69

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.02

Date announced for January 02, 2024

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/10

Customer/Code	Samui Beach Club Owner Limited	Sampling Date ^[4]	December 2, 2025
Customer Address	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[4]	Ice Machine - Rooftop 7	Analyzed Date	December 3-11, 2025
Sampling Method ^[4]	Grab Sampling	Report Date	December 12, 2025
Sampling By ^[4]	Miss. Yonlatda Thaneerat	Report No.	PKT6812015

Sampling Name ^[4]	Ice Melt
Sampling Time ^[4]	10.42 AM.
Analysis No.	25684739

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^[3]	MPN/100 mL	SM : 9221 B	< 1.8 ^[5]	≤ 2.2
2. Escherichia coli ^[3]	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25684739 : Clear liquid, colorless, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 24th Edition 2023

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991), Ice Melt.

[3] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[4] : Information received from customers

[5] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

12, 12, 68

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

12, 12, 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	September 8, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[5]	Main Pool	Analyzed Date	September 9, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 26, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/09/L006

Sampling Name ^[5]	Swimming Pool Water
Sampling Time ^[5]	10.12 AM.
Analysis No.	L6809012

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6809012 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14


[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrsion TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :



Miss. Jantip Mittak

Laboratory Analyst

26 / 9 / 68

Aproved By :



Miss. Saowapa Nukaew

Laboratory Manager

26 / 9 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์และทดสอบ

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written aproral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	September 8, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[5]	Guest Room No.964	Analyzed Date	September 9, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 26, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/09/L006

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.30 AM.
Analysis No.	L6809013

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6809013 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Disases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

Miss. Jantip Mittak

Laboratory Analyst

26 / 9 / 68

Aproved By :

Miss. Saowapa Nukaew

Laboratory Manager

26 / 9 / 68

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์น้ำ

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written apporral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 3/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	September 8, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[5]	Main Kitchen	Analyzed Date	September 9, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 26, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/09/L006


Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.32 AM.
Analysis No.	L6809014

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6809014 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark [1] : Pascualle, W. and McDevitt, D. *Legionella* culture. In Garcia, L.S. (ed.) *Clinical Microbiology Procedures Handbook*, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14
[2] : DourmonE, *Isolation Of Legionella from Clinical specimens.* In Harrision TG and AG Taylor (ed.) *A Laboratory Manual for Legionella*. John Wiley and Sons Ltd., London. 1988 : 13-30.
[3] : Centers for Diseases Control and Prevention. 2005. *Procedures for the Recovery of Legionella from the Environment*. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.
[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University
[5] : Information received from customers

Reported By :



Miss. Jantip Mittak

Laboratory Analyst

26 / 9 / 68

Aproved By :



Miss. Saowapa Nukaew

Laboratory Manager

26 / 9 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
เพื่อปฏิบัติภารกิจด้านเคมี

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 4/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	September 8, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[5]	Raw Water Tank	Analyzed Date	September 9, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 26, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/09/L006

Sampling Name ^[5]	Raw Water
Sampling Time ^[5]	09.56 AM.
Analysis No.	L6809015

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6809015 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :



Miss. Jantip Mittak

Laboratory Analyst

26 / 9 / 68

Aproved By :



Miss. Saowapa Nukaew

Laboratory Manager

26 / 9 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
สำนักงานปฏิบัติการวิเคราะห์

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 5/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	September 8, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	September 9, 2025
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	September 9, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	September 26, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/09/L006

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	09.51 AM.
Analysis No.	L6809016

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6809016 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W and McDewitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

Miss. Jantip Mittak

Laboratory Analyst

26/9/25

Aproved By :

Miss. Saowapa Nukaew

Laboratory Manager

26/9/25



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written apporral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	December 2, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[5]	Main Pool	Analyzed Date	December 3, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 18, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/12/L001

Sampling Name ^[5]	Swimming Pool Water
Sampling Time ^[5]	10.31 AM.
Analysis No.	L6812001

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6812001 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :




Miss. Jantip Mittak

Laboratory Analyst

18 / 12 / 68

Aproved By :



Miss. Saowapa Nukaew

Laboratory Manager

18 / 12 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	December 2, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[5]	Guest Room No.942	Analyzed Date	December 3, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 18, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/12/L001

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.55 AM.
Analysis No.	L6812002

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6812002 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14


[2] : DourmonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :



Miss. Jantip Mittak

Laboratory Analyst

18 / 12 / 68

Approved By :



Miss. Saowapa Nukaew

Laboratory Manager

18 / 12 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 3/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	December 2, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[5]	Main Kitchen	Analyzed Date	December 3, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 18, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/12/L001

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	11.08 AM.
Analysis No.	L6812003

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6812003 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

Miss. Jantip Mittak

Laboratory Analyst

18, 12, 68

Aproved By :

Miss. Saowapa Nukaew

Laboratory Manager

18, 12, 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written apporral.

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 4/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	December 2, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[5]	Raw Water Tank	Analyzed Date	December 3, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 18, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/12/L001

Sampling Name ^[5]	Raw Water
Sampling Time ^[5]	10.15 AM.
Analysis No.	L6812004

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6812004 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. Legionella culture. In Garcia, L.S. (ed.) Clinical Microbiology Procedures Handbook, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, Isolation Of Legionella from Clinical specimens,. In Harrision TG and AG Taylor (ed.) A Laboratory Manual for Legionella. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Disceases Control and Prevention. 2005. Procedures for the Recovery of Legionella from the Environment. Centers for Disceases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

Miss. Jantip Mittak

Laboratory Analyst

18/12/65

Aproved By :

Miss. Saowapa Nukaew

Laboratory Manager

18/12/65



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approral.



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 5/5

Customer/Code ^[5]	6S-071/1 Samui Beach Club Owner Limited	Sampling Date ^[5]	December 2, 2025
Customer Address ^[5]	239-239/1 M.3 T.Maikhao A.Thalang, Phuket 83110	Receiving Date	December 3, 2025
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	December 3, 2025
Sampling Method ^[3]	Grab Sampling	Report Date	December 18, 2025
Sampling By	Miss Yonlatda Thaneerat	Report No.	PKT68/12/L001

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.31 AM.
Analysis No.	L6812005

Parameter	Unit	Method of Analysis ^{[1][2][3]}	Result
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected ^[4]

Physical Appearance Sample L6812005 : Clear, colorless liquid, no sediment Container : Normal G 1.0 L

Remark

[1] : Pasculle, W.and McDevitt, D. *Legionella* culture. In Garcia, L.S. (ed.) *Clinical Microbiology Procedures Handbook*, Third edition and 2007 update. ASM Press. Washington DC. 2010.3.11.4.1-13.6.14

[2] : DournonE, *Isolation Of Legionella from Clinical specimens.*, In Harrision TG and AG Taylor (ed.) *A Laboratory Manual for Legionella*. John Wiley and Sons Ltd., London. 1988 : 13-30.

[3] : Centers for Diseases Control and Prevention. 2005. *Procedures for the Recovery of Legionella from the Environment*. Centers for Diseases Control and Prevention, U.S. Department of Health and Human Services, Atlanta.

[4] : Use subcontracting services from the Product Standards Testing Center. Phuket Rajabhat University

[5] : Information received from customers

Reported By :

Miss. Jantip Mittak

Laboratory Analyst

18 / 12 / 68

Aproved By :

Miss. Saowapa Nukaew

Laboratory Manager

18 / 12 / 68



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
หลังปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.